



SCHEMATIC DIAGRAM

TO SET ALTERNATION TIME

SELECT TIME AT WHICH YOU WISH THE COMPRESSORS TO ALTERNATE.  
PUSH ONE PIN OUT. IF YOU WISH FOR MULTIPLE ALTERNATIONS  
DURING A 24 HOUR PERIOD, MOVE ONE PIN OUT AT THE DESIRED TIMES.  
IF NO ALTERNATION IS DESIRED, PUSH ALL PINS IN.

	Drawing Title					
	COMBINATION BLOWER & PUMP					
	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
DATE 8/28/03	S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	<hr/> <hr/> <hr/> <b>COX</b> <hr/> <hr/>			PURCHASE ORDER NUMBER	
	CADDY PARISH FIRE STATION #5	Research and Technology, Inc.			DRAWING NUMBER	CP-1414/R1
					SHEET NUMBER	1