



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

| | |
|------|-----------------|
| NP-1 | PUMP 1 |
| NP-2 | PUMP 2 |
| NP-3 | RUN |
| NP-4 | RUN |
| NP-5 | HOA |
| NP-6 | HOA |
| NP-7 | HIGH TEMP |
| NP-8 | HIGH TEMP |
| NP-9 | HIGH TEMP RESET |

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

| | | | | | | | | |
|------------------|---|---|-------------------------------|---|---|--|------------|--|
| | Drawing Title ENCLOSURE | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| DATE 12/08/05 | | REFERENCE DRAWING S/N | NO. Sales Engineer C.C. | REVISION-LOCATION Application Engineer R.C. | ECN DRAWN BY C. RACHAL | DATE APPROVED BY | BY DATE | |
| | Project Title DUPLEX PUMP CONTROL PANEL | <div>COX</div> <div>Research and Technology, Inc.</div> | | | P.O. Box 77808 Baton Rouge, LA 70809 Ph (225) 756-3271 | PURCHASE ORDER NUMBER DRAWING NUMBER CP-2220 | | |