
COX

Research and Technology, Inc.

DUPLEX BLOWER
CONTROL PANEL
WARREN DAVIE

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2146

VOLTAGE	<u>120/240V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>1/60</u>	
NO. MOTORS	<u>2</u>	
HP	<u>5</u>	
FLA	<u>28</u>	
TYPE OF PUMP	<u>Blower</u>	(Self-Priming, Submersible)
MANUFACTURER	<u></u>	
CATALOG NUMBER	<u></u>	
CONTROL VOLTAGE	<u>120V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 4X</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Fiberglass</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u></u>	(Floats, Bubbler, Other)
CAPACITORS	<u></u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u></u>	
THERM. & SEAL FAIL WIRING FIGURE	<u></u>	


OPTIONS:


SEAL FAIL LIGHTS	<u></u>	(Submersible Only)
SEAL FAIL RELAYS	<u></u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u></u>	(Submersible Only)
HT PUMP SHUTDOWN	<u></u>	(Self-Primer, Submersible)
ALARM HORN	<u></u>	
ALARM LIGHT	<u></u>	
LIGHT PANEL MTD	<u></u>	
LIGHT REMOTE MTD	<u></u>	
LIGHT FLASHER	<u></u>	
LIGHTNING ARRESTER	<u></u>	
ELAPSED TIME METER	<u></u>	
PHASE MONITOR	<u></u>	
NEMA RATED STARTERS	<u></u>	
GROUND FAULT RECPT.	<u></u>	
GREEN RUN LIGHTS VS. RED	<u></u>	
POLE, BOX, SEAL	<u></u>	
INTRINSICALLY SAFE RELAYS	<u></u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u></u>	
ECONOMY VERSION	<u></u>	

SOLD TO: Delta Process, Inc. -New Orleans, LA


TAG : Warren Davie

SHIP TO: Delta Process, Inc. - Denham Springs, LA

	Drawing Title							
	PANEL DESCRIPTION							
DATE 8/10/05			REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title		<div style="text-align: center;">  COX Research and Technology, Inc. </div>			PURCHASE ORDER NUMBER		
	DUPLUX BLOWER CONTROL PANEL					DRAWING NUMBER CP-2146		
						SHEET NUMBER 1		



	Drawing Title								
	POWER DIAGRAM								
DATE 8/10/05		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED			
	Project Title					PURCHASE ORDER NUMBER			
	DUPLEX BLOWER CONTROL PANEL					DRAWING NUMBER CP-2146			
						SHEET NUMBER			2



PANEL IS DESIGNED TO RUN BLOWERS WITH A MINIMUM OF 15 MINUTES OF OFF TIME BETWEEN ALTERNATION. PINS PUSHED OUT ON CLOCK INDICATE RUN TIME. PINS PUSHED IN INDICATE OFF TIME. EACH PIN IS EQUAL TO 15 MINUTES.

IF NO OFF TIME IS REQUIRED BETWEEN ALTERNATION, REMOVE JUMPER FROM TERMINALS ⑤ AND ⑥. PLACE JUMPER ACROSS TERMINALS ⑦ AND ⑧. NOW BLOWERS WILL RUN CONTINUOUSLY. SET 1 PIN IN AT THE TIME YOU WISH THE BLOWERS TO ALTERNATE. ALL REMAINING PINS SHOULD BE PUSHED OUT.

* REMOVE JUMPERS AND INSTALL LOCKOUT DEVICES IF REQUIRED



	Drawing Title CONTROL DIAGRAM							
DATE 8/10/05			REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY DATE
	Project Title DUPLEX BLOWER CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER
DRAWING NUMBER CP-2146								
SHEET NUMBER								
						3		

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809


Ph. (225)756-3271
Fax (225)755-1030



REMOVE JUMPERS & INSTALL
LOCKOUT DEVICES IF REQUIRED

IF NO OFF TIME IS REQUIRED BETWEEN
ALTERNATION, REMOVE JUMPER FROM
TERMINALS ⑤ AND ⑥. PLACE JUMPER ACROSS
TERMINALS ⑦ AND ⑧. NOW BLOWERS WILL RUN
CONTINUOUSLY. SET 1 PIN IN AT THE TIME YOU
WISH THE BLOWERS TO ALTERNATE.
ALL REMAINING PINS SHOULD BE PUSHED OUT.

	Drawing Title							
	EXTERNAL CONNECTIONS							
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
8/10/05		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED		
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2146		
						SHEET NUMBER 4		



VIEW OF FRONT OF ENCLOSURE

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	BLOWER 1
NP-2	BLOWER 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

	Drawing Title							
	ENCLOSURE							
DATE 8/10/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY DATE	
	Project Title	COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER		
	DUPLEX BLOWER CONTROL PANEL					DRAWING NUMBER CP-2146		
						SHEET NUMBER 5		

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1614HPL	ENCLOSURE
2	1	STAHLIN	BP1614AL	BACKPLATE
3	2	ABB	A30-30-10-84	STARTER
4	2	ABB	TA25DU32	O.L. (24-32A)
5	2	SQUARE D	QOU260	CIRCUIT BREAKER 1,2
6	1	MARATHON	1323580	DISTRIBUTION BLOCK
7	2	ACI	JR22P3M20B	H.O.A. SWITCH
8	2	ACI	JR22FR	RED PILOT LIGHTS
9	1	TIMEMARK	261DT120	ALTERNATING RELAY
10	1	GRASSLIN	FM1/STUZZL	TIMER
11	1	ABB	OT100E3	MAIN DISCONNECT
12				

	Drawing Title						
	<h3 style="margin: 0;">BILL OF MATERIALS</h3>						
DATE 8/10/05		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> <h2 style="margin: 0;">COX</h2> <p style="margin: 0;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER <div style="text-align: right;">CP-2146</div> SHEET NUMBER <div style="text-align: right;">6</div>
	DUPLEX BLOWER CONTROL PANEL						