
COX

Research and Technology, Inc.

ROSEDALE UNIT #9
DUPLEX PUMP
CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2344

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	7.5	
FLA	39	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	BARNES	
CATALOG NUMBER	4SE7524L	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	YES	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:


SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS	X	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		

SOLD TO: Delta Process - Bossier City, LA


TAG : ROSEDALE UNIT#9

SHIP TO: Delta Process - Ruston, LA


	Drawing Title							
	PANEL DESCRIPTION							
DATE 3/29/06			REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
	DUPLIX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2344	
							SHEET NUMBER 1	




	Drawing Title
--	---



Drawing Title							
CONTROL DIAGRAM							
DATE	3/29/06	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED
			C.C.	R.C.	BY C. RACHAL		DATE
Project Title					PURCHASE ORDER NUMBER		
DUPLIX PUMP CONTROL PANEL					DRAWING NUMBER CP-2344		
					SHEET NUMBER 3		



	Drawing Title						
	CONTROL DIAGRAM						
DATE 3/29/06		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED	
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2344	
						SHEET NUMBER	4




NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL
NP-9	HIGH TEMP
NP-10	HIGH TEMP

VIEW OF SWING OUT PANEL



Drawing Title									
ENCLOSURE									
DATE	3/29/06	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
		S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED		
			C.C.	R.C.	BY C. RACHAL		BY	DATE	
Project Title					P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER		
DUPLEX PUMP CONTROL PANEL		<div>COX</div> <div>Research and Technology, Inc.</div>			Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2344		
							SHEET NUMBER 5		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	ALLIED	AM30240RL	ENCLOSURE
1a	1	ALLIED	P3024A	BACKPLATE
2	1	ABB	OT100E3	MAIN DISC. SWITCH
3	2	C-H	CE15HNS3AB	MOTOR STARTER
4	6	C-H	C316KNA3C	HEATER PACK
5	2	SQUARE D	QOU280	CB1, CB2
6	3	SQUARE D	QOU115	CB4, CB5, CB6
7	1	TIMEMARK	261DT120	ALTERNATING RELAY
8	4	ACI	JR22FR	RED PILOT LIGHT
9	2	ACI	JR22P3M20B	HOA SWITCH
10	1	TOMAR	490S-120	ALARM LIGHT
11	1	MARATHON	1323580	DISTRIBUTION BLOCK
12	2	REDINGTON	711-0190	ELAPSED TIME METER
13	2	SSAC	LLC54AA	SEAL FAIL RELAY
14	1	DELTA	LA302R	LIGHTNING ARRESTER
15	1	STOCK		GFI
16	2	GE	6X555	START RELAY
17	2	GE	3GA14	RUN CAPACITOR 60 μ^f
18	2	MALLORY	4X661	START CAPACITOR 233-280 μ^f
19	1	SQUARE D	QOU110	CB3
20	1	DAYTON	2A561	TIME DELAY RELAY
21	2	ACI	JR22FY	AMBER PILOT LIGHT
22	3	IDEC	RU2SAC120	CR1,2,3
23	2	IDEC	RU4SAC120	CR4,5
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 3/29/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2344 SHEET NUMBER 6
	DUPLEX PUMP CONTROL PANEL						