
COX

Research and Technology, Inc.

DUPLEX SELF PRIMING PUMP
CONTROL PANEL
LAKE PROVIDENCE, LA

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-1605

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	15	
FLA	42	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 3R	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Painted Steel	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE		
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS	X SQUARE D	
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET	X	
ECONOMY VERSION		
SWING INTERNAL DOOR	X	

SOLD TO:	Delta Process - Ruston, LA
TAG :	Duplex S.P. Pump Control Panel
	Lake Providence, LA

SHIP TO:	Delta Process - Ruston, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 7/21/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030	PURCHASE ORDER NUMBER	
	DUPLEX S.P. PUMP CONTROL PANEL					DRAWING NUMBER CP-1605	
						SHEET NUMBER 1	




	Drawing Title								
	POWER DIAGRAM								
DATE 7/21/03		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED			
	Project Title							PURCHASE ORDER NUMBER	
	DUPLEX S.P. PUMP CONTROL PANEL							DRAWING NUMBER CP-1605	
								SHEET NUMBER	2

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)756-1030



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	PUSH TO RESET

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

DATE 7/21/03	Drawing Title ENCLOSURE		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
			S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED		
						BY	C. RACHAL	BY	DATE	
			Project Title						PURCHASE ORDER NUMBER	
	DUPLEX S.P. PUMP CONTROL PANEL		COX Research and Technology, Inc.		P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1605 SHEET NUMBER			
									4	

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	EBE	302410REPL	ENCLOSURE
1a	1	EBE	A3024P	BACKPLATE
1b	1	EBE	A3024SP	DEAD FRONT
2	1	ABB	S3B225DW	MOLDED CASE SWITCH
3	2	SQUARE D	8536SD01V02	MOTOR STARTER NEMA SZ 2
4	2	SQUARE D	B88.0	O.L. HEATERS
5	2	SQUARE D	QOU380	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	1	AC/DC	BL5-R-120	ALARM LIGHT
9	1	C-H	CHSA03	LIGHTNING ARRESTER
10	2	GRASSLIN	UWZ52E	ELAPSED TIME METER
11	1	SSAC	PLMU11	PHASE MONITOR
12	2	ACI	JR22P3M20B	HOA SWITCH
13	2	ACI	JR22FY	AMBER PILOT LIGHT
14	1	MARATHON	1323580	DISTRIBUTION BLOCK
15	1	ABB	OHB65L10	HANDLE
16	1	ABB	OX10X225	SHAFT
17	1	ACI	JR22AN11B	PB
18	2	MAGNACRAFT	W388AMLCPX-9	LATCHING RELAY
19	1	ABB	K5VD-M	MECHANISM
20				

	Drawing Title						
	BILL OF MATERIALS						
DATE 7/21/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 150px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1605 SHEET NUMBER 5
	DUPLEX S.P. PUMP CONTROL PANEL						