

COX

Research and Technology, Inc.


AMERICAN SPRINKLER
DONALDSONVILLE SCHOOL
CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2314



NEMA 4X FIBERGLASS ENCLOSURE



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1 MANUAL FILL-OFF-AUTO FILL

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

	Drawing Title							
	ENCLOSURE							
DATE 2/17/06		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE
		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED	
	Project Title				BY C. RACHAL		BY	DATE
	CONTROL PANEL	<div><div></div><div>COX</div><div>Research and Technology, Inc.</div><div></div></div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
					Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2314	
							SHEET NUMBER 3	

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1614HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1614AL	BACKPLATE
2	2	MOORE	330R	LEVEL CONTROLLERS
3	1	ACI	JR22FR	RED PILOT LIGHT
4	1	ACI	JR22P3M20B	HOA SWITCH
5	1	SQUARE D	QOU120	CB1
6	1	MARATHON	1321570	NEUTRAL BLOCK
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 2/21/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2315 SHEET NUMBER
	CONTROL PANEL						4