
COX

Research and Technology, Inc.

DUPLEX PUMP CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2243

VOLTAGE	<u>277/480V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>3/60</u>	
NO. MOTORS	<u>2</u>	
HP	<u>10</u>	
FLA	<u>14</u>	
TYPE OF PUMP	<u>Self-Priming</u>	(Self-Priming, Submersible)
MANUFACTURER	<u>G-R</u>	
CATALOG NUMBER	<u>-</u>	
CONTROL VOLTAGE	<u>120V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 4X</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Fiberglass</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u>Floats</u>	(Floats, Bubbler, Other)
CAPACITORS	<u>No</u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u>N/A</u>	
THERM. & SEAL FAIL WIRING FIGURE	<u> </u>	

OPTIONS:


SEAL FAIL LIGHTS	<u> </u>	(Submersible Only)
SEAL FAIL RELAYS	<u> </u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u> </u>	(Submersible Only)
HT PUMP SHUTDOWN	<u>X</u>	(Self-Primer, Submersible)
ALARM HORN	<u> </u>	
ALARM LIGHT	<u>X</u>	
LIGHT PANEL MTD	<u>X</u>	
LIGHT REMOTE MTD	<u> </u>	
LIGHT FLASHER	<u> </u>	
LIGHTNING ARRESTER	<u> </u>	
ELAPSED TIME METER	<u>X</u>	
PHASE MONITOR	<u>X</u>	
NEMA RATED STARTERS	<u>X ABB</u>	
GROUND FAULT RECPT.	<u> </u>	
GREEN RUN LIGHTS VS. RED	<u> </u>	
POLE, BOX, SEAL	<u> </u>	
INTRINSICALLY SAFE RELAYS	<u> </u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u>X</u>	
ECONOMY VERSION	<u> </u>	

SOLD TO: COASTAL PROCESS, LLC


TAG :

SHIP TO:


	Drawing Title						
	PANEL DESCRIPTION						
DATE 12/20/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLIX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2243
							SHEET NUMBER 1



	Drawing Title							
	POWER DIAGRAM							
DATE 12/20/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2243	
							SHEET NUMBER 2	



	Drawing Title CONTROL DIAGRAM							
DATE 12/20/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN DRAWN BY C. RACHAL	DATE APPROVED BY	BY DATE	
	Project Title DUPLEX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER	
							DRAWING NUMBER CP-2243	
							SHEET NUMBER 3	



VIEW OF FRONT OF ENCLOSURE

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	HIGH TEMP RESET

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

DATE 12/20/05	Drawing Title								
	ENCLOSURE								
	Project Title								
	DUPLEX PUMP CONTROL PANEL								
		REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE
		S/N		Sales Engineer		Application Engineer		DRAWN	
				C.C.		R.C.		BY C. RACHAL	
								APPROVED	
								BY	DATE
								PURCHASE ORDER NUMBER	
								DRAWING NUMBER	
								CP-2243	
								SHEET NUMBER	
								4	

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPL	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	2	ABB	A26N1-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU19	O.L. RELAY (13-19A)
4	2	ABB	T1NO30TL	CIRCUIT BREAKER
5	2	ACI	JR22FR	RED PILOT LIGHT
6	2	ACI	JR22P3M20B	HOA SWITCH
7	1	ABB	OT63E3	DISCONNECT SWITCH
8	1	ABB	T4150PSF-1	TRANSFORMER
9	1	SSAC	PLMU-11	PHASE MONITOR
10	1	MARATHON	1323580	DISTRIBUTION BLOCK
11	2	ACI	JR22FY	AMBER PILOT LIGHT
12	1	ACI	JR22AN11B	PUSH BUTTON
13	2	MAGNECRAFT	W388AMLCPX-9	LATCHING RELAYS
14	1	TIMEMARK	261DT120	ALTERNATING RELAY
15	1	AC/DC	BL5-R-120	ALARM LIGHT
16	2	REDINGTON	711-0190	ELAPSED TIME METER
17				
18				
19				
20				
21				
22				
23				
24				
25				

[illegible]