



VIEW OF SWING OUT PANEL

NOTE:

SEWER GASES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASES.

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

Drawing Title	ENCLOSURE						
		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
S/N	Sales Engineer	Application Engineer	DRAWN		APPROVED		
	C.C.	R.C.	BY C. RACHAL	BY	DATE		
Project Title	DUPLEX PUMP CONTROL PANEL	COX	Research and Technology, Inc.	P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
				Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER	CP-2171	
					SHEET NUMBER		
							4