
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
LIFT STATION #3

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2240

VOLTAGE	277/480V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	40	
FLA	52	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	G-R	
CATALOG NUMBER	-	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 3R	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Painted Steel	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:


SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT		
LIGHT PANEL MTD		
LIGHT REMOTE MTD	X	
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS	X	
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET	X	
ECONOMY VERSION		

SOLD TO: Delta Process - Ruston, LA


TAG : Lift Station #3

SHIP TO: Delta Process - Ruston, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 12/09/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL				DRAWING NUMBER CP-2240		
					SHEET NUMBER 1		




	Drawing Title								
	POWER DIAGRAM								
DATE 12/09/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY	APPROVED
	Project Title	COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-2240			
						SHEET NUMBER 2			



* REMOVE JUMPERS AND INSTALL LOCKOUT DEVICES IF REQUIRED

Drawing Title							
CONTROL DIAGRAM							
DATE 12/09/05		REFERENCE DRAWING		NO.		REVISION-LOCATION	
Project Title		S/N		Sales Engineer C.C.		Application Engineer R.C.	
DUPLIX PUMP CONTROL PANEL				DRAWN BY C. RACHAL		APPROVED BY DATE	
				P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2240	
						SHEET NUMBER 3	



VIEW OF SWING OUT PANEL

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	HIGH TEMP RESET

DATE 12/09/05	Drawing Title							
	ENCLOSURE							
	Project Title							
	DUPLEX PUMP CONTROL PANEL					P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER	
						Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2240	
							SHEET NUMBER 4	

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	C & I	C-242010RHPL	ENCLOSURE
1a	1	C & I	CI-24P20	BACKPLATE
1b	1	C & I	CI-2420SPA	DEAD FRONT
2	2	ABB	A75N3-30-11-84	MOTOR STARTER
3	2	ABB	TA75DU63	O.L. RELAY (45-63A)
4	2	ABB	T1N080TL	CB2, CB3
5	2	ACI	JR22FR	RED PILOT LIGHT
6	2	ACI	JR22P3M20B	HOA SWITCH
7	1	ABB	S3H225DW	CB1
8	1	ABB	T4150PSF1	TRANSFORMER
9	1	SSAC	PLMU-11	PHASE MONITOR
10	1	MARATHON	1323580	DISTRIBUTION BLOCK
11	2	ACI	JR22FY	AMBER PILOT LIGHT
12	1	ACI	JR22AN11B	PUSH BUTTON
13	2	MAGNECRAFT	W388AMLCPX-9	LATCHING RELAYS
14	1	TIMEMARK	261DT120	ALTERNATING RELAY
15	1	DELTA	CA603R	SURGE CAPACITOR
16	1	SQUARE D	QOU110	CB4
17	1	DELTA	LA603	LIGHTNING ARRESTER
18	2	REDINGTON	711-0190	ELAPSED TIME METER
19	1	DAYTON	4BA54	HEATER
20	1	SAGINAW	SCE-TEMNC	THERMOSTAT
21	1	ABB	K5VDM	MECHANICAL OPERATOR
22	1	ABB	OX10X225	SHAFT
23	1	ABB	OHB65J10	HANDLE
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 12/09/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 100px;"> COX <small>Research and Technology, Inc.</small> </div>			<small>P.O. Box 77808 Baton Rouge, LA 70809</small> <small>Ph. (225)756-3271 Fax (225)755-1030</small>		<small>PURCHASE ORDER NUMBER</small> <small>DRAWING NUMBER</small> <div style="text-align: right;">CP-2240</div> <small>SHEET NUMBER</small> <div style="text-align: right;">5</div>
	DUPLEX PUMP CONTROL PANEL						