

---

---

# COX

Research and Technology, Inc.

---

---

LEON LOWE  
SAW MILL CREEK  
DUPLEX PUMP  
CONTROL PANEL

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

CP-1750


VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	2.7	
FLA	11.9	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	Gorman Rupp	
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	Yes	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	X	(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER	X	
LIGHTNING ARRESTER	X	
ELAPSED TIME METER		
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		

SOLD TO: Delta Process - New Orleans, LA  
TAG : LEON LOWE  
SAW MILL CREEK

SHIP TO: Delta Process - Denham Springs, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 12/03/07		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY COREYC	ECN	DATE
	Project Title	<div style="text-align: center;">   Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1750
							SHEET NUMBER 1



	Drawing Title						
	POWER DIAGRAM						
DATE 12/03/07		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
	Project Title	S/N	Sales Engineer C.C.	Application Engineer R.C.	BY COREYC	APPROVED	
	DUPLEX PUMP CONTROL PANEL					PURCHASE ORDER NUMBER	
						DRAWING NUMBER CP-1750	
						SHEET NUMBER	2


**COX**

Research and Technology, Inc.

P.O. Box 77808  
Baton Rouge, LA  
70809

Ph. (225)756-3271  
Fax (225)756-1030





VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

**NOTE:**  
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASSES.

NP-1 PUMP 1  
NP-2 PUMP 2  
NP-3 RUN  
NP-4 RUN  
NP-5 HOA  
NP-6 HOA

DATE 12/03/07	Drawing Title								
	ENCLOSURE								
	Project Title		REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE
	DUPLEX PUMP CONTROL PANEL		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		BY	DATE
						BY COREYC		BY	DATE
								PURCHASE ORDER NUMBER	
								DRAWING NUMBER	
								CP-1750	
								SHEET NUMBER	
								4	

# BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	VYNCKIER	VJ1816HWPLDF	ENCLOSURE
1a	1	VYNCKIER	MP1816A	BACKPLATE
2	1	ABB	OT63E3	MAIN DISC. SWITCH
3	2	ABB	A16-30-10-84	MOTOR STARTER
4	2	ABB	TA25DU14	O.L. RELAY (10-14A)
5	2	SQUARE D	QOU225	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	AC/DC	BL5-R-120-TF	ALARM LIGHT
10	1	DELTA	LA302R	LIGHTNING ARRESTER
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>						
DATE 12/03/07		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY COREYC	ECN	DATE
	Project Title	<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 150px;"> <h1 style="margin: 0;">COX</h1> <p style="margin: 0; font-size: small;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER CP-1750 SHEET NUMBER 5
	DUPLEX PUMP CONTROL PANEL						