

---

---

# COX

Research and Technology, Inc.

---

---

SPRINGHILL #9  
DUPLEX PUMP  
CONTROL PANEL

Cox Research and Technology, Inc.  
14697 S. Harrells Ferry Road  
Baton Rouge, LA. 70816  
(225) 756-3271 Fax (225) 755-1030

CP-2124

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	10	
FLA	26	
TYPE OF PUMP	Self-Priming	(Self-Priming, Submersible)
MANUFACTURER	GR	
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		

OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR	X	
NEMA RATED STARTERS		
GROUND FAULT RECPT.	X	
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET	X	
ECONOMY VERSION		

SOLD TO: Delta Process - Bossier City, LA


TAG : SPRINGHILL #9


\_\_\_\_\_

SHIP TO: Delta Process - Ruston, LA


\_\_\_\_\_

\_\_\_\_\_

	Drawing Title						
	PANEL DESCRIPTION						
DATE 8/04/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;">   <b>COX</b>            Research and Technology, Inc.         </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER CP-2124
							SHEET NUMBER 1







**NOTE:**  
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.  
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE  
PANEL TO PREVENT ENTRY OF GASSES.

# NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	HIGH TEMP
NP-8	HIGH TEMP
NP-9	HIGH TEMP RESET

Drawing Title	ENCLOSURE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
DATE	8/03/05	Sales Engineer	C.C.	Application Engineer	R.C.	BY	C. RACHAL	APPROVED
Project Title	DUPLEX PUMP CONTROL PANEL		COX		P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER	
		Research and Technology, Inc.		Ph. (225)756-3271 Fax (225)755-1030		DRAWING NUMBER		CP-2124
						SHEET NUMBER		4

## BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	2	ABB	A40-30-10-84	MOTOR STARTER
3	2	ABB	TA42DU32	O.L. RELAY (22-32A)
4	2	SQUARE D	QOU350	CB1, CB2
5	1	TIMEMARK	261DT120	ALTERNATING RELAY
6	2	ACI	JR22FR	RED PILOT LIGHT
7	2	ACI	JR22P3M20B	HOA SWITCH
8	1	DELTA	LA603	LIGHTNING ARRESTER
9	1	ABB	OT63E3	DISCONNECT SWITCH
10	1	SSAC	PLMU-11	PHASE MONITOR
11	2	REDINGTON	711-0190	ELAPSED TIME METER
12	2	ACI	JR22FY	AMBER PILOT LIGHT
13	1	MARATHON	1323580	DISTRIBUTION BLOCK
14	1	MARATHON	1321570	NEUTRAL BLOCK
15	1	SQUARE D	QOU115	CB3
16	1	STOCK		GFI RECEPTACLE
17	1	AC/DC	BL5-R-120	ALARM LIGHT
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 8/03/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> <b>COX</b>  Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809  Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER  DRAWING NUMBER CP-2124 SHEET NUMBER 5
	DUPLEX PUMP CONTROL PANEL						