


SOURCE TO EQUIPMENT



NOTE:

CONTACTOR NOT NEEDED FOR LASER COOLER & FLANGE MACHINE
EXT. LIGHT TO BE INSTALLED UP HIGH NEAR HOIST CONNECT TO CR1

* VERIFY INCOMING VOLTAGE BEFORE APPLYING POWER TO CONTROL PANEL.
TRANSFORMER WIRED FOR 480V PRIMARY.

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030
CP2114