
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
LOYOLA

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2258

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	2	
FLA	12	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	Myers	
CATALOG NUMBER	WG 20-21	

CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	Yes	(Yes, No)
CAPACITOR WIRING FIGURE	M	
THERM. & SEAL FAIL WIRING FIGURE	1, 6, 8	


OPTIONS:


SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER		
ELAPSED TIME METER		
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION	X	

SOLD TO: Delta Environmental - Denham Springs, LA
TAG : LOYOLA

SHIP TO: Delta Environmental - Denham Springs, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE 1/12/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	BY C. RACHAL	ECN	DATE BY
	Project Title	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-2258	
						SHEET NUMBER 1	






NOTE 1: INSTALL A JUMPER WIRE BETWEEN THESE TERMINALS
IF PUMP IS SUPPLIED WITHOUT EXTERNAL THERMAL WIRES

NOTE 2: NOT SUPPLIED ON ALL PUMPS

* DIVERSIFIED ALTERNATOR

** FOR 3 FLOAT SETUP, LAG FLOAT WILL ACT AS HIGH LEVEL ALSO.
IF 4 FLOATS ARE REQUIRED, REMOVE JUMPER AND USE SEPARATE FLOATS.

DATE 1/12/06	Drawing Title							
	CONTROL DIAGRAM		1		ADDED NOTE 1 & 2		1/27/06	RC
	REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE
	S/N		Sales Engineer C.C.		Application Engineer R.C.		BY C. RACHAL	
Project Title								PURCHASE ORDER NUMBER
DUPLIX PUMP CONTROL PANEL								DRAWING NUMBER CP-2258
								SHEET NUMBER 3



VIEW OF FRONT OF ENCLOSURE

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL

NOTE:

SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

	Drawing Title							
	ENCLOSURE							
DATE 1/12/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
	Project Title				P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			Ph. (225)756-3271 Fax (225)755-1030	DRAWING NUMBER CP-2258		
						SHEET NUMBER 4		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1614HPL	ENCLOSURE
1a	1	STAHLIN	BP1614	BACKPLATE
2	2	ABB	A16-30-10-84	MOTOR STARTER
3	2	ABB	TA25DU14	O.L. RELAY (10-14A)
4	2	SQUARE D	QOU230	CB1, CB2
5	1	DIVERSIFIED	ARB-120-ADA	ALTERNATING RELAY
6	4	LAVATO	MONOBLOCK	RED PILOT LIGHT
7	2	ACI	JR22P3M20B	HOA SWITCH
8	1	INGRAM	MX-15	ALARM LIGHT
9	1	MARATHON	1323580	DISTRIBUTION BLOCK
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 1/12/06		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2258 SHEET NUMBER 5
	DUPLEX PUMP CONTROL PANEL						