
COX

Research and Technology, Inc.

IRRIGATION MART

SIMPLEX PUMP
CONTROL PANEL

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-1920

VOLTAGE	<u>277/480V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>3/60</u>	
NO. MOTORS	<u>2</u>	
HP	<u>25</u>	
FLA	<u>34</u>	
TYPE OF PUMP	<u>Above Ground</u>	(Self-Priming, Submersible)
MANUFACTURER	<u></u>	
CATALOG NUMBER	<u></u>	
CONTROL VOLTAGE	<u>120V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 3R</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Painted Steel</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u>Start Stop PB</u>	(Floats, Bubbler, Other)
CAPACITORS	<u>No</u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u>N/A</u>	
THERM. & SEAL FAIL WIRING FIGURE	<u></u>	


OPTIONS:


SEAL FAIL LIGHTS	<u></u>	(Submersible Only)
SEAL FAIL RELAYS	<u></u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u></u>	(Submersible Only)
HT PUMP SHUTDOWN	<u></u>	(Self-Primer, Submersible)
ALARM HORN	<u></u>	
ALARM LIGHT	<u></u>	
LIGHT PANEL MTD	<u></u>	
LIGHT REMOTE MTD	<u></u>	
LIGHT FLASHER	<u></u>	
LIGHTNING ARRESTER	<u>X</u>	
ELAPSED TIME METER	<u>X</u>	
PHASE MONITOR	<u>X</u>	
NEMA RATED STARTERS	<u></u>	
GROUND FAULT RECPT.	<u></u>	
GREEN RUN LIGHTS VS. RED	<u></u>	
POLE, BOX, SEAL	<u></u>	
INTRINSICALLY SAFE RELAYS	<u></u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u></u>	
ECONOMY VERSION	<u></u>	


SOLD TO: Irrigation Mart

TAG :

SHIP TO:

	Drawing Title						
	PANEL DESCRIPTION						
DATE 10/06/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;">  COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	SIMPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP-1920
							SHEET NUMBER 1





FRONT VIEW

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NAMEPLATE SCHEDULE

NP-1 PUMP 1
NP-2 RUN
NP-3 START
NP-4 STOP

	Drawing Title ENCLOSURE									
DATE 10/06/04			REFERENCE DRAWING		NO.	REVISION-LOCATION		ECN	DATE	BY
			S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN		APPROVED		
						BY C. RACHAL		BY	DATE	
	Project Title		<div>=====</div> <div>COX</div> <div>Research and Technology, Inc.</div> <div>=====</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER		
	DRAWING NUMBER CP-1920									
	SHEET NUMBER 4									
	SIMPLEX PUMP CONTROL PANEL									

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	EBE	24208REPL	ENCLOSURE
1a	1	EBE	2420P	BACKPLATE
2	1	ABB	S1N070TL	CB1
3	1	ACI	JR22FR	RED PILOT LIGHT
4	1	ACI	JR22AN11R	PUSH BUTTON RED
5	1	ABB	T4150PSF1	TRANSFORMER
6	1	ACI	JR22AN11G	PUSH BUTTON GREEN
7	1	DELTA	LA603	LIGHTNING ARRESTER
8	1	SSAC	PLMU-11	PHASE MONITOR
9	1	MCMaster	1672T22	ELAPSED TIME METER
10	1	ABB	TA42DU42	O.L. RELAY (29-42A)
11	1	ABB	A30-30-10-84	MOTOR STARTER
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	<h3 style="margin: 0;">BILL OF MATERIALS</h3>						
DATE 10/06/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="border-top: 3px double black; border-bottom: 3px double black; padding: 5px 0;"> <h2 style="margin: 0;">COX</h2> <p style="margin: 0;">Research and Technology, Inc.</p> </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-1920 SHEET NUMBER <div style="text-align: right;">5</div>
	<h3 style="margin: 0;">SIMPLEX PUMP CONTROL PANEL</h3>						