

PARSON & SANDERSON, INC.

DUPLEX PUMP
CONTROL PANEL
ADDIS

PARSON & SANDERSON, INC.
P.O. BOX 958
METAIRIE, LA 70004
(504) 733-1330 Fax (504) 736-9348

CP-1859

VOLTAGE	120/240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	1/60	
NO. MOTORS	2	
HP	3	
FLA	36	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER	MEYERS	
CATALOG NUMBER		
CONTROL VOLTAGE	120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	Yes	(Yes, No)
CAPACITOR WIRING FIGURE	M	
THERM. & SEAL FAIL WIRING FIGURE	1, 6, 8	

OPTIONS:


SEAL FAIL LIGHTS	X	(Submersible Only)
SEAL FAIL RELAYS	X	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER		
LIGHTNING ARRESTER	X	
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET	X	
ECONOMY VERSION		

SOLD TO: Parson & Sanderson, Inc.


TAG : ADDIS

SHIP TO: Mouch Mobile Home Park, LLC.


	Drawing Title						
	PANEL DESCRIPTION						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
7/29/04		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE
	Project Title	PARSON & SANDERSON, INC. P.O. BOX 958 METAIRIE, LA 70004 (504) 733-1330 Fax (504) 736-9348				PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-1859	
						SHEET NUMBER 1	



	Drawing Title
--	---



	Drawing Title							
	CONTROL DIAGRAM							
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
7/29/04		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED		
	Project Title	PARSON & SANDERSON, INC.				PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	P.O. BOX 958 METAIRIE, LA 70004 (504) 733-1330 Fax (504) 736-9348				DRAWING NUMBER CP-1859		
						SHEET NUMBER 4		



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NP-1	PUMP 1
NP-2	PUMP 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA
NP-7	SEAL FAIL
NP-8	SEAL FAIL
NP-9	HIGH TEMP RESET
NP-10	HIGH TEMP RESET

NOTE:

SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

	Drawing Title								
	ENCLOSURE								
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY		
7/29/04		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED			
	Project Title	PARSON & SANDERSON, INC.					PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	P.O. BOX 958 METAIRIE, LA 70004					DRAWING NUMBER CP-1859		
		(504) 733-1330 Fax (504) 736-9348					SHEET NUMBER 5		

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	1	ABB	OT100E3	MAIN DISC. SWITCH
3	2	ABB	A40-30-10-84	MOTOR STARTER
4	2	ABB	TA42DU42	O.L. RELAY (29-42A)
5	2	SQUARE D	QOU270	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	AC/DC	BL5-R-120	ALARM LIGHT
10	1	DELTA	LA302	LIGHTNING ARRESTER
11	2	REDINGTON	711-0190	ELAPSED TIME METER
12	2	SSAC	LLC54AA	SEAL FAIL RELAY
13	1	MARATHON	1323580	DISTRIBUTION BLOCK
14	2	ACI	JR22BL11R	PTT RED LIGHT
15	2	ACI	JR22FY	YELLOW PILOT LIGHT
16	1	DAYTON	5YZ85N	TIME DELAY RELAY
17	2	IDEC	RU4S-A110	CR2,CR4
18	2	OMRON	G2R2SAC120	CR3,CR5
19				
20				
21				
22				
23				
24				
25				

	Drawing Title						
	BILL OF MATERIALS						
DATE 7/29/04		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	PARSON & SANDERSON, INC. P.O. BOX 958 METAIRIE, LA 70004 (504) 733-1330 Fax (504) 736-9348				PURCHASE ORDER NUMBER	
	DUPLEX PUMP CONTROL PANEL					DRAWING NUMBER CP-1859	
						SHEET NUMBER 6	