
COX

Research and Technology, Inc.

DUPLEX PUMP
CONTROL PANEL
7 1/2HP-32A

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP1431A


VOLTAGE	240V	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	3/60	
NO. MOTORS	2	
HP	7 1/2	
FLA	32	
TYPE OF PUMP	Submersible	(Self-Priming, Submersible)
MANUFACTURER		
CATALOG NUMBER		
CONTROL VOLTAGE	24V/120V	(120V, Other)
ENCLOSURE	NEMA 4X	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	Fiberglass	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	Floats	(Floats, Bubbler, Other)
CAPACITORS	No	(Yes, No)
CAPACITOR WIRING FIGURE	N/A	
THERM. & SEAL FAIL WIRING FIGURE		


OPTIONS:

SEAL FAIL LIGHTS		(Submersible Only)
SEAL FAIL RELAYS		(Submersible Only)
SEAL FAIL PUMP SHUTDOWN		(Submersible Only)
HT PUMP SHUTDOWN	X	(Self-Primer, Submersible)
ALARM HORN		
ALARM LIGHT	X	
LIGHT PANEL MTD	X	
LIGHT REMOTE MTD		
LIGHT FLASHER	X	
LIGHTNING ARRESTER		
ELAPSED TIME METER	X	
PHASE MONITOR		
NEMA RATED STARTERS		
GROUND FAULT RECPT.		
GREEN RUN LIGHTS VS. RED		
POLE, BOX, SEAL		
INTRINSICALLY SAFE RELAYS		
HIGH TEMP. LOCKOUT, MANUAL RESET		
ECONOMY VERSION		


SOLD TO: Lafayette Consolidated Government
TAG : Utilities, Wastewater Treatment

SHIP TO: Lafayette, LA


	Drawing Title						
	PANEL DESCRIPTION						
DATE 6/30/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE
	Project Title	<div style="text-align: center;">  Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809		PURCHASE ORDER NUMBER
	DUPLEX PUMP CONTROL PANEL				Ph. (225)756-3271 Fax (225)756-1030		DRAWING NUMBER CP1431A
							SHEET NUMBER 1




	Drawing Title							
	POWER DIAGRAM		1	CHANGED FLA		06/30/03	CTR	
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	
6/30/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	DRAWN BY C. RACHAL	APPROVED BY	DATE	
	Project Title				PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL	<div>COX</div> <div>Research and Technology, Inc.</div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)756-1030			
					DRAWING NUMBER CP1431A			
					SHEET NUMBER 2			



	Drawing Title								
	CONTROL DIAGRAM								
DATE	6/30/03	REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY	APPROVED	
		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	BY	DATE		
	Project Title	COX			P.O. Box 77808 Baton Rouge, LA 70809	PURCHASE ORDER NUMBER			
	DUPLEX PUMP CONTROL PANEL	Research and Technology, Inc.			Ph. (225)756-3271 Fax (225)756-1030	DRAWING NUMBER CP1431A			
						SHEET NUMBER 3			



	Drawing Title						
	CONTROL DIAGRAM						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
6/30/03		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	APPROVED	
	Project Title				PURCHASE ORDER NUMBER		
	DUPLEX PUMP CONTROL PANEL	<div> <div>COX</div> <div>Research and Technology, Inc.</div> </div>			P.O. Box 77808 Baton Rouge, LA 70809	DRAWING NUMBER CP1431A	
					Ph. (225)756-3271 Fax (225)756-1030	SHEET NUMBER	4



VIEW OF SWING OUT PANEL

NAMEPLATE SCHEDULE

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NP-1 PUMP 1
NP-2 PUMP 2
NP-3 RUN
NP-4 RUN
NP-5 HOA
NP-6 HOA

DATE 6/30/03	Drawing Title							
	ENCLOSURE							
REFERENCE DRAWING		NO.		REVISION-LOCATION		ECN	DATE	BY
S/N		Sales Engineer C.C.		Application Engineer R.C.		DRAWN BY C. RACHAL		APPROVED BY
Project Title								DATE
DUPLEX PUMP CONTROL PANEL								PURCHASE ORDER NUMBER
								DRAWING NUMBER
								CP1431A
								SHEET NUMBER
								5

BILL OF MATERIALS

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	STAHLIN	RJ1816HPLDF	ENCLOSURE
1a	1	STAHLIN	BP1816AL	BACKPLATE
2	1	ABB	S1N100TL	CIRCUIT BREAKER
3	2	ABB	A26N1-30-10-84	MOTOR STARTER
4	2	ABB	TA25DU32	O.L. RELAY (24-32A)
5	2	SQUARE D	QOU360	CB1, CB2
6	1	TIMEMARK	261DT120	ALTERNATING RELAY
7	2	ACI	JR22FR	RED PILOT LIGHT
8	2	ACI	JR22P3M20B	HOA SWITCH
9	1	AC/DC	BL5-R-120	ALARM LIGHT
10	2	GRASSLIN	UWZ52E	ELAPSED TIME METER
11	1	SSAC	FS126	FLASHER
12	1	SQUARE D	9070TF50D23	TRANSFORMER 240/480-24
13	1	SQUARE D	QOU115	CB3
14	1	ABB	OX10X225	SHAFT FOR DISC. SWITCH
15	1	ABB	OHB65J10	DISC. SWITCH HANDLE
16	1	ABB	K2VD-M	MECHANISM
17	5	OMRON	2SAC24	RELAY
18				
19				
20				
21				
22				
23				
24				
25				

	Drawing Title							
	<h2 style="margin: 0;">BILL OF MATERIALS</h2>							
DATE 6/30/03		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	DRAWN BY C. RACHAL	ECN	DATE	BY
		<div style="border: 1px solid black; padding: 5px; margin: 0 auto; width: 100px;"> <h3 style="margin: 0;">COX</h3> <p style="margin: 0; font-size: small;">Research and Technology, Inc.</p> </div>		<p style="margin: 0; font-size: small;">P.O. Box 77808 Baton Rouge, LA 70809</p> <p style="margin: 0; font-size: small;">Ph. (225)756-3271 Fax (225)756-1030</p>		<p style="margin: 0; font-size: small;">PURCHASE ORDER NUMBER</p> <hr/> <p style="margin: 0; font-size: small;">DRAWING NUMBER CP1431A</p> <hr/> <p style="margin: 0; font-size: small;">SHEET NUMBER 6</p>		
	Project Title	<h2 style="margin: 0;">DUPLEX PUMP CONTROL PANEL</h2>						