
COX

Research and Technology, Inc.

DUPLEX BLOWER
CONTROL PANEL
GATORS & FRIENDS

Cox Research and Technology, Inc.
14697 S. Harrells Ferry Road
Baton Rouge, LA. 70816
(225) 756-3271 Fax (225) 755-1030

CP-2023

VOLTAGE	<u>208V</u>	(480V, 277/480V, 240V, 120/240V, 208V, 120/208V)
PHASE/HZ	<u>3/60</u>	
NO. MOTORS	<u>2</u>	
HP	<u>3</u>	
FLA	<u>11.0</u>	
TYPE OF PUMP	<u>Blower</u>	(Self-Priming, Submersible)
MANUFACTURER	<u></u>	
CATALOG NUMBER	<u></u>	
CONTROL VOLTAGE	<u>120V</u>	(120V, Other)
ENCLOSURE	<u>NEMA 4X</u>	(NEMA 1, NEMA 3R, NEMA 4, NEMA 4X)
ENCLOSURE MATERIAL	<u>Fiberglass</u>	(Painted Steel, Stainless Steel, Fiberglass)
CONTROL SENSOR	<u></u>	(Floats, Bubbler, Other)
CAPACITORS	<u></u>	(Yes, No)
CAPACITOR WIRING FIGURE	<u></u>	
THERM. & SEAL FAIL WIRING FIGURE	<u></u>	

OPTIONS:


SEAL FAIL LIGHTS	<u></u>	(Submersible Only)
SEAL FAIL RELAYS	<u></u>	(Submersible Only)
SEAL FAIL PUMP SHUTDOWN	<u></u>	(Submersible Only)
HT PUMP SHUTDOWN	<u></u>	(Self-Primer, Submersible)
ALARM HORN	<u></u>	
ALARM LIGHT	<u></u>	
LIGHT PANEL MTD	<u></u>	
LIGHT REMOTE MTD	<u></u>	
LIGHT FLASHER	<u></u>	
LIGHTNING ARRESTER	<u></u>	
ELAPSED TIME METER	<u></u>	
PHASE MONITOR	<u></u>	
NEMA RATED STARTERS	<u></u>	
GROUND FAULT RECPT.	<u></u>	
GREEN RUN LIGHTS VS. RED	<u></u>	
POLE, BOX, SEAL	<u></u>	
INTRINSICALLY SAFE RELAYS	<u></u>	
HIGH TEMP. LOCKOUT, MANUAL RESET	<u></u>	
ECONOMY VERSION	<u></u>	


SOLD TO: Delta Process

TAG : Gators & Friends

SHIP TO: Delta Process - Denham Springs, LA

	Drawing Title						
	PANEL DESCRIPTION						
DATE		REFERENCE DRAWING	NO.	REVISION-LOCATION	ECN	DATE	BY
3/24/05		S/N	Sales Engineer C.C.	Application Engineer R.C.	BY C. RACHAL	BY	DATE
	Project Title	<div style="text-align: center;"> COX Research and Technology, Inc. </div>			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030		PURCHASE ORDER NUMBER DRAWING NUMBER CP-2023 SHEET NUMBER 1
	DUPLEX BLOWER CONTROL PANEL						






PANEL IS DESIGNED TO RUN AERATORS WITH A MINIMUM OF 15 MINUTES OF OFF TIME BETWEEN ALTERNATION. PINS PUSHED OUT ON CLOCK INDICATE RUN TIME. PINS PUSHED IN INDICATE OFF TIME. EACH PIN IS EQUAL TO 15 MINUTES.

IF NO OFF TIME IS REQUIRED BETWEEN ALTERNATION, REMOVE JUMPER FROM TERMINALS ⑤ AND ⑥ PLACE JUMPER ACROSS TERMINALS ⑦ AND ⑧ NOW AERATORS WILL RUN CONTINUOUSLY. SET 1 PIN IN AT THE TIME YOU WISH THE AERATORS TO ALTERNATE. ALL REMAINING PINS SHOULD BE PUSHED OUT.

* REMOVE JUMPERS AND INSTALL LOCKOUT DEVICES IF REQUIRED

	Drawing Title CONTROL DIAGRAM							
DATE 3/24/05			REFERENCE DRAWING S/N		NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.		DRAWN BY C. RACHAL
	Project Title DUPLEX BLOWER CONTROL PANEL		COX Research and Technology, Inc.			P.O. Box 77808 Baton Rouge, LA 70809 Ph. (225)756-3271 Fax (225)755-1030	PURCHASE ORDER NUMBER DRAWING NUMBER CP-2023 SHEET NUMBER	
							3	




	Drawing Title						
	EXTERNAL CONNECTIONS						
DATE 3/24/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY
	Project Title	DRAWN BY C. RACHAL			APPROVED BY		
	DUPLEX BLOWER CONTROL PANEL	PURCHASE ORDER NUMBER			DRAWING NUMBER CP-2023		
		SHEET NUMBER			4		

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030



VIEW OF FRONT COVER

NAMEPLATE SCHEDULE

NOTE:
SEWER GASSES WILL DESTROY COMPONENTS IN PANEL.
PROPER SEALS MUST BE INSTALLED EXTERNAL TO THE
PANEL TO PREVENT ENTRY OF GASSES.

NP-1	BLOWER 1
NP-2	BLOWER 2
NP-3	RUN
NP-4	RUN
NP-5	HOA
NP-6	HOA

	Drawing Title							
	ENCLOSURE							
DATE 3/24/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY	
	Project Title	DRAWN BY C. RACHAL			APPROVED BY DATE			
	DUPLEX BLOWER CONTROL PANEL	PURCHASE ORDER NUMBER						
		DRAWING NUMBER CP-2023						
		SHEET NUMBER			5			

COX

Research and Technology, Inc.

P.O. Box 77808
Baton Rouge, LA
70809

Ph. (225)756-3271
Fax (225)755-1030

BILL OF MATERIAL

ITEM	QTY	MANUFACTURER	PART NO.	DESCRIPTION
1	1	VYNCKIER	VJ1816HWPL	ENCLOSURE
2	1	VYNCKIER	MP1816A	BACKPLATE
3	2	ABB	A16-30-10-84	STARTER
4	2	ABB	TA25DU14	O.L. (10-14A)
5	2	ABB	S1N020TL	CIRCUIT BREAKER 1,2
6	2	ACI	JR22P3M20B	H.O.A. SWITCH
7	1	DIVERSIFIED	ARB 120 ADA	ALTERNATING RELAY
8	1	GRASSLIN	FM/1 STUZH-L	TIMER
9	2	ACI	JR22FR	RED PILOT LIGHT
10	1	SQUARE D	9070TF150D1	TRANSFORMER
11	1	ABB	OT63E3	DISCONNECT SWITCH

	Drawing Title								
	BILL OF MATERIALS								
DATE 3/24/05		REFERENCE DRAWING S/N	NO. Sales Engineer C.C.	REVISION-LOCATION Application Engineer R.C.	ECN	DATE	BY		
	Project Title					PURCHASE ORDER NUMBER			
	DUPLEX BLOWER CONTROL PANEL	COX Research and Technology, Inc.				P.O. Box 77808 Baton Rouge, LA 70809	DRAWING NUMBER CP-2023		
						Ph. (225)756-3271 Fax (225)755-1030	SHEET NUMBER	6	