



Comparison of Event-Based Processing Algorithms for Experimental 2D2C Velocimetry

Sidaard Gunasekaran*

University of Dayton, Dayton, Ohio, 45469, United States

Michael Mongin†

U.S. Air Force Research Laboratory, Wright-Patterson Air Force Base, Ohio 45433

Osama A. AlSattam‡

University of Dayton, Dayton, Ohio, 45469, United States

Keigo Hirakawa§

University of Dayton, Dayton, Ohio, 45469, United States

Event-based cameras, which operate without traditional frames and instead capture asynchronous changes in intensity, offer a transformative approach to flow diagnostics. This study investigates the application of event-based methods for velocimetry around an SD7003 wing and compares their performance to traditional Particle Image Velocimetry (PIV). Four event-based algorithms—Weighted Tracking (Linear and Non-Linear fits), Kalman Filter, and Motion Compensation—are evaluated using a combination of freestream, near-surface, and wake flow scenarios. Results demonstrate that event-based methods successfully replicate global flow trends observed in PIV, including mean and median velocity estimates, while also capturing subtle flow features such as near-surface pressure gradients and wake asymmetry with higher resolution. Unlike PIV, which is constrained by frame rate and windowed processing, event-based methods track individual tracer particles, resolving flow features even in regions with steep gradients. The weighted tracking methods exhibited the closest agreement with PIV, while Kalman Filter and Motion Compensation methods showed slight biases in U-velocity, hypothesized to result from input parameter tuning. The findings highlight the potential of event-based methods as a viable candidate for flow diagnostics.

Nomenclature

$I(t)$	= Intensity of each pixel	c	= Wing Chord
$C_{Temporal}$	= Temporal Contrast	U_{∞}	= Freestream Velocity
α	= Angle of Attack	PIV	= Particle Image Velocimetry
x, y	= Co-ordinates in X and Y directions	EB – PIV	= Event-Based PIV
U, V	= Velocities in X and Y Directions		

I. Introduction

Event-based cameras, also known as dynamic vision sensors (DVS) or Address-Event Representation (AER) cameras, were initially developed by Mahowald to emulate the human retina's sensitivity to motion [1]. Unlike traditional cameras, event-based cameras operate in a frame-free manner, capturing only changes in light intensity rather than recording complete frames at regular intervals. This asynchronous output is characterized by the independent operation of each pixel, which transmits events when relative changes in intensity surpass a threshold [2]. Advances in DVS technology, pioneered at the Institute of Neuroinformatics, University of Zurich, have been

* Associate Professor, Mechanical and Aerospace Engineering Department, AIAA Senior Member. gunasekarans1@udayton.edu

† Aerospace Engineer, AFRL, AIAA Member. michael.mongin@us.af.mil

‡ Ph.D. Student, Department of Electrical and Computer Engineering. alsattamo1@udayton.edu

§ Professor, Department of Electrical and Computer Engineering. khirakawa1@udayton.edu

extensively detailed by Lichtsteiner et al. [2] and Posch et al. [3]. The working principle of event-based cameras revolves around detecting temporal contrast changes in intensity. Each pixel generates an event when the logarithmic intensity contrast exceeds a predefined threshold, defined mathematically as:

$$C_{Temporal} = \frac{1}{I(t)} \frac{dI(t)}{dt} \quad (1)$$

where $I(t)$ represents the intensity at time t . The camera outputs an asynchronous stream of events, consisting of four data columns: x and y (pixel coordinates), t (timestamp in microseconds), and p (polarity, representing ON or OFF states). The logarithmic sensitivity of DVS sensors enables a high dynamic range (up to 120 dB) and low pixel latency (as little as 15 μ s under optimal lighting) [4]. Operating with a sample clock rate near 1 MHz, these cameras achieve a temporal resolution of approximately 1 μ s.

Figure 1 illustrates a simulated comparison between conventional and event-based cameras for the circular motion of particles in a field of view. Conventional cameras produce frame-based outputs at fixed intervals (δt), capturing static snapshots. Conversely, event cameras provide an asynchronous stream of timestamped events, exclusively recording motion without static background information.




Figure 1 Illustration of the output differences between a conventional camera (frame-based approach) and an event-based camera (asynchronous event stream) for a cluster of particles undergoing circular motion.

The unique non-frame-based approach of event-based cameras positions them as promising tools for velocimetry. Table 1 highlights the comparison between traditional time-resolved Particle Image Velocimetry (PIV) and event-based PIV. Traditional PIV relies on precise synchronization between the camera and laser, as well as tailored delays between laser pulses to capture adequate particle displacement (8 - 10 pixels) within the sensor's field of view. It also requires homogeneous seeding for accurate velocity estimation through cross-correlation.

Event-based velocimetry, on the other hand, eliminates synchronization and time-delay requirements due to its frame-free nature. While uniform tracer particles improve tracking, they are not strictly necessary. Event cameras operate with safer Class IIIB lasers instead of the high-power Class IV lasers used in traditional methods. However, a significant limitation of event-based cameras is their resolution; the maximum currently available resolution is 1 MP, compared to up to 16 MP or higher for traditional PIV cameras. Furthermore, traditional PIV benefits from decades of algorithmic development for denoising and filtering, whereas event-based velocimetry is limited by the scarcity of validated algorithms for processing noisy event data. Addressing these gaps is one of the core objectives of this study.

1.1 Use of Event Camera for Flow Diagnostics

Dynamic vision sensors (DVS), commonly referred to as event cameras, have increasingly been employed to

visualize and quantify fluid flows. Drazen et al. [5] demonstrated the potential of a DVS sensor for particle tracking velocimetry (PTV) in dense solid-liquid two-phase pipe flows. Similarly, Ni et al. [6] used event-based imaging to track 12-micron microspheres, successfully capturing Brownian motion. Borer et al. [4] achieved the first application of PTV in air, employing event-based cameras to track sparsely seeded helium-filled soap bubbles within a large experimental setup featuring a 1-meter field of view. Wang et al. [7] further advanced this field by implementing stereoscopic PTV with two event-based cameras, enabling three-dimensional particle tracking in a smaller volume. More recently, Willert and Klinner [8] utilized event cameras to measure velocity fields in the wake of a circular cylinder in both wind and water tunnels, benchmarking their results against the traditional two-dimensional, two-component (2D-2C) Particle Image Velocimetry (PIV) methodology.

Table 1 Key differences between traditional time-resolved Particle Image Velocimetry (TR-PIV) and event-based Particle Image Velocimetry (Event-PIV)

Time Resolved Traditional PIV (TR – PIV)		Event Based PIV (EB-PIV)
Experimentation	Synchronization	Required between camera and laser
	Calibration	Requires calculating time delay and frame rate between pulses using FOV dimension
	Seeding	Requires uniform and homogenous seeding
Camera	Type	High Speed Camera with Double Shutter for Wind tunnel and without for Water tunnel
	Resolution	High Spatial Resolution
	Output	Synchronized Frames
Light Source	Type	High Power Double Pulsed Lasers for Wind Tunnel and Continuous lasers for water tunnel
	Safety	Class IV
Analysis		Plethora of tools developed over decades (denoising, cross-correlation, etc.)
Accuracy	Spatial Resolution	Interrogation Windows
	Temporal Resolution	Depends on MP of camera
System Cost		More than \$80,000

Table 2 provides a comparative overview of key aspects such as test setups, cameras used, seeding particles, lighting, processing algorithms, and spatiotemporal resolutions across these notable studies. Beyond fluid flow applications, event cameras have also found use in various domains, including industrial automation, Internet of Things (IoT), monitoring systems, automotive and mobility technologies, and medical devices [9]. A comprehensive review of event-based sensing technology and its foundational concepts is available in Tayarani-Najaran and Schmuker [10]. While existing algorithms for "optical flow" detection—used in applications like detecting vehicles, trees, and people—are highly effective in general-purpose scenarios, they are not optimized for fluid flow measurements. Such algorithms rely on events across broader areas, such as edges and curves, whereas fluid flow analysis involves tracer particles that, when focused properly, occupy only a few pixels.

To harness the capabilities of event cameras for velocimetry, custom algorithms must be developed to filter, denoise, and extract velocity information from raw data. Some methods attempt to create virtual "frames" by time-sampling event data and processing them with traditional cross-correlation techniques. However, this approach introduces challenges, such as denoised data creating empty interrogation regions that reduce correlation quality, and windowed interrogation techniques decreasing spatial resolution.

Table 2 Overview of experimental setups and methodologies from key event-based velocimetry studies: Drazen et al. [5], Wang et al. [7], and Willert and Klinner [8].

Reference	Drazen et al. [5]	Wang et al. [7]	Willert and Klinner [8]	
Velocimetry Setup Type	2C-2D	3C-3D	2C-2D	
Test Section Dimensions (mm)	Pipe (50 x 2700)	Hexagonal Tank	Water Tunnel (400 x 250 x 60)	Wind Tunnel (76 x 76 x 1500)
Article of Investigation	Flow in pipe driven by pump	Magnetic Stirring in a tank	Flow driven by a pump	Wake of a cylinder
FOV Dimensions (mm)	7.75 x 7.75	6.23 x 3.6 x 5.4	54 x 30	31 x 17.5
Magnification ($\mu\text{m}/\text{pix}$)	60.55	15	42.3	41.2
Event Camera Used	DVS (128 x 128 pix)	Prophesee PEK3SHEM (480 x 360 pix)	Prophesee EVK2 HD (1280 x 720 pix)	
Seeding Particles	Polyestyrene (950 μm)	White Polyethylene (90 - 106 μm)	Silver coated glass (10 μm)	Paraffin Droplets (1 μm)
Lighting	5W CW Laser	Collimated LED	5.6W CW Laser	4W CW Laser
Algorithm used	Particle Tracker	Event-Based Optical Flow	Motion Compensation	
Spatial Resolution	Per Particle	Per Volume	40 x 40 pix	
Temporal Resolution (ms)	20	NA	20	

In this paper, we evaluate and compare the performance of three in-house developed algorithms—weighted tracking with linear fit, weighted tracking with non-linear fit, and Kalman filter-based tracking and the Motion Compensation algorithm developed by Willert [8] against the traditional PIV results. While Willert's study demonstrated the feasibility of event-based velocimetry by comparing its performance with traditional Particle Image Velocimetry (PIV), it relied on a windowed interrogation approach akin to conventional PIV. This approach, while effective, inherently limits spatial resolution and does not fully leverage the capabilities of event cameras for tracking individual particles.

In contrast, the methods employed in the current study are particle-based, enabling the tracking of individual particle motion throughout the flow field. This particle-level resolution provides a more detailed and hypothetically, an accurate depiction of velocity fields, avoiding the loss of spatial information associated with windowed techniques. By benchmarking the in-house developed algorithms against traditional PIV method, this research not only highlights the potential of particle-based tracking for event cameras but also aims to identify the most robust and accurate approach for event-based velocimetry.

II. Processing Algorithms Used

Four distinct algorithms were employed to estimate velocity from the event data. These algorithms, described below, highlight both particle-based and image-based approaches to leveraging event camera data for velocimetry:

1. Weighted Tracking with Non-Linear Fit

The weighted tracking algorithm, detailed in AlSattam et al. [11, 12], estimates particle trajectories using a second-degree polynomial fit. This non-linear fit approach is particularly well-suited for capturing curved or complex motion paths, such as those found in separated flow regions or turbulent flows where linear assumptions do not hold. By applying polynomial regression to sequences of particle positions, the algorithm estimates both velocity and acceleration by differentiating the fitted polynomial over time. This flexibility allows it to accurately track particles in dynamic environments with significant changes in flow behavior, enhancing its utility for highly unsteady or non-linear flows.

2. Weighted Tracking with Linear Fit

The linear fit method simplifies particle tracking by employing a linear regression to approximate particle paths over short time windows. In this approach, the slope of the fitted line corresponds to the particle's velocity. This method excels in cases where particles exhibit relatively constant or linear motion, such as laminar flows. Due to its computational simplicity, the linear fit method is highly robust and efficient for basic tracking tasks. However, its inability to account for non-linear motion patterns limits its applicability in turbulent or rapidly varying flow regions where more complex models, such as the non-linear fit, are required.

3. Kalman Filter-Based Tracking

The Kalman filter-based tracking algorithm, described in detail by AlSattam et al. [12, 13], employs a causal filtering approach to estimate particle positions and velocities while accounting for noise and uncertainties in the measurements. This method recursively predicts the state of each particle and updates the predictions using incoming event data. By applying a weighted average of the prediction and the observation, the Kalman filter minimizes the impact of measurement noise and erratic particle behavior. This probabilistic approach is particularly advantageous in highly dynamic environments, such as turbulent fluid flows, where rapid fluctuations and incomplete observations present significant challenges for traditional tracking algorithms. The Kalman filter's robustness makes it a powerful tool for real-time applications requiring noise-resilient velocity estimation.

4. Motion Compensation Algorithm

The Motion Compensation algorithm, originally introduced by Gallego et al. [14] was adapted and implemented by Willert et al. [8] for event-based velocimetry applications. Unlike particle-based tracking methods, this technique

adjusts the observation frame to align with the expected flow field. The algorithm predicts velocities by iteratively realigning the frame and counting the number of events in each alignment, enhancing the accuracy of particle tracking. This approach is particularly effective in high-speed or directional flows, where background interference or motion artifacts would otherwise hinder traditional tracking methods. However, as a windowed approach, it sacrifices particle-level resolution and is less adept at resolving individual particle motions compared to particle-based techniques.

III. Experimental setup

A. University of Dayton Water Tunnel

The event-based velocimetry and traditional velocimetry experiments were conducted at the University of Dayton Water Tunnel (UDWaT), shown in Figure 2. This facility features a horizontal free-surface water tunnel with a 6:1 contraction ratio. The test section measures 38 cm in width, 46 cm in height, and 152 cm in length, with a freestream speed range of 7.5 cm/s to 38 cm/s. The tunnel is equipped with a one-degree-of-freedom motion stage, comprising an H2W Technologies linear motor driven by a Xenus XTL-230-18 motor driver from Copley Controls. A rack-and-pinion gear system converts the motor's linear motion into rotational motion, enabling precise pitching of a test article within the tunnel's test section. Closed-loop feedback and control for adjusting the angle of attack and coefficient of lift are facilitated by a dSPACE MicroLabBox with BNC-type terminations, programmed using the MATLAB LabVIEW Real-Time Interface (RTI).



Figure 2 University of Dayton Water Tunnel (UDWaT) facility




Figure 3 Images showing the design, fabrication, and installation of the SD7003 wing model.

B. Test Model

To visualize both the upper and lower surfaces of the wing, an SD7003 wing model was fabricated using clear resin. After three iterations with different resin materials, the final model was fabricated using Accura ClearVue High Resolution resin, which included a clear coat as shown in Figure 3. This material was chosen because it eliminated the need for sanding or external polishing, resulting in a smooth and transparent surface. The wing model had a span of 7.25 inches, a chord of 3 inches, and an aspect ratio close to 5. When immersed in the water tunnel, the model's transparency allowed the laser to pass through and illuminate both the upper and lower surfaces effectively, facilitating visualization during the experiments.

C. Test Setup for Event-Camera and Traditional Velocimetry

The wing model was mounted to a force sensor connected to the linear actuator. The field of view was positioned at the tunnel centerline, aligning with the midspan of the model. To facilitate image acquisition, a 45° mirror was placed in front of the cameras, parallel to the bottom surface of the tunnel, as depicted in Figure 4. For traditional Particle Image Velocimetry (PIV), a PCO DiMax S4 high-speed camera with a 2016 x 2016 pixel CMOS sensor was used. For event-based velocimetry, a Prophesee EVK2 camera equipped with a 1280 x 720 pixel sensor was employed. Simultaneous data acquisition was achieved by positioning a 50-50 beam splitter after the mirror, with the two cameras arranged orthogonally to each other. A 50 mm lens was used on the event camera, while a 100 mm lens was paired with the PCO DiMax camera. This setup ensured accurate and synchronized image acquisition for both traditional and event-based velocimetry techniques.




Figure 4 A schematic (left) and actual setup (right) of the event-based and traditional velocimetry system in the University of Dayton Water Tunnel. The setup includes a 2.4W laser, laser optics, a 45° mirror, a 50-50 beam splitter, and two cameras: the Prophesee EVK2 event camera and the PCO DiMax high-speed camera.

The event camera was calibrated using a dot plate. Because the event camera does not display an image unless motion is detected, slight vibrations were introduced to the test setup to generate detectable events. The resulting circles on the dot plate were captured over a duration of 4 seconds. Events were grouped into 10 ms intervals, and a circle-finding algorithm was applied to identify the field of view (FOV) for the entire 4-second data set, based on each 10 ms interval. The dot plate calibration and detected circles are illustrated in Figure 5a, while an interquartile range (IQR) plot of the X and Y FOVs obtained from the calibration algorithm is shown in Figure 5b. The X FOV of the event camera was measured to be 162 mm, and the Y FOV was 90 mm.




Figure 5(a) Detected circles from the dot plate calibration process in one 10 ms interval (b) Interquartile range (IQR) plot showing the X and Y field of view (FOV) dimensions obtained from the calibration with 4 seconds of data.

E. Test Matrix

The test matrix for the force-based experiments and simultaneous PIV and event-based velocimetry is summarized in Table 3. Force-based testing was conducted at three tunnel speeds, with angles of attack ranging from -20° to 20° in 1° increments. The Reynolds numbers for these tests ranged from 17,000 to 32,000, based on the wing chord. For traditional and event-based velocimetry, testing was performed over an angle of attack range of 0° to 10° , in 2° increments.

The parameters for traditional PIV, including the number of frames, frame rates, and exposure times, are provided in Table 3. For event-based velocimetry, 4 seconds of data were captured for each case, with two different high-pass filter (HPF) bias settings applied during data acquisition. The HPF bias setting determines the minimum rate of illumination change required for a pixel to output an event, allowing for filtering of slower changes in lighting. This filtering effectively removes static background elements, isolating fast-moving objects and reducing background noise. While the results presented in this paper are based on an HPF bias of 80, the sensitivity of results to other bias settings (e.g., 120) will be explored in a follow-up study. Additionally, freestream data was collected at various speeds using both methods to establish baseline comparisons. The experimental design ensures robust velocity measurements across a range of flow conditions, enabling a detailed evaluation of both traditional and event-based velocimetry techniques.

Table 3 Summary of test conditions, including tunnel speeds, angles of attack (AOA), Reynolds numbers (Re), and camera settings for both traditional PIV and event-based velocimetry.

	Force-Based Testing		Traditional PIV				Event Based PIV	
Velocity (m/s)	AOA (Deg)	Re	AOA (Deg)	No of TR-PIV Frames	Frame Rate (Hz)	Exposure (μ s)	Duration of Event Acquisition (sec)	HPF Bias Setting
0.2	-20 to 20	17745	0,2,4,6,8,10	1500	238	1300	4	80, 120
0.3		26617			330	1200		
0.37		32827			440	800		
0.2	No-Wing (Freestream Only)	-	-	1500	238	1300	4	80, 120
0.3					330	1200		
0.37					440	800		

IV. Results

1. Force Based Results

The coefficient of lift (C_L) as a function of angle of attack (AOA) for the wing at three different Reynolds numbers is shown in Figure 6. At the highest velocity tested (0.37 m/s), the lift curve slope closely follows the predicted trend from the low Reynolds number corrected lift curve slope, represented by the dashed line. Similarly, the results at 0.3 m/s exhibit a comparable trend, except for deviations in the stall angle. At 0.2 m/s, however, the lift curve slope changes noticeably around a 5° AOA, which is hypothesized to result from the formation of a laminar separation bubble (LSB). At higher velocities (0.3 m/s and 0.37 m/s), the LSB is believed to break earlier, leading to a higher standard deviation in the lift coefficient between AOAs of 4° and 8°. In contrast, at 0.2 m/s, the standard deviation in this range is lower because the separation bubble remains attached and sheds only at higher angles of attack. Based on the observed lift curve behavior at different velocities, the angle of attack range for traditional and event-based PIV measurements was narrowed to 0° to 10° in 2° increments to focus on regions of interest while minimizing potential data inconsistencies.




Figure 6 Lift curves for the wing at three velocities corresponding to Reynolds numbers of 17,745 (0.2 m/s), 26,617 (0.3 m/s), and 32,827 (0.37 m/s). The dashed line represents the low Reynolds number corrected lift curve slope.

2. Velocimetry Results

2.1 Freestream

The comparison between the four event-based algorithms and the traditional PIV method is presented in this section, beginning with the freestream velocities. Figure 7 shows the normalized U-velocity contours for freestream velocities of 0.2, 0.3, and 0.37 m/s, obtained using the conventional PIV method and the event-based algorithms. The contours from traditional PIV exhibit smooth variations across the field of view, owing to the windowed approach with 50% overlap, which smooths gradients but reduces spatial resolution. In contrast, the event-based methods display speckled patterns across the field of view, a characteristic of particle tracking approaches that resolve individual particle trajectories. This pattern is due to the inherent increase in the spatial resolution when compared to PIV but introduces a less smooth representation of the flowfield. For reference, processing PIV data with smaller interrogation windows (e.g., 32×32 in the first iteration and 16×16 in the second iteration) would produce similar speckling but at the cost of reduced overall accuracy.

Both the linear and non-linear fit methods in the weighted tracking approach show similar behavior. However, a consistent bias is observed across the field of view for all velocities when using the Kalman filter and motion compensation methods. This bias is likely due to improper tuning of these algorithms for the specific dataset. A sensitivity study to address this will be detailed in a future paper. The velocity histograms for all methods at the three freestream velocities are also shown in Figure 7. The PIV method produces histograms with narrower distributions and higher kurtosis, indicating less variability. In contrast, the event-based methods capture broader velocity distributions for all tested velocities. A clear bias in the mean velocity is observed for all event-based methods compared to traditional PIV, though this bias diminishes as velocity increases. For the 0.3 and 0.37 m/s cases, the weighted tracking methods demonstrate good agreement with PIV in capturing the mean velocity. However, the Kalman filter and motion compensation methods exhibit a higher degree of bias compared to the weighted tracking methods.




Figure 7 (Top) U-velocity contours at 0.2, 0.3, and 0.37 m/s from PIV and event-based methods. PIV shows smooth gradients, while event-based methods exhibit speckling due to particle-level resolution. (Bottom) Velocity histograms highlight broader distributions for event-based methods and a decreasing bias in mean velocity at higher speeds.

Figure 8 evaluates the statistical performance of PIV and four event-based algorithms across various freestream velocities. The mean and median generally decrease with velocity, with PIV, WT-Linear, and WT-Non-Linear displaying similar, stable trends. However, Motion Compensation consistently underestimates these central tendencies, while the Kalman Filter exhibits significant variability and pronounced changes in both metrics. Skewness results indicate increasingly negative skew (left-tailed distributions) as velocity increases, with the Kalman Filter and Motion Compensation showing the greatest sensitivity to these changes. Kurtosis reveals that the Kalman Filter produces sharp peaks and heavy tails, particularly at intermediate velocities, highlighting its susceptibility to extreme outliers. In contrast, PIV and WT methods maintain near-normal kurtosis (~ 3), demonstrating better stability across all metrics. Overall, WT methods exhibit statistical robustness and reliability comparable to PIV, while the Kalman Filter is highly sensitive to velocity changes, and Motion Compensation underestimates velocities and displays asymmetric distributions.




Figure 8 Comparison of mean, median, skewness, and kurtosis for PIV and four event-based algorithms (WT-Linear, WT-Non-Linear, Kalman Filter, and Motion Compensation). WT methods show trends similar to PIV, with stable distributions across velocities. The Kalman Filter demonstrates high sensitivity and variability, while Motion Compensation consistently underestimates and displays skewed distributions.




Figure 9 Comparison of normalized U-velocity contours from PIV and four event-based methods (WT-Linear, WT-Non-Linear, Kalman Filter, and Motion Compensation) at angles of attack ranging from $\alpha = 0^\circ$ to $\alpha = 10^\circ$. PIV shows smooth gradients and clear flow separation, while event-based methods capture similar trends. Weighted tracking methods closely align with PIV results, while Kalman Filter and Motion Compensation exhibit slight biases and shadow artifacts near the leading edge.

2.2 Flow Around SD7003 Wing

A comparative analysis of the normalized U-velocity contours around the SD7003 wing was conducted between the PIV method and the various event-based algorithms. The normalized U-velocity contours at different angles of attack (α) are shown in Figure 9. The rows represent angles of attack ranging from $\alpha = 0^\circ$ to $\alpha = 10^\circ$, while the columns correspond to the different algorithms used. As seen in the freestream case, the traditional PIV method produces smooth and uniform gradients around the wing, capturing higher velocities on the upper surface, lower velocities on the lower surface, and flow separation regions. The event-based methods display similar trends, with the weighted tracking methods (WT-Linear and WT-Non-Linear) closely resembling the PIV results. Flow separation and stall behavior, especially at $\alpha = 10^\circ$ are well captured by both the PIV and the event-based methods. However, the weighted tracking methods (linear and non-linear fits) show the closest agreement with PIV, particularly in representing the transition from attached flow to separation. This consistency across angles of attack suggests that weighted tracking methods are robust and suitable for analyzing aerodynamic behavior. The Kalman Filter and Motion Compensation methods, while capturing the general trends, show more sensitivity to velocity changes. These methods also show a slight bias in the magnitude of the contours. This bias could be attributed to the algorithmic assumptions, noise modeling, etc. that require further tuning for the flow conditions studied. This tuning, along with a sensitivity analysis, is currently under investigation and will be addressed in a future publication. Additionally, the shadow cast by the leading edge of the wing is distinctly visible in the Motion Compensation results, whereas it is less pronounced in the other methods. Overall, at each angle of attack, the trends observed in PIV are successfully captured by the event-based methods, with the weighted tracking algorithms demonstrating the closest alignment.




Figure 10 Comparison of normalized U-velocity contours from PIV and event-based methods (WT-Linear, WT-Non-Linear, Kalman Filter, and Motion Compensation) at freestream velocities of 0.2 m/s, 0.3 m/s, and 0.37 m/s, with a fixed angle of attack ($\alpha = 4^\circ$)

While Figure 9 illustrates the changes in the flow field as a function of angle of attack, Figure 10 depicts the variation of normalized U-velocity at different freestream velocities around the wing at a fixed angle of attack ($\alpha = 4^\circ$). At a freestream velocity of 0.2 m/s, the wake is noticeably thicker, with flow separation occurring near the quarter chord of the wing. As the velocity increases, the wake becomes thinner, reflecting reduced flow separation and enhanced boundary layer attachment. At 0.37 m/s, the displacement thickness over the wing, as predicted by XFLR5, is shown as a green line. The experimental results, including both PIV and event-based methods, align well with the XFLR5 prediction. The event-based methods once again exhibit remarkable similarity in trends and magnitudes compared to PIV. However, a consistent bias in velocity magnitude is observed in the Kalman Filter and Motion Compensation methods, which may require further refinement and parameter tuning.

In Figure 10, the event-based methods estimate slightly lower wake velocities compared to PIV. This is further illustrated in Figure 11, which presents freestream-normalized momentum deficit profiles at $\alpha = 0^\circ$ and $\alpha = 2^\circ$, for the three velocities tested. To account for the observed bias in the Kalman Filter and Motion Compensation methods, the wake velocities were normalized with the respective freestream velocity observed in each method, enabling a more effective comparison. As shown in Figure 11, PIV consistently predicts lower velocities in the wake region across all

freestream velocities. This discrepancy can be partially attributed to a limitation in traditional PIV methods: the frame interval (Δt) or frame rate must be tuned for specific regions of interest in the field of view, particularly when large velocity gradients are present. In this study, Δt was optimized for the freestream velocity, ensuring tracer particles traveled 8–10 pixels per displacement in the freestream region. However, this tuning does not account for the lower particle displacements in the wake region, violating the established rule of thumb for cross-correlation accuracy. Consequently, lower cross-correlation peak magnitudes and reduced velocity estimation accuracy are expected in the wake. Event-based methods, in contrast, are not constrained by a fixed frame rate. They effectively track particles regardless of velocity variations across the field of view, enabling accurate measurements even in regions with high velocity gradients. This capability of event-based methods to excel in areas with steep gradients has been demonstrated using synthetic data in Alsattam et al. [11, 12].




Figure 11 Momentum deficit profiles predicted by PIV and event-based methods (WT-Linear, WT-Non-Linear, Kalman Filter, and Motion Compensation) at freestream velocities of 0.2 m/s, 0.3 m/s, and 0.37 m/s at $\alpha = 0^\circ$ and $\alpha = 2^\circ$. Event-based methods show consistent performance across the wake and freestream, while PIV results are influenced by frame-rate tuning optimized for the freestream region.

Traditional PIV encounters significant challenges in resolving flow features near the surface of test models due to reflections caused by high-power lasers. Addressing this often requires the application of rhodamine paint to the model surface and the use of lens filters on the PIV camera. However, even with these adjustments, accurately capturing surface flow features remains difficult. Event-based methods, by contrast, are not impacted by static reflections from the test model, as the event camera only registers dynamic changes within its field of view. This enables event-based methods to better capture near-surface flow features compared to traditional PIV.

Figure 12 illustrates this advantage. The normalized U-velocity contours provide a close-up comparison between traditional PIV and the weighted tracking method with a non-linear fit. The displacement thickness predicted by XFLR5 is overlaid on the contours. Traditional PIV shows a region of flow acceleration beneath the predicted displacement thickness, while the event-based method more accurately captures flow deceleration in this region. The advantage of event-based methods is further demonstrated by the coefficient of pressure (C_p) profiles at different freestream velocities with an angle of attack of 4° . Compared to C_p predictions from XFLR5, the weighted tracking

method provides a closer match than traditional PIV. Traditional PIV struggles to resolve the pressure gradients caused by the laminar separation bubble near the surface, while event-based methods capture these gradients with comparatively greater accuracy. This highlights the potential of event-based methods for resolving critical near-surface flow features that are difficult to measure using traditional PIV techniques.




Figure 12 (Top) Normalized U-velocity contours comparing traditional PIV and WT-Non-Linear at $\alpha = 4^\circ$ with XFLR5-predicted displacement thickness (green line). **(Bottom)** C_p profiles at freestream velocities of 0.2, 0.3, and 0.37 m/s. Event-based methods align more closely with XFLR5 predictions, capturing surface pressure gradients more accurately than PIV.




Figure 13 Histograms of normalized U-velocity for PIV and event-based methods at angles of attack from $\alpha = 0^\circ$ to $\alpha = 10^\circ$ at 0.37 m/s. Event-based methods capture global trends with reasonable precision but exhibit slight bias compared to PIV.

To further validate the normalized U-velocity estimates from event-based methods against traditional PIV, histograms of U-velocity at various angles of attack (α) are shown in Figure 13 for a freestream velocity of 0.37 m/s. Similar to the freestream results, a slight bias is observed in the event-based methods compared to traditional PIV. At low angles of attack (0° and 2°), the histograms are relatively narrow and symmetric, indicating stable flow. However, as the angle of attack increases, the histograms broaden significantly, reflecting increased flow variability due to separation and stall effects. The weighted tracking methods (WT-Linear and WT-Non-Linear) closely align with PIV across all angles of attack, particularly in capturing the widening distributions at higher α . In contrast, the Kalman Filter and Motion Compensation methods exhibit greater bias, especially at higher angles, likely due to challenges in resolving separated flow regions. However, as mentioned before, these methods might likely need to be tuned further.




Figure 14 Mean and median U-velocity values for PIV and event-based methods a function of angle of attack at freestream velocities of 0.2 m/s, 0.3 m/s, and 0.37 m/s. Event-based methods replicate global trends observed in PIV, with weighted tracking methods showing the closest agreement.

Figure 14 presents the variation of the mean and median of normalized U-velocity as a function of angle of attack (α) for all five methods at three different freestream velocities. These metrics capture the combined effects of flow acceleration over the upper surface, deceleration along the lower surface, and wake dynamics, as illustrated in Figures 9 and 10. For all methods, the mean and median remain roughly constant with increasing α , indicating that on a global scale, the event-based methods successfully replicate the trends observed in traditional PIV. However, consistent with the histograms in Figure 13, a fixed bias error exists between PIV and the event-based methods across all cases. Among the event-based methods, the weighted tracking methods (WT-Linear and WT-Non-Linear) show the closest agreement with PIV, while the Kalman Filter method follows. The Motion Compensation method exhibits the largest bias, highlighting its limitations in accurately capturing global velocity features.

Following the analysis of normalized U-velocity around the wing, a similar comparison was conducted for the normalized V-velocity. In most steady flows around wings, the V-velocity is typically an order of magnitude smaller than the U-velocity, making accurate estimation of V-velocity challenging, even for traditional PIV, due to limitations inherent in cross-correlation algorithms. Figure 15 shows the normalized V-velocity contours around the wing at $\alpha = 8^\circ$ for all three freestream velocities tested. Once again, the event-based methods demonstrate a reasonable match to the traditional PIV results, capturing key flow features around the wing. Due to the high resolution achieved by tracking individual tracer particles, the event-based methods resolve flow features, particularly on the upper surface and in the wing's wake, more effectively than PIV. In contrast, the use of interrogation window sizes and 50% overlap in traditional PIV results in smoothed gradients, reducing its ability to resolve finer flow details in these regions.

The histograms corresponding to the contours in Figure 15 are shown in Figure 16 for different angles of attack (α) at a freestream velocity of 0.37 m/s. Interestingly, the constant bias observed in normalized U-velocity between

PIV and the event-based methods is not present in the V-velocity results. Across all angles of attack, the event-based methods exhibit a higher degree of overlap with PIV, demonstrating their accuracy in capturing vertical velocity components. As the angle of attack increases, the V-velocity histograms broaden, similar to the trend observed for U-velocity, reflecting the increased variability in the flowfield caused by separation and stall. Notably, the peaks and valleys in the V-velocity histograms, associated with distinct regions of the flowfield (e.g., upper surface, wake), are accurately captured by the event-based methods. Among these, the weighted tracking methods (WT-Linear and WT-Non-Linear) align most closely with PIV, while the Kalman Filter method exhibits greater deviation.




Figure 15 Comparison of normalized V-velocity contours from PIV and event-based methods at $\alpha = 8^\circ$ and freestream velocities of 0.2 m/s, 0.3 m/s, and 0.37 m/s. Event-based methods resolve flow features on the upper surface and in the wake with greater detail than traditional PIV, which smooths gradients due to its window-based approach




Figure 16 Probability density functions (PDFs) of normalized V-velocity for PIV and event-based methods at angles of attack from $\alpha = 0^\circ$ to $\alpha = 10^\circ$ at 0.37 m/s for $U_\infty = 0.37$ m/s. Event-based methods show high overlap with PIV distributions, with weighted tracking methods achieving the closest match.

Figure 17 illustrates the variation of the mean and median of normalized V-velocity as a function of angle of attack (α) for all five methods and three freestream velocities tested. Similar to the results in Figure 14, the mean and median values capture the V-velocity trends on the upper surface, lower surface, and wake, reflecting the features observed in Figure 15. As the angle of attack increases, the mean and median V-velocity decrease, driven by increased flow separation and a corresponding rise in negative V-velocity components. The event-based methods closely replicate the trends and magnitudes of PIV, as shown in the histogram analysis in Figure 16. However, it is unclear why a bias error is consistently observed in the normalized U-velocity estimates but not in the V-velocity estimates from the event-based methods.

Despite this uncertainty, the strong agreement between the mean, median, and overall distribution of U- and V-velocity from event-based methods and PIV highlights the suitability of event-based methods for velocimetry. These results reinforce their potential as a viable alternative to traditional PIV, particularly given their ability to capture flow features across the upper and lower surfaces and wake regions effectively.




Figure 17 Mean and median V-velocity values for PIV and event-based methods as a function of angle of attack at freestream velocities of 0.2 m/s, 0.3 m/s, and 0.37 m/s. Event-based methods demonstrate trends and magnitudes comparable to PIV, with no observable bias in V-velocity.

V. Conclusion

This study presents a comprehensive evaluation of event-based methods for velocimetry in comparison to traditional PIV, focusing on the flow around an SD7003 wing at various freestream velocities and angles of attack. The results demonstrate that event-based methods, particularly the weighted tracking algorithms (WT-Linear and WT-Non-Linear), offer strong agreement with PIV across a range of flow features, including velocity distributions, near-surface flow dynamics, and global velocity trends. Despite the inherent differences in data acquisition and processing approaches between event-based and frame-based techniques, the findings validate the capability of event-based methods to serve as reliable alternatives for flow diagnostics.

The analysis of normalized U and V-velocity contours and distributions highlighted several key findings:

1. Event-based methods effectively captured global trends in the mean and median of normalized U and V-velocity across all tested velocities and angles of attack. While a consistent bias error was observed in the U-velocity estimates, the V-velocity estimates showed no such bias, aligning closely with PIV results.
2. Event-based methods resolved near-surface flow features, such as displacement thickness and pressure gradients, more accurately than traditional PIV, which struggled with reflections and smoothing due to interrogation window overlap.

3. Event-based methods accurately captured the peaks and valleys in velocity histograms, reflecting the distinct regions of the flowfield. The weighted tracking methods showed the closest agreement with PIV, while the Kalman Filter method exhibited some deviations.
4. Due to their particle-level resolution, event-based methods outperformed PIV in capturing sharp gradients and resolving subtle flow dynamics, particularly in regions of high velocity variability, such as the wing wake and areas of separation.

The findings also underscore the inherent advantages of event-based methods over PIV. Unlike PIV, which relies on optimized frame rates and interrogation window sizes that can smooth gradients and reduce resolution, event-based methods operate frame-free and track individual particles in real time. This allows them to provide high-resolution velocity data across all regions of the flowfield, including areas with steep gradients or low particle displacements.

The bias observed in the U-velocity is hypothesized to result from improper tuning of the methods. For example, the Kalman Filter approach involves several variables, such as measurement noise and initial conditions, that can significantly affect the accuracy of the final results. Similarly, the Motion Compensation algorithm relies on adjusting the observation frame to align with the expected flowfield velocity. The range and resolution of the expected flowfield velocity provided as input to this method can have a substantial impact on its performance. Even the weighted tracking methods include several tuning parameters that can influence the accuracy of the final outcomes. Performing a comprehensive sensitivity analysis of these input parameters across all methods is the focus of future work and will be discussed in a follow-up paper.

VI. Acknowledgement

SG is grateful for the support from Air Force Office of Scientific Research (AFOSR) monitored by Dr. Gregg Abate (Grant no: FA9550-23-1-0707)

VII. References

- [1] Mahowald, M.: VLSI analogs of neuronal visual processing: a synthesis of form and function. Ph.D. thesis, California Institute of Technology Pasadena (1992)
- [2] Lichtsteiner, Patrick, Christoph Posch, and Tobi Delbruck. "A 128 x128 120 dB 15 μ s latency asynchronous temporal contrast vision sensor." *IEEE journal of solid-state circuits* 43, no. 2 (2008): 566-576.
- [3] Posch, Christoph, Teresa Serrano-Gotarredona, Bernabe Linares-Barranco, and Tobi Delbruck. "Retinomorphic event-based vision sensors: bioinspired cameras with spiking output." *Proceedings of the IEEE* 102, no. 10 (2014): 1470-1484.
- [4] Borer, David, T. Delbruck, and Thomas Rösger. "Three-dimensional particle tracking velocimetry using dynamic vision sensors." *Experiments in Fluids* 58, no. 12 (2017): 1-7.
- [5] Drazen, David, Patrick Lichtsteiner, Philipp Häfliger, Tobi Delbrück, and Atle Jensen. "Toward real-time particle tracking using an event-based dynamic vision sensor." *Experiments in Fluids* 51, no. 5 (2011): 1465-1469.
- [6] Ni, Zhenjiang, Cécile Pacoret, Ryad Benosman, Siohoi Ieng, and Stéphane RÉGNIER*. "Asynchronous event-based high speed vision for microparticle tracking." *Journal of microscopy* 245, no. 3 (2012): 236-244.
- [7] Wang, Yuanhao, Ramzi Idoughi, and Wolfgang Heidrich. "Stereo event-based particle tracking velocimetry for 3d fluid flow reconstruction." In *European Conference on Computer Vision*, pp. 36-53. Springer, Cham, 2020.

- [8] Willert, Christian E., and Joachim Klinner. "Event-based imaging velocimetry: an assessment of event-based cameras for the measurement of fluid flows." *Experiments in Fluids* 63, no. 6 (2022): 101.
- [9] "Event-Based Vision Applications." PROPHESSEE, May 16, 2022. <https://www.prophesee.ai/event-based-vision-applications/>
- [10] Tayarani-Najaran, Mohammad-Hassan, and Michael Schmuker. "Event-based sensing and signal processing in the visual, auditory, and olfactory domain: a review." *Frontiers in Neural Circuits* 15 (2021): 610446.
- [11] AlSattam, Osama A., Michael P. Mongin, Andrew Killian, Sidaard Gunasekaran, and Keigo Hirakawa. "Toward Event-Based Noise-Robust High Density Particle Velocimetry." In *AIAA SCITECH 2024 Forum*, p. 2663. 2024.
- [12] AlSattam, Osama A. "Noise Robust Particle Event Velocimetry with A Kalman Filter-Based Tracking." PhD diss., University of Dayton, 2024.
- [13] AlSattam, Osama, Michael Mongin, Mitchell Grose, Sidaard Gunasekaran, and Keigo Hirakawa. "KF-PEV: a causal Kalman filter-based particle event velocimetry." *Experiments in Fluids* 65, no. 9 (2024): 141.
- [14] Gallego, Guillermo, Henri Rebecq, and Davide Scaramuzza. "A unifying contrast maximization framework for event cameras, with applications to motion, depth, and optical flow estimation." In *Proceedings of the IEEE/CVF Conference on Computer Vision and Pattern Recognition*, pp. 3867–3876. 2018. <https://doi.org/10.1109/CVPR.2018.00407>.
- [15] Lynch, K. P. "Fluere for Particle Image Velocimetry: User Manual." (2011).