
Response
trip to first switching
Sectionalizing
to first customers restored
Repair
to last customer restored
(i) Crew-based sectionalizing
night call-out
26 to 68 min
crew switching, megger
38 to 63 min
repair
92 to 941 min after trip
(ii) FPI-assisted remote sectionalizing
night call-out
26 to 68 min
remote switching, 6 to 22 min
crew zone, 38 to 63 min
repair
92 to 941 min after trip
(iii) Automated FLISR
FLISR isolation and restoration, 1 to 5 min
night call-out
crew zone, 38 to 63 min
repair
92 to 941 min after trip
automatic (protection, ADMS)
control room, remote
field crew, on site
call-out of operator and crew