

400/220/110/66 kV TRANSMISSION INTERRUPTIONS FOR LC,LS & FAULTS FOR THE MONTH OF DECEMBER-2024

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA - HV2)	MACHE_110	12:16	14:23	2:07	LINE CLEAR AVAILED
2	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	BAILHONGAL_110	09:55	16:22	6:27	LINE CLEAR AVAILED
3	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (10MVA1)	MKHUBLI_110	09:00	17:45	8:45	LINE CLEAR AVAILED
4	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BAILHONGAL_110	09:55	16:20	6:25	LINE CLEAR AVAILED
5	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BENAKATTI_110	14:09	14:20	0:11	LINE CLEAR AVAILED
6	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3 (20MVA2)	MKHUBLI_110	09:00	17:45	8:45	LINE CLEAR AVAILED
7	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1 (20MVA1)	MKHUBLI_110	09:03	14:50	5:47	LINE CLEAR AVAILED
8	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	BAILHONGAL_110	09:55	16:21	6:26	LINE CLEAR AVAILED
9	01-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	BAILHONGAL_110	09:55	16:21	6:26	LINE CLEAR AVAILED
10	01-Dec-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA1	AMBEWADI_220	18:00	18:43	0:43	TRIPPED ON FAULT
11	01-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI1	ATHANI_220	05:55	19:30	13:35	LINE CLEAR AVAILED
12	01-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI2	ATHANI_220	05:55	19:31	13:36	LINE CLEAR AVAILED
13	01-Dec-24	BAGALKOTE	110	LINE	BAILHONGAL-MK HUBLI	BAILHONGAL_110	09:55	16:18	6:23	LINE CLEAR AVAILED
14	01-Dec-24	BAGALKOTE	110	LINE	GHATAPRABHA220- GHATAPRABHA1	GHATAPRABHA_220	10:20	14:41	4:21	LINE CLEAR AVAILED
15	01-Dec-24	BAGALKOTE	110	LINE	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_220	10:20	14:42	4:22	LINE CLEAR AVAILED
16	01-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
17	01-Dec-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR1	HAVERI_220	15:15 (30.11.2024)			LINE CLEAR AVAILED
18	01-Dec-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR2	HAVERI_220	15:15 (30.11.2024)			LINE CLEAR AVAILED
19	01-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	19:22 (30.11.2024)	9:59 (01.12.2024)	14:37	LINE CLEAR AVAILED
20	01-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
21	01-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
22	01-Dec-24	BAGALKOTE	110	LINE	HUNGUND-JINDAL(JSW)	HUNGUND_110	06:00	06:18	0:18	TRIPPED ON FAULT
23	01-Dec-24	BAGALKOTE	110	LINE	HUNGUN-JINDAL	HUNAGUND_110	06:00	06:18	0:18	TRIPPED ON FAULT
24	01-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	12:32 (21.10.2024)			LINE CLEAR AVAILED
25	01-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
26	01-Dec-24	BAGALKOTE	110	LINE	MKHUBLI-KITTUR	STATION NOT AFFECTED MKHUBLI_110	08:40	14:25	5:45	LINE CLEAR AVAILED
27	01-Dec-24	BAGALKOTE	110	LINE	MKHUBLI-MKH2	MKHUBLI_110	09:10	14:40	5:30	LINE CLEAR AVAILED
28	01-Dec-24	BAGALKOTE	110	LINE	MRUTHYUN-L2-NARENDRA	MRUTHYUNJAYA NAGAR_110	05:13	09:11	3:58	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
29	01-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
30	01-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
31	01-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
32	01-Dec-24	BAGALKOTE	110	LINE	SOUDATTI220-MMCL	SOUDATTI_220	13:10	13:16	0:06	LINE CLEAR AVAILED
33	01-Dec-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-HIREBAGEWADI-I	SUVARNA SOUDA_110	07:52	17:15	9:23	LINE CLEAR AVAILED
34	01-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
35	01-Dec-24	BANGALORE	220	LINE	220KV BIDADI PGCIL 400 - BIDADI 220 -1	NO STATION AFFECTED	12:20	15:37	03:17	LINE CLEAR AVAILED
36	01-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
37	01-Dec-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - BIDADI 220 -1	NO STATION AFFECTED	11:35	15:41	04:06	LINE CLEAR AVAILED
38	01-Dec-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - BIDADI 220 -2	NO STATION AFFECTED	11:35	15:41	04:06	LINE CLEAR AVAILED
39	01-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
40	01-Dec-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	10:50	10:54	00:04	LINE CLEAR AVAILED
41	01-Dec-24	BANGALORE	66	LINE	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	17:52	18:08	00:16	TRIPPED ON FAULT
42	01-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - CHIKKENAHALLI LINK	CHIKKENAHALLI, SHIVANAHALLI, ALLIMARADANAHALLI	16:02	16:50	00:48	TRIPPED ON FAULT
43	01-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - WISTRON (EHT)	WISTRON(EHT)	23:40	23:50	00:10	LINE CLEAR AVAILED
44	01-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASLU	07:20	07:37	00:17	TRIPPED ON FAULT
45	01-Dec-24	BANGALORE	66	LINE	66KV RBI - ELITA PROMENADE	ELITA PROMENENDE	10:53	10:58	00:05	LINE CLEAR AVAILED
46	01-Dec-24	BANGALORE	66	LINE	66KV RBI - ELITA PROMENADE	RBI	15:40	15:45	00:05	LINE CLEAR AVAILED
47	01-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	11:09	11:14	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
48	01-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	10:50	10:56	00:06	LINE CLEAR AVAILED
49	01-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI	10:53	10:58	00:05	LINE CLEAR AVAILED
50	01-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	14:41	15:16	00:35	LINE CLEAR AVAILED
51	01-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	09:09	09:14	00:05	LINE CLEAR AVAILED
52	01-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST VIEW	15:43	15:46	00:03	LINE CLEAR AVAILED
53	01-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	16:22	16:29	00:07	LINE CLEAR AVAILED
54	01-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	18:39	19:09	00:30	TRIPPED ON FAULT
55	01-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	HALAGURU, HONNIGANAHALLI,ACHALU	11:16	11:31	00:15	TRIPPED ON FAULT
56	01-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BG ROAD	20:40	20:45	00:05	TRIPPED ON FAULT
57	01-Dec-24	BANGALORE	220	TRANSFORMER	HV1	BRINDAVANA 220	09:04	13:25	04:21	LINE CLEAR AVAILED
58	01-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	22:47	22:57	00:10	TRIPPED ON FAULT
59	01-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	09:12	09:17	00:05	LINE CLEAR AVAILED
60	01-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	17:30	17:55	00:25	LINE CLEAR AVAILED
61	01-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	11:15	11:20	00:05	TRIPPED ON FAULT
62	01-Dec-24	BANGALORE	220	TRANSFORMER	HV2	BRINDAVANA 220	13:35	16:55	03:20	LINE CLEAR AVAILED
63	01-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUNDLU KOTTUR	18:10	18:30	00:20	LINE CLEAR AVAILED
64	01-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	09:12	09:17	00:05	LINE CLEAR AVAILED
65	01-Dec-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJHALLI_66,HOSAHALLI_66,HUDEM_66	19:40	20:15	00:35	MAIN SUPPLY FAILURE
66	01-Dec-24	GULBARGA	66	LINE	HALWARTHY-GINIGERA	GINIGERA_66	10:50	15:10	04:20	LINE CLEAR AVAILED
67	01-Dec-24	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	09:45	09:50	00:05	TRIPPED ON FAULT
68	01-Dec-24	GULBARGA	110	LINE	KEMBHAVI-SHAHAPUR	KEMBHAVI_110	23:58:00	12:19	12:21	LINE CLEAR AVAILED
69	01-Dec-24	GULBARGA	110	LINE	KEMBHAVI-SHAHAPUR	KEMBHAVI_110, KBJNL_IPP	23:29	23:35	00:06	TRIPPED ON FAULT
70	01-Dec-24	GULBARGA	66	LINE	KUDILIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66,HOSAHALLI_66,HUDEM_66	19:40(01.12.2024)			TRIPPED ON FAULT
71	01-Dec-24	GULBARGA	110	LINE	LINGASUGUR-KPRL	LINGASUGUR_220	21:38	21:45	00:07	TRIPPED ON FAULT
72	01-Dec-24	GULBARGA	110	LINE	NAGNOOR-SHAHAPUR	NAGNOOR_110	10:50	11:53	01:03	LINE CLEAR AVAILED
73	01-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
74	01-Dec-24	HASAN	110	LINE	ARSK2-ARASIKERE	ARASIKERE_220	08:25	08:33	00:08	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
75	01-Dec-24	HASAN	220	LINE	GERSOPA-TALGUPA2	gerusoppa_gen	22:38(01.12.2024)			TRIPPED ON FAULT
76	01-Dec-24	HASAN	110	TRANSFORMER	HV1	ARASIKERE_110	16:39	16:56	00:17	TRIPPED ON FAULT
77	01-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	17:45(29.11.2024)	14:36(01.12.2024)	44:51HRS	LINE CLEAR AVAILED
78	01-Dec-24	HASAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAG	08:16	09:44	01:28	LINE CLEAR AVAILED
79	01-Dec-24	HASAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	22:38(01.12.2024)			TRIPPED ON FAULT
80	01-Dec-24	HASAN	66	LINE	TAVAREC-HONNALLI	TAVAREC	12:50	13:00	00:10	TRIPPED ON FAULT
81	01-Dec-24	MYSORE	66	LINE	BEGUR 220-66/11kV BEGUR-1	NO STATIONS EFFECTED	06:08	06:17	00:09	TRIPPED ON FAULT
82	01-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
83	01-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
84	01-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI -1	NO STATIONS EFFECTED	9:08 (30/11/2024)			LINE CLEAR AVAILED
85	01-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI -2	NO STATIONS EFFECTED	9:08 (30/11/2024)			LINE CLEAR AVAILED
86	01-Dec-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	11:15	11:35	00:20	MAIN SUPPLY FAILURE
87	01-Dec-24	MYSORE	66	TRANSFORMER	HV1	MADESWARAPURA_66	17:05	17:15	00:10	LINE CLEAR AVAILED
88	01-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
89	01-Dec-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	11:15	11:35	00:20	MAIN SUPPLY FAILURE
90	01-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
91	01-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
92	01-Dec-24	MYSORE	66	LINE	PARINAMIPURA- THALAKADU	NO STATIONS EFFECTED	06:05	06:15	00:10	TRIPPED ON FAULT
93	01-Dec-24	MYSORE	66	LINE	PONNAMPETE- SRIMANGALA	SRIMANGALA_66	17:13	17:18	00:05	TRIPPED ON FAULT
94	01-Dec-24	MYSORE	66	LINE	THUMBLA-CHIDRAVALLI- MEGHALAPURA	NO STATIONS EFFECTED	16:32	16:42	00:10	TRIPPED ON FAULT
95	01-Dec-24	MYSORE	66	LINE	TUBINAKERE-B.SEEHALLI- TARIPURA-ARAKERE	ARAKERE_66 CHAMLAPURA_66 GAMANAHALLY_66 TARIPURA_66	17:43	17:59	00:16	TRIPPED ON FAULT
96	01-Dec-24	TUMKUR	220	LINE	220KV GUTTUR - DAVANGERE SRS 220 LINE-3	DAVANAGERERE220KV & 66KV O/G LINES	12:02	15:17	3:15	TRIPPED ON FAULT
97	01-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV BANUVALLI LINE	66KV NANDIGUDI,BANUVALLI,E HT CARGIL	13:04	13:16	0:12	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
98	01-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	19:28	19:38	0:10	TRIPPED ON FAULT
99	01-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	19:38	20:10	0:32	TRIPPED ON FAULT
100	01-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	20:38	23:59	0:22	TRIPPED ON FAULT
101	01-Dec-24	TUMKUR	220	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	20:10	20:38	0:28	TRIPPED ON FAULT
102	01-Dec-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-VIJAYA STEEL	VIJAYA STEEL	14:30	20:46	6:16	LINE CLEAR AVAIED
103	01-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (DABASPETE)	KOLALA_66, URDIGERE_66	11:35	11:55	0:20	LINE CLEAR AVAIED
104	01-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
105	01-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
106	01-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
107	01-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
108	01-Dec-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	11:19	11:31	0:12	TRIPPED ON FAULT
109	01-Dec-24	TUMKUR	66	LINE	HOSADURGA(MADHURE) 220KV-NEERGUNDA_66KV	66KV HOSADURGA, NEERGUNDA	11:50	12:00	0:10	TRIPPED ON FAULT
110	01-Dec-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE_66	PDKOTE_66	6:40	6:45	0:05	MAIN SUPPLY FAILURE
111	01-Dec-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE_66 I/C LINE-2	PDKOTE_66	6:40	7:05	0:25	TRIPPED ON FAULT
112	01-Dec-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE_66 I/C LINE-2	PDKOTE_66	8:15	8:25	0:10	TRIPPED ON FAULT
113	01-Dec-24	TUMKUR	66	LINE	SASALUHALLA-CHIKKAJAJUR	SASALUHALLA_66	10:00	11:05	1:05	TRIPPED ON FAULT
114	01-Dec-24	TUMKUR	66	LINE	SHYAGALE_66-KEREBILCHI_66	66KV KEREBILICHI , WATER WORKS SS	13:15	13:20	0:05	TRIPPED ON FAULT
115	01-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA KOLALA_66	KOLALA_66	1:49	2:15	0:26	LINE CLEAR AVAIED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
116	01-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA KOLALA_66	KOLALA_66	8:10	10:42	2:32	LINE CLEAR AVAILED
117	01-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA TURUVANUR_66	TURUVANUR_66	12:17	12:27	0:10	TRIPPED ON FAULT
118	01-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
119	01-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
120	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(B)_110	13:16	13:21	0:05	TRIPPED ON FAULT
121	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(B)_110	18:09	18:12	0:03	TRIPPED ON FAULT
122	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	DEVANGOAN_110	16:58	17:08	0:10	LINE CLEAR AVAILED
123	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	LAKAMANAHALLI_110	15:37	18:28	2:51	LINE CLEAR AVAILED
124	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	HATTARAGI_110	09:43	18:17	8:34	LINE CLEAR AVAILED
125	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	PG HUNSHYAL_110	16:25	17:39	1:14	LINE CLEAR AVAILED
126	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	UCHAGOAN_110	12:01	12:25	0:24	LINE CLEAR AVAILED
127	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	KADANAKOPPA_110	17:28	17:48	0:20	TRIPPED ON FAULT
128	02-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	GAJENDRAGAD_110	16:44	17:05	0:21	TRIPPED ON FAULT
129	02-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	NARENDRA_220	11:35	12:46	1:11	LINE CLEAR AVAILED
130	02-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	NARENDRA_220	14:20	17:20	3:00	LINE CLEAR AVAILED
131	02-Dec-24	BAGALKOTE	110	LINE	AEQUS220-LN4(HATTARGI)	AEQUS_220	9:49	13:32	3:43	LINE CLEAR AVAILED
132	02-Dec-24	BAGALKOTE	110	LINE	ALBAL-RAY SOLAR	ALBAL_110	22:37	22:58	0:21	TRIPPED ON FAULT
133	02-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI1	ATHANI_220	06:14	19:27	13:13	LINE CLEAR AVAILED
134	02-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI2	ATHANI_220	06:14	19:28	13:14	LINE CLEAR AVAILED
135	02-Dec-24	BAGALKOTE	220	LINE	ATHANI220-AIGALI1	ATHANI_220	06:17	06:52	0:35	TRIPPED ON FAULT
136	02-Dec-24	BAGALKOTE	110	LINE	ATHANI220-BALIGERI	ATHANI_220	06:17	06:35	0:18	TRIPPED ON FAULT
137	02-Dec-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(HIREMASALI)	ATHARGA_110	03:24	03:35	0:11	TRIPPED ON FAULT
138	02-Dec-24	BAGALKOTE	110	LINE	BABLESHWAR- MAMADAPUR(TIKOTA)	BABLESHWAR_110	19:53 (18.11.2024)	15:06 (02.12.2024)	331:13:00	LINE CLEAR AVAILED
139	02-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 1	BELGAUM_220	10:31	17:15	6:44	LINE CLEAR AVAILED
140	02-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 2	BELGAUM_220	10:31	17:15	6:44	LINE CLEAR AVAILED
141	02-Dec-24	BAGALKOTE	220	LINE	BELGAUM-KANABARGI1	BELGAUM_220	10:47	15:24	4:37	LINE CLEAR AVAILED
142	02-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
143	02-Dec-24	BAGALKOTE	110	LINE	HATTARAGI-HUKKERI (SANGAM SUGARS)	HATTARAGI_110	09:39	18:17	8:38	LINE CLEAR AVAILED
144	02-Dec-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR1	HAVERI_220	15:15 (30.11.2024)	18:48 (02.12.2024)	51:33:00	LINE CLEAR AVAILED
145	02-Dec-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR2	HAVERI_220	15:15 (30.11.2024)	18:48 (02.12.2024)	51:33:00	LINE CLEAR AVAILED
146	02-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
147	02-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
148	02-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	12:32 (21.10.2024)			LINE CLEAR AVAILED
149	02-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-RANNABELAGALI	MAHALINGAPUR_220	18:40 (02.12.2024)			TRIPPED ON FAULT
150	02-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
151	02-Dec-24	BAGALKOTE	220	LINE	NARENDRA- KANABARGI	NARENDRA_220	10:40	17:10	6:30	LINE CLEAR AVAILED
152	02-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
153	02-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
154	02-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
155	02-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL(HONAVADA)	TIKOTA_110	15:06	17:59	2:53	LINE CLEAR AVAILED
156	02-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
157	02-Dec-24	BAGALKOTE	110	LINE	YADAWAD-ISEL(ISARA SOLAR)	YADAWAD_110	18:45	19:42	0:57	LINE CLEAR AVAILED
158	02-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
159	02-Dec-24	BANGALORE	220	LINE	220KV JIGANI 220 - YARANDANAHALLI 220	NO STATION AFFECTED	18:25	23:59	05:34	LINE CLEAR AVAILED
160	02-Dec-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - YARANDANAHALLI 2	NO STATION AFFECTED	18:25	23:59	05:34	LINE CLEAR AVAILED
161	02-Dec-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - YARANDANAHALLI 3	NO STATION AFFECTED	17:50	23:59	06:09	LINE CLEAR AVAILED
162	02-Dec-24	BANGALORE	220	LINE	220KV NAGANATHAPURA 220 - HSR LAYOUT 220	NO STATION AFFECTED	15:20	16:09	00:49	LINE CLEAR AVAILED
163	02-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
164	02-Dec-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	BG ROAD	06:07	06:12	00:05	LINE CLEAR AVAILED
165	02-Dec-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	09:37	10:04	00:27	TRIPPED ON FAULT
166	02-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, MANDIKAL, GUDIBANDE	17:52	18:02	00:10	TRIPPED ON FAULT
167	02-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	00:37	00:45	00:08	TRIPPED ON FAULT
168	02-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	10:41	10:55	00:14	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
169	02-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - KC VALLEY (EHT)	KC VALLEY(EHT)	07:32	08:27	00:55	TRIPPED ON FAULT
170	02-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - KC VALLEY (EHT)	KC VALLEY(EHT)	11:25	12:25	01:00	TRIPPED ON FAULT
171	02-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASANUR	DALASANUR, MALLASANDRA, DRDO	17:35	17:47	00:12	TRIPPED ON FAULT
172	02-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	18:35	19:04	00:29	LINE CLEAR AVAILED
173	02-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	04:03	11:58	07:55	TRIPPED ON FAULT
174	02-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	06:00	10:00	04:00	TRIPPED ON FAULT
175	02-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	10:00	11:33	01:33	LINE CLEAR AVAILED
176	02-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	09:38	11:30	01:52	LINE CLEAR AVAILED
177	02-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	NO STATION AFFECTED	15:17	15:32	00:15	TRIPPED ON FAULT
178	02-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	18:50	18:59	00:09	LINE CLEAR AVAILED
179	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	09:54	10:17	00:23	TRIPPED ON FAULT
180	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HONNIGANAHALLI	11:48	11:54	00:06	TRIPPED ON FAULT
181	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	06:17	06:22	00:05	LINE CLEAR AVAILED
182	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MITTEMARI 220	22:40	23:28	00:48	TRIPPED ON FAULT
183	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SIDLAGATTA	00:40	01:00	00:20	TRIPPED ON FAULT
184	02-Dec-24	BANGALORE	220	TRANSFORMER	HV1	YARANDANAHALLI 220	18:10	23:59	05:49	LINE CLEAR AVAILED
185	02-Dec-24	BANGALORE	66	TRANSFORMER	HV1	YENNIGADALE	14:05	14:30	00:25	LINE CLEAR AVAILED
186	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTUR YELAHANKA	14:30	14:46	00:16	TRIPPED ON FAULT
187	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	AVANI	14:55	15:10	00:15	TRIPPED ON FAULT
188	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	AVANI	17:25	17:55	00:30	TRIPPED ON FAULT
189	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KEMBODI	21:20	21:40	00:20	TRIPPED ON FAULT
190	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	06:17	06:22	00:05	LINE CLEAR AVAILED
191	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NELAKADRENAHALLI	08:40	08:50	00:10	TRIPPED ON FAULT
192	02-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR_66	16:07	16:15	00:08	TRIPPED ON FAULT
193	02-Dec-24	BANGALORE	220	TRANSFORMER	HV2	YARANDANAHALLI 220	18:04	18:10	00:06	LINE CLEAR AVAILED
194	02-Dec-24	BANGALORE	66	TRANSFORMER	HV3	HOSKOTE 66	13:45	14:05	00:20	LINE CLEAR AVAILED
195	02-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	08:48	10:21	01:33	TRIPPED ON FAULT
196	02-Dec-24	GULBARGA	400	LINE	BTPS-GUTTUR(JINDAL)	GUTTUR_400	22:33(2.12.2024)			TRIPPED ON FAULT
197	02-Dec-24	GULBARGA	400	LINE	BTPS-RTPS	BTPS_400	11:20	17:59	06:39	LINE CLEAR AVAILED
198	02-Dec-24	GULBARGA	66	TRANSFORMER	HV1	GINIGERA_66	17:40	18:35	00:55	LINE CLEAR AVAILED
199	02-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KALBURGI NORTH_110	23:10	23:18	00:08	TRIPPED ON FAULT
200	02-Dec-24	GULBARGA	66	TRANSFORMER	HV1	UCHCHANGIDURGA_66	14:10	14:20	00:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
201	02-Dec-24	GULBARGA	110	TRANSFORMER	HV2	ALIPUR_220	12:52	12:58	00:06	TRIPPED ON FAULT
202	02-Dec-24	GULBARGA	220	TRANSFORMER	HV2	LINGASUGUR_220	00:48	01:06	00:18	TRIPPED ON FAULT
203	02-Dec-24	GULBARGA	110	TRANSFORMER	HV3	BELLARY NOTH	14:06	14:11	00:05	LINE CLEAR AVAILED
204	02-Dec-24	GULBARGA	66	LINE	ITTAGGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66,UJJANI_66	12:14	18:15	06:01	LINE CLEAR AVAILED
205	02-Dec-24	GULBARGA	66	LINE	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66	06:33	07:02	00:29	TRIPPED ON FAULT
206	02-Dec-24	GULBARGA	66	LINE	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,TBPCL_IP	05:46	06:05	00:19	TRIPPED ON FAULT
207	02-Dec-24	GULBARGA	110	LINE	KHANAPUR-WADGERA	WADAGERA_110	19:26	19:31	00:05	TRIPPED ON FAULT
208	02-Dec-24	GULBARGA	66	LINE	KUDILIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66,HOSAHALLI_66,HUDEM_66	19:40(01.12.2024)	2:15(2.12.2024)	06:35	TRIPPED ON FAULT
209	02-Dec-24	GULBARGA	220	LINE	LINGAPUR-GDHALLI2	LINGAPUR_220	10:22	17:56	07:34	LINE CLEAR AVAILED
210	02-Dec-24	GULBARGA	110	LINE	LINGASUGUR-CMHS_IPP	LINGASUGUR_220	05:01	05:07	00:06	TRIPPED ON FAULT
211	02-Dec-24	GULBARGA	110	LINE	LINGASUGUR-KPRL	LINGASUGUR_220	01:15	10:57	09:42	TRIPPED ON FAULT
212	02-Dec-24	GULBARGA	110	TRANSFORMER	LV1	LINGASUGUR_220	00:48	01:11	00:23	TRIPPED ON FAULT
213	02-Dec-24	GULBARGA	110	TRANSFORMER	LV2	LINGASUGUR_220	00:48	01:07	00:19	TRIPPED ON FAULT
214	02-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
215	02-Dec-24	GULBARGA	220	LINE	SHAHAPUR-FIROZABAD-2	SHAHAPUR_220	22:00	23:59	02:00	LINE CLEAR AVAILED
216	02-Dec-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	05:43	05:50	00:07	TRIPPED ON FAULT
217	02-Dec-24	HASAN	110	LINE	BAIKAM-BAJPE	BAIKAMPADY_110	17:45	19:15	01:30	MAIN SUPPLY FAILURE
218	02-Dec-24	HASAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADY_110	17:45	19:42	01:57	TRIPPED ON FAULT
219	02-Dec-24	HASAN	110	LINE	BANTWA-SALATTUR	BANTWAL_110	16:34	17:06	00:32	TRIPPED ON FAULT
220	02-Dec-24	HASAN	66	LINE	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	08:17	08:22	00:05	MAIN SUPPLY FAILURE
221	02-Dec-24	HASAN	220	LINE	GERSOPA-TALGUPA2	gerusoppa_gen	22:38(01.12.2024)			TRIPPED ON FAULT
222	02-Dec-24	HASAN	66	LINE	HASSN22-HN PURA	HASSAN_220	18:10	19:33	01:23	TRIPPED ON FAULT
223	02-Dec-24	HASAN	220	LINE	HASSN22-Shomoga	HASSAN_220	10:20	17:10	06:50	LINE CLEAR AVAILED
224	02-Dec-24	HASAN	110	LINE	HULICA-HSNGD	HULICAL_110	09:39	09:45	00:06	LINE CLEAR AVAILED
225	02-Dec-24	HASAN	220	TRANSFORMER	HV1	KADUR_220	13:36	13:51	00:15	LINE CLEAR AVAILED
226	02-Dec-24	HASAN	110	TRANSFORMER	HV1	KONAJE_110	16:34	17:06	00:32	MAIN SUPPLY FAILURE
227	02-Dec-24	HASAN	66	TRANSFORMER	HV1	MALLAPURA_66	16:05	16:20	00:15	MAIN SUPPLY FAILURE
228	02-Dec-24	HASAN	66	TRANSFORMER	HV1	SOMANAHALLI_66	14:10	14:29	00:19	TRIPPED ON FAULT
229	02-Dec-24	HASAN	110	TRANSFORMER	HV1	SORABA_110	11:05	11:56	00:51	LINE CLEAR AVAILED
230	02-Dec-24	HASAN	110	TRANSFORMER	HV2	DMKURKE_110	14:00	14:16	00:16	TRIPPED ON FAULT
231	02-Dec-24	HASAN	110	TRANSFORMER	HV2	KAVOOR_220	17:43	18:00	00:17	TRIPPED ON FAULT
232	02-Dec-24	HASAN	110	TRANSFORMER	HV2	KONAJE_110	16:34	17:06	00:32	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
233	02-Dec-24	HASAN	110	TRANSFORMER	HV2	NITTUR_110	19:29	22:52	03:23	TRIPPED ON FAULT
234	02-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	11:15	13:05	01:50	LINE CLEAR AVAILED
235	02-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	14:12	14:14	00:02	LINE CLEAR AVAILED
236	02-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	15:51	16:40	00:49	LINE CLEAR AVAILED
237	02-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	18:43	18:48	00:05	LINE CLEAR AVAILED
238	02-Dec-24	HASAN	110	TRANSFORMER	HV2	SORABA_110	11:05	11:56	00:51	LINE CLEAR AVAILED
239	02-Dec-24	HASAN	110	TRANSFORMER	HV3	KONAJE_110	16:34	17:06	00:32	MAIN SUPPLY FAILURE
240	02-Dec-24	HASAN	110	LINE	KAVOOR-AMR	KAVOOR_220	16:09	16:19	00:10	TRIPPED ON FAULT
241	02-Dec-24	HASAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	15:14	15:46	00:32	TRIPPED ON FAULT
242	02-Dec-24	HASAN	110	TRANSFORMER	LV1	KADUR_220	13:36	13:51	00:15	LINE CLEAR AVAILED
243	02-Dec-24	HASAN	110	LINE	MADHUV-KUNDAPURA	MADHUVANA_110	20:31	21:46	01:15	TRIPPED ON FAULT
244	02-Dec-24	HASAN	220	LINE	MRSSHM-HSN	MRSMG_220	10:21	17:10	06:49	LINE CLEAR AVAILED
245	02-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMG_220	19:55(02.12.2024)			TRIPPED ON FAULT
246	02-Dec-24	HASAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	17:45	19:12	01:27	TRIPPED ON FAULT
247	02-Dec-24	HASAN	110	LINE	MSEZ-KAVOOR	MSEZ_220	17:29	18:40	01:11	TRIPPED ON FAULT
248	02-Dec-24	HASAN	110	LINE	NANDIKU-ISTR	NANDIKUR_110	19:15	20:04	00:49	TRIPPED ON FAULT
249	02-Dec-24	HASAN	110	LINE	NANDIKU-NDKR-SUZLON	NANDIKUR_110	18:15	18:27	00:12	TRIPPED ON FAULT
250	02-Dec-24	HASAN	110	LINE	PUTTUR-PUTTUR2	PUTTUR_220	09:19	12:36	03:17	LINE CLEAR AVAILED
251	02-Dec-24	HASAN	220	LINE	SHRAVITY-TALAGUPPA1	sharavathy_gen	10:24	19:22	08:58	LINE CLEAR AVAILED
252	02-Dec-24	HASAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	11:10	11:20	00:10	TRIPPED ON FAULT
253	02-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	11:05	11:56	00:51	LINE CLEAR AVAILED
254	02-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	10:22	17:03	06:41	LINE CLEAR AVAILED
255	02-Dec-24	HASAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	22:38(01.12.2024)			TRIPPED ON FAULT
256	02-Dec-24	HASAN	66	LINE	UDDURKO-HASSAN1	UDDURKOPLU_66	08:15	08:25	00:10	MAIN SUPPLY FAILURE
257	02-Dec-24	MYSORE	66	LINE	BEGUR-B MATTAKERE	NO STATIONS EFFECTED	02:04	02:12	00:08	TRIPPED ON FAULT
258	02-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
259	02-Dec-24	MYSORE	66	LINE	CHANDALLI-BG PURA	NO STATIONS EFFECTED	17:42	18:21	00:39	TRIPPED ON FAULT
260	02-Dec-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE	TERAKANAMBI_66	19:32	19:39	00:07	TRIPPED ON FAULT
261	02-Dec-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE	TERAKANAMBI_66	20:53	21:06	00:12	TRIPPED ON FAULT
262	02-Dec-24	MYSORE	66	LINE	CRNAGAR-KOLLEGALA	NO STATIONS EFFECTED	21:21	21:36	00:15	TRIPPED ON FAULT
263	02-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
264	02-Dec-24	MYSORE	66	LINE	HARVEY-KABBALLI	NO STATIONS EFFECTED	23:19	23:27	00:07	TRIPPED ON FAULT
265	02-Dec-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66	17:41	17:52	00:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
266	02-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI -1	NO STATIONS EFFECTED	9:08 (30/11/2024)	11:03:00 (2/12/2024)	73:55 HRs	LINE CLEAR AVAILED
267	02-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI -2	NO STATIONS EFFECTED	9:08 (30/11/2024)	11:03:00 (2/12/2024)	73:55 HRs	LINE CLEAR AVAILED
268	02-Dec-24	MYSORE	66	LINE	HEBBANI-VADKEPURA	VADKEPURA_66 KIRUGAVALU_66 MALIYURU_66	07:51	08:01	00:10	TRIPPED ON FAULT
269	02-Dec-24	MYSORE	66	LINE	HOOTAGALLY-BEML	HEBBAL-INDUSTRIAL_66	12:26	16:56	04:29	TRIPPED ON FAULT
270	02-Dec-24	MYSORE	66	TRANSFORMER	HV1	DEVNUR(N'GUD)_66	12:36	12:53	00:16	LINE CLEAR AVAILED
271	02-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
272	02-Dec-24	MYSORE	66	TRANSFORMER	HV2	GUDDENAHALLI_66	11:56	12:03	00:07	TRIPPED ON FAULT
273	02-Dec-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	17:59	20:00	02:00	TRIPPED ON FAULT
274	02-Dec-24	MYSORE	66	LINE	JAIPUR-HAMPAPURA	HAMPAPURA(K)_66	10:09	10:16	00:07	TRIPPED ON FAULT
275	02-Dec-24	MYSORE	66	LINE	KADAKOLA-DOORA	DOORA_66 HULLALLI_66	10:55	11:05	00:10	TRIPPED ON FAULT
276	02-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
277	02-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
278	02-Dec-24	MYSORE	66	LINE	KASALGERE-KOPPA	NO STATIONS EFFECTED	17:46	17:58	00:12	TRIPPED ON FAULT
279	02-Dec-24	MYSORE	66	LINE	KOPPA -KASALGERE	NO STATIONS EFFECTED	17:54	17:59	00:05	TRIPPED ON FAULT
280	02-Dec-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	NO STATIONS EFFECTED	23:14	23:22	00:08	TRIPPED ON FAULT
281	02-Dec-24	MYSORE	66	LINE	MUGUR-CR NAGARA	MUGUR_66	21:22	21:38	00:16	TRIPPED ON FAULT
282	02-Dec-24	MYSORE	66	LINE	PERIYAPATNA-HANGODU-PONNAMPETE	NO STATIONS EFFECTED	03:08	03:14	00:05	TRIPPED ON FAULT
283	02-Dec-24	MYSORE	66	LINE	PERIYAPATNA-HANGODU-PONNAMPETE	NO STATIONS EFFECTED	04:10	11:00	06:49	TRIPPED ON FAULT
284	02-Dec-24	MYSORE	66	LINE	PONNAMPETE-SRIMANGALA	SRIMANGALA_66	00:45	00:50	00:05	TRIPPED ON FAULT
285	02-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	07:51	08:04	00:13	TRIPPED ON FAULT
286	02-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	18:00:00 (2/12/2024)			TRIPPED ON FAULT
287	02-Dec-24	MYSORE	66	LINE	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	07:51	07:57	00:06	TRIPPED ON FAULT
288	02-Dec-24	MYSORE	66	LINE	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	18:00:00 (2/12/2024)			TRIPPED ON FAULT
289	02-Dec-24	MYSORE	66	LINE	SFCSIVA-ATRIA	NO STATIONS EFFECTED	18:00:00 (2/12/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
290	02-Dec-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	17:59	18:21	00:22	TRIPPED ON FAULT
291	02-Dec-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	18:43	18:45	00:01	TRIPPED ON FAULT
292	02-Dec-24	MYSORE	66	LINE	SHIVALLI-TUBINKERE	NAGAMANGALA_66	08:40	09:00	00:20	TRIPPED ON FAULT
293	02-Dec-24	MYSORE	66	LINE	THUMBLA-VYASARAJAPURA	VYASARAJAPURA_66 GARGESHWARI_66	16:17	16:37	00:20	TRIPPED ON FAULT
294	02-Dec-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	21:45:00 (2/12/2024)			TRIPPED ON FAULT
295	02-Dec-24	MYSORE	66	LINE	VYASARAJAPURA-GARGESHWARI	NO STATIONS EFFECTED	16:17	16:37	00:20	TRIPPED ON FAULT
296	02-Dec-24	MYSORE	66	LINE	YEREHALLI HAND POST-HD KOTE	HDKOTE_66 ANTHARSANTHE_66	17:57	18:07	00:10	TRIPPED ON FAULT
297	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA MADHUGIRI_66	MADHUGIRI_66	12:15	12:45	0:30	LINE CLEAR AVAILED
298	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA HULIYURDURGA	HULIYURDURGA_66	9:02	9:17	0:15	TRIPPED ON FAULT
299	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA YADVANI_66	YADVANI_66	13:37	13:47	0:10	TRIPPED ON FAULT
300	02-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,C HILUR	16:01	16:12	0:11	TRIPPED ON FAULT
301	02-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE	66KV BILICHODU, PALLAGATTE,	22:20	24:00	1:40	TRIPPED ON FAULT
302	02-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE, SOKKE	20:20	20:30	0:10	TRIPPED ON FAULT
303	02-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE, SOKKE	20:45	21:00	0:15	TRIPPED ON FAULT
304	02-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE, SOKKE	21:20	21:40	0:20	TRIPPED ON FAULT
305	02-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	14:20	15:05	0:45	LINE CLEAR AVAILED
306	02-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	1:30	2:40	1:10	LINE CLEAR AVAILED
307	02-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	2:50	2:58	0:08	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
308	02-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	23:58:00	1:30	1:32	TRIPPED ON FAULT
309	02-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV - KANCHIPURA_66I	KANCHIPURA_66	13:30	15:05	1:35	LINE CLEAR AVAILED
310	02-Dec-24	TUMKUR	220	LINE	BENKIKERE 220KV- HOSADURGA LINE 1 (MADHURE)	HOSADURGA_220	23:36 (02.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
311	02-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
312	02-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
313	02-Dec-24	TUMKUR	66	LINE	GUTTUR_66KV- HALASABALU_66	GUTTUR_66KV	11:19	11:31	0:12	MAIN SUPPLY FAILURE
314	02-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD_66 LINE-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	14:20	15:05	0:45	LINE CLEAR AVAILED
315	02-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD_66 LINE-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	14:20	15:05	0:45	LINE CLEAR AVAILED
316	02-Dec-24	TUMKUR	220	LINE	HONNALLI 220K- BENKIKERE-2	BENKIKERE_220	23:32 (02.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
317	02-Dec-24	TUMKUR	66	LINE	JAVAGONDANAHALLY- BEVINAHALLY	66KV J G HALLI, BEVINAHALLI	12:40	13:00	0:20	TRIPPED ON FAULT
318	02-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV- SHIMOGA1	110KV MAYSANDRA AND 110 KV HANDANKERE	19:55	23:15	3:20	TRIPPED ON FAULT
319	02-Dec-24	TUMKUR	66	LINE	PANDARAHALLI_66 LINE-1- HIREGUNTANUR- 66	HIREGUNTANUR_66	12:40	13:01	0:21	LINE CLEAR AVAILED
320	02-Dec-24	TUMKUR	66	LINE	PANDARAHALLI_66 LINE-2- HIREGUNTANUR- 66	HIREGUNTANUR_66	12:40	13:01	0:21	LINE CLEAR AVAILED
321	02-Dec-24	TUMKUR	66	LINE	SHIMOGA_220- K.B.CROSS,I/C LINE	110KV MAYSANDRA AND 110 KV HANDANKERE	19:55	20:09	0:14	TRIPPED ON FAULT
322	02-Dec-24	TUMKUR	66	LINE	SHYAGALE_66- KEREILCHI_66	66KV KEREILCHI , WATER WORKS SS	12:50	12:55	0:05	TRIPPED ON FAULT
323	02-Dec-24	TUMKUR	66	LINE	SIRA_220- TAVAREKERE 66KV	66KV TAVAREKERE	13:05	13:33	0:28	TRIPPED ON FAULT
324	02-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66LINE-1	66KV SIRA	7:27	7:35	0:08	TRIPPED ON FAULT
325	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 20MVA MADHUGIRI 66	MADHUGIRI_66	12:05	12:41	0:36	LINE CLEAR AVAILED
326	02-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
327	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA CHANNAGIRI_66	CHANNAGIRI_66	16:25	16:35	0:10	TRIPPED ON FAULT
328	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA CHANNAGIRI_66	CHANNAGIRI_66	17:01	17:11	0:10	TRIPPED ON FAULT
329	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA GOPPENAHALLI_66	GOPPENAHALLI_66	16:05	16:20	0:15	LINE CLEAR AVAILED
330	02-Dec-24	TUMKUR	66	TRANSFORMER	TR-3 20MVA ANTHRASANAHALI 220KV	ANTHRASANAHALI 220KV	11:44	11:52	0:08	TRIPPED ON FAULT
331	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KAGWAD_110	11:35	18:20	6:45	LINE CLEAR AVAILED
332	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RANEENNUR_220	10:38	12:27	1:49	LINE CLEAR AVAILED
333	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA- HV2)	MUDEBIHAL_110	10:48	10:55	0:07	TRIPPED ON FAULT
334	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	DEVAGOAN_110	14:05	15:42	1:37	LINE CLEAR AVAILED
335	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MRUTHYUNJAY NAGAR_110	09:16	16:14	6:58	TRIPPED ON FAULT
336	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KAGWAD_110	10:05	18:26	8:21	LINE CLEAR AVAILED
337	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	YELLPARHATTI_110	12:39	12:48	0:09	TRIPPED ON FAULT
338	03-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	BAGALKOT_220	00:01	00:13	0:12	TRIPPED ON FAULT
339	03-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NAGZHARI1	AMBEWADI_220	10:05	15:37	5:32	LINE CLEAR AVAILED
340	03-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NAGZHARI2	AMBEWADI_220	10:05	15:37	5:32	LINE CLEAR AVAILED
341	03-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI1	ATHANI_220	06:11	19:48	13:37	LINE CLEAR AVAILED
342	03-Dec-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI2	ATHANI_220	06:12	19:49	13:37	LINE CLEAR AVAILED
343	03-Dec-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI (HIREMASALI)	ATHARGA_110	04:43	04:50	0:07	TRIPPED ON FAULT
344	03-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220- KERUR	BAGALKOT_220	00:34	10:38	10:04	TRIPPED ON FAULT
345	03-Dec-24	BAGALKOTE	220	LINE	BELGAUM- KANABARGI2	BELGAUM_220	11:58	16:03	4:05	LINE CLEAR AVAILED
346	03-Dec-24	BAGALKOTE	110	LINE	BELGAUM -MACHE (BGM EXPRESS LINE)	BELGAUM 110(NEHRU NAGAR)	14:00	15:04	1:04	LINE CLEAR AVAILED
347	03-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- NEHRU NAGAR	BELGAUM_220	14:03	15:03	1:00	LINE CLEAR AVAILED
348	03-Dec-24	BAGALKOTE	110	LINE	BYADAGI- HAVERI(RAILWAY)	BYADAGI_110	10:53	10:57	0:04	TRIPPED ON FAULT
349	03-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	17:50 (5.10.2024)	11:46 (3.12.2024)	1409:56:00	LINE CLEAR AVAILED
350	03-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
351	03-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
352	03-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
353	03-Dec-24	BAGALKOTE	220	LINE	HUBLI-NAGZARI-2	HUBLI_220	01:15	06:33	5:18	LINE CLEAR AVAILED
354	03-Dec-24	BAGALKOTE	220	LINE	HUBLI-NAGZARI-3	HUBLI_220	00:31	06:31	6:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
355	03-Dec-24	BAGALKOTE	220	LINE	HUBLI-SIRSI-1	HUBLI_220	1:08	6:48	5:40	LINE CLEAR AVAILED
356	03-Dec-24	BAGALKOTE	220	LINE	HUBLI-SIRSI-2	HUBLI_220	01:11	06:45	5:34	LINE CLEAR AVAILED
357	03-Dec-24	BAGALKOTE	110	LINE	HUNGUND-ILKAL-2	HUNGUND_110	06:26	06:45	0:19	TRIPPED ON FAULT
358	03-Dec-24	BAGALKOTE	110	LINE	HUNGUND-KPJNL	HUNGUND_110	06:26	06:50	0:24	TRIPPED ON FAULT
359	03-Dec-24	BAGALKOTE	110	LINE	ITNAL-RAIBAG(HIDKAL)	ITNAL_110	10:30	19:13	8:43	LINE CLEAR AVAILED
360	03-Dec-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	08:11	10:58	2:47	LINE CLEAR AVAILED
361	03-Dec-24	BAGALKOTE	110	LINE	KERUR-BAGALKOT	KERUR_110	00:43	10:50	10:07	LINE CLEAR AVAILED
362	03-Dec-24	BAGALKOTE	110	LINE	KERUR-KONNUR	KERUR_110	10:43	13:47	3:04	LINE CLEAR AVAILED
363	03-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	12:32 (21.10.2024)	1:12 (3:12:2024)	1020:40:00	LINE CLEAR AVAILED
364	03-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3:12.2024)			LINE CLEAR AVAILED
365	03-Dec-24	BAGALKOTE	110	LINE	KULGERI CROSS-KER (KERUR)	KULGERI CROSS_110	01:12	13:00	11:48	LINE CLEAR AVAILED
366	03-Dec-24	BAGALKOTE	110	LINE	KULIGOD-GMSH (OSTRO MAHA WIND)	KULIGOD_110	11:03	18:03	7:00	LINE CLEAR AVAILED
367	03-Dec-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	12:41	13:07	0:26	LINE CLEAR AVAILED
368	03-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- HIDIKAL	MAHALINGAPUR_220	10:38	18:23	7:45	LINE CLEAR AVAILED
369	03-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- RANNABELAGALI	MAHALINGAPUR_220	18:40 (02.12.2024)	17:42 (03.12.2024)	23:02:00	TRIPPED ON FAULT
370	03-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
371	03-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- KULIGOD	MUGALKHOD_220	11:07	17:54	6:47	LINE CLEAR AVAILED
372	03-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
373	03-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
374	03-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
375	03-Dec-24	BAGALKOTE	110	LINE	SUVARNA SOUDA- HIREBAGEWADI	SUVARNA SOUDA_110	03:02	07:31	4:29	TRIPPED ON FAULT
376	03-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-KNSC	TAKKALAKI_110	18:55	19:45	0:50	LINE CLEAR AVAILED
377	03-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-WRDC	TAKKALAKI_110	18:55	19:41	0:46	LINE CLEAR AVAILED
378	03-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL (BABALESHWARA)	TIKOTA_110	11:15 (03.12.2024)			LINE CLEAR AVAILED
379	03-Dec-24	BAGALKOTE	110	LINE	TUMMINKATTI- F2(RATTIHALLI)	TUMMINKATTI-110	03:39	03:57	0:18	TRIPPED ON FAULT
380	03-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
381	03-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	12:42	13:07	0:25	LINE CLEAR AVAILED
382	03-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_220	03:30	10:36	7:06	TRIPPED ON FAULT
383	03-Dec-24	BAGALKOTE	110	LINE	YADAWAD-ISEL (IZARA SOLAR)	YADAWAD_110	00:01	00:25	0:24	TRIPPED ON FAULT
384	03-Dec-24	BANGALORE	220	LINE	220KV A STATION 220 - NRS 220	NO STATION AFFECTED	14:11	23:59	09:48	LINE CLEAR AVAILED
385	03-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
386	03-Dec-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - YARANDANAHALLI 2	NO STATION AFFECTED	10:28	10:44	00:16	LINE CLEAR AVAILED
387	03-Dec-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - YARANDANAHALLI 3	NO STATION AFFECTED	23:58:00	00:16	00:18	LINE CLEAR AVAILED
388	03-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
389	03-Dec-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - BWSSB HAROHALLI 220	BWSSB HAROHALLI 220, KIADB HAROHALLI 220, KANAKAPURA 220	01:21	01:40	00:19	TRIPPED ON FAULT
390	03-Dec-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - BWSSB HAROHALLI 220	NO STATION AFFECTED	01:40	14:36	12:56	LINE CLEAR AVAILED
391	03-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	00:28	10:41	10:13	LINE CLEAR AVAILED
392	03-Dec-24	BANGALORE	400	LINE	400KV SOMANAHALLI PGCIL 400 - MYLASANDRA 400	NO STATION AFFECTED	16:01	23:59	07:58	LINE CLEAR AVAILED
393	03-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	DASHAVARA, BEVOOR, VANDARAGUPPE, SANKALGERE, RAMANAGARA	16:04	16:11	00:07	TRIPPED ON FAULT
394	03-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	NO STATION AFFECTED	08:32	11:03	02:31	TRIPPED ON FAULT
395	03-Dec-24	BANGALORE	66	LINE	66KV CHELUR - CHAKAVELU	CHELUR, CHAKAVELU	12:40	12:45	00:05	TRIPPED ON FAULT
396	03-Dec-24	BANGALORE	66	LINE	66KV CHELUR - CHAKAVELU	CHELUR, CHAKAVELU	13:15	13:20	00:05	TRIPPED ON FAULT
397	03-Dec-24	BANGALORE	66	LINE	66KV CHELUR - CHAKAVELU	CHELUR, CHAKAVELU	18:30	18:40	00:10	LINE CLEAR AVAILED
398	03-Dec-24	BANGALORE	66	LINE	66KV CHELUR - CHAKAVELU	CHELUR, CHAKAVELU	14:45	18:00	03:15	LINE CLEAR AVAILED
399	03-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 1	NO STATION AFFECTED	16:48	16:53	00:05	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
400	03-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	15:41	15:50	00:09	TRIPPED ON FAULT
401	03-Dec-24	BANGALORE	66	LINE	66KV HOODY 220 - HP EHT	HP(EHT)	14:36	15:30	00:54	LINE CLEAR AVAILED
402	03-Dec-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - KORAMANGALA 2	NO STATION AFFECTED	17:47	17:58	00:11	LINE CLEAR AVAILED
403	03-Dec-24	BANGALORE	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	12:30	16:30	04:00	LINE CLEAR AVAILED
404	03-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACHALU	ACHALU, HONNIGANAHALLI, HALAGUR	01:21	01:41	00:20	MAIN SUPPLY FAILURE
405	03-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA	MANIYAMBAL, MARALAWADI, GODUR	01:21	01:43	00:22	MAIN SUPPLY FAILURE
406	03-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	01:21	01:41	00:20	MAIN SUPPLY FAILURE
407	03-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNASENAHALLI	01:21	01:41	00:20	MAIN SUPPLY FAILURE
408	03-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	DODDALAHALLI, SHIVANAHALLI KMF	01:21	01:43	00:22	MAIN SUPPLY FAILURE
409	03-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - ORCHID LAMINATES-2	ORCHID LAMINATES	01:21	01:41	00:20	MAIN SUPPLY FAILURE
410	03-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - SANJEEVANADODDI	RANGANDODDI	01:21	01:41	00:20	MAIN SUPPLY FAILURE
411	03-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	01:21	01:41	00:20	MAIN SUPPLY FAILURE
412	03-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR,SANKALGERE, DASHAVARA, VANDARAGUPPE	00:14	00:20	00:06	TRIPPED ON FAULT
413	03-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR,SANKALGERE, DASHAVARA, VANDARAGUPPE	00:29	01:08	00:39	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
414	03-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR,SANKALGERE, DASHAVARA, VANDARAGUPPE	10:47	11:09	00:22	TRIPPED ON FAULT
415	03-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	14:25	14:39	00:14	TRIPPED ON FAULT
416	03-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	06:08	06:25	00:17	TRIPPED ON FAULT
417	03-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	17:26	17:31	00:05	LINE CLEAR AVAILED
418	03-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANKUNTE	15:40	15:45	00:05	LINE CLEAR AVAILED
419	03-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	15:51	16:06	00:15	LINE CLEAR AVAILED
420	03-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	NO STATION AFFECTED	18:45	23:59	05:14	LINE CLEAR AVAILED
421	03-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE, SAMANDURU	10:22	10:43	00:21	LINE CLEAR AVAILED
422	03-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	10:26	10:43	00:17	LINE CLEAR AVAILED
423	03-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYA CITY	10:22	10:43	00:21	LINE CLEAR AVAILED
424	03-Dec-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	13:15	13:20	00:05	TRIPPED ON FAULT
425	03-Dec-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	13:50	13:55	00:05	TRIPPED ON FAULT
426	03-Dec-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	14:30	14:35	00:05	TRIPPED ON FAULT
427	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BRIGADE TECH GARDEN	14:57	15:04	00:07	TRIPPED ON FAULT
428	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DOMMASANDRA	10:15	11:15	01:00	LINE CLEAR AVAILED
429	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ELITA PROMENENDE	07:25	07:28	00:03	LINE CLEAR AVAILED
430	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	00:30	00:35	00:05	TRIPPED ON FAULT
431	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KIADB HAROHALLI 220	01:21	01:40	00:19	MAIN SUPPLY FAILURE
432	03-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KIADB HAROHALLI 220	01:21	01:40	00:19	MAIN SUPPLY FAILURE
433	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	22:05	22:10	00:05	LINE CLEAR AVAILED
434	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MITTEMARI 220	16:45	17:20	00:35	TRIPPED ON FAULT
435	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SIDLAGATTA	14:26	14:50	00:24	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
436	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR_66	09:49	09:55	00:06	TRIPPED ON FAULT
437	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR_66	10:47	10:55	00:08	TRIPPED ON FAULT
438	03-Dec-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	00:51	00:58	00:07	TRIPPED ON FAULT
439	03-Dec-24	BANGALORE	220	TRANSFORMER	HV1	YARANDANAHALLI 220	23:58:00	00:18	00:20	LINE CLEAR AVAILED
440	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	12:30	12:38	00:08	TRIPPED ON FAULT
441	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDAPURA	15:00	15:02	00:02	LINE CLEAR AVAILED
442	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHATRA	11:30	11:43	00:13	LINE CLEAR AVAILED
443	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	D CROSS	15:47	15:52	00:05	TRIPPED ON FAULT
444	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GANJGIUNTE	09:13	09:23	00:10	TRIPPED ON FAULT
445	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HULIMANGALA	14:10	15:57	01:47	LINE CLEAR AVAILED
446	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KIADB HAROHALLI 220	01:21	01:40	00:19	MAIN SUPPLY FAILURE
447	03-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KIADB HAROHALLI 220	01:21	01:40	00:19	MAIN SUPPLY FAILURE
448	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	11:50	11:55	00:05	LINE CLEAR AVAILED
449	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	22:05	22:10	00:05	LINE CLEAR AVAILED
450	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	PLATINUM CITY	07:14	07:27	00:13	TRIPPED ON FAULT
451	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	RAJANUKUNTE	13:35	13:40	00:05	LINE CLEAR AVAILED
452	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	10:13	10:20	00:07	LINE CLEAR AVAILED
453	03-Dec-24	BANGALORE	220	TRANSFORMER	HV2	YARANDANAHALLI 220	00:20	00:45	00:25	LINE CLEAR AVAILED
454	03-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YEDAMADU	11:27	12:07	00:40	LINE CLEAR AVAILED
455	03-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	10:26	10:41	00:15	LINE CLEAR AVAILED
456	03-Dec-24	GULBARGA	400	LINE	BTPS-GUTTUR(JINDAL)	GUTTUR_400	22:33(2.12.2024)			TRIPPED ON FAULT
457	03-Dec-24	GULBARGA	220	LINE	HALWARTHY-LINGAPUR LINE 1	LINGAPUR_110	12:42	19:13	06:31	LINE CLEAR AVAILED
458	03-Dec-24	GULBARGA	220	LINE	HATTIGUDUR-FIROZABAD-2	HATTIGUDUR_220	23:58:00	07:05	07:07	LINE CLEAR AVAILED
459	03-Dec-24	GULBARGA	110	LINE	HATTIGUDUR-M.KOLLUR	M.KOLLUR_110	03:40	03:47	00:07	TRIPPED ON FAULT
460	03-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALAND_110	03:15	04:10	00:55	TRIPPED ON FAULT
461	03-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	17:31	17:41	00:10	TRIPPED ON FAULT
462	03-Dec-24	GULBARGA	110	TRANSFORMER	HV1	CHIKKASUGUR_110	02:41	02:45	00:04	TRIPPED ON FAULT
463	03-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KANAKAGIRI_110	11:45	17:30	05:45	LINE CLEAR AVAILED
464	03-Dec-24	GULBARGA	220	TRANSFORMER	HV1 & HV2	KUDLIGI_220	09:10	09:25	00:15	TRIPPED ON FAULT
465	03-Dec-24	GULBARGA	110	TRANSFORMER	HV2	CHIKKASUGUR_110	21:55	22:00	00:05	TRIPPED ON FAULT
466	03-Dec-24	GULBARGA	66	TRANSFORMER	HV2	HALVAGALU_66	09:45	09:50	00:05	TRIPPED ON FAULT
467	03-Dec-24	GULBARGA	110	TRANSFORMER	HV2	VADAVATTI_110	09:30	17:45	08:15	LINE CLEAR AVAILED
468	03-Dec-24	GULBARGA	110	TRANSFORMER	HV3	BELLARY NORTH_110	11:24	12:26	01:02	LINE CLEAR AVAILED
469	03-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHIKKASUGUR_110	23:05	23:10	00:05	TRIPPED ON FAULT
470	03-Dec-24	GULBARGA	110	LINE	KANAKAGIRI-SULEKAL	NAVALI_110	17:00	17:30	00:30	LINE CLEAR AVAILED
471	03-Dec-24	GULBARGA	220	LINE	KAPNOOR-FEROZABAD	KAPNOOR_220	19:21	23:59	04:38	LINE CLEAR AVAILED
472	03-Dec-24	GULBARGA	220	LINE	KAPNOOR-HUMNABAD1	KAPNOOR_220	23:58:00	06:48	06:50	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
473	03-Dec-24	GULBARGA	110	LINE	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HAN AMANAL_110,HIRGONNA GAR 110	11:33	14:25	02:52	LINE CLEAR AVAILED
474	03-Dec-24	GULBARGA	220	LINE	LINGAPUR-BTPS	BTPS_220	05:18	12:22	07:04	TRIPPED ON FAULT
475	03-Dec-24	GULBARGA	220	LINE	LINGAPUR-HALWARTHY1	HALWARTHY_220	12:40	19:17	06:37	LINE CLEAR AVAILED
476	03-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	11:40	15:51	04:11	LINE CLEAR AVAILED
477	03-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	02:55	15:52	12:57	TRIPPED ON FAULT
478	03-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	ADVI AMARESHWARA_110,MAD LAPUR 110,MANVI 110	01:20	01:25	00:05	TRIPPED ON FAULT
479	03-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	ADVI AMARESHWARA_110,MAD LAPUR 110,MANVI 110	06:27	06:35	00:08	TRIPPED ON FAULT
480	03-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	ADVI AMARESHWARA_110,MAD LAPUR 110,MANVI 110	09:58	10:03	00:05	TRIPPED ON FAULT
481	03-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	ADVI AMARESHWARA_110,MAD LAPUR 110,MANVI 110	11:58	16:58	05:00	LINE CLEAR AVAILED
482	03-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66	14:03	14:07	00:04	TRIPPED ON FAULT
483	03-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
484	03-Dec-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	02:48	03:00	00:12	TRIPPED ON FAULT
485	03-Dec-24	GULBARGA	110	LINE	SULEKAL-HANWAL	HANWAL_110	19:41	19:46	00:05	TRIPPED ON FAULT
486	03-Dec-24	GULBARGA	110	LINE	SULEKAL-HANWAL	HANWAL_110	00:15	00:39	00:24	TRIPPED ON FAULT
487	03-Dec-24	GULBARGA	66	LINE	UCHANGIDURGA-BILCHOD	BILCHOD_66	18:00	18:10	00:10	LINE CLEAR AVAILED
488	03-Dec-24	GULBARGA	110	LINE	YERDONA-MARALAHALLI LINE	YERDONA_110,BENNUR_110	19:41	19:52	00:11	TRIPPED ON FAULT
489	03-Dec-24	GULBARGA	110	LINE	YERDONA-MARALAHALLI LINE	YERDONA_110,BENNUR_110	00:15	00:49	00:34	TRIPPED ON FAULT
490	03-Dec-24	HASAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	02:55	05:30	02:35	MAIN SUPPLY FAILURE
491	03-Dec-24	HASAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	02:12	15:47	13:35	MAIN SUPPLY FAILURE
492	03-Dec-24	HASAN	110	LINE	BRAHMAV-MANIPAL	BRAHMAVARA_110	13:49	17:11	03:22	LINE CLEAR AVAILED
493	03-Dec-24	HASAN	66	LINE	CHIKNAGARA-ALUVALLI	CHIKKANAGARA_220	18:43(3.12.2024)			TRIPPED ON FAULT
494	03-Dec-24	HASAN	66	LINE	CRPATNA-HNPURA	CRPATNA_220	15:07	17:48	02:41	TRIPPED ON FAULT
495	03-Dec-24	HASAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_66	14:20	15:13	00:53	MAIN SUPPLY FAILURE
496	03-Dec-24	HASAN	66	LINE	DODDAKA-KRNAGARA	DODDAKADNUR_66	14:20	14:50	00:30	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
497	03-Dec-24	HASAN	220	LINE	GERSOPA-TALGUPA2	gen_gersoppa	22:38(01.12.2024)	14:39 (3.12.2024)	39:40 hrs	LINE CLEAR AVAILED
498	03-Dec-24	HASAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	02:54	07:10	04:16	TRIPPED ON FAULT
499	03-Dec-24	HASAN	66	LINE	HASSN22-SKPURA	HASSAN_220	08:43	12:58	04:15	TRIPPED ON FAULT
500	03-Dec-24	HASAN	66	TRANSFORMER	HV1	ARAKALGUD_66	02:55	05:30	02:35	MAIN SUPPLY FAILURE
501	03-Dec-24	HASAN	66	TRANSFORMER	HV1	ARAKALGUD_66	11:10	11:20	00:10	LINE CLEAR AVAILED
502	03-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	14:49	17:12	02:23	LINE CLEAR AVAILED
503	03-Dec-24	HASAN	110	TRANSFORMER	HV1	ESSUR_110	09:45	16:03	06:18	MAIN SUPPLY FAILURE
504	03-Dec-24	HASAN	220	TRANSFORMER	HV1	KAVOOR_220	09:47	12:13	02:26	TRIPPED ON FAULT
505	03-Dec-24	HASAN	110	TRANSFORMER	HV1	KEMAR_220	03:57	11:54	07:57	TRIPPED ON FAULT
506	03-Dec-24	HASAN	110	TRANSFORMER	HV1	MSEZ_220	01:53	04:07	02:14	TRIPPED ON FAULT
507	03-Dec-24	HASAN	220	TRANSFORMER	HV1	MSEZ_220	08:35	14:01	05:26	TRIPPED ON FAULT
508	03-Dec-24	HASAN	110	TRANSFORMER	HV1	NITTUR_110	13:20	14:01	00:41	LINE CLEAR AVAILED
509	03-Dec-24	HASAN	110	TRANSFORMER	HV1	NITTUR_110	11:04	14:10	03:06	LINE CLEAR AVAILED
510	03-Dec-24	HASAN	110	TRANSFORMER	HV1	SALATHUR_110	12:23	14:43	02:20	LINE CLEAR AVAILED
511	03-Dec-24	HASAN	66	TRANSFORMER	HV1	SOMANAHALLI_66	02:57	03:10	00:13	TRIPPED ON FAULT
512	03-Dec-24	HASAN	66	TRANSFORMER	HV1	UDAYAPURA_66	11:50	11:55	00:05	TRIPPED ON FAULT
513	03-Dec-24	HASAN	110	TRANSFORMER	HV1CBreaker	KARKALA_110	11:44	12:47	01:03	LINE CLEAR AVAILED
514	03-Dec-24	HASAN	66	TRANSFORMER	HV2	ARAKALGUD_66	02:55	05:30	02:35	MAIN SUPPLY FAILURE
515	03-Dec-24	HASAN	66	TRANSFORMER	HV2	ARAKALGUD_66	11:10	11:20	00:10	LINE CLEAR AVAILED
516	03-Dec-24	HASAN	66	TRANSFORMER	HV2	CHIKKAMAGALORE_66	01:00	04:04	03:04	TRIPPED ON FAULT
517	03-Dec-24	HASAN	66	TRANSFORMER	HV2	CHIKKAMAGALORE_66	12:39	14:48	02:09	LINE CLEAR AVAILED
518	03-Dec-24	HASAN	110	TRANSFORMER	HV2	ESSUR_110	09:45	16:03	06:18	MAIN SUPPLY FAILURE
519	03-Dec-24	HASAN	66	TRANSFORMER	HV2	HIRESAVE_66	10:45	12:41	01:56	LINE CLEAR AVAILED
520	03-Dec-24	HASAN	110	TRANSFORMER	HV2	KADUR_220	14:45	16:50	02:05	LINE CLEAR AVAILED
521	03-Dec-24	HASAN	110	TRANSFORMER	HV2	KUNDAPURA_110	14:40	15:13	00:33	LINE CLEAR AVAILED
522	03-Dec-24	HASAN	110	TRANSFORMER	HV2	MSEZ_220	01:53	04:05	02:12	TRIPPED ON FAULT
523	03-Dec-24	HASAN	110	TRANSFORMER	HV2	SALATHUR_110	12:23	14:43	02:20	LINE CLEAR AVAILED
524	03-Dec-24	HASAN	66	TRANSFORMER	HV2	UDAYAPURA_66	11:50	11:55	00:05	TRIPPED ON FAULT
525	03-Dec-24	HASAN	110	TRANSFORMER	HV3	KAVOOR_220	09:47	11:49	02:02	TRIPPED ON FAULT
526	03-Dec-24	HASAN	220	LINE	KAVOOR-KEMR1	KAVOOR_220	05:09	18:49	13:40	LINE CLEAR AVAILED
527	03-Dec-24	HASAN	220	LINE	KEMAR-UPCL	KEMAR_220	06:08	12:13	06:05	TRIPPED ON FAULT
528	03-Dec-24	HASAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	11:10	18:44	07:34	LINE CLEAR AVAILED
529	03-Dec-24	HASAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	11:15	15:05	03:50	LINE CLEAR AVAILED
530	03-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	14:41	14:48	00:07	LINE CLEAR AVAILED
531	03-Dec-24	HASAN	110	TRANSFORMER	LV1	KAVOOR_220	09:47	12:13	02:26	TRIPPED ON FAULT
532	03-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	08:35	14:01	05:26	TRIPPED ON FAULT
533	03-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	03:16	03:25	00:09	TRIPPED ON FAULT
534	03-Dec-24	HASAN	110	TRANSFORMER	LV2	MSEZ_220	01:53	04:39	02:46	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
535	03-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	05:55	06:20	00:25	TRIPPED ON FAULT
536	03-Dec-24	HASAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	02:55	05:40	02:45	MAIN SUPPLY FAILURE
537	03-Dec-24	HASAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:50	12:00	01:10	MAIN SUPPLY FAILURE
538	03-Dec-24	HASAN	66	LINE	MATTNAV-DIDGTHL	MATTANAVILE_66	10:37	10:52	00:15	TRIPPED ON FAULT
539	03-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMG_220	19:55(2.12.2024)	12:39(3.12.2024)	16:43 hrs	LINE CLEAR AVAILED
540	03-Dec-24	HASAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	02:12	03:30	01:18	TRIPPED ON FAULT
541	03-Dec-24	HASAN	110	LINE	MSEZ-GSS31	MSEZ_220	01:50	03:35	01:45	TRIPPED ON FAULT
542	03-Dec-24	HASAN	110	LINE	MSEZ-KAVOOR	MSEZ_220	1:53(3.12.2024)			TRIPPED ON FAULT
543	03-Dec-24	HASAN	110	LINE	MSEZ-RAIL CBreaker	MSEZ_220	01:53	03:56	02:03	TRIPPED ON FAULT
544	03-Dec-24	HASAN	110	LINE	NANDIKU-ISTR	NANDIKUR_110	05:28	05:56	00:28	TRIPPED ON FAULT
545	03-Dec-24	HASAN	110	LINE	NANDIKU-ISTR	NANDIKUR_110	10:55	13:25	02:30	LINE CLEAR AVAILED
546	03-Dec-24	HASAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	11:27	15:04	03:37	LINE CLEAR AVAILED
547	03-Dec-24	HASAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	12:23	14:43	02:20	LINE CLEAR AVAILED
548	03-Dec-24	HASAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	09:46	11:28	01:42	TRIPPED ON FAULT
549	03-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:33	19:03	09:30	LINE CLEAR AVAILED
550	03-Dec-24	HASAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	22:38(01.12.2024)	14:38 (3.12.2024)	39:59 hrs	LINE CLEAR AVAILED
551	03-Dec-24	HASAN	220	LINE	UPCL-KEMAR2	gen_upcl	06:08	12:13	06:05	TRIPPED ON FAULT
552	03-Dec-24	HASAN	110	LINE	VITTAL-PUTR SLTUR	VITTALA_110	12:23	14:43	02:20	LINE CLEAR AVAILED
553	03-Dec-24	HASAN	66	LINE	VKANDLI-HASSAN	KANDLI_66	11:20	11:40	00:20	LINE CLEAR AVAILED
554	03-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
555	03-Dec-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBI_66	03:09	03:19	00:09	TRIPPED ON FAULT
556	03-Dec-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBI_66	19:10	19:15	00:05	TRIPPED ON FAULT
557	03-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
558	03-Dec-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	11:57	13:31	01:33	LINE CLEAR AVAILED
559	03-Dec-24	MYSORE	66	LINE	HANNUR-AJJIPURA	COWDALLI_66BANDALLI_66AJJIPURA_66RAMAPURA_MYS_66MARTAHALLI_66	10:40	10:46	00:06	TRIPPED ON FAULT
560	03-Dec-24	MYSORE	66	LINE	HARVEY-KABBALLI	NO STATIONS EFFECTED	19:10	19:20	00:10	TRIPPED ON FAULT
561	03-Dec-24	MYSORE	66	LINE	HEBBANI-VAJMANGALA	THUMBLA_66	12:23	12:32	00:09	TRIPPED ON FAULT
562	03-Dec-24	MYSORE	66	LINE	HEBBANI-VAJMANGALA	VYASARAJAPURA_66THUMBLA_66GARGESHWARI_66	07:07	07:18	00:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
563	03-Dec-24	MYSORE	66	LINE	HONNALLI-ATTIGULIPURA	ATTIGULIPURA_66	06:00	06:05	00:05	TRIPPED ON FAULT
564	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	AYRALLI_66	00:40	00:45	00:05	TRIPPED ON FAULT
565	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	AYRALLI_66	07:15	07:20	00:05	TRIPPED ON FAULT
566	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	AYRALLI_66	09:40	09:45	00:05	TRIPPED ON FAULT
567	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	AYRALLI_66	13:45	13:50	00:05	TRIPPED ON FAULT
568	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUDDENAHALLI_66	12:16	14:01	01:44	LINE CLEAR AVAILED
569	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	01:20	01:40	00:20	MAIN SUPPLY FAILURE
570	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	14:23	15:25	01:02	LINE CLEAR AVAILED
571	03-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
572	03-Dec-24	MYSORE	66	TRANSFORMER	HV2	KADABALLI_66	12:15	13:15	01:00	LINE CLEAR AVAILED
573	03-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
574	03-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
575	03-Dec-24	MYSORE	66	LINE	KOPPA-KASALGERE	NO STATIONS EFFECTED	02:58	13:59	11:01	TRIPPED ON FAULT
576	03-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
577	03-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66HARIYALDA MMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
578	03-Dec-24	MYSORE	66	LINE	KUSHALNAGARA-RAMANTHAPURA	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	03:58	04:11	00:13	TRIPPED ON FAULT
579	03-Dec-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:14	13:32	01:18	LINE CLEAR AVAILED
580	03-Dec-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	07:08	07:12	00:03	TRIPPED ON FAULT
581	03-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	14:15	17:15	03:00	LINE CLEAR AVAILED
582	03-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	18:00:00 (2/12/2024)	7:40 (3/12/2024)	13:40 HRs	TRIPPED ON FAULT
583	03-Dec-24	MYSORE	66	LINE	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	13:30	17:10	03:40	LINE CLEAR AVAILED
584	03-Dec-24	MYSORE	66	LINE	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	18:00:00 (2/12/2024)	7:40 (3/12/2024)	13:40 HRs	TRIPPED ON FAULT
585	03-Dec-24	MYSORE	66	LINE	SFCSIVA-ATRIA	NO STATIONS EFFECTED	18:00:00 (2/12/2024)			TRIPPED ON FAULT
586	03-Dec-24	MYSORE	66	LINE	THUMBLA-CHIDRAVALLI-MEGALAPURA	VYASARAJAPURA_66 THUMBLA_66	07:06	07:18	00:12	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
587	03-Dec-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	21:45:00 (2/12/2024)	12:13 (03/12/2024)	14:27 HRs	TRIPPED ON FAULT
588	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 12.5MVA YADVANI_66	YADVANI_66	9:26	9:30	0:04	TRIPPED ON FAULT
589	03-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV AMRUTHUR LINE	66KV SANTHEMAVATHUR,AMRU THUR ,SANABGHATTA,YEDAVANI	18:19	18:29	0:10	TRIPPED ON FAULT
590	03-Dec-24	TUMKUR	66	LINE	220KV MADHURE-66KV O/G LINE HALRAMESHWARA-1 AND MADADAKERE	HALURAMESHWARA AND MADADAKERE	22:55	23:05	0:10	TRIPPED ON FAULT
591	03-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	66KV CHALALKERE, BALENAHLLI	16:51	17:03	0:12	TRIPPED ON FAULT
592	03-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE	66KV BILICHODU , PALLAGAHATTE	23:58:00	7:00	7:02	TRIPPED ON FAULT
593	03-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE, SOKKE	21:20 (02.12.2024)	15:40 (03.12.2024)	18:20	TRIPPED ON FAULT
594	03-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	0:25	1:30	1:05	TRIPPED ON FAULT
595	03-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	66KVJAGALURU	9:10	10:05	0:55	TRIPPED ON FAULT
596	03-Dec-24	TUMKUR	220	LINE	BENKIKERE 220KV- HOSADURGA LINE 1 (MADHURE)	HOSADURGA_220	23:36 (02.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
597	03-Dec-24	TUMKUR	400	LINE	GUTTUR 400kV- BTPS LINE	GUTTUR_400	22:32 (02.12.2024)	5:40 (03.12.2024)	7:08	TRIPPED ON FAULT
598	03-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
599	03-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42(30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
600	03-Dec-24	TUMKUR	220	LINE	HONNALLI 220K- BENKIKERE-2	BENKIKERE_220	23:32 (02.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
601	03-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV- SHIMOCHA1	220KV K B CROSS	23:58:00	12:39	12:41	LINE CLEAR AVAILED
602	03-Dec-24	TUMKUR	66	LINE	RAMPURA66- NAGASAMUDRA LINE-1	RAMAPURA_66	11:50	14:45	2:55	LINE CLEAR AVAILED
603	03-Dec-24	TUMKUR	66	LINE	RAMPURA66- NAGASAMUDRA LINE-2	RAMAPURA_66	15:00	15:29	0:29	LINE CLEAR AVAILED
604	03-Dec-24	TUMKUR	220	LINE	SIRA220-SIRA 1	SIRA_66	8:10	8:18	0:08	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
605	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-1, 6.3 MVA, HEGGERE_66	HEGGERE_66	10:50	11:30	0:40	LINE CLEAR AVAILED
606	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-1, 8 MVA, JIDDIGERE_66	JIDDIGERE_66	12:10	12:30	0:20	LINE CLEAR AVAILED
607	03-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
608	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 12.5MVA MADHUGIRI_66	MADHUGIRI_66	12:00	13:30	1:30	LINE CLEAR AVAILED
609	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 12.5MVA MYLANAHALLI_66	MYLANAHALLI_66	10:35	10:45	0:10	TRIPPED ON FAULT
610	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 12.5MVA TURUVANURU_66	TURUVANURU_66	13:10	13:25	0:15	TRIPPED ON FAULT
611	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 12.5MVA TURUVANURU_66	TURUVANURU_66	19:01	19:11	0:10	TRIPPED ON FAULT
612	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 20MVA HIRIYUR_220KV	HIRIYUR_220KV	16:16	16:25	0:09	TRIPPED ON FAULT
613	03-Dec-24	TUMKUR	66	TRANSFORMER	TR-2, 8 MVA, JIDDIGERE_66	JIDDIGERE_66	12:35	12:45	0:10	LINE CLEAR AVAILED
614	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	AREMALLAPUR_110	10:30	17:58	7:28	LINE CLEAR AVAILED
615	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	AREMALLAPUR_110	18:02	18:27	0:25	TRIPPED ON FAULT
616	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	10:34	17:13	6:39	LINE CLEAR AVAILED
617	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	15:13	15:27	0:14	TRIPPED ON FAULT
618	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN_110	10:11	10:18	0:07	TRIPPED ON FAULT
619	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN_110	14:49	14:54	0:05	TRIPPED ON FAULT
620	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YARGATTI_110	12:53	13:06	0:13	LINE CLEAR AVAILED
621	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	AREMALLAPUR_110	10:30	18:30	8:00	LINE CLEAR AVAILED
622	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BIJAPUR_220	11:39	12:59	1:20	LINE CLEAR AVAILED
623	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN (S)_110	09:26	09:34	0:08	TRIPPED ON FAULT
624	04-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA-HV3)	SHIGGOAN_110	23:09	23:17	0:08	TRIPPED ON FAULT
625	04-Dec-24	BAGALKOTE	400	TRANSFORMER	400/220KV,ICT1(HV)	DHONI_400	10:54	17:22	6:28	LINE CLEAR AVAILED
626	04-Dec-24	BAGALKOTE	220	LINE	400/220KV,ICT1(LV)	DHONI_400	10:54	17:24	6:30	LINE CLEAR AVAILED
627	04-Dec-24	BAGALKOTE	110	LINE	ALNVR-RLY Cbreaker	ALNAVAR_110	09:48	10:00	0:12	TRIPPED ON FAULT
628	04-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NAGJHARI2	AMBEWADI_220	10:08	14:32	4:24	LINE CLEAR AVAILED
629	04-Dec-24	BAGALKOTE	110	LINE	AREMALLAPUR-GUTTAL(BELUR)	AREMALLAPUR_110	12:32	17:53	5:21	LINE CLEAR AVAILED
630	04-Dec-24	BAGALKOTE	220	LINE	BAGALKOT- VAJRAMATTI1	BAGALKOT_220	03:25	04:07	0:42	TRIPPED ON FAULT
631	04-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
632	04-Dec-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	11:16	17:34	6:18	LINE CLEAR AVAILED
633	04-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
634	04-Dec-24	BAGALKOTE	110	LINE	HOSAHONNATTI-F2(GUTTAL)	HOSAHONNATTI_110	11:15	16:59	5:44	LINE CLEAR AVAILED
635	04-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
636	04-Dec-24	BAGALKOTE	220	LINE	HUBLI-SIRSI -2	HUBLI_220	12:12	13:44	1:32	LINE CLEAR AVAILED
637	04-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3:12.2024)			LINE CLEAR AVAILED
638	04-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
639	04-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
640	04-Dec-24	BAGALKOTE	220	LINE	RANEENNUR- BALLIGAVI	RANEENNUR_220	12:15	13:30	1:15	TRIPPED ON FAULT
641	04-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-AREMALLAPUR(HONNATTI)	RANEENNUR_220	11:20	16:40	5:20	LINE CLEAR AVAILED
642	04-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-AREMALLAPUR(HONNATTI)	RANEENNUR_220	16:44	16:56	0:12	LINE CLEAR AVAILED
643	04-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-AREMALLAPUR(HONNATTI)	RANEENNUR_220	17:59	18:09	0:10	TRIPPED ON FAULT
644	04-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-HIREKERUR	RANEENNUR_220	12:16	12:20	0:04	LINE CLEAR AVAILED
645	04-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-RATTIHALI(TUMMINKATTI)	RANEENNUR_220	12:16	12:20	0:04	LINE CLEAR AVAILED
646	04-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
647	04-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
648	04-Dec-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-HIRE BAGEWADI	SUVARNA SOUDA_110	10:30	17:53	7:23	LINE CLEAR AVAILED
649	04-Dec-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-MACHE	SUVARNA SOUDA_110	10:30	17:53	7:23	LINE CLEAR AVAILED
650	04-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL (TAKKALAKI)	TIKOTA_110	11:15 (03.12.2024)	11:10 (4.12.2024)	23:55:00	LINE CLEAR AVAILED
651	04-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
652	04-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	3:25	3:59	0:34	TRIPPED ON FAULT
653	04-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	03:25	04:43	1:18	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
654	04-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI- KAWATAGI LIS	VAJRAMATTI_220	14:05	14:20	0:15	TRIPPED ON FAULT
655	04-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_220	16:04	18:24	2:20	LINE CLEAR AVAILED
656	04-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
657	04-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	10:10	23:59	13:49	LINE CLEAR AVAILED
658	04-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
659	04-Dec-24	BANGALORE	400	LINE	400KV NELAMANGALA 400 - HASSAN	NO STATION AFFECTED	10:27	17:12	06:45	LINE CLEAR AVAILED
660	04-Dec-24	BANGALORE	400	LINE	400KV NELAMANGALA 400 - TALAGUPPA	NO STATION AFFECTED	10:09	19:29	09:20	LINE CLEAR AVAILED
661	04-Dec-24	BANGALORE	66	LINE	66KV AVANI - KC VALLEY (EHT)	NO STATION AFFECTED	12:25	12:35	00:10	LINE CLEAR AVAILED
662	04-Dec-24	BANGALORE	66	LINE	66KV AVANI - KC VALLEY (EHT)	NO STATION AFFECTED	18:10	18:45	00:35	LINE CLEAR AVAILED
663	04-Dec-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGAR	NO STATION AFFECTED	10:45	15:56	05:11	LINE CLEAR AVAILED
664	04-Dec-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	12:34	12:38	00:04	LINE CLEAR AVAILED
665	04-Dec-24	BANGALORE	66	LINE	66KV K & C VALLEY - NAL EHT	NAL(EHT)	08:33	09:43	01:10	TRIPPED ON FAULT
666	04-Dec-24	BANGALORE	66	LINE	66KV KGF - BEML (EHT)	BEML	13:36	13:41	00:05	LINE CLEAR AVAILED
667	04-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - 66KV BHP MINI IRRIGATION EHT	BHP MINI IRRIGATION(EHT)	12:32	14:44	02:12	LINE CLEAR AVAILED
668	04-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - 66KV SHELL EHT	SHELL(EHT)	13:11	14:42	01:31	LINE CLEAR AVAILED
669	04-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	SOLURU(GUDEMARNAHALLI)	00:08	00:19	00:11	TRIPPED ON FAULT
670	04-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	06:51	07:07	00:16	TRIPPED ON FAULT
671	04-Dec-24	BANGALORE	66	LINE	66KV NANDI (MUDDENAHALLI) - CB PURA I/A	NO STATION AFFECTED	13:34	13:52	00:18	TRIPPED ON FAULT
672	04-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - KC VALLEY (EHT)	NO STATION AFFECTED	13:00	13:10	00:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
673	04-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - KC VALLEY (EHT)	NO STATION AFFECTED	19:00	19:10	00:10	LINE CLEAR AVAILED
674	04-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - BMTC	NATIONAL COLLEGE	11:25	11:28	00:03	LINE CLEAR AVAILED
675	04-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - BMTC	NO STATION AFFECTED	11:25	18:23	06:58	LINE CLEAR AVAILED
676	04-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	06:45	06:52	00:07	LINE CLEAR AVAILED
677	04-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - NANDI (MUDDENAHALLI)	NANDI(MUDDENAHALLI)	13:34	13:49	00:15	TRIPPED ON FAULT
678	04-Dec-24	BANGALORE	66	LINE	66KV REMCO - VIJAYANAGAR	VIJAYANAGARA	22:20	22:30	00:10	LINE CLEAR AVAILED
679	04-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	14:05	14:20	00:15	LINE CLEAR AVAILED
680	04-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	13:38	13:58	00:20	LINE CLEAR AVAILED
681	04-Dec-24	BANGALORE	66	LINE	66KV SUGUTUR - KC VALLEY (EHT)	NO STATION AFFECTED	17:25	17:30	00:05	LINE CLEAR AVAILED
682	04-Dec-24	BANGALORE	66	LINE	66KV SUGUTUR - KC VALLEY (EHT)	NO STATION AFFECTED	18:29	18:35	00:06	LINE CLEAR AVAILED
683	04-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	NO STATION AFFECTED	23:58:00	11:05	11:07	LINE CLEAR AVAILED
684	04-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	NO STATION AFFECTED	11:05	17:20	06:15	LINE CLEAR AVAILED
685	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	10:32	10:46	00:14	LINE CLEAR AVAILED
686	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHINTAMANI 66	16:20	16:25	00:05	TRIPPED ON FAULT
687	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHINTAMANI 66	16:25	17:00	00:35	LINE CLEAR AVAILED
688	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KAMBIPURA	11:15	11:20	00:05	LINE CLEAR AVAILED
689	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KIADB HARDWARE PARK 220	16:06	16:49	00:43	LINE CLEAR AVAILED
690	04-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KIADB HARDWARE PARK 220	15:58	16:54	00:56	LINE CLEAR AVAILED
691	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	22:01	22:06	00:05	LINE CLEAR AVAILED
692	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NANDINI LAYOUT	06:45	06:52	00:07	LINE CLEAR AVAILED
693	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	12:40	13:55	01:15	LINE CLEAR AVAILED
694	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOMANATHPURA	18:05	18:20	00:15	TRIPPED ON FAULT
695	04-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	22:17	22:25	00:08	LINE CLEAR AVAILED
696	04-Dec-24	BANGALORE	220	TRANSFORMER	HV2	EXORA 220	10:15	18:20	08:05	LINE CLEAR AVAILED
697	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KAMBIPURA	14:00	14:02	00:02	LINE CLEAR AVAILED
698	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KEMBODI	13:35	14:55	01:20	LINE CLEAR AVAILED
699	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	22:01	22:06	00:05	LINE CLEAR AVAILED
700	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	11:35	12:35	01:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
701	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	THAYALUR	17:10	17:40	00:30	LINE CLEAR AVAILED
702	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	05:44	05:52	00:08	TRIPPED ON FAULT
703	04-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	22:17	22:25	00:08	LINE CLEAR AVAILED
704	04-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - LIMBAVALI IPP	NO STATION AFFECTED	16:15	16:40	00:25	TRIPPED ON FAULT
705	04-Dec-24	GULBARGA	400	LINE	BTPS-GUTTUR(JINDAL)	GUTTUR_400	22:33(2.12.2024)	17:02(04.12.2024)	32:35HRS	TRIPPED ON FAULT
706	04-Dec-24	GULBARGA	220	LINE	HALWARTHY-ILCIPP	HALWARTHY_220	11:35	13:22	01:47	LINE CLEAR AVAILED
707	04-Dec-24	GULBARGA	110	LINE	HATTIGUDUR-NAGNOOR	NAGNOOR_110	20:48	21:00	00:12	TRIPPED ON FAULT
708	04-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALAND_110	14:50	15:00	00:10	TRIPPED ON FAULT
709	04-Dec-24	GULBARGA	110	TRANSFORMER	HV1	GABBUR_110	11:27	14:30	03:03	TRIPPED ON FAULT
710	04-Dec-24	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	10:22	15:37	05:15	LINE CLEAR AVAILED
711	04-Dec-24	GULBARGA	110	TRANSFORMER	HV2	GINIGERA_110	12:20	14:00	01:40	LINE CLEAR AVAILED
712	04-Dec-24	GULBARGA	110	TRANSFORMER	HV2	HOSAHALLI_66	23:30	23:55	00:25	TRIPPED ON FAULT
713	04-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHIKKASUGUR_110	09:25	13:10	03:45	LINE CLEAR AVAILED
714	04-Dec-24	GULBARGA	220	LINE	KAPNOOR-FEROZABAD	KAPNOOR_220	23:58:00	16:48	16:50	LINE CLEAR AVAILED
715	04-Dec-24	GULBARGA	110	LINE	KUDLIGI-CJHALLI	CJHALLI_66, HOSAHALLI_66, HUDEM_66	11:30	11:40	00:10	TRIPPED ON FAULT
716	04-Dec-24	GULBARGA	220	LINE	KUDLIGI-CYCLICENERGY_IPP	KUDLIGI_220	11:20	11:45	00:25	TRIPPED ON FAULT
717	04-Dec-24	GULBARGA	110	LINE	LINGASUGUR-GURGUNTA	GURGUNTA_110	06:54	07:11	00:17	TRIPPED ON FAULT
718	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	15:17	15:45	00:28	TRIPPED ON FAULT
719	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	15:45	18:14	02:29	LINE CLEAR AVAILED
720	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	18:24	18:45	00:21	TRIPPED ON FAULT
721	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	18:45	21:14	02:29	LINE CLEAR AVAILED
722	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1&2	LINGASUGUR_220	10:26	15:07	04:41	LINE CLEAR AVAILED
723	04-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	16:37	18:15	01:38	LINE CLEAR AVAILED
724	04-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANHATTI_66	15:11	18:34	03:23	LINE CLEAR AVAILED
725	04-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
726	04-Dec-24	GULBARGA	110	LINE	RAICHUR-MATAMARI	MATAMARI_110	12:03	13:14	01:11	LINE CLEAR AVAILED
727	04-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR1,2	GABBUR_110,GUGAL_110, DEODURGA_110	11:15	11:20	00:05	TRIPPED ON FAULT
728	04-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR1,2	GABBUR_110,GUGAL_110, DEODURGA_110	11:30	12:02	00:32	TRIPPED ON FAULT
729	04-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR1,2	GABBUR_110,GUGAL_110, DEODURGA_110	15:39	18:45	03:06	LINE CLEAR AVAILED
730	04-Dec-24	GULBARGA	110	LINE	SEDAM-CHITAPUR	CHITAPUR_110	19:00	19:05	00:05	TRIPPED ON FAULT
731	04-Dec-24	GULBARGA	110	LINE	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110, TURVIHAL_110	11:27	11:38	00:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
732	04-Dec-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	15:44	15:54	00:10	TRIPPED ON FAULT
733	04-Dec-24	HASAN	110	LINE	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	12:02	14:46	02:44	LINE CLEAR AVAILED
734	04-Dec-24	HASAN	66	LINE	CHIKNAGARA-ALUVALLI	CHIKKANAGARA_220	18:43(3.12.2024)			TRIPPED ON FAULT
735	04-Dec-24	HASAN	66	LINE	CKMGLR220-KALSAPURA	CHIKMAGALUR_220	13:21	13:38	00:17	TRIPPED ON FAULT
736	04-Dec-24	HASAN	220	LINE	GOPALAP-HNPUR22	GOPALPURA_220	23:07(04.12.2024)			TRIPPED ON FAULT
737	04-Dec-24	HASAN	66	LINE	HASSN22-HN PURA	HASSAN_220	11:57	14:48	02:51	LINE CLEAR AVAILED
738	04-Dec-24	HASAN	66	LINE	HNPR2-RNPR2	HOLENARASIPURA_220	11:01	11:03	00:02	LINE CLEAR AVAILED
739	04-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	11:46	16:05	04:19	LINE CLEAR AVAILED
740	04-Dec-24	HASAN	66	TRANSFORMER	HV1	HALEBEEDU_66	13:02	14:27	01:25	LINE CLEAR AVAILED
741	04-Dec-24	HASAN	220	TRANSFORMER	HV1	HEGGUNJE_220	10:38	13:46	03:08	LINE CLEAR AVAILED
742	04-Dec-24	HASAN	110	TRANSFORMER	HV1	KEMAR_220	10:15	12:26	02:11	LINE CLEAR AVAILED
743	04-Dec-24	HASAN	220	TRANSFORMER	HV1	MSEZ_220	10:20	12:39	02:19	LINE CLEAR AVAILED
744	04-Dec-24	HASAN	66	TRANSFORMER	HV2	HALEBEEDU_66	14:27	15:26	00:59	LINE CLEAR AVAILED
745	04-Dec-24	HASAN	220	TRANSFORMER	HV2	PUTTUR_220	09:43	13:22	03:39	LINE CLEAR AVAILED
746	04-Dec-24	HASAN	110	LINE	KEMAR-Manipal2	KEMAR_220	15:51	16:01	00:10	TRIPPED ON FAULT
747	04-Dec-24	HASAN	110	LINE	KEMAR-NANDHIKUR2	KEMAR_220	11:22	17:38	06:16	LINE CLEAR AVAILED
748	04-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	10:18	12:42	02:24	LINE CLEAR AVAILED
749	04-Dec-24	HASAN	110	TRANSFORMER	LV2	PUTTUR_220	09:43	13:22	03:39	LINE CLEAR AVAILED
750	04-Dec-24	HASAN	110	LINE	NANDIKU-KEMAR2	NANDIKUR_110	11:22	17:38	06:16	LINE CLEAR AVAILED
751	04-Dec-24	HASAN	110	LINE	SHRLKP-RANEENNUR	SHIRALKOPPA_220	12:18	13:33	01:15	TRIPPED ON FAULT
752	04-Dec-24	HASAN	400	LINE	TALAGU-NELAMANGALA2	TALAGUPPA_400	10:09	19:30	09:21	LINE CLEAR AVAILED
753	04-Dec-24	MYSORE	66	LINE	BG NAGARA-AC GIRI-VADERALLI	NO STATIONS EFFECTED	11:15	11:50	00:35	LINE CLEAR AVAILED
754	04-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
755	04-Dec-24	MYSORE	66	LINE	CR NAGARA-MUGURU-KOLLEGALA	NO STATIONS EFFECTED	06:10	06:20	00:10	TRIPPED ON FAULT
756	04-Dec-24	MYSORE	66	LINE	GUNDALPETE-TERAKANAMBI-CR NAGARA	TERAKANAMBE_66	06:37	07:17	00:39	TRIPPED ON FAULT
757	04-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
758	04-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
759	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	14:30	15:54	01:23	LINE CLEAR AVAILED
760	04-Dec-24	MYSORE	220	TRANSFORMER	HV1	HARVEY_66 BADANAGUPPE_66 HONAGANURU_66 SOMVARAPETE(GALIPURA)_66 CHANDAKAVADI_66	06:37	06:52	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
761	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	11:41	11:46	00:05	TRIPPED ON FAULT
762	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	15:15	15:25	00:10	LINE CLEAR AVAILED
763	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	MAMBALLI_66	11:30	12:05	00:35	LINE CLEAR AVAILED
764	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	SATHEGALA_66	17:25	18:11	00:46	LINE CLEAR AVAILED
765	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
766	04-Dec-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLY_66	10:30	12:29	01:59	LINE CLEAR AVAILED
767	04-Dec-24	MYSORE	220	TRANSFORMER	HV2	DODDARAYAPET_66 PANDYADAHUNDI_66	06:37	06:54	00:17	TRIPPED ON FAULT
768	04-Dec-24	MYSORE	66	TRANSFORMER	HV2	HULLALLI_66	17:31	17:40	00:09	TRIPPED ON FAULT
769	04-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	11:58	12:08	00:09	LINE CLEAR AVAILED
770	04-Dec-24	MYSORE	66	TRANSFORMER	HV2	SHIVALLY_66	12:35	15:05	02:30	LINE CLEAR AVAILED
771	04-Dec-24	MYSORE	220	TRANSFORMER	HV2	TUBINAKERE_220	10:51	14:03	03:11	LINE CLEAR AVAILED
772	04-Dec-24	MYSORE	220	LINE	KADAKOLA-BASTHIPURA 1	NO STATIONS EFFECTED	12:07	16:18	04:11	LINE CLEAR AVAILED
773	04-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
774	04-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
775	04-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
776	04-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66HARIYALDA MMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
777	04-Dec-24	MYSORE	66	LINE	MUGURU-TAYURU	NO STATIONS EFFECTED	18:08	18:13	00:05	TRIPPED ON FAULT
778	04-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	16:10	16:20	00:10	TRIPPED ON FAULT
779	04-Dec-24	MYSORE	66	LINE	SFCSIVA-ATRIA	NO STATIONS EFFECTED	18:00:00 (2/12/2024)	10:45 (04/12/2024)	40:45 HRs	TRIPPED ON FAULT
780	04-Dec-24	MYSORE	66	LINE	SFCSIVA-ATRIA	NO STATIONS EFFECTED	13:45 (04/12/2024)			LINE CLEAR AVAILED
781	04-Dec-24	MYSORE	66	LINE	SOMVARPETE-HONNALLI	ARKALVADI_66 ATTIGULIPURA_66 HONNALY MYS 66	05:30	05:40	00:10	TRIPPED ON FAULT
782	04-Dec-24	MYSORE	66	LINE	SOMVARPETE-HONNALLI	ARKALVADI_66 ATTIGULIPURA_66 HONNALY MYS 66	13:10	13:15	00:05	TRIPPED ON FAULT
783	04-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA TURUVANURU_66	TURUVANURU_66	13:40	16:08	2:28	LINE CLEAR AVAILED
784	04-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV NALLUR	66KV NALLUR,LINGADAHALLI	16:46	17:03	0:17	TRIPPED ON FAULT
785	04-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR,MALEBENNUR,D EVARBELAKERE	6:52	7:02	0:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
786	04-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV HALURAMESHWARA LINE-1	66KV HALRAMESHWARA,MADA DAKERE	0:15	0:30	0:15	TRIPPED ON FAULT
787	04-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV HALURAMESHWARA LINE-1	66KV HALRAMESHWARA,MADA DAKERE	6:35	6:50	0:15	TRIPPED ON FAULT
788	04-Dec-24	TUMKUR	220	LINE	BENKIKERE 220KV-HOSADURGA LINE 1 (MADHURE)	HOSADURGA_220	23:36 (02.12.2024)	11:27 (04.12.2024)	1DAY, 11:27 HR	LINE CLEAR AVAIED
789	04-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
790	04-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAIED
791	04-Dec-24	TUMKUR	66	LINE	HANGAL66-THALLAK 1	HANGAL_66	11:00	11:02	0:02	TRIPPED ON FAULT
792	04-Dec-24	TUMKUR	66	LINE	HANGAL66-THALLAK 2	HANGAL_66	15:14 (04.12.2024)	8:02 (05.12.2024)	17:48	LINE CLEAR AVAIED
793	04-Dec-24	TUMKUR	220	LINE	HONNALLI 220K-BENKIKERE-2	BENKIKERE_220	23:32 (02.12.2024)	11:11 (04.12.2024)	1DAY, 11:39 HR	LINE CLEAR AVAIED
794	04-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMGHATTA,	22:51	0:06	1:15	TRIPPED ON FAULT
795	04-Dec-24	TUMKUR	66	LINE	RAMPURA66-NAGASAMUDRA LINE-1	RAMAPURA_66	15:20	17:00	1:40	LINE CLEAR AVAIED
796	04-Dec-24	TUMKUR	66	LINE	RAMPURA66-NAGASAMUDRA LINE-2	RAMAPURA_66	15:20	17:00	1:40	LINE CLEAR AVAIED
797	04-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 10 MVA AMMASANDRA_66	AMMASANDRA_66	11:05	14:05	3:00	LINE CLEAR AVAIED
798	04-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA C.T.KERE_66	C.T.KERE_66	16:31	16:42	0:11	LINE CLEAR AVAIED
799	04-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
800	04-Dec-24	TUMKUR	66	LINE	TURUVANUR66-CHITRADURGA	TURUVANUR_66	0:18	0:25	0:07	TRIPPED ON FAULT
801	04-Dec-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	0:18	0:25	0:07	TRIPPED ON FAULT
802	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BELLATTI_110	10:30	17:10	6:40	LINE CLEAR AVAIED
803	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	DAMBAL_110	10:02	17:22	7:20	LINE CLEAR AVAIED
804	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BELLATTI_110	10:08	17:15	7:07	LINE CLEAR AVAIED
805	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(B)_110	13:56	14:24	0:28	LINE CLEAR AVAIED
806	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MUNDARGI_110	10:03	17:45	7:42	LINE CLEAR AVAIED
807	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10MVA)	HIDAKALDAM_110	10:51	11:07	0:16	TRIPPED ON FAULT
808	05-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	BELLATTI_110	10:08	17:15	7:07	LINE CLEAR AVAIED
809	05-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	NARENDRA_220	13:03	13:32	0:29	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
810	05-Dec-24	BAGALKOTE	110	LINE	AEQUS220-LN3(DADDI)	AEQUS_220	15:18	18:09	2:51	LINE CLEAR AVAILED
811	05-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA1	AMBEWADI_220	11:21	12:19	0:58	LINE CLEAR AVAILED
812	05-Dec-24	BAGALKOTE	110	LINE	BELLATTI-AB SOLAR	BELLATTI_110	16:29	18:10	1:41	LINE CLEAR AVAILED
813	05-Dec-24	BAGALKOTE	110	LINE	BELLATTI-ENERCON2	BELLATTI_110	10:20	18:07	7:47	LINE CLEAR AVAILED
814	05-Dec-24	BAGALKOTE	110	LINE	DAMBAL-AKHILAGYA SOLAR	DAMBAL_110	10:25	17:22	6:57	LINE CLEAR AVAILED
815	05-Dec-24	BAGALKOTE	110	LINE	DAMBAL-EILS(L1) (ENERCON)	DAMBAL_110	10:25	17:33	7:08	LINE CLEAR AVAILED
816	05-Dec-24	BAGALKOTE	110	LINE	DAMBAL-GADAG	DAMBAL_110	10:22	17:31	7:09	LINE CLEAR AVAILED
817	05-Dec-24	BAGALKOTE	110	LINE	DAMBAL-SUZLON 1 & 2	DAMBAL_110	10:25	17:32	7:07	LINE CLEAR AVAILED
818	05-Dec-24	BAGALKOTE	110	LINE	GADAG220-DAMBAL	GADAG_220	10:23	17:09	6:46	LINE CLEAR AVAILED
819	05-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
820	05-Dec-24	BAGALKOTE	110	LINE	HAVERI220-TILUVALLI(HANGAL)	HAVERI_220	20:29 (05.12.2024)			TRIPPED ON FAULT
821	05-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
822	05-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
823	05-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
824	05-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)			LINE CLEAR AVAILED
825	05-Dec-24	BAGALKOTE	110	LINE	KUMTA-SIRSI 1	KUMTA_110	16:22	17:13	0:51	TRIPPED ON FAULT
826	05-Dec-24	BAGALKOTE	110	LINE	MALGHAN(B)-BAGEWADI(RAILWAY)	MALGHAN(B)_110	11:00	16:03	5:03	LINE CLEAR AVAILED
827	05-Dec-24	BAGALKOTE	110	LINE	MALGHAN(B)-MAMDAPUR (MATTIHAL)	MALGHAN(B)_110	12:45	13:50	1:05	LINE CLEAR AVAILED
828	05-Dec-24	BAGALKOTE	220	LINE	MKHUBLI- NARENDRA2	MKHUBLI_220	11:40	15:43	4:03	LINE CLEAR AVAILED
829	05-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
830	05-Dec-24	BAGALKOTE	110	LINE	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	10:15	10:35	0:20	LINE CLEAR AVAILED
831	05-Dec-24	BAGALKOTE	110	LINE	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	17:20	17:40	0:20	LINE CLEAR AVAILED
832	05-Dec-24	BAGALKOTE	110	LINE	NANADI- CHIKKODI	NANADI_110	11:40	11:45	0:05	TRIPPED ON FAULT
833	05-Dec-24	BAGALKOTE	220	LINE	NARENDRA- AMBEWADI1	NARENDRA_220	11:21	12:19	0:58	LINE CLEAR AVAILED
834	05-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
835	05-Dec-24	BAGALKOTE	110	LINE	RAMANKOPPA-SAVANUR(DUNDASI)	RAMANKOPPA_110	09:02	17:38	8:36	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
836	05-Dec-24	BAGALKOTE	110	LINE	SAMBAPUR ROAD-DAMBAL	SAMBAPUR ROAD_110	10:29	16:34	6:05	LINE CLEAR AVAILED
837	05-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
838	05-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN220-LN1(DUNDASI)	SHIGGOAN_220	10:04	16:45	6:41	LINE CLEAR AVAILED
839	05-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
840	05-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
841	05-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
842	05-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
843	05-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
844	05-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDHURASHWATHA, GUNDLU KOTTUR	11:25	11:35	00:10	TRIPPED ON FAULT
845	05-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) DG3	NO STATION AFFECTED	11:13	13:36	02:23	TRIPPED ON FAULT
846	05-Dec-24	BANGALORE	66	LINE	66KV KODIHALLI - BIJJALLI - HUNASENAHALLI	BIJJAHALLI, HUNSENAHALLI	15:40	16:20	00:40	LINE CLEAR AVAILED
847	05-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	18:02	18:17	00:15	TRIPPED ON FAULT
848	05-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 1	NO STATION AFFECTED	07:11	08:33	01:22	TRIPPED ON FAULT
849	05-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 2	NO STATION AFFECTED	07:10	08:30	01:20	TRIPPED ON FAULT
850	05-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	12:23	13:12	00:49	LINE CLEAR AVAILED
851	05-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	14:50	17:08	02:18	TRIPPED ON FAULT
852	05-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	07:13	07:54	00:41	TRIPPED ON FAULT
853	05-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	13:04	13:11	00:07	LINE CLEAR AVAILED
854	05-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - REMCO	NO STATION AFFECTED	11:09	13:51	02:42	LINE CLEAR AVAILED
855	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ANDERSONPETE	17:20	17:25	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
856	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BG ROAD	14:25	14:35	00:10	LINE CLEAR AVAILED
857	05-Dec-24	BANGALORE	220	TRANSFORMER	HV1	CHANNAPATNA 220	13:45	14:22	00:37	LINE CLEAR AVAILED
858	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	16:40	16:50	00:10	TRIPPED ON FAULT
859	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HULLENAHALLI	12:50	13:55	01:05	LINE CLEAR AVAILED
860	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	18:25	18:30	00:05	TRIPPED ON FAULT
861	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SRINIVASPURA 66	10:25	15:45	05:20	TRIPPED ON FAULT
862	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	17:45	18:10	00:25	TRIPPED ON FAULT
863	05-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VRISHABHAVATHI 220	13:11	13:12	00:01	LINE CLEAR AVAILED
864	05-Dec-24	BANGALORE	220	TRANSFORMER	HV1	VRISHABHAVATHI 220	12:19	13:54	01:35	LINE CLEAR AVAILED
865	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ADDAGAL	14:45	14:55	00:10	TRIPPED ON FAULT
866	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ANDERSONPETE	14:10	17:20	03:10	LINE CLEAR AVAILED
867	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HULLENAHALLI	12:50	13:55	01:05	LINE CLEAR AVAILED
868	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	REMCO	16:41	16:46	00:05	LINE CLEAR AVAILED
869	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	REMCO	10:08	11:03	00:55	LINE CLEAR AVAILED
870	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	06:40	06:50	00:10	TRIPPED ON FAULT
871	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	17:30	17:55	00:25	LINE CLEAR AVAILED
872	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VRISHABHAVATHI 220	14:42	14:43	00:01	LINE CLEAR AVAILED
873	05-Dec-24	BANGALORE	220	TRANSFORMER	HV2	VRISHABHAVATHI 220	15:10	16:24	01:14	LINE CLEAR AVAILED
874	05-Dec-24	BANGALORE	66	TRANSFORMER	HV2	WELCAST	16:17	16:34	00:17	TRIPPED ON FAULT
875	05-Dec-24	GULBARGA	220	LINE	HALBARGA-HUMNABAD1&2	HALBARGA_220	09:40	16:35	06:55	LINE CLEAR AVAILED
876	05-Dec-24	GULBARGA	110	LINE	HALBARGA-HUMNABAD1, HALLIKHED, BHALKI, SANTHAPUR, KOLHAR1&2, CHIDRI, KAMATHANA, KHANAPUR TSS LINE	HALLIKHED_110, BHALKI_110, SANTHAPUR_110, KOLHAR_110, CHIDRI_110, KAMATHANA_110, KHANAPUR_110	16:00	16:30	00:30	LINE CLEAR AVAILED
877	05-Dec-24	GULBARGA	220	TRANSFORMER	HV1	HATTIGUDUR_220	11:22	13:38	02:16	LINE CLEAR AVAILED
878	05-Dec-24	GULBARGA	220	TRANSFORMER	HV1	LINGASUGUR_220	16:35	18:16	01:41	LINE CLEAR AVAILED
879	05-Dec-24	GULBARGA	110	TRANSFORMER	HV1	MARGUTTI_110	13:30	14:22	00:52	LINE CLEAR AVAILED
880	05-Dec-24	GULBARGA	220	TRANSFORMER	HV2	LINGASUGUR_220	12:23	16:30	04:07	LINE CLEAR AVAILED
881	05-Dec-24	GULBARGA	220	TRANSFORMER	HV2	SHAHAPUR_220	11:22	13:38	02:16	LINE CLEAR AVAILED
882	05-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	23:58:00	09:53	09:55	LINE CLEAR AVAILED
883	05-Dec-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	06:35	09:53	03:18	LINE CLEAR AVAILED
884	05-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	AMARESHWARA_110,MAD LAPUR_110,MANVI_110	10:33	15:45	05:12	LINE CLEAR AVAILED
885	05-Dec-24	GULBARGA	110	LINE	MARGUTTI-KAPNOOR	MARGUTTI_110	13:32	14:22	00:50	LINE CLEAR AVAILED
886	05-Dec-24	GULBARGA	110	LINE	MUNIRABAD-BHORUKA	BHORUKA_IPP	10:29	16:42	06:13	LINE CLEAR AVAILED
887	05-Dec-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPURA	MALLAPUR_110,KEREHAL LI_110	20:31	20:41	00:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
888	05-Dec-24	GULBARGA	110	LINE	MUNIRABAD-RAYAKERE	DONIMALAI_110,NMDC_FACTORY_IPP	09:48	16:38	06:50	LINE CLEAR AVAILED
889	05-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVGALU	HALVAGALU_66,HARVI_66	02:02	02:15	00:13	TRIPPED ON FAULT
890	05-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVGALU	HALVAGALU_66,HARVI_66	10:20	10:26	00:06	TRIPPED ON FAULT
891	05-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
892	05-Dec-24	GULBARGA	110	LINE	RAICHUR-MALIYABAD	MALIYABAD_110,VADAVATI_110,YERAGERA_110,YA PALADINNI_110	10:10	13:38	03:28	LINE CLEAR AVAILED
893	05-Dec-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR1	SINDHANOOR_110,SIRWAR_110	06:25	06:30	00:05	TRIPPED ON FAULT
894	05-Dec-24	GULBARGA	110	LINE	RUDRAWADI-KADAGANCHI	RUDRAWADI_110	16:45	16:50	00:05	MAIN SUPPLY FAILURE
895	05-Dec-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	11:15	11:25	00:10	TRIPPED ON FAULT
896	05-Dec-24	GULBARGA	66	LINE	TELAGI-KURUBARAHALLI	KURUBARAHALLI_66,SHAMANUR SUGAR_IPP	10:10	10:20	00:10	TRIPPED ON FAULT
897	05-Dec-24	HASAN	110	LINE	ANAVATTI	SHIRALKOPPA_220	14:50	16:55	02:05	LINE CLEAR AVAILED
898	05-Dec-24	HASAN	110	LINE	BADRAVATY3	MRSMG_220	09:37	17:33	07:56	LINE CLEAR AVAILED
899	05-Dec-24	HASAN	110	LINE	BARANG	SHIRALKOPPA_220	11:25	13:34	02:09	LINE CLEAR AVAILED
900	05-Dec-24	HASAN	220	LINE	DABUSPETE	KADUR_220	14:00(5.12.2024)			TRIPPED ON FAULT
901	05-Dec-24	HASAN	110	LINE	GAJNUR	MRSMG_220	10:09(5.12.2024)			LINE CLEAR AVAILED
902	05-Dec-24	HASAN	220	LINE	GOPALAP-HNPUR22	GOPALAPURA_220	23:07(04.12.2024)	00:8(05.12.2024)	1:00 hrs	LINE CLEAR AVAILED
903	05-Dec-24	HASAN	66	LINE	HASSAN	SAKALESH PURA_66	12:01	13:02	01:01	LINE CLEAR AVAILED
904	05-Dec-24	HASAN	110	LINE	HIRIYADKA	MANIPAL_110	12:30	12:45	00:15	TRIPPED ON FAULT
905	05-Dec-24	HASAN	110	LINE	HOSANGADI	HALADY_110	16:45	17:25	00:40	TRIPPED ON FAULT
906	05-Dec-24	HASAN	110	TRANSFORMER	HV1	ANAVATTI_110	12:10	12:50	00:40	LINE CLEAR AVAILED
907	05-Dec-24	HASAN	110	TRANSFORMER	HV1	BHADRAVATHI_110	09:38	17:35	07:57	LINE CLEAR AVAILED
908	05-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	11:11	13:50	02:39	LINE CLEAR AVAILED
909	05-Dec-24	HASAN	66	TRANSFORMER	HV1	MALLAPURA_66	08:10	08:25	00:15	MAIN SUPPLY FAILURE
910	05-Dec-24	HASAN	110	TRANSFORMER	HV1	NANDIKUR_110	16:42	17:29	00:47	MAIN SUPPLY FAILURE
911	05-Dec-24	HASAN	110	TRANSFORMER	HV2	BHADRAVATHI_110	09:38	17:35	07:57	LINE CLEAR AVAILED
912	05-Dec-24	HASAN	220	TRANSFORMER	HV2	KEMAR_220	16:41	17:40	00:59	TRIPPED ON FAULT
913	05-Dec-24	HASAN	220	TRANSFORMER	HV2	MRSMG_220	09:28	16:43	07:15	LINE CLEAR AVAILED
914	05-Dec-24	HASAN	110	TRANSFORMER	HV2	NANDIKUR_110	16:42	17:29	00:47	MAIN SUPPLY FAILURE
915	05-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATH PURA_66	13:07	16:18	03:11	LINE CLEAR AVAILED
916	05-Dec-24	HASAN	110	TRANSFORMER	HV3	BHADRAVATHI_110	09:38	17:35	07:57	LINE CLEAR AVAILED
917	05-Dec-24	HASAN	220	LINE	HV3	KADUR_220	13:18	17:50	04:32	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
918	05-Dec-24	HASAN	110	LINE	ISTR	NANDIKUR_110	16:42	17:29	00:47	MAIN SUPPLY FAILURE
919	05-Dec-24	HASAN	110	LINE	KAVOOR	MSEZ_220	1:53(3.12.2024)	16:48(5.12.2024)	62:54 hrs	TRIPPED ON FAULT
920	05-Dec-24	HASAN	110	LINE	KEMAR2	NANDIKUR_110	16:42	17:29	00:47	MAIN SUPPLY FAILURE
921	05-Dec-24	HASAN	220	LINE	KEMAR3	gen_varahi	16:32	17:26	00:54	TRIPPED ON FAULT
922	05-Dec-24	HASAN	66	LINE	KRNAGARA	DODDAKADNUR_66	14:00	14:35	00:35	LINE CLEAR AVAILED
923	05-Dec-24	HASAN	66	LINE	KRNAGARA	DODDAKADNUR_66	15:40	16:30	00:50	LINE CLEAR AVAILED
924	05-Dec-24	HASAN	110	LINE	Kulashkhara1	KAVOOR_220	10:01	18:09	08:08	LINE CLEAR AVAILED
925	05-Dec-24	HASAN	110	LINE	LST3	gen_lph	16:13	17:05	00:52	LINE CLEAR AVAILED
926	05-Dec-24	HASAN	110	LINE	LST3	SAGARA_110	16:10	17:04	00:54	LINE CLEAR AVAILED
927	05-Dec-24	HASAN	110	TRANSFORMER	LV2	KEMAR_220	16:41	17:40	00:59	TRIPPED ON FAULT
928	05-Dec-24	HASAN	110	TRANSFORMER	LV2	MRSMG_220	09:28	16:43	07:15	LINE CLEAR AVAILED
929	05-Dec-24	HASAN	110	LINE	MAVALI	SORABA_110	16:16(5.12.2024)			TRIPPED ON FAULT
930	05-Dec-24	HASAN	110	LINE	NANDHIKUR1	KEMAR_220	10:26	11:59	01:33	LINE CLEAR AVAILED
931	05-Dec-24	HASAN	110	LINE	NANDHIKUR1	KEMAR_220	16:41	17:25	00:44	TRIPPED ON FAULT
932	05-Dec-24	HASAN	110	LINE	NANDHIKUR2	KEMAR_220	16:41	17:27	00:46	TRIPPED ON FAULT
933	05-Dec-24	HASAN	110	LINE	NDKR-SUZLON	NANDIKUR_110	16:42	17:29	00:47	MAIN SUPPLY FAILURE
934	05-Dec-24	HASAN	110	LINE	SHIMOGA IC LINE	GAJNUR_110	10:26(5.12.2024)			LINE CLEAR AVAILED
935	05-Dec-24	HASAN	110	LINE	SORABA	SAGARA_110	14:50	16:08	01:18	LINE CLEAR AVAILED
936	05-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:40	19:12	09:32	LINE CLEAR AVAILED
937	05-Dec-24	HASAN	220	LINE	VRH	HEGGUNJE_220	16:32	17:26	00:54	TRIPPED ON FAULT
938	05-Dec-24	MYSORE	66	LINE	BANNIMANTAPA-FTS-1	FTS_66	10:01	17:30	07:28	LINE CLEAR AVAILED
939	05-Dec-24	MYSORE	66	LINE	BANNIMANTAPA-FTS-2	FTS_66	10:01	17:30	07:28	LINE CLEAR AVAILED
940	05-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
941	05-Dec-24	MYSORE	66	LINE	DK MAIDANA-JYOTHINAGARA	JYOTHINAGARA_66	09:23	18:01	08:38	LINE CLEAR AVAILED
942	05-Dec-24	MYSORE	66	LINE	DODDINDHUVADI-KOTHANUR	NO STATIONS EFFECTED	16:45	16:55	00:10	TRIPPED ON FAULT
943	05-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
944	05-Dec-24	MYSORE	66	LINE	HANUR-AJIPURA-BANDALLI	AJJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	09:55	10:05	00:10	TRIPPED ON FAULT
945	05-Dec-24	MYSORE	66	LINE	HEBBANI-BANNUR	NO STATIONS EFFECTED	10:25	15:45	05:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
946	05-Dec-24	MYSORE	66	LINE	HEBBANI-BG PURA-CHIDRAVALLI	BGPURA_66 CHIDRAVALLI_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	06:16	06:28	00:12	TRIPPED ON FAULT
947	05-Dec-24	MYSORE	66	LINE	HEBBANI-BG PURA-CHIDRAVALLI	NO STATIONS EFFECTED	14:00	15:22	01:22	LINE CLEAR AVAILED
948	05-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
949	05-Dec-24	MYSORE	66	LINE	HONNAHALLI-ATTIGULIPURA	ATTIGULIPURA_66	06:00	06:05	00:05	TRIPPED ON FAULT
950	05-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
951	05-Dec-24	MYSORE	66	TRANSFORMER	HV2	SHEELUNERE_66	14:10	14:40	00:30	LINE CLEAR AVAILED
952	05-Dec-24	MYSORE	66	LINE	JYOTHINAGARA-FTS	FTS_66	08:19	18:51	10:32	LINE CLEAR AVAILED
953	05-Dec-24	MYSORE	66	LINE	JYOTHINAGARA-VAJAMANGALA	JYOTHINAGARA_66	10:08	16:58	06:50	LINE CLEAR AVAILED
954	05-Dec-24	MYSORE	220	LINE	KADAKOLA-ADAKANAHALLI-1	NO STATIONS EFFECTED	11:01	12:20	01:19	LINE CLEAR AVAILED
955	05-Dec-24	MYSORE	220	LINE	KADAKOLA-ADAKANAHALLI-2	NO STATIONS EFFECTED	12:29	14:50	02:20	LINE CLEAR AVAILED
956	05-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
957	05-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
958	05-Dec-24	MYSORE	66	LINE	KARYA-HEMMARAGALA	HEMMARGALA_66	15:57	16:15	00:18	TRIPPED ON FAULT
959	05-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
960	05-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
961	05-Dec-24	MYSORE	66	LINE	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	10:43	10:47	00:03	TRIPPED ON FAULT
962	05-Dec-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	16:30	17:00	00:30	LINE CLEAR AVAILED
963	05-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	12:10	14:57	02:47	LINE CLEAR AVAILED
964	05-Dec-24	MYSORE	66	LINE	PANNYADAHUNDI-KARYA	HEMMARGALA_66, KARYA_66	15:57	16:02	00:05	TRIPPED ON FAULT
965	05-Dec-24	MYSORE	66	LINE	PARINAMIPURA-KOLLEGALA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	06:18	06:29	00:11	TRIPPED ON FAULT
966	05-Dec-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	13:24	15:34	02:09	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
967	05-Dec-24	MYSORE	66	LINE	SFC SIVA-10 MW SOLAR	NO STATIONS EFFECTED	06:05	06:27	00:22	TRIPPED ON FAULT
968	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-1	NO STATIONS EFFECTED	09:43	11:41	01:57	LINE CLEAR AVAILED
969	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-2	NO STATIONS EFFECTED	09:43	11:41	01:57	LINE CLEAR AVAILED
970	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-6	NO STATIONS EFFECTED	09:43	18:14	08:30	LINE CLEAR AVAILED
971	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-7	NO STATIONS EFFECTED	12:59	15:07	02:08	LINE CLEAR AVAILED
972	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-8	NO STATIONS EFFECTED	11:47	12:53	01:06	LINE CLEAR AVAILED
973	05-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI-9	NO STATIONS EFFECTED	11:47	12:53	01:06	LINE CLEAR AVAILED
974	05-Dec-24	MYSORE	66	LINE	SFCSIVA-ATRIA	NO STATIONS EFFECTED	13:45 (04/12/2024)	19:45 (05/12/2024)	30:00 HRs	LINE CLEAR AVAILED
975	05-Dec-24	MYSORE	66	LINE	VIJAYANAGARA-FTS	FTS_66	08:31	19:59	11:27	LINE CLEAR AVAILED
976	05-Dec-24	TUMKUR	110	LINE	220KV NITTUR-110 KV KALLUR	66KV KALLUR	19:21	19:39	0:18	TRIPPED ON FAULT
977	05-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-2- HANAGAL	66KV HANGAL,66 NAGASAMUDRA & RAMPURA	7:04	8:02	0:58	LINE CLEAR AVAILED
978	05-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-2- HANAGAL	66KV HANGAL,NAGASAMUDRA & RAMPURA	19:05	20:14	1:09	TRIPPED ON FAULT
979	05-Dec-24	TUMKUR	66	LINE	66 KV RAMAGIRI LINE-66KV BAGUR LINE	NO STATION AFFECTED	17:10	17:20	0:10	TRIPPED ON FAULT
980	05-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	1:50	2:15	0:25	TRIPPED ON FAULT
981	05-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
982	05-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
983	05-Dec-24	TUMKUR	220	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	17:32	19:43	2:11	TRIPPED ON FAULT
984	05-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-MIDIGESHI_66-1 LINE	66KV MIDIGESHI, HOSKERE	3:39	3:49	0:10	TRIPPED ON FAULT
985	05-Dec-24	TUMKUR	66	LINE	SASALUHALLA_66 -KNNL W/S	KNNL W/S	18:03	19:37	1:34	TRIPPED ON FAULT
986	05-Dec-24	TUMKUR	66	LINE	TELLIGI_KURUBARAHALLI 66	KURUBARAHALLI MUSS, SHAMNUR SUGAR IPP	10:20	10:25	0:05	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
987	05-Dec-24	TUMKUR	66	LINE	THALLAK 220KV- HANGAL 66KV	HANGAL_66	15:14 (04.12.2024)	8:02 (05.12.2024)	17:48	LINE CLEAR AVAILED
988	05-Dec-24	TUMKUR	66	TRANSFORMER	TR1 8 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	16:15	16:55	0:40	LINE CLEAR AVAILED
989	05-Dec-24	TUMKUR	220	TRANSFORMER	TR-1,100MVA (HV SIDE))THALLAK_220	THALLAK_220	19:04	19:48	0:44	TRIPPED ON FAULT
990	05-Dec-24	TUMKUR	220	TRANSFORMER	TR-1,100MVA (LV SIDE))THALLAK_220	THALLAK_220	19:04	19:48	0:44	TRIPPED ON FAULT
991	05-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
992	05-Dec-24	TUMKUR	66	TRANSFORMER	TR2 6.3 MVA,HEGGERE_66	HEGGERE_66	11:05	12:40	1:35	LINE CLEAR AVAILED
993	05-Dec-24	TUMKUR	220	TRANSFORMER	TR-2 100MVA CHITRADURGA_66	CHITRADURGA_66	12:57	17:53	4:56	LINE CLEAR AVAILED
994	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KALADAGI_110	10:04	13:47	3:43	LINE CLEAR AVAILED
995	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SALAHALLI_110	09:44	18:26	8:42	LINE CLEAR AVAILED
996	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	16:49	16:54	0:05	TRIPPED ON FAULT
997	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	DAMBAL_110	11:32	11:45	0:13	LINE CLEAR AVAILED
998	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	HANAGAL_110	00:01	04:05	4:04	LINE CLEAR AVAILED
999	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULGERI CROSS_110	00:10	00:20	0:10	TRIPPED ON FAULT
1000	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(B)_110	09:21	15:23	6:02	LINE CLEAR AVAILED
1001	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	16:13	16:24	0:11	LINE CLEAR AVAILED
1002	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	10:04	10:09	0:05	TRIPPED ON FAULT
1003	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KALADAGI_110	10:04	13:46	3:42	LINE CLEAR AVAILED
1004	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	HIDIKAL DAM	13:34	14:36	1:02	LINE CLEAR AVAILED
1005	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	15:31	15:44	0:13	LINE CLEAR AVAILED
1006	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	SALAHALLI_110	09:44	17:55	8:11	LINE CLEAR AVAILED
1007	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	UCHAGOAN_110	18:49	21:35	2:46	TRIPPED ON FAULT
1008	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	HANAGAL_110	00:01	04:11	4:10	LINE CLEAR AVAILED
1009	06-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(10MVA)	SALAHALLI_110	09:44	18:12	8:28	LINE CLEAR AVAILED
1010	06-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	NARENDRA_220	13:14	15:33	2:19	LINE CLEAR AVAILED
1011	06-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	NARENDRA_220	13:48	13:53	0:05	TRIPPED ON FAULT
1012	06-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA2	AMBEWADI_220	16:26 (06.12.2024)			TRIPPED ON FAULT
1013	06-Dec-24	BAGALKOTE	110	LINE	ATHARGA-RAILWAY	ATHARGA_110	15:34	15:52	0:18	TRIPPED ON FAULT
1014	06-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F7- RAMDURG	BAGALKOT_220	10:58	15:40	4:42	LINE CLEAR AVAILED
1015	06-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-KALADAGI	BAGALKOT_220	10:03	13:41	3:38	LINE CLEAR AVAILED
1016	06-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220- LOKAPUR(KAINKATTI)	BAGALKOT_220	04:59	05:11	0:12	TRIPPED ON FAULT
1017	06-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220- LOKAPUR(KAINKATTI)	BAGALKOT_220	10:06	17:03	6:57	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1018	06-Dec-24	BAGALKOTE	220	LINE	BIDNAL- HUBLI3(HUBLI2)	BIDNAL_220	11:21	14:54	3:33	LINE CLEAR AVAILED
1019	06-Dec-24	BAGALKOTE	110	LINE	GADAG220- SHIRAHATTI	GADAG_220	10:46	13:28	2:42	LINE CLEAR AVAILED
1020	06-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
1021	06-Dec-24	BAGALKOTE	110	LINE	HAVERI220- TILUVALLI(HANGAL)	HAVERI_220	20:29 (05.12.2024)	4:03 (06.12.2024)	7:34:00	TRIPPED ON FAULT
1022	06-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
1023	06-Dec-24	BAGALKOTE	220	LINE	HUBLI- BIDNAL2	HUBLI_220	11:21	14:54	3:33	LINE CLEAR AVAILED
1024	06-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1025	06-Dec-24	BAGALKOTE	110	LINE	INDI220- DEVARGENNUR	INDI_220	15:34	15:45	0:11	LINE CLEAR AVAILED
1026	06-Dec-24	BAGALKOTE	110	LINE	INDI220- INDI	INDI_220	15:13	15:28	0:15	LINE CLEAR AVAILED
1027	06-Dec-24	BAGALKOTE	110	LINE	INDI220- ZALKI1	INDI_220	16:08	16:16	0:08	LINE CLEAR AVAILED
1028	06-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
1029	06-Dec-24	BAGALKOTE	110	LINE	KALADAGI-BAGALKOT	KALADAGI_110	10:05	13:42	3:37	LINE CLEAR AVAILED
1030	06-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3:12.2024)			LINE CLEAR AVAILED
1031	06-Dec-24	BAGALKOTE	220	LINE	MKHUBLI- NARENDRA2	MKHUBLI_220	11:49	16:49	5:00	LINE CLEAR AVAILED
1032	06-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1033	06-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
1034	06-Dec-24	BAGALKOTE	110	LINE	SALAHALLI-GM NAVAR	SALAHALLI_110	09:44	17:54	8:10	LINE CLEAR AVAILED
1035	06-Dec-24	BAGALKOTE	110	LINE	SALAHALLI-LOKAPUR	SALAHALLI_110	09:44	17:56	8:12	LINE CLEAR AVAILED
1036	06-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
1037	06-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
1038	06-Dec-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-HIRE BAGEWADI	SUVARNA SOUDA_110	08:48	13:47	4:59	LINE CLEAR AVAILED
1039	06-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
1040	06-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1041	06-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1042	06-Dec-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	NO STATION AFFECTED	12:39	13:05	00:26	TRIPPED ON FAULT
1043	06-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400- DB PURA 1	NO STATION AFFECTED	14:02	16:58	02:56	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1044	06-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DB PURA 2	NO STATION AFFECTED	14:02	16:58	02:56	LINE CLEAR AVAILED
1045	06-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1046	06-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDURASHWATHA AND G.KOTTUR	12:15	12:30	00:15	TRIPPED ON FAULT
1047	06-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI) DG4	HENNUR CROSS (GEDALAHALLI), PURVANKARA PALM BEACH	13:24	13:27	00:03	LINE CLEAR AVAILED
1048	06-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI	66KV MELEHALLI, 66KV KEMPANAHALLI, 66KV URAGAHALLI, 66KV JALAMANGALA, 66KV KUTAGALU, 66KV CHIKKAGANGANAWADI	17:58	18:05	00:07	TRIPPED ON FAULT
1049	06-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY DG3	SHOBA CITY	12:38	13:24	00:46	TRIPPED ON FAULT
1050	06-Dec-24	BANGALORE	66	LINE	66KV MASTHENAHALLI - TALAGAWARA	TALAGAWARA & CHEEMANGLA	12:47	12:57	00:10	LINE CLEAR AVAILED
1051	06-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - MAHALAKSHMI LAYOUT	NO STATION AFFECTED	12:12	12:54	00:42	LINE CLEAR AVAILED
1052	06-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - MAHALAKSHMI LAYOUT	NO STATION AFFECTED	22:38	23:59	01:21	LINE CLEAR AVAILED
1053	06-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	16:22	18:40	02:18	TRIPPED ON FAULT
1054	06-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	66KV MAHALAKSHMI LAYOUT STATION	22:01	22:30	00:29	LINE CLEAR AVAILED
1055	06-Dec-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA & CHEEMANGLA	17:37	17:47	00:10	LINE CLEAR AVAILED
1056	06-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	NO STATION AFFECTED	08:22	09:32	01:10	LINE CLEAR AVAILED
1057	06-Dec-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELLE RAILWAYS.	19:45	19:50	00:05	TRIPPED ON FAULT
1058	06-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI) _DG4	HENNUR CROSS (GEDALAHALLI), PURVANKARA PALM BEACH	15:36	15:40	00:04	LINE CLEAR AVAILED
1059	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	66KV MAHALAKSHMI LAYOUT STATION	22:01	22:06	00:05	LINE CLEAR AVAILED
1060	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHANDRAPPA CIRCLE	11:45	12:00	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1061	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	17:33	18:27	00:54	LINE CLEAR AVAILED
1062	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ELITA PROMENADE	10:25	10:30	00:05	LINE CLEAR AVAILED
1063	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NALLIMARADAHALLI	11:35	11:45	00:10	LINE CLEAR AVAILED
1064	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETAN	11:05	14:40	03:35	TRIPPED ON FAULT
1065	06-Dec-24	BANGALORE	220	TRANSFORMER	HV1	PUTTENAHALLI YELAHANKA 220(NO LOAD AFFECTED	09:42	13:20	03:38	LINE CLEAR AVAILED
1066	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RAJANKUNTE	15:00	15:05	00:05	LINE CLEAR AVAILED
1067	06-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RAMDEVARAGUDI	17:00	18:00	01:00	LINE CLEAR AVAILED
1068	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	66KV MAHALAKSHMI LAYOUT STATION	22:01	22:06	00:05	LINE CLEAR AVAILED
1069	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDAPURA	08:53	09:50	00:57	TRIPPED ON FAULT
1070	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DEVARABISANAHALLI	10:40	11:00	00:20	TRIPPED ON FAULT
1071	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	13:17	13:27	00:10	TRIPPED ON FAULT
1072	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KANASAWADI	14:05	14:10	00:05	LINE CLEAR AVAILED
1073	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KUMBARANAHALLI	12:50	13:50	01:00	LINE CLEAR AVAILED
1074	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MALLASANDRA (T D HALLI)	12:03	12:07	00:04	LINE CLEAR AVAILED
1075	06-Dec-24	BANGALORE	220	TRANSFORMER	HV2	PUTTENAHALLI YELAHANKA 220(NO LOAD AFFECTED	13:23	16:12	02:49	LINE CLEAR AVAILED
1076	06-Dec-24	BANGALORE	66	TRANSFORMER	HV2	RAJANKUNTE	13:05	13:10	00:05	LINE CLEAR AVAILED
1077	06-Dec-24	GULBARGA	220	LINE	ALIPUR-BTPS	ALIPUR_220	05:17	05:48	00:31	TRIPPED ON FAULT
1078	06-Dec-24	GULBARGA	220	LINE	ALIPUR-BTPS	ALIPUR_220	05:48	10:30	04:42	TRIPPED ON FAULT
1079	06-Dec-24	GULBARGA	220	LINE	ALIPUR-BTPS	ALIPUR_220	10:30	12:57	02:27	LINE CLEAR AVAILED
1080	06-Dec-24	GULBARGA	110	LINE	BYAGWAT-MALLAT	BYAGWAT_110, WALKAMDINNI_110	13:40	13:48	00:08	TRIPPED ON FAULT
1081	06-Dec-24	GULBARGA	220	LINE	FEROZABAD-AVAADA	FEROZABAD_400	24:00:00	24:01:00	0:01:00	LINE CLEAR AVAILED
1082	06-Dec-24	GULBARGA	110	LINE	HALWARTHY- HIRESINDOGI	HIRESIDOGI_110	09:25	14:49	05:24	LINE CLEAR AVAILED
1083	06-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	17:39	17:50	00:11	TRIPPED ON FAULT
1084	06-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	14:05	14:12	00:07	TRIPPED ON FAULT
1085	06-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HARAPANAHALLI_66	08:40	08:45	00:05	TRIPPED ON FAULT
1086	06-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KUDILIGI_220	06:20	07:00	00:40	TRIPPED ON FAULT
1087	06-Dec-24	GULBARGA	110	TRANSFORMER	HV2	CHUKSUGUR_110	24:00:00	24:01:00	0:01:00	LINE CLEAR AVAILED
1088	06-Dec-24	GULBARGA	220	TRANSFORMER	HV2	KUDILIGI_220	06:20	06:40	00:20	TRIPPED ON FAULT
1089	06-Dec-24	GULBARGA	66	LINE	ITTAGGI-KUDLIGI 1,2	KOGALI_66,KUDLIGI_66,CJ HALLI_66,HOSAHALLI_66, HUDEM_66	10:36	17:10	06:34	LINE CLEAR AVAILED
1090	06-Dec-24	GULBARGA	110	LINE	KALBURGI UNIVERSITY- KALBURGI NORTH	KALBURGI UNIVERSITY_110	11:30	14:30	03:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1091	06-Dec-24	GULBARGA	110	LINE	KUDITINI-TORANGALU	TORANGALU_110,METRI_110,KURUGOD_110	07:10	07:20	00:10	LINE CLEAR AVAILED
1092	06-Dec-24	GULBARGA	110	LINE	KUDITINI-TORANGALU	TORANGALU_110,METRI_110,KURUGOD_110	17:05	17:10	00:05	LINE CLEAR AVAILED
1093	06-Dec-24	GULBARGA	110	LINE	MADLAPUR-MALLAT	ADVIAMARESHWAR_110	12:57	14:10	01:13	LINE CLEAR AVAILED
1094	06-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
1095	06-Dec-24	GULBARGA	110	LINE	RAICHUR-SINDHNOOR1	SINDHNOOR_110, SIRWAR_110	06:20	06:45	00:25	TRIPPED ON FAULT
1096	06-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-KONKAL	KONKAL_110	06:15	06:20	00:05	TRIPPED ON FAULT
1097	06-Dec-24	GULBARGA	220	LINE	SEDAM-CLEANMAX_SLR	SEDAM_220	17:56	18:52	00:56	LINE CLEAR AVAILED
1098	06-Dec-24	GULBARGA	220	LINE	SEDAM-FEROZABAD	SEDAM_220	23:58:00	22:28	22:30	TRIPPED ON FAULT
1099	06-Dec-24	GULBARGA	110	LINE	SEDAM-KURKUNTA	KURKUNTA_110	18:27	20:34	02:07	TRIPPED ON FAULT
1100	06-Dec-24	HASAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	12:30	13:45	01:15	LINE CLEAR AVAILED
1101	06-Dec-24	HASAN	110	LINE	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	10:26(5.12.2024)	9:20(6.12.2024)	22:53 hrs	LINE CLEAR AVAILED
1102	06-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	11:20	17:35	06:15	LINE CLEAR AVAILED
1103	06-Dec-24	HASAN	110	TRANSFORMER	HV1	GERUMARa_110	12:34	13:32	00:58	LINE CLEAR AVAILED
1104	06-Dec-24	HASAN	220	TRANSFORMER	HV1	KADUR_220	11:45	15:30	03:45	LINE CLEAR AVAILED
1105	06-Dec-24	HASAN	66	TRANSFORMER	HV1	KIADB HASSAN_66	11:25	11:45	00:20	LINE CLEAR AVAILED
1106	06-Dec-24	HASAN	110	TRANSFORMER	HV2	MRSMSG_220	12:21	13:40	01:19	LINE CLEAR AVAILED
1107	06-Dec-24	HASAN	110	LINE	JOG-JST2	gen_mghe	14:27	15:31	01:04	TRIPPED ON FAULT
1108	06-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	14:00(5.12.2024)	11:35 (6.12.2024)	21:34 hrs	LINE CLEAR AVAILED
1109	06-Dec-24	HASAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	10:15	12:51	02:36	LINE CLEAR AVAILED
1110	06-Dec-24	HASAN	110	TRANSFORMER	LV1	KADUR_220	06:14	15:30	09:16	LINE CLEAR AVAILED
1111	06-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:00	15:15	04:15	LINE CLEAR AVAILED
1112	06-Dec-24	HASAN	110	LINE	MRSSHM-BADRAVATY3	MRSMSG_220	13:57	14:01	00:04	LINE CLEAR AVAILED
1113	06-Dec-24	HASAN	110	LINE	MRSSHM-GAJNUR	MRSMSG_220	10:09(5.12.2024)	8:56(6.12.2024)	22:46 hrs	LINE CLEAR AVAILED
1114	06-Dec-24	HASAN	110	LINE	MRSSHM-RLW CBreaker	MRSMSG_220	10:15	14:30	04:15	LINE CLEAR AVAILED
1115	06-Dec-24	HASAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	12:45	14:45	02:00	TRIPPED ON FAULT
1116	06-Dec-24	HASAN	220	LINE	MRSSHM-VARAH2	MRSMSG_220	13:10	17:40	04:30	TRIPPED ON FAULT
1117	06-Dec-24	HASAN	110	LINE	SAGARA-JST2	SAGARA_110	14:27	15:31	01:04	TRIPPED ON FAULT
1118	06-Dec-24	HASAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:13	15:42	04:29	MAIN SUPPLY FAILURE
1119	06-Dec-24	HASAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	11:42	15:20	03:38	LINE CLEAR AVAILED
1120	06-Dec-24	HASAN	220	LINE	SHRAVTY-TALAGUPPA1	gen_sharavathy	09:25	17:28	08:03	LINE CLEAR AVAILED
1121	06-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	11:42	15:20	03:38	LINE CLEAR AVAILED
1122	06-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	16:16(5.12.2024)	16:18(6.12.2024)	24:01 hrs	LINE CLEAR AVAILED
1123	06-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:25	17:28	08:03	LINE CLEAR AVAILED
1124	06-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	12:45	14:45	02:00	TRIPPED ON FAULT
1125	06-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	13:10	17:40	04:30	TRIPPED ON FAULT
1126	06-Dec-24	MYSORE	66	LINE	BANNIMANTAPA-FTS 1	FTS_66	12:43	12:58	00:14	TRIPPED ON FAULT
1127	06-Dec-24	MYSORE	66	LINE	BANNIMANTAPA-FTS 2	FTS_66	12:43	12:59	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1128	06-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
1129	06-Dec-24	MYSORE	66	LINE	CRNAGAR-CHANDAKAVADI	CHANDAKAVADI_66	03:27	03:30	00:03	TRIPPED ON FAULT
1130	06-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
1131	06-Dec-24	MYSORE	220	LINE	HEBBANI-MADHUVAHALLI 1	NO STATIONS EFFECTED	10:40	11:34	00:54	LINE CLEAR AVAILED
1132	06-Dec-24	MYSORE	220	LINE	HEBBANI-MADHUVAHALLI 2	NO STATIONS EFFECTED	09:40	10:39	00:59	LINE CLEAR AVAILED
1133	06-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
1134	06-Dec-24	MYSORE	66	LINE	HEBBANI-SIMSHA	NO STATIONS EFFECTED	20:18	20:33	00:15	TRIPPED ON FAULT
1135	06-Dec-24	MYSORE	66	LINE	HEBBANI-SIMSHA	NO STATIONS EFFECTED	11:20	13:12	01:52	LINE CLEAR AVAILED
1136	06-Dec-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	12:17	13:28	01:11	LINE CLEAR AVAILED
1137	06-Dec-24	MYSORE	66	LINE	HEBBANI-VADKEPURA	NO STATIONS EFFECTED	11:50	12:45	00:55	LINE CLEAR AVAILED
1138	06-Dec-24	MYSORE	66	LINE	HOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	10:36	16:22	05:46	LINE CLEAR AVAILED
1139	06-Dec-24	MYSORE	66	TRANSFORMER	HV1	MALLAVALLI_66	09:43	10:11	00:28	LINE CLEAR AVAILED
1140	06-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1141	06-Dec-24	MYSORE	220	TRANSFORMER	HV1	TUBINKERE_220	11:29	14:39	03:09	LINE CLEAR AVAILED
1142	06-Dec-24	MYSORE	220	TRANSFORMER	HV2	HEBBANI_220	11:06	12:08	01:02	LINE CLEAR AVAILED
1143	06-Dec-24	MYSORE	66	TRANSFORMER	HV2	JYOTHINAGARA_66	12:35	13:07	00:32	LINE CLEAR AVAILED
1144	06-Dec-24	MYSORE	220	LINE	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	11:45	15:34	03:49	LINE CLEAR AVAILED
1145	06-Dec-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	07:51	16:10	08:19	LINE CLEAR AVAILED
1146	06-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1147	06-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1148	06-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
1149	06-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
1150	06-Dec-24	MYSORE	220	LINE	MADHUVANAHALLI-TKHALI 1	NO STATIONS EFFECTED	10:40	11:34	00:54	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1151	06-Dec-24	MYSORE	220	LINE	MADHUVANAHALLI-TKHALLI 2	NO STATIONS EFFECTED	09:40	10:39	00:59	LINE CLEAR AVAILED
1152	06-Dec-24	MYSORE	66	LINE	MUGUR-THAYUR	THAYURU_66 VYASRAJPURA_66 GARGESHWARI_66 TNARASIPURA_66	18:20	18:25	00:05	TRIPPED ON FAULT
1153	06-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	20:18:00 (6/12/2024)			TRIPPED ON FAULT
1154	06-Dec-24	MYSORE	66	LINE	SFCSIVA-5 MW SOLAR	NO STATIONS EFFECTED	20:18:00 (6/12/2024)			TRIPPED ON FAULT
1155	06-Dec-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	20:18	20:21	00:02	TRIPPED ON FAULT
1156	06-Dec-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	02:52	02:57	00:05	TRIPPED ON FAULT
1157	06-Dec-24	TUMKUR	66	LINE	220KV MADHURE-66KV O/G LINE HALRAMESHWARA-1 AND MADADAKERE	66KV HALURAMESHWARA AND MADADAKERE	23:40	23:55	0:15	TRIPPED ON FAULT
1158	06-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1	66KV HANAGAL, NAGASAMUDRA AND RAMPURA	1:14	1:34	0:20	TRIPPED ON FAULT
1159	06-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-2	HANAGAL, NAGASAMUDRA AND RAMPURA	0:07	0:30	0:23	TRIPPED ON FAULT
1160	06-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	NIL (IDLE LINE)	23:54	23:59	0:05	TRIPPED ON FAULT
1161	06-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA	66KV MYLANAHALLI VV PURA	6:17	6:32	0:15	TRIPPED ON FAULT
1162	06-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	PALLAGATE,BILICHODU	5:35	5:50	0:15	TRIPPED ON FAULT
1163	06-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	PALLAGATE,BILICHODU	6:17	6:50	0:33	TRIPPED ON FAULT
1164	06-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	SOKKE,PALLAGATE,BILICH ODU	22:50	23:00	0:10	TRIPPED ON FAULT
1165	06-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	66KV JAGALURU	6:20	6:45	0:25	TRIPPED ON FAULT
1166	06-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV UJJINI (OTHER ZONE)	6:20	6:45	0:25	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1167	06-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-BELLAVI_66	66KV BELLAVI, DODDASARANGI, HEGGERE, MALLSANDRA	7:10	7:31	0:21	TRIPPED ON FAULT
1168	06-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	-66KV ANAGODU , ATTIGERE	1:55	2:32	0:37	TRIPPED ON FAULT
1169	06-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	-66KV HARIHAR NEW	19:43	19:48	0:05	TRIPPED ON FAULT
1170	06-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	12:00	12:10	0:10	TRIPPED ON FAULT
1171	06-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	6:56	14:10	7:14	TRIPPED ON FAULT
1172	06-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV-BEERANAHALLI-2	BEERANAHALLI	13:45	22:36	8:51	LINE CLEAR AVAILED
1173	06-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1174	06-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1175	06-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA-1	GUTUR_400	13:45	22:36	8:51	LINE CLEAR AVAILED
1176	06-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV- 66KV CHALLAKERE	66KV SANIKERE	7:15	7:20	0:05	TRIPPED ON FAULT
1177	06-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV-66KV BEVINAHALLY	KRHALLY, DASUDI, JGHALLY, BEVINAHALLY	21:10	21:20	0:10	TRIPPED ON FAULT
1178	06-Dec-24	TUMKUR	66	LINE	HIRIYUR220kv-P.R. PURA_66	P.R. PURA_66	11:40	12:40	1:00	LINE CLEAR AVAILED
1179	06-Dec-24	TUMKUR	66	LINE	KUKKAWADA_66-BASAVAPATNA	66KV THAVANAGI	13:15	14:15	1:00	TRIPPED ON FAULT
1180	06-Dec-24	TUMKUR	66	LINE	KUKKAWADA_66-DAVANGERE_220 LINE 1	KUKKUWADA, SHYGALE, DSCL, KEREILICHI, WATER WORKS, THAVANAGI	13:15	13:25	0:10	TRIPPED ON FAULT
1181	06-Dec-24	TUMKUR	66	LINE	MATHOD_66-GARAGA PANCHANAHALLI LINE	GARAGA PANCHANAHALLI_66	15:20	15:45	0:25	LINE CLEAR AVAILED
1182	06-Dec-24	TUMKUR	66	LINE	SHAGALE_66-KEREILICHI_66	66KV SHYGALE, KEREILICHI & WATER WORKS	11:10	11:15	0:05	TRIPPED ON FAULT
1183	06-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA (HV SIDE) CHITRADURGA_220KV	CHITRADURGA_220KV	8:50	14:13	5:23	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1184	06-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA (HV SIDE)THALLAK_220	THALLAK_220	0:07	0:26	0:19	TRIPPED ON FAULT
1185	06-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA (HV SIDE)THALLAK_220	THALLAK_220	1:14	1:29	0:15	TRIPPED ON FAULT
1186	06-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
1187	06-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA KUKKAWADA_66	KUKKAWADA_66	9:33	9:45	0:12	TRIPPED ON FAULT
1188	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HALIYAL(ATHANI)_110	10:06	15:49	5:43	LINE CLEAR AVAILED
1189	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RAMANAKOPPA_110	10:20	17:35	7:15	LINE CLEAR AVAILED
1190	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TADASINAKOPPA_110	10:01	16:30	6:29	LINE CLEAR AVAILED
1191	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TADASINAKOPPA_110	10:01	16:30	6:29	LINE CLEAR AVAILED
1192	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	09:22	16:37	7:15	LINE CLEAR AVAILED
1193	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	DEVARAGENNUR_110	09:25	16:14	6:49	LINE CLEAR AVAILED
1194	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	HALIYAL(ATHANI)_110	10:06	15:50	5:44	LINE CLEAR AVAILED
1195	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	RAMANAKOPPA_110	10:15	18:00	7:45	LINE CLEAR AVAILED
1196	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MAMADAPUR_110	09:22	16:50	7:28	LINE CLEAR AVAILED
1197	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	TODALBAGI_110	10:25	18:29	8:04	LINE CLEAR AVAILED
1198	07-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	MAMADAPUR_110	09:27	21:31	12:04	LINE CLEAR AVAILED
1199	07-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	SIRSI_220	16:17	16:21	0:04	TRIPPED ON FAULT
1200	07-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA1	AMBEWADI_220	08:34	13:33	4:59	LINE CLEAR AVAILED
1201	07-Dec-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA2	AMBEWADI_220	16:26 (06.12.2024)	13:33 (07.12.2024)		TRIPPED ON FAULT
1202	07-Dec-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI2	ATHANI_220	14:46	14:48	0:02	TRIPPED ON FAULT
1203	07-Dec-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI2	ATHANI_220	14:53	15:14	0:21	TRIPPED ON FAULT
1204	07-Dec-24	BAGALKOTE	110	LINE	ATHANI220-BALIGERI	ATHANI_220	14:40	15:22	0:42	LINE CLEAR AVAILED
1205	07-Dec-24	BAGALKOTE	110	LINE	ATHANI220-HALYAL	ATHANI_220	10:04	15:48	5:44	LINE CLEAR AVAILED
1206	07-Dec-24	BAGALKOTE	220	LINE	DHONI400-LINGAPUR1(HALVARTHY1)	DHONI_400	10:40	18:11	07:31	LINE CLEAR AVAILED
1207	07-Dec-24	BAGALKOTE	220	LINE	DHONI400-LINGAPUR2(HALVARTHY2)	DHONI_400	10:23	18:12	07:49	LINE CLEAR AVAILED
1208	07-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
1209	07-Dec-24	BAGALKOTE	110	LINE	HALIYAL-ATHANI	HALIYAL(ATHANI)_110	10:09	15:47	5:38	LINE CLEAR AVAILED
1210	07-Dec-24	BAGALKOTE	110	LINE	HALIYAL-HALIYAL LIS	HALIYAL(ATHANI)_110	10:10	15:47	5:37	LINE CLEAR AVAILED
1211	07-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
1212	07-Dec-24	BAGALKOTE	110	LINE	HIREHAL-IDLE(BADAMI)	HIREHAL_110	11:40	18:30	6:50	LINE CLEAR AVAILED
1213	07-Dec-24	BAGALKOTE	110	LINE	HIREHAL-MFRSLR	HIREHAL_110	10:00	17:38	7:38	LINE CLEAR AVAILED
1214	07-Dec-24	BAGALKOTE	110	LINE	HIREHAL-RON	HIREHAL_110	10:15	17:32	7:17	LINE CLEAR AVAILED
1215	07-Dec-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI2	HUBLI_220	13:19	14:09	0:50	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1216	07-Dec-24	BAGALKOTE	110	LINE	HUBLI220- RAMANKOPPA	HUBLI_220	11:08	17:25	6:17	LINE CLEAR AVAILED
1217	07-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1218	07-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
1219	07-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3:12.2024)			LINE CLEAR AVAILED
1220	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR- B.BAGEWADI-1	MAMADAPUR_110	09:28	14:36	5:08	LINE CLEAR AVAILED
1221	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR- B.BAGEWADI-2	MAMADAPUR_110	09:30	15:46	6:16	LINE CLEAR AVAILED
1222	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR- BABALESHWARA	MAMADAPUR_110	09:26	14:46	5:20	LINE CLEAR AVAILED
1223	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-BLGM SLR (BELGAUM SOLAR)	MAMADAPUR_110	09:31	14:42	5:11	LINE CLEAR AVAILED
1224	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-SHIRBUR	MAMADAPUR_110	09:26	14:51	5:25	LINE CLEAR AVAILED
1225	07-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR- TODALABHAGI (SAVALAGI)	MAMADAPUR_110	09:26	15:06	5:40	LINE CLEAR AVAILED
1226	07-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1227	07-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
1228	07-Dec-24	BAGALKOTE	110	LINE	RAMANAKOPPA-HUBLI	RAMANAKOPPA_110	10:20	17:35	7:15	LINE CLEAR AVAILED
1229	07-Dec-24	BAGALKOTE	110	LINE	RAMANAKOPPA- SAVANUR(DUNDASI)	RAMANAKOPPA_110	10:20	17:35	7:15	LINE CLEAR AVAILED
1230	07-Dec-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	10:12	17:32	7:20	LINE CLEAR AVAILED
1231	07-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
1232	07-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
1233	07-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN220- MUNDAGOD	SHIGGOAN_220	10:39	18:09	7:30	LINE CLEAR AVAILED
1234	07-Dec-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHI1	SIRSI_220	16:16 (07.12.2024)			TRIPPED ON FAULT
1235	07-Dec-24	BAGALKOTE	110	LINE	SOUDATTI220- UDAKERI	SOUDATTI_220	22:35	23:20	0:45	TRIPPED ON FAULT
1236	07-Dec-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD(NARENDRA)	TADASINAKOPPA_110	10:01	16:30	6:29	LINE CLEAR AVAILED
1237	07-Dec-24	BAGALKOTE	110	LINE	TADASINAKOPPA- TARIHAL(KAIDB GAMANAGATTI	TADASINAKOPPA_110	09:53	16:38	6:45	LINE CLEAR AVAILED
1238	07-Dec-24	BAGALKOTE	110	LINE	TIKOTA- BHUTNAL(TAKKALAKI)	TIKOTA_110	13:33 (05.12.2024)	9:50 (07.12.2024)	44:17:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1239	07-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
1240	07-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1241	07-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	11:30	23:59	12:29	LINE CLEAR AVAILED
1242	07-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1243	07-Dec-24	BANGALORE	220	LINE	220KV MAGADI 220 - ANCHEPALYA CKT 2	ANCHEPALYA 220	11:30	12:45	01:15	LINE CLEAR AVAILED
1244	07-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
1245	07-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	CHEEMANGALA, TALAGAWARA	17:05	18:04	00:59	LINE CLEAR AVAILED
1246	07-Dec-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BIAL BEGUR 220	NO STATION AFFECTED	01:56	02:12	00:16	TRIPPED ON FAULT
1247	07-Dec-24	BANGALORE	66	LINE	66KV HSR 220 - JAKKASANDRA	NO STATION AFFECTED	10:05	12:28	02:23	TRIPPED ON FAULT
1248	07-Dec-24	BANGALORE	66	LINE	66KV ITI 220 - NGEF	NGEF	11:30	12:42	01:12	LINE CLEAR AVAILED
1249	07-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARANAHALLI	06:21	06:31	00:10	TRIPPED ON FAULT
1250	07-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - HONDA LTD (EHT)	HONDA LTD(EHT)	11:00	12:00	01:00	LINE CLEAR AVAILED
1251	07-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	NATIONAL COLLEGE	08:50	08:55	00:05	LINE CLEAR AVAILED
1252	07-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA, DEVANAHALLI 66	08:56	09:09	00:13	TRIPPED ON FAULT
1253	07-Dec-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 1	NO STATION AFFECTED BYADRAHALLI,	10:56	13:45	02:49	TRIPPED ON FAULT
1254	07-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	SRIGANDAKAVAL, KODIGEHALLI	09:42	10:38	00:56	TRIPPED ON FAULT
1255	07-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	11:01	12:32	01:31	LINE CLEAR AVAILED
1256	07-Dec-24	BANGALORE	66	LINE	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI	10:44	10:55	00:11	LINE CLEAR AVAILED
1257	07-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:00	16:25	00:25	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1258	07-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	YETHAMBADI, IGGALURU, K HONALGERE	16:00	16:25	00:25	MAIN SUPPLY FAILURE
1259	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHANDRAPPA CIRLCE	09:25	09:35	00:10	LINE CLEAR AVAILED
1260	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HEJJALA	06:15	06:25	00:10	TRIPPED ON FAULT
1261	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	09:14	09:19	00:05	LINE CLEAR AVAILED
1262	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAASTHI	17:10	18:09	00:59	LINE CLEAR AVAILED
1263	07-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SOMANAHALLI 220	10:08	13:05	02:57	LINE CLEAR AVAILED
1264	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	09:41	09:46	00:05	LINE CLEAR AVAILED
1265	07-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TK HALLI 220	16:00	16:26	00:26	MAIN SUPPLY FAILURE
1266	07-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BMTC	15:45	16:02	00:17	TRIPPED ON FAULT
1267	07-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	13:30	13:40	00:10	TRIPPED ON FAULT
1268	07-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAASTHI	17:10	18:09	00:59	LINE CLEAR AVAILED
1269	07-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NGEF	10:08	10:10	00:02	LINE CLEAR AVAILED
1270	07-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	09:41	09:46	00:05	LINE CLEAR AVAILED
1271	07-Dec-24	BANGALORE	220	TRANSFORMER	HV2	TK HALLI 220	16:00	16:23	00:23	TRIPPED ON FAULT
1272	07-Dec-24	BANGALORE	220	TRANSFORMER	HV3	TK HALLI 220	16:00	16:23	00:23	TRIPPED ON FAULT
1273	07-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - LIMBAVALI	TK HALLI 220	16:00	16:31	00:31	MAIN SUPPLY FAILURE
1274	07-Dec-24	BANGALORE	220	LINE	TK HALLI 220 - MANDYA 1	KK DODDI, KM DODDI, KIADB MANDYA, TALAGAVADI, TUMBGERE	16:00	16:23	00:23	MAIN SUPPLY FAILURE
1275	07-Dec-24	BANGALORE	220	LINE	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, KIADB MANDYA, TALAGAVADI, TUMBGERE	16:00	16:25	00:25	MAIN SUPPLY FAILURE
1276	07-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	16:00	23:59	07:59	MAIN SUPPLY FAILURE
1277	07-Dec-24	GULBARGA	66	LINE	HAGARIBOMMANAHALLI-ITTAGI	HAGARIBOMMMANAHALLI_66	09:27	13:10	03:43	LINE CLEAR AVAILED
1278	07-Dec-24	GULBARGA	220	LINE	HALWARTHY-DONI1	HALWARTHY_220	10:23	18:11	07:48	LINE CLEAR AVAILED
1279	07-Dec-24	GULBARGA	220	LINE	HALWARTHY-DONI2	HALWARTHY_220	10:38	18:12	07:34	LINE CLEAR AVAILED
1280	07-Dec-24	GULBARGA	66	LINE	HIREHADAHAGALI1-ITTAGI	HIREHADAGALI_66	06:39	06:43	00:04	TRIPPED ON FAULT
1281	07-Dec-24	GULBARGA	110	TRANSFORMER	HV1	DONIMALAI_110	09:35	15:25	05:50	LINE CLEAR AVAILED
1282	07-Dec-24	GULBARGA	110	TRANSFORMER	HV1	MARGUTTI_110	19:16	19:24	00:08	TRIPPED ON FAULT
1283	07-Dec-24	GULBARGA	220	TRANSFORMER	HV2	MALLAT_220	11:10	15:10	04:00	LINE CLEAR AVAILED
1284	07-Dec-24	GULBARGA	110	LINE	KIADB KUDITINI-MUNIRABAD	KUDITINI_110,KURUGOD_110,METRI_110,TORANGA LU_110	12:28	12:34	00:06	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1285	07-Dec-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	00:25	00:32	00:07	TRIPPED ON FAULT
1286	07-Dec-24	GULBARGA	110	LINE	MALLAT-BYAGAWAT	BYAGAWAT_110	10:57	15:25	04:28	LINE CLEAR AVAILED
1287	07-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANHATTI_66,HANSI_66(IDLE LINE)	06:44	06:51	00:07	TRIPPED ON FAULT
1288	07-Dec-24	GULBARGA	110	LINE	MUNIRABAD-HARE KRISHNA LINE	HAREKRISHNA_IPP, KIRLOSKER_FACTORY_IPP	11:36	11:50	00:14	TRIPPED ON FAULT
1289	07-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
1290	07-Dec-24	GULBARGA	110	LINE	SHAHAPUR-SHORAPUR	SHORAPUR_110	06:32	06:38	00:06	TRIPPED ON FAULT
1291	07-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	09:39	09:49	00:10	TRIPPED ON FAULT
1292	07-Dec-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR3	SINDHANOOR_110	10:10	15:35	05:25	LINE CLEAR AVAILED
1293	07-Dec-24	GULBARGA	110	LINE	YERADONA-MARALAHALLI	YERADONA_110,BENNUR_110	00:27	00:37	00:10	TRIPPED ON FAULT
1294	07-Dec-24	GULBARGA	110	LINE	YERADONA-MARALAHALLI	YERADONA_110,BENNUR_110	15:02	15:12	00:10	TRIPPED ON FAULT
1295	07-Dec-24	HASAN	110	LINE	AJAMPU-KADUR	AJAMPURA_110	10:30	17:45	07:15	MAIN SUPPLY FAILURE
1296	07-Dec-24	HASAN	110	LINE	AJAMPU-SHIVANI	AJAMPURA_110	10:30	17:45	07:15	MAIN SUPPLY FAILURE
1297	07-Dec-24	HASAN	110	TRANSFORMER	HV1	AJAMPURA_110	10:30	17:45	07:15	MAIN SUPPLY FAILURE
1298	07-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	12:13	16:15	04:02	LINE CLEAR AVAILED
1299	07-Dec-24	HASAN	110	TRANSFORMER	HV1	MADHUVANA_110	11:00	11:05	00:05	TRIPPED ON FAULT
1300	07-Dec-24	HASAN	220	TRANSFORMER	HV1	MSEZ_220	12:41	13:35	00:54	LINE CLEAR AVAILED
1301	07-Dec-24	HASAN	110	TRANSFORMER	HV1	PUTTUR_110	09:30	09:54	00:24	LINE CLEAR AVAILED
1302	07-Dec-24	HASAN	110	TRANSFORMER	HV2	AJAMPURA_110	10:30	17:45	07:15	MAIN SUPPLY FAILURE
1303	07-Dec-24	HASAN	220	TRANSFORMER	HV2	KADUR_220	12:20	16:31	04:11	LINE CLEAR AVAILED
1304	07-Dec-24	HASAN	110	TRANSFORMER	HV2	PUTTUR_110	09:30	09:54	00:24	LINE CLEAR AVAILED
1305	07-Dec-24	HASAN	110	TRANSFORMER	HV3	MADHUVANA_110	10:52	10:59	00:07	TRIPPED ON FAULT
1306	07-Dec-24	HASAN	110	LINE	KADUR-AJAMPURA	KADUR_220	10:20	17:33	07:13	LINE CLEAR AVAILED
1307	07-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	14:02	14:16	00:14	TRIPPED ON FAULT
1308	07-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	12:41	13:35	00:54	LINE CLEAR AVAILED
1309	07-Dec-24	HASAN	110	TRANSFORMER	LV2	KADUR_220	12:20	16:31	04:11	LINE CLEAR AVAILED
1310	07-Dec-24	HASAN	220	LINE	MRSSHM-DAVANGERE	MRSMG_220	10:08	14:34	04:26	LINE CLEAR AVAILED
1311	07-Dec-24	HASAN	110	TRANSFORMER	MRSSHM-MPM	MRSMG_220	11:11	11:43	00:32	LINE CLEAR AVAILED
1312	07-Dec-24	HASAN	220	LINE	SHRAVITY-SIRISI 1	gen_sharvathy	16:16(7.12.2024)			TRIPPED ON FAULT
1313	07-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:27	13:58	04:31	LINE CLEAR AVAILED
1314	07-Dec-24	MYSORE	66	LINE	AC GIRI-BGNAGARA VADERALLI	ADICHUNCHANAGIRI_66	14:40	17:10	02:30	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1315	07-Dec-24	MYSORE	66	LINE	BEGUR 220-SANTHE SARGUR	SANTHESARAGUR_66 ANTHARSANTHE_66 HDKOTE_66 YERALLI HAND POST_66	02:55	03:05	00:10	TRIPPED ON FAULT
1316	07-Dec-24	MYSORE	66	LINE	BEGUR 66-B MATTEKERE	B MATKERE_66	02:54	03:02	00:08	TRIPPED ON FAULT
1317	07-Dec-24	MYSORE	66	LINE	BG NAGARA-KADABALLI	BGNAGARA_66	13:19	16:22	03:02	LINE CLEAR AVAILED
1318	07-Dec-24	MYSORE	66	LINE	BG NAGARA-NAGMAGALA 220	BGNAGARA_66	12:13	16:21	04:07	LINE CLEAR AVAILED
1319	07-Dec-24	MYSORE	66	LINE	BG NAGARA-VADERALLI	BGNAGARA_66	14:36	16:32	01:55	LINE CLEAR AVAILED
1320	07-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
1321	07-Dec-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE 2	NO STATIONS EFFECTED	12:34	15:25	02:51	LINE CLEAR AVAILED
1322	07-Dec-24	MYSORE	66	LINE	GUNDLUPETE-CR NAGARA	TERAKANAMBE_66	12:34	15:25	02:51	LINE CLEAR AVAILED
1323	07-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
1324	07-Dec-24	MYSORE	66	LINE	HEBBANI 220-SHIMSHA	NO STATIONS EFFECTED	04:35	05:06	00:31	TRIPPED ON FAULT
1325	07-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
1326	07-Dec-24	MYSORE	66	LINE	HOOTAGALLI 220-HAMPAPURA(K)	HAMPAPURA(K)_66	06:45	07:10	00:25	TRIPPED ON FAULT
1327	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	ADICHUNCHANAGIRI_66	10:20	17:10	06:50	LINE CLEAR AVAILED
1328	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	BGNAGARA_66	10:13	16:45	06:31	LINE CLEAR AVAILED
1329	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	11:55	12:10	00:15	LINE CLEAR AVAILED
1330	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	HADLI_66	16:00	16:30	00:30	MAIN SUPPLY FAILURE
1331	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	10:14	11:35	01:21	LINE CLEAR AVAILED
1332	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	09:50	14:15	04:25	LINE CLEAR AVAILED
1333	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	KMDODDI_66	16:00	16:30	00:30	MAIN SUPPLY FAILURE
1334	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	09:33	16:17	06:43	LINE CLEAR AVAILED
1335	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1336	07-Dec-24	MYSORE	66	TRANSFORMER	HV1	VADERALLI_66	10:00	16:50	06:50	LINE CLEAR AVAILED
1337	07-Dec-24	MYSORE	66	TRANSFORMER	HV2	ADICHUNCHANAGIRI_66	10:20	17:10	06:50	LINE CLEAR AVAILED
1338	07-Dec-24	MYSORE	66	TRANSFORMER	HV2	BGNAGARA_66	10:14	16:42	06:27	LINE CLEAR AVAILED
1339	07-Dec-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	14:05	17:33	03:27	LINE CLEAR AVAILED
1340	07-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	09:33	16:17	06:43	LINE CLEAR AVAILED
1341	07-Dec-24	MYSORE	66	TRANSFORMER	HV2	VADERALLI_66	10:00	16:50	06:50	LINE CLEAR AVAILED
1342	07-Dec-24	MYSORE	66	LINE	JYOTHI NAGARA-FTS	NO STATIONS EFFECTED	15:11	18:59	03:47	LINE CLEAR AVAILED
1343	07-Dec-24	MYSORE	66	LINE	KADABALLI-BG NAGARA	KADABALLY_66	10:00	16:35	06:35	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1344	07-Dec-24	MYSORE	66	LINE	KADAKOLA 220-DK MAIDANA	NO STATIONS EFFECTED	14:43	17:17	02:33	TRIPPED ON FAULT
1345	07-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1346	07-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1347	07-Dec-24	MYSORE	66	LINE	KK DODDI-KIADB MANDYA	KOLKARANADODDI_66	12:45	16:15	03:30	LINE CLEAR AVAILED
1348	07-Dec-24	MYSORE	66	LINE	KK DODDI-TKHALLI	KOLKARANADODDI_66	12:49	16:16	03:26	LINE CLEAR AVAILED
1349	07-Dec-24	MYSORE	66	LINE	KR PETE 220-KRPET 1	NO STATIONS EFFECTED	06:19	18:37	12:18	LINE CLEAR AVAILED
1350	07-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
1351	07-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
1352	07-Dec-24	MYSORE	66	LINE	KUSHALNAGARA 220-SOMWARPETE	SOMWARPETE _33	12:26	12:32	00:06	TRIPPED ON FAULT
1353	07-Dec-24	MYSORE	66	LINE	KUSHALNAGARA 220-SOMWARPETE	SOMWARPETE _33	17:03	17:11	00:07	TRIPPED ON FAULT
1354	07-Dec-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	09:00	09:05	00:05	TRIPPED ON FAULT
1355	07-Dec-24	MYSORE	66	LINE	MAMBALLI-YELANDUR	NO STATIONS EFFECTED	08:59	09:04	00:05	TRIPPED ON FAULT
1356	07-Dec-24	MYSORE	66	LINE	SANTHE SARGUR-CHANDRAVADI	CHANDRAVADI_66 HURA_66	02:55	03:05	00:10	TRIPPED ON FAULT
1357	07-Dec-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	20:18:00 (6/12/2024)	6:20 (7/12/2024)	10:01 HRs	TRIPPED ON FAULT
1358	07-Dec-24	MYSORE	66	LINE	SFCSIVA-5 MW SOLAR	NO STATIONS EFFECTED	20:18:00 (6/12/2024)	6:00 (7/12/2024)	9:41 HRs	TRIPPED ON FAULT
1359	07-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1360	07-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1361	07-Dec-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	04:36	04:38	00:02	TRIPPED ON FAULT
1362	07-Dec-24	MYSORE	66	LINE	TNPURA-MUGUR	TNARASIPURA_66	10:06	18:30	08:24	LINE CLEAR AVAILED
1363	07-Dec-24	MYSORE	66	LINE	VADERALLI-BG NAGARA	VADERALLI_66	15:05	16:45	01:40	LINE CLEAR AVAILED
1364	07-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA TR1 HOSADURGA_220	HOSADURGA_220	12:00	23:59	11:59	LINE CLEAR AVAILED
1365	07-Dec-24	TUMKUR	220	LINE	220KV GUTTUR 3 LINE-DAVANGERE SRS 220	220KV DAVANGERE	11:44	17:43	5:59	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1366	07-Dec-24	TUMKUR	110	LINE	220KV NITTUR-110 KV KALLUR	110 KV KALLUR	12:41	17:28	4:47	LINE CLEAR AVAILED
1367	07-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	NIL (IDLE LINE)	23:58:00	0:05	0:07	TRIPPED ON FAULT
1368	07-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV GOWRASAMUDRA	66KV GOWRASAMUDRA	17:40	18:21	0:41	LINE CLEAR AVAILED
1369	07-Dec-24	TUMKUR	220	LINE	ANCHEPALYA-220kV MAGADI	ANCHEPALYA_220	11:30	12:45	1:15	LINE CLEAR AVAILED
1370	07-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR NEW	0:03	0:13	0:10	TRIPPED ON FAULT
1371	07-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR NEW	1:38	1:48	0:10	TRIPPED ON FAULT
1372	07-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 & 2 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA	9:07	12:33	3:26	LINE CLEAR AVAILED
1373	07-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA	12:00	12:10	0:10	TRIPPED ON FAULT
1374	07-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1375	07-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1376	07-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV-66KV BEVINAHALLY	66KV KRHALLY, DASUDI, JGHALLY, BEVINAHALLY	8:06	8:14	0:08	TRIPPED ON FAULT
1377	07-Dec-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:30	18:15	7:45	LINE CLEAR AVAILED
1378	07-Dec-24	TUMKUR	66	LINE	HOSADURGA(MADHURE) 220KV-NEERGUNDA_66KV	66KV HOSADURGA , NEERGUNDA	14:30	14:45	0:15	TRIPPED ON FAULT
1379	07-Dec-24	TUMKUR	400	LINE	JAGALUR 400KV-BPS2 (BALLARI400KV)	JAGALUR 400KV	7:01	18:47	11:46	LINE CLEAR AVAILED
1380	07-Dec-24	TUMKUR	66	LINE	PANDARAHALLI-CHITRADURGA LINE 3	HOLALKERE_66, PONDARAHALLUI_66,	10:40	18:20	7:40	LINE CLEAR AVAILED
1381	07-Dec-24	TUMKUR	66	TRANSFORMER	TR1 20MVA	SIRA_66	12:40	13:55	1:15	LINE CLEAR AVAILED
1382	07-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
1383	07-Dec-24	TUMKUR	66	TRANSFORMER	TR2 20MVA	HIREHALLI_66	4:44 (06.12.2024)	10:03 (07.12.2024)	17:19	TRIPPED ON FAULT
1384	07-Dec-24	TUMKUR	66	TRANSFORMER	TR2 20MVA	SIRA_66	12:00	12:35	0:35	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1385	07-Dec-24	TUMKUR	66	LINE	URDIGERE-KOLALA	URDIGERE_66	8:15	8:30	0:15	TRIPPED ON FAULT
1386	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KANABARAGI LAYOUT_110	09:49	10:49	1:00	LINE CLEAR AVAILED
1387	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MV-HV2)	MACHE_110	16:33	16:44	0:11	LINE CLEAR AVAILED
1388	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KALAGHATAGI_110	07:45	07:56	0:11	TRIPPED ON FAULT
1389	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MRUTHYUNJAY NAGAR_110	08:26	08:46	0:20	LINE CLEAR AVAILED
1390	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SOUDATTI_110	01:04	03:10	2:06	TRIPPED ON FAULT
1391	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	THORVI_110	15:14	15:19	0:05	TRIPPED ON FAULT
1392	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	MK HUBLI_110	17:38	23:32	5:54	TRIPPED ON FAULT
1393	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	ATHANI_110	22:38 (08.12.2024)			TRIPPED ON FAULT
1394	08-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	MAMADAPUR_110	02:16	03:18	1:02	TRIPPED ON FAULT
1395	08-Dec-24	BAGALKOTE	110	LINE	ATHANI220- ATHANI	ATHANI_220	22:08	22:38	00:30	TRIPPED ON FAULT
1396	08-Dec-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	22:08	22:30	00:22	TRIPPED ON FAULT
1397	08-Dec-24	BAGALKOTE	220	LINE	DHONI400- LINGAPUR1(HALVARTHY1)	DHONI_400	11:05	19:11	08:06	LINE CLEAR AVAILED
1398	08-Dec-24	BAGALKOTE	220	LINE	DHONI400- LINGAPUR2(HALVARTHY2)	DHONI_400	11:05	19:11	08:06	LINE CLEAR AVAILED
1399	08-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
1400	08-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
1401	08-Dec-24	BAGALKOTE	110	LINE	HUBLI220- TARIHAL	HUBLI_220	06:24	11:15	04:51	LINE CLEAR AVAILED
1402	08-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1403	08-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
1404	08-Dec-24	BAGALKOTE	110	LINE	KUDACHI220-UGARKHUD	KUDACHI_220	03:45	09:40	05:55	TRIPPED ON FAULT
1405	08-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)			LINE CLEAR AVAILED
1406	08-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1407	08-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	10:20	10:31	00:11	TRIPPED ON FAULT
1408	08-Dec-24	BAGALKOTE	110	LINE	NARAGUND-BPCL	NARAGUND_110	02:52	03:25	0:33	TRIPPED ON FAULT
1409	08-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1410	08-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
1411	08-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
1412	08-Dec-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHI1	SIRSI_220	16:16 (07.12.2024)	11:53 (08.12.2024)	19:37:00	TRIPPED ON FAULT
1413	08-Dec-24	BAGALKOTE	110	LINE	TARIHAL- BHUTNAL(TAKKALAKI)	TIKOTA_110	14:15 (08.12.2024)			LINE CLEAR AVAILED
1414	08-Dec-24	BAGALKOTE	110	LINE	TARIHAL-HUBLI1	TARIHAL_110	06:22	11:16	4:54	LINE CLEAR AVAILED
1415	08-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
1416	08-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220- TUBINAKERE 220	NO STATION AFFECTED	17:36	18:35	00:59	TRIPPED ON FAULT
1417	08-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1418	08-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 1	NO STATION AFFECTED	23:30	23:59	00:29	TRIPPED ON FAULT
1419	08-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1420	08-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
1421	08-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	08:39	23:59	15:20	TRIPPED ON FAULT
1422	08-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	13:02	13:15	00:13	TRIPPED ON FAULT
1423	08-Dec-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	NO STATION AFFECTED	18:28	20:10	01:42	TRIPPED ON FAULT
1424	08-Dec-24	BANGALORE	66	LINE	66KV BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	13:37	13:41	00:04	LINE CLEAR AVAILED
1425	08-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI	16:42	16:52	00:10	TRIPPED ON FAULT
1426	08-Dec-24	BANGALORE	66	LINE	66KV KGF - BEML (EHT)	BEML(EHT)	15:53	18:23	02:30	LINE CLEAR AVAILED
1427	08-Dec-24	BANGALORE	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	11:05	11:09	00:04	LINE CLEAR AVAILED
1428	08-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR I/A	02:30	03:06	00:36	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1429	08-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	NO STATION AFFECTED	02:30	23:59	21:29	TRIPPED ON FAULT
1430	08-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	15:26	15:30	00:04	LINE CLEAR AVAILED
1431	08-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELCAST	15:28	15:30	00:02	LINE CLEAR AVAILED
1432	08-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR	PADMANABHANAGARA	10:08	10:24	00:16	TRIPPED ON FAULT
1433	08-Dec-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	ABBIGERE	15:12	15:16	00:04	LINE CLEAR AVAILED
1434	08-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	15:20	15:30	00:10	TRIPPED ON FAULT
1435	08-Dec-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	14:30	14:40	00:10	LINE CLEAR AVAILED
1436	08-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RAMADEVARAGUDI	12:25	14:05	01:40	TRIPPED ON FAULT
1437	08-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SOMANAHALLI 220	10:08	13:05	02:57	LINE CLEAR AVAILED
1438	08-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	14:17	14:22	00:05	LINE CLEAR AVAILED
1439	08-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	14:17	14:22	00:05	LINE CLEAR AVAILED
1440	08-Dec-24	BANGALORE	66	TRANSFORMER	HV3	NELAMANGALA 66	04:22	06:44	02:22	TRIPPED ON FAULT
1441	08-Dec-24	BANGALORE	66	TRANSFORMER	HV3	NELAMANGALA 66	08:58	09:22	00:24	LINE CLEAR AVAILED
1442	08-Dec-24	BANGALORE	400	LINE	ICT 1	DEVANAHALLI HARDWARE PARK 400	11:17	18:52	07:35	LINE CLEAR AVAILED
1443	08-Dec-24	GULBARGA	110	LINE	DONGARGAON-KAMALNAGAR-AURAD	DONGARGAON_110	21:20	22:30	01:10	TRIPPED ON FAULT
1444	08-Dec-24	GULBARGA	66	LINE	GUDEKOTE-KUDLIGI	GUDEKOTE_66, CJHALLI_66, HOSAHALLI_66, HUDEM_66	21:45	22:00	00:15	TRIPPED ON FAULT
1445	08-Dec-24	GULBARGA	66	LINE	HARAPANAHALLI-ITTAGGI	HARAPANAHALLI_66	10:40	16:25	05:45	LINE CLEAR AVAILED
1446	08-Dec-24	GULBARGA	66	LINE	HARAPANAHALLI-ITTAGI	HARAPANAHALLI_66	10:30	16:25	05:55	LINE CLEAR AVAILED
1447	08-Dec-24	GULBARGA	110	TRANSFORMER	HV1	HANUMSAGAR_110	09:20	09:50	00:30	LINE CLEAR AVAILED
1448	08-Dec-24	GULBARGA	66	TRANSFORMER	HV1	PUNABGHATTA_66	22:40	22:45	00:05	TRIPPED ON FAULT
1449	08-Dec-24	GULBARGA	110	TRANSFORMER	HV2	HANUMNAL_110	12:40	13:30	00:50	LINE CLEAR AVAILED
1450	08-Dec-24	GULBARGA	110	TRANSFORMER	HV3	MOKA_110	23:30	23:40	00:10	TRIPPED ON FAULT
1451	08-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66	23:18	23:51	00:33	TRIPPED ON FAULT
1452	08-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
1453	08-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-TELADI	TELADI_66KURUBARAHALLI_66,SHAMANUR SUGAR_IPP	14:03	14:13	00:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1454	08-Dec-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR1	SINDHANOOR_110,SIRWAR_110	11:44	11:50	00:06	TRIPPED ON FAULT
1455	08-Dec-24	HASAN	400	LINE	HASSAN4-UPCL2	HASSAN_400	09:38	15:59	06:21	LINE CLEAR AVAILED
1456	08-Dec-24	HASAN	400	LINE	HBNHL-HASSAN4	HEBBANAHALLI_400	09:38	15:59	06:21	LINE CLEAR AVAILED
1457	08-Dec-24	HASAN	66	LINE	HIREMAN-RDL	HIREMANGALUR_66	23:58:00	15:39	15:41	TRIPPED ON FAULT
1458	08-Dec-24	HASAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	23:58:00	00:46	00:48	MAIN SUPPLY FAILURE
1459	08-Dec-24	HASAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	10:10	10:15	00:05	LINE CLEAR AVAILED
1460	08-Dec-24	HASAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	11:20	11:30	00:10	LINE CLEAR AVAILED
1461	08-Dec-24	HASAN	66	TRANSFORMER	HV1	MALLAPURA_66	15:20	15:30	00:10	MAIN SUPPLY FAILURE
1462	08-Dec-24	HASAN	110	TRANSFORMER	HV3	BAIKAMPADI_110	10:11	13:49	03:38	LINE CLEAR AVAILED
1463	08-Dec-24	HASAN	110	LINE	JOG-JST1	gen_mghe	12:40	13:41	01:01	TRIPPED ON FAULT
1464	08-Dec-24	HASAN	110	LINE	JOG-JST2	gen_mghe	12:40	13:41	01:01	TRIPPED ON FAULT
1465	08-Dec-24	HASAN	110	LINE	SAGARA-JST1	SAGARA_110	12:40	13:41	01:01	TRIPPED ON FAULT
1466	08-Dec-24	HASAN	220	LINE	SHRAVTY-SIRISI 1	gen_sharavathy	16:16(7.12.2024)	12:54(8.12.2024)	20:37 hrs	LINE CLEAR AVAILED
1467	08-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
1468	08-Dec-24	MYSORE	66	LINE	CR NAGARA-BADANKUPPE 1	BADANAGUPPE_66	10:04	16:46	06:42	LINE CLEAR AVAILED
1469	08-Dec-24	MYSORE	66	LINE	CR NAGARA-BADANKUPPE 2	NO STATIONS EFFECTED	10:04	16:47	06:43	LINE CLEAR AVAILED
1470	08-Dec-24	MYSORE	66	LINE	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	09:53	18:14	08:20	LINE CLEAR AVAILED
1471	08-Dec-24	MYSORE	66	LINE	CR NAGARA-PANYADAHUNDI	HEMMARGALA_66 KARYA_66 PANDYADAHUNDI_66	11:01	14:21	03:19	LINE CLEAR AVAILED
1472	08-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
1473	08-Dec-24	MYSORE	66	LINE	HEBBANI-BG PURA-CHIDRAVALLI	VYSARAJAPURA_66 CHIDRAVALLI_66THUMBLA_66	16:54	17:06	00:12	TRIPPED ON FAULT
1474	08-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 1	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1475	08-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 2	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1476	08-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
1477	08-Dec-24	MYSORE	66	LINE	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	08:15	13:23	05:08	LINE CLEAR AVAILED
1478	08-Dec-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	13:05 (8/12/2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1479	08-Dec-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	BOGADHI_66KALAMANDIR A_66	11:26	11:44	00:18	TRIPPED ON FAULT
1480	08-Dec-24	MYSORE	66	TRANSFORMER	HV1	KADAKOLA_220	10:13	16:12	05:58	LINE CLEAR AVAILED
1481	08-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1482	08-Dec-24	MYSORE	66	TRANSFORMER	HV2	CHANDAKAVADI_66	18:31	18:53	00:21	LINE CLEAR AVAILED
1483	08-Dec-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	02:57	03:01	00:03	TRIPPED ON FAULT
1484	08-Dec-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_220	10:13	17:16	07:02	LINE CLEAR AVAILED
1485	08-Dec-24	MYSORE	220	LINE	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	12:30	17:51	05:21	LINE CLEAR AVAILED
1486	08-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1487	08-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1488	08-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	10:13	18:48	08:34	LINE CLEAR AVAILED
1489	08-Dec-24	MYSORE	66	LINE	KR PETE 220-KRISHNAPURA	NO STATIONS EFFECTED	10:15 (8/12/2024)			LINE CLEAR AVAILED
1490	08-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
1491	08-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
1492	08-Dec-24	MYSORE	66	LINE	MAMBALLI-YELANDUR	YELANDUR_66	17:57	18:02	00:05	TRIPPED ON FAULT
1493	08-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1494	08-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1495	08-Dec-24	MYSORE	66	LINE	SOMWARPETE-HONNAHALLI	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI_66	06:03	06:12	00:09	TRIPPED ON FAULT
1496	08-Dec-24	MYSORE	66	LINE	TALAKADU-ADANI	NO STATIONS EFFECTED	23:16	23:23	00:06	TRIPPED ON FAULT
1497	08-Dec-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	17:35	18:34	00:59	LINE CLEAR AVAILED
1498	08-Dec-24	MYSORE	220	LINE	TUBINKERE-KOTTIPURA	NO STATIONS EFFECTED	8:38 (8/12/2024)			TRIPPED ON FAULT
1499	08-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV NALLUR	66KV NALLUR,LINGADAHALLI	6:03	6:16	0:13	TRIPPED ON FAULT
1500	08-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KVNYAMATHI,SAVALAN GA,CHILUR	15:17	15:30	0:13	TRIPPED ON FAULT
1501	08-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1 (HNAGAL)	66KV HANAGAL, NAGASAMUDRA AND RAMPURA	18:30	18:45	0:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1502	08-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-2	66KV HANAGAL, NAGASAMUDRA AND RAMPURA	18:31	19:00	0:29	TRIPPED ON FAULT
1503	08-Dec-24	TUMKUR	220	LINE	DAVANGERE SRS 220-220KV HONNALI 1 LINE	HONNALLI_220	12:33	13:19	0:46	TRIPPED ON FAULT
1504	08-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	11:10	11:40	0:30	TRIPPED ON FAULT
1505	08-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1506	08-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1507	08-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV-66KV BEVINAHALLY	KRHALLY, DASUDI, JGHALLY, BEVINAHALLY	8:06	8:14	0:08	TRIPPED ON FAULT
1508	08-Dec-24	TUMKUR	66	LINE	KUKKAWADA_66-BASAVAPATNA_66	66KV THYAVANAGI SS	14:28	14:38	0:10	TRIPPED ON FAULT
1509	08-Dec-24	TUMKUR	220	LINE	MADHUGIRI_220-VASANTANARASAPURA_220-1	VASANTANARASAPURA_220	23:30	23:52	0:22	TRIPPED ON FAULT
1510	08-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	23:25	23:35	0:10	TRIPPED ON FAULT
1511	08-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
1512	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NAVANAGAR(H)_110	11:08	13:03	1:55	LINE CLEAR AVAILED
1513	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TALIKOT_110	10:12	18:11	7:59	LINE CLEAR AVAILED
1514	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA-HV2)	UGARKHUD_110	13:29	13:59	0:30	TRIPPED ON FAULT
1515	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULAGERI CROSS_110	16:39	17:05	0:26	LINE CLEAR AVAILED
1516	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	09:55	10:00	0:05	TRIPPED ON FAULT
1517	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	MUDDEBIHAL_110	14:07	14:16	0:09	TRIPPED ON FAULT
1518	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	ATHANI_110	12:18	13:58	1:40	LINE CLEAR AVAILED
1519	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TALIKOT_110	10:12	18:11	7:59	LINE CLEAR AVAILED
1520	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	PG HUNSHYAL_110	11:49	11:59	0:10	TRIPPED ON FAULT
1521	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4	ANKALI_110	09:25	09:35	0:10	TRIPPED ON FAULT
1522	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA)	HUBLI_220	22:50	23:01	0:11	TRIPPED ON FAULT
1523	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	MK HUBLI_110	15:01	15:35	0:34	LINE CLEAR AVAILED
1524	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	ATHANI_110	22:38 (08.12.2024)	0:08 (09.12.2024)	1:30	TRIPPED ON FAULT
1525	09-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA-HV2)	ZALKI_110	11:58	12:30	0:32	TRIPPED ON FAULT
1526	09-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	GADAG_220	10:46	14:48	4:02	LINE CLEAR AVAILED
1527	09-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	GADAG_220	10:46	14:49	4:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1528	09-Dec-24	BAGALKOTE	110	LINE	BABALEHSHWARA-TIKOTA (MAMADAPUR)	BABALEHSHWARA_110	11:50	14:56	3:06	LINE CLEAR AVAILED
1529	09-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- GMNAVAR1	BIJAPUR_220	09:49	11:03	1:14	LINE CLEAR AVAILED
1530	09-Dec-24	BAGALKOTE	220	LINE	DHONI400- LINGAPUR1(HALVARTHY1)	DHONI_400	9:30	18:48	9:18	LINE CLEAR AVAILED
1531	09-Dec-24	BAGALKOTE	220	LINE	DHONI400- LINGAPUR2(HALVARTHY2)	DHONI_400	09:30	18:49	9:19	LINE CLEAR AVAILED
1532	09-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
1533	09-Dec-24	BAGALKOTE	110	LINE	HAVERI220- HANGAL(KULENUR)	HAVERI_220	10:31	15:46	5:15	LINE CLEAR AVAILED
1534	09-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
1535	09-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1536	09-Dec-24	BAGALKOTE	110	LINE	INDI220- DVHG(ATHARGA)	INDI_220	01:27	01:42	0:15	TRIPPED ON FAULT
1537	09-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
1538	09-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)			LINE CLEAR AVAILED
1539	09-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR- GSML1	MAHALINGAPUR_220	10:38	11:04	0:26	TRIPPED ON FAULT
1540	09-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR- GSML2	MAHALINGAPUR_220	10:38	11:04	0:26	TRIPPED ON FAULT
1541	09-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-BLGM_SLR	MAMADAPUR_110	09:57	10:08	0:11	TRIPPED ON FAULT
1542	09-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-BLGM_SLR	MAMADAPUR_110	11:58	19:26	7:28	LINE CLEAR AVAILED
1543	09-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1544	09-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
1545	09-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220- AREMALLAPUR (HONNATTI)	RANEENNUR_220	5:33	5:42	0:09	TRIPPED ON FAULT
1546	09-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
1547	09-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
1548	09-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG2	SIRSI_110	13:15	15:28	2:13	LINE CLEAR AVAILED
1549	09-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG2	SIRSI_110	15:30 (09.12.2024)			LINE CLEAR AVAILED
1550	09-Dec-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	10:50	18:20	7:30	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1551	09-Dec-24	BAGALKOTE	110	LINE	TARIHAL-BHUTNAL(TAKKALAKI)	TIKOTA_110	14:15 (08.12.2024)	11:11 (09.12.2024)	20:56	LINE CLEAR AVAILED
1552	09-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
1553	09-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	14:00	20:13	06:13	LINE CLEAR AVAILED
1554	09-Dec-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	18:07	23:59	05:52	TRIPPED ON FAULT
1555	09-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1556	09-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1557	09-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 1	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1558	09-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 2	NO STATION AFFECTED	00:40	01:22	00:42	LINE CLEAR AVAILED
1559	09-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1560	09-Dec-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 - CKT 1	VIKAS TECH PARK 220	10:25	15:30	05:05	LINE CLEAR AVAILED
1561	09-Dec-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 - CKT 1	VIKAS TECH PARK 220	20:45	21:15	00:30	LINE CLEAR AVAILED
1562	09-Dec-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 -2	SARJAPURA 220	10:47	11:08	00:21	TRIPPED ON FAULT
1563	09-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
1564	09-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	23:58:00	10:30	10:32	TRIPPED ON FAULT
1565	09-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	10:30	19:05	08:35	LINE CLEAR AVAILED
1566	09-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	19:05	19:21	00:16	LINE CLEAR AVAILED
1567	09-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	19:21	23:59	04:38	TRIPPED ON FAULT
1568	09-Dec-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGAR	VIDYANAGARA	17:22	17:27	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1569	09-Dec-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	NO STATION AFFECTED	06:30	23:59	17:29	TRIPPED ON FAULT
1570	09-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:01	10:06	00:05	LINE CLEAR AVAILED
1571	09-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADUBISANAHALLI (TAP)	KADUBISANAHALLI	14:59	15:23	00:24	TRIPPED ON FAULT
1572	09-Dec-24	BANGALORE	66	LINE	66KV ITI 220 - BAGAMANE WTC 2	NO STATION AFFECTED	19:18	20:59	01:41	TRIPPED ON FAULT
1573	09-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220_DG4	GRIND WELL NORTON(EHT)	09:02	09:24	00:22	TRIPPED ON FAULT
1574	09-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220_DG4	NO STATION AFFECTED	13:17	18:09	04:52	LINE CLEAR AVAILED
1575	09-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	19:02	19:07	00:05	LINE CLEAR AVAILED
1576	09-Dec-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - RAYALPADU	RAYALPADU, ADDAGAL	18:10	18:22	00:12	TRIPPED ON FAULT
1577	09-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1578	09-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	06:10	06:23	00:13	TRIPPED ON FAULT
1579	09-Dec-24	BANGALORE	66	LINE	66KV RBI - ELITA PROMENADE	RBI	17:21	17:25	00:04	LINE CLEAR AVAILED
1580	09-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	10:48	11:13	00:25	MAIN SUPPLY FAILURE
1581	09-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	10:48	11:22	00:34	MAIN SUPPLY FAILURE
1582	09-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA, WIPRO(EHT)	10:48	11:12	00:24	MAIN SUPPLY FAILURE
1583	09-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	NO STATION AFFECTED	12:39	15:05	02:26	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1584	09-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI, SOUTH CITY	09:35	10:09	00:34	TRIPPED ON FAULT
1585	09-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	22:14	23:59	01:45	LINE CLEAR AVAILED
1586	09-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II	BIEC, ALUR	21:16	23:59	02:43	TRIPPED ON FAULT
1587	09-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	THAYALUR, MN HALLI, NG HULKUR	18:11	18:31	00:20	TRIPPED ON FAULT
1588	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	CESSNA 66	16:25	16:30	00:05	LINE CLEAR AVAILED
1589	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	CESSNA 66	16:25	16:30	00:05	LINE CLEAR AVAILED
1590	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	10:20	10:30	00:10	LINE CLEAR AVAILED
1591	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	23:40	23:45	00:05	LINE CLEAR AVAILED
1592	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	15:27	15:36	00:09	LINE CLEAR AVAILED
1593	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	20:45	21:25	00:40	MAIN SUPPLY FAILURE
1594	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	10:20	10:30	00:10	LINE CLEAR AVAILED
1595	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	23:40	23:45	00:05	LINE CLEAR AVAILED
1596	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	15:27	15:36	00:09	LINE CLEAR AVAILED
1597	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	20:45	21:25	00:40	MAIN SUPPLY FAILURE
1598	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ ECO WORLD	10:20	10:30	00:10	LINE CLEAR AVAILED
1599	09-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ ECO WORLD	23:40	23:45	00:05	LINE CLEAR AVAILED
1600	09-Dec-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	10:05	12:00	01:55	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1601	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	13:12	13:15	00:03	LINE CLEAR AVAILED
1602	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	EMBASSY TECH PARK	12:57	13:02	00:05	LINE CLEAR AVAILED
1603	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	10:48	11:11	00:23	MAIN SUPPLY FAILURE
1604	09-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	10:46	11:10	00:24	MAIN SUPPLY FAILURE
1605	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOMENAHALLI	15:05	15:10	00:05	LINE CLEAR AVAILED
1606	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	13:00	14:20	01:20	LINE CLEAR AVAILED
1607	09-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	23:40	23:45	00:05	LINE CLEAR AVAILED
1608	09-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GOKULA	16:37	16:38	00:01	LINE CLEAR AVAILED
1609	09-Dec-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	18:25	18:30	00:05	TRIPPED ON FAULT
1610	09-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KUMBALAGODU 220	10:39	13:00	02:21	LINE CLEAR AVAILED
1611	09-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	10:48	11:08	00:20	MAIN SUPPLY FAILURE
1612	09-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SARJAPURA 220	10:46	11:10	00:24	MAIN SUPPLY FAILURE
1613	09-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR_66	08:40	08:55	00:15	TRIPPED ON FAULT
1614	09-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	10:05	18:08	08:03	LINE CLEAR AVAILED
1615	09-Dec-24	BANGALORE	220	TRANSFORMER	HV2	VIKAS TECH PARK 220	10:25	15:30	05:05	LINE CLEAR AVAILED
1616	09-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	16:55	17:18	00:23	TRIPPED ON FAULT
1617	09-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	03:35	03:45	00:10	TRIPPED ON FAULT
1618	09-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	03:45	04:50	01:05	LINE CLEAR AVAILED
1619	09-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	11:26	14:15	02:49	LINE CLEAR AVAILED
1620	09-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KUDLIGI_220	14:25	14:45	00:20	TRIPPED ON FAULT
1621	09-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KUDLIGI_220	17:40	18:00	00:20	TRIPPED ON FAULT
1622	09-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KUDLIGI_220	18:00	18:25	00:25	TRIPPED ON FAULT
1623	09-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KUDLIGI_220	18:30	18:45	00:15	TRIPPED ON FAULT
1624	09-Dec-24	GULBARGA	220	TRANSFORMER	HV1,HV2	KUDLIGI_220	14:05	14:10	00:05	TRIPPED ON FAULT
1625	09-Dec-24	GULBARGA	220	TRANSFORMER	HV2	KUDLIGI_220	14:25	14:30	00:05	TRIPPED ON FAULT
1626	09-Dec-24	GULBARGA	110	TRANSFORMER	HV3	SIRIGUPPA_110	11:04	12:55	01:51	LINE CLEAR AVAILED
1627	09-Dec-24	GULBARGA	110	TRANSFORMER	HV6	MUNIRABAD_220	09:33	22:05	12:32	LINE CLEAR AVAILED
1628	09-Dec-24	GULBARGA	110	LINE	KALBURGI UNIVERSITY-KALBURGI NORTH	KALBURGI UNIVERSITY_110	13:10	14:50	01:40	LINE CLEAR AVAILED
1629	09-Dec-24	GULBARGA	220	LINE	KAPNOOR-HUMNABAD2	HUMNABAD_220	14:40	17:14	02:34	LINE CLEAR AVAILED
1630	09-Dec-24	GULBARGA	66	LINE	KUDILIGI-SOKKE	SOKKE_66	20:40	21:00	00:20	TRIPPED ON FAULT
1631	09-Dec-24	GULBARGA	66	LINE	KUDILIGI-SOKKE	UJJANI_66,KOTTUR_66,SOKKE_66	20:10	20:15	00:05	LINE CLEAR AVAILED
1632	09-Dec-24	GULBARGA	66	LINE	KUDLIGI-ACME SOLAR	KUDLIGI_220	20:50(9.12.2024)			TRIPPED ON FAULT
1633	09-Dec-24	GULBARGA	110	LINE	KUSTAGI-SUZLON 2_IPP	KUSTAGI_220	17:17	20:50	03:33	LINE CLEAR AVAILED
1634	09-Dec-24	GULBARGA	110	LINE	LINGASUGUR-KPRL_IPP	LINGASUGUR_220	23:45	23:52	00:07	LINE CLEAR AVAILED
1635	09-Dec-24	GULBARGA	110	LINE	MALLAT-ALKOD	ALKOD_110,GALAG_110	10:30	17:04	06:34	LINE CLEAR AVAILED
1636	09-Dec-24	GULBARGA	110	LINE	MALLAT-ALKOD	ALKOD_110,GALAG_110	17:15	17:45	00:30	LINE CLEAR AVAILED
1637	09-Dec-24	GULBARGA	110	LINE	NALWAR-SHAHPUR	NALWAR_110	19:55	20:10	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1638	09-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
1639	09-Dec-24	GULBARGA	110	LINE	SANTHPUR-HALBARGA	SANTHAPUR_110	06:31	06:40	00:09	TRIPPED ON FAULT
1640	09-Dec-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI1	CHINCHOLI_110	14:00	17:37	03:37	LINE CLEAR AVAILED
1641	09-Dec-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	10:20	18:10	07:50	LINE CLEAR AVAILED
1642	09-Dec-24	GULBARGA	110	LINE	SHAHAPUR-NAGANOOR	KEMBHAVI_110, NAGANOOR_110, HUNASAGI_110, ASKI_110, TALIKOT_110, KBJNL LIS KEMBHAVI_110	10:20	17:37	07:17	LINE CLEAR AVAILED
1643	09-Dec-24	GULBARGA	220	LINE	SHAHAPUR-RTPS1	SHAHAPUR_220	04:57	05:25	00:28	TRIPPED ON FAULT
1644	09-Dec-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	08:44	13:43	04:59	TRIPPED ON FAULT
1645	09-Dec-24	GULBARGA	110	LINE	SINDHANOOR-WALABALLARI	WALABALLARI_110	09:44	15:10	05:26	LINE CLEAR AVAILED
1646	09-Dec-24	GULBARGA	66	LINE	TBHALLI-ITTAGGI	TAMBRAHALLI_66,MORAG ERE_66,HAMPASAGAR_66	19:40	19:55	00:15	TRIPPED ON FAULT
1647	09-Dec-24	HASAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:43	12:11	00:28	TRIPPED ON FAULT
1648	09-Dec-24	HASAN	66	LINE	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	11:43	12:11	00:28	TRIPPED ON FAULT
1649	09-Dec-24	HASAN	110	LINE	HALADY1-HIRIYADKA	HALADY_110	10:33	13:06	02:33	LINE CLEAR AVAILED
1650	09-Dec-24	HASAN	220	LINE	HGUNJE-VARAHI	HEGGUNJE_220	10:37	11:17	00:40	LINE CLEAR AVAILED
1651	09-Dec-24	HASAN	66	TRANSFORMER	HV1	ATTICHOWDENAHALLI_66	11:45	13:40	01:55	MAIN SUPPLY FAILURE
1652	09-Dec-24	HASAN	66	TRANSFORMER	HV1	ATTICHOWDENAHALLI_66	13:31	15:30	01:59	LINE CLEAR AVAILED
1653	09-Dec-24	HASAN	66	TRANSFORMER	HV1	MANJUNATHPURA_66	10:31	14:03	03:32	LINE CLEAR AVAILED
1654	09-Dec-24	HASAN	66	TRANSFORMER	HV2	MANJUNATHPURA_66	10:31	14:03	03:32	LINE CLEAR AVAILED
1655	09-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	18:07(9.12.2024)			TRIPPED ON FAULT
1656	09-Dec-24	HASAN	220	LINE	KAVOOR-KEMR1	KAVOOR_220	10:45	14:02	03:17	LINE CLEAR AVAILED
1657	09-Dec-24	HASAN	110	LINE	KAVOOR-Kulashkhara1	KAVOOR_220	10:20	16:16	05:56	LINE CLEAR AVAILED
1658	09-Dec-24	HASAN	110	LINE	KEMAR-BELMAN	KEMAR_220	10:46	12:34	01:48	LINE CLEAR AVAILED
1659	09-Dec-24	HASAN	66	LINE	LINE1	MANJUNATHPURA_66	10:31	14:03	03:32	LINE CLEAR AVAILED
1660	09-Dec-24	HASAN	66	LINE	LINE2	MANJUNATHPURA_66	10:31	14:03	03:32	LINE CLEAR AVAILED
1661	09-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	10:00	14:23	04:23	LINE CLEAR AVAILED
1662	09-Dec-24	HASAN	110	LINE	MRSSHM-MPM	MRSMG_220	09:03	13:35	04:32	LINE CLEAR AVAILED
1663	09-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMG_220	12:15	18:52	06:37	TRIPPED ON FAULT
1664	09-Dec-24	HASAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	10:45	14:02	03:17	LINE CLEAR AVAILED
1665	09-Dec-24	HASAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	10:00	14:43	04:43	MAIN SUPPLY FAILURE
1666	09-Dec-24	HASAN	220	LINE	SHRAVITY-SHIMOGA3	sharavathy_gen	12:15	18:52	06:37	TRIPPED ON FAULT
1667	09-Dec-24	HASAN	220	LINE	SHRAVITY-SHIMOGA4	sharavathy_gen	14:35	14:38	00:03	TRIPPED ON FAULT
1668	09-Dec-24	HASAN	220	LINE	SHRAVITY-TALAGUPPA1	sharavathy_gen	09:22	17:49	08:27	LINE CLEAR AVAILED
1669	09-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:22	17:49	08:27	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1670	09-Dec-24	HASAN	66	LINE	UDAYAP-BAGUR	UDAYAPURA_66	11:43	12:22	00:39	TRIPPED ON FAULT
1671	09-Dec-24	HASAN	220	LINE	VARAHI-KEMAR3	varahi_gen	10:37	11:17	00:40	LINE CLEAR AVAILED
1672	09-Dec-24	MYSORE	66	LINE	BELAGOLA-HOOTAGALLI	BELAGOLA_66	10:00	15:55	05:55	LINE CLEAR AVAILED
1673	09-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
1674	09-Dec-24	MYSORE	66	LINE	CHANDRAWADI-HURA	HURA_66	18:09	18:14	00:05	TRIPPED ON FAULT
1675	09-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
1676	09-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 1	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1677	09-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 2	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1678	09-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
1679	09-Dec-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	13:05 (8/12/2024)			LINE CLEAR AVAILED
1680	09-Dec-24	MYSORE	66	LINE	HONNALLI-SOMWARPETE	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI_66	13:20	14:20	01:00	LINE CLEAR AVAILED
1681	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	13:44 (9/12/2024)			LINE CLEAR AVAILED
1682	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	HULLAHALLI_66	13:01	13:47	00:46	LINE CLEAR AVAILED
1683	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	17:47	18:20	00:33	LINE CLEAR AVAILED
1684	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	09:38	15:53	06:15	LINE CLEAR AVAILED
1685	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	MADDUR_66	10:43	14:16	03:33	LINE CLEAR AVAILED
1686	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	RKNAGARA_66	12:28	13:28	01:00	LINE CLEAR AVAILED
1687	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	RKNAGARA_66	13:57	15:02	01:05	LINE CLEAR AVAILED
1688	09-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1689	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	HONNALLY_MYS_66	03:25	03:55	00:30	LINE CLEAR AVAILED
1690	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	HULLAHALLI_66	12:00	13:01	01:01	LINE CLEAR AVAILED
1691	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	KIKKERI_66	17:00	17:45	00:45	LINE CLEAR AVAILED
1692	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	16:15	16:25	00:10	LINE CLEAR AVAILED
1693	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	RKNAGARA_66	12:28	13:25	00:57	LINE CLEAR AVAILED
1694	09-Dec-24	MYSORE	66	TRANSFORMER	HV2	RKNAGARA_66	13:57	14:23	00:26	LINE CLEAR AVAILED
1695	09-Dec-24	MYSORE	66	TRANSFORMER	HV3	KIKKERI_66	14:54	16:51	01:56	LINE CLEAR AVAILED
1696	09-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1697	09-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1698	09-Dec-24	MYSORE	66	LINE	KIKKERI-KR PETE	NO STATIONS EFFECTED	17:05	17:50	00:45	LINE CLEAR AVAILED
1699	09-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	06:28	09:49	03:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1700	09-Dec-24	MYSORE	66	LINE	KR PETE 220-KRISHNAPURA	NO STATIONS EFFECTED	10:15 (8/12/2024)	9:51 (9/12/2024)	23:36 HRs	LINE CLEAR AVAILED
1701	09-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
1702	09-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
1703	09-Dec-24	MYSORE	66	LINE	MANDYA-MC2	NO STATIONS EFFECTED	02:49	03:00	00:10	TRIPPED ON FAULT
1704	09-Dec-24	MYSORE	66	LINE	PANYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	06:20	06:25	00:05	TRIPPED ON FAULT
1705	09-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1706	09-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1707	09-Dec-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	YESSLUR_66HETHUR_66	23:24	23:47	00:22	TRIPPED ON FAULT
1708	09-Dec-24	MYSORE	66	LINE	SOMWARPETE-HONNALLI	ATTIGULIPURA_66 HONNALLY_MYS_66 ARKALAWADI 66	01:52	02:02	00:10	TRIPPED ON FAULT
1709	09-Dec-24	MYSORE	66	LINE	TALAKADU-ADANI	NO STATIONS EFFECTED	07:31	07:36	00:05	TRIPPED ON FAULT
1710	09-Dec-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	19:00	20:14	01:14	LINE CLEAR AVAILED
1711	09-Dec-24	MYSORE	220	LINE	TUBINKERE-KOTTIPURA	NO STATIONS EFFECTED	8:38 (8/12/2024)			TRIPPED ON FAULT
1712	09-Dec-24	TUMKUR	66	TRANSFORMER	20 MVA TR-3 ANTHARASANAHALLI_220kV	ANTHARASANAHALLI_220kV	10:05	16:55	6:50	LINE CLEAR AVAILED
1713	09-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV DEVARAHALLI	66KV DEVARAHALLI,SANTHEBENNUR,KEREBILACHI	2:45	2:55	0:10	TRIPPED ON FAULT
1714	09-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV GOPPENAHALLI	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	11:10	11:45	0:35	TRIPPED ON FAULT
1715	09-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	14:00	14:50	0:50	TRIPPED ON FAULT
1716	09-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	17:40	18:00	0:20	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1717	09-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	18:05	18:25	0:20	TRIPPED ON FAULT
1718	09-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	18:25	19:15	0:50	TRIPPED ON FAULT
1719	09-Dec-24	TUMKUR	66	LINE	66kv H D PURA-66kv PANDARAHALLI	66kv H D PURA	11:01	12:34	1:33	LINE CLEAR AVAILED
1720	09-Dec-24	TUMKUR	66	LINE	66kv HOLALKERE-66kv PANDARAHALLI LINE 1 & 2	66kv HOLALKERE	11:10	12:05	0:55	LINE CLEAR AVAILED
1721	09-Dec-24	TUMKUR	66	LINE	66KV KEREKILACHI -66KV SANTHEBENNUR	66KV KEREKILACHI, JAKLI KNNL WW	14:55	15:05	0:10	MAIN SUPPLY FAILURE
1722	09-Dec-24	TUMKUR	66	LINE	66KV KEREKILACHI -66KV SHYGALE	66KV KEREKILACHI, JAKLI KNNL WW	13:20	13:30	0:10	MAIN SUPPLY FAILURE
1723	09-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	18:53	19:03	0:10	TRIPPED ON FAULT
1724	09-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	66KV JAGALUR, SOKKE	19:50	20:20	0:30	TRIPPED ON FAULT
1725	09-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	66KV JAGALUR, SOKKE	20:55	21:05	0:10	TRIPPED ON FAULT
1726	09-Dec-24	TUMKUR	66	LINE	66kv VIJAPURA-DAVANAGERE 66	BARAASAGARA_66, SIRIGERE 66	10:30	11:20	0:50	LINE CLEAR AVAILED
1727	09-Dec-24	TUMKUR	66	LINE	66kv VIJAPURA-DAVANAGERE 66	BARAASAGARA_66, SIRIGERE 66	17:10	17:40	0:30	LINE CLEAR AVAILED
1728	09-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA- 220kv CHITRADURGA	BHARAMASAGARA_66	10:30	17:40	7:10	LINE CLEAR AVAILED
1729	09-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220kv-PANDARAHALLI 2	HIREGUNTANUR_66, PANDARAHALLI 66	11:19	12:12	0:53	LINE CLEAR AVAILED
1730	09-Dec-24	TUMKUR	66	LINE	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66, HOLALKERE_66, H D PURA 66	11:00	12:35	1:35	LINE CLEAR AVAILED
1731	09-Dec-24	TUMKUR	220	LINE	DAVANGERE SRS 220-220KV HONNALI 1 LINE	HONNALLI_220	12:33	13:19	0:46	TRIPPED ON FAULT
1732	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV DAVANAGERE LINE	66KV DAVANAGERE	15:24	15:59	0:35	LINE CLEAR AVAILED
1733	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV DAVANAGERE LINE	66KV DAVANAGERE	18:09	18:15	0:06	LINE CLEAR AVAILED
1734	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR	15:24	15:54	0:30	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1735	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR	17:10	17:12	0:02	LINE CLEAR AVAILED
1736	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV YARAGUNTA LINE	66KV YARAGUNTA	15:24	15:53	0:29	LINE CLEAR AVAILED
1737	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	15:24	15:53	0:29	LINE CLEAR AVAILED
1738	09-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	17:07	17:09	0:02	LINE CLEAR AVAILED
1739	09-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1740	09-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
1741	09-Dec-24	TUMKUR	400	LINE	JAGALUR 400KV-BPS2 (BALLARI400KV)	JAGALUR 400KV	9:18	17:04	7:46	LINE CLEAR AVAILED
1742	09-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMGHATTA,	6:10	6:23	0:13	TRIPPED ON FAULT
1743	09-Dec-24	TUMKUR	220	LINE	NITTUR 220kV- ARASIKERE LINE	NITTUR_220	21:45 (9.12.2024)	2:23 (10.12.2024)	4:38	LINE CLEAR AVAILED
1744	09-Dec-24	TUMKUR	110	LINE	NITTUR 220kV-DODDAGUNI	DODDAGUNI_110	13:40	14:15	0:35	LINE CLEAR AVAILED
1745	09-Dec-24	TUMKUR	66	TRANSFORMER	SIRA66 - BUKKAPATNA66	SIRA_66	17:30	17:40	0:10	TRIPPED ON FAULT
1746	09-Dec-24	TUMKUR	110	TRANSFORMER	TR1 10MVA	DODDAGUNI_110	13:40	14:15	0:35	LINE CLEAR AVAILED
1747	09-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	7:25	7:40	0:15	TRIPPED ON FAULT
1748	09-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	10:05	10:15	0:10	TRIPPED ON FAULT
1749	09-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	11:00	11:10	0:10	TRIPPED ON FAULT
1750	09-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
1751	09-Dec-24	TUMKUR	220	TRANSFORMER	TR2 100MVA	DAVANAGERE_220	15:27	17:00	1:33	LINE CLEAR AVAILED
1752	09-Dec-24	TUMKUR	110	TRANSFORMER	TR2 12.5MVA	DODDAGUNI_110	13:00	13:15	0:15	LINE CLEAR AVAILED
1753	09-Dec-24	TUMKUR	110	TRANSFORMER	TR2 12.5MVA	DODDAGUNI_110	13:30	14:15	0:45	LINE CLEAR AVAILED
1754	09-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	SANIKERE_66	17:25	17:40	0:15	TRIPPED ON FAULT
1755	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ATHARGA_110	11:30	12:30	1:00	LINE CLEAR AVAILED
1756	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULAGERI CROSS_110	20:00	20:09	0:09	TRIPPED ON FAULT
1757	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BEDI_110	05:44	12:01	6:17	LINE CLEAR AVAILED
1758	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	DEVANAGOAN_110	12:27	16:09	3:42	LINE CLEAR AVAILED
1759	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	PG HUNSYAL_110	09:44	10:14	0:30	TRIPPED ON FAULT
1760	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	CHIKKODI_110	11:22	12:42	1:20	LINE CLEAR AVAILED
1761	10-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	CHIKKODI_110	11:20	11:30	0:10	TRIPPED ON FAULT
1762	10-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	GADAG_220	10:56	17:24	6:28	LINE CLEAR AVAILED
1763	10-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	NARENDRA_220	15:34	18:16	2:42	LINE CLEAR AVAILED
1764	10-Dec-24	BAGALKOTE	110	LINE	AHERI220-LN3(CHANDAKAVATE)	AHERI_220	17:01	17:39	0:38	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1765	10-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-SUPA-1	AMBEWADI_220	11:38	13:03	1:25	LINE CLEAR AVAILED
1766	10-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F6-KERUR	BAGALKOT_220	8:09	8:18	0:09	TRIPPED ON FAULT
1767	10-Dec-24	BAGALKOTE	110	LINE	BIDNAL220-ANNIGERI	BIDNAL_220	06:35	10:02	3:27	TRIPPED ON FAULT
1768	10-Dec-24	BAGALKOTE	220	LINE	BIDNAL-NAGJHARI2	BIDNAL_220	09:45	14:33	4:48	LINE CLEAR AVAILED
1769	10-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220-RAIBAG 1	CHIKKODI_220	11:11	12:06	0:55	TRIPPED ON FAULT
1770	10-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220-RAIBAG 2	CHIKKODI_220	11:11	12:06	0:55	TRIPPED ON FAULT
1771	10-Dec-24	BAGALKOTE	220	LINE	DHONI-LINGAPUR1(HALVARTHY1)	DHONI_400	10:52	16:55	6:03	LINE CLEAR AVAILED
1772	10-Dec-24	BAGALKOTE	220	LINE	DHONI-LINGAPUR2(HALVARTHY2)	DHONI_400	10:52	16:55	6:03	LINE CLEAR AVAILED
1773	10-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
1774	10-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
1775	10-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1776	10-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
1777	10-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)			LINE CLEAR AVAILED
1778	10-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-MRN	KULAGERI CROSS_110	05:42	05:44	0:02	TRIPPED ON FAULT
1779	10-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-GSML1	MAHALINGAPUR_220	11:50	13:11	1:21	LINE CLEAR AVAILED
1780	10-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI	MALGHAN_110	04:12	04:22	0:10	TRIPPED ON FAULT
1781	10-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI (RLY)	MALGHAN_110	04:12	04:23	0:11	TRIPPED ON FAULT
1782	10-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVASUG	MALGHAN_110	04:12	04:22	0:10	TRIPPED ON FAULT
1783	10-Dec-24	BAGALKOTE	110	LINE	MALGHAN-MAMADAPUT(MATHIHAL)	MALGHAN_110	04:12	04:28	0:16	TRIPPED ON FAULT
1784	10-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1785	10-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
1786	10-Dec-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	3:31	3:40	0:09	TRIPPED ON FAULT
1787	10-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
1788	10-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1789	10-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	15:30 (09.12.2024)			LINE CLEAR AVAILED
1790	10-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
1791	10-Dec-24	BANGALORE	220	LINE	220KV BIDADI 220 - RAILWAY (EHT)	NO STATION AFFECTED	10:28	13:15	02:47	LINE CLEAR AVAILED
1792	10-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	10:21	19:34	09:13	LINE CLEAR AVAILED
1793	10-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	12:47	13:02	00:15	TRIPPED ON FAULT
1794	10-Dec-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	23:58:00	01:34	01:36	TRIPPED ON FAULT
1795	10-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1796	10-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1797	10-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
1798	10-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - ANCHEPALYA CKT 1	NO STATION AFFECTED	11:26	13:22	01:56	LINE CLEAR AVAILED
1799	10-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
1800	10-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 2	NO STATION AFFECTED	10:39	18:09	07:30	LINE CLEAR AVAILED
1801	10-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	23:58:00	13:05	13:06	TRIPPED ON FAULT
1802	10-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	13:05	14:20	01:15	LINE CLEAR AVAILED
1803	10-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	14:20	15:00	00:40	TRIPPED ON FAULT
1804	10-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	15:00	18:20	03:20	LINE CLEAR AVAILED
1805	10-Dec-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	09:55	18:45	08:50	LINE CLEAR AVAILED
1806	10-Dec-24	BANGALORE	66	LINE	66KV AREHALLI - BANASHANKARI	NO STATION AFFECTED	09:49	15:52	06:03	LINE CLEAR AVAILED
1807	10-Dec-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	NO STATION AFFECTED	23:58:00	11:30	11:32	TRIPPED ON FAULT
1808	10-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:01	10:06	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1809	10-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	20:05	20:30	00:25	LINE CLEAR AVAILED
1810	10-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	15:40	16:50	01:10	LINE CLEAR AVAILED
1811	10-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	12:10	14:28	02:18	LINE CLEAR AVAILED
1812	10-Dec-24	BANGALORE	66	LINE	66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)	BANASAWADI	13:22	17:19	03:57	LINE CLEAR AVAILED
1813	10-Dec-24	BANGALORE	66	LINE	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	02:15	02:31	00:16	TRIPPED ON FAULT
1814	10-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220 _DG4	GRINDWELL NORTON(EHT)	14:26	16:59	02:33	TRIPPED ON FAULT
1815	10-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:45	18:50	00:05	LINE CLEAR AVAILED
1816	10-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
1817	10-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - BYATARAYANAPURA (L&T) _DG4	BYATARAYANAPURA	07:55	09:53	01:58	TRIPPED ON FAULT
1818	10-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	16:36	16:39	00:03	LINE CLEAR AVAILED
1819	10-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	13:33	13:49	00:16	TRIPPED ON FAULT
1820	10-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	07:30	07:38	00:08	LINE CLEAR AVAILED
1821	10-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAILWHEEL AND AXLE SECORTES (EHT) - ATTURU _DG3	ATTUR YELAHANKA, WHEEL & AXIL, ESCORTS	09:04	09:41	00:37	TRIPPED ON FAULT
1822	10-Dec-24	BANGALORE	66	LINE	66KV SIDDALAGHATTA - MELUR	VIJAYAPURA, JANGAMKOTE, MELUR	08:50	08:55	00:05	LINE CLEAR AVAILED
1823	10-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVANA 220	NO STATION AFFECTED	14:46	16:21	01:35	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1824	10-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	23:58:00	06:13	06:15	LINE CLEAR AVAILED
1825	10-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	14:45	14:53	00:08	MAIN SUPPLY FAILURE
1826	10-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	14:45	15:05	00:20	TRIPPED ON FAULT
1827	10-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II	BIEC, ALUR	23:58:00	05:58	0.25	TRIPPED ON FAULT
1828	10-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR	18:11	18:37	00:26	MAIN SUPPLY FAILURE
1829	10-Dec-24	BANGALORE	66	LINE	66KV TUBAGERE - CB PURA I/A 1	NO STATION AFFECTED	13:33	13:54	00:21	TRIPPED ON FAULT
1830	10-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI) _DG4	NO STATION AFFECTED	15:49	16:49	01:00	LINE CLEAR AVAILED
1831	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	10:25	14:28	04:03	LINE CLEAR AVAILED
1832	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	22:39	22:47	00:08	TRIPPED ON FAULT
1833	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DODDAKARI	11:10	11:12	00:02	LINE CLEAR AVAILED
1834	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JANGAMKOTE	12:32	12:52	00:20	LINE CLEAR AVAILED
1835	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	K&C VALLEY	10:28	10:33	00:05	LINE CLEAR AVAILED
1836	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAASTHI	22:20	22:30	00:10	TRIPPED ON FAULT
1837	10-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	06:17	06:21	00:04	LINE CLEAR AVAILED
1838	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	AREHALLI	10:35	10:41	00:06	LINE CLEAR AVAILED
1839	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BANASAWADI	13:22	17:20	03:58	LINE CLEAR AVAILED
1840	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DODDAKARI	13:20	13:22	00:02	LINE CLEAR AVAILED
1841	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	K&C VALLEY	12:25	12:28	00:03	LINE CLEAR AVAILED
1842	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KENGERI	09:35	09:40	00:05	LINE CLEAR AVAILED
1843	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KHB	11:01	11:05	00:04	LINE CLEAR AVAILED
1844	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	M GOLLAHALLI	12:10	12:20	00:10	TRIPPED ON FAULT
1845	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	06:17	06:21	00:04	LINE CLEAR AVAILED
1846	10-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TALAGUNDA	12:45	13:45	01:00	LINE CLEAR AVAILED
1847	10-Dec-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	12:10	15:06	02:56	LINE CLEAR AVAILED
1848	10-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - HEBBANI	NO STATION AFFECTED	15:10	17:38	02:28	LINE CLEAR AVAILED
1849	10-Dec-24	BANGALORE	220	LINE	TK HALLI 220 - HEBBANI 1	NO STATION AFFECTED	09:48	11:09	01:21	LINE CLEAR AVAILED
1850	10-Dec-24	BANGALORE	220	LINE	TK HALLI 220 - HEBBANI 1	NO STATION AFFECTED	11:10	13:52	02:42	LINE CLEAR AVAILED
1851	10-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	13:23	17:48	04:25	LINE CLEAR AVAILED
1852	10-Dec-24	GULBARGA	220	LINE	HALBARGA-HUMNABAD	HUMNABAD_220	09:44:00	9:51:00	0:07:00	TRIPPED ON FAULT
1853	10-Dec-24	GULBARGA	110	LINE	HATTIGUDUR-SHAHAPUR1	SHAHAPUR_110	11:14	17:03	05:49	LINE CLEAR AVAILED
1854	10-Dec-24	GULBARGA	66	TRANSFORMER	HV1	ARSIKERE_66	08:30	09:30	01:00	TRIPPED ON FAULT
1855	10-Dec-24	GULBARGA	110	TRANSFORMER	HV1	JAWALGERA_110	10:25	16:55	06:30	LINE CLEAR AVAILED
1856	10-Dec-24	GULBARGA	66	TRANSFORMER	HV1	TELGI_66	16:15	16:20	00:05	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION	
1857	10-Dec-24	GULBARGA	110	TRANSFORMER	HV2	MADLAPUR_110	08:20	08:25	00:05	TRIPPED ON FAULT	
1858	10-Dec-24	GULBARGA	110	TRANSFORMER	HV2	MADLAPUR_110	10:00	11:50	01:50	LINE CLEAR AVAILED	
1859	10-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHICKSUGUR_110	12:14	12:34	00:20	TRIPPED ON FAULT	
1860	10-Dec-24	GULBARGA	110	TRANSFORMER	HV3	MUNIRABAD_220	09:33	22:05	12:32	LINE CLEAR AVAILED	
1861	10-Dec-24	GULBARGA	110	TRANSFORMER	HV3	SIRGUPPA_110	11:04	12:55	01:51	LINE CLEAR AVAILED	
1862	10-Dec-24	GULBARGA	220	LINE	KAPNOOR-HUMNABAD2	HUMNABAD_220	14:40	17:14	02:34	LINE CLEAR AVAILED	
1863	10-Dec-24	GULBARGA	66	LINE	KUDLIGI-ACME SOLAR	KUDLIGI_220	20:50(9.12.2024)	7:10(10.12.2024)	10:20	TRIPPED ON FAULT	
1864	10-Dec-24	GULBARGA	110	LINE	KUSHTAGI-GANADAL	GANADAL_110	02:25	02:50	00:25	TRIPPED ON FAULT	
1865	10-Dec-24	GULBARGA	110	LINE	LINGASUGUR-KPRL_IPP	LINGASUGUR_220	23:45	23:52	00:07	LINE CLEAR AVAILED	
1866	10-Dec-24	GULBARGA	110	LINE	MADLAPUR-RAICHUR	MADLAPUR_110	10:00	10:15	00:15	LINE CLEAR AVAILED	
1867	10-Dec-24	GULBARGA	110	LINE	MALLAT-ALKOD	GALAG_110, ALKOD_110	10:30	17:04	06:34	LINE CLEAR AVAILED	
1868	10-Dec-24	GULBARGA	110	LINE	MALLAT-ALKOD	GALAG_110, ALKOD_110	17:15	17:45	00:30	LINE CLEAR AVAILED	
1869	10-Dec-24	GULBARGA	110	LINE	NAGNOOR-HATTIGUDUR	NAGNOOR_110	10:22	17:37	07:15	LINE CLEAR AVAILED	
1870	10-Dec-24	GULBARGA	110	LINE	NALWAR-SHAHAPUR	NALWAR_110	19:55	20:10	00:15	TRIPPED ON FAULT	
1871	10-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED	
1872	10-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-HONAGERA	HONAGERA_110	13:30	16:10	02:40	LINE CLEAR AVAILED	
1873	10-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-SAIDAPUR	SAIDAPUR_110	22:25	22:48	00:23	TRIPPED ON FAULT	
1874	10-Dec-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI1	CHINCHOLI_110	14:00	17:37	03:37	LINE CLEAR AVAILED	
1875	10-Dec-24	GULBARGA	110	LINE	SHAHAPUR-DEVAPUR	SHORAPUR_110,DEVAPUR_110	10:07	16:55	06:48	LINE CLEAR AVAILED	
1876	10-Dec-24	GULBARGA	110	LINE	SHAHAPUR-KHANAPUR1	KHANAPUR_110	11:18	16:56	05:38	LINE CLEAR AVAILED	
1877	10-Dec-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	DEVBURGA_110	11:31	16:55	05:24	LINE CLEAR AVAILED	
1878	10-Dec-24	GULBARGA	110	LINE	SHAHAPUR-YADGIRI	YADGIRI_110	11:30	16:56	05:26	LINE CLEAR AVAILED	
1879	10-Dec-24	GULBARGA	110	LINE	SINDHANOOR-ADAVI	AMARESHWAR	JAWALGERA_110	11:00	17:20	06:20	LINE CLEAR AVAILED
1880	10-Dec-24	GULBARGA	110	LINE	SINDHANOOR-WALABALLARI	WALABALLARI_110	10:25	16:55	06:30	LINE CLEAR AVAILED	
1881	10-Dec-24	GULBARGA	220	LINE	SULEKAL-LINGAPUR	LINGAPUR_220	13:49	16:48	02:59	LINE CLEAR AVAILED	
1882	10-Dec-24	HASAN	110	LINE	ALKOLA-MRS	ALKOLA_110	11:25	11:31	00:06	TRIPPED ON FAULT	
1883	10-Dec-24	HASAN	66	LINE	BALLUPE-KANDLI	BALLUPETE_66	10:38	16:50	06:12	LINE CLEAR AVAILED	
1884	10-Dec-24	HASAN	66	LINE	CHKNGR-LN2	CHIKKANAGARA_220	11:52	14:20	02:28	LINE CLEAR AVAILED	
1885	10-Dec-24	HASAN	66	LINE	CHKNGR-LN3	CHIKKANAGARA_220	11:52	14:20	02:28	LINE CLEAR AVAILED	
1886	10-Dec-24	HASAN	66	LINE	HASSN22-SKPURA2	HASSAN_220	10:46	14:44	03:58	LINE CLEAR AVAILED	
1887	10-Dec-24	HASAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	09:00	17:29	08:29	LINE CLEAR AVAILED	
1888	10-Dec-24	HASAN	66	LINE	HNPR2-HNPR1	HOLENARASIPURA_220	14:58	16:00	01:02	LINE CLEAR AVAILED	
1889	10-Dec-24	HASAN	66	LINE	HNPURA-HNPR2	HNPURA_66	15:10	16:00	00:50	LINE CLEAR AVAILED	
1890	10-Dec-24	HASAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	15:18	16:04	00:46	LINE CLEAR AVAILED	
1891	10-Dec-24	HASAN	110	TRANSFORMER	HV1	ALKOLA_110	09:23	10:05	00:42	LINE CLEAR AVAILED	
1892	10-Dec-24	HASAN	110	TRANSFORMER	HV1	ALKOLA_110	11:25	11:34	00:09	TRIPPED ON FAULT	
1893	10-Dec-24	HASAN	66	TRANSFORMER	HV1	BALLUPETE_66	10:31	15:31	05:00	LINE CLEAR AVAILED	
1894	10-Dec-24	HASAN	66	TRANSFORMER	HV1	DUDDA_66	14:39	17:50	03:11	LINE CLEAR AVAILED	

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1895	10-Dec-24	HASAN	220	LINE	HV1	HGGUNJE_220	10:30	12:40	02:10	LINE CLEAR AVAILED
1896	10-Dec-24	HASAN	66	TRANSFORMER	HV1	HIEMAGALUR_220	13:50	14:00	00:10	TRIPPED ON FAULT
1897	10-Dec-24	HASAN	66	TRANSFORMER	HV1	HNPURA_66	14:58	15:10	00:12	MAIN SUPPLY FAILURE
1898	10-Dec-24	HASAN	220	TRANSFORMER	HV1	KADUR_220	12:28	13:06	00:38	LINE CLEAR AVAILED
1899	10-Dec-24	HASAN	66	TRANSFORMER	HV1	KANDLI_66	10:03	16:01	05:58	LINE CLEAR AVAILED
1900	10-Dec-24	HASAN	110	TRANSFORMER	HV1	KEMAR_220	13:10	15:31	02:21	LINE CLEAR AVAILED
1901	10-Dec-24	HASAN	66	TRANSFORMER	HV1	MAGGE_66	10:42	16:54	06:12	MAIN SUPPLY FAILURE
1902	10-Dec-24	HASAN	66	TRANSFORMER	HV1	SAKLESH PURA_66	10:21	17:12	06:51	LINE CLEAR AVAILED
1903	10-Dec-24	HASAN	66	TRANSFORMER	HV1	SAKLESH PURA_66	19:18	19:39	00:21	TRIPPED ON FAULT
1904	10-Dec-24	HASAN	110	TRANSFORMER	HV2	ALKOLA_110	11:25	11:33	00:08	TRIPPED ON FAULT
1905	10-Dec-24	HASAN	110	TRANSFORMER	HV2	HGGUNJE_220	12:14	14:03	01:49	LINE CLEAR AVAILED
1906	10-Dec-24	HASAN	66	TRANSFORMER	HV2	HNPURA_66	14:58	15:10	00:12	MAIN SUPPLY FAILURE
1907	10-Dec-24	HASAN	110	TRANSFORMER	HV2	HOSANGAD_110	14:43	16:42	01:59	LINE CLEAR AVAILED
1908	10-Dec-24	HASAN	66	TRANSFORMER	HV2	KANDLI_66	10:03	16:01	05:58	LINE CLEAR AVAILED
1909	10-Dec-24	HASAN	110	TRANSFORMER	HV2	KEMAR_220	10:14	13:08	02:54	LINE CLEAR AVAILED
1910	10-Dec-24	HASAN	66	TRANSFORMER	HV2	MAGGE_66	10:42	16:54	06:12	MAIN SUPPLY FAILURE
1911	10-Dec-24	HASAN	220	TRANSFORMER	HV2	PUTTUR_220	11:50	14:38	02:48	LINE CLEAR AVAILED
1912	10-Dec-24	HASAN	66	TRANSFORMER	HV2	SAKLESH PURA_66	10:21	17:12	06:51	LINE CLEAR AVAILED
1913	10-Dec-24	HASAN	110	TRANSFORMER	HV2	KARKALA_110	07:35	07:51	00:16	TRIPPED ON FAULT
1914	10-Dec-24	HASAN	110	TRANSFORMER	HV3	ALKOLA_110	11:25	11:33	00:08	TRIPPED ON FAULT
1915	10-Dec-24	HASAN	110	TRANSFORMER	HV3	MANIPAL_110	10:25	10:40	00:15	LINE CLEAR AVAILED
1916	10-Dec-24	HASAN	110	TRANSFORMER	HV3	MANIPAL_110	12:40	13:33	00:53	LINE CLEAR AVAILED
1917	10-Dec-24	HASAN	110	TRANSFORMER	HV4	MANIPAL_110	10:23	13:35	03:12	LINE CLEAR AVAILED
1918	10-Dec-24	HASAN	110	TRANSFORMER	HV4	PUTTUR_110	09:27	12:42	03:15	LINE CLEAR AVAILED
1919	10-Dec-24	HASAN	110	TRANSFORMER	HV5	KAVOOR_220	09:50	17:12	07:22	LINE CLEAR AVAILED
1920	10-Dec-24	HASAN	110	TRANSFORMER	HV5	MANIPAL_110	10:25	13:37	03:12	LINE CLEAR AVAILED
1921	10-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	18:07(9.12.2024)	1:34(10.12.2024)	7:27HRS	LINE CLEAR AVAILED
1922	10-Dec-24	HASAN	66	LINE	KANDLI-SAKLESH PUR	KANDLI_66	10:40	16:54	06:14	LINE CLEAR AVAILED
1923	10-Dec-24	HASAN	110	LINE	KARKLA-HIRIYADKA	KARKALA_110	10:32	10:33	00:01	LINE CLEAR AVAILED
1924	10-Dec-24	HASAN	110	LINE	KARKLA-HIRIYADKA	KARKALA_110	13:17	13:20	00:03	LINE CLEAR AVAILED
1925	10-Dec-24	HASAN	110	LINE	KAVOOR-GURUPURA	KAVOOR_220	09:11	18:54	09:43	LINE CLEAR AVAILED
1926	10-Dec-24	HASAN	110	LINE	KEMAR-BELMAN	KEMAR_220	12:09	16:04	03:55	LINE CLEAR AVAILED
1927	10-Dec-24	HASAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	06:21	13:14	06:53	TRIPPED ON FAULT
1928	10-Dec-24	HASAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	15:30	19:58	04:28	MAIN SUPPLY FAILURE
1929	10-Dec-24	HASAN	110	LINE	LV1	HGGUNJE_220	11:16	13:16	02:00	LINE CLEAR AVAILED
1930	10-Dec-24	HASAN	110	TRANSFORMER	LV2	PUTTUR_220	11:50	14:38	02:48	LINE CLEAR AVAILED
1931	10-Dec-24	HASAN	110	LINE	MADHUV-BRK_HRD CBreaker	MADHUVANA_110	09:01	17:30	08:29	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1932	10-Dec-24	HASAN	110	LINE	MADHUV-BRK_MDV CBreaker	MADHUVANA_110	09:01	17:30	08:29	LINE CLEAR AVAILED
1933	10-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	10:09	15:02	04:53	LINE CLEAR AVAILED
1934	10-Dec-24	HASAN	66	LINE	SAKALE-HASSAN	SAKLESH PURA_66	10:30	17:12	06:42	LINE CLEAR AVAILED
1935	10-Dec-24	HASAN	66	LINE	SAKALE-HASSAN1	SAKLESH PURA_66	10:30	17:12	06:42	LINE CLEAR AVAILED
1936	10-Dec-24	HASAN	66	LINE	SAKALE-IPCL1	SAKLESH PURA_66	10:29	17:12	06:43	LINE CLEAR AVAILED
1937	10-Dec-24	HASAN	66	LINE	SAKALE-IPCL2	SAKLESH PURA_66	10:31	17:12	06:41	LINE CLEAR AVAILED
1938	10-Dec-24	HASAN	110	LINE	SALATHU-KONAJE	SALATHUR_66	15:30	19:58	04:28	TRIPPED ON FAULT
1939	10-Dec-24	HASAN	110	LINE	SALATHU-VITLA	SALATHUR_66	15:30	15:37	00:07	TRIPPED ON FAULT
1940	10-Dec-24	HASAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	10:10	10:30	00:20	MAIN SUPPLY FAILURE
1941	10-Dec-24	HASAN	66	LINE	SOMNHL-HNPURA	SOMANAHALLI_66	15:00	15:10	00:10	MAIN SUPPLY FAILURE
1942	10-Dec-24	HASAN	66	LINE	SOMNHL-HNPURA	SOMANAHALLI_66	15:21	16:05	00:44	MAIN SUPPLY FAILURE
1943	10-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	09:33	17:43	08:10	LINE CLEAR AVAILED
1944	10-Dec-24	HASAN	220	LINE	VARAHI-HEGGUNJE	varahi_gen	10:31	12:41	02:10	LINE CLEAR AVAILED
1945	10-Dec-24	MYSORE	66	LINE	220KV NAGAMANGALA -BG NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	18:02	18:10	00:08	TRIPPED ON FAULT
1946	10-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
1947	10-Dec-24	MYSORE	66	LINE	GOLUR-DEVANUR NANJANGUDU	DEVANOORNGUDU_66SU TTUR_66	07:30	07:33	00:03	TRIPPED ON FAULT
1948	10-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
1949	10-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 1	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1950	10-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 2	NO STATIONS EFFECTED	14:04 (8/12/2024)			LINE CLEAR AVAILED
1951	10-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
1952	10-Dec-24	MYSORE	66	LINE	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	08:29	12:19	03:50	LINE CLEAR AVAILED
1953	10-Dec-24	MYSORE	66	LINE	HEBBANI-SHIMSHA	NO STATIONS EFFECTED	15:20	17:31	02:11	LINE CLEAR AVAILED
1954	10-Dec-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	15:07	17:34	02:27	LINE CLEAR AVAILED
1955	10-Dec-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	13:05 (8/12/2024)	12:47 (10/12/2024)	47:42 HRs	LINE CLEAR AVAILED
1956	10-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI 1	NO STATIONS EFFECTED	11:07	13:48	02:41	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1957	10-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI 2	NO STATIONS EFFECTED	09:47	11:07	01:20	LINE CLEAR AVAILED
1958	10-Dec-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAP 1	BANNIMANTAP_66	10:15	16:42	06:27	LINE CLEAR AVAILED
1959	10-Dec-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAP 2	BANNIMANTAP_66	10:15	16:43	06:28	LINE CLEAR AVAILED
1960	10-Dec-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	13:44 (9/12/2024)			LINE CLEAR AVAILED
1961	10-Dec-24	MYSORE	220	TRANSFORMER	HV1	HEBBANI_220	11:07	11:47	00:40	LINE CLEAR AVAILED
1962	10-Dec-24	MYSORE	66	TRANSFORMER	HV1	KADABALLI_66	10:53	12:51	01:58	LINE CLEAR AVAILED
1963	10-Dec-24	MYSORE	220	TRANSFORMER	HV1	KRPET_220	12:10	13:53	01:43	LINE CLEAR AVAILED
1964	10-Dec-24	MYSORE	66	TRANSFORMER	HV1	NANJANGUDU_66	09:50	10:28	00:38	TRIPPED ON FAULT
1965	10-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1966	10-Dec-24	MYSORE	66	TRANSFORMER	HV2	BGNAGARA_66	14:40	15:08	00:27	LINE CLEAR AVAILED
1967	10-Dec-24	MYSORE	66	TRANSFORMER	HV2	KADABALLI_66	12:55	14:00	01:05	LINE CLEAR AVAILED
1968	10-Dec-24	MYSORE	66	TRANSFORMER	HV2	NANJANGUDU_66	09:50	10:28	00:38	TRIPPED ON FAULT
1969	10-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEBACHALLI_66	12:30	18:39	06:09	LINE CLEAR AVAILED
1970	10-Dec-24	MYSORE	66	TRANSFORMER	HV3	NANJANGUDU_66	09:50	10:28	00:38	TRIPPED ON FAULT
1971	10-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1972	10-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
1973	10-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
1974	10-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
1975	10-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	18:13 (10/12/2024)			TRIPPED ON FAULT
1976	10-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	07:53	07:58	00:04	TRIPPED ON FAULT
1977	10-Dec-24	MYSORE	66	LINE	MALAVALLI-SHIMSHA	NO STATIONS EFFECTED	15:37	17:23	01:46	LINE CLEAR AVAILED
1978	10-Dec-24	MYSORE	66	LINE	NANJANGUDU-RTSS	NO STATIONS EFFECTED	09:50	10:28	00:38	TRIPPED ON FAULT
1979	10-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1980	10-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	16:30 (7/12/2024)			LINE CLEAR AVAILED
1981	10-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 6	NO STATIONS EFFECTED	14:46	17:52	03:05	LINE CLEAR AVAILED
1982	10-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 6	NO STATIONS EFFECTED	21:20	21:26	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1983	10-Dec-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	YESSLUR_66HETHUR_66	10:55	11:12	00:16	LINE CLEAR AVAILED
1984	10-Dec-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	YESSLUR_66HETHUR_66	13:00	14:45	01:45	LINE CLEAR AVAILED
1985	10-Dec-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	10:10	18:35	08:25	LINE CLEAR AVAILED
1986	10-Dec-24	MYSORE	220	LINE	TUBINKERE-KOTTIPURA	NO STATIONS EFFECTED	8:38 (8/12/2024)			TRIPPED ON FAULT
1987	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV AMRUTHUR LINE	66KV SANTHEMAVATHUR,AMRU THUR,SANABGHATTA,YED AVANI	10:01	17:35	7:34	LINE CLEAR AVAILED
1988	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2	66KV HULLENAHALLI,KUDUR,S RIGIRIPURA	10:01	17:30	7:29	LINE CLEAR AVAILED
1989	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 1	66KV ANCHEPLAYA,BHAKTHAR AHALLI	10:01	17:28	7:27	LINE CLEAR AVAILED
1990	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV B.G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIY UR	10:01	17:33	7:32	LINE CLEAR AVAILED
1991	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV HEBBUR LINE	66KV HEBBUR,HONNENAHALI,T HIMMASANDRA	10:01	17:31	7:30	LINE CLEAR AVAILED
1992	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV HULIYURDURGA LINE	66KV HULIYURDURGA,CHOWD ANKUPPE,HULIYAR,NIDSA LE	10:01	17:32	7:31	LINE CLEAR AVAILED
1993	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV KEMPANAHALLI LINE	66KV KEMPANAHALLI,HAGALKO TE,MATTIKERE	10:01	17:35	7:34	LINE CLEAR AVAILED
1994	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV KUNIGAL LINE	66KV KUNIGAL	10:01	17:29	7:28	LINE CLEAR AVAILED
1995	10-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV VIJAYA STEEL LINE	VIJAYA STEEL	10:01	18:37	8:36	LINE CLEAR AVAILED
1996	10-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV GOPPENAHALLI	66KV GOPPENAHALLI,TAVAREK ERE	2:40	2:57	0:17	TRIPPED ON FAULT
1997	10-Dec-24	TUMKUR	66	LINE	220KV GUTTUR 1 LINE-DAVANGERE SRS 220	DAVANGERE SRS 220	10:39	12:40	2:01	LINE CLEAR AVAILED
1998	10-Dec-24	TUMKUR	66	LINE	220KV MADHURE,MATHOD_66KV	66KV NEERAGUNDA GATE	10:05	18:25	8:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
1999	10-Dec-24	TUMKUR	110	LINE	220KV NITTUR-110 KV K.G.TEMPLE	110 KV K.G.TEMPLE	1:18	1:58	0:40	LINE CLEAR AVAILED
2000	10-Dec-24	TUMKUR	400	LINE	400 KV GUTTUR-NARENDRA-II	400 KV GUTTUR	1:13	11:12	9:59	LINE CLEAR AVAILED
2001	10-Dec-24	TUMKUR	400	LINE	400 KV GUTTUR-NARENDRA-II	400 KV GUTTUR	22:17	23:59	1:42	LINE CLEAR AVAILED
2002	10-Dec-24	TUMKUR	220	LINE	400/220KV NELAMANGALA-ANCHELPALYA 220KV LINE-1	220KV ANCHEPALYA	11:27	13:22	1:55	LINE CLEAR AVAILED
2003	10-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE	6:00	6:20	0:20	TRIPPED ON FAULT
2004	10-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	10:15	10:20	0:05	LINE CLEAR AVAILED
2005	10-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV PALLAGATTE	66KV PALLAGATTE	10:15	10:25	0:10	LINE CLEAR AVAILED
2006	10-Dec-24	TUMKUR	66	LINE	BILCHODU-SOKKE	BILCHODU_66, PALLAGATTE_66	6:00	6:20	0:20	MAIN SUPPLY FAILURE
2007	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	66KV ANAGODU , ATTIGERE	15:35	16:43	1:08	LINE CLEAR AVAILED
2008	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV AVARAGERE LINE	66KV AVARAGERE	15:33	16:26	0:53	LINE CLEAR AVAILED
2009	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 & 2 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA	10:16	15:16	5:00	LINE CLEAR AVAILED
2010	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA, KEREKILACHI, WWWKNNI	16:10	17:29	1:19	TRIPPED ON FAULT
2011	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA, KEREKILACHI, WWWKNNI	15:50	17:29	1:39	TRIPPED ON FAULT
2012	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV MAYAKONDA LINE	66KV MAYAKONDA, SSALU, CHICKAJAJUR	15:34	16:28	0:54	LINE CLEAR AVAILED
2013	10-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV YARAGUNTA LINE	66KV YARAGUNTA	15:36	16:26	0:50	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2014	10-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2015	10-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2016	10-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV- 66KV CHALLAKERE	66KV SANIKERE	8:20	8:30	0:10	TRIPPED ON FAULT
2017	10-Dec-24	TUMKUR	66	LINE	HONNALLI 220KV- DAVANAGERE SRS	HONNALLI_220	12:45	14:45	2:00	LINE CLEAR AVAILED
2018	10-Dec-24	TUMKUR	66	LINE	MAYAKONDA_66- CHIKKAJAJUR_66	66KV KUTTIGAHALLI, WATERHOUSE	2:05	2:25	0:20	TRIPPED ON FAULT
2019	10-Dec-24	TUMKUR	66	LINE	MAYAKONDA_66- CHIKKAJAJUR_66	66KV KUTTIGAHALLI, WATERHOUSE	6:05	6:20	0:15	TRIPPED ON FAULT
2020	10-Dec-24	TUMKUR	66	LINE	SASALUHALLA- CHIKKAJAJUR	SASALUHALLA_66	15:35	16:25	0:50	LINE CLEAR AVAILED
2021	10-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1	66KV KALLAMBELLA, KIADB	21:49	21:56	0:07	TRIPPED ON FAULT
2022	10-Dec-24	TUMKUR	66	TRANSFORMER	TR1 100MVA	ANCHEPALYA_220	10:01	17:24	7:23	LINE CLEAR AVAILED
2023	10-Dec-24	TUMKUR	66	TRANSFORMER	TR1 100MVA	ANCHEPALYA_220	10:01	17:25	7:24	LINE CLEAR AVAILED
2024	10-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	0:40	0:45	0:05	TRIPPED ON FAULT
2025	10-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	0:50	0:55	0:05	TRIPPED ON FAULT
2026	10-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	SAVALANGA_66	13:40	14:15	0:35	LINE CLEAR AVAILED
2027	10-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
2028	10-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5	KUKKAWADA_66	4:00	4:05	0:05	TRIPPED ON FAULT
2029	10-Dec-24	TUMKUR	66	TRANSFORMER	TR2 8MVA	SAVALANGA_66	12:40	13:35	0:55	LINE CLEAR AVAILED
2030	10-Dec-24	TUMKUR	66	TRANSFORMER	TR3 20MVA	ANTHRASANAHALLI_220	0:28	1:43	1:15	LINE CLEAR AVAILED
2031	10-Dec-24	TUMKUR	66	TRANSFORMER	TR3 20MVA	ANTHRASANAHALLI_220	0:29	1:52	1:23	LINE CLEAR AVAILED
2032	10-Dec-24	TUMKUR	66	LINE	TURUVANUR_66KV- CHITRADURGA220	TURUVANUR_66KV	18:09	18:14	0:05	MAIN SUPPLY FAILURE
2033	10-Dec-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	18:09	18:19	0:10	TRIPPED ON FAULT
2034	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ARGA_110	09:12	13:12	4:00	LINE CLEAR AVAILED
2035	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	12:21	12:28	0:07	TRIPPED ON FAULT
2036	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KALGHATAGI_110	09:37	09:46	0:09	LINE CLEAR AVAILED
2037	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	ARGA_110	09:15	16:43	7:28	LINE CLEAR AVAILED
2038	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KALGHATAGI_110	09:37	09:48	0:11	LINE CLEAR AVAILED
2039	11-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	CHIKKODI_110	16:13	16:22	0:09	TRIPPED ON FAULT
2040	11-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	NARENDRA_220	11:39	11:45	0:06	LINE CLEAR AVAILED
2041	11-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1(HV2)	GADAG_220	10:28	18:11	7:43	LINE CLEAR AVAILED
2042	11-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	NARENDRA_220	08:24	11:33	3:09	LINE CLEAR AVAILED
2043	11-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:28	18:11	7:43	LINE CLEAR AVAILED
2044	11-Dec-24	BAGALKOTE	110	LINE	ARGA-ANKOLA	ARGA_110	09:10	12:47	3:37	LINE CLEAR AVAILED
2045	11-Dec-24	BAGALKOTE	110	LINE	ARGA-KARWAR	ARGA_110	09:03	13:10	4:07	LINE CLEAR AVAILED
2046	11-Dec-24	BAGALKOTE	110	LINE	BABALESHWAR-VSE	BABALESHWAR_110	18:09	18:47	0:38	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2047	11-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
2048	11-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
2049	11-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2050	11-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2051	11-Dec-24	BAGALKOTE	110	LINE	KARWAR220 -ARGA	KARWAR_220	09:04	13:10	4:06	LINE CLEAR AVAILED
2052	11-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	18:10 (28.11.2024)	8:53 (11.12.2024)	302:43:00	LINE CLEAR AVAILED
2053	11-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2054	11-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3:12.2024)			LINE CLEAR AVAILED
2055	11-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2056	11-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
2057	11-Dec-24	BAGALKOTE	110	LINE	RAMANNKOPPA-SRS	RAMANNKOPPA_110	11:35	13:05	1:30	LINE CLEAR AVAILED
2058	11-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
2059	11-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2060	11-Dec-24	BAGALKOTE	110	LINE	SIRSI220- RAMANKOPPA	HUBLI_220	11:37	13:01	1:24	LINE CLEAR AVAILED
2061	11-Dec-24	BAGALKOTE	220	LINE	SIRSI220- UMMACHAGI	SIRSI_220	08:52	12:09	3:17	LINE CLEAR AVAILED
2062	11-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	15:30 (09.12.2024)			LINE CLEAR AVAILED
2063	11-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2064	11-Dec-24	BAGALKOTE	110	LINE	UMMACHAGI-KIRUVATTI	UMMACHAGI_110	12:09	14:07	1:58	LINE CLEAR AVAILED
2065	11-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 -TUBINAKERE 220	NO STATION AFFECTED	11:41	13:27	01:46	LINE CLEAR AVAILED
2066	11-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2067	11-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2068	11-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2069	11-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 -SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2070	11-Dec-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	11:40	13:25	01:45	LINE CLEAR AVAILED
2071	11-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:05	10:10	00:05	LINE CLEAR AVAILED
2072	11-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - NELAMANGALA CKT 1	NELAMANGALA 66	14:05	14:40	00:35	TRIPPED ON FAULT
2073	11-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - AMARJYOTHI 1 - LEELAVENTURE (TAP)	LEELA VENTURE	14:22	14:26	00:04	LINE CLEAR AVAILED
2074	11-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - AMARJYOTHI 1 - LEELAVENTURE (TAP)	LEELA VENTURE	18:20	18:23	00:03	LINE CLEAR AVAILED
2075	11-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)	AMARJYOTHI	14:22	14:26	00:04	LINE CLEAR AVAILED
2076	11-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)	AMARJYOTHI	18:20	18:23	00:03	LINE CLEAR AVAILED
2077	11-Dec-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI	10:30	15:45	05:15	LINE CLEAR AVAILED
2078	11-Dec-24	BANGALORE	66	LINE	66KV ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	09:55	15:20	05:25	LINE CLEAR AVAILED
2079	11-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	08:44	09:11	00:27	TRIPPED ON FAULT
2080	11-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	19:01	19:06	00:05	LINE CLEAR AVAILED
2081	11-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	NO STATION AFFECTED	23:58:00	04:40	04:42	TRIPPED ON FAULT
2082	11-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	NO STATION AFFECTED	22:04	23:59	01:55	TRIPPED ON FAULT
2083	11-Dec-24	BANGALORE	66	LINE	66KV MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI	18:01	18:03	00:02	TRIPPED ON FAULT
2084	11-Dec-24	BANGALORE	66	LINE	66KV SIDDALAGHATTA - MELUR	NO STATION AFFECTED	11:55	14:00	02:05	LINE CLEAR AVAILED
2085	11-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	09:43	15:29	05:46	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2086	11-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	10:00	15:35	05:35	LINE CLEAR AVAILED
2087	11-Dec-24	BANGALORE	66	LINE	GOWRIBIDANUR 220 - AFTL(EHT)	AFTL(EHT)	06:59	07:15	00:16	TRIPPED ON FAULT
2088	11-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHANDRAPPA CIRCLE	11:15	23:59	12:44	LINE CLEAR AVAILED
2089	11-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	09:54	10:04	00:10	TRIPPED ON FAULT
2090	11-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBALAGODU 220	13:10	13:17	00:07	TRIPPED ON FAULT
2091	11-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	06:03	06:08	00:05	LINE CLEAR AVAILED
2092	11-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	11:50	13:20	01:30	LINE CLEAR AVAILED
2093	11-Dec-24	BANGALORE	66	TRANSFORMER	HV2	EAST DIVISION COMPOUND 220	14:20	14:25	00:05	LINE CLEAR AVAILED
2094	11-Dec-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	13:15	15:55	02:40	LINE CLEAR AVAILED
2095	11-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	06:03	06:08	00:05	LINE CLEAR AVAILED
2096	11-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MASTHENAHALLI	10:05	12:35	02:30	LINE CLEAR AVAILED
2097	11-Dec-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	13:15	15:55	02:40	LINE CLEAR AVAILED
2098	11-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, TALAGAVADI, MANDYA KIADB, TUMBGERE	06:24	06:43	00:19	TRIPPED ON FAULT
2099	11-Dec-24	GULBARGA	110	LINE	ALLIPUR-SOUTH	BISILHALLI_110	10:41	10:50	00:09	TRIPPED ON FAULT
2100	11-Dec-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGI	BENNEHALLI_66	24:00:00	24:01:00	0:01:00	LINE CLEAR AVAILED
2101	11-Dec-24	GULBARGA	110	TRANSFORMER	HV3	ALLIPUR_220	11:36	12:20	00:44	TRIPPED ON FAULT
2102	11-Dec-24	GULBARGA	110	TRANSFORMER	HV3	ALLIPUR_220	13:35	13:44	00:09	TRIPPED ON FAULT
2103	11-Dec-24	GULBARGA	110	TRANSFORMER	HV3	MUNIRABAD_220	17:16	17:21	00:05	TRIPPED ON FAULT
2104	11-Dec-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	17:40	18:15	00:35	TRIPPED ON FAULT
2105	11-Dec-24	GULBARGA	220	LINE	KAPNOOR-HUMNABAD1	HUMNABAD_220	11:26	14:31	03:05	LINE CLEAR AVAILED
2106	11-Dec-24	GULBARGA	110	LINE	KHANAPUR-GONDEDAGI	KHANAPUR_110	06:03	06:22	00:19	TRIPPED ON FAULT
2107	11-Dec-24	GULBARGA	66	LINE	KUDALGI-HANSI	HANSI_66, CHILAKANAHATTI_66	16:45	16:55	00:10	TRIPPED ON FAULT
2108	11-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
2109	11-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDDAPUR	MUDDAPUR_110	10:15	14:15	04:00	LINE CLEAR AVAILED
2110	11-Dec-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	18:05	18:17	00:12	TRIPPED ON FAULT
2111	11-Dec-24	GULBARGA	110	LINE	VENKATAGIRI-GANGAVATI	VENKATAGIRI_110	10:00	13:25	03:25	LINE CLEAR AVAILED
2112	11-Dec-24	GULBARGA	110	LINE	VENKATAGIRI-GANGAVATI	VENKATAGIRI_110	13:25	17:20	03:55	LINE CLEAR AVAILED
2113	11-Dec-24	HASAN	66	LINE	BHADRA-LINGADAHALLI	bhadra_gen	09:30	09:50	00:20	TRIPPED ON FAULT
2114	11-Dec-24	HASAN	66	LINE	CHIKABO-KUSHLNAGAR	CHIKKABOMMENAHALLI_66	12:54	14:51	01:57	MAIN SUPPLY FAILURE
2115	11-Dec-24	HASAN	220	LINE	CHKNGR-F2	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2116	11-Dec-24	HASAN	66	LINE	CHKNGR-LN2	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2117	11-Dec-24	HASAN	66	LINE	CHKNGR-LN3	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2118	11-Dec-24	HASAN	66	LINE	CHKNGR-LN4	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2119	11-Dec-24	HASAN	66	LINE	CHKNGR-LN5	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2120	11-Dec-24	HASAN	220	LINE	HBNHL-OG1	HEBBANAHALLI_400	10:44	16:14	05:30	LINE CLEAR AVAILED
2121	11-Dec-24	HASAN	220	LINE	HBNHL-OG2	HEBBANAHALLI_400	10:44	16:14	05:30	LINE CLEAR AVAILED
2122	11-Dec-24	HASAN	110	TRANSFORMER	HV3	PUTTUR_110	06:05	14:05	08:00	TRIPPED ON FAULT
2123	11-Dec-24	HASAN	110	TRANSFORMER	HV5	KAVOOR_220	09:47	12:19	02:32	LINE CLEAR AVAILED
2124	11-Dec-24	HASAN	110	LINE	KAVOOR-GURUPURA	KAVOOR_220	09:28	18:05	08:37	LINE CLEAR AVAILED
2125	11-Dec-24	HASAN	66	LINE	LV1	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2126	11-Dec-24	HASAN	66	LINE	LV2	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2127	11-Dec-24	HASAN	220	LINE	OG1 CBreaker	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2128	11-Dec-24	HASAN	220	LINE	OG2 CBreaker	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2129	11-Dec-24	HASAN	220	LINE	OG3 CBreaker	CHIKKANAGARA_220	10:42	16:45	06:03	MAIN SUPPLY FAILURE
2130	11-Dec-24	HASAN	220	LINE	SHRAVTY-SHIMOGA3	sharavathy_gen	10:48	11:16	00:28	TRIPPED ON FAULT
2131	11-Dec-24	HASAN	220	LINE	SHRAVTY-SHIRALKOPPA	sharavathy_gen	09:56	18:23	08:27	LINE CLEAR AVAILED
2132	11-Dec-24	HASAN	220	LINE	SHRAVTY-TALAGUPPA1	sharavathy_gen	09:33	17:45	08:12	LINE CLEAR AVAILED
2133	11-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	09:54	18:22	08:28	LINE CLEAR AVAILED
2134	11-Dec-24	MYSORE	66	LINE	BEGURU-B MATTIGERE	B MATKERE_66	04:29	04:35	00:05	TRIPPED ON FAULT
2135	11-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
2136	11-Dec-24	MYSORE	66	LINE	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	14:55	16:14	01:18	LINE CLEAR AVAILED
2137	11-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
2138	11-Dec-24	MYSORE	66	LINE	HD KOTE-ANTHARA SANTHE-TARAKA LIS	ANTHARSANTHE_66	10:10	12:15	02:05	LINE CLEAR AVAILED
2139	11-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 1	NO STATIONS EFFECTED	14:04 (8/12/2024)	18:24 (11/12/2024)	100:20 HRS	LINE CLEAR AVAILED
2140	11-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 2	NO STATIONS EFFECTED	14:04 (8/12/2024)	18:26 (11/12/2024)	100:22 HRS	LINE CLEAR AVAILED
2141	11-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2142	11-Dec-24	MYSORE	66	LINE	HOOTAGALLI-HAMPAPURA	HAMPAPURA_66	09:01	09:14	00:13	TRIPPED ON FAULT
2143	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	13:44 (9/12/2024)	14:46 (11/12/2024)	73:02 HRS	LINE CLEAR AVAILED
2144	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	10:00	18:26	08:26	LINE CLEAR AVAILED
2145	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	01:10	01:25	00:15	MAIN SUPPLY FAILURE
2146	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2147	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	TALAGAVADI_66	06:23	06:43	00:20	MAIN SUPPLY FAILURE
2148	11-Dec-24	MYSORE	66	TRANSFORMER	HV1	YERALLI HAND POST_66	10:00	16:30	06:30	LINE CLEAR AVAILED
2149	11-Dec-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	10:00	18:26	08:26	LINE CLEAR AVAILED
2150	11-Dec-24	MYSORE	66	TRANSFORMER	HV2	MALAVALLI_66	01:10	01:25	00:15	MAIN SUPPLY FAILURE
2151	11-Dec-24	MYSORE	66	TRANSFORMER	HV2	TALAGAVADI_66	06:23	06:43	00:20	MAIN SUPPLY FAILURE
2152	11-Dec-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	06:54	07:01	00:07	TRIPPED ON FAULT
2153	11-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2154	11-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2155	11-Dec-24	MYSORE	66	LINE	KK DODDI-KIADB MANDYA	NO STATIONS EFFECTED	06:23	08:59	02:36	TRIPPED ON FAULT
2156	11-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2157	11-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2158	11-Dec-24	MYSORE	66	LINE	KUNTHURU-BANNARI IPP	NO STATIONS EFFECTED	06:37	06:42	00:05	TRIPPED ON FAULT
2159	11-Dec-24	MYSORE	66	LINE	KUSHALNAGARA 220-KARADI LAKKANAKERA LIS-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66RUDRAPATNA_66CBHALLI_66	12:35	14:45	02:10	LINE CLEAR AVAILED
2160	11-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	18:13 (10/12/2024)	13:49 (11/12/2024)	43:36 HRS	TRIPPED ON FAULT
2161	11-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	13:20	13:28	00:07	TRIPPED ON FAULT
2162	11-Dec-24	MYSORE	66	LINE	SANTHE SARAGURU-B MATTIGERE	B MATKERE_66	04:29	04:41	00:11	TRIPPED ON FAULT
2163	11-Dec-24	MYSORE	66	LINE	SANTHE SARAGURU-SUBHASH LINE 1	NO STATIONS EFFECTED	04:30	08:00	03:30	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2164	11-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 1	NO STATIONS EFFECTED	16:30 (7/12/2024)	18:24 (11/12/2024)	121:54 HRS	LINE CLEAR AVAILED
2165	11-Dec-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 2	NO STATIONS EFFECTED	16:30 (7/12/2024)	18:26 (11/12/2024)	121:56 HRS	LINE CLEAR AVAILED
2166	11-Dec-24	MYSORE	66	LINE	SHIVALLI-NAGAMANAGALA	NAGAMANGALA_66	18:05	18:20	00:15	TRIPPED ON FAULT
2167	11-Dec-24	MYSORE	220	LINE	TUBINKERE-KOTTIPURA	NO STATIONS EFFECTED	8:38 (8/12/2024)	13:24 (11/12/2024)	100:46 HRS	TRIPPED ON FAULT
2168	11-Dec-24	MYSORE	66	LINE	YARAHALLI HAND POST-SANTHE SARGURU	YERALLI HAND POST_66	10:15	12:15	02:00	LINE CLEAR AVAILED
2169	11-Dec-24	TUMKUR	66	TRANSFORMER	20 MVA TR-1	220KV ANTHARASANAHALLI	0:28	1:52	1:24	LINE CLEAR AVAILED
2170	11-Dec-24	TUMKUR	110	TRANSFORMER	20 MVA TR-1	K B CROSS_220	15:28	15:56	0:28	LINE CLEAR AVAILED
2171	11-Dec-24	TUMKUR	66	TRANSFORMER	20 MVA TR-3	220KV ANTHARASANAHALLI	0:28	1:43	1:15	LINE CLEAR AVAILED
2172	11-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	NIL (IDLE LINE)	19:14	19:25	0:11	TRIPPED ON FAULT
2173	11-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV PALLAGATES/S , SOKKE, BILICHODU	4:50	5:05	0:15	TRIPPED ON FAULT
2174	11-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV PALLAGATES/S , SOKKE, BILICHODU	13:35	13:45	0:10	TRIPPED ON FAULT
2175	11-Dec-24	TUMKUR	66	LINE	66KV SIRIGERE- CHITRADURGA	66KV SIRIGERE	10:15	10:46	0:31	LINE CLEAR AVAILED
2176	11-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA- PONDARAHALLI-1	BHARAMASAGARA_66	10:00	16:05	6:05	LINE CLEAR AVAILED
2177	11-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2178	11-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2179	11-Dec-24	TUMKUR	66	LINE	SANTHEBENNUR- KEREBILCHI	66KV KEREILCHI	9:55	10:05	0:10	MAIN SUPPLY FAILURE
2180	11-Dec-24	TUMKUR	66	LINE	SHAGALE_66- KEREBILCHI_66	KEREILACHI, KNNL WW	9:55	10:05	0:10	LINE CLEAR AVAILED
2181	11-Dec-24	TUMKUR	66	LINE	SIRA220-KIADB 2(KALLAMBELLA)	66KV KALLAMBELLA	18:56	19:02	0:06	TRIPPED ON FAULT
2182	11-Dec-24	TUMKUR	66	LINE	SIRA220-KIADB 2(KALLAMBELLA)	66KV KALLAMBELLA	22:11	22:16	0:05	TRIPPED ON FAULT
2183	11-Dec-24	TUMKUR	66	LINE	SIRA220-KIADB 2(KALLAMBELLA)	66KV KALLAMBELLA	23:04	23:20	0:16	TRIPPED ON FAULT
2184	11-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 , 2, 3 LINE	66KV SIRA	13:23	14:20	0:57	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2185	11-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	3:40	3:45	0:05	TRIPPED ON FAULT
2186	11-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	15:00	15:10	0:10	TRIPPED ON FAULT
2187	11-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	MYLANAHALLI_66	16:15	17:10	0:55	LINE CLEAR AVAILED
2188	11-Dec-24	TUMKUR	110	TRANSFORMER	TR1 20MVA	KBCROSS_220	15:28	15:56	0:28	LINE CLEAR AVAILED
2189	11-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	NOT YET CHARGED		TRIPPED ON FAULT
2190	11-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5	KUKKAWADA_66	9:55	10:00	0:05	TRIPPED ON FAULT
2191	11-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	BILCHODU_66	10:50	11:00	0:10	TRIPPED ON FAULT
2192	11-Dec-24	TUMKUR	66	LINE	VIJAPURA- DAVANAGERE_66	BHARAMASAGARA_66, SIRIGERE_66	10:15	10:46	0:31	LINE CLEAR AVAILED
2193	12-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11,HV2(20MVA)	KULAGERI CROSS_110	11:52	12:06	0:14	TRIPPED ON FAULT
2194	12-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA- HV2)	MORATAGI_110	13:25	13:30	0:05	TRIPPED ON FAULT
2195	12-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULAGERI CROSS_110	11:42	17:01	5:19	LINE CLEAR AVAILED
2196	12-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA)	HUBLI_220	10:35	17:13	6:38	LINE CLEAR AVAILED
2197	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BIDNAL_220	9:27	12:53	3:26	LINE CLEAR AVAILED
2198	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	BAGALKOT_220	16:04	18:15	2:11	LINE CLEAR AVAILED
2199	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	GADAG_220	9:58	21:32	11:34	LINE CLEAR AVAILED
2200	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2(HV4)	GADAG_220	16:57	19:56	2:59	LINE CLEAR AVAILED
2201	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	GADAG_220	21:02	22:05	1:03	LINE CLEAR AVAILED
2202	12-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV1	BIDNAL_220	9:27	12:57	3:30	LINE CLEAR AVAILED
2203	12-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	BAGALKOT_220	16:04	18:16	2:12	LINE CLEAR AVAILED
2204	12-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	GADAG_220	9:58	21:33	11:35	LINE CLEAR AVAILED
2205	12-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2(LV4)	GADAG_220	16:57	19:56	2:59	LINE CLEAR AVAILED
2206	12-Dec-24	BAGALKOTE	110	LINE	ATHANI220- AIGALI1	ATHANI_220	21:53	22:06	0:13	TRIPPED ON FAULT
2207	12-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
2208	12-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
2209	12-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2210	12-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2211	12-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2212	12-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)			LINE CLEAR AVAILED
2213	12-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- BANAHATTI	MAHALINGAPUR_220	10:46	10:50	0:04	LINE CLEAR AVAILED
2214	12-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2215	12-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2216	12-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
2217	12-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2218	12-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_110	15:30 (09.12.2024)	17:18 (12.12.2024)	73:48:00	LINE CLEAR AVAILED
2219	12-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2220	12-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	TUBINAKERE 220	08:06	08:50	00:44	TRIPPED ON FAULT
2221	12-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2222	12-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2223	12-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2224	12-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
2225	12-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:19	10:21	00:02	LINE CLEAR AVAILED
2226	12-Dec-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	14:45	15:39	00:54	LINE CLEAR AVAILED
2227	12-Dec-24	BANGALORE	66	LINE	66KV GURUVINAPURA - BV HALLI	BV HALLI	10:03	15:06	05:03	LINE CLEAR AVAILED
2228	12-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	08:44	12:25	03:41	TRIPPED ON FAULT
2229	12-Dec-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	10:41	10:46	00:05	LINE CLEAR AVAILED
2230	12-Dec-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	16:05	16:25	00:20	LINE CLEAR AVAILED
2231	12-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	15:08	15:18	00:10	TRIPPED ON FAULT
2232	12-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	16:09	16:21	00:12	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2233	12-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:31	18:36	00:05	LINE CLEAR AVAILED
2234	12-Dec-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI	22:18	22:27	00:09	TRIPPED ON FAULT
2235	12-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, THIMMAMPALLI, GULUR	17:20	17:29	00:09	TRIPPED ON FAULT
2236	12-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - VIJAYANAGAR	NO STATION AFFECTED	10:27	17:36	07:09	LINE CLEAR AVAILED
2237	12-Dec-24	BANGALORE	66	LINE	66KV RBI - ELITA PROMENADE	RBI	17:33	17:38	00:05	LINE CLEAR AVAILED
2238	12-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	10:45	10:55	00:10	LINE CLEAR AVAILED
2239	12-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	10:28	10:36	00:08	LINE CLEAR AVAILED
2240	12-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI	10:23	10:27	00:04	LINE CLEAR AVAILED
2241	12-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST VIEW	15:51	15:58	00:07	LINE CLEAR AVAILED
2242	12-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	16:23	16:32	00:09	LINE CLEAR AVAILED
2243	12-Dec-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	13:25	15:10	01:45	LINE CLEAR AVAILED
2244	12-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GODUR	13:10	14:00	00:50	LINE CLEAR AVAILED
2245	12-Dec-24	BANGALORE	66	TRANSFORMER	HV1	PILLAGUMPA	15:15	15:28	00:13	TRIPPED ON FAULT
2246	12-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	10:07	17:46	07:39	LINE CLEAR AVAILED
2247	12-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BUDIGERE	15:12	15:24	00:12	TRIPPED ON FAULT
2248	12-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NARASAPURA	05:05	06:36	01:31	TRIPPED ON FAULT
2249	12-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	10:07	17:46	07:39	LINE CLEAR AVAILED
2250	12-Dec-24	BANGALORE	220	TRANSFORMER	HV3	SOMANAHALLI 220	10:40	14:23	03:43	LINE CLEAR AVAILED
2251	12-Dec-24	GULBARGA	110	LINE	BADALADAKU-APMC_IPP	BADALADKU_220	21:55	23:59	02:04	LINE CLEAR AVAILED
2252	12-Dec-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGI	BENNEHALLI_66	10:00(08.12.2024)			LINE CLEAR AVAILED
2253	12-Dec-24	GULBARGA	400	LINE	BTPS-RTPS	BTPS_400	06:10	09:30	03:20	TRIPPED ON FAULT
2254	12-Dec-24	GULBARGA	110	LINE	CHITAPUR-SEDAM	CHITAPUR_110	10:30(12.12.2024)			LINE CLEAR AVAILED
2255	12-Dec-24	GULBARGA	110	LINE	GURUMITKAL-SEDAM	GURUMITKAL_110	21:35	21:55	00:20	TRIPPED ON FAULT
2256	12-Dec-24	GULBARGA	110	TRANSFORMER	HV1	CHIKKASUGUR_110	07:52	09:24	01:32	LINE CLEAR AVAILED
2257	12-Dec-24	GULBARGA	110	TRANSFORMER	HV1	HANUMASAGAR_110	12:05	15:25	03:20	LINE CLEAR AVAILED
2258	12-Dec-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	10:03	17:45	07:42	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2259	12-Dec-24	GULBARGA	110	TRANSFORMER	HV1	SULEKAL_220	13:20	14:20	01:00	LINE CLEAR AVAILED
2260	12-Dec-24	GULBARGA	220	TRANSFORMER	HV1	SULEKAL_220	10:06	11:50	01:44	LINE CLEAR AVAILED
2261	12-Dec-24	GULBARGA	110	TRANSFORMER	HV1&2	MADLAPUR_110	09:20	17:20	08:00	LINE CLEAR AVAILED
2262	12-Dec-24	GULBARGA	110	TRANSFORMER	HV2	MANVI_110	10:03	17:45	07:42	LINE CLEAR AVAILED
2263	12-Dec-24	GULBARGA	220	TRANSFORMER	HV2	SEDAM_220	10:15(12.12.2024)			LINE CLEAR AVAILED
2264	12-Dec-24	GULBARGA	66	TRANSFORMER	HV3	MUNIRABAD_220	09:19	16:15	06:56	LINE CLEAR AVAILED
2265	12-Dec-24	GULBARGA	110	LINE	KHANAPUR-GONDEDAGI	GONDEDAGI_110	06:03	06:22	00:19	TRIPPED ON FAULT
2266	12-Dec-24	GULBARGA	110	LINE	KHANAPUR-GONDEDAGI	GONDEDAGI_110	11:07	18:00	06:53	LINE CLEAR AVAILED
			110	LINE	KHANAPUR-SHAHAPUR1&2	SHIRWAL_110, SANNATHI_IPP, KAHANAPUR RAILWAR_110, WADAGERA_110,	11:07	14:05	02:58	LINE CLEAR AVAILED
2267	12-Dec-24	GULBARGA	110	LINE	KURKUNTA-SEDAM	KURKUNTA_110	17:10	17:35	00:25	LINE CLEAR AVAILED
2268	12-Dec-24	GULBARGA	110	LINE	MALLAT -HINDUJA lpp	MALLAT_220	18:15	21:25	03:10	LINE CLEAR AVAILED
2269	12-Dec-24	GULBARGA	110	LINE	MALLAT -MADLAPUR	MANVI_110	10:20	15:00	04:40	LINE CLEAR AVAILED
2270	12-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILAKANAHATTI	CHILAKANAHATTI_66	09:17	17:34	08:17	LINE CLEAR AVAILED
2271	12-Dec-24	GULBARGA	66	LINE	MUNIRABAD-TIE LINE	MUNIRABAD_220	09:17	17:36	08:19	LINE CLEAR AVAILED
2272	12-Dec-24	GULBARGA	66	LINE	MUNIRABAD-U P HALLI	VENKATAPUR_66	09:17	16:59	07:42	LINE CLEAR AVAILED
2273	12-Dec-24	GULBARGA	110	LINE	MUNIRBAD-SANKALAPUR	SANKALAPUR_110, KAMALAPUR_110	10:25	15:23	04:58	LINE CLEAR AVAILED
2274	12-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
2275	12-Dec-24	GULBARGA	220	LINE	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	04:56	05:30	00:34	TRIPPED ON FAULT
2276	12-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	10:00	17:00	07:00	LINE CLEAR AVAILED
2277	12-Dec-24	HASAN	66	LINE	BALEHN-JENUGADDE1	BALEHONNUR_66	12:32	18:51	06:19	LINE CLEAR AVAILED
2278	12-Dec-24	HASAN	66	LINE	BALEHN-JENUGADDE2	BALEHONNUR_66	11:54	12:32	00:38	LINE CLEAR AVAILED
2279	12-Dec-24	HASAN	110	LINE	BANTWA-SALATTUR	BANTWAL_110	06:41	06:58	00:17	TRIPPED ON FAULT
2280	12-Dec-24	HASAN	110	LINE	GAJNUR-OUTGOING LINE	GAJANUR_110	16:56	17:54	00:58	LINE CLEAR AVAILED
2281	12-Dec-24	HASAN	66	LINE	HNPR2-HASS2	HOLENARASIPURA_220	10:05	19:27	09:22	LINE CLEAR AVAILED
2282	12-Dec-24	HASAN	66	LINE	HNPR2-HASS3	HOLENARASIPURA_220	10:30	10:37	00:07	LINE CLEAR AVAILED
2283	12-Dec-24	HASAN	66	LINE	HNPR2-MYSOR2	HOLENARASIPURA_220	11:24	11:26	00:02	LINE CLEAR AVAILED
2284	12-Dec-24	HASAN	66	TRANSFORMER	HV1	MALALI_66	10:00	19:35	09:35	LINE CLEAR AVAILED
2285	12-Dec-24	HASAN	110	TRANSFORMER	HV2	BEJAI_110	10:00	14:00	04:00	MAIN SUPPLY FAILURE
2286	12-Dec-24	HASAN	110	TRANSFORMER	HV2	KONAJE_110	06:41	07:01	00:20	MAIN SUPPLY FAILURE
2287	12-Dec-24	HASAN	110	LINE	KAVOOR-BEJAI	KAVOOR_220	14:15	18:12	03:57	LINE CLEAR AVAILED
2288	12-Dec-24	HASAN	110	LINE	KEMAR-Manipal1	KEMAR_220	11:36	12:33	00:57	LINE CLEAR AVAILED
2289	12-Dec-24	HASAN	110	LINE	KEMAR-Manipal2	KEMAR_220	10:28	11:27	00:59	LINE CLEAR AVAILED
2290	12-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	17:31	17:42	00:11	TRIPPED ON FAULT
2291	12-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	17:31	17:42	00:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2292	12-Dec-24	HASAN	66	LINE	MALALICRPATNA	MALALI_66	10:00	19:35	09:35	LINE CLEAR AVAILED
2293	12-Dec-24	HASAN	66	LINE	MALALI-HASSAN	MALALI_66	10:00	19:30	09:30	LINE CLEAR AVAILED
2294	12-Dec-24	HASAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	09:45	14:54	05:09	LINE CLEAR AVAILED
2295	12-Dec-24	HASAN	110	LINE	MANIPAL-KEMAR1	MANIPAL_110	11:36	12:38	01:02	LINE CLEAR AVAILED
2296	12-Dec-24	HASAN	110	LINE	MANIPAL-KEMAR2	MANIPAL_110	10:39	11:28	00:49	LINE CLEAR AVAILED
2297	12-Dec-24	HASAN	110	LINE	MANIPAL-NITTUR	MANIPAL_110	09:32	14:48	05:16	LINE CLEAR AVAILED
2298	12-Dec-24	HASAN	110	LINE	MRSSHM-SS2	MRSMG_220	09:32	13:13	03:41	LINE CLEAR AVAILED
2299	12-Dec-24	HASAN	110	LINE	NANDIKU-BELMAN	NANDIKUR_110	10:39	16:30	05:51	LINE CLEAR AVAILED
2300	12-Dec-24	HASAN	220	LINE	SHRAVTY-TALAGUPPA 2	sharavathy_gen	15:35	18:14	02:39	LINE CLEAR AVAILED
2301	12-Dec-24	HASAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	15:32	17:26	01:54	LINE CLEAR AVAILED
2302	12-Dec-24	HASAN	66	LINE	SINGAP-KACHENALLI	SINGAPURA_66	09:52	16:56	07:04	LINE CLEAR AVAILED
2303	12-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	08:40	09:15	00:35	LINE CLEAR AVAILED
2304	12-Dec-24	HASAN	220	LINE	TALAGU-SGS2	TALAGUPPA_400	15:35	18:14	02:39	LINE CLEAR AVAILED
2305	12-Dec-24	MYSORE	66	LINE	BG PURA-CHANDALLI	CHANDALLI_66	15:18	16:46	01:27	LINE CLEAR AVAILED
2306	12-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
2307	12-Dec-24	MYSORE	66	LINE	CHIKKAMANDYA-MANDYA	NO STATIONS EFFECTED	14:16	17:51	03:34	LINE CLEAR AVAILED
2308	12-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
2309	12-Dec-24	MYSORE	66	LINE	HARAVE-KABBALLI	NO STATIONS EFFECTED	10:04	10:11	00:07	TRIPPED ON FAULT
2310	12-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
2311	12-Dec-24	MYSORE	66	TRANSFORMER	HV1	CHIDRAVALLI_66	10:00	17:00	07:00	LINE CLEAR AVAILED
2312	12-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	23:40 (12/12/2024)			TRIPPED ON FAULT
2313	12-Dec-24	MYSORE	66	TRANSFORMER	HV1	GARGESHWARI_66	10:00	16:30	06:30	LINE CLEAR AVAILED
2314	12-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2315	12-Dec-24	MYSORE	66	TRANSFORMER	HV1	THUMBLA_66	10:00	17:00	07:00	LINE CLEAR AVAILED
2316	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	CHIDRAVALLI_66	10:00	17:00	07:00	LINE CLEAR AVAILED
2317	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	GARGESHWARI_66	10:00	16:30	06:30	LINE CLEAR AVAILED
2318	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	KIRUGAVALU_66	14:54	18:13	03:18	LINE CLEAR AVAILED
2319	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	11:03	16:07	05:03	LINE CLEAR AVAILED
2320	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	17:36	17:45	00:09	LINE CLEAR AVAILED
2321	12-Dec-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	10:00	17:00	07:00	LINE CLEAR AVAILED
2322	12-Dec-24	MYSORE	66	LINE	K.K DODDI-MANDYA KIADB	KIADBMANDYA_66	09:53	13:29	03:35	LINE CLEAR AVAILED
2323	12-Dec-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	11:36	13:21	01:44	LINE CLEAR AVAILED
2324	12-Dec-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	11:10	13:18	02:08	LINE CLEAR AVAILED
2325	12-Dec-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	10:07	16:35	06:28	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2326	12-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2327	12-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2328	12-Dec-24	MYSORE	66	LINE	KAMPLAPURA-PERIYAPATNA	PERIYAPATNA_66	10:35	15:40	05:05	LINE CLEAR AVAILED
2329	12-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2330	12-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2331	12-Dec-24	MYSORE	66	LINE	KUSHALANAGARA 220-PERIYAPATNA-1	PERIYAPATNA_66	10:04	17:11	07:07	LINE CLEAR AVAILED
2332	12-Dec-24	MYSORE	66	LINE	KUSHALANAGARA 220-PERIYAPATNA-2	BYLUKUPPE_66	10:04	17:12	07:07	LINE CLEAR AVAILED
2333	12-Dec-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	NO STATIONS EFFECTED	04:45	04:52	00:07	TRIPPED ON FAULT
2334	12-Dec-24	MYSORE	66	LINE	MAMBALLI-YELANDURU	YELANDUR_66	15:47	15:52	00:05	TRIPPED ON FAULT
2335	12-Dec-24	MYSORE	66	LINE	MANDYA KIADB-TUMBEKERE	TUMBEKERE_66	09:52	15:04	05:12	LINE CLEAR AVAILED
2336	12-Dec-24	MYSORE	66	LINE	MANDYA-MANDYA M4	NO STATIONS EFFECTED	14:21	17:47	03:26	LINE CLEAR AVAILED
2337	12-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI 1	NO STATIONS EFFECTED	08:17	08:54	00:37	LINE CLEAR AVAILED
2338	12-Dec-24	MYSORE	66	LINE	SFC SIVA-HEBBANI 2	NO STATIONS EFFECTED	08:17	08:54	00:36	LINE CLEAR AVAILED
2339	12-Dec-24	MYSORE	220	LINE	TUBINAKERE-CHANNAPATNA	NO STATIONS EFFECTED	08:06	08:50	00:44	TRIPPED ON FAULT
2340	12-Dec-24	MYSORE	66	LINE	VYASARAJAPURA-GARGESHWARI	GARGESHWARI_66	10:00	17:05	07:05	LINE CLEAR AVAILED
2341	12-Dec-24	MYSORE	66	LINE	VYASARAJAPURA-THUMBLA	VYASRAJPURA_66	10:00	17:05	07:05	LINE CLEAR AVAILED
2342	12-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA TR 2 SIRA	SIRA_220	21:49	22:06	0:17	TRIPPED ON FAULT
2343	12-Dec-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR1	BILCHODU_66	16:50	16:55	0:05	TRIPPED ON FAULT
2344	12-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,C HILUR	9:09	9:19	0:10	TRIPPED ON FAULT
2345	12-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV HALURAMESHWARA LINE-1	66KV HALRAMESHWARA,MADA DAKERE	6:00	6:15	0:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2346	12-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	5:45	5:55	0:10	TRIPPED ON FAULT
2347	12-Dec-24	TUMKUR	66	LINE	66KVHOLALKERE LINE-2 I/C LINE	66KV CHICKJAJUR, RAMGIRI	15:25	15:45	0:20	TRIPPED ON FAULT
2348	12-Dec-24	TUMKUR	66	TRANSFORMER	8 MVA TR 1	PULAMAGHATTA_66	12:40	12:50	0:10	LINE CLEAR AVAILED
2349	12-Dec-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66 CHELURU_66,	12:45	12:55	0:10	TRIPPED ON FAULT
2350	12-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-CHELUR	HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	9:42	16:20	6:38	LINE CLEAR AVAILED
2351	12-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	66kv ANAGODU, ATTIGERE	11:22	11:36	0:14	LINE CLEAR AVAILED
2352	12-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV MAYAKONDA LINE	MAYAKONDA_66, SASALUHALLA_66, CHIKKAJAJUR_66	11:22	11:38	0:16	LINE CLEAR AVAILED
2353	12-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV MELLEKATTE LINE	66KV MELLEKATTE , KADAJJI	11:22	11:38	0:16	LINE CLEAR AVAILED
2354	12-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2355	12-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2356	12-Dec-24	TUMKUR	66	LINE	KORATAGERE-MADHUGIRI2	KORATAGERE_66	19:50	20:05	0:15	TRIPPED ON FAULT
2357	12-Dec-24	TUMKUR	66	LINE	PANDARAHALLI-HOLALKERE	PANDARAHALLY_66	15:52	16:02	0:10	MAIN SUPPLY FAILURE
2358	12-Dec-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	21:57	22:07	0:10	LINE CLEAR AVAILED
2359	12-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BTRAHMASANDRA	3:05	3:15	0:10	TRIPPED ON FAULT
2360	12-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BTRAHMASANDRA	17:31	18:06	0:35	TRIPPED ON FAULT
2361	12-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BTRAHMASANDRA	19:11	19:17	0:06	TRIPPED ON FAULT
2362	12-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BTRAHMASANDRA	21:49	22:16	0:27	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2363	12-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 2 (KIADB-2)	66KV O/G LINES BUKKAPTANA & TAVREKERE LINES HT TO REDUCE THE LOAD	21:49	22:16	0:27	TRIPPED ON FAULT
2364	12-Dec-24	TUMKUR	66	LINE	SIRA220-TAVAREKERE	TAVAREKERE_66	21:57	22:16	0:19	LINE CLEAR AVAILED
2365	12-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA PULAMAGHATTA_66	PULAMAGHATTA_66	4:10 (23.10.2024)	17:30 (12.12.2024)	19 DAYS 5:20 hrs	TRIPPED ON FAULT
2366	13-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MORATAGI_110	06:40	06:45	0:05	TRIPPED ON FAULT
2367	13-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MORATAGI_110	08:05	08:10	0:05	TRIPPED ON FAULT
2368	13-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	HUKKERI_110	09:18	09:24	0:06	TRIPPED ON FAULT
2369	13-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(10MVA-HV2)	GAJENDRAGAD_110	11:48	17:15	5:27	LINE CLEAR AVAILED
2370	13-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	MUNAVALLI_110	14:40	15:00	0:20	TRIPPED ON FAULT
2371	13-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2372	13-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2373	13-Dec-24	BAGALKOTE	110	LINE	ATHANI220-ATHANI	ATHANI_220	10:58	11:02	0:04	TRIPPED ON FAULT
2374	13-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F10-KALADAGI	BAGALKOT_220	11:05	11:23	0:18	LINE CLEAR AVAILED
2375	13-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F3-NAVANAGAR-1	BAGALKOT_220	11:06	11:23	0:17	LINE CLEAR AVAILED
2376	13-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F5-GULEDGUDDA	BAGALKOT_220	11:06	11:24	0:18	LINE CLEAR AVAILED
2377	13-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
2378	13-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
2379	13-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2380	13-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2381	13-Dec-24	BAGALKOTE	110	LINE	KERUR-BAGALKOT	KERUR_110	10:15 (13.12.2024)			LINE CLEAR AVAILED
2382	13-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2383	13-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS-KERUR	STATION NOT AFFECTED KULAGERI CROSS_110	13:39 (3.12.2024)	10:24 (13.12.2024)	236:45:00	LINE CLEAR AVAILED
2384	13-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2385	13-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2386	13-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-AREMALLAPUR(HONNATTI)	RANEENNUR_220	09:45	19:31	9:46	LINE CLEAR AVAILED
2387	13-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-HIREKERUR	RANEENNUR_220	18:43	18:46	0:03	LINE CLEAR AVAILED
2388	13-Dec-24	BAGALKOTE	110	LINE	RANEENNUR220-RATTIHALLI (TUMMINAKTTE)	RANEENNUR_220	18:43	18:46	0:03	LINE CLEAR AVAILED
2389	13-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
2390	13-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2391	13-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2392	13-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220-VAJRAMATTI	VAJRAMATTI_220	15:22	17:19	1:57	LINE CLEAR AVAILED
2393	13-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2394	13-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2395	13-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2396	13-Dec-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 - CKT 1	VIKAS TECH PARK 220	08:30	11:55	03:25	LINE CLEAR AVAILED
2397	13-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
2398	13-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE	12:53	12:57	00:04	LINE CLEAR AVAILED
2399	13-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ATTUR YELAHANKA, ABBIGERE, WELCAST	13:28	14:33	01:05	LINE CLEAR AVAILED
2400	13-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:08	10:13	00:05	LINE CLEAR AVAILED
2401	13-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	08:18	12:21	04:03	TRIPPED ON FAULT
2402	13-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISC	01:22	01:46	00:24	TRIPPED ON FAULT
2403	13-Dec-24	BANGALORE	66	LINE	66KV IRGAMPALLI - M GOLLAHALLI	M GOLLAHALLI	14:35	15:45	01:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2404	13-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	HAROBEL, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNASENAHALLI	07:20	07:30	00:10	TRIPPED ON FAULT
2405	13-Dec-24	BANGALORE	66	LINE	66KV KEMBODI - MUDIYANUR TAP POINT	NO STATION AFFECTED	11:40	12:05	00:25	LINE CLEAR AVAILED
2406	13-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	13:57	17:13	03:16	LINE CLEAR AVAILED
2407	13-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN-2	NO STATION AFFECTED	13:27	17:13	03:46	TRIPPED ON FAULT
2408	13-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - CHIKKENAHALLI LINK	SHIVANAHALLI 66	10:03	10:10	00:07	TRIPPED ON FAULT
2409	13-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	KENGERI SATELLITE TOWN MASTHENAHALLI,	10:58	12:08	01:10	TRIPPED ON FAULT
2410	13-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	TALAGAWARA, CHEEMANGALA	18:15	18:20	00:05	LINE CLEAR AVAILED
2411	13-Dec-24	BANGALORE	66	LINE	66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)	BEST STEELS(EHT)	00:50	21:17	20:27	TRIPPED ON FAULT
2412	13-Dec-24	BANGALORE	66	LINE	66KV MEI LAYOUT - WIDIA	NO STATION AFFECTED	15:29	17:49	02:20	TRIPPED ON FAULT
2413	13-Dec-24	BANGALORE	66	LINE	66KV MELEHALLI - JALAMANGALA	JALAMANGALA, CHIKKAGANGANAWADI, KUTAGAL	16:46	16:56	00:10	TRIPPED ON FAULT
2414	13-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAILWHEEL AND AXLE SECORTES - ATTURU DG4	ATTUR YELAHANKA, ABBIGERE, WELCAST	11:12	12:54	01:42	LINE CLEAR AVAILED
2415	13-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASANUR	YELDUR, DALASANUR, MALLASANDRA	06:57	07:15	00:18	TRIPPED ON FAULT
2416	13-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELCAST	15:09	15:12	00:03	LINE CLEAR AVAILED
2417	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	VIKAS TECH PARK 220	08:30	08:40	00:10	LINE CLEAR AVAILED
2418	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	VIKAS TECH PARK 220	12:05	12:08	00:03	LINE CLEAR AVAILED
2419	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	VIKAS TECH PARK 220	08:30	08:40	00:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2420	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	VIKAS TECH PARK 220	12:05	12:08	00:03	LINE CLEAR AVAILED
2421	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	08:23	08:48	00:25	MAIN SUPPLY FAILURE
2422	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	12:05	12:08	00:03	LINE CLEAR AVAILED
2423	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	08:23	08:48	00:25	MAIN SUPPLY FAILURE
2424	13-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	12:05	12:08	00:03	LINE CLEAR AVAILED
2425	13-Dec-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	ABBIGERE	14:35	14:39	00:04	LINE CLEAR AVAILED
2426	13-Dec-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	WELCAST	12:48	12:51	00:03	LINE CLEAR AVAILED
2427	13-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	20:51	20:58	00:07	LINE CLEAR AVAILED
2428	13-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYA CITY	20:52	21:00	00:08	LINE CLEAR AVAILED
2429	13-Dec-24	BANGALORE	66	LINE	AVERAHALLI 66kV - T BEGUR	T BEGUR	11:10	14:57	03:47	LINE CLEAR AVAILED
2430	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ATTUR YELAHANKA	11:12	17:20	06:08	LINE CLEAR AVAILED
2431	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ATTUR YELAHANKA	18:30	19:20	00:50	LINE CLEAR AVAILED
2432	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	15:00	15:17	00:17	LINE CLEAR AVAILED
2433	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HOSKOTE 66	12:40	13:05	00:25	LINE CLEAR AVAILED
2434	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KEMBODI	13:10	13:15	00:05	LINE CLEAR AVAILED
2435	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	M GOLLAHALLI	00:05	00:25	00:20	TRIPPED ON FAULT
2436	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANCHENAHALLI	13:25	13:40	00:15	TRIPPED ON FAULT
2437	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR_66	10:40	10:50	00:10	TRIPPED ON FAULT
2438	13-Dec-24	BANGALORE	66	TRANSFORMER	HV1	T BEGUR	09:55	23:59	14:04	LINE CLEAR AVAILED
2439	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTUR YELAHANKA	11:12	17:05	05:53	LINE CLEAR AVAILED
2440	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTUR YELAHANKA	17:40	17:46	00:06	LINE CLEAR AVAILED
2441	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HEJJALA	12:35	13:10	00:35	LINE CLEAR AVAILED
2442	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HOSKOTE 66	16:50	17:15	00:25	LINE CLEAR AVAILED
2443	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	K&C VALLEY	09:55	10:20	00:25	LINE CLEAR AVAILED
2444	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KEMBODI	10:35	10:40	00:05	LINE CLEAR AVAILED
2445	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MANCHENAHALLI	13:05	13:20	00:15	TRIPPED ON FAULT
2446	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NALLIMARADANAHALLI	15:15	15:30	00:15	TRIPPED ON FAULT
2447	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAMAKA	10:50	11:05	00:15	LINE CLEAR AVAILED
2448	13-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	20:47	20:56	00:09	LINE CLEAR AVAILED
2449	13-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	20:52	20:56	00:04	LINE CLEAR AVAILED
2450	13-Dec-24	GULBARGA	66	LINE	BADALADUKU-ACME SOLAR IPP	ACME SOLAR IPP	21:55(12.12.2024)	1:45(13.12.2024)	03:50	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2451	13-Dec-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGI	BENNEHALLI_66	10:00(08.12.2024)	16:00(13.12.2024)	118 HRS	LINE CLEAR AVAILED
2452	13-Dec-24	GULBARGA	110	LINE	BHALKI-LADHA	LADHA_110	10:20	15:15	04:55	LINE CLEAR AVAILED
2453	13-Dec-24	GULBARGA	220	LINE	FEROZABAD-NIMBARGA2	NIMBARGA_220	00:03	07:11	07:08	LINE CLEAR AVAILED
2454	13-Dec-24	GULBARGA	220	LINE	FEROZABAD-SHAHAPUR2	SHAHAPUR_220	00:02	07:09	07:07	LINE CLEAR AVAILED
2455	13-Dec-24	GULBARGA	110	LINE	GANADAL-NAVALI	NAVALI_110	04:30	04:40	00:10	MAIN SUPPLY FAILURE
2456	13-Dec-24	GULBARGA	110	LINE	HALAKUNDI-BELLARY SOUTH	HALAKUNDI_110	03:26	03:36	00:10	TRIPPED ON FAULT
2457	13-Dec-24	GULBARGA	110	LINE	HALBARGA-BHALAKI	BHALAKI_110	13:20	22:35	09:15	LINE CLEAR AVAILED
2458	13-Dec-24	GULBARGA	220	LINE	HATTIGUDUR-FIROZABAD-2	HATTIGUDUR_220	00:03	07:09	07:06	LINE CLEAR AVAILED
2459	13-Dec-24	GULBARGA	220	TRANSFORMER	HV1	KAPNOOR_220	11:50	12:46	00:56	LINE CLEAR AVAILED
2460	13-Dec-24	GULBARGA	220	TRANSFORMER	HV2	SULEKAL_220	15:15	17:55	02:40	LINE CLEAR AVAILED
2461	13-Dec-24	GULBARGA	110	LINE	KUSTAGT-KANAKAGIRI	GANADAL_110	04:30	04:39	00:09	TRIPPED ON FAULT
2462	13-Dec-24	GULBARGA	110	LINE	LINGASUGUR-LATHUR GAMESH_IPP	LINGASUGUR_220	09:50	18:15	08:25	LINE CLEAR AVAILED
2463	13-Dec-24	GULBARGA	110	LINE	MARGUTTI-SOLAR_IPP	MARGUTTI_110	13:57	15:20	01:23	LINE CLEAR AVAILED
2464	13-Dec-24	GULBARGA	110	LINE	RAICHUR-SINDHANUR 2	KURDI CROSS_110	10:55	13:25	02:30	LINE CLEAR AVAILED
2465	13-Dec-24	GULBARGA	110	LINE	YERDONA-MARALOHALLA	HANAWA_110,BENNUR_110	10:48	10:58	00:10	TRIPPED ON FAULT
2466	13-Dec-24	HASAN	110	LINE	DMKURK-HONNAVALI	DMKURKE_110	10:04	17:16	07:12	LINE CLEAR AVAILED
2467	13-Dec-24	HASAN	220	LINE	GERSOPA-SHIMOGA	gerusoppa_gen	11:25	16:17	04:52	LINE CLEAR AVAILED
2468	13-Dec-24	HASAN	66	LINE	HNPR2-HASS2	HOLENARASIPURA_220	11:05	12:02	00:57	LINE CLEAR AVAILED
2469	13-Dec-24	HASAN	110	LINE	HOSNGD-VTRG2	HOSANGADI_110	16:00	16:59	00:59	LINE CLEAR AVAILED
2470	13-Dec-24	HASAN	110	TRANSFORMER	HV1	DMKURKE_110	10:03	17:19	07:16	LINE CLEAR AVAILED
2471	13-Dec-24	HASAN	110	TRANSFORMER	HV1	GURUVAYANAKERE_110	10:08	11:31	01:23	LINE CLEAR AVAILED
2472	13-Dec-24	HASAN	220	TRANSFORMER	HV1	KADUR_220	11:04	12:53	01:49	LINE CLEAR AVAILED
2473	13-Dec-24	HASAN	66	TRANSFORMER	HV1	MALALI_66	11:05	12:05	01:00	MAIN SUPPLY FAILURE
2474	13-Dec-24	HASAN	66	TRANSFORMER	HV1	SALAGAME_66	10:03	17:08	07:05	LINE CLEAR AVAILED
2475	13-Dec-24	HASAN	110	TRANSFORMER	HV2	DMKURKE_110	10:03	17:20	07:17	LINE CLEAR AVAILED
2476	13-Dec-24	HASAN	66	TRANSFORMER	HV2	DUDDA_66	13:06	14:20	01:14	LINE CLEAR AVAILED
2477	13-Dec-24	HASAN	66	TRANSFORMER	HV2	SALAGAME_66	10:03	17:08	07:05	LINE CLEAR AVAILED
2478	13-Dec-24	HASAN	220	TRANSFORMER	HV2	SHIRALKOPPA_220	10:22	18:32	08:10	LINE CLEAR AVAILED
2479	13-Dec-24	HASAN	220	TRANSFORMER	HV3	KEMAR_220	09:12	14:11	04:59	LINE CLEAR AVAILED
2480	13-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
2481	13-Dec-24	HASAN	110	LINE	KAVOOR-KLSKR2	KAVOOR_220	17:20(13.12.2024)			TRIPPED ON FAULT
2482	13-Dec-24	HASAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	10:27	18:14	07:47	LINE CLEAR AVAILED
2483	13-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	17:47	17:57	00:10	TRIPPED ON FAULT
2484	13-Dec-24	HASAN	110	TRANSFORMER	LV2	SHIRALKOPPA_220	10:22	18:32	08:10	LINE CLEAR AVAILED
2485	13-Dec-24	HASAN	110	TRANSFORMER	LV3	KEMAR_220	09:13	14:11	04:58	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2486	13-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:05	12:05	01:00	MAIN SUPPLY FAILURE
2487	13-Dec-24	HASAN	66	LINE	MALALI-HASSAN	MALALI_66	11:05	12:05	01:00	MAIN SUPPLY FAILURE
2488	13-Dec-24	HASAN	66	LINE	MRSSHM-BD-1	MRSMSG_220	09:11	13:25	04:14	LINE CLEAR AVAILED
2489	13-Dec-24	HASAN	66	LINE	MRSSHM-BD-2	MRSMSG_220	13:35	16:48	03:13	LINE CLEAR AVAILED
2490	13-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY4	MRSMSG_220	14:25	19:10	04:45	TRIPPED ON FAULT
2491	13-Dec-24	HASAN	220	LINE	MRSSHM-STRP	MRSMSG_220	11:25	16:16	04:51	LINE CLEAR AVAILED
2492	13-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:27	18:11	07:44	LINE CLEAR AVAILED
2493	13-Dec-24	HASAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	10:03	17:08	07:05	LINE CLEAR AVAILED
2494	13-Dec-24	HASAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	10:02	17:06	07:04	LINE CLEAR AVAILED
2495	13-Dec-24	HASAN	220	LINE	SHRAVTY-SHIMOGA4	sharavathy_gen	14:25	19:10	04:45	TRIPPED ON FAULT
2496	13-Dec-24	HASAN	110	LINE	SHRLKP-ANAVATTI	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2497	13-Dec-24	HASAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2498	13-Dec-24	HASAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2499	13-Dec-24	HASAN	110	LINE	SHRLKP-MAVALLI	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2500	13-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	09:47	18:48	09:01	LINE CLEAR AVAILED
2501	13-Dec-24	HASAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2502	13-Dec-24	HASAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:40	18:45	00:05	MAIN SUPPLY FAILURE
2503	13-Dec-24	HASAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	10:10	17:05	06:55	LINE CLEAR AVAILED
2504	13-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
2505	13-Dec-24	MYSORE	66	LINE	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	09:06	10:17	01:11	LINE CLEAR AVAILED
2506	13-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)			LINE CLEAR AVAILED
2507	13-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
2508	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	23:40 (12/12/2024)	00:40 (13/12/2024)	01:00HRS	TRIPPED ON FAULT
2509	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA(K)_66	10:40	14:30	03:50	LINE CLEAR AVAILED
2510	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	HARVEY_66	12:56	13:38	00:41	LINE CLEAR AVAILED
2511	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	12:30	15:47	03:17	LINE CLEAR AVAILED
2512	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	MEGALAPURA_66	12:04	13:25	01:21	LINE CLEAR AVAILED
2513	13-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2514	13-Dec-24	MYSORE	66	TRANSFORMER	HV2	HAMPAPURA(K)_66	10:40	14:30	03:50	LINE CLEAR AVAILED
2515	13-Dec-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	13:27	14:20	00:52	LINE CLEAR AVAILED
2516	13-Dec-24	MYSORE	66	LINE	JYOTHINAGARA-VAJAMANGALA	NO STATIONS EFFECTED	09:33	10:10	00:36	LINE CLEAR AVAILED
2517	13-Dec-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	08:14	14:27	06:13	LINE CLEAR AVAILED
2518	13-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2519	13-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2520	13-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2521	13-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2522	13-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI - KUNTHURU	NO STATIONS EFFECTED	13:41	13:46	00:05	TRIPPED ON FAULT
2523	13-Dec-24	MYSORE	66	LINE	RK NAGARA-KOPALUR(MANDAKALLI)	RKNAGARA_66	09:51	16:30	06:38	LINE CLEAR AVAILED
2524	13-Dec-24	MYSORE	66	LINE	TALAKADU-ADANI	NO STATIONS EFFECTED	08:38	08:44	00:05	TRIPPED ON FAULT
2525	13-Dec-24	MYSORE	66	LINE	VAJAMANGALA-DEVNURU(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	11:00	11:07	00:07	TRIPPED ON FAULT
2526	13-Dec-24	TUMKUR	66	LINE	TELIGI_66-KURUBARAHALLI_66	KURUBARAHALLI_66	6:25	9:30	3:05	MAIN SUPPLY FAILURE
2527	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8MVA TAVAREKERE_66(C)	TAVAREKERE_66	12:05	12:15	0:10	TRIPPED ON FAULT
2528	13-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV PALLAGATTE	SOKKE,PALLAGATTE	11:55	12:05	0:10	TRIPPED ON FAULT
2529	13-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220-66KV PANDARAHALLI LINE	SIRIGERE_66-CHITRADURGA_66,BHARA MASAGARA_66,VIJAPURA_66	9:15	10:10	0:55	LINE CLEAR AVAILED
2530	13-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220-66KV PANDARAHALLI LINE	SIRIGERE_66-CHITRADURGA_66,BHARA MASAGARA_66,VIJAPURA_66	15:30	16:20	0:50	LINE CLEAR AVAILED
2531	13-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2532	13-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2533	13-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 11KV	GUTUR_400	23:58:00	11:54	11:56	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2534	13-Dec-24	TUMKUR	66	LINE	GUTTUR 400kV-NARENDRA-1	NARENDRA -1 LINE	16:51	18:00	1:09	TRIPPED ON FAULT
2535	13-Dec-24	TUMKUR	66	LINE	K.B.CROSS_220KV-HANDANAKERE_110	SHETTYKERE,DODDANAGERE,MATTIGHATTA,HANDANKERE HULIYAR	16:51	18:00	1:09	TRIPPED ON FAULT
2536	13-Dec-24	TUMKUR	66	LINE	K.B.CROSS_220KV-HARIDASANAHALLI_110	HARIDASANAHALLI_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2537	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-BANDIHALLI(TIPTUR)	BANDIHALLI_110, TIPTUR_110, HALKURKE_110, HUNASEGHTT_110, KEREKODI_110, HONNAVALI_110, D M KURKE	11:55	16:50	4:55	LINE CLEAR AVAILED
2538	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110,KATHRIKEHALI_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2539	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV- HULIYUR	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2540	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALI_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2541	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-NELAMANGALA(ANTHARASANAHALLI)	KBCROSS_220	11:55	16:50	4:55	LINE CLEAR AVAILED
2542	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-NONAVINAKERE_110	NONAVINAKERE_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2543	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-SHIMOGA1	KBCROSS_220	11:55	16:50	4:55	LINE CLEAR AVAILED
2544	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV- TIPTUR	TIPTUR_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2545	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	11:55	16:50	4:55	LINE CLEAR AVAILED
2546	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	11:55	16:50	4:55	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2547	13-Dec-24	TUMKUR	66	LINE	KB CROSS 220kV-THIMMANAHALLI_110	C N HALLI_110, THIMMANAHALLI_110,KAT HRIKEHAL 110	11:55	16:50	4:55	LINE CLEAR AVAILED
2548	13-Dec-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66,TAVARE KERE 66	16:33	17:04	0:31	LINE CLEAR AVAILED
2549	13-Dec-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66,TAVARE KERE 66,	15:41	15:50	0:09	LINE CLEAR AVAILED
2550	13-Dec-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66,TAVARE KERE 66,	19:30	19:41	0:11	LINE CLEAR AVAILED
2551	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	15:41	15:50	0:09	LINE CLEAR AVAILED
2552	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	16:33	17:02	0:29	LINE CLEAR AVAILED
2553	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	19:38	19:41	0:03	LINE CLEAR AVAILED
2554	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 3 (KIADB-2)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	15:41	15:50	0:09	LINE CLEAR AVAILED
2555	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 3 (KIADB-2)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	16:33	17:02	0:29	LINE CLEAR AVAILED
2556	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 3 (KIADB-2)	66KV KIADB, KALLAMBELLA, BRAHMASANDRA	19:38	19:41	0:03	LINE CLEAR AVAILED
2557	13-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 LINE 1	KIADB ,KALLAMBELLA	2:25	2:38	0:13	TRIPPED ON FAULT
2558	13-Dec-24	TUMKUR	66	LINE	THOVINAKERE66- TMTP	THOVINAKERE_66	12:05	12:45	0:40	LINE CLEAR AVAILED
2559	13-Dec-24	TUMKUR	110	TRANSFORMER	TR-1 10MVA AMMASANDRA_110	AMMASANDRA_110	13:08	13:10	0:02	TRIPPED ON FAULT
2560	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA JAGALUR_66	JAGALUR_66	6:20	6:25	0:05	TRIPPED ON FAULT
2561	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA MYLANAHALLI_66	MYLANAHALLI_66	4:30	17:10	12:40	LINE CLEAR AVAILED
2562	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA THOVINAKERE_66	THOVINAKERE_66	12:10	13:20	1:10	LINE CLEAR AVAILED
2563	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 20MVA THOVINAKERE_66	THOVINAKERE_66	11:40	12:45	1:05	LINE CLEAR AVAILED
2564	13-Dec-24	TUMKUR	220	TRANSFORMER	TR2 100MVA HV SIDE SIRA_220KV	O/G LINES SIRA 66,BUKKAPATTANA, TAVAREKERE	16:34	19:14	2:40	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2565	13-Dec-24	TUMKUR	66	TRANSFORMER	TR2 100MVA LV SIDE SIRA_220KV	O/G LINES SIRA 66,BUKKAPATTANA, TAVAREKERE	15:42	15:50	0:08	LINE CLEAR AVAILED
2566	13-Dec-24	TUMKUR	66	TRANSFORMER	TR2 100MVA LV SIDE SIRA_220KV	O/G LINES SIRA 66,BUKKAPATTANA, TAVAREKERE	16:34	19:14	2:40	LINE CLEAR AVAILED
2567	13-Dec-24	TUMKUR	220	TRANSFORMER	TR2 100MVA SIRA_220KV	O/G LINES SIRA 66,BUKKAPATTANA, TAVAREKERE	2:25	2:38	0:13	TRIPPED ON FAULT
2568	13-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVAJAVAGONDANAH ALLI 66	JAVAGONDANAHALLI_66	4:30	6:00	1:30	TRIPPED ON FAULT
2569	13-Dec-24	TUMKUR	66	LINE	TURUVANUR_66KV-CHITRADURGA220	TURUVANUR_66KV	6:32	6:37	0:05	TRIPPED ON FAULT
2570	14-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	DADDI_110	10:23	11:59	1:36	LINE CLEAR AVAILED
2571	14-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MUDALAGI_110	11:25	13:20	1:55	LINE CLEAR AVAILED
2572	14-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2573	14-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2574	14-Dec-24	BAGALKOTE	110	LINE	ALNAVAR-RAILWAY	ALNAVAR_110	18:03	18:08	0:05	LINE CLEAR AVAILED
2575	14-Dec-24	BAGALKOTE	110	LINE	BYADAGI-RAILWAY	BYADAGI_110	15:25	15:30	0:05	TRIPPED ON FAULT
2576	14-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
2577	14-Dec-24	BAGALKOTE	110	LINE	HALIYAL-ALNAVAR	HALIYAL(ATHANI)_110	10:36	17:50	7:14	LINE CLEAR AVAILED
2578	14-Dec-24	BAGALKOTE	110	LINE	HALIYAL-ALNAVAR	HALIYAL(ATHANI)_110	17:53	17:58	0:05	LINE CLEAR AVAILED
2579	14-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
2580	14-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2581	14-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2582	14-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2583	14-Dec-24	BAGALKOTE	110	LINE	KUDACHI220-SHIRAGUPPI	KUDACHI_220	05:10	05:30	0:20	TRIPPED ON FAULT
2584	14-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2585	14-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN10(KULIGOD)	MUGALKHOD_220	13:31	13:44	0:13	TRIPPED ON FAULT
2586	14-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2587	14-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
2588	14-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2589	14-Dec-24	BAGALKOTE	110	LINE	TIRKARSHIGIHALLI-KITTUR	TIRKARSHIGIHALLI_110	00:40	01:00	0:20	TRIPPED ON FAULT
2590	14-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2591	14-Dec-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	11:41	15:14	03:33	LINE CLEAR AVAILED
2592	14-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2593	14-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2594	14-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2595	14-Dec-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	NO STATION AFFECTED	16:42	17:10	00:28	LINE CLEAR AVAILED
2596	14-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
2597	14-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAWARA, VANDARAGUPPE	13:31	13:34	00:03	LINE CLEAR AVAILED
2598	14-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:12	10:17	00:05	LINE CLEAR AVAILED
2599	14-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	TADIGOL CROSS	17:57	18:07	00:10	TRIPPED ON FAULT
2600	14-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	TADIGOL CROSS	18:34	18:48	00:14	TRIPPED ON FAULT
2601	14-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGMANE TECH PARK	11:44	11:48	00:04	LINE CLEAR AVAILED
2602	14-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGMANE TECH PARK	14:50	14:52	00:02	LINE CLEAR AVAILED
2603	14-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADUBISANAHALLI (TAP)	KADUBISANAHALLI	11:44	11:48	00:04	LINE CLEAR AVAILED
2604	14-Dec-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADUBISANAHALLI (TAP)	KADUBISANAHALLI	14:50	14:52	00:02	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2605	14-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	LR BANDE	20:28	20:35	00:07	LINE CLEAR AVAILED
2606	14-Dec-24	BANGALORE	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	09:15	09:20	00:05	LINE CLEAR AVAILED
2607	14-Dec-24	BANGALORE	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	NO STATION AFFECTED	10:51	16:14	05:23	LINE CLEAR AVAILED
2608	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACHALU	ACHALU, HONNIGANAHALLI, HALAGURU	07:58	08:53	00:55	TRIPPED ON FAULT
2609	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	CHIKKENAHALLI, ALLIMARADANAHALLI	07:58	08:18	00:20	MAIN SUPPLY FAILURE
2610	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA	CHATRA, MARALWADI, MANIYAMBAL, GODUR	07:58	08:19	00:21	MAIN SUPPLY FAILURE
2611	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	07:58	08:18	00:20	MAIN SUPPLY FAILURE
2612	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALLI, HUNASENAHALLI, BIJJAHALLI	07:58	08:18	00:20	MAIN SUPPLY FAILURE
2613	14-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI KMF, DODDALAHALLI	07:58	08:18	00:20	MAIN SUPPLY FAILURE
2614	14-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA	10:15	13:39	03:24	LINE CLEAR AVAILED
2615	14-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:16	18:31	00:15	LINE CLEAR AVAILED
2616	14-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	NO STATION AFFECTED	11:20	11:30	00:10	TRIPPED ON FAULT
2617	14-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	22:24	22:27	00:03	LINE CLEAR AVAILED
2618	14-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO	10:01	14:08	04:07	LINE CLEAR AVAILED
2619	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	C STATION 66	06:10	06:15	00:05	LINE CLEAR AVAILED
2620	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	12:20	15:00	02:40	LINE CLEAR AVAILED
2621	14-Dec-24	BANGALORE	220	TRANSFORMER	HV1	CHANNAPATNA 220	13:42	15:10	01:28	LINE CLEAR AVAILED
2622	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HAL 220	11:09	11:11	00:02	LINE CLEAR AVAILED
2623	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KEMPANAHALLI	12:15	12:25	00:10	TRIPPED ON FAULT
2624	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	19:16	19:31	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2625	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RAMANAGARA	10:15	15:48	05:33	LINE CLEAR AVAILED
2626	14-Dec-24	BANGALORE	66	TRANSFORMER	HV1	REMCO	10:01	14:08	04:07	LINE CLEAR AVAILED
2627	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTIBELE	06:10	06:15	00:05	LINE CLEAR AVAILED
2628	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	10:12	12:54	02:42	LINE CLEAR AVAILED
2629	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HAL 220	11:12	11:17	00:05	LINE CLEAR AVAILED
2630	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	RAMANAGARA	10:15	15:48	05:33	LINE CLEAR AVAILED
2631	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	REMCO	10:01	14:08	04:07	LINE CLEAR AVAILED
2632	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	T BEGUR	20:12	20:28	00:16	TRIPPED ON FAULT
2633	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	T BEGUR	00:18	05:00	04:42	TRIPPED ON FAULT
2634	14-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	17:15	17:30	00:15	LINE CLEAR AVAILED
2635	14-Dec-24	BANGALORE	66	TRANSFORMER	HV3	ATTIBELE	06:10	06:15	00:05	LINE CLEAR AVAILED
2636	14-Dec-24	BANGALORE	400	LINE	ICT 1	NELAMANGALA 400	10:42	18:08	07:26	LINE CLEAR AVAILED
2637	14-Dec-24	BANGALORE	220	TRANSFORMER	LV1	KANAKAPURA 220	07:58	08:15	00:17	TRIPPED ON FAULT
2638	14-Dec-24	BANGALORE	220	TRANSFORMER	LV2	KANAKAPURA 220	07:58	08:40	00:42	TRIPPED ON FAULT
2639	14-Dec-24	GULBARGA	66	TRANSFORMER	HV2	BANAVIKAL_66	17:10	18:05	00:55	LINE CLEAR AVAILED
2640	14-Dec-24	GULBARGA	66	LINE	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66,MOREG ERA_66,HAMPASAGARA_6 6	10:20	16:40	06:20	LINE CLEAR AVAILED
2641	14-Dec-24	GULBARGA	110	LINE	KALBURGI UNIVERSITY- KALBURGI NORTH2	KALBURGI NORTH_110	16:15(14.12.2024)			TRIPPED ON FAULT
2642	14-Dec-24	GULBARGA	110	LINE	KUSTAGI-HANUMASAGAR LINE	HANUMASAGAR_110.HIRE GONNAGAR_110,HANUM ANAL_110	05:48	06:02	00:14	TRIPPED ON FAULT
2643	14-Dec-24	GULBARGA	110	LINE	KUSTAGI-HANUMASAGAR LINE	HANUMASAGAR_110.HIRE GONNAGAR_110,HANUM ANAL_110	18:03	18:05	00:02	TRIPPED ON FAULT
2644	14-Dec-24	GULBARGA	110	LINE	SULEKAL-SRIRAMNAGAR	SRIRAMNAGAR_110	12:00	14:42	02:42	LINE CLEAR AVAILED
2645	14-Dec-24	GULBARGA	110	LINE	SULEKAL-TAVARAGERA	TAVARAGERA_110	21:23	21:49	00:26	TRIPPED ON FAULT
2646	14-Dec-24	GULBARGA	110	LINE	YELLBURGA-VAJRABANDI	YELLBURGA_110,KUKUNO OR_110,	10:15	10:34	00:19	TRIPPED ON FAULT
2647	14-Dec-24	GULBARGA	110	LINE	YERDONA-MARALOHALLA	HANAWA_110,BENNUR_1 10	11:39	11:49	00:10	TRIPPED ON FAULT
2648	14-Dec-24	HASAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	16:28	16:48	00:20	TRIPPED ON FAULT
2649	14-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
2650	14-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	11:03	12:52	01:49	LINE CLEAR AVAILED
2651	14-Dec-24	HASAN	110	LINE	KAVOOR-KLSKR2	KAVOOR_220	17:20(13.12.2024)	8:38(14.12.2024)	15:18HRS	LINE CLEAR AVAILED
2652	14-Dec-24	HASAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	10:09	19:07	08:58	LINE CLEAR AVAILED
2653	14-Dec-24	HASAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	12:00	12:05	00:05	LINE CLEAR AVAILED
2654	14-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:08	19:07	08:59	LINE CLEAR AVAILED
2655	14-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	11:02	12:28	01:26	LINE CLEAR AVAILED
2656	14-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2657	14-Dec-24	MYSORE	66	LINE	HALAGURU-HAROHALLI	NO STATIONS EFFECTED	11:25 (01/12/2024)	8:45 (14/12/2024)	309:19 HRs	LINE CLEAR AVAILED
2658	14-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
2659	14-Dec-24	MYSORE	66	LINE	HOSURGATE-HUNSUR	HOSURGATE_66	10:12	17:48	07:36	LINE CLEAR AVAILED
2660	14-Dec-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	NO STATIONS EFFECTED	12:43	18:47	06:04	TRIPPED ON FAULT
2661	14-Dec-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	07:57	08:45	00:48	MAIN SUPPLY FAILURE
2662	14-Dec-24	MYSORE	66	TRANSFORMER	HV1	KMDODDI_66	11:20	17:49	06:29	LINE CLEAR AVAILED
2663	14-Dec-24	MYSORE	66	TRANSFORMER	HV1	KUNTHUR_66	10:00	15:56	05:55	LINE CLEAR AVAILED
2664	14-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANIVARASANTHE_66	12:00	12:05	00:05	MAIN SUPPLY FAILURE
2665	14-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2666	14-Dec-24	MYSORE	66	TRANSFORMER	HV2	KMDODDI_66	09:35	17:53	08:18	LINE CLEAR AVAILED
2667	14-Dec-24	MYSORE	66	TRANSFORMER	HV2	KUNTHUR_66	10:00	16:00	06:00	LINE CLEAR AVAILED
2668	14-Dec-24	MYSORE	66	TRANSFORMER	HV2	MADDUR_66	18:21	18:39	00:18	MAIN SUPPLY FAILURE
2669	14-Dec-24	MYSORE	66	TRANSFORMER	HV2	MALAVALLI_66	13:29	13:50	00:21	LINE CLEAR AVAILED
2670	14-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2671	14-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2672	14-Dec-24	MYSORE	66	LINE	KM DODDI-TK HALLI	KMDODDI_66	16:28	17:11	00:43	LINE CLEAR AVAILED
2673	14-Dec-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:00	17:10	00:10	TRIPPED ON FAULT
2674	14-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2675	14-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATemple_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2676	14-Dec-24	MYSORE	66	LINE	KUNTHUR-SANTHEMARALLI	KUNTHUR_66	12:13	14:34	02:20	LINE CLEAR AVAILED
2677	14-Dec-24	MYSORE	66	LINE	MADDUR-K.HONALGERE	MADDUR_66	10:02	18:39	08:37	LINE CLEAR AVAILED
2678	14-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	12:24	14:27	02:02	LINE CLEAR AVAILED
2679	14-Dec-24	MYSORE	66	LINE	MANDYA-CHIKKAMANDYA	NO STATIONS EFFECTED	09:47	18:05	08:18	LINE CLEAR AVAILED
2680	14-Dec-24	MYSORE	66	LINE	MANDYA-MADDUR	NO STATIONS EFFECTED	10:11	18:29	08:17	LINE CLEAR AVAILED
2681	14-Dec-24	MYSORE	66	LINE	MANDYA-MC2	MANDYA_66	10:13	17:39	07:25	LINE CLEAR AVAILED
2682	14-Dec-24	MYSORE	66	LINE	MANDYA-MC4	NO STATIONS EFFECTED	10:13	18:09	07:55	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2683	14-Dec-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	YESSLUR_66HETHUR_66	12:25	12:37	00:12	LINE CLEAR AVAILED
2684	14-Dec-24	MYSORE	66	LINE	TUBINKERE-PANDAVAPURA	BANANGADI_66DODDABY ADARAHALLI_66PANDAVA PURA 66	06:50	07:01	00:11	TRIPPED ON FAULT
2685	14-Dec-24	TUMKUR	66	LINE	220KV MADHURE,MATHOD_66KV	MATHOD_66KV	11:20	18:25	7:05	LINE CLEAR AVAILED
2686	14-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV SOKKE,66KV PALLAGATTE,66KV BILICHODU.	3:25	3:40	0:15	TRIPPED ON FAULT
2687	14-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2688	14-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2689	14-Dec-24	TUMKUR	110	TRANSFORMER	TR-1 10MVA AMMASANDRA 110	AMMASANDRA_110	1:33	7:10	5:37	TRIPPED ON FAULT
2690	14-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA BILICHODU-66KV	BILICHODU_66KV	8:40	8:45	0:05	TRIPPED ON FAULT
2691	14-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA GULIGENAHALLI_66KV	GULIGENAHALLI_66KV	13:20	14:10	0:50	LINE CLEAR AVAILED
2692	14-Dec-24	TUMKUR	66	LINE	TR-1 12.5 MVA GULIGENAHALLI 66KV	GULIGENAHALLI_66KV	13:20	15:30	2:10	LINE CLEAR AVAILED
2693	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ANKOLA_110	01:45	02:07	0:22	TRIPPED ON FAULT
2694	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	03:21	03:30	0:09	TRIPPED ON FAULT
2695	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	THORVI_110	13:22	13:24	0:02	TRIPPED ON FAULT
2696	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KAGAWAD_110	09:39	09:50	0:11	TRIPPED ON FAULT
2697	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NAVALAGI_110	03:35	04:05	0:30	TRIPPED ON FAULT
2698	15-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NIPPANI_110	23:03	23:27	0:24	TRIPPED ON FAULT
2699	15-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2700	15-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2701	15-Dec-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	6:59	18:25	11:26	LINE CLEAR AVAILED
2702	15-Dec-24	BAGALKOTE	220	LINE	DHONI400-LINGAPUR1(HALVARTHY1)	DHONI_400	10:59	17:30	6:31	LINE CLEAR AVAILED
2703	15-Dec-24	BAGALKOTE	220	LINE	DHONI400-LINGAPUR2(HALVARTHY2)	DHONI_400	11:00	17:30	6:30	LINE CLEAR AVAILED
2704	15-Dec-24	BAGALKOTE	110	LINE	GALATAGA-KOGANALLI	GALATAGA_110	09:25	10:10	0:45	TRIPPED ON FAULT
2705	15-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL 110	12:47 (10.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2706	15-Dec-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	11:49	11:56	0:07	LINE CLEAR AVAILED
2707	15-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM-ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)			LINE CLEAR AVAILED
2708	15-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2709	15-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2710	15-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2711	15-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVA SUG(BASAVA SUGARS)	MALGHAN(B)_110	06:34	06:39	0:05	TRIPPED ON FAULT
2712	15-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2713	15-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
2714	15-Dec-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	15:01	15:25	0:24	TRIPPED ON FAULT
2715	15-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)			LINE CLEAR AVAILED
2716	15-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2717	15-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL(TAKKALAKI)	TIKOTA_110	10:08	20:58	10:50	LINE CLEAR AVAILED
2718	15-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2719	15-Dec-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	DABUSPETE 220	10:00	16:37	06:37	LINE CLEAR AVAILED
2720	15-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2721	15-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2722	15-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2723	15-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DABASPETE 220 (B3)	DABUSPETE 220	10:04	17:30	07:26	LINE CLEAR AVAILED
2724	15-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
2725	15-Dec-24	BANGALORE	66	LINE	66KV AVANI - MULABAGAL	MULBAGAL, ADB SOLAR	11:30	11:50	00:20	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2726	15-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - K RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	06:15	06:23	00:08	TRIPPED ON FAULT
2727	15-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:12	10:17	00:05	LINE CLEAR AVAILED
2728	15-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	21:02	21:07	00:05	TRIPPED ON FAULT
2729	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - AVERAHALLI	AVERAHALLI, T BEGUR	10:04	17:10	07:06	LINE CLEAR AVAILED
2730	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - HIREHALLI	HIREHALLI	10:03	17:39	07:36	LINE CLEAR AVAILED
2731	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - JINDAL (EHT)	JINDAL(EHT)	10:03	17:51	07:48	LINE CLEAR AVAILED
2732	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - NELAMANGALA CKT 1	NELAMANGALA 66	10:03	17:38	07:35	LINE CLEAR AVAILED
2733	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - SK STEEL	SK STEEL(EHT)	10:02	17:10	07:08	LINE CLEAR AVAILED
2734	15-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	10:03	17:49	07:46	LINE CLEAR AVAILED
2735	15-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	22:12	22:16	00:04	LINE CLEAR AVAILED
2736	15-Dec-24	BANGALORE	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	NO STATION AFFECTED	10:59	14:53	03:54	LINE CLEAR AVAILED
2737	15-Dec-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	BAGGANADODDI, KUMBARANAHALLI	07:35	08:28	00:53	MAIN SUPPLY FAILURE
2738	15-Dec-24	BANGALORE	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI 66, JIGANI LINK ROAD	07:35	08:25	00:50	MAIN SUPPLY FAILURE
2739	15-Dec-24	BANGALORE	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	DOMMASANDRA	11:34	11:40	00:06	LINE CLEAR AVAILED
2740	15-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN-2	NO STATION AFFECTED	07:03	08:12	01:09	TRIPPED ON FAULT
2741	15-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARIYOTHI (TAP)	NO STATION AFFECTED	16:00	19:51	03:51	TRIPPED ON FAULT
2742	15-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - CHIKKENAHALLI LINK	SHIVANAHALLI	16:17	16:33	00:16	TRIPPED ON FAULT
2743	15-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE, DODDERI	10:35	15:00	04:25	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2744	15-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	17:51	17:56	00:05	LINE CLEAR AVAILED
2745	15-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	17:03	17:08	00:05	LINE CLEAR AVAILED
2746	15-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	NO STATION AFFECTED	23:58:00	14:03	14:05	LINE CLEAR AVAILED
2747	15-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	06:49	11:43	04:54	MAIN SUPPLY FAILURE
2748	15-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	06:49	07:42	00:53	TRIPPED ON FAULT
2749	15-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:20	11:40	00:20	LINE CLEAR AVAILED
2750	15-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	10:46	16:38	05:52	LINE CLEAR AVAILED
2751	15-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	BYADRAHALLI, SRIGANDA KAVALU, KODIGEHALLI	10:16	16:28	06:12	LINE CLEAR AVAILED
2752	15-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	NO STATION AFFECTED	10:42	16:47	06:05	LINE CLEAR AVAILED
2753	15-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	11:30	11:45	00:15	TRIPPED ON FAULT
2754	15-Dec-24	BANGALORE	66	LINE	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI	16:51	16:56	00:05	LINE CLEAR AVAILED
2755	15-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	BOMMASANDRA	10:42	10:54	00:12	TRIPPED ON FAULT
2756	15-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	NO STATION AFFECTED	12:42	15:10	02:28	TRIPPED ON FAULT
2757	15-Dec-24	BANGALORE	66	LINE	DABUSPETE 220 - EMMVEE SOLAR(EHT)	EMMVEE SOLAR(EHT)	10:01	17:23	07:22	LINE CLEAR AVAILED
2758	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	15:13	15:18	00:05	LINE CLEAR AVAILED
2759	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	C STATION 66	12:37	14:30	01:53	LINE CLEAR AVAILED
2760	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	10:12	10:17	00:05	LINE CLEAR AVAILED
2761	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DABUSPETE 220	10:01	16:51	06:50	LINE CLEAR AVAILED
2762	15-Dec-24	BANGALORE	220	TRANSFORMER	HV1	DABUSPETE 220	10:00	16:53	06:53	LINE CLEAR AVAILED
2763	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HONNIGANAHALLI	05:30	09:00	03:30	LINE CLEAR AVAILED
2764	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JADIGENAHALLI	13:40	14:15	00:35	LINE CLEAR AVAILED
2765	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KOTHIPURA 220	10:15	14:19	04:04	LINE CLEAR AVAILED
2766	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	06:53	07:00	00:07	LINE CLEAR AVAILED
2767	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	22:10	22:15	00:05	LINE CLEAR AVAILED
2768	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANCHENAHALLI	03:40	04:10	00:30	TRIPPED ON FAULT
2769	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	06:49	07:29	00:40	LINE CLEAR AVAILED
2770	15-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	11:20	11:27	00:07	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2771	15-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	06:49	07:29	00:40	TRIPPED ON FAULT
2772	15-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	07:30	11:18	03:48	LINE CLEAR AVAILED
2773	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTIBELE	17:40	17:50	00:10	LINE CLEAR AVAILED
2774	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	10:00	15:40	05:40	LINE CLEAR AVAILED
2775	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DABUSPETE 220	10:01	17:09	07:08	LINE CLEAR AVAILED
2776	15-Dec-24	BANGALORE	220	TRANSFORMER	HV2	DABUSPETE 220	10:00	16:54	06:54	LINE CLEAR AVAILED
2777	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	11:15	11:20	00:05	LINE CLEAR AVAILED
2778	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KYALANUR	14:18	14:45	00:27	TRIPPED ON FAULT
2779	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	06:53	07:00	00:07	LINE CLEAR AVAILED
2780	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	22:10	22:15	00:05	LINE CLEAR AVAILED
2781	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOMANAHALLI 220	06:02	06:30	00:28	TRIPPED ON FAULT
2782	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOMANAHALLI 220	10:20	11:31	01:11	LINE CLEAR AVAILED
2783	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ST JOHN WOOD	06:02	06:10	00:08	TRIPPED ON FAULT
2784	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ST JOHN WOOD	06:10	14:02	07:52	TRIPPED ON FAULT
2785	15-Dec-24	BANGALORE	66	TRANSFORMER	HV2	T BEGUR	20:15	21:30	01:15	LINE CLEAR AVAILED
2786	15-Dec-24	BANGALORE	66	TRANSFORMER	HV3	ATTIBELE	17:40	17:50	00:10	LINE CLEAR AVAILED
2787	15-Dec-24	BANGALORE	66	TRANSFORMER	HV3	NELAMANGALA 66	17:39	18:02	00:23	LINE CLEAR AVAILED
2788	15-Dec-24	BANGALORE	220	TRANSFORMER	HV5	SRS PEENYA 220	10:24	16:22	05:58	LINE CLEAR AVAILED
2789	15-Dec-24	BANGALORE	400	LINE	ICT 2	NELAMANGALA 400	13:46	18:34	04:48	LINE CLEAR AVAILED
2790	15-Dec-24	BANGALORE	220	TRANSFORMER	LV1	JIGANI 220	07:35	08:20	00:45	TRIPPED ON FAULT
2791	15-Dec-24	BANGALORE	220	TRANSFORMER	LV2	JIGANI 220	07:35	08:21	00:46	TRIPPED ON FAULT
2792	15-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	23:46	23:59	00:13	TRIPPED ON FAULT
2793	15-Dec-24	GULBARGA	220	LINE	HALEARTHY-ILC_IPP	HALWARTHY_220	09:25	09:45	00:20	LINE CLEAR AVAILED
2794	15-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARI NORTH_110	16:48	17:03	00:15	TRIPPED ON FAULT
2795	15-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HALUVAGALU_66	08:45	10:00	01:15	LINE CLEAR AVAILED
2796	15-Dec-24	GULBARGA	110	TRANSFORMER	HV1	YADGIR_110	10:40	17:25	06:45	LINE CLEAR AVAILED
2797	15-Dec-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	06:43	07:20	00:37	TRIPPED ON FAULT
2798	15-Dec-24	GULBARGA	110	TRANSFORMER	HV2	YADGIR_110	10:40	13:15	02:35	LINE CLEAR AVAILED
2799	15-Dec-24	GULBARGA	110	TRANSFORMER	HV2	YADGIR_110	10:45	16:30	05:45	LINE CLEAR AVAILED
2800	15-Dec-24	GULBARGA	110	TRANSFORMER	HV3	YADGIR_110	10:45	18:45	08:00	LINE CLEAR AVAILED
2801	15-Dec-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	13:39	15:23	01:44	LINE CLEAR AVAILED
2802	15-Dec-24	GULBARGA	110	LINE	YADGIR-KBJNL	YADGIR_110	10:50	20:40	09:50	LINE CLEAR AVAILED
2803	15-Dec-24	GULBARGA	110	LINE	YADGIR-KBJNL	YADGIR_110	10:50	20:40	09:50	LINE CLEAR AVAILED
2804	15-Dec-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	11:02	20:20	09:18	LINE CLEAR AVAILED
2805	15-Dec-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	10:58	20:32	09:34	LINE CLEAR AVAILED
2806	15-Dec-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	11:03	13:15	02:12	LINE CLEAR AVAILED
2807	15-Dec-24	HASAN	220	LINE	GERSOPA-SHIMOGA	gerusoppa_gen	11:19	15:13	03:54	TRIPPED ON FAULT
2808	15-Dec-24	HASAN	110	TRANSFORMER	HV1	SAGARA_110	10:08	16:53	06:45	LINE CLEAR AVAILED
2809	15-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
2810	15-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	10:08	16:51	06:43	LINE CLEAR AVAILED
2811	15-Dec-24	HASAN	220	LINE	KADUR-DABUSET	KADUR_220	10:10	16:36	06:26	LINE CLEAR AVAILED
2812	15-Dec-24	HASAN	220	LINE	KEMAR-BAJPE1	KEMAR_220	08:22	18:01	09:39	LINE CLEAR AVAILED
2813	15-Dec-24	HASAN	220	LINE	MRSSHM-STRRP	MRSMG_220	11:19	15:12	03:53	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2814	15-Dec-24	HASAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	08:22	18:01	09:39	LINE CLEAR AVAILED
2815	15-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
2816	15-Dec-24	MYSORE	66	LINE	HARAVE-THAMMADAHALLI LIS (EHT)	NO STATIONS EFFECTED	09:20	09:35	00:15	TRIPPED ON FAULT
2817	15-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
2818	15-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2819	15-Dec-24	MYSORE	66	TRANSFORMER	HV1	YELANDUR_66	10:10	16:15	06:05	LINE CLEAR AVAILED
2820	15-Dec-24	MYSORE	66	TRANSFORMER	HV2	YELANDUR_66	10:10	16:15	06:05	LINE CLEAR AVAILED
2821	15-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2822	15-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2823	15-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2824	15-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATemple_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2825	15-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI- HANNUR 1	NO STATIONS EFFECTED	06:43	06:50	00:06	TRIPPED ON FAULT
2826	15-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI- MAMBALLI	MAMBALLI_66	10:17	15:53	05:36	LINE CLEAR AVAILED
2827	15-Dec-24	MYSORE	66	LINE	TUBINAKERE- JAKKANAHALLI	NO STATIONS EFFECTED	01:43	01:48	00:05	TRIPPED ON FAULT
2828	15-Dec-24	MYSORE	66	LINE	VAJAMANGALA- DEVNUR(MYSURU)	DEVANOORMYS_66 RAJEEVNAGARA_66	08:14	08:21	00:07	TRIPPED ON FAULT
2829	15-Dec-24	MYSORE	66	LINE	YELANDURU- HONGANURU	YELANDUR_66	10:25	16:30	06:05	LINE CLEAR AVAILED
2830	15-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV HALURAMESHWARA LINE-1	66KV HALRAMESHWARA,MADA DAKERE	5:45	6:00	0:15	TRIPPED ON FAULT
2831	15-Dec-24	TUMKUR	66	LINE	220KV THALLAK-BG KERE LINE-2	BG KERE LINE-2	6:30	6:46	0:16	TRIPPED ON FAULT
2832	15-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU, PALLAGATTE,SOKKE	1:35	1:40	0:05	TRIPPED ON FAULT
2833	15-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	1:35	1:45	0:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2834	15-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI	6:05	6:15	0:10	TRIPPED ON FAULT
2835	15-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220-66KV PANDARAHALLI LINE	SIRIGERE_66-CHITRADURGA_66,BHARA MASAGARA_66,VIJAPURA_66	9:55	18:25	8:30	LINE CLEAR AVAILED
2836	15-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2837	15-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2838	15-Dec-24	TUMKUR	66	LINE	GUTTUR 400KV- KAIGA 11KV	KAIGA 11KV	3:11	7:25	4:14	TRIPPED ON FAULT
2839	15-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMGHATTA,	5:04	5:10	0:06	TRIPPED ON FAULT
2840	15-Dec-24	TUMKUR	66	LINE	PANDARAHALLI-HOLALKERE	HOLALKERE_66,HDPURA_66,	6:30	6:40	0:10	TRIPPED ON FAULT
2841	15-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 HALUVAGALU_66	HALUVAGALU_66	8:45	10:00	1:15	LINE CLEAR AVAILED
2842	15-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA BILICHODU-66KV	BILICHODU_66KV	6:25	6:30	0:05	TRIPPED ON FAULT
2843	15-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA MVA GOPPENAHALLI_66	GOPPENAHALLI_66	11:40	11:45	0:05	TRIPPED ON FAULT
2844	15-Dec-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR_66	JAGALUR_66	6:30	6:40	0:10	MAIN SUPPLY FAILURE
2845	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	GHATAPRABHA_220	13:13	13:35	0:22	LINE CLEAR AVAILED
2846	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIRSI_220	18:45	19:45	1:00	TRIPPED ON FAULT
2847	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ALBAL_110	10:13	11:30	1:17	LINE CLEAR AVAILED
2848	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ALBAL_110	12:35	16:12	3:37	LINE CLEAR AVAILED
2849	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ANKALI_110	11:20	11:35	0:15	TRIPPED ON FAULT
2850	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	06:55	07:00	0:05	TRIPPED ON FAULT
2851	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA-HV1)	KALADAGI_110	14:42	15:03	0:21	LINE CLEAR AVAILED
2852	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA-HV1)	KALADAGI_110	15:18	15:25	0:07	LINE CLEAR AVAILED
2853	16-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	ALBAL_110	10:13	18:00	7:47	LINE CLEAR AVAILED
2854	16-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2855	16-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	HAVERI_220	16:50	17:06	0:16	LINE CLEAR AVAILED
2856	16-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2(HV1)	GADAG_220	11:08	11:45	0:37	LINE CLEAR AVAILED
2857	16-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
2858	16-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	HAVERI_220	17:02	17:07	0:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2859	16-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2(LV1)	GADAG_220	11:08	11:47	0:39	LINE CLEAR AVAILED
2860	16-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
2861	16-Dec-24	BAGALKOTE	110	LINE	HAVERI220- BYADAGI	HAVERI_220	17:06	19:57	2:51	LINE CLEAR AVAILED
2862	16-Dec-24	BAGALKOTE	110	LINE	HAVERI220- HANGAL(KULENUR)	HAVERI_220	17:01	18:01	1:00	LINE CLEAR AVAILED
2863	16-Dec-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALAGI(BELGAUM)	HIDIKAL DAM_110	14:51 (01.12.2024)	23:23 (16.12.2024)	368:32:00	LINE CLEAR AVAILED
2864	16-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2865	16-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
2866	16-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
2867	16-Dec-24	BAGALKOTE	110	LINE	KUDACHI220-UGARKHUD	KUDACHI_220	19:30	19:55	0:25	TRIPPED ON FAULT
2868	16-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2869	16-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN12(PG HUNSHYAL)	MUGALKHOD_220	13:06	14:29	1:23	LINE CLEAR AVAILED
2870	16-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
2871	16-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-CHIKKODI	STATION NOT AFFECTED SANKESHWARA_110	11:26 (23.09.2024)	4:48 (23.12.2024)	2177:22:00	LINE CLEAR AVAILED
2872	16-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
2873	16-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
2874	16-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	17:47	18:35	00:48	LINE CLEAR AVAILED
2875	16-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
2876	16-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2877	16-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
2878	16-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
2879	16-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - KOLAR 1	KOLAR 220	13:34	14:27	00:53	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2880	16-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:08	10:13	00:05	LINE CLEAR AVAILED
2881	16-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	13:54	14:54	01:00	LINE CLEAR AVAILED
2882	16-Dec-24	BANGALORE	66	LINE	66KV GANJIGUNTE - PALLICHERLU	PALLICHERLU	10:25	17:10	06:45	LINE CLEAR AVAILED
2883	16-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	06:58	07:13	00:15	TRIPPED ON FAULT
2884	16-Dec-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	11:36	11:46	00:10	LINE CLEAR AVAILED
2885	16-Dec-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	14:47	14:53	00:06	LINE CLEAR AVAILED
2886	16-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4	HOSKOTE 66	10:35	10:40	00:05	LINE CLEAR AVAILED
2887	16-Dec-24	BANGALORE	66	LINE	66KV KOLAR 220 - BANGARPET 2	BANGARPETE	11:35	11:40	00:05	LINE CLEAR AVAILED
2888	16-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)	NO STATION AFFECTED	08:02	13:11	05:09	LINE CLEAR AVAILED
2889	16-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)	NO STATION AFFECTED	07:05	13:11	06:06	TRIPPED ON FAULT
2890	16-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:12	18:17	00:05	LINE CLEAR AVAILED
2891	16-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	15:10	15:15	00:05	LINE CLEAR AVAILED
2892	16-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	18:00	18:13	00:13	TRIPPED ON FAULT
2893	16-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - KUMBALAGODU 220	NO STATION AFFECTED	11:45	14:45	03:00	LINE CLEAR AVAILED
2894	16-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	14:06	14:52	00:46	LINE CLEAR AVAILED
2895	16-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:58	17:11	00:13	TRIPPED ON FAULT
2896	16-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	17:42	17:47	00:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2897	16-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU, YETHAMBADI, K HONALGERE	16:58	17:12	00:14	TRIPPED ON FAULT
2898	16-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	NO STATION AFFECTED	07:51	07:52	00:01	LINE CLEAR AVAILED
2899	16-Dec-24	BANGALORE	66	LINE	HBR LAYOUT 66 - 66kV INTER CONNECTING BAY	HBR LAYOUT 66	11:57	14:02	02:05	LINE CLEAR AVAILED
2900	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BANGARPETE	15:15	15:17	00:02	LINE CLEAR AVAILED
2901	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	C STATION 66	16:05	16:10	00:05	LINE CLEAR AVAILED
2902	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	13:46	13:56	00:10	TRIPPED ON FAULT
2903	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	IISc	05:48	06:09	00:21	TRIPPED ON FAULT
2904	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ITI 220	15:24	15:35	00:11	LINE CLEAR AVAILED
2905	16-Dec-24	BANGALORE	220	TRANSFORMER	HV1	ITI 220	11:09	14:05	02:56	LINE CLEAR AVAILED
2906	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MELEHALLI	10:00	15:00	05:00	LINE CLEAR AVAILED
2907	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	PLATINUM CITY	23:00	23:05	00:05	TRIPPED ON FAULT
2908	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RAYALPADU	10:10	10:30	00:20	LINE CLEAR AVAILED
2909	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	11:40	11:45	00:05	LINE CLEAR AVAILED
2910	16-Dec-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	23:26	23:35	00:09	TRIPPED ON FAULT
2911	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BANGARPETE	10:55	11:00	00:05	LINE CLEAR AVAILED
2912	16-Dec-24	BANGALORE	220	TRANSFORMER	HV2	HSR LAYOUT 220	11:49	14:41	02:52	LINE CLEAR AVAILED
2913	16-Dec-24	BANGALORE	220	TRANSFORMER	HV2	ITI 220	14:15	16:50	02:35	LINE CLEAR AVAILED
2914	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	K&C VALLEY	17:05	17:20	00:15	LINE CLEAR AVAILED
2915	16-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KOLAR 220	13:05	14:48	01:43	LINE CLEAR AVAILED
2916	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MELEHALLI	10:00	15:00	05:00	LINE CLEAR AVAILED
2917	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NALLIMARADANAHALLI	14:00	14:05	00:05	TRIPPED ON FAULT
2918	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	17:25	17:30	00:05	LINE CLEAR AVAILED
2919	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VOKKALERI	12:50	13:55	01:05	LINE CLEAR AVAILED
2920	16-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VOKKALERI	14:00	15:10	01:10	LINE CLEAR AVAILED
2921	16-Dec-24	BANGALORE	66	TRANSFORMER	HV3	BAGMANE WTC	22:16	23:02	00:46	TRIPPED ON FAULT
2922	16-Dec-24	BANGALORE	66	TRANSFORMER	HV3	BANGARPETE	13:10	14:40	01:30	LINE CLEAR AVAILED
2923	16-Dec-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	23:58:00	07:57	07:59	TRIPPED ON FAULT
2924	16-Dec-24	GULBARGA	110	LINE	HALBARGA-HUMNABAD	HALBARGA_110	18:01	18:08	00:07	TRIPPED ON FAULT
2925	16-Dec-24	GULBARGA	110	LINE	HALBARGA-KOLAR1	KOLAR_110	06:31	06:47	00:16	TRIPPED ON FAULT
2926	16-Dec-24	GULBARGA	110	LINE	HALBARGA-KOLAR1	KOLAR_110	08:05	13:22	05:17	LINE CLEAR AVAILED
2927	16-Dec-24	GULBARGA	110	LINE	HALBARGA-KOLAR2	KOLAR_110	06:31	06:44	00:13	TRIPPED ON FAULT
2928	16-Dec-24	GULBARGA	110	LINE	HALBARGA-KOLAR2	KOLAR_110	08:05	13:22	05:17	LINE CLEAR AVAILED
2929	16-Dec-24	GULBARGA	220	TRANSFORMER	HV1	SHAHAPUR_220	15:28	17:26	01:58	LINE CLEAR AVAILED
2930	16-Dec-24	GULBARGA	110	TRANSFORMER	HV2	BISIHALLI_110	13:15	13:30	00:15	TRIPPED ON FAULT
2931	16-Dec-24	GULBARGA	66	TRANSFORMER	HV2	HANSI_66	10:15	11:20	01:05	LINE CLEAR AVAILED
2932	16-Dec-24	GULBARGA	110	TRANSFORMER	HV2	HANUMANAL_110	18:05	19:20	01:15	TRIPPED ON FAULT
2933	16-Dec-24	GULBARGA	110	TRANSFORMER	HV2	KURUGODU_110	10:50	11:40	00:50	LINE CLEAR AVAILED
2934	16-Dec-24	GULBARGA	110	LINE	LINGASUGUR-GURGUNTA	GURGUNTA_110	14:24	16:07	01:43	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2935	16-Dec-24	GULBARGA	110	LINE	NANDOODR-SHAHABAD	UNIVERSITY_110, NANDOODR_110	12:15	14:00	01:45	LINE CLEAR AVAILED
2936	16-Dec-24	GULBARGA	66	LINE	NEELAGUNDA- HALVAGALU	HALUVAGALU_66,LIS NITTUR,HARIVI_66,	15:42	15:51	00:09	TRIPPED ON FAULT
2937	16-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
2938	16-Dec-24	GULBARGA	110	LINE	RAJESHWAR-HUMNABAD	RAJESHWAR_110	10:43	10:57	00:14	TRIPPED ON FAULT
2939	16-Dec-24	GULBARGA	110	LINE	SANTHPUR-HALBARGA	SANTHAPUR_110	10:43	10:47	00:04	TRIPPED ON FAULT
2940	16-Dec-24	GULBARGA	110	LINE	SINDHANOOR- NIRLOOTI_IPP	SINDHANOOR_220	18:10	18:20	00:10	TRIPPED ON FAULT
2941	16-Dec-24	GULBARGA	110	LINE	SINDHANOOR- WALKAMDINI	WALKAMDINI_110	09:00	13:45	04:45	LINE CLEAR AVAILED
2942	16-Dec-24	GULBARGA	110	LINE	SULEKAL-ITTAGI	ITTAGI_110	10:10	18:46	08:36	LINE CLEAR AVAILED
2943	16-Dec-24	GULBARGA	66	LINE	TELIGI-KURUBANAHALLI	KURUBANAHALLI_110,SH AMANUR SUGAR_IPP	15:45	15:50	00:05	TRIPPED ON FAULT
2944	16-Dec-24	HASAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	10:03	10:06	00:03	LINE CLEAR AVAILED
2945	16-Dec-24	HASAN	66	LINE	HASSN22-HSN66	HASSAN_220	10:09	10:16	00:07	LINE CLEAR AVAILED
2946	16-Dec-24	HASAN	110	LINE	HGUNJE-HIRIYADKA	HEGGUNJE_220	15:25	15:27	00:02	LINE CLEAR AVAILED
2947	16-Dec-24	HASAN	66	TRANSFORMER	HV1	DIDIGA_66	06:23	06:39	00:16	TRIPPED ON FAULT
2948	16-Dec-24	HASAN	110	TRANSFORMER	HV1	HEGGUNJE_220	14:35	14:37	00:02	LINE CLEAR AVAILED
2949	16-Dec-24	HASAN	110	TRANSFORMER	HV1	KADUR_220	11:11	18:14	07:03	LINE CLEAR AVAILED
2950	16-Dec-24	HASAN	66	TRANSFORMER	HV1	NAGARTHI_66	11:50	13:06	01:16	LINE CLEAR AVAILED
2951	16-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	11:02	11:10	00:08	TRIPPED ON FAULT
2952	16-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
2953	16-Dec-24	HASAN	220	LINE	KADUR-SHIMOGA	KADUR_220	10:05	14:06	04:01	LINE CLEAR AVAILED
2954	16-Dec-24	HASAN	220	LINE	KAVOOR-BAJPE2	KAVOOR_220	10:14	14:00	03:46	LINE CLEAR AVAILED
2955	16-Dec-24	HASAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	09:30	17:43	08:13	LINE CLEAR AVAILED
2956	16-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	21:34	21:49	00:15	TRIPPED ON FAULT
2957	16-Dec-24	HASAN	220	LINE	MRSSHM-KADUR	MRSMSG_220	10:18	14:06	03:48	LINE CLEAR AVAILED
2958	16-Dec-24	HASAN	110	LINE	MRSSHM-SS1	MRSMSG_220	09:53	14:33	04:40	LINE CLEAR AVAILED
2959	16-Dec-24	HASAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	10:15	14:00	03:45	LINE CLEAR AVAILED
2960	16-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	09:29	17:43	08:14	LINE CLEAR AVAILED
2961	16-Dec-24	HASAN	110	LINE	PUTTUR-PUTTUR2	PUTTUR_220	10:02	12:18	02:16	LINE CLEAR AVAILED
2962	16-Dec-24	HASAN	220	LINE	SHRAVTY-SHIRALKOPPA	sharavathy_gen	16:23	17:28	01:05	LINE CLEAR AVAILED
2963	16-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	16:23	17:28	01:05	LINE CLEAR AVAILED
2964	16-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
2965	16-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
2966	16-Dec-24	MYSORE	66	TRANSFORMER	HV1	BOOKANAKERE_66	14:55	16:05	01:10	LINE CLEAR AVAILED
2967	16-Dec-24	MYSORE	66	TRANSFORMER	HV1	RAVANDUR_66	14:35	14:40	00:05	TRIPPED ON FAULT
2968	16-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANIVARASANTHE_66	10:05	10:10	00:05	MAIN SUPPLY FAILURE
2969	16-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2970	16-Dec-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	16:54	17:12	00:18	MAIN SUPPLY FAILURE
2971	16-Dec-24	MYSORE	66	TRANSFORMER	HV2	CHUNCHUNKATTE_66	11:35	12:15	00:40	LINE CLEAR AVAILED
2972	16-Dec-24	MYSORE	66	TRANSFORMER	HV2	GUDDENAHALLI_66	05:00	05:05	00:05	TRIPPED ON FAULT
2973	16-Dec-24	MYSORE	66	TRANSFORMER	HV2	RAVANDUR_66	14:35	14:40	00:05	TRIPPED ON FAULT
2974	16-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEMARAHALLI_66	11:37	13:06	01:29	LINE CLEAR AVAILED
2975	16-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEMARAHALLI_66	13:05	14:00	00:55	LINE CLEAR AVAILED
2976	16-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2977	16-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
2978	16-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
2979	16-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
2980	16-Dec-24	MYSORE	66	LINE	MADDUR-KIADB SOMANAHALLI	KIADB SOMANAHALLI_66	11:15	11:25	00:10	TRIPPED ON FAULT
2981	16-Dec-24	MYSORE	66	LINE	PANYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	06:25	06:30	00:05	TRIPPED ON FAULT
2982	16-Dec-24	MYSORE	66	LINE	PANYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	23:55	23:59	00:05	TRIPPED ON FAULT
2983	16-Dec-24	MYSORE	66	LINE	RAVANDURU-ADANI IPP	NO STATIONS EFFECTED	14:35	14:40	00:05	TRIPPED ON FAULT
2984	16-Dec-24	MYSORE	66	TRANSFORMER	SHANIVARSANTHE-HV2	SANIVARASANTHE_66	10:05	10:10	00:05	MAIN SUPPLY FAILURE
2985	16-Dec-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	SANIVARASANTHE_66	00:25	00:57	00:32	TRIPPED ON FAULT
2986	16-Dec-24	MYSORE	66	LINE	TALAKADU-ADANI IPP	NO STATIONS EFFECTED	16:50	16:58	00:08	TRIPPED ON FAULT
2987	16-Dec-24	TUMKUR	66	LINE	MADURE_220 HALURAMESWARA_220kv	HALURAMESWARA_66, HOSADURGA_66,MADADKERE_66	14:15	14:35	0:20	LINE CLEAR AVAILED
2988	16-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV AMRUTHUR LINE	SANTHEMAVATHUR,AMRUTHUR ,SANABGHATTA, YEDAVANI	14:13	14:49	0:36	TRIPPED ON FAULT
2989	16-Dec-24	TUMKUR	66	LINE	400KV HIREMALLANAHOLE-220KV CHITRADURGA-1	220KV CHITRADURGA-1	5:13	9:15	4:02	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
2990	16-Dec-24	TUMKUR	66	LINE	66KV KURUBARAHALLI- 66KV TELGI LINE 2	66KV KURUBARAHALLI,IPP SHAMANUR SUGARS	15:45	15:55	0:10	TRIPPED ON FAULT
2991	16-Dec-24	TUMKUR	66	LINE	CHANNAGIRI- LINGADAHALLI	CHANNAGIRI_66	11:25 (16.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2992	16-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR NEW	15:16	15:28	0:12	TRIPPED ON FAULT
2993	16-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2994	16-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
2995	16-Dec-24	TUMKUR	66	LINE	GUTTUR 400KV- KAIGA 11KV	KAIGA 11KV	3:11	7:25	4:14	TRIPPED ON FAULT
2996	16-Dec-24	TUMKUR	66	LINE	HIRIYUR_220KV-66KV RANGANATHAPURA	66kv RANAGANATHAPURA	17:25	17:35	0:10	TRIPPED ON FAULT
2997	16-Dec-24	TUMKUR	66	LINE	TMTP_66- BRAHMASANDRA_66, O/G LINE 2	66KV ANKSANDRA,BRAMSANDR A, SUNVIK PLANT	15:40	16:04	0:24	TRIPPED ON FAULT
2998	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA BILICHODU- 66KV	BILICHODU_66KV	9:59	10:02	0:03	TRIPPED ON FAULT
2999	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA MATHOD_66KV	MATHOD_66KV	9:45	10:00	0:15	TRIPPED ON FAULT
3000	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA MATHOD_66KV	MATHOD_66KV	10:15	10:20	0:05	LINE CLEAR AVAILED
3001	16-Dec-24	TUMKUR	110	TRANSFORMER	TR-2 10 MVA KADEHALLI_110	KADEHALLI_110	2:15	2:20	0:05	TRIPPED ON FAULT
3002	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 10MVA HULIYUR_110	HULIYUR_110	3:04	3:20	0:16	TRIPPED ON FAULT
3003	16-Dec-24	TUMKUR	110	TRANSFORMER	TR-2 10MVA HULIYUR_110	HULIYUR_110	3:04	3:20	0:16	TRIPPED ON FAULT
3004	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA BILICHODU- 66KV	BILICHODU_66KV	6:51	7:00	0:09	TRIPPED ON FAULT
3005	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA JAVAGONDANAHALLI_66K V	JAVAGONDANAHALLI_66K V	14:12	14:16	0:04	TRIPPED ON FAULT
3006	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA MATHOD_66KV	MATHOD_66KV	13:00	13:10	0:10	TRIPPED ON FAULT
3007	16-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA TUMKUR _66KV	TUMKUR_66KV	10:40	12:45	2:05	LINE CLEAR AVAILED
3008	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	DEVANGOAN_110	15:55	16:32	0:37	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3009	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MUNDARAGI_110	12:00	12:55	0:55	LINE CLEAR AVAILED
3010	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	14:11	16:43	2:32	LINE CLEAR AVAILED
3011	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	HANAGAL_110	11:34	12:22	0:48	TRIPPED ON FAULT
3012	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR(B)_110	10:45	18:41	7:56	LINE CLEAR AVAILED
3013	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	THORVI_110	15:49	15:55	0:06	TRIPPED ON FAULT
3014	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	SALAHALLI_110	15:59	21:59	6:00	TRIPPED ON FAULT
3015	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	HANAGAL_110	10:04	10:28	0:24	TRIPPED ON FAULT
3016	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MUNDARAGI_110	12:00	12:55	0:55	LINE CLEAR AVAILED
3017	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA-HV1)	DAVALESHWAR_110	13:56	14:38	0:42	LINE CLEAR AVAILED
3018	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA-HV1)	GAJENDRAGAD_110	08:06	13:08	5:02	TRIPPED ON FAULT
3019	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA-HV1)	SANKESHWAR_110	10:50	11:03	0:13	TRIPPED ON FAULT
3020	17-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(10MVA)	JAMAKHANDI_110	14:42	15:01	0:19	TRIPPED ON FAULT
3021	17-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3022	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	AEQUS_220	05:16	05:24	0:08	LINE CLEAR AVAILED
3023	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BELGAUM_220	04:43	05:32	0:49	LINE CLEAR AVAILED
3024	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3025	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	AEQUS_220	05:16	05:24	0:08	LINE CLEAR AVAILED
3026	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	BELGAUM_220	04:43	05:32	0:49	LINE CLEAR AVAILED
3027	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	HAVERI_220	11:34	12:20	0:46	TRIPPED ON FAULT
3028	17-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV3	BELGAUM_220	04:43	05:31	0:48	LINE CLEAR AVAILED
3029	17-Dec-24	BAGALKOTE	220	LINE	AEQUS -F1(BELGAUM1)	AEQUS_220	04:29	05:19	0:50	TRIPPED ON FAULT
3030	17-Dec-24	BAGALKOTE	220	LINE	AEQUS-F4(KANAGALA2)	AEQUS_220	4:29	5:25	0:56	TRIPPED ON FAULT
3031	17-Dec-24	BAGALKOTE	110	LINE	AHERI220-ALMEL1	AHERI_220	15:15	15:40	0:25	LINE CLEAR AVAILED
3032	17-Dec-24	BAGALKOTE	110	LINE	AHERI220-ALMEL2	AHERI_220	14:35	15:15	0:40	LINE CLEAR AVAILED
3033	17-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F2-BAGALKOT-2	BAGALKOT_220	07:10	07:22	0:12	TRIPPED ON FAULT
3034	17-Dec-24	BAGALKOTE	220	LINE	BELGAUM- KANABARGI1	BELGAUM_220	04:59	09:39	4:40	TRIPPED ON FAULT
3035	17-Dec-24	BAGALKOTE	220	LINE	BELGAUM- KANABARGI2	BELGAUM_220	05:01	05:57	0:56	TRIPPED ON FAULT
3036	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220-HUDLI(ANKALAGI)	BELGAUM_220	04:30	04:54	0:24	LINE CLEAR AVAILED
3037	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- HUKKERI	BELGAUM_220	04:44	05:34	0:50	LINE CLEAR AVAILED
3038	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- KANABARGI LAYOUT	BELGAUM_220	04:30	04:54	0:24	LINE CLEAR AVAILED
3039	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- MACHE EXPRESS	BELGAUM_220	04:30	04:38	0:08	LINE CLEAR AVAILED
3040	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- NEHRU NAGAR	BELGAUM_220	04:30	04:54	0:24	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3041	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- VODAGOAN	BELGAUM_220	04:30	04:38	0:08	LINE CLEAR AVAILED
3042	17-Dec-24	BAGALKOTE	110	LINE	BELGAUM220- VODAGOAN	BELGAUM_220	21:56	22:14	0:18	TRIPPED ON FAULT
3043	17-Dec-24	BAGALKOTE	220	LINE	BIDNAL- NAGJHARI2	BIDNAL_220	8:00	16:56	8:56	TRIPPED ON FAULT
3044	17-Dec-24	BAGALKOTE	220	LINE	BIDNAL- SHIGGOAN2	BIDNAL_220	17:12	19:18	2:06	LINE CLEAR AVAILED
3045	17-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220- SANKESHWAR	CHIKKODI_220	05:08	05:14	0:06	LINE CLEAR AVAILED
3046	17-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220- SANKESHWAR	CHIKKODI_220	10:30	10:35	0:05	LINE CLEAR AVAILED
3047	17-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
3048	17-Dec-24	BAGALKOTE	110	LINE	HATTARAGI- HUKKERI(SANGAM SUGARS)	HATTARAGI_110	05:32	06:21	0:49	LINE CLEAR AVAILED
3049	17-Dec-24	BAGALKOTE	220	LINE	HAVERI- SHIGGOAN2	HAVERI_220	17:39	17:42	0:03	LINE CLEAR AVAILED
3050	17-Dec-24	BAGALKOTE	110	LINE	HAVERI220- BYADAGI	HAVERI_220	17:31	22:42	5:11	LINE CLEAR AVAILED
3051	17-Dec-24	BAGALKOTE	110	LINE	HAVERI220- HANGAL	HAVERI_220	17:40	17:49	0:09	LINE CLEAR AVAILED
3052	17-Dec-24	BAGALKOTE	110	LINE	HAVERI220- KNNL	HAVERI_220	09:40	11:32	1:52	LINE CLEAR AVAILED
3053	17-Dec-24	BAGALKOTE	110	LINE	HAVERI220- TILUVALLI	HAVERI_220	17:39	17:49	0:10	LINE CLEAR AVAILED
3054	17-Dec-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI3	HUBLI_220	14:11	16:26	2:15	LINE CLEAR AVAILED
3055	17-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3056	17-Dec-24	BAGALKOTE	110	LINE	HUKKERI- HATTARAGI(AEQUES)	HUKKERI_110	05:04	09:41	4:37	LINE CLEAR AVAILED
3057	17-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
3058	17-Dec-24	BAGALKOTE	110	LINE	JAMBAGI-MUDHOL(HALKI)	JAMBAGI_110	10:25	16:39	6:14	LINE CLEAR AVAILED
3059	17-Dec-24	BAGALKOTE	220	LINE	KANAGALA-F1(AEQU1)	KANAGALA_220	4:29	5:23	0:54	TRIPPED ON FAULT
3060	17-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
3061	17-Dec-24	BAGALKOTE	110	LINE	KUDACHI220- AINAPUR (YELPARAHATTI)	KUDACHI_220	20:05	20:41	0:36	TRIPPED ON FAULT
3062	17-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3063	17-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
3064	17-Dec-24	BAGALKOTE	110	LINE	SANKESHWAR-HUKKERI	SANKESHWAR_110	04:56	09:15	4:19	LINE CLEAR AVAILED
3065	17-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- BIDNAL	SHIGGOAN_220	17:29	19:18	1:49	LINE CLEAR AVAILED
3066	17-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3067	17-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
3068	17-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	05:27	06:13	00:46	TRIPPED ON FAULT
3069	17-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	SRINIVASAPURA 220	07:20	08:19	00:59	MAIN SUPPLY FAILURE
3070	17-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 2	SRINIVASAPURA 220	07:20	08:19	00:59	MAIN SUPPLY FAILURE
3071	17-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
3072	17-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3073	17-Dec-24	BANGALORE	220	LINE	220KV HOODY 400 - EPIP 220	NO STATION AFFECTED	11:12	13:50	02:38	LINE CLEAR AVAILED
3074	17-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3075	17-Dec-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	NO STATION AFFECTED	10:00	15:13	05:13	LINE CLEAR AVAILED
3076	17-Dec-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 -2	NO STATION AFFECTED	08:52	11:55	03:03	LINE CLEAR AVAILED
3077	17-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
3078	17-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	CHINTAMANI 220	07:20	08:07	00:47	MAIN SUPPLY FAILURE
3079	17-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 2	CHINTAMANI 220	07:20	08:07	00:47	MAIN SUPPLY FAILURE
3080	17-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 1	T GOLLAHALLI 220	07:20	08:29	01:09	MAIN SUPPLY FAILURE
3081	17-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 2	T GOLLAHALLI 220	07:20	08:29	01:09	MAIN SUPPLY FAILURE
3082	17-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	TIMES OF INDIA(EHT), BMRCL, YARANDANAHALLI 220	11:40	23:59	12:19	LINE CLEAR AVAILED
3083	17-Dec-24	BANGALORE	400	LINE	400KV NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	09:20	19:02	09:42	LINE CLEAR AVAILED
3084	17-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	15:13	15:29	00:16	TRIPPED ON FAULT
3085	17-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	10:00	15:13	05:13	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3086	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - 66KV CHINTAMANI	CHINTAMANI 66, RAILWAY TRACTION 66/25KV (EHT)	07:20	08:20	01:00	MAIN SUPPLY FAILURE
3087	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	07:20	08:25	01:05	MAIN SUPPLY FAILURE
3088	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	07:20	08:25	01:05	MAIN SUPPLY FAILURE
3089	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLI	IRGAMPALLI, M GOLLAHALLI	07:20	08:25	01:05	MAIN SUPPLY FAILURE
3090	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - K RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	07:20	08:04	00:44	MAIN SUPPLY FAILURE
3091	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	11:00	11:06	00:06	LINE CLEAR AVAILED
3092	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	07:20	08:20	01:00	MAIN SUPPLY FAILURE
3093	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	07:20	08:24	01:04	MAIN SUPPLY FAILURE
3094	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, Y HUNASENAHALLI	07:20	08:20	01:00	MAIN SUPPLY FAILURE
3095	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	TADIGOL CROSS	07:20	08:28	01:08	MAIN SUPPLY FAILURE
3096	17-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	07:20	08:13	00:53	MAIN SUPPLY FAILURE
3097	17-Dec-24	BANGALORE	66	LINE	66KV DRDO - T D HALLI (MALLASANDRA)	DRDO(EHT)	08:38	08:40	00:02	LINE CLEAR AVAILED
3098	17-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - ALIPURA	ALIPURA, THONDEBHAVI	08:05	08:28	00:23	LOAD CURTAILMENT
3099	17-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	07:25	08:05	00:40	LOAD CURTAILMENT
3100	17-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	07:25	08:28	01:03	LOAD CURTAILMENT
3101	17-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	08:05	08:28	00:23	LOAD CURTAILMENT
3102	17-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	17:22	17:32	00:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3103	17-Dec-24	BANGALORE	66	LINE	66KV GUNDLU KOTHUR - BAGEPALLI	NO STATION AFFECTED	06:40	06:50	00:10	TRIPPED ON FAULT
3104	17-Dec-24	BANGALORE	66	LINE	66KV K RAGHUTTAHALLI - BOMMEPALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	08:26	08:29	00:03	LINE CLEAR AVAILED
3105	17-Dec-24	BANGALORE	66	LINE	66KV KOLAR 220 - TAMAKA - DRDO	NO STATION AFFECTED	07:54	07:57	00:03	LINE CLEAR AVAILED
3106	17-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARIYOTHI (TAP)	NO STATION AFFECTED	13:50	13:53	00:03	LINE CLEAR AVAILED
3107	17-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:43	18:48	00:05	LINE CLEAR AVAILED
3108	17-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	08:49	08:59	00:10	TRIPPED ON FAULT
3109	17-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	NO STATION AFFECTED	17:35	17:40	00:05	LINE CLEAR AVAILED
3110	17-Dec-24	BANGALORE	66	LINE	66KV NAGANATHIPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY PH2 SEC 2, CHOKKASANDRA	07:13	07:31	00:18	TRIPPED ON FAULT
3111	17-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	08:15	08:26	00:11	TRIPPED ON FAULT
3112	17-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KHB DC_SC_DG1	KHB	12:29	12:40	00:11	TRIPPED ON FAULT
3113	17-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA, BG ROAD	11:32	11:54	00:22	TRIPPED ON FAULT
3114	17-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI	10:20	15:12	04:52	LINE CLEAR AVAILED
3115	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - G KODIHALLI	G KODIHALLI	07:20	08:27	01:07	MAIN SUPPLY FAILURE
3116	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 1	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	07:20	08:25	01:05	MAIN SUPPLY FAILURE
3117	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 2	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	07:20	08:25	01:05	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3118	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	07:20	08:25	01:05	MAIN SUPPLY FAILURE
3119	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 1	SRINIVASAPURA 66	07:20	08:24	01:04	MAIN SUPPLY FAILURE
3120	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 2	SRINIVASAPURA 66	07:20	08:24	01:04	MAIN SUPPLY FAILURE
3121	17-Dec-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASANUR	DALASANUR, YELDUR, MALLASANDRA DRDO(EHT)	07:20	08:33	01:13	MAIN SUPPLY FAILURE
3122	17-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	18:35	18:54	00:19	LINE CLEAR AVAILED
3123	17-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	12:29	12:50	00:21	TRIPPED ON FAULT
3124	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	07:20	08:35	01:15	MAIN SUPPLY FAILURE
3125	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL, ADB SOLAR, K&C VALLEY PUMP HOUSE	07:20	08:35	01:15	MAIN SUPPLY FAILURE
3126	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML	07:20	08:34	01:14	MAIN SUPPLY FAILURE
3127	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	07:20	08:34	01:14	MAIN SUPPLY FAILURE
3128	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	07:20	08:37	01:17	MAIN SUPPLY FAILURE
3129	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	07:20	08:34	01:14	MAIN SUPPLY FAILURE
3130	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BAIRKUR	07:20	08:42	01:22	MAIN SUPPLY FAILURE
3131	17-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	THAYALUR, MN HALLI, NG HULKUR	07:20	08:35	01:15	MAIN SUPPLY FAILURE
3132	17-Dec-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	06:40	06:50	00:10	TRIPPED ON FAULT
3133	17-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A- BIOCON (ELECTRONIC CITY 2)	BIOCON	06:22	07:15	00:53	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3134	17-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	11:31	11:53	00:22	LINE CLEAR AVAILED
3135	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ANJANAPURA	11:40	11:45	00:05	LINE CLEAR AVAILED
3136	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BAGEPALLI	16:00	16:05	00:05	LINE CLEAR AVAILED
3137	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JAYADEVA	17:53	18:22	00:29	TRIPPED ON FAULT
3138	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KHB	12:29	12:45	00:16	TRIPPED ON FAULT
3139	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBALAGODU 220	10:05	14:55	04:50	LINE CLEAR AVAILED
3140	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MEI LAYOUT	11:35	11:40	00:05	LINE CLEAR AVAILED
3141	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NAGANATHPURA 220	09:57	12:01	02:04	LINE CLEAR AVAILED
3142	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	PLATINUM CITY	01:30	01:37	00:07	TRIPPED ON FAULT
3143	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	10:27	10:31	00:04	LINE CLEAR AVAILED
3144	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	15:27	15:32	00:05	LINE CLEAR AVAILED
3145	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SRINIVASAPURA 220	07:20	08:23	01:03	MAIN SUPPLY FAILURE
3146	17-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SRINIVASAPURA 220	05:27	06:13	00:46	TRIPPED ON FAULT
3147	17-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SRINIVASAPURA 220	07:20	08:22	01:02	MAIN SUPPLY FAILURE
3148	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	T GOLLAHALLI 220	07:20	08:29	01:09	MAIN SUPPLY FAILURE
3149	17-Dec-24	BANGALORE	220	TRANSFORMER	HV1	T GOLLAHALLI 220	07:20	08:29	01:09	MAIN SUPPLY FAILURE
3150	17-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	22:44	23:12	00:28	LINE CLEAR AVAILED
3151	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	16:00	16:45	00:45	LINE CLEAR AVAILED
3152	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KHB	12:29	12:45	00:16	TRIPPED ON FAULT
3153	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KUMBALAGODU 220	10:05	14:55	04:50	LINE CLEAR AVAILED
3154	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	RMZ	12:05	12:08	00:03	LINE CLEAR AVAILED
3155	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	10:27	10:31	00:04	LINE CLEAR AVAILED
3156	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	15:27	15:32	00:05	LINE CLEAR AVAILED
3157	17-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SRINIVASAPURA 220	07:20	08:22	01:02	MAIN SUPPLY FAILURE
3158	17-Dec-24	BANGALORE	220	TRANSFORMER	HV2	T GOLLAHALLI 220	07:20	08:29	01:09	MAIN SUPPLY FAILURE
3159	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	22:44	23:10	00:26	LINE CLEAR AVAILED
3160	17-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	11:31	11:53	00:22	LINE CLEAR AVAILED
3161	17-Dec-24	BANGALORE	66	TRANSFORMER	HV3	KUMBALAGODU 220	10:05	14:55	04:50	LINE CLEAR AVAILED
3162	17-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	11:31	11:53	00:22	LINE CLEAR AVAILED
3163	17-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	11:31	11:52	00:21	LINE CLEAR AVAILED
3164	17-Dec-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERDONA_110,BENNUR_110	12:37	12:47	00:10	TRIPPED ON FAULT
3165	17-Dec-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERDONA_110,BENNUR_110	14:43	14:53	00:10	TRIPPED ON FAULT
3166	17-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALAND_110	11:25	17:50	06:25	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3167	17-Dec-24	GULBARGA	66	TRANSFORMER	HV1	GUDEKOTE_66	11:50	14:00	02:10	LINE CLEAR AVAILED
3168	17-Dec-24	GULBARGA	110	TRANSFORMER	HV1	YADGIR_110	12:50	13:10	00:20	TRIPPED ON FAULT
3169	17-Dec-24	GULBARGA	110	TRANSFORMER	HV1&2,3	KOPPAL_110	09:05	17:58	08:53	LINE CLEAR AVAILED
3170	17-Dec-24	GULBARGA	66	TRANSFORMER	HV2	GUDEKOTE_66	11:50	13:45	01:55	LINE CLEAR AVAILED
3171	17-Dec-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY TRACTION	KHANAPUR_110	05:39	05:49	00:10	TRIPPED ON FAULT
3172	17-Dec-24	GULBARGA	110	LINE	KOPPAL-HALWARTHY 1&2	KOPPAL_110	09:05	11:25	02:20	LINE CLEAR AVAILED
3173	17-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALUVAGALU_66,LIS NITTUR,HARIVI_66,	11:21	11:26	00:05	TRIPPED ON FAULT
3174	17-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALUVAGALU_66,LIS NITTUR,HARIVI_66,	07:13	07:30	00:17	TRIPPED ON FAULT
3175	17-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
3176	17-Dec-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI	CHINCHOLI_110	17:49	18:41	00:52	LINE CLEAR AVAILED
3177	17-Dec-24	GULBARGA	110	LINE	SHAHABAD-MORATAGI	MORATAGI_110	01:20	01:32	00:12	TRIPPED ON FAULT
3178	17-Dec-24	GULBARGA	110	LINE	SULEKAL-KANAKAGIRI	KANAKAGIRI_110,NAVALI_110,	15:45	17:25	01:40	LINE CLEAR AVAILED
3179	17-Dec-24	HASAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	09:00	17:13	08:13	LINE CLEAR AVAILED
3180	17-Dec-24	HASAN	66	LINE	HNPR2-HASS1	HNPUA_220	11:26	14:41	03:15	LINE CLEAR AVAILED
3181	17-Dec-24	HASAN	66	LINE	HNPR2-HNPR1	HNPUA_220	10:34	14:41	04:07	LINE CLEAR AVAILED
3182	17-Dec-24	HASAN	66	LINE	HNPUA-HASSAN	HNPUA_66	10:29	17:03	06:34	LINE CLEAR AVAILED
3183	17-Dec-24	HASAN	66	LINE	HNPUA-RAMNATHPURA	HNPUA_66	10:29	17:03	06:34	LINE CLEAR AVAILED
3184	17-Dec-24	HASAN	66	LINE	HNPUA-SOMANAHALLI	HNPUA_66	10:29	17:03	06:34	LINE CLEAR AVAILED
3185	17-Dec-24	HASAN	110	LINE	HULICA-HSNGD	HULICAL_110	11:02	14:50	03:48	LINE CLEAR AVAILED
3186	17-Dec-24	HASAN	66	TRANSFORMER	HV1	HANGARAHALLI_66	10:16	14:50	04:34	LINE CLEAR AVAILED
3187	17-Dec-24	HASAN	66	TRANSFORMER	HV1	HNPUA_66	10:29	17:03	06:34	LINE CLEAR AVAILED
3188	17-Dec-24	HASAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	05:53	08:56	03:03	TRIPPED ON FAULT
3189	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HANGARAHALLI_66	10:17	14:49	04:32	LINE CLEAR AVAILED
3190	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HNPUA_66	10:29	17:03	06:34	LINE CLEAR AVAILED
3191	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	05:38	05:47	00:09	TRIPPED ON FAULT
3192	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	06:31	06:41	00:10	TRIPPED ON FAULT
3193	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	10:11	12:28	02:17	TRIPPED ON FAULT
3194	17-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	15:11	16:28	01:17	TRIPPED ON FAULT
3195	17-Dec-24	HASAN	66	TRANSFORMER	HV2	KANDLI_66	14:47	15:07	00:20	LINE CLEAR AVAILED
3196	17-Dec-24	HASAN	110	TRANSFORMER	HV2	KEMAR_220	11:18	12:40	01:22	TRIPPED ON FAULT
3197	17-Dec-24	HASAN	220	TRANSFORMER	HV2	PUTTUR_220	09:05	17:44	08:39	LINE CLEAR AVAILED
3198	17-Dec-24	HASAN	66	TRANSFORMER	HV2	SATHENAHALLI_66	11:14	11:30	00:16	LINE CLEAR AVAILED
3199	17-Dec-24	HASAN	110	TRANSFORMER	HV3	MANIPAL_110	10:31	15:16	04:45	TRIPPED ON FAULT
3200	17-Dec-24	HASAN	110	TRANSFORMER	HV3	MANIPAL_110	14:53	15:16	00:23	TRIPPED ON FAULT
3201	17-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
3202	17-Dec-24	HASAN	110	TRANSFORMER	HV4	MANIPAL_110	09:54	15:19	05:25	LINE CLEAR AVAILED
3203	17-Dec-24	HASAN	220	LINE	KEMAR-BAJPE1	KEMAR_220	10:24	18:57	08:33	LINE CLEAR AVAILED
3204	17-Dec-24	HASAN	110	LINE	KEMAR-KARKALA	KEMAR_220	14:04	18:16	04:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3205	17-Dec-24	HASAN	110	TRANSFORMER	LV2	PUTTUR_220	09:04	17:45	08:41	LINE CLEAR AVAILED
3206	17-Dec-24	HASAN	220	LINE	MRSSHM-VARAH13	MRSMG_220	10:01	13:42	03:41	LINE CLEAR AVAILED
3207	17-Dec-24	HASAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	10:24	18:57	08:33	LINE CLEAR AVAILED
3208	17-Dec-24	HASAN	220	LINE	PUTTUR-KEMAR1	PUTTUR_220	17:12	17:18	00:06	TRIPPED ON FAULT
3209	17-Dec-24	HASAN	66	LINE	SOMNHL-GDNEHALI	SOMANAHALLI_66	10:30	12:55	02:25	LINE CLEAR AVAILED
3210	17-Dec-24	HASAN	220	LINE	VARAH1-SHMG3	gen_varahi	10:01	13:43	03:42	LINE CLEAR AVAILED
3211	17-Dec-24	MYSORE	66	LINE	AJJIPURA-COWDALLI	COWDALLI_66 MARTAHALLI_66 RAMAPURA MYS 66	00:55	01:00	00:05	TRIPPED ON FAULT
3212	17-Dec-24	MYSORE	66	LINE	BEGUR 220-HARAVE	NO STATIONS EFFECTED	06:15	06:15		TRIPPED ON FAULT
3213	17-Dec-24	MYSORE	66	LINE	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66	11:20	15:15	03:55	LINE CLEAR AVAILED
3214	17-Dec-24	MYSORE	66	LINE	BESAGARAHALLI-KOPPA	BESAGARAHALLI_66	11:25	15:15	03:50	LINE CLEAR AVAILED
3215	17-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
3216	17-Dec-24	MYSORE	66	LINE	DEVNUR(N'GUD)-BAS-1	NO STATIONS EFFECTED	10:01	16:56	06:54	LINE CLEAR AVAILED
3217	17-Dec-24	MYSORE	66	LINE	DEVNUR(N'GUD)-BAS-2	NO STATIONS EFFECTED	10:04	16:56	06:51	LINE CLEAR AVAILED
3218	17-Dec-24	MYSORE	66	LINE	DEVNUR(N'GUD)-GOLLUR	DEVANOORNGUDU_66	10:03	16:59	06:55	LINE CLEAR AVAILED
3219	17-Dec-24	MYSORE	66	LINE	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	10:01	18:20	08:19	LINE CLEAR AVAILED
3220	17-Dec-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	BASARALU_66	10:05	18:09	08:04	LINE CLEAR AVAILED
3221	17-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
3222	17-Dec-24	MYSORE	66	LINE	HEBBANI-SFC-3	NO STATIONS EFFECTED	10:41	11:53	01:12	LINE CLEAR AVAILED
3223	17-Dec-24	MYSORE	66	LINE	HEBBANI-SFC-4	NO STATIONS EFFECTED	10:41	11:53	01:12	LINE CLEAR AVAILED
3224	17-Dec-24	MYSORE	66	LINE	HEBBANI-SFC-5	NO STATIONS EFFECTED	10:41	11:53	01:12	LINE CLEAR AVAILED
3225	17-Dec-24	MYSORE	66	LINE	HOOTAGALLY-BARC LINE-1 EHT	NO STATIONS EFFECTED	12:22	12:42	00:19	TRIPPED ON FAULT
3226	17-Dec-24	MYSORE	66	LINE	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	11:40	19:29	07:49	LINE CLEAR AVAILED
3227	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	BESAGARAHALLI_66	10:00	16:15	06:15	LINE CLEAR AVAILED
3228	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORMYS_66	10:04	18:20	08:16	LINE CLEAR AVAILED
3229	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORNGUDU_66	10:06	18:26	08:20	LINE CLEAR AVAILED
3230	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	DODDABYADARAHALLI_66	13:45	15:29	01:44	LINE CLEAR AVAILED
3231	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	HONAGANURU_66	04:45	15:38	10:53	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3232	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	HUNSUR_66	10:05	18:10	08:05	LINE CLEAR AVAILED
3233	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	MANDAKALLI_66	10:00	15:43	05:43	LINE CLEAR AVAILED
3234	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	MANDGERE_66	13:15	13:25	00:10	MAIN SUPPLY FAILURE
3235	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	MEGALAPURA_66	10:08	17:25	07:16	LINE CLEAR AVAILED
3236	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	RAJEEVNAGARA_66	10:05	17:25	07:20	LINE CLEAR AVAILED
3237	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANIVARASANTHE_66	11:17	17:07	05:50	LINE CLEAR AVAILED
3238	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3239	17-Dec-24	MYSORE	66	TRANSFORMER	HV1	VAJAMANGALA_220	11:40	17:38	05:58	LINE CLEAR AVAILED
3240	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	BESAGARAHALLI_66	10:00	16:15	06:15	LINE CLEAR AVAILED
3241	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	09:19	09:45	00:25	LINE CLEAR AVAILED
3242	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORMYS_66	10:04	18:20	08:16	LINE CLEAR AVAILED
3243	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	10:05	18:26	08:20	LINE CLEAR AVAILED
3244	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	DODDABYADARAHALLI_66	15:30	16:40	01:09	LINE CLEAR AVAILED
3245	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	10:05	18:10	08:05	LINE CLEAR AVAILED
3246	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	10:06	17:25	07:18	LINE CLEAR AVAILED
3247	17-Dec-24	MYSORE	66	TRANSFORMER	HV2	RAJEEVNAGARA_66	10:05	17:25	07:20	LINE CLEAR AVAILED
3248	17-Dec-24	MYSORE	66	LINE	KABBALLI-CLEAN SOLAR EHT	NO STATIONS EFFECTED	00:10	00:20	00:10	TRIPPED ON FAULT
3249	17-Dec-24	MYSORE	220	LINE	KADAKOLA-HOOTAGALLY	NO STATIONS EFFECTED	09:50	11:38	01:47	LINE CLEAR AVAILED
3250	17-Dec-24	MYSORE	66	LINE	KADAKOLA-KOPALUR(MANDAKALLI)	MANDAKALLI_66	10:20	12:16	01:56	LINE CLEAR AVAILED
3251	17-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3252	17-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3253	17-Dec-24	MYSORE	66	LINE	KM DODDI-SCSL	NO STATIONS EFFECTED	11:19	11:52	00:33	LINE CLEAR AVAILED
3254	17-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
3255	17-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
3256	17-Dec-24	MYSORE	66	LINE	KUSHALANAGARA 220-MADIKERI	MADIKERI_66	10:54	18:14	07:19	LINE CLEAR AVAILED
3257	17-Dec-24	MYSORE	66	LINE	MADIKERI-SUNTTIKOPA	MADIKERI_66	10:00	18:24	08:24	LINE CLEAR AVAILED
3258	17-Dec-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	MADIKERI_66	10:00	18:18	08:18	LINE CLEAR AVAILED
3259	17-Dec-24	MYSORE	66	TRANSFORMER	MANDGERE-HV2	MANDGERE_66	13:15	13:25	00:10	MAIN SUPPLY FAILURE
3260	17-Dec-24	MYSORE	66	LINE	MEGHALAPURA-VAJMANGALA	MEGALAPURA_66	12:03	17:25	05:22	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3261	17-Dec-24	MYSORE	66	LINE	NAGAMANGALA-NAGAMANGALA 220	NO STATIONS EFFECTED	12:10	13:10	01:00	LINE CLEAR AVAILED
3262	17-Dec-24	MYSORE	66	LINE	RK NAGARA-KOPALUR(MANDAKALLI)	MANDAKALLI_66	10:04	15:41	05:37	LINE CLEAR AVAILED
3263	17-Dec-24	MYSORE	66	LINE	SANTHE SARAGUR-KALSON(MASTER POWER)	NO STATIONS EFFECTED	06:45	07:09	00:24	TRIPPED ON FAULT
3264	17-Dec-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	10:40	10:59	00:18	LINE CLEAR AVAILED
3265	17-Dec-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	11:30	11:56	00:26	LINE CLEAR AVAILED
3266	17-Dec-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	10:40	10:55	00:15	LINE CLEAR AVAILED
3267	17-Dec-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	11:37	11:55	00:17	LINE CLEAR AVAILED
3268	17-Dec-24	MYSORE	66	LINE	THALAKADU-ADHANI	NO STATIONS EFFECTED	18:25	21:12	02:47	LINE CLEAR AVAILED
3269	17-Dec-24	MYSORE	66	LINE	THUMBLA-MEGALAPURA	MEGALAPURA_66	11:35	17:00	05:25	LINE CLEAR AVAILED
3270	17-Dec-24	MYSORE	66	LINE	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	10:15	17:19	07:04	LINE CLEAR AVAILED
3271	17-Dec-24	MYSORE	66	LINE	VC FORM-NAGAMANGALA	NAGAMANGALA_66	02:48	02:59	00:11	TRIPPED ON FAULT
3272	17-Dec-24	MYSORE	66	LINE	VC FORM-NAGAMANGALA	NO STATIONS EFFECTED	13:20	13:35	00:15	LINE CLEAR AVAILED
3273	17-Dec-24	TUMKUR	66	LINE	MADURE_220 HALURAMESWARA_220kv	HALURAMESWARA_66, HOSADURGA_66 MADADKERE_66	12:10	12:35	0:25	LINE CLEAR AVAILED
3274	17-Dec-24	TUMKUR	66	LINE	220kv Guttur 2 line- DAVANGERE SRS 220	DAVANGERE 220kv & O/G Lines	11:11	12:37	1:26	LINE CLEAR AVAILED
3275	17-Dec-24	TUMKUR	66	LINE	220kv Guttur 3 line- DAVANGERE SRS 220	DAVANGERE 220kv & O/G Lines	19:00 (17.12.2024)	NOT YET CHARGED		LINE CLEAR AVAILED
3276	17-Dec-24	TUMKUR	220	LINE	220KV GUTTUR 3 LINE- DAVANGERE SRS 220	DAVANGERE 220kv & O/G LINES	11:50	19:00	7:10	TRIPPED ON FAULT
3277	17-Dec-24	TUMKUR	220	LINE	220KV GUTTUR 3 LINE- DAVANGERE SRS 220	DAVANGERE 220kv & O/G LINES	18:47	23:59	5:12	LINE CLEAR AVAILED
3278	17-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,C HILUR	6:25	6:35	0:10	TRIPPED ON FAULT
3279	17-Dec-24	TUMKUR	400	LINE	400kv HIREMALLANAHOLE- 220kv CHITRADURGA-1	220kv CHITRADURGA-1	16:12	17:51	1:39	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3280	17-Dec-24	TUMKUR	66	LINE	66KV KURUBARAHALLI-66KV TELGI LINE 2	66KV KURUBARAHALLI,IPP SHAMANUR SUGARS	11:20	11:30	0:10	TRIPPED ON FAULT
3281	17-Dec-24	TUMKUR	66	LINE	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	12:07	12:12	0:05	LINE CLEAR AVAILED
3282	17-Dec-24	TUMKUR	66	LINE	BENKIKERE 220kV-NALLUR	NALLUR_66	12:06	12:13	0:07	LINE CLEAR AVAILED
3283	17-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA_66-PANDARAHALLI LINE-1	BHARAMASAGARA_66,SIRIGERE_66, VIJAPURA_66	10:20	10:53	0:33	LINE CLEAR AVAILED
3284	17-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA_66-PANDARAHALLI LINE-1	BHARAMASAGARA_66,SIRIGERE_66, VIJAPURA_66	7:30	7:45	0:15	MAIN SUPPLY FAILURE
3285	17-Dec-24	TUMKUR	66	LINE	CHANNAGIRI-LINGADAHALLI 66KV	CHANNAGIRI_66	11:25 (16.12.2024)	12:38 (18.12.2024)	2DAYS 1:15	LINE CLEAR AVAILED
3286	17-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR 66. SOKKE 66	6:45	6:55	0:10	MAIN SUPPLY FAILURE
3287	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS - HARIHARA-HOSPET_66	HARIHARA_66	11:50	12:50	1:00	LINE CLEAR AVAILED
3288	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	-66KV ANAGODU , ATTIGERE	11:50	12:49	0:59	TRIPPED ON FAULT
3289	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 1 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	11:50	12:20	0:30	TRIPPED ON FAULT
3290	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	11:50	12:20	0:30	TRIPPED ON FAULT
3291	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	14:16	18:05	3:49	TRIPPED ON FAULT
3292	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE 66	MELLEKATTE_66, KADAJJI 66	11:50	12:50	1:00	LINE CLEAR AVAILED
3293	17-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS_220KV-DAVANGERE 66	DAVANAGERE_66	11:50	12:23	0:33	LINE CLEAR AVAILED
3294	17-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	15:40 (30.11.2024)	17:40(17.12.2024)	17DAYS, 02:00	LINE CLEAR AVAILED
3295	17-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:42 (30.11.2024)	17:44(17.12.2024)	17 DAYS 02:04	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3296	17-Dec-24	TUMKUR	400	LINE	ICT-1400kV HIREMALLANAHOLE	400kV HIREMALLANAHOLE	10:37	14:26	3:49	LINE CLEAR AVAILED
3297	17-Dec-24	TUMKUR	66	LINE	KB CROSS 220KV- HANDANKERE_110	SHETTIKERE, HANDANKERE, MATHIGATTA GATE, HULIYAR, DODDENNEGERE 66KV NITRAHALLI,	8:10	8:30	0:20	LINE CLEAR AVAILED
3298	17-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220- NITRAHALLI_66	PURUVARA	16:06	16:16	0:10	TRIPPED ON FAULT
3299	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 100MVA ANTHRASANAHALLI 220KV	ANTHRASANAHALLI 220KV	16:50	17:15	0:25	LINE CLEAR AVAILED
3300	17-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA KIADB 220KV	KIADB 220KV	13:18	15:25	2:07	LINE CLEAR AVAILED
3301	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA AMRUTHUR_66KV	AMRUTHUR_66KV	17:34	18:35	1:01	LINE CLEAR AVAILED
3302	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5 MVA MATHOD_66KV	MATHOD_66KV	5:25	5:35	0:10	TRIPPED ON FAULT
3303	17-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 20 MVA KIADB 220KV	KIADB 220KV	11:59	12:43	0:44	LINE CLEAR AVAILED
3304	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA NIDSLE_66KV	NIDSALE_66	10:20	16:20	6:00	LINE CLEAR AVAILED
3305	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA P.D.KOTE_66KV	P.D.KOTE_66	20:08	20:15	0:07	TRIPPED ON FAULT
3306	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA RAMPURA_66KV	RAMPURA_66KV	21:53	22:01	0:08	TRIPPED ON FAULT
3307	17-Dec-24	TUMKUR	220	TRANSFORMER	TR-2 100MVA KIADB 220KV	KIADB 220KV	12:25	13:09	0:44	LINE CLEAR AVAILED
3308	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA AMRUTHUR_66KV	AMRUTHUR_66KV	17:34	18:35	1:01	LINE CLEAR AVAILED
3309	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5 MVA BILICHODU- 66KV	BILICHODU_66KV	12:05	12:10	0:05	TRIPPED ON FAULT
3310	17-Dec-24	TUMKUR	220	TRANSFORMER	TR-2 20 MVA KIADB 220KV	KIADB 220KV	13:32	16:26	2:54	LINE CLEAR AVAILED
3311	17-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 8 MVA NIDSLE_66KV	NIDSALE_66	10:20	16:20	6:00	LINE CLEAR AVAILED
3312	18-Dec-24	BAGALKOTE	220	LINE	BIDNAL-TADASA1	BIDNAL_220	10:51	16:29	5:38	LINE CLEAR AVAILED
3313	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NAREGAL_110	23:20 (17.12.2024)	16:35 (18.12.2024)	17:15	TRIPPED ON FAULT
3314	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SHIRGOAN_110	15:33	16:10	0:37	LINE CLEAR AVAILED
3315	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	HUBLI_220	10:37	17:32	6:55	LINE CLEAR AVAILED
3316	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KAVALWADA_110	11:53	17:25	5:32	LINE CLEAR AVAILED
3317	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SALAHALLI_110	05:34	11:23	5:49	TRIPPED ON FAULT
3318	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	HONNAVAR_110	10:00	14:22	4:22	LINE CLEAR AVAILED
3319	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KAGWAD_110	11:26	12:26	1:00	LINE CLEAR AVAILED
3320	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KUD DHARWAD_110	11:58	12:05	0:07	LINE CLEAR AVAILED
3321	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	CHANDKAVATE_110	04:27	04:34	0:07	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3322	18-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	TIKOTA_110	11:14	11:16	0:02	LINE CLEAR AVAILED
3323	18-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3324	18-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	VAJARAMATTI_220	15:42	17:06	1:24	LINE CLEAR AVAILED
3325	18-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3326	18-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	VAJARAMATTI_220	15:42	17:08	1:26	LINE CLEAR AVAILED
3327	18-Dec-24	BAGALKOTE	400	TRANSFORMER	400/220KV,ICT1(HV)	DHONI_400	09:50	20:26	10:36	LINE CLEAR AVAILED
3328	18-Dec-24	BAGALKOTE	220	LINE	400/220KV,ICT1(LV)	DHONI_400	09:49	20:29	10:40	LINE CLEAR AVAILED
3329	18-Dec-24	BAGALKOTE	110	LINE	ARGA- ANKOLA	ARGA_110	12:11	12:13	0:02	LINE CLEAR AVAILED
3330	18-Dec-24	BAGALKOTE	110	LINE	BIJAPUR-KIADB BIJAPUR2	BIJAPUR_220	12:37	12:48	0:11	TRIPPED ON FAULT
3331	18-Dec-24	BAGALKOTE	110	LINE	DAMBAL- GADAG2(SAMBAPUR ROAD)	DAMBAL_110	12:10	13:06	0:56	LINE CLEAR AVAILED
3332	18-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
3333	18-Dec-24	BAGALKOTE	110	LINE	HAVERI220-BYADAGI	HAVERI_220	14:13	21:17	7:04	LINE CLEAR AVAILED
3334	18-Dec-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA 1	HUBLI_220	12:53	15:09	2:16	TRIPPED ON FAULT
3335	18-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3336	18-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)			LINE CLEAR AVAILED
3337	18-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
3338	18-Dec-24	BAGALKOTE	220	LINE	MK HUBLI-NARENDRA2	MK HUBLI_220	12:39	15:11	2:32	TRIPPED ON FAULT
3339	18-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3340	18-Dec-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI1	NARENDRA_220	12:52	14:58	2:06	TRIPPED ON FAULT
3341	18-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
3342	18-Dec-24	BAGALKOTE	110	LINE	SAMBAPUR-DAMBAL	SAMBAPUR_110	12:10	13:06	0:56	LINE CLEAR AVAILED
3343	18-Dec-24	BAGALKOTE	110	LINE	SHIGGAON220- SAVANUR(GANJIGATTI)	SAVANUR_110	12:08	14:35	2:27	LINE CLEAR AVAILED
3344	18-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
3345	18-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TIK(TIKOTA)	TAKKALAKI_110	12:37	13:00	0:23	LINE CLEAR AVAILED
3346	18-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TIK(TIKOTA)	TAKKALAKI_110	13:08 (18.12.2024)			LINE CLEAR AVAILED
3347	18-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-WRD(WARADA SOLAR)	TAKKALAKI_110	13:35	21:57	8:22	LINE CLEAR AVAILED
3348	18-Dec-24	BAGALKOTE	110	LINE	THORVI- TIKOTA	THORVI_110	12:43	13:08	0:25	LINE CLEAR AVAILED
3349	18-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3350	18-Dec-24	BANGALORE	220	LINE	220KV A STATION 220 - NRS 220	NO STATION AFFECTED	11:01	20:11	09:10	LINE CLEAR AVAILED
3351	18-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
3352	18-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3353	18-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3354	18-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
3355	18-Dec-24	BANGALORE	220	LINE	220KV NRS 220 - VRUSHABHAVATI 220	NRS 220	10:40	17:35	06:55	LINE CLEAR AVAILED
3356	18-Dec-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - NRS 220	NRS 220	10:36	17:32	06:56	LINE CLEAR AVAILED
3357	18-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	23:58:00	18:59	04:59	LINE CLEAR AVAILED
3358	18-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	09:55	20:04	10:09	LINE CLEAR AVAILED
3359	18-Dec-24	BANGALORE	66	LINE	66KV BIDADI 220 - URAGAHALLI	URAGAHALLI	15:25	15:30	00:05	LINE CLEAR AVAILED
3360	18-Dec-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDAGUNTE, DIBBURAHALLI	17:05	17:25	00:20	TRIPPED ON FAULT
3361	18-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	17:05	17:17	00:12	TRIPPED ON FAULT
3362	18-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:24	10:29	00:05	LINE CLEAR AVAILED
3363	18-Dec-24	BANGALORE	66	LINE	66KV DCROSS - AIR EHT - RAJANKUNTE	RAJANKUNTE	13:45	13:50	00:05	LINE CLEAR AVAILED
3364	18-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	NO STATION AFFECTED	11:57	14:28	02:31	LINE CLEAR AVAILED
3365	18-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) DG3	NO STATION AFFECTED	11:15	19:25	08:10	LINE CLEAR AVAILED
3366	18-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	12:22	12:24	00:02	LINE CLEAR AVAILED
3367	18-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	LR BANDE	15:06	15:09	00:03	LINE CLEAR AVAILED
3368	18-Dec-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	NO STATION AFFECTED	11:47	13:19	01:32	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3369	18-Dec-24	BANGALORE	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	11:40	11:45	00:05	LINE CLEAR AVAILED
3370	18-Dec-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	10:17	16:29	06:12	LINE CLEAR AVAILED
3371	18-Dec-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	14:25	14:30	00:05	LINE CLEAR AVAILED
3372	18-Dec-24	BANGALORE	66	LINE	66KV KADABE HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220 _DG4	GRINDWELL NORTON(EHT)	15:20	15:43	00:23	TRIPPED ON FAULT
3373	18-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI	10:00	15:30	05:30	LINE CLEAR AVAILED
3374	18-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI	MELEHALLI, KEMPANAHALLI, URAGAHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGAL	07:29	07:36	00:07	TRIPPED ON FAULT
3375	18-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI	NO STATION AFFECTED	11:50	15:17	03:27	LINE CLEAR AVAILED
3376	18-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - URAGAHALLI	URAGAHALLI	11:15	11:25	00:10	LINE CLEAR AVAILED
3377	18-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	10:15	14:25	04:10	LINE CLEAR AVAILED
3378	18-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	09:05	09:10	00:05	LINE CLEAR AVAILED
3379	18-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	NO STATION AFFECTED	10:15	14:25	04:10	LINE CLEAR AVAILED
3380	18-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:44	18:49	00:05	LINE CLEAR AVAILED
3381	18-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66 _DG3	MANYATHA TECH PARK 66	11:05	13:39	02:34	LINE CLEAR AVAILED
3382	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - A.R.CIRCLE STATION (A2)	NO STATION AFFECTED	09:55	20:07	10:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3383	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY, PALLADIUM	10:26	17:57	07:31	LINE CLEAR AVAILED
3384	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISc	05:37	05:41	00:04	LINE CLEAR AVAILED
3385	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	NO STATION AFFECTED	09:55	20:04	10:09	LINE CLEAR AVAILED
3386	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - SHOBHA INDRAPRASTHA (A1)	NO STATION AFFECTED	09:55	19:57	10:02	LINE CLEAR AVAILED
3387	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	07:04	07:10	00:06	LINE CLEAR AVAILED
3388	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	NO STATION AFFECTED	09:55	18:08	08:13	LINE CLEAR AVAILED
3389	18-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	10:26	18:09	07:43	LINE CLEAR AVAILED
3390	18-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASALU	06:37	06:50	00:13	TRIPPED ON FAULT
3391	18-Dec-24	BANGALORE	66	LINE	66KV PRESTIGE SHANTHINIKETHAN - DARSHITHA EHT	NO STATION AFFECTED	14:25	16:00	01:35	LINE CLEAR AVAILED
3392	18-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANKUNTE	13:10	13:15	00:05	LINE CLEAR AVAILED
3393	18-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:13	12:24	00:11	LINE CLEAR AVAILED
3394	18-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:30	15:35	00:05	LINE CLEAR AVAILED
3395	18-Dec-24	BANGALORE	66	LINE	66KV SIDDALAGHATTA - MELUR	JANGAMKOTE, MELUR, VIJAYAPURA	10:05	10:10	00:05	LINE CLEAR AVAILED
3396	18-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI, SOUTH CITY	18:09	18:23	00:14	TRIPPED ON FAULT
3397	18-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR - AREHALLI	PADMANABHANAGARA	10:05	16:04	05:59	LINE CLEAR AVAILED
3398	18-Dec-24	BANGALORE	66	LINE	66KV VIJAYAPURA - JANGAMKOTE - MELUR	JANGAMKOTE, MELUR, VIJAYAPURA	07:00	07:08	00:08	LINE CLEAR AVAILED
3399	18-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	18:55	19:06	00:11	LINE CLEAR AVAILED
3400	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHELUR	11:05	11:20	00:15	TRIPPED ON FAULT
3401	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANYATHA TECH PARK 66	11:07	13:40	02:33	LINE CLEAR AVAILED
3402	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NRS 220	10:20	17:41	07:21	LINE CLEAR AVAILED
3403	18-Dec-24	BANGALORE	220	TRANSFORMER	HV1	NRS 220	10:31	17:34	07:03	LINE CLEAR AVAILED
3404	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	12:15	12:24	00:09	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3405	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	15:30	15:35	00:05	LINE CLEAR AVAILED
3406	18-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	12:15	15:35	03:20	LINE CLEAR AVAILED
3407	18-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	21:42	21:46	00:04	LINE CLEAR AVAILED
3408	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BAGEPALLI	16:00	16:05	00:05	LINE CLEAR AVAILED
3409	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MANYATHA TECH PARK 66	11:10	13:45	02:35	LINE CLEAR AVAILED
3410	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	11:20	17:40	06:20	LINE CLEAR AVAILED
3411	18-Dec-24	BANGALORE	220	TRANSFORMER	HV2	NRS 220	10:31	17:34	07:03	LINE CLEAR AVAILED
3412	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	21:42	21:46	00:04	LINE CLEAR AVAILED
3413	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAYALUR	10:30	10:50	00:20	LINE CLEAR AVAILED
3414	18-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	18:54	19:00	00:06	LINE CLEAR AVAILED
3415	18-Dec-24	BANGALORE	66	TRANSFORMER	HV3	MANYATHA TECH PARK 66	11:12	18:03	06:51	LINE CLEAR AVAILED
3416	18-Dec-24	BANGALORE	66	TRANSFORMER	HV3	NRS 220	12:20	17:41	05:21	LINE CLEAR AVAILED
3417	18-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	18:54	19:00	00:06	LINE CLEAR AVAILED
3418	18-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	18:56	19:00	00:04	LINE CLEAR AVAILED
3419	18-Dec-24	BANGALORE	66	TRANSFORMER	HV4	NRS 220	13:20	23:59	10:39	LINE CLEAR AVAILED
3420	18-Dec-24	BANGALORE	66	TRANSFORMER	HV5	NRS 220	14:20	17:40	03:20	LINE CLEAR AVAILED
3421	18-Dec-24	GULBARGA	110	LINE	BYAGWAT-WALKAMDINNI	WALKAMDINNI_110	06:18	06:23	00:05	TRIPPED ON FAULT
3422	18-Dec-24	GULBARGA	66	TRANSFORMER	HV1	CHORNUR_66	17:55	18:25	00:30	LINE CLEAR AVAILED
3423	18-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	07:15	07:20	00:05	TRIPPED ON FAULT
3424	18-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	07:45	07:55	00:10	TRIPPED ON FAULT
3425	18-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KANAKAGIRI_110	22:20	23:59	01:39	TRIPPED ON FAULT
3426	18-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KUDITINI_110	15:15	15:25	00:10	LINE CLEAR AVAILED
3427	18-Dec-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	MYLARA_66,GIRIYAPURA_66,MAGALA_66	06:30	06:35	00:05	TRIPPED ON FAULT
3428	18-Dec-24	GULBARGA	110	LINE	KAPNOOR-GULBARGA WEST1	GULBARGA WEST_110	10:30	16:57	06:27	LINE CLEAR AVAILED
3429	18-Dec-24	GULBARGA	220	LINE	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	18:37	19:52	01:15	TRIPPED ON FAULT
3430	18-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
3431	18-Dec-24	GULBARGA	110	LINE	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110, TURVIHAL_110	10:14	14:30	04:16	LINE CLEAR AVAILED
3432	18-Dec-24	HASAN	220	LINE	GOPALAP-HNPUR21	GOPALPURA_220	10:05	14:05	04:00	LINE CLEAR AVAILED
3433	18-Dec-24	HASAN	220	LINE	GOPALAP-HNPUR22	GOPALPURA_220	14:15	18:17	04:02	LINE CLEAR AVAILED
3434	18-Dec-24	HASAN	220	LINE	HGUNJE-KMR 2	HEGGUNJE_220	10:42	13:29	02:47	LINE CLEAR AVAILED
3435	18-Dec-24	HASAN	220	LINE	HNPR2-GPLPR1	HOLENARASIPURA_220	10:05	14:05	04:00	LINE CLEAR AVAILED
3436	18-Dec-24	HASAN	220	LINE	HNPR2-GPLPR2	HOLENARASIPURA_220	14:15	18:17	04:02	LINE CLEAR AVAILED
3437	18-Dec-24	HASAN	110	LINE	HULICA-HSNGD	HULICAL_110	10:05	17:05	07:00	LINE CLEAR AVAILED
3438	18-Dec-24	HASAN	110	LINE	HULICA-KVR	HULICAL_110	10:05	17:05	07:00	LINE CLEAR AVAILED
3439	18-Dec-24	HASAN	66	TRANSFORMER	HV1	ATTICHOWDENAHALLI_66	14:00	14:20	00:20	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3440	18-Dec-24	HASAN	66	TRANSFORMER	HV1	ATTICHOWDENAHALLI_66	15:50	16:30	00:40	MAIN SUPPLY FAILURE
3441	18-Dec-24	HASAN	66	TRANSFORMER	HV1	HANGRAHALLI_66	09:21	10:14	00:53	LINE CLEAR AVAILED
3442	18-Dec-24	HASAN	110	TRANSFORMER	HV1	HULICAL_110	10:05	17:05	07:00	LINE CLEAR AVAILED
3443	18-Dec-24	HASAN	110	TRANSFORMER	HV1	NANDIKUR_110	02:08	02:09	00:01	TRIPPED ON FAULT
3444	18-Dec-24	HASAN	110	TRANSFORMER	HV1	SINGATGERE_110	10:20	19:21	09:01	LINE CLEAR AVAILED
3445	18-Dec-24	HASAN	110	TRANSFORMER	HV2	BARANGI_110	10:08	17:11	07:03	LINE CLEAR AVAILED
3446	18-Dec-24	HASAN	66	TRANSFORMER	HV2	HOLALUR_66	12:16	12:30	00:14	TRIPPED ON FAULT
3447	18-Dec-24	HASAN	110	TRANSFORMER	HV2	KADUR_220	17:58	20:00	02:02	TRIPPED ON FAULT
3448	18-Dec-24	HASAN	110	TRANSFORMER	HV3	KAVOOR_220	10:19	16:34	06:15	LINE CLEAR AVAILED
3449	18-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
3450	18-Dec-24	HASAN	110	LINE	KADUR-NGNHL	KADUR_220	09:19	19:14	09:55	LINE CLEAR AVAILED
3451	18-Dec-24	HASAN	110	LINE	KADUR-YGTI	KADUR_220	09:20	19:11	09:51	LINE CLEAR AVAILED
3452	18-Dec-24	HASAN	220	LINE	KEMAR-BAJPE1	KEMAR_220	17:27	18:53	01:26	TRIPPED ON FAULT
3453	18-Dec-24	HASAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	07:17	18:53	11:36	LINE CLEAR AVAILED
3454	18-Dec-24	HASAN	110	LINE	KEMAR-BELMAN	KEMAR_220	09:14	13:05	03:51	LINE CLEAR AVAILED
3455	18-Dec-24	HASAN	220	LINE	KEMAR-HEGGUNJE	KEMAR_220	10:42	13:29	02:47	LINE CLEAR AVAILED
3456	18-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMG_2203	09:15	15:01	05:46	TRIPPED ON FAULT
3457	18-Dec-24	HASAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	17:27	18:53	01:26	TRIPPED ON FAULT
3458	18-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	07:16	18:53	11:37	LINE CLEAR AVAILED
3459	18-Dec-24	HASAN	220	LINE	SHRAVTY-SHIMOGA3	sharavathy_gen	09:15	15:01	05:46	TRIPPED ON FAULT
3460	18-Dec-24	HASAN	110	LINE	SINGATG-YAGATI	SINGATGERE_110	10:20	19:21	09:01	LINE CLEAR AVAILED
3461	18-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	16:54	17:00	00:06	LINE CLEAR AVAILED
3462	18-Dec-24	HASAN	66	LINE	UDAYAP- ATTICHOWDENAHALLI	UDAYAPURA_66	16:00	16:29	00:29	LINE CLEAR AVAILED
3463	18-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
3464	18-Dec-24	MYSORE	66	LINE	CR NAGARA-HARAVE	NO STATIONS EFFECTED	11:02	13:59	02:57	LINE CLEAR AVAILED
3465	18-Dec-24	MYSORE	66	LINE	CR NAGARA-MUGURU- KOLLEGALA	MUGUR_66	15:24	16:48	01:24	LINE CLEAR AVAILED
3466	18-Dec-24	MYSORE	66	LINE	CR NAGARA- TERAKANAMBI- GUNDLUPETE	TERAKANAMBE_66	10:13	18:17	08:04	LINE CLEAR AVAILED
3467	18-Dec-24	MYSORE	66	LINE	GUNDLUPETE-BEGURU 1	GUNDULPET_66	10:05	17:45	07:40	LINE CLEAR AVAILED
3468	18-Dec-24	MYSORE	66	LINE	GUNDLUPETE-BEGURU 2	GUNDULPET_66	10:05	17:45	07:40	LINE CLEAR AVAILED
3469	18-Dec-24	MYSORE	66	LINE	GUNDLUPETE-BHARGI- HANGLA	BHARGI_66 HANGLA_66	10:05	18:27	08:22	LINE CLEAR AVAILED
3470	18-Dec-24	MYSORE	66	LINE	GUNDLUPETE- BOMMALAPURA	BOMMALAPURA_66	10:05	18:17	08:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3471	18-Dec-24	MYSORE	66	LINE	GUNDLUPETE-KABBALLI	NO STATIONS EFFECTED	10:05	18:40	08:35	LINE CLEAR AVAILED
3472	18-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
3473	18-Dec-24	MYSORE	66	LINE	HEBBANI-SFC1	NO STATIONS EFFECTED	11:08	11:27	00:19	LINE CLEAR AVAILED
3474	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	10:05	17:45	07:40	LINE CLEAR AVAILED
3475	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	10:05	17:48	07:43	LINE CLEAR AVAILED
3476	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	KRNAGARA_66	10:20	16:35	06:15	LINE CLEAR AVAILED
3477	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	12:14	12:25	00:11	LINE CLEAR AVAILED
3478	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	14:43	14:47	00:03	LINE CLEAR AVAILED
3479	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3480	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	SHEELUNERE_66	14:25	14:40	00:15	LINE CLEAR AVAILED
3481	18-Dec-24	MYSORE	66	TRANSFORMER	HV1	SINDHUVALLI_66	10:10	18:30	08:20	LINE CLEAR AVAILED
3482	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	GUNDULPET_66	10:05	18:43	08:38	LINE CLEAR AVAILED
3483	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOPPA_66	10:05	17:48	07:43	LINE CLEAR AVAILED
3484	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	KRNAGARA_66	10:20	16:35	06:15	LINE CLEAR AVAILED
3485	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	NAGAMANGALA_66	12:14	12:25	00:11	LINE CLEAR AVAILED
3486	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	NAGAMANGALA_66	14:43	14:47	00:03	LINE CLEAR AVAILED
3487	18-Dec-24	MYSORE	66	TRANSFORMER	HV2	SINDHUVALLI_66	10:10	18:30	08:20	LINE CLEAR AVAILED
3488	18-Dec-24	MYSORE	66	TRANSFORMER	HV3	GUNDULPET_66	10:05	18:43	08:38	LINE CLEAR AVAILED
3489	18-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3490	18-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3491	18-Dec-24	MYSORE	66	LINE	KR NAGARA-BHERYA	NO STATIONS EFFECTED	14:25	16:30	02:05	LINE CLEAR AVAILED
3492	18-Dec-24	MYSORE	66	LINE	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	14:25	16:36	02:11	LINE CLEAR AVAILED
3493	18-Dec-24	MYSORE	66	LINE	KR NAGARA-GAVADGERE	NO STATIONS EFFECTED	14:25	16:30	02:05	LINE CLEAR AVAILED
3494	18-Dec-24	MYSORE	66	LINE	KR NAGARA-KUSHALNAGARA-MIRLE-GRAPHITE INDIAIPP	KRNAGARA_66	14:26	16:30	02:03	LINE CLEAR AVAILED
3495	18-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
3496	18-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
3497	18-Dec-24	MYSORE	66	LINE	KUSHALNAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	22:26	22:53	00:27	TRIPPED ON FAULT
3498	18-Dec-24	MYSORE	66	LINE	MADIKERI-SUNTHIKOPA	SUNTIKOPPA_66	22:25	22:39	00:13	TRIPPED ON FAULT
3499	18-Dec-24	MYSORE	66	TRANSFORMER	MUGURU-HV1	MUGUR_66	10:00	14:35	04:35	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3500	18-Dec-24	MYSORE	66	LINE	MUGURU-JANNURU	JANNUR_66	15:25	17:00	01:35	LINE CLEAR AVAILED
3501	18-Dec-24	MYSORE	66	LINE	MUGURU-THAYURU	THAYURU_66	10:00	17:55	07:55	LINE CLEAR AVAILED
3502	18-Dec-24	MYSORE	66	LINE	PONNAMPETE-SRIMANGALA	SRIMANGALA_66	23:14	23:21	00:07	TRIPPED ON FAULT
3503	18-Dec-24	MYSORE	66	LINE	SINDUVALLI-BEGURU	SINDHUVALLI_66	15:15	17:47	02:32	LINE CLEAR AVAILED
3504	18-Dec-24	MYSORE	66	LINE	TN PURA-THAYURU	THAYURU_66	10:19	17:56	07:36	LINE CLEAR AVAILED
3505	18-Dec-24	MYSORE	220	LINE	TUBINAKERE-YELIYURU	NO STATIONS EFFECTED	14:16	17:50	03:34	LINE CLEAR AVAILED
3506	18-Dec-24	TUMKUR	66	LINE	220 KV GUTTUR 2 LINE-DAVANGERE SRS 220	DAVANGERE SRS 220	16:36	16:57	0:21	TRIPPED ON FAULT
3507	18-Dec-24	TUMKUR	220	LINE	220KV GUTTUR 3 LINE-DAVANGERE SRS 220	DAVANGERE 220KV & O/G LINES	23:58:00	16:24	16:26	LINE CLEAR AVAILED
3508	18-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV PALLAGATTE AND BILICHODU	2:55	3:10	0:15	TRIPPED ON FAULT
3509	18-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-MALLADIHALLI	MALLADIHALLI_66	10:01	10:09	0:08	LINE CLEAR AVAILED
3510	18-Dec-24	TUMKUR	66	LINE	CHITRADURGA SRS-CHITRADURGA OLD MUSS 2 LINE	66KV PANDARAHALLI, CHITRAHALLI, HOLALKERE	6:55	7:16	0:21	TRIPPED ON FAULT
3511	18-Dec-24	TUMKUR	66	LINE	CHITRADURGA SRS-PANDARAHALLI-LINE-1	66KV BHARAMASAGARA,SIRIGERE, VIJAPURA	9:14	9:24	0:10	TRIPPED ON FAULT
3512	18-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	-66KV ANAGODU , ATTIGERE	12:31	12:33	0:02	TRIPPED ON FAULT
3513	18-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	-66KV HARIHAR NEW	12:27	12:30	0:03	TRIPPED ON FAULT
3514	18-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	-66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPATNA	10:40	10:44	0:04	TRIPPED ON FAULT
3515	18-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV YARAGUNTA LINE	-66KV YARAGUNTA	16:20	16:23	0:03	TRIPPED ON FAULT
3516	18-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:11	17:22	6:11	LINE CLEAR AVAILED
3517	18-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV-BEERANAHALLI1	BEERANAHALLI1	10:53	18:41	7:48	LINE CLEAR AVAILED
3518	18-Dec-24	TUMKUR	66	LINE	HIREHALLI_66 HONNUDIKE_66 TAPING LINE	HONNUDIKE_66	16:25	18:12	1:47	LINE CLEAR AVAILED
3519	18-Dec-24	TUMKUR	220	LINE	JAGALUR 400KV-CHITRADURGA-2_220KV	CHITRADURGA-2_220KV	16:15	17:53	1:38	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3520	18-Dec-24	TUMKUR	220	LINE	THALLAK 220KV-HIREMALLANAHOLE 1	HIREMALLANAHOLE 1	15:12	19:01	3:49	LINE CLEAR AVAILED
3521	18-Dec-24	TUMKUR	66	LINE	THALLAK 220KV-NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	10:25	16:57	6:32	LINE CLEAR AVAILED
3522	18-Dec-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA_220	CHITRADURGA_220	11:38	13:48	2:10	LINE CLEAR AVAILED
3523	18-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 , 12.5 MVA SANIKERE_66	SANIKERE_66	16:18	16:33	0:15	LINE CLEAR AVAILED
3524	18-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 , 8MVA P.D. KOTE_66	P.D. KOTE_66	7:44	7:50	0:06	LINE CLEAR AVAILED
3525	18-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 , 8MVA P.D. KOTE_66	P.D. KOTE_66	8:43	8:52	0:09	LINE CLEAR AVAILED
3526	18-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 ,TR-2 12.5MVA KADAJI_66	KADAJJI_66	11:28	17:28	6:00	LINE CLEAR AVAILED
3527	18-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 AND TR-2 12.5MVA HONNUDIKE_66	HONNUDIKE_66	10:15	18:15	8:00	LINE CLEAR AVAILED
3528	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	DADDI_110	15:29	15:41	0:12	LINE CLEAR AVAILED
3529	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	JAMAKHANDI_110	12:42	14:08	1:26	TRIPPED ON FAULT
3530	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SOUDATTI_220	15:34	18:50	3:16	TRIPPED ON FAULT
3531	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KALAGATAGI_110	07:44	07:49	18:15	TRIPPED ON FAULT
3532	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR(B)_110	07:58	08:07	21:15	TRIPPED ON FAULT
3533	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KAGAWAD_110	04:35	08:00	3:25	TRIPPED ON FAULT
3534	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KAGAWAD_110	10:40	14:09	17:15	LINE CLEAR AVAILED
3535	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	SANKESHWARA_110	16:01	16:38	0:37	LINE CLEAR AVAILED
3536	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	RATTIHALI_110	11:52	13:14	1:22	LINE CLEAR AVAILED
3537	19-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	KADANAKOPPA_110	10:05	10:16	0:11	TRIPPED ON FAULT
3538	19-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	HUBLI_220	9:23 (19.12.2024)			LINE CLEAR AVAILED
3539	19-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3540	19-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	HUBLI_220	9:22 (19.12.2024)			LINE CLEAR AVAILED
3541	19-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3542	19-Dec-24	BAGALKOTE	110	LINE	AEQUS220-DADDI	AEQUS_220	6:38	6:46	0:08	TRIPPED ON FAULT
3543	19-Dec-24	BAGALKOTE	110	LINE	DEVANGOAN-F1(GATTARAGI)	DEVANGOAN_110	15:23	15:52	0:29	LINE CLEAR AVAILED
3544	19-Dec-24	BAGALKOTE	220	LINE	GADAG- HARTHI2	GADAG_220	11:25	18:01	6:36	LINE CLEAR AVAILED
3545	19-Dec-24	BAGALKOTE	110	LINE	GADAG220-BETAGERI(ROH)	GADAG_220	12:10	12:24	0:14	TRIPPED ON FAULT
3546	19-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	12:20	12:55	0:35	LINE CLEAR AVAILED
3547	19-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
3548	19-Dec-24	BAGALKOTE	110	LINE	HIREHAL-IDLE(BADAMI)	HIREHAL_110	12:33	13:29	0:56	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3549	19-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3550	19-Dec-24	BAGALKOTE	110	LINE	JAMAKHANDI- MAHALINGAPUR	STATION NOT AFFECTED JAMAKHANDI_110	15:57 (05.12.2024)	16:08 (19.12.2024)	336:11:00	LINE CLEAR AVAILED
3551	19-Dec-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	10:45	13:20	19:15	LINE CLEAR AVAILED
3552	19-Dec-24	BAGALKOTE	110	LINE	KERUR-KONNUR	KERUR_110	12:19	12:40	20:15	LINE CLEAR AVAILED
3553	19-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
3554	19-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3555	19-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
3556	19-Dec-24	BAGALKOTE	110	LINE	RON-GAJENDRAGADA1	RON_110	12:13	12:34	0:21	LINE CLEAR AVAILED
3557	19-Dec-24	BAGALKOTE	110	LINE	RON-GAJENDRAGADA2	RON_110	12:13	12:35	0:22	LINE CLEAR AVAILED
3558	19-Dec-24	BAGALKOTE	110	LINE	RON-GMSH	RON_110	12:14	12:46	0:32	LINE CLEAR AVAILED
3559	19-Dec-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	12:22	12:27	0:05	LINE CLEAR AVAILED
3560	19-Dec-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	12:21	12:28	0:07	LINE CLEAR AVAILED
3561	19-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)			LINE CLEAR AVAILED
3562	19-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN220- LN3(SHIGGOAN110)	SHIGGOAN_220	15:05	16:52	1:47	LINE CLEAR AVAILED
3563	19-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN-GANJIGATTI	SHIGGOAN_110	15:02	16:53	1:51	LINE CLEAR AVAILED
3564	19-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TIK(TIKOTA)	TAKKALAKI_110	13:08 (18.12.2024)	14:22 (19.12.2024)	25:14:00	LINE CLEAR AVAILED
3565	19-Dec-24	BAGALKOTE	110	LINE	TIKOTA- BHUTNAL(TAKKALAKI)	TIKOTA_110	14:20	14:24	0:04	LINE CLEAR AVAILED
3566	19-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
3567	19-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	14:01	17:54	03:53	LINE CLEAR AVAILED
3568	19-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	22:25	23:05	00:40	TRIPPED ON FAULT
3569	19-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
3570	19-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3571	19-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
3572	19-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	13:49	14:28	00:39	TRIPPED ON FAULT
3573	19-Dec-24	BANGALORE	400	LINE	400KV NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	09:45	15:29	05:44	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3574	19-Dec-24	BANGALORE	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CB PURA URBAN	16:37	16:51	00:14	TRIPPED ON FAULT
3575	19-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:02	10:06	00:04	LINE CLEAR AVAILED
3576	19-Dec-24	BANGALORE	66	LINE	66KV EPIP 220 - BRIGADE TECH GARDEN	BRIGADE TECH GARDEN	13:15	13:30	00:15	LINE CLEAR AVAILED
3577	19-Dec-24	BANGALORE	66	LINE	66KV GUNDAMGERE - SASALU	SASALU	06:34	06:52	00:18	TRIPPED ON FAULT
3578	19-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	LR BANDE	12:25	15:05	02:40	LINE CLEAR AVAILED
3579	19-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	09:02	10:20	01:18	TRIPPED ON FAULT
3580	19-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	NO STATION AFFECTED	11:13	14:56	03:43	LINE CLEAR AVAILED
3581	19-Dec-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ELITA PROMENADE	ELITA PROMENENDE	10:11	15:33	05:22	LINE CLEAR AVAILED
3582	19-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)	NO STATION AFFECTED	09:34	20:38	11:04	LINE CLEAR AVAILED
3583	19-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	15:30	16:35	01:05	LINE CLEAR AVAILED
3584	19-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KAMBIPURA	KAMBIPURA	10:10	16:30	06:20	LINE CLEAR AVAILED
3585	19-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:54	18:58	00:04	LINE CLEAR AVAILED
3586	19-Dec-24	BANGALORE	66	LINE	66KV LAKKUR - DEVANAGUNDHI	DEVANGUNDI	07:45	08:10	00:25	TRIPPED ON FAULT
3587	19-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	MATHIKERE, AGALAKOTE, CHIKKAGANGANAWADI, JALAMANGALA, KUTAGAL	12:13	12:30	00:17	TRIPPED ON FAULT
3588	19-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, THIMAMPALLI, GULUR	17:37	17:47	00:10	LINE CLEAR AVAILED
3589	19-Dec-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	NO STATION AFFECTED	17:15	17:58	00:43	LINE CLEAR AVAILED
3590	19-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	NO STATION AFFECTED	23:58:00	14:50	14:52	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3591	19-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	18:05	18:20	00:15	TRIPPED ON FAULT
3592	19-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	17:20	17:38	00:18	LINE CLEAR AVAILED
3593	19-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVANA 220	NO STATION AFFECTED	17:12	17:38	00:26	LINE CLEAR AVAILED
3594	19-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR HALAGURU,	06:43	07:04	00:21	TRIPPED ON FAULT
3595	19-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	HONNIGANAHALLI, ACCHALU	07:14	07:24	00:10	TRIPPED ON FAULT
3596	19-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	13:49	14:28	00:39	MAIN SUPPLY FAILURE
3597	19-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	19:42	19:52	00:10	LINE CLEAR AVAILED
3598	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ELITA PROMENENDE	15:37	19:11	03:34	LINE CLEAR AVAILED
3599	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	08:23	08:28	00:05	TRIPPED ON FAULT
3600	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	H GOLLAHALLI	12:25	12:30	00:05	TRIPPED ON FAULT
3601	19-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KOTHIPURA 220	10:05	12:10	02:05	LINE CLEAR AVAILED
3602	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MALLANAYAKANAHALLI	15:25	15:27	00:02	LINE CLEAR AVAILED
3603	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	13:20	14:10	00:50	LINE CLEAR AVAILED
3604	19-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SRINIVASAPURA 220	22:25	23:08	00:43	TRIPPED ON FAULT
3605	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SULIBELE	13:42	13:58	00:16	TRIPPED ON FAULT
3606	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TUBUGERE	12:30	12:45	00:15	TRIPPED ON FAULT
3607	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VICTORIA HOSPITAL	10:08	10:11	00:03	LINE CLEAR AVAILED
3608	19-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	22:12	22:19	00:07	LINE CLEAR AVAILED
3609	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BRIGADE TECH GARDEN	10:33	10:35	00:02	LINE CLEAR AVAILED
3610	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	03:01	04:05	01:04	TRIPPED ON FAULT
3611	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	14:20	15:30	01:10	LINE CLEAR AVAILED
3612	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DEVANGUNDI	07:45	08:10	00:25	TRIPPED ON FAULT
3613	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	EMBASSY TECH PARK	10:10	10:15	00:05	LINE CLEAR AVAILED
3614	19-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KOTHIPURA 220	13:20	14:45	01:25	LINE CLEAR AVAILED
3615	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	LR BANDE	10:30	10:32	00:02	LINE CLEAR AVAILED
3616	19-Dec-24	BANGALORE	220	TRANSFORMER	HV2	MITTEMARI 220	16:40	17:55	01:15	LINE CLEAR AVAILED
3617	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SAMANDURU	16:12	16:41	00:29	LINE CLEAR AVAILED
3618	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VICTORIA HOSPITAL	15:52	15:55	00:03	LINE CLEAR AVAILED
3619	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	22:12	22:19	00:07	LINE CLEAR AVAILED
3620	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	13:49	14:28	00:39	MAIN SUPPLY FAILURE
3621	19-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	19:42	19:52	00:10	LINE CLEAR AVAILED
3622	19-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	19:42	19:52	00:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3623	19-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	13:49	14:28	00:39	MAIN SUPPLY FAILURE
3624	19-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	19:42	19:52	00:10	LINE CLEAR AVAILED
3625	19-Dec-24	BANGALORE	66	TRANSFORMER	HV4	NRS 220	23:58:00	17:49	17:51	LINE CLEAR AVAILED
3626	19-Dec-24	GULBARGA	220	LINE	FEROZABAD-AVAADA SOLAR	FEROZABAD_400	18:29	20:17	01:48	LINE CLEAR AVAILED
3627	19-Dec-24	GULBARGA	110	LINE	GHATTARGA-AFZALPUR	AFZALPUR_110	12:10	15:50	03:40	LINE CLEAR AVAILED
3628	19-Dec-24	GULBARGA	110	TRANSFORMER	HV1	ALAND_110	16:05	16:35	00:30	LINE CLEAR AVAILED
3629	19-Dec-24	GULBARGA	66	TRANSFORMER	HV1	CHORNUR_66	12:20	13:00	00:40	LINE CLEAR AVAILED
3630	19-Dec-24	GULBARGA	110	TRANSFORMER	HV1	GHATTARGA_110	10:15	10:25	00:10	TRIPPED ON FAULT
3631	19-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KANAKAGIRI_110	22:20	23:59	01:39	TRIPPED ON FAULT
3632	19-Dec-24	GULBARGA	66	TRANSFORMER	HV1	KOTTUR_66	14:15	14:20	00:05	TRIPPED ON FAULT
3633	19-Dec-24	GULBARGA	66	TRANSFORMER	HV1	PUNABHAGATTA_66	13:30	13:35	00:05	TRIPPED ON FAULT
3634	19-Dec-24	GULBARGA	66	TRANSFORMER	HV1	PUNABHAGATTA_66	13:50	14:15	00:25	TRIPPED ON FAULT
3635	19-Dec-24	GULBARGA	66	TRANSFORMER	HV1 &HV2	PUNABHAGATTA_66	06:20	07:00	00:40	LINE CLEAR AVAILED
3636	19-Dec-24	GULBARGA	110	TRANSFORMER	HV2	GHATTARGA_110	11:50	14:00	02:10	TRIPPED ON FAULT
3637	19-Dec-24	GULBARGA	66	TRANSFORMER	HV2	PUNABHAGATTA_66	06:15	06:20	00:05	TRIPPED ON FAULT
3638	19-Dec-24	GULBARGA	66	TRANSFORMER	HV2	UCCHANGIDURGA_66	13:05	13:15	00:10	TRIPPED ON FAULT
3639	19-Dec-24	GULBARGA	66	TRANSFORMER	HV3	HALVAGALU_66	09:45	10:30	00:45	LINE CLEAR AVAILED
3640	19-Dec-24	GULBARGA	110	LINE	KUSTAGI-KBJNL	KALALBANDI_110	10:34	16:26	05:52	LINE CLEAR AVAILED
3641	19-Dec-24	GULBARGA	110	LINE	KUSTAGI-TAVARAGERA	TAVARAGERA_110	10:15	16:13	05:58	LINE CLEAR AVAILED
3642	19-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHATTI_66	10:15	13:50	03:35	LINE CLEAR AVAILED
3643	19-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
3644	19-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 2	GUGAL_110,GABBUR_110	20:25	20:39	00:14	TRIPPED ON FAULT
3645	19-Dec-24	GULBARGA	220	LINE	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	18:18	18:33	00:15	TRIPPED ON FAULT
3646	19-Dec-24	GULBARGA	110	LINE	TEKKALKOTE-RENEW SOLAR	TEKKALKOTE_110	03:35	03:50	00:15	TRIPPED ON FAULT
3647	19-Dec-24	HASAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	10:02	17:25	07:23	LINE CLEAR AVAILED
3648	19-Dec-24	HASAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	10:02	17:25	07:23	LINE CLEAR AVAILED
3649	19-Dec-24	HASAN	66	LINE	ATTICHO-HNPURA	ATTICHOWDENHALLI_66	10:05	18:20	08:15	LINE CLEAR AVAILED
3650	19-Dec-24	HASAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	10:10	18:37	08:27	LINE CLEAR AVAILED
3651	19-Dec-24	HASAN	66	LINE	BAGUR-UDAYAPUR	BAGUR_66	10:10	18:37	08:27	LINE CLEAR AVAILED
3652	19-Dec-24	HASAN	66	LINE	BYARAPU-BAGUR	K.BYRAPURA_66	10:10	18:37	08:27	LINE CLEAR AVAILED
3653	19-Dec-24	HASAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:05	17:35	07:30	LINE CLEAR AVAILED
3654	19-Dec-24	HASAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	10:05	17:40	07:35	LINE CLEAR AVAILED
3655	19-Dec-24	HASAN	66	LINE	CHANNAR-SHETTIHALLI	CHANNARAYAPATNA_66	10:00	18:00	08:00	LINE CLEAR AVAILED
3656	19-Dec-24	HASAN	66	LINE	CHANNAR-UDAYAPURA1	CHANNARAYAPATNA_66	10:20	18:10	07:50	LINE CLEAR AVAILED
3657	19-Dec-24	HASAN	66	LINE	CHANNAR-UDAYAPURA2	CHANNARAYAPATNA_66	10:20	18:10	07:50	LINE CLEAR AVAILED
3658	19-Dec-24	HASAN	66	LINE	CHANNAR-YACH1	CHANNARAYAPATNA_66	10:30	17:25	06:55	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3659	19-Dec-24	HASAN	66	LINE	CHANNAR-YACH2	CHANNARAYAPATNA_66	10:30	17:25	06:55	LINE CLEAR AVAILED
3660	19-Dec-24	HASAN	66	TRANSFORMER	HV1	ARAKALGUD_66	10:02	17:27	07:25	LINE CLEAR AVAILED
3661	19-Dec-24	HASAN	66	TRANSFORMER	HV1	ATTICHOWDENHALLI_66	10:05	18:20	08:15	LINE CLEAR AVAILED
3662	19-Dec-24	HASAN	66	TRANSFORMER	HV1	BAGUR_66	10:10	18:56	08:46	LINE CLEAR AVAILED
3663	19-Dec-24	HASAN	220	TRANSFORMER	HV1	CRPATNA_220	13:44	17:12	03:28	LINE CLEAR AVAILED
3664	19-Dec-24	HASAN	66	TRANSFORMER	HV1	DODDAMAGGE_66	10:00	17:25	07:25	LINE CLEAR AVAILED
3665	19-Dec-24	HASAN	66	TRANSFORMER	HV1	K.BYRAPURA_66	10:05	18:38	08:33	LINE CLEAR AVAILED
3666	19-Dec-24	HASAN	220	TRANSFORMER	HV1	KAVOOR_220	10:55	16:28	05:33	LINE CLEAR AVAILED
3667	19-Dec-24	HASAN	66	TRANSFORMER	HV1	RAMPURA_66	10:05	18:40	08:35	LINE CLEAR AVAILED
3668	19-Dec-24	HASAN	66	TRANSFORMER	HV1	SATHENAHALLI_66	10:05	12:50	02:45	LINE CLEAR AVAILED
3669	19-Dec-24	HASAN	110	TRANSFORMER	HV1	SHIKARIPURA_110	15:45	15:50	00:05	TRIPPED ON FAULT
3670	19-Dec-24	HASAN	66	TRANSFORMER	HV1	UDAYAPURA_66	10:05	18:26	08:21	LINE CLEAR AVAILED
3671	19-Dec-24	HASAN	66	TRANSFORMER	HV1	YESLUR_66	10:05	17:12	07:07	LINE CLEAR AVAILED
3672	19-Dec-24	HASAN	66	TRANSFORMER	HV2	ARAKALGUD_66	10:02	17:27	07:25	LINE CLEAR AVAILED
3673	19-Dec-24	HASAN	66	TRANSFORMER	HV2	BAGUR_66	10:10	18:37	08:27	LINE CLEAR AVAILED
3674	19-Dec-24	HASAN	220	TRANSFORMER	HV2	CRPATNA_220	09:46	13:42	03:56	LINE CLEAR AVAILED
3675	19-Dec-24	HASAN	66	TRANSFORMER	HV2	DODDAMAGGE_66	10:00	17:25	07:25	LINE CLEAR AVAILED
3676	19-Dec-24	HASAN	220	TRANSFORMER	HV2	KAVOOR_220	16:29	18:42	02:13	LINE CLEAR AVAILED
3677	19-Dec-24	HASAN	110	TRANSFORMER	HV2	MRSMG_220	08:54	15:40	06:46	LINE CLEAR AVAILED
3678	19-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMPURA_66	10:05	18:40	08:35	LINE CLEAR AVAILED
3679	19-Dec-24	HASAN	66	TRANSFORMER	HV2	SATHENAHALLI_66	10:05	12:50	02:45	LINE CLEAR AVAILED
3680	19-Dec-24	HASAN	110	TRANSFORMER	HV2	SHIKARIPURA_110	15:23	15:28	00:05	TRIPPED ON FAULT
3681	19-Dec-24	HASAN	66	TRANSFORMER	HV2	UDAYAPURA_66	10:05	18:26	08:21	LINE CLEAR AVAILED
3682	19-Dec-24	HASAN	110	TRANSFORMER	HV3	MRSMG_220	08:54	15:40	06:46	LINE CLEAR AVAILED
3683	19-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
3684	19-Dec-24	HASAN	110	TRANSFORMER	HV4	MRSMG_220	08:54	15:40	06:46	LINE CLEAR AVAILED
3685	19-Dec-24	HASAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	10:13	12:41	02:28	LINE CLEAR AVAILED
3686	19-Dec-24	HASAN	220	LINE	KEMAR-Varahi1	KEMAR_220	11:14	14:30	03:16	LINE CLEAR AVAILED
3687	19-Dec-24	HASAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	11:27	13:13	01:46	LINE CLEAR AVAILED
3688	19-Dec-24	HASAN	66	TRANSFORMER	LV1	CRPATNA_220	13:44	17:12	03:28	LINE CLEAR AVAILED
3689	19-Dec-24	HASAN	110	TRANSFORMER	LV1	KAVOOR_220	10:55	16:28	05:33	LINE CLEAR AVAILED
3690	19-Dec-24	HASAN	66	TRANSFORMER	LV1	MRSMG_220	09:46	16:40	06:54	LINE CLEAR AVAILED
3691	19-Dec-24	HASAN	66	TRANSFORMER	LV2	CRPATNA_220	09:46	13:42	03:56	LINE CLEAR AVAILED
3692	19-Dec-24	HASAN	110	TRANSFORMER	LV2	KAVOOR_220	16:29	18:42	02:13	LINE CLEAR AVAILED
3693	19-Dec-24	HASAN	66	LINE	MRSSHM-DVG1	MRSMG_220	09:46	16:40	06:54	LINE CLEAR AVAILED
3694	19-Dec-24	HASAN	66	LINE	RAMPUR-BEGUR	RAMPURA_66	10:05	18:40	08:35	LINE CLEAR AVAILED
3695	19-Dec-24	HASAN	110	LINE	SAGARA-SORABA	SAGARA_110	12:05	14:40	02:35	LINE CLEAR AVAILED
3696	19-Dec-24	HASAN	66	LINE	SATHENA-UDAY	SATHENAHALLI_66	10:05	12:50	02:45	LINE CLEAR AVAILED
3697	19-Dec-24	HASAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	16:32	17:13	00:41	LINE CLEAR AVAILED
3698	19-Dec-24	HASAN	66	LINE	UDAYAP-BAGUR	UDAYAPURA_66	10:05	18:36	08:31	LINE CLEAR AVAILED
3699	19-Dec-24	HASAN	66	LINE	UDAYAP-SATHENAHALLI	UDAYAPURA_66	10:05	18:19	08:14	LINE CLEAR AVAILED
3700	19-Dec-24	HASAN	66	LINE	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:05	18:13	08:08	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3701	19-Dec-24	HASAN	220	LINE	VARAHI-KEMAR1	varahi_gen	11:14	14:30	03:16	LINE CLEAR AVAILED
3702	19-Dec-24	HASAN	66	LINE	YESLUR-SNVRST	YESLUR_66	10:05	17:12	07:07	LINE CLEAR AVAILED
3703	19-Dec-24	MYSORE	66	LINE	BEGUR 220-B MATTGERE	B MATKERE_66	11:05	11:15	00:10	TRIPPED ON FAULT
3704	19-Dec-24	MYSORE	66	LINE	BEGUR 220-SARAGURU	ANTHARSANTHE_66 CHANDRAVADI_66 HDKOTE_66 HURA_66 SANTHESARAGUR_66 YERALLI HAND POST_66	11:02	11:10	00:08	TRIPPED ON FAULT
3705	19-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
3706	19-Dec-24	MYSORE	66	LINE	CHANDALLI-BG PURA	NO STATIONS EFFECTED	12:46	12:56	00:10	LINE CLEAR AVAILED
3707	19-Dec-24	MYSORE	66	LINE	CHANDALLI-THALAKADU	NO STATIONS EFFECTED	12:33	12:46	00:13	LINE CLEAR AVAILED
3708	19-Dec-24	MYSORE	66	LINE	CHIKKAMANDYA-MANDYA	NO STATIONS EFFECTED	11:06	12:22	01:16	LINE CLEAR AVAILED
3709	19-Dec-24	MYSORE	66	LINE	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	11:53	12:41	00:47	LINE CLEAR AVAILED
3710	19-Dec-24	MYSORE	66	LINE	G UKKADA-SRIRANGAPATNA	SRIRANGAPATNA_66	10:00	17:40	07:40	LINE CLEAR AVAILED
3711	19-Dec-24	MYSORE	66	LINE	G UKKADA-TUBINAKERE	GARUDANAUKADDA_66	11:54	12:41	00:47	LINE CLEAR AVAILED
3712	19-Dec-24	MYSORE	66	LINE	GAMANAHALLI-B. SEEHALLI(CHAMALAPURA)	GAMANAHALLY_66	12:55	13:40	00:45	LINE CLEAR AVAILED
3713	19-Dec-24	MYSORE	66	LINE	HARAVE-KABBALLI	KABHALLY_66	15:57	17:57	01:59	LINE CLEAR AVAILED
3714	19-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
3715	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	JAIPUR_66	10:02	16:52	06:50	LINE CLEAR AVAILED
3716	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	08:00	14:59	06:59	LINE CLEAR AVAILED
3717	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	BOGADHI_66	10:00	19:00	09:00	LINE CLEAR AVAILED
3718	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	CHAMLAPURA_66	10:30	16:00	05:30	LINE CLEAR AVAILED
3719	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	10:00	17:14	07:13	LINE CLEAR AVAILED
3720	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	15:44	18:21	02:37	TRIPPED ON FAULT
3721	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	18:46	18:58	00:12	LINE CLEAR AVAILED
3722	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	19:23	21:16	01:53	LINE CLEAR AVAILED
3723	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUDDENAHALLI_66	09:04	17:50	08:45	LINE CLEAR AVAILED
3724	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	07:14	07:24	00:10	MAIN SUPPLY FAILURE
3725	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI(JAK)_66	12:38	15:56	03:17	LINE CLEAR AVAILED
3726	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	HARVEY_66	09:18	16:05	06:46	LINE CLEAR AVAILED
3727	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	10:00	18:05	08:05	LINE CLEAR AVAILED
3728	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	PONNAMPET_66	09:33	17:34	08:01	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3729	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANIVARASANTHE_66	10:00	17:45	07:45	LINE CLEAR AVAILED
3730	19-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3731	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	JAIPUR_66	10:02	16:52	06:50	LINE CLEAR AVAILED
3732	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	10:13	14:58	04:44	LINE CLEAR AVAILED
3733	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	BOGADHI_66	10:00	19:00	09:00	LINE CLEAR AVAILED
3734	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	CHANDAKAVADI_66	13:13	13:44	00:31	LINE CLEAR AVAILED
3735	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	DKMAIDANA_66	10:00	17:14	07:14	LINE CLEAR AVAILED
3736	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	GUDDENAHALLI_66	21:00	21:58	00:58	TRIPPED ON FAULT
3737	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	07:14	07:24	00:10	MAIN SUPPLY FAILURE
3738	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	09:18	16:05	06:46	LINE CLEAR AVAILED
3739	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	11:10	11:20	00:10	TRIPPED ON FAULT
3740	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	KABHALLY_66	10:00	18:05	08:05	LINE CLEAR AVAILED
3741	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	09:33	17:36	08:03	LINE CLEAR AVAILED
3742	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANIVARASANTHE_66	10:00	17:45	07:45	LINE CLEAR AVAILED
3743	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEBACHALLI_66	10:40	12:17	01:36	LINE CLEAR AVAILED
3744	19-Dec-24	MYSORE	66	TRANSFORMER	HV2	SFCSHIVA_66	10:32	12:31	01:58	LINE CLEAR AVAILED
3745	19-Dec-24	MYSORE	66	TRANSFORMER	HV3	PONNAMPET_66	09:33	17:33	08:00	LINE CLEAR AVAILED
3746	19-Dec-24	MYSORE	66	TRANSFORMER	HV3	SFCSHIVA_66	10:32	12:31	01:59	LINE CLEAR AVAILED
3747	19-Dec-24	MYSORE	66	LINE	JYOTHINAGARA-DK MAIDANA	DKMAIDANA_66	10:11	16:55	06:44	LINE CLEAR AVAILED
3748	19-Dec-24	MYSORE	66	LINE	KABBALLI-ATRIA SOLAR	NO STATIONS EFFECTED	16:00	18:00	02:00	LINE CLEAR AVAILED
3749	19-Dec-24	MYSORE	66	LINE	KABBALLI-CLEAN SOLAR EHT	NO STATIONS EFFECTED	06:25	06:35	00:10	TRIPPED ON FAULT
3750	19-Dec-24	MYSORE	66	LINE	KABBALLI-CLEAN SOLAR EHT	NO STATIONS EFFECTED	16:00	18:00	02:00	LINE CLEAR AVAILED
3751	19-Dec-24	MYSORE	66	LINE	KABBALLI-GUNDLUPETE	KABHALLY_66	15:55	18:00	02:05	LINE CLEAR AVAILED
3752	19-Dec-24	MYSORE	66	LINE	KABBALLI-HARAVE	KABHALLY_66	16:00	18:00	02:00	LINE CLEAR AVAILED
3753	19-Dec-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	DKMAIDANA_66	10:07	17:00	06:53	LINE CLEAR AVAILED
3754	19-Dec-24	MYSORE	66	LINE	KADAKOLA-JAIPURA	JAIPUR_66	10:10	12:02	01:52	LINE CLEAR AVAILED
3755	19-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3756	19-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
3757	19-Dec-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA-MUGUR	NO STATIONS EFFECTED	14:37	14:48	00:10	TRIPPED ON FAULT
3758	19-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
3759	19-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3760	19-Dec-24	MYSORE	66	LINE	KUSHALANAGARA 220-KARADILAKKINAKERE	ALUR SIDDAPURA_66 KANAGAL_66	07:42	08:01	00:19	TRIPPED ON FAULT
3761	19-Dec-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	VIRAJPET_66	09:41	16:30	06:49	TRIPPED ON FAULT
3762	19-Dec-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU-PONNAMPETE	PONNAMPET_66 VIRAJPET_66	09:36	10:43	01:07	LINE CLEAR AVAILED
3763	19-Dec-24	MYSORE	66	LINE	PONNAMPETE-SRIMANGALA	SRIMANGALA_66	09:40	17:24	07:44	LINE CLEAR AVAILED
3764	19-Dec-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPET	VIRAJPET_66	09:44	10:49	01:05	LINE CLEAR AVAILED
3765	19-Dec-24	MYSORE	66	LINE	SHANIVARASANTHE-YESSLUR	NO STATIONS EFFECTED	19:43	19:54	00:10	LINE CLEAR AVAILED
3766	19-Dec-24	MYSORE	66	LINE	TUBINAKERE-MANDYA M4	NO STATIONS EFFECTED	11:27	12:18	00:50	LINE CLEAR AVAILED
3767	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 ,12.5 MVA BELLAVI_66	BELLAVI_66	12:05	12:40	0:35	LINE CLEAR AVAILED
3768	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 ,20 MVA CHANNAGIRI_66	CHANNAGIRI_66	10:48	10:53	0:05	TRIPPED ON FAULT
3769	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 ,20MVA BELLAVI_66	BELLAVI_66	12:05	12:40	0:35	LINE CLEAR AVAILED
3770	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-2,12.5 MVA ,JAVAGONDANAHALLI_66	JAVAGONDANAHALLI_66	11:10	12:25	1:15	LINE CLEAR AVAILED
3771	19-Dec-24	TUMKUR	66	LINE	VIJAPURA_66 -O/G LINE DAVANGERE_66	SIRIGERE_66, VIJAPURA_66	15:45	16:10	0:25	LINE CLEAR AVAILED
3772	19-Dec-24	TUMKUR	66	TRANSFORMER	100MVA TR-1 ,220KV ANCHEPALYA LV SIDE	220KV ANCHEPALYA	11:36	12:06	0:30	TRIPPED ON FAULT
3773	19-Dec-24	TUMKUR	66	TRANSFORMER	100MVA TR-1 ,220KV DAVANAGERE(LV SIDE)	220KV DAVANAGERE	11:07	11:25	0:18	LINE CLEAR AVAILED
3774	19-Dec-24	TUMKUR	66	TRANSFORMER	100MVA TR-1 ,220KV KDBVNP HV SIDE	KDBVNP_220KV	10:55	14:41	3:46	LINE CLEAR AVAILED
3775	19-Dec-24	TUMKUR	220	LINE	100MVA TR-1 ,220KV KIADB HV SIDE	KDBVNP_220KV	10:55	14:41	3:46	LINE CLEAR AVAILED
3776	19-Dec-24	TUMKUR	220	LINE	100MVA TR-1 ,220KV KIADB HV SIDE	KDBVNP_220KV	15:08	17:14	2:06	LINE CLEAR AVAILED
3777	19-Dec-24	TUMKUR	220	LINE	100MVA TR-1 ,220KV THALLAK HV SIDE	THALLAK_220KV	19:24	19:36	0:12	TRIPPED ON FAULT
3778	19-Dec-24	TUMKUR	66	TRANSFORMER	100MVA TR-1 ,220KV THALLAK LV SIDE	THALLAK_220KV	19:24	19:38	0:14	TRIPPED ON FAULT
3779	19-Dec-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV AMRUTHUR LINE	66KV SANTHEMAVATHUR,AMRU THUR,SANABGHATTA,YED AVANI	11:35	12:41	1:06	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3780	19-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,C HILUR	11:59	12:10	0:11	TRIPPED ON FAULT
3781	19-Dec-24	TUMKUR	66	LINE	220KV MADHURE,MATHOD_66KV	MATHOD_66KV	17:00	17:05	0:05	LINE CLEAR AVAILED
3782	19-Dec-24	TUMKUR	66	LINE	220KV MADHURE,MATHOD_66KV	MATHOD_66KV, GARAGA , PANCHANAHALLI_66	12:30	12:50	0:20	LINE CLEAR AVAILED
3783	19-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV GOWRASAMUDRA	66KV GOWRASAMUDRA, KONASAGARA	19:24	19:43	0:19	TRIPPED ON FAULT
3784	19-Dec-24	TUMKUR	220	LINE	400 KV HIREMALLANAHOLE - 220KV CHITRADURGA-1	220KV CHITRADURGA-1	16:46	18:48	2:02	LINE CLEAR AVAILED
3785	19-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV PALLAGATTE AND BILICHODU	11:25	13:15	1:50	LINE CLEAR AVAILED
3786	19-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-__KORATGERE_66	66KV CT KERE, BELDAHARA, SANKENAHALLI.	6:46	7:03	0:17	TRIPPED ON FAULT
3787	19-Dec-24	TUMKUR	66	LINE	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	12:05	12:40	0:35	LINE CLEAR AVAILED
3788	19-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA_66-PANDARAHALLI LINE-1	BHARAMASAGARA_66,SIRIGERE_66, VIJAPURA_66	11:10	16:10	5:00	LINE CLEAR AVAILED
3789	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	-66KV HARIHAR NEW	5:57	6:02	0:05	TRIPPED ON FAULT
3790	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	-66KV HARIHAR NEW	11:05	11:28	0:23	LINE CLEAR AVAILED
3791	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV YARAGUNTA LINE	66KV YARAGUNTA LINE	11:05	11:28	0:23	LINE CLEAR AVAILED
3792	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS_220KV - AVAREGERE_66	AVAREGERE_66	11:02	11:28	0:26	LINE CLEAR AVAILED
3793	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS_220KV - AVAREGERE_66	AVAREGERE_66	16:07	16:40	0:33	LINE CLEAR AVAILED
3794	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS_220KV - DAVANGERE_66	DAVANAGERE_66	11:04	11:28	0:24	LINE CLEAR AVAILED
3795	19-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS_220KV - DAVANGERE_66	DAVANAGERE_66	16:10	16:37	0:27	LINE CLEAR AVAILED
3796	19-Dec-24	TUMKUR	66	LINE	KEREBILCHE-SANTHEBENNUR	KEREBILCHI_66	9:55	10:05	0:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3797	19-Dec-24	TUMKUR	66	LINE	PANDARAHALLI-CHITRADURGA 3	PONDARAHALLUI_66, CHITRAHALLI_66, H D PURA 6	11:25	12:20	0:55	LINE CLEAR AVAILED
3798	19-Dec-24	TUMKUR	110	TRANSFORMER	TR-1 10MVA,HANDANAKERE_110	HANDANAKERE_110	12:27	15:11	2:44	LINE CLEAR AVAILED
3799	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA,KUKKAWADA_66	KUKKAWADA_66	10:00	16:55	6:55	LINE CLEAR AVAILED
3800	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA,KUKKAWADA_66	KUKKAWADA_66	10:00	16:55	6:55	LINE CLEAR AVAILED
3801	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA,SAVALANGA_66	SAVALANGA_66	10:30	17:10	6:40	LINE CLEAR AVAILED
3802	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA,KUKKAWADA_66	KUKKAWADA_66	10:00	16:55	6:55	LINE CLEAR AVAILED
3803	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA,NEERAGUNDA_66	NEERAGUNDA_66	14:05	14:22	0:17	LINE CLEAR AVAILED
3804	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA,SAVALANGA_66	SAVALANGA_66	10:30	17:10	6:40	LINE CLEAR AVAILED
3805	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8 MVA,SHAGLE_66	SHAGLE_66	10:10	12:55	2:45	LINE CLEAR AVAILED
3806	19-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA HONNALLI_66	HONNALLI_66	13:30	13:40	0:10	LINE CLEAR AVAILED
3807	19-Dec-24	TUMKUR	110	TRANSFORMER	TR-2 20MVA,HANDANAKERE_110	HANDANAKERE_110	12:27	15:11	2:44	LINE CLEAR AVAILED
3808	19-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 8 MVA,SHAGLE_66	SHAGLE_66	10:10	12:55	2:45	LINE CLEAR AVAILED
3809	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	GADAG_110	10:04	17:06	7:02	LINE CLEAR AVAILED
3810	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MALLIGERE_110	11:45	15:43	3:58	LINE CLEAR AVAILED
3811	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KALADAGI_110	13:10	13:17	0:07	TRIPPED ON FAULT
3812	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
3813	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	GADAG_110	10:04	17:06	7:02	LINE CLEAR AVAILED
3814	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KIRUVATTI_110	13:05	13:37	0:32	LINE CLEAR AVAILED
3815	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MALGHAN_110	23:29	23:45	0:16	TRIPPED ON FAULT
3816	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MANTUR(G)_110	15:23	17:12	1:49	LINE CLEAR AVAILED
3817	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	ITNAL_110	22:05	22:11	0:06	TRIPPED ON FAULT
3818	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	ITNAL_110	22:14	22:20	0:06	TRIPPED ON FAULT
3819	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	THORVI_110	08:18	08:23	0:05	TRIPPED ON FAULT
3820	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	UGAR KHUD_110	16:55	17:05	0:10	LINE CLEAR AVAILED
3821	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	NAVALAGI_110	22:58	23:05	0:07	TRIPPED ON FAULT
3822	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	RON_110	10:30	11:09	0:39	TRIPPED ON FAULT
3823	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	GADAG_110	10:02	18:13	8:11	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3824	20-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	GADAG_110	10:02	18:13	8:11	LINE CLEAR AVAILED
3825	20-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	KUDUCHI_220	07:44	08:07	0:23	TRIPPED ON FAULT
3826	20-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3827	20-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED HUBLI_220	9:23 (19.12.2024)			LINE CLEAR AVAILED
3828	20-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	KUDUCHI_220	07:44	08:09	0:25	TRIPPED ON FAULT
3829	20-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
3830	20-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED HUBLI_220	9:22 (19.12.2024)			LINE CLEAR AVAILED
3831	20-Dec-24	BAGALKOTE	110	LINE	AHERI-DEVARAHIPPARAGI	AHERI_220	14:13	16:25	2:12	LINE CLEAR AVAILED
3832	20-Dec-24	BAGALKOTE	110	LINE	ANNIGERI-GADAG	ANNIGERI_110	10:00	20:07	10:07	LINE CLEAR AVAILED
3833	20-Dec-24	BAGALKOTE	110	LINE	ATHARGA-KNISLR	ATHARGA_110	18:11	19:24	1:13	LINE CLEAR AVAILED
3834	20-Dec-24	BAGALKOTE	110	LINE	DADDI-F2(HONAGA)	DADDI_110	16:16	16:39	0:23	LINE CLEAR AVAILED
3835	20-Dec-24	BAGALKOTE	110	LINE	GADAG220-GADAG	GADAG_220	10:43	16:54	6:11	LINE CLEAR AVAILED
3836	20-Dec-24	BAGALKOTE	110	LINE	GADAG-ANNIGERI	GADAG_110	10:44	16:54	6:10	LINE CLEAR AVAILED
3837	20-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
3838	20-Dec-24	BAGALKOTE	110	LINE	HANAGAL-HAVERI220	HANAGAL_110	11:47	12:02	0:15	TRIPPED ON FAULT
3839	20-Dec-24	BAGALKOTE	110	LINE	HAVERI-HANAGAL(KULENUR)	HAVERI_220	09:56	10:14	0:18	LOAD CURTAILMENT
3840	20-Dec-24	BAGALKOTE	110	LINE	HAVERI-SAVANUR	HAVERI_220	0:0 (19.12.2024)	11:54 (20.12.2024)	11:54:00	LINE CLEAR AVAILED
3841	20-Dec-24	BAGALKOTE	110	LINE	HAVERI-TILUVALI(HANAGAL)	HAVERI_220	07:55	08:38	0:43	LOAD CURTAILMENT
3842	20-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3843	20-Dec-24	BAGALKOTE	110	LINE	HUNGUND-BAGEWADI(KUDAL SANGAM)	HUNGUND_110	04:50	04:57	0:07	TRIPPED ON FAULT
3844	20-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
3845	20-Dec-24	BAGALKOTE	110	LINE	KUDALA SANGAMA-HUNUGUNDA	KUDALA SANGAMA_110	04:48	04:57	0:09	TRIPPED ON FAULT
3846	20-Dec-24	BAGALKOTE	110	LINE	KUDUCHI220-UGAR	KUDUCHI_220	07:40	15:00	7:20	TRIPPED ON FAULT
3847	20-Dec-24	BAGALKOTE	110	LINE	KUDUCHI220-YALPARATTI	KUDUCHI_220	07:40	07:55	0:15	TRIPPED ON FAULT
3848	20-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR-TERDAL	MAHALINGAPUR_220	16:10	16:41	0:31	LINE CLEAR AVAILED
3849	20-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI	MALGHAN_110	23:29	23:45	0:16	TRIPPED ON FAULT
3850	20-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVA SUG	MALGHAN_110	23:29	23:45	0:16	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3851	20-Dec-24	BAGALKOTE	110	LINE	MALLIGERE-I/CLINEVAJRAMAT	MALLIGERE_110	11:45	15:43	3:58	LINE CLEAR AVAILED
3852	20-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-BAGEWADI2	MAMADAPUR_110	23:35	23:54	0:19	TRIPPED ON FAULT
3853	20-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3854	20-Dec-24	BAGALKOTE	220	LINE	NARENDRA-SHIGGOAN	NARENDRA_220	11:27 (25.11.2024)	20:34 (20.12.2024)	609:07:00	LINE CLEAR AVAILED
3855	20-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
3856	20-Dec-24	BAGALKOTE	110	LINE	SANKESHWARA-HEERA SUGARS (HSFCG2)	SANKESHWARA_110	10:12	10:38	0:26	LINE CLEAR AVAILED
3857	20-Dec-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	11:26 (25.11.2024)	20:24 (20.12.2024)	608:58:00	LINE CLEAR AVAILED
3858	20-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
3859	20-Dec-24	BAGALKOTE	110	LINE	VAJARAMATTI220- MELLIGERI	VAJARAMATTI_220	11:45	15:42	3:57	LINE CLEAR AVAILED
3860	20-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	14:01	15:18	01:17	LINE CLEAR AVAILED
3861	20-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 1	NO STATION AFFECTED	14:46	16:40	01:54	LINE CLEAR AVAILED
3862	20-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
3863	20-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3864	20-Dec-24	BANGALORE	220	LINE	220KV HOODY 400 - SHOBHA DREAMS 220	NO STATION AFFECTED	12:15	17:38	05:23	LINE CLEAR AVAILED
3865	20-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
3866	20-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
3867	20-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	YARANDANAHALLI 220	12:25	15:27	03:02	LINE CLEAR AVAILED
3868	20-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:00	10:04	00:04	LINE CLEAR AVAILED
3869	20-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	NO STATION AFFECTED	17:53	18:59	01:06	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3870	20-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	07:03	23:59	16:56	LINE CLEAR AVAILED
3871	20-Dec-24	BANGALORE	66	LINE	66KV KHODAYS 220 - FALCON CITY	PRESIGE FALCON CITY	10:37	14:02	03:25	LINE CLEAR AVAILED
3872	20-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4	NO STATION AFFECTED	13:00	14:39	01:39	TRIPPED ON FAULT
3873	20-Dec-24	BANGALORE	66	LINE	66KV KONDASPURA (SAFAL) - NTT GLOBAL DATA NETMAGIC 66/11KV EHT	NTT(EHT)	10:00	17:00	07:00	LINE CLEAR AVAILED
3874	20-Dec-24	BANGALORE	66	LINE	66KV KUDUMULAKUNTE - THERIYUR	THERIYUR	08:00	08:50	00:50	MAIN SUPPLY FAILURE
3875	20-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	19:00	19:06	00:06	LINE CLEAR AVAILED
3876	20-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	AGALAKOTE, MATHIKERE	06:47	07:03	00:16	TRIPPED ON FAULT
3877	20-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	AGALAKOTE, MATHIKERE	10:11	17:57	07:46	LINE CLEAR AVAILED
3878	20-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66 _DG3	MANYATHA 66	11:47	13:48	02:01	LINE CLEAR AVAILED
3879	20-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - BMTC	NO STATION AFFECTED	10:50	17:10	06:20	LINE CLEAR AVAILED
3880	20-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	08:05	08:09	00:04	LINE CLEAR AVAILED
3881	20-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVANA 220	MAHALAKSHMI LAYOUT, NANDINI LAYOUT	06:39	10:35	03:56	LINE CLEAR AVAILED
3882	20-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	06:38	06:48	00:10	TRIPPED ON FAULT
3883	20-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	15:11	16:40	01:29	TRIPPED ON FAULT
3884	20-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	NO STATION AFFECTED	12:26	13:15	00:49	LINE CLEAR AVAILED
3885	20-Dec-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	13:15	13:25	00:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3886	20-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	10:01	18:11	08:10	LINE CLEAR AVAILED
3887	20-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	15:53	16:02	00:09	LINE CLEAR AVAILED
3888	20-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	13:18	13:24	00:06	LINE CLEAR AVAILED
3889	20-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	08:28	09:26	00:58	TRIPPED ON FAULT
3890	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	AGALAKOTE	18:40	18:45	00:05	TRIPPED ON FAULT
3891	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHANDRA LAYOUT	10:01	18:11	08:10	LINE CLEAR AVAILED
3892	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKENAHALLI	15:05	15:12	00:07	LINE CLEAR AVAILED
3893	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DIVYASHREE TECH PARK	11:05	11:10	00:05	LINE CLEAR AVAILED
3894	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	15:22	15:30	00:08	LINE CLEAR AVAILED
3895	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	IGGALUR	10:00	17:25	07:25	LINE CLEAR AVAILED
3896	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JALAMANGALA	10:05	15:15	05:10	LINE CLEAR AVAILED
3897	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 220	14:34	14:51	00:17	TRIPPED ON FAULT
3898	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	10:00	17:00	07:00	LINE CLEAR AVAILED
3899	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	15:40	15:46	00:06	TRIPPED ON FAULT
3900	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	17:20	17:25	00:05	LINE CLEAR AVAILED
3901	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	12:30	13:15	00:45	LINE CLEAR AVAILED
3902	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	14:17	14:25	00:08	TRIPPED ON FAULT
3903	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	07:28	07:35	00:07	TRIPPED ON FAULT
3904	20-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SAHAKARINAGAR 220	11:04	13:07	02:03	LINE CLEAR AVAILED
3905	20-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SHOBHA DREAMS 220	10:05	12:26	02:21	LINE CLEAR AVAILED
3906	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	10:40	11:20	00:40	LINE CLEAR AVAILED
3907	20-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	07:54	08:05	00:11	LINE CLEAR AVAILED
3908	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRA LAYOUT	10:01	18:11	08:10	LINE CLEAR AVAILED
3909	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	15:05	15:12	00:07	LINE CLEAR AVAILED
3910	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HOSPALYA CIRCLE	11:40	15:42	04:02	LINE CLEAR AVAILED
3911	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	IGGALUR	10:00	17:25	07:25	LINE CLEAR AVAILED
3912	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KONDASAPURA	10:00	17:00	07:00	LINE CLEAR AVAILED
3913	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	17:20	17:25	00:05	LINE CLEAR AVAILED
3914	20-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SAHAKARINAGAR 220	13:08	15:07	01:59	LINE CLEAR AVAILED
3915	20-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SHOBHA DREAMS 220	12:30	13:33	01:03	LINE CLEAR AVAILED
3916	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAVAREKERE	09:38	10:00	00:22	LINE CLEAR AVAILED
3917	20-Dec-24	BANGALORE	220	TRANSFORMER	HV2	TK HALLI 220	11:36	15:52	04:16	LINE CLEAR AVAILED
3918	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	07:53	08:05	00:12	LINE CLEAR AVAILED
3919	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	13:16	13:22	00:06	LINE CLEAR AVAILED
3920	20-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	15:55	16:02	00:07	LINE CLEAR AVAILED
3921	20-Dec-24	BANGALORE	66	TRANSFORMER	HV3	DIVYASHREE TECH PARK	14:03	14:08	00:05	LINE CLEAR AVAILED
3922	20-Dec-24	BANGALORE	66	TRANSFORMER	HV3	IGGALUR	10:00	17:25	07:25	LINE CLEAR AVAILED
3923	20-Dec-24	BANGALORE	220	TRANSFORMER	HV3	TK HALLI 220	10:10	11:29	01:19	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3924	20-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	13:16	13:22	00:06	LINE CLEAR AVAILED
3925	20-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	15:55	16:02	00:07	LINE CLEAR AVAILED
3926	20-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	13:30	16:01	02:31	LINE CLEAR AVAILED
3927	20-Dec-24	GULBARGA	220	LINE	BTPS-ALIPUR	ALIPUR_220,LINGAPUR_220	07:55	19:39	11:44	LINE CLEAR AVAILED
3928	20-Dec-24	GULBARGA	220	LINE	BTPS-ALIPUR	ALIPUR_220,LINGAPUR_220	19:46	22:54	03:08	LINE CLEAR AVAILED
3929	20-Dec-24	GULBARGA	220	LINE	BTPS-ALIPUR	ALIPUR_220,LINGAPUR_220	23:29	23:36	00:07	LINE CLEAR AVAILED
3930	20-Dec-24	GULBARGA	220	LINE	BTPS-ALIPUR	ALIPUR_220,LINGAPUR_220	23:37(20.12.2024)			LINE CLEAR AVAILED
3931	20-Dec-24	GULBARGA	220	LINE	BTPS-LINGAPURA	ALIPUR_220,LINGAPUR_220	9:32(20.12.2024)			LINE CLEAR AVAILED
3932	20-Dec-24	GULBARGA	110	LINE	BYAGWAT-WALKAMDINNI	BYAGWAT_110	08:30	12:20	03:50	LINE CLEAR AVAILED
3933	20-Dec-24	GULBARGA	110	LINE	DHADESUGUR-SIRIGUPPA	SIRIGUPPA_110,TEKKALOTE_110,SIRIGERICROSS_110	10:40	10:51	00:11	MAIN SUPPLY FAILURE
3934	20-Dec-24	GULBARGA	110	LINE	HALBARGA-HALLIKHED	HALLIKHED_110	09:30	16:31	07:01	LINE CLEAR AVAILED
3935	20-Dec-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERDONA_110,BENNUR_110	12:47	12:57	00:10	TRIPPED ON FAULT
3936	20-Dec-24	GULBARGA	110	LINE	HUMNABAD-HALLIKHED	HALLIKHED_110	09:14	16:31	07:17	LINE CLEAR AVAILED
3937	20-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	07:50	08:00	00:10	TRIPPED ON FAULT
3938	20-Dec-24	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	07:35	07:45	00:10	TRIPPED ON FAULT
3939	20-Dec-24	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	08:23	08:55	00:32	TRIPPED ON FAULT
3940	20-Dec-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	ALAND_110	10:30	17:15	06:45	LINE CLEAR AVAILED
3941	20-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHICKSUGUR_110	07:30	07:50	00:20	TRIPPED ON FAULT
3942	20-Dec-24	GULBARGA	66	LINE	ITTAGI-CLEAN MAX 1&2	ITTAGI_220	11:00	12:14	01:14	LINE CLEAR AVAILED
3943	20-Dec-24	GULBARGA	110	LINE	KIADB-SATHAVANA	SATHAVAHANA_IPP,KURUGOD_110,KUDITINI_110,TORANGALU_110,METRI_110	11:27	11:43	00:16	TRIPPED ON FAULT
3944	20-Dec-24	GULBARGA	220	LINE	LINGAPUR-GDHALLI2	LINGAPUR_220	15:17	20:50	05:33	LINE CLEAR AVAILED
3945	20-Dec-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	12:40	16:27	03:47	LINE CLEAR AVAILED
3946	20-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHTTI_66	09:37	15:15	05:38	LINE CLEAR AVAILED
3947	20-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHTTI_66	18:09	18:18	00:09	TRIPPED ON FAULT
3948	20-Dec-24	GULBARGA	66	LINE	MUNIRABAD-TIE LINE	MUNIRABAD_220	18:09	18:18	00:09	TRIPPED ON FAULT
3949	20-Dec-24	GULBARGA	110	LINE	MUNIRABD-HARIKRISHNA	KIRLOSKAR_IPP	15:00	15:57	00:57	LINE CLEAR AVAILED
3950	20-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3951	20-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 1	GABBUR_110,DEODURGA_110	15:24	17:58	02:34	LINE CLEAR AVAILED
3952	20-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 2	GUGAL_110	11:25	12:38	01:13	TRIPPED ON FAULT
3953	20-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-SEDAM2	RAMASAMUDRA_220	11:18	15:01	03:43	LINE CLEAR AVAILED
3954	20-Dec-24	GULBARGA	110	LINE	SHAHAPUR-JEEWARGI	JEEWARGI_110	07:42	10:48	03:06	LINE CLEAR AVAILED
3955	20-Dec-24	GULBARGA	110	LINE	SHAHAPUR-M.KOLLUR	M.KOLLUR_110	07:42	07:59	00:17	LINE CLEAR AVAILED
3956	20-Dec-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	DEODURGA_110	07:42	07:59	00:17	LINE CLEAR AVAILED
3957	20-Dec-24	GULBARGA	110	LINE	SULEKAL-SORABHA SOLAR	SULEKAL_220	17:20	20:40	03:20	LINE CLEAR AVAILED
3958	20-Dec-24	HASAN	110	LINE	AJAMPU-KADUR	AJJAMPURA_110	15:30	15:40	00:10	MAIN SUPPLY FAILURE
3959	20-Dec-24	HASAN	110	LINE	AJAMPU-SHIVANI	AJJAMPURA_110	06:10	08:25	02:15	TRIPPED ON FAULT
3960	20-Dec-24	HASAN	66	LINE	CHANNAR-UDAYPURA	CHANNARAYAPATNA_66	07:24	07:57	00:33	TRIPPED ON FAULT
3961	20-Dec-24	HASAN	66	LINE	HNPR2-HASS2	HOLENARASIPURA_220	11:18	12:18	01:00	LINE CLEAR AVAILED
3962	20-Dec-24	HASAN	66	LINE	HNPR2-HASS3	HOLENARASIPURA_220	11:49	12:01	00:12	LINE CLEAR AVAILED
3963	20-Dec-24	HASAN	110	TRANSFORMER	HV1	AJJAMPURA_110	14:55	15:15	00:20	TRIPPED ON FAULT
3964	20-Dec-24	HASAN	220	TRANSFORMER	HV1	MSEZ_220	09:59	12:11	02:12	LINE CLEAR AVAILED
3965	20-Dec-24	HASAN	66	TRANSFORMER	HV1	RAMESHWARNAGARA_66	10:38	14:37	03:59	LINE CLEAR AVAILED
3966	20-Dec-24	HASAN	110	TRANSFORMER	HV1	SORABA_110	18:25	19:24	00:59	LINE CLEAR AVAILED
3967	20-Dec-24	HASAN	66	TRANSFORMER	HV1	UGANE_66	10:25	15:34	05:09	LINE CLEAR AVAILED
3968	20-Dec-24	HASAN	110	TRANSFORMER	HV1	VITLA_110	10:59	15:29	04:30	LINE CLEAR AVAILED
3969	20-Dec-24	HASAN	110	TRANSFORMER	HV2	KADUR_220	16:04	17:11	01:07	LINE CLEAR AVAILED
3970	20-Dec-24	HASAN	220	TRANSFORMER	HV2	KEMAR_220	10:09	11:50	01:41	LINE CLEAR AVAILED
3971	20-Dec-24	HASAN	110	TRANSFORMER	HV2	MRSMG_220	09:02	15:12	06:10	LINE CLEAR AVAILED
3972	20-Dec-24	HASAN	220	TRANSFORMER	HV2	MSEZ_220	12:13	14:05	01:52	LINE CLEAR AVAILED
3973	20-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	10:38	14:36	03:58	LINE CLEAR AVAILED
3974	20-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	09:08	09:41	00:33	TRIPPED ON FAULT
3975	20-Dec-24	HASAN	110	TRANSFORMER	HV2	VITLA_110	13:51	15:30	01:39	LINE CLEAR AVAILED
3976	20-Dec-24	HASAN	110	TRANSFORMER	HV2 CB	BELAGUMBA_110	14:23	15:27	01:04	LINE CLEAR AVAILED
3977	20-Dec-24	HASAN	220	TRANSFORMER	HV3	KAVOOR_220	14:20	18:05	03:45	LINE CLEAR AVAILED
3978	20-Dec-24	HASAN	110	TRANSFORMER	HV3	MRSMG_220	09:02	15:12	06:10	LINE CLEAR AVAILED
3979	20-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
3980	20-Dec-24	HASAN	220	LINE	KADUR0DABUSET	KADUR_220	11:09(20.12.2024)	12:47(21.12.2024)	25:37 hrs	LINE CLEAR AVAILED
3981	20-Dec-24	HASAN	110	LINE	KADUR-AJAMPURA	KADUR_220	15:38	16:24	00:46	LINE CLEAR AVAILED
3982	20-Dec-24	HASAN	110	LINE	KADUR-TNGL	KADUR_220	10:32	13:54	03:22	LINE CLEAR AVAILED
3983	20-Dec-24	HASAN	110	LINE	KARKLA-L1	KARKALA_110	09:53	11:54	02:01	LINE CLEAR AVAILED
3984	20-Dec-24	HASAN	110	LINE	KARKLA-L2	KARKALA_110	11:54	11:57	00:03	LINE CLEAR AVAILED
3985	20-Dec-24	HASAN	110	LINE	KARKLA-L2	KARKALA_110	09:48	09:53	00:05	LINE CLEAR AVAILED
3986	20-Dec-24	HASAN	66	LINE	KIADB H-RAMESWARNAGAR	KIADB HASSAN_66	10:35	14:35	04:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
3987	20-Dec-24	HASAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	10:26	17:06	06:40	LINE CLEAR AVAILED
3988	20-Dec-24	HASAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:30	15:50	05:20	LINE CLEAR AVAILED
3989	20-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	09:59	12:11	02:12	LINE CLEAR AVAILED
3990	20-Dec-24	HASAN	110	TRANSFORMER	LV2	KEMAR_220	10:09	11:50	01:41	LINE CLEAR AVAILED
3991	20-Dec-24	HASAN	110	TRANSFORMER	LV2	MSEZ_220	12:13	14:05	01:52	LINE CLEAR AVAILED
3992	20-Dec-24	HASAN	110	TRANSFORMER	LV3	KAVOOR_220	14:20	18:05	03:45	LINE CLEAR AVAILED
3993	20-Dec-24	HASAN	110	LINE	MOODAB-KEMAR	MOODABIDRE_110	09:28	11:54	02:26	LINE CLEAR AVAILED
3994	20-Dec-24	HASAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	08:34	14:18	05:44	LINE CLEAR AVAILED
3995	20-Dec-24	HASAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:38	14:36	03:58	LINE CLEAR AVAILED
3996	20-Dec-24	HASAN	110	LINE	SALATHU-KONAJE	SALATHUR_110	10:39	13:55	03:16	LINE CLEAR AVAILED
3997	20-Dec-24	HASAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	13:36	15:47	02:11	LINE CLEAR AVAILED
3998	20-Dec-24	HASAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:38	14:36	03:58	LINE CLEAR AVAILED
3999	20-Dec-24	HASAN	110	LINE	SHIRAL-SANDA	SHIRALKOPPA_110	11:16	18:20	07:04	LINE CLEAR AVAILED
4000	20-Dec-24	HASAN	110	LINE	SHRLKP-KITTDADAHALLI	SHIRALKOPPA_220	11:09	13:34	02:25	LINE CLEAR AVAILED
4001	20-Dec-24	HASAN	110	LINE	SHRLKP-MAVALI	SHIRALKOPPA_220	12:50	15:06	02:16	LINE CLEAR AVAILED
4002	20-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	12:45	14:20	01:35	LINE CLEAR AVAILED
4003	20-Dec-24	HASAN	66	LINE	UDDURKO-SUZLON1	UDDURKOPLU_66	08:10	08:40	00:30	TRIPPED ON FAULT
4004	20-Dec-24	HASAN	66	LINE	UGANE-L2	UGANE_66	10:25	15:34	05:09	LINE CLEAR AVAILED
4005	20-Dec-24	HASAN	110	LINE	VITTAL-PUTR_SLTUR	VITLA_110	13:35	15:29	01:54	LINE CLEAR AVAILED
4006	20-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
4007	20-Dec-24	MYSORE	66	LINE	CHANDALLI-THALAKADU	THALAKADU_66	15:36	17:30	01:54	LINE CLEAR AVAILED
4008	20-Dec-24	MYSORE	66	LINE	HANNUR-ECORN_WND	NO STATIONS EFFECTED	08:52	11:48	02:55	LINE CLEAR AVAILED
4009	20-Dec-24	MYSORE	66	LINE	HDKOTE-TARAKA	NO STATIONS EFFECTED	10:32	14:38	04:05	LINE CLEAR AVAILED
4010	20-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
4011	20-Dec-24	MYSORE	66	LINE	HOTAGALLY-BOGHADI	NO STATIONS EFFECTED	16:33	16:35	00:02	LINE CLEAR AVAILED
4012	20-Dec-24	MYSORE	66	LINE	HOTAGALLY-DATTAGALLI	DATTAGALLY_66	10:09	16:53	06:44	LINE CLEAR AVAILED
4013	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	07:05	07:34	00:28	TRIPPED ON FAULT
4014	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	07:00	07:40	00:40	LINE CLEAR AVAILED
4015	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	10:31	13:01	02:29	LINE CLEAR AVAILED
4016	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	GARUDANAUKADDA_66	10:20	19:18	08:58	LINE CLEAR AVAILED
4017	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	09:48	11:22	01:33	LINE CLEAR AVAILED
4018	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANTHEBACHALLI_66	09:18	16:43	07:25	LINE CLEAR AVAILED
4019	20-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4020	20-Dec-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	09:48	11:22	01:33	LINE CLEAR AVAILED
4021	20-Dec-24	MYSORE	66	TRANSFORMER	HV2	MADESHWARAPURA_66	11:50	12:50	01:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4022	20-Dec-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	08:05	15:54	07:48	LINE CLEAR AVAILED
4023	20-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4024	20-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4025	20-Dec-24	MYSORE	66	LINE	KIRUGAVALU-MALIYUR	MALIYURU_66	10:31	16:11	05:40	LINE CLEAR AVAILED
4026	20-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
4027	20-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
4028	20-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	09:48	10:29	00:40	LINE CLEAR AVAILED
4029	20-Dec-24	MYSORE	66	LINE	MUGUR-THAYUR	TNARASIPURA_66 THAYURU_66 GARGESHWARI_66	06:50	06:55	00:05	TRIPPED ON FAULT
4030	20-Dec-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 1	NO STATIONS EFFECTED	11:45	14:43	02:58	LINE CLEAR AVAILED
4031	20-Dec-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	14:47	15:38	00:51	LINE CLEAR AVAILED
4032	20-Dec-24	MYSORE	66	LINE	PERIAPATNA-HUNSUR	KAMPLAPURA_66	10:31	17:30	06:58	LINE CLEAR AVAILED
4033	20-Dec-24	MYSORE	66	LINE	RKNAGAR-DATTAGALLI	DATTAGALLY_66	09:48	17:13	07:24	LINE CLEAR AVAILED
4034	20-Dec-24	MYSORE	66	LINE	SANVARSANTE-YESSLUR	YETTUR_66 YESSALURU_66	14:26	14:35	00:09	LINE CLEAR AVAILED
4035	20-Dec-24	MYSORE	66	LINE	SUTTUR-ALAMBUR LIS EHT	NO STATIONS EFFECTED	15:37	16:35	00:58	LINE CLEAR AVAILED
4036	20-Dec-24	MYSORE	66	LINE	YATHMBADI-TKHALLI	NO STATIONS EFFECTED	12:15	13:32	01:17	LINE CLEAR AVAILED
4037	20-Dec-24	TUMKUR	220	LINE	100 MVA TR-1 AND 100 MVA TR-2 , K.B. CROSS_220KV	110KV TIPTUR, 110KV AMMASANDRA, 110KV TURUVEKERE, 110KV CHIKKANAYAKANAHALLI, 110KV THIMMENAHALLI	5:49	6:06	0:17	TRIPPED ON FAULT
4038	20-Dec-24	TUMKUR	220	LINE	100MVA TR-1 ,220KV KIADB HV SIDE	KDBVNP_220KV	14:34	15:44	1:10	LINE CLEAR AVAILED
4039	20-Dec-24	TUMKUR	220	LINE	100MVA TR-2 ,220KV KIADB HV SIDE	KDBVNP_220KV	15:46	17:26	1:40	LINE CLEAR AVAILED
4040	20-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV DEVARAHALLI	66KV DEVARAHALLI,SANTHEBENNUR,KEREBILACHI	15:19	15:30	0:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4041	20-Dec-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDRAHALLI LINE1	66KV SIRIGERI. BARAMASAGARA, VIJAYAPURA	10:11	10:21	0:10	TRIPPED ON FAULT
4042	20-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA	66KV MYLANAHALLI, VV PURA AND DYAVARANAHALLI	5:54	6:09	0:15	TRIPPED ON FAULT
4043	20-Dec-24	TUMKUR	66	LINE	220KVANTHRASANAHALLI - CHELUR LINE	66KVCHELUR, HAGALWADI, NANDIHALLI CROSS, HOSAKERE	5:47	5:55	0:08	TRIPPED ON FAULT
4044	20-Dec-24	TUMKUR	220	LINE	ANCHEPALYA_220KV - NAGAMANGALA-1	NAGAMANGALA-1	11:44	14:43	2:59	LINE CLEAR AVAILED
4045	20-Dec-24	TUMKUR	220	LINE	ANCHEPALYA_220KV - NAGAMANGALA-2	NAGAMANGALA-2	14:47	15:38	0:51	LINE CLEAR AVAILED
4046	20-Dec-24	TUMKUR	220	LINE	ANTHRASANAHALLI_220-K.B.CROSS,I/C LINE	220 KV BUS COUPLER CHARGED AND SUPPLY RESTORED FROM 220 KV SHIMOOGHA LINE AT 6:06HRS	5:49	6:06	0:17	TRIPPED ON FAULT
4047	20-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-CHANNAGIRI	LINGADAHALLI_66, CHANNAGIRI_66	21:22	22:25	1:03	LINE CLEAR AVAILED
4048	20-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREHILCHI_66	15:37	15:50	0:13	LINE CLEAR AVAILED
4049	20-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREHILCHI_66	15:50	22:35	6:45	LINE CLEAR AVAILED
4050	20-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	21:22	22:25	1:03	LINE CLEAR AVAILED
4051	20-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-NALLUR	NALLUR_66	21:22	22:25	1:03	LINE CLEAR AVAILED
4052	20-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	7:57	8:40	0:43	LINE CLEAR AVAILED
4053	20-Dec-24	TUMKUR	66	LINE	HANAGAL- RAMPURA	RAMAPURA_66 NAGASAMUDRA_66	6:40	7:01	0:21	LINE CLEAR AVAILED
4054	20-Dec-24	TUMKUR	66	LINE	HANGAL66-THALLAK 1	HANGAL_66	6:40	6:58	0:18	TRIPPED ON FAULT
4055	20-Dec-24	TUMKUR	110	LINE	KATRIKEHAL-THIMMANAHALLI_110	KATRIKEHAL_110	12:20	15:40	3:20	MAIN SUPPLY FAILURE
4056	20-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV-ANTHARASANAHALLI	ANTHARASANAHALLI_220	5:49	6:06	0:17	TRIPPED ON FAULT
4057	20-Dec-24	TUMKUR	220	LINE	KDBVNP_PGCL	KDBVNP_220	12:17	13:54	1:37	LINE CLEAR AVAILED
4058	20-Dec-24	TUMKUR	66	LINE	PAVAGADA220-NAGALMADIKE LINE-1	NAGALMADIKE_66	18:25	18:45	0:20	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4059	20-Dec-24	TUMKUR	66	LINE	PAVAGADA220-NAGALMADIKE LINE-2	NAGALMADIKE_66	18:25	18:45	0:20	TRIPPED ON FAULT
4060	20-Dec-24	TUMKUR	66	TRANSFORMER	TR1 ,8 MVA TAVARAKERE 66@	TAVARAKERE _66	12:45	12:55	0:10	TRIPPED ON FAULT
4061	20-Dec-24	TUMKUR	66	LINE	TR1, 12.5 MVA HULIYURDURGA_66	HULIYURDURGA_66	10:10	18:05	7:55	LINE CLEAR AVAILED
4062	20-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA HULIYURDURGA_66	HULIYURDURGA_66	10:10	18:05	7:55	LINE CLEAR AVAILED
4063	20-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA SASALUHALLA_66	SASALUHALLA_66	18:40	18:50	0:10	TRIPPED ON FAULT
4064	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	JAMAKHANDI_110	10:16	17:53	07:37	LINE CLEAR AVAILED
4065	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	11:01	11:05	00:04	LINE CLEAR AVAILED
4066	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	JAMAKHANDI_110	10:16	17:54	07:38	LINE CLEAR AVAILED
4067	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ALBAL_110	00:04	00:29	00:25	TRIPPED ON FAULT
4068	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	22:05	22:10	00:05	TRIPPED ON FAULT
4069	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	TERDAL_110	16:00	16:15	00:15	TRIPPED ON FAULT
4070	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	HUKKERI_110	18:03	18:06	00:03	TRIPPED ON FAULT
4071	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV(20MVA)	HUBLI_220	09:52	14:35	04:43	LINE CLEAR AVAILED
4072	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (10MVA)	SHIGGOAN_110	12:01	12:35	00:34	LINE CLEAR AVAILED
4073	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA)	UCHAGOAN_110	13:10	15:45	02:35	LINE CLEAR AVAILED
4074	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
4075	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	07:30	07:36	00:06	TRIPPED ON FAULT
4076	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	UCHAGOAN_110	11:26	13:02	01:36	LINE CLEAR AVAILED
4077	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULGERI CROSS_110	00:12	00:16	00:04	TRIPPED ON FAULT
4078	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULGERI CROSS_110	10:11	10:15	00:04	TRIPPED ON FAULT
4079	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MAMADAPUR_110	11:25	11:47	00:22	LINE CLEAR AVAILED
4080	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	KADANAKOPPA_110	03:49	04:09	00:20	TRIPPED ON FAULT
4081	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	KADANAKOPPA_110	04:15	04:20	00:05	TRIPPED ON FAULT
4082	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	KADANAKOPPA_110	11:43	18:08	06:25	LINE CLEAR AVAILED
4083	21-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	MK HUBLI_110	15:01	17:24	02:23	LINE CLEAR AVAILED
4084	21-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4085	21-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED HUBLI_220	9:23 (19.12.2024)	17:46 (21.12.2024)	56:29:00	LINE CLEAR AVAILED
4086	21-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4087	21-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED HUBLI_220	9:22 (19.12.2024)	17:46 (21.12.2024)	56:28:00	LINE CLEAR AVAILED
4088	21-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
4089	21-Dec-24	BAGALKOTE	110	LINE	AEQUES220-LN3(DADDI)	AEQUES_220	02:07	15:07	13:00	TRIPPED ON FAULT
4090	21-Dec-24	BAGALKOTE	220	LINE	AEQUS -F1(BELAGAVI -1)	AEQUES_220	07:48	10:00	02:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4091	21-Dec-24	BAGALKOTE	220	LINE	AEQUS -F2(BELAGAVI-2)	AEQUES_220	03:08	10:05	06:57	TRIPPED ON FAULT
4092	21-Dec-24	BAGALKOTE	110	LINE	AMEWADI220-NK-2	AMBEWADI_220	10:07	17:19	07:12	LINE CLEAR AVAILED
4093	21-Dec-24	BAGALKOTE	110	LINE	ARGA-KARWAR	ARGA_110	06:44	06:46	00:02	LINE CLEAR AVAILED
4094	21-Dec-24	BAGALKOTE	110	LINE	BAGEWADI-MAMADAPUR1	BAGEWADI_220	02:13	02:25	00:12	TRIPPED ON FAULT
4095	21-Dec-24	BAGALKOTE	110	LINE	BAGEWADI-MAMADAPUR1	BAGEWADI_220	06:51	06:58	00:07	TRIPPED ON FAULT
4096	21-Dec-24	BAGALKOTE	110	LINE	BAGEWADI-MAMADAPUR2	BAGEWADI_220	02:13	02:25	00:12	TRIPPED ON FAULT
4097	21-Dec-24	BAGALKOTE	110	LINE	BAGEWADI-MAMADAPUR2	BAGEWADI_220	06:51	06:58	00:07	TRIPPED ON FAULT
4098	21-Dec-24	BAGALKOTE	110	LINE	BELGAUM220-HUKKERI(UCHGAON -UDYAMBAG)	220KV BELAGAVI	02:46	02:58	00:12	TRIPPED ON FAULT
4099	21-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 1	BELAGAVI_220	07:48	10:00	02:12	LINE CLEAR AVAILED
4100	21-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 2	BELGAUM_220	03:08	10:01	06:53	TRIPPED ON FAULT
4101	21-Dec-24	BAGALKOTE	220	LINE	BIDNAL-ANNIGERI	BIDNAL_220	17:25	19:20	01:55	LINE CLEAR AVAILED
4102	21-Dec-24	BAGALKOTE	220	LINE	BIDNAL-GADAG ROAD	BIDNAL_220	10:51	14:44	03:53	LINE CLEAR AVAILED
4103	21-Dec-24	BAGALKOTE	220	LINE	BIDNAL-HARTHI1	BIDNAL_220	15:43	18:07	02:24	LINE CLEAR AVAILED
4104	21-Dec-24	BAGALKOTE	220	LINE	BIDNAL-HARTHI2	BIDNAL_220	18:16	20:09	01:53	LINE CLEAR AVAILED
4105	21-Dec-24	BAGALKOTE	110	LINE	DADDI-F1(AEQUS)	DADDI_110	03:15	15:14	11:59	LINE CLEAR AVAILED
4106	21-Dec-24	BAGALKOTE	110	LINE	DADDI-F2(HONAGA)	DADDI_110	15:10	15:14	00:04	LINE CLEAR AVAILED
4107	21-Dec-24	BAGALKOTE	110	LINE	GADAG220- GADAG1(BETAGERI)	GADAG_220	10:52	17:06	06:14	LINE CLEAR AVAILED
4108	21-Dec-24	BAGALKOTE	220	LINE	GADAG220- HARTI -1	GADAG_220	12:05	19:47	07:42	LINE CLEAR AVAILED
4109	21-Dec-24	BAGALKOTE	110	LINE	GADAGROAD- GOPNK(BIDNAL)	GADAGROAD_110	10:28	15:05	04:37	LINE CLEAR AVAILED
4110	21-Dec-24	BAGALKOTE	220	LINE	GHATPRABHA220- NARENDRA -1	GHATAPRABHA_220	11:22	17:06	05:44	LINE CLEAR AVAILED
4111	21-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
4112	21-Dec-24	BAGALKOTE	110	LINE	HIREMURAL- F1(MUDEBEHAL)	HIREMURAL_110	02:15	02:20	00:05	LINE CLEAR AVAILED
4113	21-Dec-24	BAGALKOTE	110	LINE	HONAGA-DADDI	HONAGA_110	02:46	03:12	00:26	TRIPPED ON FAULT
4114	21-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4115	21-Dec-24	BAGALKOTE	220	LINE	HUBLI220-SIRSI1	HUBLI_220	12:31	16:30	03:59	LINE CLEAR AVAILED
4116	21-Dec-24	BAGALKOTE	220	LINE	HUBLI220-SIRSI2	HUBLI_220	12:32	16:31	03:59	LINE CLEAR AVAILED
4117	21-Dec-24	BAGALKOTE	110	LINE	KARWAR220-ARGA	KARWAR_220	06:27	06:45	00:18	TRIPPED ON FAULT
4118	21-Dec-24	BAGALKOTE	110	LINE	KAWALWADA-NK- 2(AMBEWADI)	KAWALWADA_110	10:00	17:10	07:10	LINE CLEAR AVAILED
4119	21-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4120	21-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	07:54	08:17	00:23	TRIPPED ON FAULT
4121	21-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	05:32	05:45	00:13	TRIPPED ON FAULT
4122	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI	MALGHAN_110	02:22	02:29	00:07	TRIPPED ON FAULT
4123	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI	MALGHAN_110	06:52	07:13	00:21	TRIPPED ON FAULT
4124	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BAGEWADI	MALGHAN_110	21:51	21:56	00:05	TRIPPED ON FAULT
4125	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVA SUG	MALGHAN_110	02:22	02:29	00:07	TRIPPED ON FAULT
4126	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVA SUG	MALGHAN_110	06:52	07:14	00:22	TRIPPED ON FAULT
4127	21-Dec-24	BAGALKOTE	110	LINE	MALGHAN-BASAVA SUG	MALGHAN_110	21:51	21:57	00:06	TRIPPED ON FAULT
4128	21-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-B.BAGEWADI2	MAMADAPUR_110	02:23	12:47	10:24	LINE CLEAR AVAILED
4129	21-Dec-24	BAGALKOTE	110	LINE	MAMADAPUR-B.BAGEWADI2	MAMADAPUR_110	21:51	22:06	00:15	TRIPPED ON FAULT
4130	21-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4131	21-Dec-24	BAGALKOTE	220	LINE	NARENDRA-BELGAUM2	NARENDRA_220	18:19 (21.12.2024)			LINE CLEAR AVAILED
4132	21-Dec-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI2	NARENDRA_220	13:25	15:59	02:34	LINE CLEAR AVAILED
4133	21-Dec-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI2	NARENDRA_220	06:01	06:40	00:39	TRIPPED ON FAULT
4134	21-Dec-24	BAGALKOTE	220	LINE	NARENDRA-SHIGGOAN1	NARENDRA_220	13:27	17:42	04:15	TRIPPED ON FAULT
4135	21-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
4136	21-Dec-24	BAGALKOTE	110	LINE	SADALA-VPPL	SADALAGA_110	09:50	14:04	04:14	LINE CLEAR AVAILED
4137	21-Dec-24	BAGALKOTE	220	LINE	SHIGGAON220-NARENDRA	220KV SHIGGAON_220	13:27	17:20	03:53	TRIPPED ON FAULT
4138	21-Dec-24	BAGALKOTE	110	LINE	SOUDATTI220-MMCL	SOUDATTI_220	11:06	11:29	00:23	TRIPPED ON FAULT
4139	21-Dec-24	BAGALKOTE	110	LINE	SUARNAS-MACHE O/G	SUVARNA SOUDHA_110	6:38 (17.12.2024)	11:02 (21.12.2024)	100:24:00	LINE CLEAR AVAILED
4140	21-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
4141	21-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
4142	21-Dec-24	BANGALORE	220	LINE	220KV EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	12:30	14:54	02:24	LINE CLEAR AVAILED
4143	21-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4144	21-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4145	21-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DABASPETE 220 (B3)	DABUSPETE 220	12:30	12:47	00:17	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4146	21-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
4147	21-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 1	T GOLLAHALLI 220	09:23	18:33	09:10	LINE CLEAR AVAILED
4148	21-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 2	T GOLLAHALLI 220	09:24	18:33	09:09	LINE CLEAR AVAILED
4149	21-Dec-24	BANGALORE	220	LINE	220KV SAHAKARNAGAR 220 - HEBBAL 220 - CPRI	HEBBALA 220, CPRI 220	16:30	16:40	00:10	TRIPPED ON FAULT
4150	21-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	BMRL, YARANDANAHALLI 220	13:21	13:49	00:28	TRIPPED ON FAULT
4151	21-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	BMRL, YARANDANAHALLI 220	14:45	23:59	09:14	TRIPPED ON FAULT
4152	21-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	10:10	10:13	00:03	LINE CLEAR AVAILED
4153	21-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	22:37	22:44	00:07	TRIPPED ON FAULT
4154	21-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	22:47	23:00	00:13	TRIPPED ON FAULT
4155	21-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	16:44	16:55	00:11	TRIPPED ON FAULT
4156	21-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:01	10:05	00:04	LINE CLEAR AVAILED
4157	21-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	NO STATION AFFECTED	18:14	20:31	02:17	TRIPPED ON FAULT
4158	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - AVERAHALLI	AVERAHALLI, T BEGUR	12:30	12:47	00:17	MAIN SUPPLY FAILURE
4159	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - HIREHALLI	HIREHALLI	12:30	12:47	00:17	MAIN SUPPLY FAILURE
4160	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - JINDAL (EHT)	JINDAL(EHT)	12:30	12:47	00:17	MAIN SUPPLY FAILURE
4161	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - NELAMANGALA CKT 1	NELAMANGALA 66	12:30	12:47	00:17	MAIN SUPPLY FAILURE
4162	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - SK STEEL	SK STEEL, KOLALA	12:30	12:47	00:17	MAIN SUPPLY FAILURE
4163	21-Dec-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	12:30	12:52	00:22	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4164	21-Dec-24	BANGALORE	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI 1)	ELECTRONIC CITY PH2 SEC 2, TATA BP SOLAR, CHOKKASANDRA	12:20	12:25	00:05	LINE CLEAR AVAILED
4165	21-Dec-24	BANGALORE	66	LINE	66KV GOKULA - RMV	RMV, IISc(EHT)	17:34	17:41	00:07	LINE CLEAR AVAILED
4166	21-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4167	21-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI(HV1 & HV3)	16:30	16:45	00:15	MAIN SUPPLY FAILURE
4168	21-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	16:30	16:42	00:12	MAIN SUPPLY FAILURE
4169	21-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	16:30	16:42	00:12	MAIN SUPPLY FAILURE
4170	21-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	16:30	16:46	00:16	LINE CLEAR AVAILED
4171	21-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4	GRINDWELL NORTON(EHT)	07:02	07:17	00:15	TRIPPED ON FAULT
4172	21-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)	NO STATION AFFECTED	12:09	17:38	05:29	LINE CLEAR AVAILED
4173	21-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	20:35	20:40	00:05	LINE CLEAR AVAILED
4174	21-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - LAKKUR	LAKKUR, DEVANAGUNDHI	18:09	18:29	00:20	TRIPPED ON FAULT
4175	21-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - BYATARAYANAPURA (L&T) _DG4	BYATARAYANAPURA	17:25	17:35	00:10	LINE CLEAR AVAILED
4176	21-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - BYATARAYANAPURA (L&T) _DG4	SAHAKARNAGAR 66	16:55	17:07	00:12	LINE CLEAR AVAILED
4177	21-Dec-24	BANGALORE	66	LINE	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY PH2 SEC 2, TATA BP SOLAR, CHOKKASANDRA	09:41	10:51	01:10	TRIPPED ON FAULT
4178	21-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	16:48	16:51	00:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4179	21-Dec-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - VICTORIA HOSPITAL	VICTORIA HOSPITAL	22:34	22:37	00:03	LINE CLEAR AVAILED
4180	21-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	21:43	21:48	00:05	LINE CLEAR AVAILED
4181	21-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	GUNDAMGERE, SASALU, DODDABELAVANGALA	11:11	11:19	00:08	TRIPPED ON FAULT
4182	21-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	11:18	11:19	00:01	LINE CLEAR AVAILED
4183	21-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KHB DC_SC_DG1	NO STATION AFFECTED	10:55	18:44	07:49	LINE CLEAR AVAILED
4184	21-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - SAHAKARNAGAR 66	SAHAKARNAGAR 66	12:42	12:56	00:14	LINE CLEAR AVAILED
4185	21-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	12:45	13:05	00:20	LINE CLEAR AVAILED
4186	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	10:01	10:05	00:04	LINE CLEAR AVAILED
4187	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE(HV2,HV3)	15:47	16:13	00:26	LINE CLEAR AVAILED
4188	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE(HV2,HV3)	12:20	12:55	00:35	LINE CLEAR AVAILED
4189	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:47	16:00	00:13	LINE CLEAR AVAILED
4190	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:08	16:35	00:27	LINE CLEAR AVAILED
4191	21-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:01	10:05	00:04	LINE CLEAR AVAILED
4192	21-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA - BMRCL PEENYA 66/33KV (EHT)	NO STATION AFFECTED	00:46	00:57	00:11	LINE CLEAR AVAILED
4193	21-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA - BMRCL PEENYA 66/33KV (EHT)	NO STATION AFFECTED	10:02	17:28	07:26	LINE CLEAR AVAILED
4194	21-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	17:00	17:51	00:51	LINE CLEAR AVAILED
4195	21-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	17:03	17:52	00:49	LINE CLEAR AVAILED
4196	21-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II	ALUR, BIEC	10:20	17:23	07:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4197	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR	PADMANABHANAGARA	10:42	10:50	00:08	LINE CLEAR AVAILED
4198	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR - AREHALLI	AREHALLI	14:19	15:00	00:41	LINE CLEAR AVAILED
4199	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL TECH	14:49	15:00	00:11	LINE CLEAR AVAILED
4200	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	RR NAGAR	16:34	16:38	00:04	LINE CLEAR AVAILED
4201	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	RR NAGAR	14:14	15:02	00:48	LINE CLEAR AVAILED
4202	21-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	11:43	13:32	01:49	LINE CLEAR AVAILED
4203	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	09:10	21:15	12:05	LINE CLEAR AVAILED
4204	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	09:10	19:25	10:15	LINE CLEAR AVAILED
4205	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA,BEML	09:10	23:59	14:49	LINE CLEAR AVAILED
4206	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA,BEML	09:10	19:28	10:18	LINE CLEAR AVAILED
4207	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALL, DODDAKARI	09:10	19:23	10:13	LINE CLEAR AVAILED
4208	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	09:10	19:22	10:12	LINE CLEAR AVAILED
4209	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	09:10	19:22	10:12	LINE CLEAR AVAILED
4210	21-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	THAYALUR, MN HALLI, NG HULKUR	09:10	19:22	10:12	LINE CLEAR AVAILED
4211	21-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	YETHAMBADI, IGGALURU, K HONALGERE	18:27	18:42	00:15	TRIPPED ON FAULT
4212	21-Dec-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUDNLU KOTTUR	18:05	18:10	00:05	TRIPPED ON FAULT
4213	21-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	10:30	15:35	05:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4214	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	10:22	15:20	04:58	LINE CLEAR AVAILED
4215	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	05:30	05:34	00:04	LINE CLEAR AVAILED
4216	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	NO STATION AFFECTED	11:30	17:32	06:02	LINE CLEAR AVAILED
4217	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - REMCO	REMCO	11:09	14:41	03:32	LINE CLEAR AVAILED
4218	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - RR NAGAR	RR NAGAR	12:10	12:13	00:03	LINE CLEAR AVAILED
4219	21-Dec-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	10:13	15:25	05:12	LINE CLEAR AVAILED
4220	21-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	13:21	13:50	00:29	MAIN SUPPLY FAILURE
4221	21-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	14:45	15:01	00:16	MAIN SUPPLY FAILURE
4222	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DOMMASANDRA	10:20	14:00	03:40	LINE CLEAR AVAILED
4223	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GUNDAMGERE	03:18	03:26	00:08	TRIPPED ON FAULT
4224	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	H GOLLAHALLI	09:10	17:40	08:30	LINE CLEAR AVAILED
4225	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HAL 220	15:30	15:33	00:03	LINE CLEAR AVAILED
4226	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MEI LAYOUT	01:32	01:40	00:08	TRIPPED ON FAULT
4227	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	RMV	10:27	10:32	00:05	LINE CLEAR AVAILED
4228	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SAHAKARINAGAR 66	12:57	13:00	00:03	LINE CLEAR AVAILED
4229	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	10:01	16:09	06:08	LINE CLEAR AVAILED
4230	21-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	10:02	15:45	05:43	LINE CLEAR AVAILED
4231	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	T GOLLAHALLI 220	09:22	19:19	09:57	LINE CLEAR AVAILED
4232	21-Dec-24	BANGALORE	220	TRANSFORMER	HV1	T GOLLAHALLI 220	09:23	19:26	10:03	LINE CLEAR AVAILED
4233	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	06:18	06:25	00:07	LINE CLEAR AVAILED
4234	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	22:10	22:17	00:07	LINE CLEAR AVAILED
4235	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	07:15	07:45	00:30	LINE CLEAR AVAILED
4236	21-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VRUSHABHAVATHI 220	10:03	16:42	06:39	LINE CLEAR AVAILED
4237	21-Dec-24	BANGALORE	220	TRANSFORMER	HV1	VRUSHABHAVATHI 220	12:37	15:53	03:16	LINE CLEAR AVAILED
4238	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DOMMASANDRA	10:20	14:00	03:40	LINE CLEAR AVAILED
4239	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	H GOLLAHALLI	09:10	17:40	08:30	LINE CLEAR AVAILED
4240	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SAHAKARINAGAR 66	11:30	11:38	00:08	LINE CLEAR AVAILED
4241	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	10:01	16:12	06:11	LINE CLEAR AVAILED
4242	21-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SARJAPURA 220	10:02	15:45	05:43	LINE CLEAR AVAILED
4243	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR_66	16:20	16:40	00:20	TRIPPED ON FAULT
4244	21-Dec-24	BANGALORE	220	TRANSFORMER	HV2	T GOLLAHALLI 220	09:23	18:35	09:12	LINE CLEAR AVAILED
4245	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VRUSHABHAVATHI 220	10:03	16:37	06:34	LINE CLEAR AVAILED
4246	21-Dec-24	BANGALORE	220	TRANSFORMER	HV2	VRUSHABHAVATHI 220	12:37	16:39	04:02	LINE CLEAR AVAILED
4247	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	13:21	13:50	00:29	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4248	21-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	14:45	15:01	00:16	MAIN SUPPLY FAILURE
4249	21-Dec-24	BANGALORE	66	TRANSFORMER	HV3	SAHAKARINAGAR 66	10:30	10:46	00:16	LINE CLEAR AVAILED
4250	21-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	13:21	13:50	00:29	MAIN SUPPLY FAILURE
4251	21-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	14:45	15:01	00:16	MAIN SUPPLY FAILURE
4252	21-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	13:21	13:50	00:29	MAIN SUPPLY FAILURE
4253	21-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	14:45	15:01	00:16	MAIN SUPPLY FAILURE
4254	21-Dec-24	GULBARGA	66	LINE	BADALADUKU-KOTTUR	KOTTUR_66	10:00	14:35	04:35	LINE CLEAR AVAILED
4255	21-Dec-24	GULBARGA	66	LINE	BADALADUKU-UJJINI	UJJINI_66,SOKKE_66,NIMB ALGERI_66	09:30	14:25	04:55	LINE CLEAR AVAILED
4256	21-Dec-24	GULBARGA	66	LINE	BADALADUKU-UJJINI	UJJINI_66,SOKKE_66,NIMB ALGERI_66	18:10	18:40	00:30	TRIPPED ON FAULT
4257	21-Dec-24	GULBARGA	220	LINE	BTPS-ALIPUR	ALIPUR_220,LINGAPUR_2 20	23:37(20.12.2024)	1:57(21.12.2024)	2:20:00	LINE CLEAR AVAILED
4258	21-Dec-24	GULBARGA	220	LINE	BTPS-LINGAPURA	ALIPUR_220,LINGAPUR_2 20	9:32(20.12.2024)	17:27(21.12.2024)	31:55:00	LINE CLEAR AVAILED
4259	21-Dec-24	GULBARGA	110	LINE	BYAGWAT-WALKAMDINNI	WALKAMDINNI_110	09:06	09:15	00:09	TRIPPED ON FAULT
4260	21-Dec-24	GULBARGA	110	LINE	HALBARGA-KOLHAR2	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY_IPP	15:57	17:30	01:33	LINE CLEAR AVAILED
4261	21-Dec-24	GULBARGA	110	LINE	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGA RGOAN_110,AURAD_110	15:57	17:17	01:20	LINE CLEAR AVAILED
4262	21-Dec-24	GULBARGA	110	TRANSFORMER	HV1	HANUMASAGAR_110	17:35	18:10	00:35	LINE CLEAR AVAILED
4263	21-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	08:45	09:05	00:20	LINE CLEAR AVAILED
4264	21-Dec-24	GULBARGA	66	TRANSFORMER	HV2	CHORNUR_66	08:30	08:50	00:20	TRIPPED ON FAULT
4265	21-Dec-24	GULBARGA	220	TRANSFORMER	HV2	KUSTAGI_220	14:34	16:54	02:20	LINE CLEAR AVAILED
4266	21-Dec-24	GULBARGA	220	TRANSFORMER	HV2	LINGASUGUR_220	09:45	12:12	02:27	LINE CLEAR AVAILED
4267	21-Dec-24	GULBARGA	110	TRANSFORMER	HV3	HANUMASAGAR_110	10:10	18:05	07:55	LINE CLEAR AVAILED
4268	21-Dec-24	GULBARGA	66	LINE	ITTAGI-RENEW LINE 1&2	ITTAGI_220	18:19	18:42	00:23	TRIPPED ON FAULT
4269	21-Dec-24	GULBARGA	220	LINE	KUSTAGI-OPDWIND_IPP	KUSTAGI_220	10:51	14:30	03:39	LINE CLEAR AVAILED
4270	21-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHATTI_66	10:29	18:18	07:49	LINE CLEAR AVAILED
4271	21-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
4272	21-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHAN GIDURGA_66,BILCHOD_6 6,ARASIKERE_66	20:24	20:31	00:07	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4273	21-Dec-24	GULBARGA	110	LINE	RAICHUR-GABBUR	GABBUR_110,GUGAL_110	09:15	13:55	04:40	LINE CLEAR AVAILED
4274	21-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-KONKAL	KONKAL_110	22:58	23:10	00:12	TRIPPED ON FAULT
4275	21-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDDAPUR	MUDDAPUR_110	01:18	01:23	00:05	TRIPPED ON FAULT
4276	21-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDGAL	MUDGAL_110, BAYYAPUR_110	09:57	16:55	06:58	LINE CLEAR AVAILED
4277	21-Dec-24	GULBARGA	110	LINE	SINDHANOOR-WALKAMDINI	WALKAMDINI_110	09:15	14:35	05:20	LINE CLEAR AVAILED
4278	21-Dec-24	HASAN	110	LINE	AJAMPU-SHIVNI	AJJAMPURA_110	06:24	06:50	00:26	TRIPPED ON FAULT
4279	21-Dec-24	HASAN	66	LINE	CRPATNA-KIKKERI	CRPATNA_220	13:43	14:05	00:22	LINE CLEAR AVAILED
4280	21-Dec-24	HASAN	110	LINE	GURUVA-KEMAR2	GURUVAYANAKERE_110	14:10	14:17	00:07	LINE CLEAR AVAILED
4281	21-Dec-24	HASAN	110	LINE	GURUVA-SLVPWR	GURUVAYANAKERE_110	14:10	14:17	00:07	LINE CLEAR AVAILED
4282	21-Dec-24	HASAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	07:15	07:25	00:10	LINE CLEAR AVAILED
4283	21-Dec-24	HASAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	18:45	18:50	00:05	LINE CLEAR AVAILED
4284	21-Dec-24	HASAN	66	LINE	HNPR2-HASS2	HOLENARASIPURA_220	20:15	20:25	00:10	TRIPPED ON FAULT
4285	21-Dec-24	HASAN	66	LINE	HNPR2-RNPR1	HOLENARASIPURA_220	11:15	16:10	04:55	LINE CLEAR AVAILED
4286	21-Dec-24	HASAN	110	TRANSFORMER	HV1	BANAVARA_110	13:10	14:35	01:25	LINE CLEAR AVAILED
4287	21-Dec-24	HASAN	110	TRANSFORMER	HV1	BANAVARA_110	15:15	17:25	02:10	LINE CLEAR AVAILED
4288	21-Dec-24	HASAN	66	TRANSFORMER	HV1	HASSAN_66	10:03	15:59	05:56	LINE CLEAR AVAILED
4289	21-Dec-24	HASAN	220	TRANSFORMER	HV1	HOLENARASIPURA_220	08:20	14:35	06:15	LINE CLEAR AVAILED
4290	21-Dec-24	HASAN	66	TRANSFORMER	HV1	KANDLI_66	11:11	11:23	00:12	LINE CLEAR AVAILED
4291	21-Dec-24	HASAN	66	TRANSFORMER	HV1	KANDLI_66	13:54	14:20	00:26	LINE CLEAR AVAILED
4292	21-Dec-24	HASAN	66	TRANSFORMER	HV1	MOSALEHOSAHALLI_66	10:25	14:45	04:20	LINE CLEAR AVAILED
4293	21-Dec-24	HASAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	10:05	17:35	07:30	LINE CLEAR AVAILED
4294	21-Dec-24	HASAN	66	TRANSFORMER	HV1	SALGAME_66	17:30	17:38	00:08	LINE CLEAR AVAILED
4295	21-Dec-24	HASAN	110	TRANSFORMER	HV1	SHIVAPURA_110	10:09	17:58	07:49	LINE CLEAR AVAILED
4296	21-Dec-24	HASAN	66	TRANSFORMER	HV1	UDAYAPURA_66	12:20	13:46	01:26	LINE CLEAR AVAILED
4297	21-Dec-24	HASAN	110	TRANSFORMER	HV2	BANAVARA_110	11:20	11:25	00:05	LINE CLEAR AVAILED
4298	21-Dec-24	HASAN	66	TRANSFORMER	HV2	HASSAN_66	11:26	15:59	04:33	LINE CLEAR AVAILED
4299	21-Dec-24	HASAN	220	TRANSFORMER	HV2	HOLENARASIPURA_220	14:40	18:26	03:46	LINE CLEAR AVAILED
4300	21-Dec-24	HASAN	66	TRANSFORMER	HV2	MOSALEHOSAHALLI_66	10:25	14:45	04:20	LINE CLEAR AVAILED
4301	21-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	10:05	17:35	07:30	LINE CLEAR AVAILED
4302	21-Dec-24	HASAN	66	TRANSFORMER	HV2	SALGAME_66	17:30	17:38	00:08	LINE CLEAR AVAILED
4303	21-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
4304	21-Dec-24	HASAN	110	TRANSFORMER	HV3	SHIRALKOPPA_110	10:14	18:20	08:06	LINE CLEAR AVAILED
4305	21-Dec-24	HASAN	110	LINE	KADUR-NERELEKERE	KADUR_220	10:34	13:21	02:47	LINE CLEAR AVAILED
4306	21-Dec-24	HASAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	14:10	14:17	00:07	LINE CLEAR AVAILED
4307	21-Dec-24	HASAN	66	TRANSFORMER	Lv1	HOLENARASIPURA_220	08:20	14:35	06:15	LINE CLEAR AVAILED
4308	21-Dec-24	HASAN	66	TRANSFORMER	Lv2	HOLENARASIPURA_220	14:40	18:26	03:46	LINE CLEAR AVAILED
4309	21-Dec-24	HASAN	66	LINE	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	10:25	14:45	04:20	LINE CLEAR AVAILED
4310	21-Dec-24	HASAN	110	LINE	MSEZ-KAVOOR	MSEZ_220	10:39	14:11	03:32	LINE CLEAR AVAILED
4311	21-Dec-24	HASAN	66	LINE	RAMNAT-BELVADI	RAMNATHPURA_66	10:50	14:41	03:51	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4312	21-Dec-24	HASAN	66	LINE	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	10:50	16:47	05:57	LINE CLEAR AVAILED
4313	21-Dec-24	HASAN	66	LINE	SALAGAM-HIREMANGLUR	SALGAME_66	17:30	17:38	00:08	LINE CLEAR AVAILED
4314	21-Dec-24	HASAN	66	LINE	SALAGAM-UDURKOPPLU	SALGAME_66	17:30	17:38	00:08	LINE CLEAR AVAILED
4315	21-Dec-24	HASAN	110	LINE	SHIVAPU-NERLEKERE	SHIVAPURA_110	10:13	17:56	07:43	LINE CLEAR AVAILED
4316	21-Dec-24	HASAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:35	18:17	07:42	LINE CLEAR AVAILED
4317	21-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
4318	21-Dec-24	MYSORE	66	LINE	CR NAGARA-SOMVARPETE	ARKALVADI_66 ATTIGULIPURA_66 HONNALLY_MYS_66 SOMVARAPETE(GALIPURA) 66	09:33	16:21	06:47	LINE CLEAR AVAILED
4319	21-Dec-24	MYSORE	66	LINE	D.R PETE-SANTHEMARAHALLI	SANTHEMARAHALLI_66	11:33	13:18	01:44	LINE CLEAR AVAILED
4320	21-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
4321	21-Dec-24	MYSORE	66	LINE	HONNALLY-ARAKALVADI	ARKALVADI_66	09:30	16:25	06:55	LINE CLEAR AVAILED
4322	21-Dec-24	MYSORE	66	LINE	HONNALLY-ATTIGULIPURA	ATTIGULIPURA_66	09:30	16:43	07:13	LINE CLEAR AVAILED
4323	21-Dec-24	MYSORE	66	LINE	HUNASURU(220)-GAVADGERE	GAVADAGERE_66	12:50	17:56	05:06	LINE CLEAR AVAILED
4324	21-Dec-24	MYSORE	66	LINE	HUNASURU(220)-HANAGODU	HANAGODU_66	10:10	16:35	06:25	LINE CLEAR AVAILED
4325	21-Dec-24	MYSORE	66	LINE	HUNASURU(220)-KAMPLAPURA	NO STATIONS EFFECTED	11:12	12:55	01:43	LINE CLEAR AVAILED
4326	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	GARUDANAUKADDA_66	10:35	17:51	07:16	LINE CLEAR AVAILED
4327	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	GAVADAGERE_66	10:00	18:00	08:00	LINE CLEAR AVAILED
4328	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	GUDDENAHALLI_66	13:09	14:49	01:40	LINE CLEAR AVAILED
4329	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	HANAGODU_66	10:00	18:41	08:41	LINE CLEAR AVAILED
4330	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	12:30	15:00	02:30	LINE CLEAR AVAILED
4331	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	SANTHEMARAHALLI_66	09:59	17:00	07:00	LINE CLEAR AVAILED
4332	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4333	21-Dec-24	MYSORE	66	TRANSFORMER	HV1	VYASRAJPURA_66	11:18	13:28	02:10	LINE CLEAR AVAILED
4334	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	COWDALLI_66	16:19	16:31	00:12	TRIPPED ON FAULT
4335	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	GAVADAGERE_66	10:00	18:00	08:00	LINE CLEAR AVAILED
4336	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	HANAGODU_66	10:00	16:41	06:41	LINE CLEAR AVAILED
4337	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	12:32	16:04	03:31	LINE CLEAR AVAILED
4338	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEBACHALLI_66	09:54	18:18	08:23	LINE CLEAR AVAILED
4339	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEMARAHALLI_66	09:59	17:00	07:00	LINE CLEAR AVAILED
4340	21-Dec-24	MYSORE	66	TRANSFORMER	HV2	VYASRAJPURA_66	13:29	15:27	01:58	LINE CLEAR AVAILED
4341	21-Dec-24	MYSORE	66	TRANSFORMER	HV3	SFCSHIVA_66	09:41	10:39	00:58	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4342	21-Dec-24	MYSORE	66	LINE	KADAKOLA-JAIPURA	NO STATIONS EFFECTED	18:43	18:54	00:11	TRIPPED ON FAULT
4343	21-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4344	21-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4345	21-Dec-24	MYSORE	66	LINE	KR NAGARA-BHERYA	BHERYA_66	04:55	05:04	00:09	TRIPPED ON FAULT
4346	21-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
4347	21-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
4348	21-Dec-24	MYSORE	66	LINE	KUNTHUR-SANTHEMARAHALLI	SANTHEMARAHALLI_66	11:30	13:23	01:53	LINE CLEAR AVAILED
4349	21-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR-1	NO STATIONS EFFECTED	00:32	00:39	00:07	TRIPPED ON FAULT
4350	21-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR-1	NO STATIONS EFFECTED	02:08	02:17	00:09	TRIPPED ON FAULT
4351	21-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR-1	NO STATIONS EFFECTED	03:31	15:00	11:29	TRIPPED ON FAULT
4352	21-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR-2	NO STATIONS EFFECTED	13:50	15:00	01:09	LINE CLEAR AVAILED
4353	21-Dec-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	VIRAJPET_66	10:04	17:14	07:10	LINE CLEAR AVAILED
4354	21-Dec-24	MYSORE	66	LINE	SANTHEMARAHALLI-D.R.PETE	SANTHEMARAHALLI_66	10:01	17:00	06:59	LINE CLEAR AVAILED
4355	21-Dec-24	MYSORE	66	LINE	THALAKADU-CHANDALLI	NO STATIONS EFFECTED	04:44	04:49	00:05	TRIPPED ON FAULT
4356	21-Dec-24	MYSORE	66	LINE	VAJAMANGALA-DEVNUR (MYS)	DEVANOORMYS_66 RAJEEVNAGARA_66	12:44	12:48	00:04	TRIPPED ON FAULT
4357	21-Dec-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDRAHALLI LINE2	6KV PANDRAHALLI LINE2	14:50	14:58	0:08	TRIPPED ON FAULT
4358	21-Dec-24	TUMKUR	66	LINE	220Kv CHITRADURGA-TURUVANUR LINE	66KV BIDARIKERE & JAGALUR	5:54	6:09	0:15	TRIPPED ON FAULT
4359	21-Dec-24	TUMKUR	66	LINE	66KV GARAGA - PANCHANAHALLI	66KV GARGA AND PANCHANAHALLI	0:25	0:35	0:10	TRIPPED ON FAULT
4360	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	0:25	0:35	0:10	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4361	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	9:25	10:10	0:45	LINE CLEAR AVAILED
4362	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	10:20	10:30	0:10	TRIPPED ON FAULT
4363	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	11:55	12:20	0:25	LINE CLEAR AVAILED
4364	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	14:50	14:55	0:05	LINE CLEAR AVAILED
4365	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	18:05	18:40	0:35	MAIN SUPPLY FAILURE
4366	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	18:50	19:20	0:30	TRIPPED ON FAULT
4367	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	20:00	20:10	0:10	TRIPPED ON FAULT
4368	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	20:45	21:00	0:15	TRIPPED ON FAULT
4369	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	22:15	22:30	0:15	TRIPPED ON FAULT
4370	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	23:20	23:30	0:10	TRIPPED ON FAULT
4371	21-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	23:45	NOT YET CHARGED		TRIPPED ON FAULT
4372	21-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-URDIGERE	URDIGERE_66	10:05	18:35	8:30	LINE CLEAR AVAILED
4373	21-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220_KORATGERE_66	66KV BELADHARA, SANKENAHALLI	10:33	10:43	0:10	TRIPPED ON FAULT
4374	21-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-KORATGERE_66	66KV BELADHARA, SANKENAHALLI	7:55	14:35	6:40	LINE CLEAR AVAILED
4375	21-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-KORATGERE_66	66KV BELADHARA, SANKENAHALLI	7:55	14:35	6:40	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4376	21-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	66KV KUKKAWADA , SHYAGLE, THYAVANAGI, BASAVAPATNA, KEREDELACHI	13:12	13:24	0:12	TRIPPED ON FAULT
4377	21-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-KORATAGERE_66 LINE1	66KV KORATAGERE, HOLAVANAHALLI, THUMBADI	6:09	6:17	0:08	TRIPPED ON FAULT
4378	21-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-MIDIGESHI_66 LINE2	66KV MIDHESHI	7:11	7:23	0:12	TRIPPED ON FAULT
4379	21-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	GARAGA_66	10:35	17:00	6:25	LINE CLEAR AVAILED
4380	21-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	KOLALA_66	10:00	18:35	8:35	LINE CLEAR AVAILED
4381	21-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	MYLANAHALLI_66	17:00	17:20	0:20	LINE CLEAR AVAILED
4382	21-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	NAGALAMADIKE_66	11:50	13:00	1:10	LINE CLEAR AVAILED
4383	21-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	GARAGA_66	10:45	17:00	6:15	LINE CLEAR AVAILED
4384	21-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	KOLALA_66	10:00	18:35	8:35	LINE CLEAR AVAILED
4385	21-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	CHITRAHALLI_66	13:05	13:10	0:05	TRIPPED ON FAULT
4386	21-Dec-24	TUMKUR	66	LINE	URDIGERE_66-O/G KOLALA_66	URDIGERE_66	10:20	16:10	5:50	LINE CLEAR AVAILED
4387	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	09:17	09:23	00:06	TRIPPED ON FAULT
4388	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	12:14	12:47	00:33	TRIPPED ON FAULT
4389	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	12:58	13:08	00:10	TRIPPED ON FAULT
4390	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	13:56	14:12	00:16	TRIPPED ON FAULT
4391	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	15:28	15:31	00:03	TRIPPED ON FAULT
4392	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	CHANDAKAVATE_110	18:11	18:15	00:04	TRIPPED ON FAULT
4393	22-Dec-24	BAGALKOTE	220	TRANSFORMER	110/11KV,HV1(10MVA)	BIDNAL_220	10:45	15:10	04:25	LINE CLEAR AVAILED
4394	22-Dec-24	BAGALKOTE	220	TRANSFORMER	110/11KV,HV1(10MVA)	BIDNAL_220	18:43	19:04	00:21	LINE CLEAR AVAILED
4395	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
4396	22-Dec-24	BAGALKOTE	220	TRANSFORMER	110/11KV,HV2(10MVA)	BIDNAL_220	10:01	16:04	06:03	LINE CLEAR AVAILED
4397	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	LAKAMANAHALLI	13:42	17:52	04:10	TRIPPED ON FAULT
4398	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TARIHAL_111	10:10	14:17	04:07	TRIPPED ON FAULT
4399	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV. HV2 (10MVA)	DAVALESHWAR_110	10:33	15:06	04:33	LINE CLEAR AVAILED
4400	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	HANAGAL_110	12:37	13:03	00:26	TRIPPED ON FAULT
4401	22-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	TARIHAL_111	10:58	14:21	03:23	TRIPPED ON FAULT
4402	22-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4403	22-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	MAHALINGAPUR_220	07:44	07:58	00:14	TRIPPED ON FAULT
4404	22-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	MAHALINGAPUR_220	07:12	07:39	00:27	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4405	22-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3(Mahalingpur 220/110)	MAHALINGAPUR_220,110 DAVALESHWAR,110KV ITNAL,110KV JSML 1&2,110KV HIDIKAL,110KV RABAKAVI	16:30	16:55	00:25	LINE CLEAR AVAILED
4406	22-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4407	22-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1 (LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
4408	22-Dec-24	BAGALKOTE	110	LINE	AMEWADI220-SUPA-1	AMBEWADI_220	15:04	16:52	01:48	LINE CLEAR AVAILED
4409	22-Dec-24	BAGALKOTE	110	LINE	AMEWADI220-SUPA-2	AMBEWADI_220	9:58	17:01	07:03	TRIPPED ON FAULT
4410	22-Dec-24	BAGALKOTE	220	LINE	AMEWADI-NARENDRA2	AMBEWADI_220	12:25	12:48	00:23	TRIPPED ON FAULT
4411	22-Dec-24	BAGALKOTE	110	LINE	ARGA-ANKOLA	ARGA_110	06:22	06:37	00:15	TRIPPED ON FAULT
4412	22-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 1	BELAGAVI_220	09:46	19:05	09:19	LINE CLEAR AVAILED
4413	22-Dec-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS 2	BELGAUM_220	09:47	19:05	09:18	LINE CLEAR AVAILED
4414	22-Dec-24	BAGALKOTE	110	LINE	DADDI-F2(HONAGA)	DADDI_110	05:38	05:46	00:08	TRIPPED ON FAULT
4415	22-Dec-24	BAGALKOTE	110	LINE	GHATAPRABHA220-SHIRAGOAN	GHATAPRABHA_220	09:07	09:34	00:27	TRIPPED ON FAULT
4416	22-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
4417	22-Dec-24	BAGALKOTE	110	LINE	HANAGAL-HAVERI	HANAGAL_110	12:38	12:39	00:01	LINE CLEAR AVAILED
4418	22-Dec-24	BAGALKOTE	110	LINE	HIDIKALDAM-ANKALAGI	HIDIKALDAM_110	08:30	08:38	00:08	LINE CLEAR AVAILED
4419	22-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4420	22-Dec-24	BAGALKOTE	110	LINE	HUBLI220-KADANKOPPA	HUBLI_220	9:07	9:52	00:45	TRIPPED ON FAULT
4421	22-Dec-24	BAGALKOTE	110	LINE	HUBLI220-RAMANKOPPA	HUBLI_220	09:07	09:49	00:42	TRIPPED ON FAULT
4422	22-Dec-24	BAGALKOTE	110	LINE	HUDLI-ANKALAGI	HUDLI_110	08:38	18:06	09:28	LINE CLEAR AVAILED
4423	22-Dec-24	BAGALKOTE	110	LINE	HUKKERI-KOTAWAGI	HUKKERI_110	07:30	09:28	01:58	TRIPPED ON FAULT
4424	22-Dec-24	BAGALKOTE	110	LINE	HUKKERI-VS (BELLADBAGEWADI)	HUKKERI_110	03:04	03:23	00:19	TRIPPED ON FAULT
4425	22-Dec-24	BAGALKOTE	110	LINE	HUKKERI-VS (BELLADBAGEWADI)	HUKKERI_110	03:23	03:53	00:30	TRIPPED ON FAULT
4426	22-Dec-24	BAGALKOTE	110	LINE	HUKKERI-VS (BELLADBAGEWADI)	HUKKERI_110	03:53	09:21	05:28	TRIPPED ON FAULT
4427	22-Dec-24	BAGALKOTE	110	LINE	ITNAL-RAIBK2(KABBUR)	ITNAL_110	02:20	09:57	07:37	TRIPPED ON FAULT
4428	22-Dec-24	BAGALKOTE	110	LINE	KADANAKOPPA-HUBLI	KADANAKOPPA_110	09:20	11:26	02:06	LINE CLEAR AVAILED
4429	22-Dec-24	BAGALKOTE	110	LINE	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	09:20	09:25	00:05	LINE CLEAR AVAILED
4430	22-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
4431	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-DAVALESHWAR	MAHALINGAPUR_220	07:12	07:40	00:28	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4432	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-DAVALESHWAR	MAHALINGAPUR_220	07:45	08:07	00:22	LINE CLEAR AVAILED
4433	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	11:45	13:22	01:37	LINE CLEAR AVAILED
4434	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	07:45	08:13	00:28	LINE CLEAR AVAILED
4435	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	07:12	07:40	00:28	LINE CLEAR AVAILED
4436	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-ITNAL	MAHALINGAPUR_220	07:12	07:42	00:30	LINE CLEAR AVAILED
4437	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-ITNAL	MAHALINGAPUR_220	07:45	08:07	00:22	LINE CLEAR AVAILED
4438	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-JAMAKHANDI	MAHALINGAPUR_220	10:00	17:30	07:30	LINE CLEAR AVAILED
4439	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-JAMAKHANDI	MAHALINGAPUR_220	05:32	05:45	00:13	TRIPPED ON FAULT
4440	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-JSML 2	MAHALINGAPUR_220	07:22	07:42	00:20	LINE CLEAR AVAILED
4441	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-JSML 2	MAHALINGAPUR_220	07:45	08:03	00:18	LINE CLEAR AVAILED
4442	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-RABAKAVI	MAHALINGAPUR_220	07:45	08:07	00:22	LINE CLEAR AVAILED
4443	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-RABAKAVI	MAHALINGAPUR_220	07:12	07:42	00:30	LINE CLEAR AVAILED
4444	22-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-RANNABELAGALI	MAHALINGAPUR_220	08:14	15:09	06:55	LINE CLEAR AVAILED
4445	22-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4446	22-Dec-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN2((RAIBAG)	MUGALAKHOD_220	07:27	10:06	02:39	TRIPPED ON FAULT
4447	22-Dec-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN2(ITNAL-1)	MUGALAKHOD_220	07:50	09:56	02:06	TRIPPED ON FAULT
4448	22-Dec-24	BAGALKOTE	220	LINE	NARENDRA-AMBEWADI2	NARENDRA_220	12:25	13:02	00:37	TRIPPED ON FAULT
4449	22-Dec-24	BAGALKOTE	220	LINE	NARENDRA-BELGAUM2	NARENDRA_220	18:19 (21.12.2024)			LINE CLEAR AVAILED
4450	22-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
4451	22-Dec-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON1	SOUDATTI_110	10:03	19:05	09:02	LINE CLEAR AVAILED
4452	22-Dec-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON2	SOUDATTI_110	10:03	19:05	09:02	LINE CLEAR AVAILED
4453	22-Dec-24	BAGALKOTE	110	LINE	SOUDAT-MUNAVALY (SOUDATTI 1)	SOUDATTI_110	10:04	16:45	06:41	LINE CLEAR AVAILED
4454	22-Dec-24	BAGALKOTE	110	LINE	SOUDAT-NARGUND (SOUDATTI 2)	SOUDATTI_110	10:04	17:38	07:34	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4455	22-Dec-24	BAGALKOTE	110	LINE	TARIHAL-IDLE(KIADB)	TARIHAL_110	10:46 (22.12.2024)			LINE CLEAR AVAILED
4456	22-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
4457	22-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
4458	22-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4459	22-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4460	22-Dec-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - JIGANI 220	JIGANI 220	10:05	17:54	07:49	LINE CLEAR AVAILED
4461	22-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - MAGADI CKT 2	MAGADI 220, ANCHEPALYA 220	10:53	18:12	07:19	LINE CLEAR AVAILED
4462	22-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
4463	22-Dec-24	BANGALORE	220	LINE	220KV YARANDANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	23:58:00	15:30	15:32	TRIPPED ON FAULT
4464	22-Dec-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	JIGANI LINK ROAD	20:13	20:18	00:05	LINE CLEAR AVAILED
4465	22-Dec-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	13:20	17:08	03:48	LINE CLEAR AVAILED
4466	22-Dec-24	BANGALORE	66	LINE	66KV BYADARAHALLI - KODIGEHALLI	KODIGEHALLI	10:10	12:20	02:10	LINE CLEAR AVAILED
4467	22-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:05	10:10	00:05	LINE CLEAR AVAILED
4468	22-Dec-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	08:00	09:17	01:17	TRIPPED ON FAULT
4469	22-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, PERESANDRA, GUDIBANDE, MANDIKAL	03:01	03:11	00:10	TRIPPED ON FAULT
4470	22-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	06:45	06:55	00:10	TRIPPED ON FAULT
4471	22-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4472	22-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI(HV1,HV3)	07:59	08:06	00:07	TRIPPED ON FAULT
4473	22-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	07:59	08:26	00:27	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4474	22-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	07:59	08:26	00:27	MAIN SUPPLY FAILURE
4475	22-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	07:59	08:05	00:06	MAIN SUPPLY FAILURE
4476	22-Dec-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	18:06	18:14	00:08	LINE CLEAR AVAILED
4477	22-Dec-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	10:00	15:21	05:21	LINE CLEAR AVAILED
4478	22-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220 _DG4	GRINDWELL NORTON(EHT)	00:37	01:15	00:38	TRIPPED ON FAULT
4479	22-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220 _DG4	GRINDWELL NORTON(EHT)	14:25	14:56	00:31	TRIPPED ON FAULT
4480	22-Dec-24	BANGALORE	66	LINE	66KV KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY PUMP HOUSE	17:15	17:35	00:20	TRIPPED ON FAULT
4481	22-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	10:49	20:03	09:14	LINE CLEAR AVAILED
4482	22-Dec-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN-2	NO STATION AFFECTED	10:49	20:03	09:14	LINE CLEAR AVAILED
4483	22-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	16:36	16:46	00:10	TRIPPED ON FAULT
4484	22-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	17:21	17:27	00:06	LINE CLEAR AVAILED
4485	22-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	17:15	17:21	00:06	TRIPPED ON FAULT
4486	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	AGALAKOTE	10:10	10:15	00:05	LINE CLEAR AVAILED
4487	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	AGALAKOTE	18:35	18:40	00:05	LINE CLEAR AVAILED
4488	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - AGALAKOTE - MATHIKERE	MATHIKERE	10:10	18:22	08:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4489	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - MAGADI 66 -HOSPALYA - ANCHEPALYA	HOSPALYA CIRCLE, MAGADI 66	10:10	18:22	08:12	LINE CLEAR AVAILED
4490	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	10:10	18:22	08:12	LINE CLEAR AVAILED
4491	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	TG HALLI	10:10	15:05	04:55	LINE CLEAR AVAILED
4492	22-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	VG DODDI	10:10	18:22	08:12	LINE CLEAR AVAILED
4493	22-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - LAKKUR	LAKKUR, DEVANAGUNDHI	13:11	13:26	00:15	TRIPPED ON FAULT
4494	22-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISC	22:02	22:07	00:05	LINE CLEAR AVAILED
4495	22-Dec-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	NO STATION AFFECTED	23:00	23:20	00:20	TRIPPED ON FAULT
4496	22-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - GOKULA	GOKULA, MATHIKERE, RMV, IISC(EHT), BEL(EHT)	07:59	08:21	00:22	MAIN SUPPLY FAILURE
4497	22-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - SAHAKARNAGAR 66	SAHAKARNAGAR 66	07:59	08:15	00:16	MAIN SUPPLY FAILURE
4498	22-Dec-24	BANGALORE	66	LINE	66KV SAHAKARNAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	07:59	08:17	00:18	MAIN SUPPLY FAILURE
4499	22-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE(HV2 & HV3)	10:21	15:33	05:12	LINE CLEAR AVAILED
4500	22-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	NO STATION AFFECTED	10:21	15:17	04:56	LINE CLEAR AVAILED
4501	22-Dec-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYACITY, ANEKAL, SAMANDURU	18:06	18:14	00:08	LINE CLEAR AVAILED
4502	22-Dec-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYACITY, ANEKAL, SAMANDURU	10:01	15:18	05:17	LINE CLEAR AVAILED
4503	22-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA,BEML	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4504	22-Dec-24	BANGALORE	66	LINE	66KV TAVAREKERE - KODIGEHALI	TAVAREKERE	18:47	18:50	00:03	LINE CLEAR AVAILED
4505	22-Dec-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	10:10	12:30	02:20	LINE CLEAR AVAILED
4506	22-Dec-24	BANGALORE	66	LINE	66KV VEMGAL - KYALANUR	KYALANUR, TALAGAVARA, CHEEMANGALA	17:15	17:31	00:16	TRIPPED ON FAULT
4507	22-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	18:06	18:14	00:08	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4508	22-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A- BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA I/A	10:25	16:42	06:17	LINE CLEAR AVAILED
4509	22-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	10:22	15:32	05:10	LINE CLEAR AVAILED
4510	22-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	09:14	10:18	01:04	LINE CLEAR AVAILED
4511	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ATTIBELE	10:08	15:35	05:27	LINE CLEAR AVAILED
4512	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BRINDAVANA 220	08:04	08:08	00:04	LINE CLEAR AVAILED
4513	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	HAL 220	14:40	14:45	00:05	LINE CLEAR AVAILED
4514	22-Dec-24	BANGALORE	220	TRANSFORMER	HV1	JIGANI 220	10:01	17:57	07:56	LINE CLEAR AVAILED
4515	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	10:00	18:00	08:00	LINE CLEAR AVAILED
4516	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI LINK ROAD	10:01	17:08	07:07	LINE CLEAR AVAILED
4517	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KODIGEHALLI	10:00	15:24	05:24	LINE CLEAR AVAILED
4518	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	LAKKUR	13:10	14:10	01:00	LINE CLEAR AVAILED
4519	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	10:10	18:30	08:20	LINE CLEAR AVAILED
4520	22-Dec-24	BANGALORE	220	TRANSFORMER	HV1	MAGADI 220	10:10	18:13	08:03	LINE CLEAR AVAILED
4521	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SAHAKARNAGAR 220	07:59	08:21	00:22	MAIN SUPPLY FAILURE
4522	22-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SAHAKARNAGAR 220	07:59	08:13	00:14	TRIPPED ON FAULT
4523	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SANJEEVANADODDI	11:00	11:05	00:05	LINE CLEAR AVAILED
4524	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SURYACITY	10:00	17:15	07:15	LINE CLEAR AVAILED
4525	22-Dec-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	17:32	18:10	00:38	LINE CLEAR AVAILED
4526	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BRINDAVANA 220	12:21	12:22	00:01	LINE CLEAR AVAILED
4527	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	12:33	12:40	00:07	TRIPPED ON FAULT
4528	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	17:00	17:30	00:30	TRIPPED ON FAULT
4529	22-Dec-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	10:01	18:00	07:59	LINE CLEAR AVAILED
4530	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	10:00	18:00	08:00	LINE CLEAR AVAILED
4531	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI LINK ROAD	10:01	17:08	07:07	LINE CLEAR AVAILED
4532	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KODIGEHALLI	10:00	15:24	05:24	LINE CLEAR AVAILED
4533	22-Dec-24	BANGALORE	220	TRANSFORMER	HV2	MAGADI 220	10:10	18:13	08:03	LINE CLEAR AVAILED
4534	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	RMV	10:41	10:45	00:04	LINE CLEAR AVAILED
4535	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SAHAKARNAGAR 220	07:59	08:30	00:31	MAIN SUPPLY FAILURE
4536	22-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SAHAKARNAGAR 220	07:59	08:13	00:14	TRIPPED ON FAULT
4537	22-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SANJEEVANADODDI	11:30	11:35	00:05	LINE CLEAR AVAILED
4538	22-Dec-24	BANGALORE	66	TRANSFORMER	HV3	BRINDAVANA 220	14:50	14:52	00:02	LINE CLEAR AVAILED
4539	22-Dec-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	10:00	18:00	08:00	LINE CLEAR AVAILED
4540	22-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	10:09	18:10	08:01	LINE CLEAR AVAILED
4541	22-Dec-24	GULBARGA	110	LINE	BELLARY NORTH-MOKA	MOKA_110,PD_HALLI_110, BISIHALLI_110	11:40	16:52	05:12	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4542	22-Dec-24	GULBARGA	220	LINE	HALWARTHY-DONI LINE1&2	HALWARHTY_110	10:29	17:47	07:18	LOAD CURTAILMENT
4543	22-Dec-24	GULBARGA	110	TRANSFORMER	HV1	GUGAL_110	05:00	05:15	00:15	TRIPPED ON FAULT
4544	22-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	17:50	18:10	00:20	LINE CLEAR AVAILED
4545	22-Dec-24	GULBARGA	66	TRANSFORMER	HV1	PUNABHAGATTA_66	21:55	22:00	00:05	TRIPPED ON FAULT
4546	22-Dec-24	GULBARGA	66	TRANSFORMER	HV2	HOSAHALLI_66	17:25	17:35	00:10	TRIPPED ON FAULT
4547	22-Dec-24	GULBARGA	110	LINE	KUSTAGI-VAJRABADNI	VAJRABANDI_110,YELBUR GA_110,KUKUNOOR_110	10:25	14:52	04:27	LINE CLEAR AVAILED
4548	22-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHTTI_66	10:29	18:18	07:49	LINE CLEAR AVAILED
4549	22-Dec-24	GULBARGA	66	LINE	NEELAGUNA-TELAGI	TELAGI_66,KURUBARAHALLI_66,SHAMANUR SUGAR_IPP,VESTAS_IPP	07:10	07:25	00:15	TRIPPED ON FAULT
4550	22-Dec-24	GULBARGA	110	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66	09:06	09:19	00:13	TRIPPED ON FAULT
4551	22-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
4552	22-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,ARASIKERE_66	10:07	10:16	00:09	TRIPPED ON FAULT
4553	22-Dec-24	GULBARGA	110	LINE	PD_HALLI-BASAI STEELS_IPP	M/s BASAI STEELS EHT CONSUMER	08:00	20:45	12:45	LINE CLEAR AVAILED
4554	22-Dec-24	GULBARGA	110	LINE	PD_HALLI-SOMASAMUDRA	PD_HALLI_110	08:00	16:42	08:42	LINE CLEAR AVAILED
4555	22-Dec-24	GULBARGA	220	LINE	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	18:16	18:26	00:10	TRIPPED ON FAULT
4556	22-Dec-24	GULBARGA	220	LINE	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	18:35	18:45	00:10	TRIPPED ON FAULT
4557	22-Dec-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	09:10	09:20	00:10	TRIPPED ON FAULT
4558	22-Dec-24	HASAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	06:20	16:40	10:20	TRIPPED ON FAULT
4559	22-Dec-24	HASAN	110	LINE	GAJNUR-IPP IC LINE	GAJANUR_110	10:03	14:55	04:52	LINE CLEAR AVAILED
4560	22-Dec-24	HASAN	66	LINE	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	10:34	18:07	07:33	LINE CLEAR AVAILED
4561	22-Dec-24	HASAN	66	LINE	HIREMAN-CKM220	HIREMAGALUR_66	10:34	18:07	07:33	LINE CLEAR AVAILED
4562	22-Dec-24	HASAN	66	LINE	HIREMAN-RDL	HIREMAGALUR_66	10:34	18:07	07:33	LINE CLEAR AVAILED
4563	22-Dec-24	HASAN	66	LINE	HNPR2-HASS1	HOLENARASIPURA_220	18:26	20:00	01:34	TRIPPED ON FAULT
4564	22-Dec-24	HASAN	66	TRANSFORMER	HV1	CHIKMAGALUR_66	10:05	21:58	11:53	LINE CLEAR AVAILED
4565	22-Dec-24	HASAN	110	TRANSFORMER	HV1	GAJANUR_110	10:03	14:55	04:52	LINE CLEAR AVAILED
4566	22-Dec-24	HASAN	66	TRANSFORMER	HV1	HIREMAGALUR_66	10:34	18:07	07:33	LINE CLEAR AVAILED
4567	22-Dec-24	HASAN	66	TRANSFORMER	HV1	KIADBHASSAN_66	10:08	14:11	04:03	LINE CLEAR AVAILED
4568	22-Dec-24	HASAN	110	TRANSFORMER	HV1	MOODABIDRE_110	12:00	12:37	00:37	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4569	22-Dec-24	HASAN	66	TRANSFORMER	HV2	CHIKMAGALUR_66	11:16	18:00	06:44	LINE CLEAR AVAILED
4570	22-Dec-24	HASAN	66	TRANSFORMER	HV2	KIADBHASSAN_66	10:07	14:11	04:04	LINE CLEAR AVAILED
4571	22-Dec-24	HASAN	110	TRANSFORMER	HV2	PUTTUR_110	09:32	09:40	00:08	TRIPPED ON FAULT
4572	22-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
4573	22-Dec-24	HASAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	08:13	19:02	10:49	LINE CLEAR AVAILED
4574	22-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMG_220	23:17(22.12.2024)			TRIPPED ON FAULT
4575	22-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	08:12	19:02	10:50	LINE CLEAR AVAILED
4576	22-Dec-24	HASAN	110	LINE	NERALA-KADUR	NERALAKERE_110	10:34	13:21	02:47	LINE CLEAR AVAILED
4577	22-Dec-24	HASAN	66	LINE	UDAYAP-SATHENAHALLI	UDAYAPURA_66	15:25	15:40	00:15	TRIPPED ON FAULT
4578	22-Dec-24	MYSORE	66	LINE	BEGUR 220KV-BEGUR 1	BEGUR_66	09:40	17:30	07:50	LINE CLEAR AVAILED
4579	22-Dec-24	MYSORE	66	LINE	BEGUR 220KV-BEGUR 2	BEGUR_66	09:40	17:30	07:50	LINE CLEAR AVAILED
4580	22-Dec-24	MYSORE	66	TRANSFORMER	BEGUR 220KV-HV1	NO STATIONS EFFECTED	16:26	17:16	00:50	LINE CLEAR AVAILED
4581	22-Dec-24	MYSORE	66	LINE	BEGUR 220KV-SARGUR	YEREHALLIHANDPOST_66 ANTHARSANTHE_66HDKO TE_66CHANDRAVADI_66S ANTHESARAGUR_66	16:03	16:10	00:07	TRIPPED ON FAULT
4582	22-Dec-24	MYSORE	66	LINE	NAGAMANGALA 220KV-GUDDENAHALLI	GUDDENAHALLI_66BOGA DHI MANDYA_66	22:42	22:51	00:09	TRIPPED ON FAULT
4583	22-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
4584	22-Dec-24	MYSORE	66	LINE	CR NAGARA-HONGANUR	HONGANUR_66	10:03	17:15	07:11	LINE CLEAR AVAILED
4585	22-Dec-24	MYSORE	66	LINE	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	12:05	14:32	02:27	LINE CLEAR AVAILED
4586	22-Dec-24	MYSORE	66	LINE	G UKKADA-TUBINAKERE	NO STATIONS EFFECTED	14:37	16:38	02:00	LINE CLEAR AVAILED
4587	22-Dec-24	MYSORE	66	LINE	HAMPAPURA-YEREHALLI HAND POST-SARGUR	DOORA_66HULLAHALLI_6 6	16:03	16:13	00:10	TRIPPED ON FAULT
4588	22-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
4589	22-Dec-24	MYSORE	66	LINE	HOOTAGALLI-BEML	HEBBAL-INDUSTRIAL_66	10:48	17:46	06:58	LINE CLEAR AVAILED
4590	22-Dec-24	MYSORE	66	LINE	HOOTAGALLI-HEBBAL	HEBBAL_66	10:30	14:45	04:15	LINE CLEAR AVAILED
4591	22-Dec-24	MYSORE	66	TRANSFORMER	HV1	GARUDANAUKADDA_66	15:55	17:05	01:10	LINE CLEAR AVAILED
4592	22-Dec-24	MYSORE	66	TRANSFORMER	HV1	HOOTAGALLI_220	12:11	13:13	01:02	LINE CLEAR AVAILED
4593	22-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4594	22-Dec-24	MYSORE	66	TRANSFORMER	HV2	HOOTAGALLI_220	12:11	13:13	01:01	LINE CLEAR AVAILED
4595	22-Dec-24	MYSORE	66	LINE	KADAKOLA-DOORA	DOORA_66HULLAHALLI_6 6	02:53	02:57	00:04	TRIPPED ON FAULT
4596	22-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4597	22-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4598	22-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
4599	22-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
4600	22-Dec-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	09:20	16:25	07:05	LINE CLEAR AVAILED
4601	22-Dec-24	MYSORE	66	LINE	METAGALLI-HEBBAL	METAGALLY_66	10:06	16:29	06:22	LINE CLEAR AVAILED
4602	22-Dec-24	MYSORE	66	LINE	METAGALLI-VIKRANTH	NO STATIONS EFFECTED	10:06	16:44	06:38	LINE CLEAR AVAILED
4603	22-Dec-24	MYSORE	66	LINE	SANTHESARGUR-B MATTAGERE	B MATKERE_66	10:05	17:30	07:25	LINE CLEAR AVAILED
4604	22-Dec-24	TUMKUR	66	LINE	100MVA TR-3 HIRIYUR_220KV	HIRIYUR_220KV	16:15	18:30	2:15	LINE CLEAR AVAILED
4605	22-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV MALLADIHALLI	66KV MALLADIHALLI	14:20	14:30	0:10	LINE CLEAR AVAILED
4606	22-Dec-24	TUMKUR	110	LINE	220KV NITTUR-110 KV SOMALAPUR	110 KV SOMALAPUR	9:10	9:35	0:25	TRIPPED ON FAULT
4607	22-Dec-24	TUMKUR	220	LINE	400KV GUTTUR - 220KVCHITRADURGA LINE	220KVCHITRADURGA LINE	14:08	16:45	2:37	TRIPPED ON FAULT
4608	22-Dec-24	TUMKUR	66	LINE	66KV MATHOD-HIRIYUR SRS 220-LINE-1 & 2	66KV MATHOD	15:00	16:45	1:45	LINE CLEAR AVAILED
4609	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	23:45:00 (21.12.2024)	00:25:00 (22.12.2024)	0:40	TRIPPED ON FAULT
4610	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	1:30	7:35	6:05	TRIPPED ON FAULT
4611	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	13:15	13:25	0:10	TRIPPED ON FAULT
4612	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	19:25	19:35	0:10	TRIPPED ON FAULT
4613	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE - PALLAGATTE_66 LINE	SOKK_66KV PALLAGATTE,BILICHODU, 66KV	23:45	23:55	0:10	TRIPPED ON FAULT
4614	22-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV SOKKE,PALLAGATTE,BILIC HODU	18:15	18:30	0:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4615	22-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-__CHELUR_66	66KV CHELUR, NANDIHALLI, HOSKERE, HAGALWADI	23:18	23:27	0:09	TRIPPED ON FAULT
4616	22-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-_MELEKOTE-66	66KV MELEKOTE, BADDIHALLI, HONNUDIKE, HIREHALLI	15:27	16:10	0:43	TRIPPED ON FAULT
4617	22-Dec-24	TUMKUR	66	LINE	CHITRADURGA_220KV - 66KV TURUVANUR	66KV MADANAYAKANAHALLI,TU RUVANUR ,JAGALU BIDAREKERE	9:43	9:55	0:12	TRIPPED ON FAULT
4618	22-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR NEW	17:50	17:55	0:05	TRIPPED ON FAULT
4619	22-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV MELLEKATTE LINE	66KV MELLEKATTE , KADAJJI	14:13	14:22	0:09	LINE CLEAR AVAILED
4620	22-Dec-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1 &2	HAVERI_220	14:39	16:20	1:41	LINE CLEAR AVAILED
4621	22-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- NARENDRA-1	NARENDRA_400	14:39	16:14	1:35	LINE CLEAR AVAILED
4622	22-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV- PGCIL-2	HIRIYUR_220	15:12	16:11	0:59	LINE CLEAR AVAILED
4623	22-Dec-24	TUMKUR	66	LINE	HIRIYUR SRS 220-66KV MATHOD-01	HINDASGHATTA AND MATHOD	15:09	16:40	1:31	LINE CLEAR AVAILED
4624	22-Dec-24	TUMKUR	66	LINE	HIRIYUR220KV-P.R. PURA_66	P.R. PURA_66	6:38	6:49	0:11	TRIPPED ON FAULT
4625	22-Dec-24	TUMKUR	66	LINE	HOSDURGA_220-66KV O/G LINE HALRAMESHWAR-1/MADADAKERE	66KV HALRAMESHWAR ,66KVMADADAKERE	19:10	20:05	0:55	TRIPPED ON FAULT
4626	22-Dec-24	TUMKUR	66	LINE	HOSDURGA_220-66KV O/G LINE HALRAMESHWAR-1/MADADAKERE	66KV HALRAMESHWAR ,66KVMADADAKERE	20:35	20:45	0:10	TRIPPED ON FAULT
4627	22-Dec-24	TUMKUR	66	LINE	MADHURE220KV_HALURA MESWARA_66	HALRAMESHWAR_66- MADADAKERE_66	15:00	16:45	1:45	LINE CLEAR AVAILED
4628	22-Dec-24	TUMKUR	66	LINE	MATHOD_66-GARAGA PANCHANAHALLI LINE	MATHOD_66,GARAGA PANCHANAHALLI_66,KAN CHIPURA	15:00	16:45	1:45	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4629	22-Dec-24	TUMKUR	220	LINE	SHIMOGA_220-K.B.CROSS,I/C LINE	110KV MAYSANDRA, KARDAL SANTHE, TALKERE, KADEHALLI, HANDANKERE, SHETTIKERE, DODDENNEGERE, MATHIGATTA, HULIYAR, BELAGALLI	23:17	23:43	0:26	TRIPPED ON FAULT
4630	22-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 2	SIRA66	10:00	17:30	7:30	LINE CLEAR AVAILED
4631	22-Dec-24	TUMKUR	66	LINE	TELIGILINE-KURUBARAHALLI_66	KURUBARAHALLI_66	7:10	7:30	0:20	MAIN SUPPLY FAILURE
4632	22-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	GARAGA_66	10:35	17:00	6:25	LINE CLEAR AVAILED
4633	22-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5 MVA	MATHOD_66	9:25	18:50	9:25	LINE CLEAR AVAILED
4634	22-Dec-24	TUMKUR	66	TRANSFORMER	TR1, 12.5 MVA SIRA_220	SIRA_220KV	10:30	15:48	5:18	LINE CLEAR AVAILED
4635	22-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	GARAGA_66	10:45	17:00	6:15	LINE CLEAR AVAILED
4636	22-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	MATHOD_66	10:35	18:50	8:15	LINE CLEAR AVAILED
4637	22-Dec-24	TUMKUR	66	TRANSFORMER	TR2 8.3 MVA	LOKIKERE_66	10:45	10:50	0:05	TRIPPED ON FAULT
4638	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV(20MVA)	THORVI_110	08:53	08:56	0:03	TRIPPED ON FAULT
4639	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	INDI_220	10:09	17:50	7:41	LINE CLEAR AVAILED
4640	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	PH COMPUND_110	11:00	11:15	0:15	TRIPPED ON FAULT
4641	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TAKKALAKI_110	16:31	16:58	0:27	LINE CLEAR AVAILED
4642	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	09:01	09:06	0:05	TRIPPED ON FAULT
4643	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	10:02	10:07	0:05	TRIPPED ON FAULT
4644	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	11:36	12:30	0:54	LINE CLEAR AVAILED
4645	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(S)_110	09:58	16:58	7:00	LINE CLEAR AVAILED
4646	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN_110	11:00	18:00	7:00	LINE CLEAR AVAILED
4647	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
4648	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	15:45	17:17	1:32	LINE CLEAR AVAILED
4649	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	BIJAPUR_220	09:05	18:26	9:21	LINE CLEAR AVAILED
4650	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(S)_110	09:58	16:58	7:00	LINE CLEAR AVAILED
4651	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN_110	13:32	16:19	2:47	LINE CLEAR AVAILED
4652	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NAVALAGI_110	17:07	18:23	1:16	LINE CLEAR AVAILED
4653	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	ZALKI_110	10:05	19:06	9:01	LINE CLEAR AVAILED
4654	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA)	ZALKI_110	10:05	19:05	9:00	LINE CLEAR AVAILED
4655	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(10MVA)	ZALKI_110	10:06	17:55	7:49	LINE CLEAR AVAILED
4656	23-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	SINDAGI_110	10:02	16:57	6:55	LINE CLEAR AVAILED
4657	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	AHERI_220	8:59	17:28	8:29	LINE CLEAR AVAILED
4658	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BIJAPUR_220	09:54	17:07	7:13	LINE CLEAR AVAILED
4659	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4660	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	AHERI_220	9:01	17:30	8:29	LINE CLEAR AVAILED
4661	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	BIJAPUR_220	09:55	17:54	7:59	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4662	23-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2(HV3)	BIJAPUR_220	09:55	17:18	7:23	LINE CLEAR AVAILED
4663	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BIJAPUR_220	09:54	17:38	7:44	LINE CLEAR AVAILED
4664	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	INDI_220	14:13	17:50	3:37	LINE CLEAR AVAILED
4665	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4666	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
4667	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	BIJAPUR_220	09:55	17:55	8:00	LINE CLEAR AVAILED
4668	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	INDI_220	14:14	17:50	3:36	LINE CLEAR AVAILED
4669	23-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2(LV3)	BIJAPUR_220	09:55	18:37	8:42	LINE CLEAR AVAILED
4670	23-Dec-24	BAGALKOTE	110	LINE	AHERI220-LN4(SINDAGI)	AHERI_220	12:49	16:54	4:05	LINE CLEAR AVAILED
4671	23-Dec-24	BAGALKOTE	220	LINE	AHERI-F1(BIJAPUR1)	AHERI_220	9:33	17:24	7:51	LINE CLEAR AVAILED
4672	23-Dec-24	BAGALKOTE	220	LINE	AHERI-F2(BIJAPUR2)	AHERI_220	09:30	17:24	7:54	LINE CLEAR AVAILED
4673	23-Dec-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI1(ALMATTI2)	BAGALKOT_220	09:16	13:51	4:35	LINE CLEAR AVAILED
4674	23-Dec-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI2(ALMATTI1)	BAGALKOT_220	01:27	13:51	12:24	TRIPPED ON FAULT
4675	23-Dec-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS1	BELGAUM_220	08:10	16:06	7:56	LINE CLEAR AVAILED
4676	23-Dec-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS2	BELGAUM_220	08:10	16:06	7:56	LINE CLEAR AVAILED
4677	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- GMNAVAR1(NANDHYAL1)	BIJAPUR_220	09:49	17:15	7:26	LINE CLEAR AVAILED
4678	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- GMNAVAR2(NANDHYAL2)	BIJAPUR_220	09:49	17:15	7:26	LINE CLEAR AVAILED
4679	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- INDI1	BIJAPUR_220	09:40	18:08	8:28	LINE CLEAR AVAILED
4680	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- INDI2	BIJAPUR_220	09:44	18:08	8:24	LINE CLEAR AVAILED
4681	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- VAISHALI1	BIJAPUR_220	09:42	18:18	8:36	LINE CLEAR AVAILED
4682	23-Dec-24	BAGALKOTE	220	LINE	BIJAPUR- VAISHALI2	BIJAPUR_220	09:42	18:20	8:38	LINE CLEAR AVAILED
4683	23-Dec-24	BAGALKOTE	110	LINE	BIJAPUR220- BAGEWADI(ENERCON)	BIJAPUR_220	09:29	18:28	8:59	LINE CLEAR AVAILED
4684	23-Dec-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR CITY	BIJAPUR_220	09:29	17:46	8:17	LINE CLEAR AVAILED
4685	23-Dec-24	BAGALKOTE	110	LINE	BIJAPUR220- KIADB1	BIJAPUR_220	09:28	17:59	8:31	LINE CLEAR AVAILED
4686	23-Dec-24	BAGALKOTE	110	LINE	BIJAPUR220- KIADB2	BIJAPUR_220	09:29	17:58	8:29	LINE CLEAR AVAILED
4687	23-Dec-24	BAGALKOTE	110	LINE	BYADAGI-HAVERU(RLW)	BYADAGI_110	01:42	01:49	0:07	TRIPPED ON FAULT
4688	23-Dec-24	BAGALKOTE	110	LINE	CHANDA KAVATE- F1(SINDAGI)	CHANDA KAVATE_110	12:54	18:29	5:35	LINE CLEAR AVAILED
4689	23-Dec-24	BAGALKOTE	220	LINE	CHIKKODI- KOLAHPUR2 (MUDASHINGI)	CHIKKODI_220	11:35	19:09	7:34	LINE CLEAR AVAILED
4690	23-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220-RAIBAG1	CHIKKODI_220	10:10	12:13	2:03	LINE CLEAR AVAILED
4691	23-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220-RAIBAG2	CHIKKODI_220	04:36	12:13	7:37	TRIPPED ON FAULT
4692	23-Dec-24	BAGALKOTE	110	LINE	DAMBAL-GADAG2(L4)	DAMBAL_110	06:58	11:51	4:53	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4693	23-Dec-24	BAGALKOTE	110	LINE	GADAG220- LAXMESHVAR	GADAG_220	12:17	15:54	3:37	LINE CLEAR AVAILED
4694	23-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
4695	23-Dec-24	BAGALKOTE	110	LINE	HIREMASALI-F1(INDI)	HIREMASALI_110	09:44	16:35	6:51	LINE CLEAR AVAILED
4696	23-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4697	23-Dec-24	BAGALKOTE	220	LINE	INDI- BIJAPUR1&2	INDI_220	09:51	17:50	7:59	LINE CLEAR AVAILED
4698	23-Dec-24	BAGALKOTE	220	LINE	INDI- MYTRA WIND	INDI_220	09:58	17:50	7:52	LINE CLEAR AVAILED
4699	23-Dec-24	BAGALKOTE	110	LINE	INDI220- DEVAR HIPPARAGI	INDI_220	10:03	17:50	7:47	LINE CLEAR AVAILED
4700	23-Dec-24	BAGALKOTE	110	LINE	INDI220- INDI	INDI_220	10:03	17:50	7:47	LINE CLEAR AVAILED
4701	23-Dec-24	BAGALKOTE	110	LINE	INDI220- ZALKI	INDI_220	10:09	17:50	7:41	LINE CLEAR AVAILED
4702	23-Dec-24	BAGALKOTE	110	LINE	KIADB BIJAPUR- B.BAGEWADI1 (RAMBHAPUR1)	KIADB BIJAPUR-110	09:30	17:43	8:13	LINE CLEAR AVAILED
4703	23-Dec-24	BAGALKOTE	110	LINE	KIADB BIJAPUR- B.BAGEWADI2 (RAMBHAPUR1)	KIADB BIJAPUR-110	09:30	17:43	8:13	LINE CLEAR AVAILED
4704	23-Dec-24	BAGALKOTE	110	LINE	KIADB BIJAPUR-BHUTNAL	KIADB BIJAPUR-110	17:47	17:51	0:04	LINE CLEAR AVAILED
4705	23-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
4706	23-Dec-24	BAGALKOTE	110	LINE	LAXMESWAR-GADAG1	LAXMESWAR_110	12:17	13:39	1:22	LINE CLEAR AVAILED
4707	23-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- RABKAVI	MAHALINGAPUR_220	11:08	17:54	6:46	LINE CLEAR AVAILED
4708	23-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4709	23-Dec-24	BAGALKOTE	110	LINE	MRUTHYUNJAY NAGAR-L2 NARENDRA(UAS DHARWAD)	MRUTHYUNJAY NAGAR_110	09:30	16:36	7:06	LINE CLEAR AVAILED
4710	23-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN1(RAIBAG1)	MUGALKHOD_220	09:42	10:02	0:20	LINE CLEAR AVAILED
4711	23-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN1(RAIBAG1)	MUGALKHOD_220	12:16	12:26	0:10	LINE CLEAR AVAILED
4712	23-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN2(RAIBAG2)	MUGALKHOD_220	09:43	10:01	0:18	LINE CLEAR AVAILED
4713	23-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN2(RAIBAG2)	MUGALKHOD_220	12:16	12:26	0:10	LINE CLEAR AVAILED
4714	23-Dec-24	BAGALKOTE	220	LINE	NARENDRA- KANABARGI1	NARENDRA_220	15:02	16:01	0:59	LINE CLEAR AVAILED
4715	23-Dec-24	BAGALKOTE	220	LINE	NARENDRA-BELGAUM2	NARENDRA_220	18:19 (21.12.2024)	16:02 (23.12.2024)	45:43:00	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4716	23-Dec-24	BAGALKOTE	110	LINE	NAVALAGI-F1(JAMAKHANDI)	NAVALAGI_110	12:59	13:10	0:11	LINE CLEAR AVAILED
4717	23-Dec-24	BAGALKOTE	110	LINE	NAVALAGI-F2(BANAHATTI)	NAVALAGI_110	13:03	17:16	4:13	LINE CLEAR AVAILED
4718	23-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
4719	23-Dec-24	BAGALKOTE	110	LINE	RAIBAG-CHIKKODI1	RAIBAG_110	10:25	12:11	1:46	LINE CLEAR AVAILED
4720	23-Dec-24	BAGALKOTE	110	LINE	RAIBAG-CHIKKODI2	RAIBAG_110	04:36	12:11	7:35	TRIPPED ON FAULT
4721	23-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
4722	23-Dec-24	BAGALKOTE	110	LINE	SAMBAPUR ROAD-DAMBALA	SAMBAPUR ROAD_110	06:58	11:56	4:58	TRIPPED ON FAULT
4723	23-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TRV(BJ CITY)	TAKKALAKI_110	08:56	17:37	8:41	LINE CLEAR AVAILED
4724	23-Dec-24	BAGALKOTE	110	LINE	TARIHAL-IDLE(KIADB)	TARIHAL_110	10:46 (22.12.2024)			LINE CLEAR AVAILED
4725	23-Dec-24	BAGALKOTE	110	LINE	THORVI-BHUTNAL	THORVI_110	08:58	14:49	5:51	LINE CLEAR AVAILED
4726	23-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL (TAKKALAKI)	TIKOTA_110	06:10	08:56	2:46	LINE CLEAR AVAILED
4727	23-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
4728	23-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-UGAR SUGARS	UGAR KHUD_110	10:40	14:30	3:50	LINE CLEAR AVAILED
4729	23-Dec-24	BANGALORE	220	LINE	220KV BWSSB HAROHALLI 220 - KIADB HAROHALLI 220	KANAKAPURA 220, KIADB HAROHALLI 220	15:33	15:43	00:10	LINE CLEAR AVAILED
4730	23-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
4731	23-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4732	23-Dec-24	BANGALORE	220	LINE	220KV KANAKAPURA 220 - TK HALLI 220	NO STATION AFFECTED	11:35	23:59	12:24	TRIPPED ON FAULT
4733	23-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	11:28	11:30	LINE CLEAR AVAILED
4734	23-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	23:59	TRIPPED ON FAULT
4735	23-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	NO STATION AFFECTED	11:57	18:20	06:23	LINE CLEAR AVAILED
4736	23-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:03	10:08	00:05	LINE CLEAR AVAILED
4737	23-Dec-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	10:25	10:27	00:02	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4738	23-Dec-24	BANGALORE	66	LINE	66KV EDC 220 - B STATION	NO STATION AFFECTED	11:42	14:08	02:26	LINE CLEAR AVAILED
4739	23-Dec-24	BANGALORE	66	LINE	66KV GOWNIPALLI - ADDAGAL	ADDAGAL	08:15	08:30	00:15	TRIPPED ON FAULT
4740	23-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR ROAD, PURVANKARA PALM BEACH	05:50	06:22	00:32	TRIPPED ON FAULT
4741	23-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR ROAD, PURVANKARA PALM BEACH	06:49	06:51	00:02	LINE CLEAR AVAILED
4742	23-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	08:24	12:03	03:39	LINE CLEAR AVAILED
4743	23-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL)_DG3	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4744	23-Dec-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	ADUGODI	07:16	07:30	00:14	TRIPPED ON FAULT
4745	23-Dec-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI	09:10	09:14	00:04	LINE CLEAR AVAILED
4746	23-Dec-24	BANGALORE	66	LINE	66KV ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	11:40	13:55	02:15	LINE CLEAR AVAILED
4747	23-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACHALU	ACHALU, HONNIGANAHALLI, HALAGURU	15:33	15:38	00:05	LINE CLEAR AVAILED
4748	23-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA	MANIYAMBAL, CHATRA, MARALAWADI, GODUR	15:33	15:46	00:13	MAIN SUPPLY FAILURE
4749	23-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	15:33	15:43	00:10	MAIN SUPPLY FAILURE
4750	23-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALLI, HUNASENAHALLI, BIJJAHALLI	15:33	15:46	00:13	MAIN SUPPLY FAILURE
4751	23-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI DAIRY, DODDALAHALLI	15:33	15:46	00:13	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4752	23-Dec-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	06:20	06:25	00:05	LINE CLEAR AVAILED
4753	23-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220_DG4	GRINDWELL NORTON, HENNUR CROSS, PURVANKARA PALM BEACH	11:59	12:12	00:13	TRIPPED ON FAULT
4754	23-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - ORCHID LAMINATES-2	ORCHID LAMINATES	15:33	15:38	00:05	LINE CLEAR AVAILED
4755	23-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - SANJEEVANADODDI	RANGANADODDI	15:33	15:38	00:05	LINE CLEAR AVAILED
4756	23-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	15:33	15:38	00:05	LINE CLEAR AVAILED
4757	23-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	18:11	18:15	00:04	LINE CLEAR AVAILED
4758	23-Dec-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	14:40	15:40	01:00	LINE CLEAR AVAILED
4759	23-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66_DG3	MANYATHA 66	13:02	15:39	02:37	LINE CLEAR AVAILED
4760	23-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY_DG3	NO STATION AFFECTED	08:08	12:06	03:58	LINE CLEAR AVAILED
4761	23-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY_DG3	SHOBHA CITY	05:55	07:03	01:08	TRIPPED ON FAULT
4762	23-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY_DG3	SHOBHA CITY	07:10	23:59	16:49	LINE CLEAR AVAILED
4763	23-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - A.R.CIRCLE STATION (A2)	NO STATION AFFECTED	12:03	18:18	06:15	LINE CLEAR AVAILED
4764	23-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	07:27	08:00	00:33	TRIPPED ON FAULT
4765	23-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	11:42	14:05	02:23	LINE CLEAR AVAILED
4766	23-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4767	23-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI)_DG4	HENNUR ROAD, PURVANKARA PALM BEACH	12:00	12:12	00:12	MAIN SUPPLY FAILURE
4768	23-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	GLOBAL TECH PARK	11:04	11:12	00:08	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4769	23-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	11:05	11:10	00:05	LINE CLEAR AVAILED
4770	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	06:23	06:26	00:03	LINE CLEAR AVAILED
4771	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	22:12	22:15	00:03	LINE CLEAR AVAILED
4772	23-Dec-24	BANGALORE	220	TRANSFORMER	HV1	EAST DIVISION COMPOUND 220	11:44	13:55	02:11	LINE CLEAR AVAILED
4773	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	11:40	11:45	00:05	LINE CLEAR AVAILED
4774	23-Dec-24	BANGALORE	220	TRANSFORMER	HV1	HSR LAYOUT 220	21:29	23:31	02:02	LINE CLEAR AVAILED
4775	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ISRO LAYOUT	12:01	12:05	00:04	LINE CLEAR AVAILED
4776	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	JANGAMKOTE	12:00	12:03	00:03	LINE CLEAR AVAILED
4777	23-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KANAKAPURA 220	15:33	15:43	00:10	MAIN SUPPLY FAILURE
4778	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KIADB HAROHALLI 220	15:33	15:38	00:05	LINE CLEAR AVAILED
4779	23-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KIADB HAROHALLI 220	15:33	15:38	00:05	LINE CLEAR AVAILED
4780	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	LAKSHMIPURA	10:05	10:32	00:27	TRIPPED ON FAULT
4781	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANCHENAHALLI	15:40	16:00	00:20	LINE CLEAR AVAILED
4782	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SADALI	11:40	13:40	02:00	LINE CLEAR AVAILED
4783	23-Dec-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	03:40	03:55	00:15	TRIPPED ON FAULT
4784	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDAPURA	11:36	11:44	00:08	LINE CLEAR AVAILED
4785	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	16:00	16:05	00:05	TRIPPED ON FAULT
4786	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHELUR	17:05	17:20	00:15	LINE CLEAR AVAILED
4787	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DIVYASHREE TECH PARK	13:14	13:20	00:06	LINE CLEAR AVAILED
4788	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDEMARANAHALLI	14:40	14:42	00:02	LINE CLEAR AVAILED
4789	23-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KANAKAPURA 220	15:33	15:43	00:10	MAIN SUPPLY FAILURE
4790	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KIADB HAROHALLI 220	15:33	15:38	00:05	LINE CLEAR AVAILED
4791	23-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KIADB HAROHALLI 220	15:33	15:38	00:05	LINE CLEAR AVAILED
4792	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MANCHENAHALLI	15:40	16:00	00:20	LINE CLEAR AVAILED
4793	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	PUTTENAHALLI 220	13:01	13:10	00:09	TRIPPED ON FAULT
4794	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAVAREKERE	23:40	23:59	00:19	LINE CLEAR AVAILED
4795	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	THAYALUR	16:05	16:35	00:30	LINE CLEAR AVAILED
4796	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VICTORIA	06:39	06:48	00:09	TRIPPED ON FAULT
4797	23-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	11:05	11:10	00:05	LINE CLEAR AVAILED
4798	23-Dec-24	BANGALORE	220	TRANSFORMER	HV3	HSR LAYOUT 220	23:43	23:59	00:16	LINE CLEAR AVAILED
4799	23-Dec-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	10:51	11:13	00:22	TRIPPED ON FAULT
4800	23-Dec-24	GULBARGA	110	LINE	AFZALPUR-MADIYAL	AFZALPUR_110	16:12	16:32	00:20	MAIN SUPPLY FAILURE
4801	23-Dec-24	GULBARGA	66	LINE	BADALADUKU-KUDLIGI	KUDLIGI_66,HANSI_66	07:45	19:50	12:05	LINE CLEAR AVAILED
4802	23-Dec-24	GULBARGA	66	LINE	BADALADUKU-UJJINI	KOTTUR_66,UJJINI_66	23:30	23:45	00:15	TRIPPED ON FAULT
4803	23-Dec-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERDONA_110,BENNUR_110	12:47	12:57	00:10	TRIPPED ON FAULT
4804	23-Dec-24	GULBARGA	66	LINE	HANSI KUDLIGI	HANSI_66	11:00	17:30	06:30	LINE CLEAR AVAILED
4805	23-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BYAGWAT_110	11:00	12:05	01:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4806	23-Dec-24	GULBARGA	110	TRANSFORMER	HV1	GUGAL_110	14:25	14:40	00:15	TRIPPED ON FAULT
4807	23-Dec-24	GULBARGA	110	TRANSFORMER	HV1	KALABURGI NORTH_110	10:07	15:02	04:55	LINE CLEAR AVAILED
4808	23-Dec-24	GULBARGA	110	TRANSFORMER	HV2	APMC_110	13:45	13:55	00:10	MAIN SUPPLY FAILURE
4809	23-Dec-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	00:45	01:25	00:40	LINE CLEAR AVAILED
4810	23-Dec-24	GULBARGA	66	TRANSFORMER	HV2	PUNABHAGATTA_66	09:45	10:15	00:30	TRIPPED ON FAULT
4811	23-Dec-24	GULBARGA	110	TRANSFORMER	HV2	SIRIGUPPA_110	07:05	07:15	00:10	TRIPPED ON FAULT
4812	23-Dec-24	GULBARGA	66	LINE	ITTAGI -KUDLIGI 2	HANSI_66,GUDEKOTE_66, CHORNUR_66,BANAVIKAL_66	07:40	21:30	13:50	LINE CLEAR AVAILED
4813	23-Dec-24	GULBARGA	66	LINE	ITTAGI-CLEAN MAX 1&2	ITTAGI_220	11:16	12:38	01:22	LINE CLEAR AVAILED
4814	23-Dec-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	07:03	08:29	01:26	TRIPPED ON FAULT
4815	23-Dec-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	10:39	15:22	04:43	LINE CLEAR AVAILED
4816	23-Dec-24	GULBARGA	110	LINE	KAPNOOR-KALBURGI NORTH	KALBURGI NORTH_110	10:53	12:55	02:02	LINE CLEAR AVAILED
4817	23-Dec-24	GULBARGA	110	LINE	KUDITINI-KUDITINI	KUDITINI_110,TORANGAL U_110,KUDITINI_110,MET RI_110,KURUGOD_110	11:15	11:22	00:07	TRIPPED ON FAULT
4818	23-Dec-24	GULBARGA	66	LINE	KUDLIGI-HANSI	KUDLIGI_66	07:35	19:50	12:15	LINE CLEAR AVAILED
4819	23-Dec-24	GULBARGA	110	LINE	MUNIRABAD-KAMPLI	KAMPLI_110, ITTAGI_110	09:30	17:30	08:00	LINE CLEAR AVAILED
4820	23-Dec-24	GULBARGA	110	LINE	MUNIRABAD-SANKLAPUR	SANKLAPURA_110	18:29	18:41	00:12	TRIPPED ON FAULT
4821	23-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
4822	23-Dec-24	GULBARGA	110	LINE	RAICHUR -MALIYABAD	MALIYABAD_110,YERAGER A_110,VADAVATTI_110,YA PALDINNI_110	16:58	17:04	00:06	TRIPPED ON FAULT
4823	23-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDDAPUR	MUDDAPUR_110	23:10	23:20	00:10	TRIPPED ON FAULT
4824	23-Dec-24	GULBARGA	220	LINE	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	07:10	07:25	00:15	TRIPPED ON FAULT
4825	23-Dec-24	GULBARGA	110	LINE	SINDHANOOR-WALKAMDINI	WALKAMDINI_110	09:05	13:55	04:50	LINE CLEAR AVAILED
4826	23-Dec-24	GULBARGA	110	LINE	SULEKAL-HANWAL	HANWAL_110,MARALIHALLA_110	13:55	15:10	01:15	LINE CLEAR AVAILED
4827	23-Dec-24	GULBARGA	110	LINE	SULEKAL-ITTAGI	MALLAPUR_110	09:50	17:40	07:50	LINE CLEAR AVAILED
4828	23-Dec-24	HASAN	66	LINE	BANDISH-ADANI	BANDISHETTIHALLI_66	07:30	07:35	00:05	MAIN SUPPLY FAILURE
4829	23-Dec-24	HASAN	66	LINE	BANDISH-HNPPURA	BANDISHETTIHALLI_66	07:30	07:35	00:05	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4830	23-Dec-24	HASAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	07:30	07:35	00:05	MAIN SUPPLY FAILURE
4831	23-Dec-24	HASAN	110	LINE	BLGMB-AFT	BELAGUMBA_110	13:50	14:10	00:20	LINE CLEAR AVAIED
4832	23-Dec-24	HASAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	06:33	06:45	00:12	TRIPPED ON FAULT
4833	23-Dec-24	HASAN	66	LINE	HNPR2-HASS3	HOLENARASIPURA_220	11:02	19:30	08:28	LINE CLEAR AVAIED
4834	23-Dec-24	HASAN	66	LINE	HNPR2-RNPR2	HOLENARASIPURA_220	07:28	07:37	00:09	TRIPPED ON FAULT
4835	23-Dec-24	HASAN	66	LINE	HNPURA-HASSAN	HNPURA_66	10:20	12:50	02:30	LINE CLEAR AVAIED
4836	23-Dec-24	HASAN	110	TRANSFORMER	HV1	BANAVARA_110	15:25	17:10	01:45	LINE CLEAR AVAIED
4837	23-Dec-24	HASAN	66	TRANSFORMER	HV1	BANDISHETTIHALLI_66	07:30	07:35	00:05	MAIN SUPPLY FAILURE
4838	23-Dec-24	HASAN	66	TRANSFORMER	HV1	CHIKKAKONDAGOLA_66	12:58	13:29	00:31	LINE CLEAR AVAIED
4839	23-Dec-24	HASAN	66	TRANSFORMER	HV1	UDAYAPURA_66	12:35	13:07	00:32	LINE CLEAR AVAIED
4840	23-Dec-24	HASAN	66	TRANSFORMER	HV1	UDAYAPURA_66	15:00	15:10	00:10	TRIPPED ON FAULT
4841	23-Dec-24	HASAN	66	TRANSFORMER	HV2	BANDISHETTIHALLI_66	07:30	07:35	00:05	MAIN SUPPLY FAILURE
4842	23-Dec-24	HASAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	10:25	10:35	00:10	TRIPPED ON FAULT
4843	23-Dec-24	HASAN	66	TRANSFORMER	HV2	CHIKKAKONDAGOLA_66	10:01	13:00	02:59	LINE CLEAR AVAIED
4844	23-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
4845	23-Dec-24	HASAN	110	LINE	KADUR-TNGL	KADUR_220	13:15	13:40	00:25	LINE CLEAR AVAIED
4846	23-Dec-24	HASAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	08:50	21:15	12:25	LINE CLEAR AVAIED
4847	23-Dec-24	HASAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	10:00	13:50	03:50	LINE CLEAR AVAIED
4848	23-Dec-24	HASAN	66	LINE	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:03	18:07	08:04	LINE CLEAR AVAIED
4849	23-Dec-24	HASAN	66	LINE	MATTNAV-DIDGTHL	MATTANAVILE_66	01:54	02:05	00:11	TRIPPED ON FAULT
4850	23-Dec-24	HASAN	66	LINE	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	11:00	11:25	00:25	MAIN SUPPLY FAILURE
4851	23-Dec-24	HASAN	66	LINE	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	19:20	19:25	00:05	MAIN SUPPLY FAILURE
4852	23-Dec-24	HASAN	66	LINE	MRSSHM-DVG2	MRSMSG_220	09:40	16:13	06:33	LINE CLEAR AVAIED
4853	23-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	23:17(22.12.2024)	12:27(23:12.2024))	13:07 hrs	LINE CLEAR AVAIED
4854	23-Dec-24	HASAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	14:04	15:44	01:40	TRIPPED ON FAULT
4855	23-Dec-24	HASAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	17:28	21:49	04:21	TRIPPED ON FAULT
4856	23-Dec-24	HASAN	220	LINE	MRSSHM-VARAH2	MRSMSG_220	11:41	12:43	01:02	LINE CLEAR AVAIED
4857	23-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	08:50	21:15	12:25	LINE CLEAR AVAIED
4858	23-Dec-24	HASAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	10:00	13:50	03:50	LINE CLEAR AVAIED
4859	23-Dec-24	HASAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	09:30	18:03	08:33	LINE CLEAR AVAIED
4860	23-Dec-24	HASAN	66	LINE	SIGEBAG-SMG-DVG2	SIGEBAGE_66	09:40	16:14	06:34	LINE CLEAR AVAIED
4861	23-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	11:49	14:57	03:08	LINE CLEAR AVAIED
4862	23-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA1	varahi_gen	14:04	15:44	01:40	TRIPPED ON FAULT
4863	23-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA1	varahi_gen	17:28	21:49	04:21	TRIPPED ON FAULT
4864	23-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA2	varahi_gen	11:41	12:43	01:02	LINE CLEAR AVAIED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4865	23-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
4866	23-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
4867	23-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI 1	NO STATIONS EFFECTED	09:09	17:36	08:27	LINE CLEAR AVAILED
4868	23-Dec-24	MYSORE	220	LINE	HEBBANI-TK HALLI 2	NO STATIONS EFFECTED	09:09	17:36	08:27	LINE CLEAR AVAILED
4869	23-Dec-24	MYSORE	66	LINE	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	18:16	18:30	00:14	TRIPPED ON FAULT
4870	23-Dec-24	MYSORE	66	TRANSFORMER	HV1	BANNUR_66	15:28	16:06	00:38	LINE CLEAR AVAILED
4871	23-Dec-24	MYSORE	66	TRANSFORMER	HV1	GAMANAHALLY_66	12:12	16:10	03:57	LINE CLEAR AVAILED
4872	23-Dec-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA(K)_66	10:05	17:03	06:58	LINE CLEAR AVAILED
4873	23-Dec-24	MYSORE	66	TRANSFORMER	HV1	PONNAMPET_66	11:00	12:59	01:58	LINE CLEAR AVAILED
4874	23-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4875	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	ANEGOLAL_66	13:00	13:25	00:25	LINE CLEAR AVAILED
4876	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	11:05	15:13	04:08	LINE CLEAR AVAILED
4877	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	GAMANAHALLY_66	21:02	21:12	00:10	TRIPPED ON FAULT
4878	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	HAMPAPURA(K)_66	10:05	17:03	06:58	LINE CLEAR AVAILED
4879	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	KUNTHUR_66	17:45	17:55	00:10	LINE CLEAR AVAILED
4880	23-Dec-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	11:00	13:00	01:59	LINE CLEAR AVAILED
4881	23-Dec-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66	10:14	12:40	02:25	LINE CLEAR AVAILED
4882	23-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4883	23-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
4884	23-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
4885	23-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
4886	23-Dec-24	MYSORE	66	LINE	MALAVALLI-KK HALLI	KADKOTHANAHALLI_66	10:02	16:37	06:35	LINE CLEAR AVAILED
4887	23-Dec-24	MYSORE	66	LINE	MUGUR-THAYUR	THAYUR_66TNARASIPURA_66	18:25	18:30	00:05	TRIPPED ON FAULT
4888	23-Dec-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	GUDDENAHALLI_66BOGA DHI_66	02:09	02:18	00:09	TRIPPED ON FAULT
4889	23-Dec-24	MYSORE	66	LINE	PERIYAPATNA-HANGUD	NO STATIONS EFFECTED	23:59 (23/12/2024)			TRIPPED ON FAULT
4890	23-Dec-24	MYSORE	66	LINE	SANTHESARGUR-B MATTAGERE	NO STATIONS EFFECTED	17:05	17:09	00:04	LINE CLEAR AVAILED
4891	23-Dec-24	MYSORE	66	LINE	SFC SIVA-5MW	NO STATIONS EFFECTED	18:16 (23/12/2024)			TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4892	23-Dec-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	18:16	18:22	00:05	TRIPPED ON FAULT
4893	23-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	23:30	23:45	0:15	TRIPPED ON FAULT
4894	23-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	1:45	2:10	0:25	TRIPPED ON FAULT
4895	23-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	11:50	14:15	2:25	LINE CLEAR AVAILED
4896	23-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	18:10	18:15	0:05	TRIPPED ON FAULT
4897	23-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KREBILCHI 66	11:25	11:41	0:16	TRIPPED ON FAULT
4898	23-Dec-24	TUMKUR	66	LINE	CHIKKAJAJUR-SASALUHALLA_66	CHIKKAJAJUR_66	15:40	15:50	0:10	TRIPPED ON FAULT
4899	23-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS _MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	14:17	15:11	0:54	TRIPPED ON FAULT
4900	23-Dec-24	TUMKUR	66	LINE	GUTTUR 400KV- KAIGA 11KV	KAIGA 11KV	3:11	7:25	4:14	TRIPPED ON FAULT
4901	23-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV-NARENDRA-2	NARENDRA -2 LINE	23:58:00	6:28	6:30	LINE CLEAR AVAILED
4902	23-Dec-24	TUMKUR	66	LINE	HIRIYUR220KV-P.R. PURA_66	P.R. PURA_66	6:38	6:49	0:11	TRIPPED ON FAULT
4903	23-Dec-24	TUMKUR	66	LINE	HOSADURGA66-RAMAGIRI	RAMAGIRI_66	5:55	6:15	0:20	TRIPPED ON FAULT
4904	23-Dec-24	TUMKUR	220	LINE	JAGALUR 400KV-CHITRADURGA-2_220KV	JAGALUR 400KV	12:12	15:20	3:08	LINE CLEAR AVAILED
4905	23-Dec-24	TUMKUR	220	LINE	JAGALUR 400KV-CHITRADURGA-2_220KV	JAGALUR 400KV	16:17	18:05	1:48	LINE CLEAR AVAILED
4906	23-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV-SHIMOGA1	KBCROSS_220	23:43	0:58	1:15	TRIPPED ON FAULT
4907	23-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV-SHIMOGA1	KBCROSS_220	0:58	12:27	11:29	LINE CLEAR AVAILED
4908	23-Dec-24	TUMKUR	110	LINE	NITTUR_220-110KV KALLUR	110KV KALLUR	10:25	13:47	3:22	LINE CLEAR AVAILED
4909	23-Dec-24	TUMKUR	110	LINE	NITTUR_220-110KV KGTEMPLE	110KV KGTEMPLE	10:25	13:47	3:22	LINE CLEAR AVAILED
4910	23-Dec-24	TUMKUR	66	TRANSFORMER	TR1 20 MVA	CHANNAGIRI_66	10:05	10:25	0:20	TRIPPED ON FAULT
4911	23-Dec-24	TUMKUR	66	TRANSFORMER	TR1 20 MVA	CHANNAGIRI_66	15:15	15:20	0:05	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4912	23-Dec-24	TUMKUR	66	TRANSFORMER	TR1 20 MVA	CHANNAGIRI_66	10:25	13:55	3:30	LINE CLEAR AVAILED
4913	23-Dec-24	TUMKUR	66	TRANSFORMER	TR2 100MVA	DAVANGERE_220KV , 66KV O/G LINES MELEKKATTE, MAYAKONDA. ATTIGERE	14:17	14:30	0:13	TRIPPED ON FAULT
4914	23-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	KUKKAWADA_66	9:01	9:06	0:05	TRIPPED ON FAULT
4915	23-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	SASALUHALLA_66	18:25	NOT YET CHARGED		LINE CLEAR AVAILED
4916	23-Dec-24	TUMKUR	66	TRANSFORMER	TR2 20 MVA	CHANNAGIRI_66	12:30	12:40	0:10	TRIPPED ON FAULT
4917	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
4918	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	10:09	13:11	3:02	LINE CLEAR AVAILED
4919	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MUNAVALLY_110	17:26	18:22	0:56	LINE CLEAR AVAILED
4920	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	NAVALGUND_110	10:40	14:17	3:37	LINE CLEAR AVAILED
4921	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NAVALAGI_110	14:56	16:20	1:24	LINE CLEAR AVAILED
4922	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	RON_110	10:21	17:51	7:30	LINE CLEAR AVAILED
4923	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	RON_110	10:20	18:14	7:54	LINE CLEAR AVAILED
4924	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	SINDAGI_110	07:53	08:00	0:07	TRIPPED ON FAULT
4925	24-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	ZALKI_110	14:10	14:35	0:25	LINE CLEAR AVAILED
4926	24-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4927	24-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
4928	24-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
4929	24-Dec-24	BAGALKOTE	110	LINE	AINAPUR-KUDACHI220	AINAPUR_110	02:33	02:48	0:15	TRIPPED ON FAULT
4930	24-Dec-24	BAGALKOTE	220	LINE	BAGALKOT - GADAG1	BAGALKOT_220	11:04	13:17	2:13	LINE CLEAR AVAILED
4931	24-Dec-24	BAGALKOTE	220	LINE	BAGALKOT - GADAG-2	BAGALKOT_220	13:25	17:32	4:07	LINE CLEAR AVAILED
4932	24-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F6-KERUR	BAGALKOT_220	09:48	10:05	0:17	LINE CLEAR AVAILED
4933	24-Dec-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS1	BELGAUM_220	17:39	17:48	0:09	LINE CLEAR AVAILED
4934	24-Dec-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS2	BELGAUM_220	17:53	17:56	0:03	LINE CLEAR AVAILED
4935	24-Dec-24	BAGALKOTE	110	LINE	BIDNAL220- ANNIGERI	BIDNAL_220	11:17	13:47	2:30	LINE CLEAR AVAILED
4936	24-Dec-24	BAGALKOTE	110	LINE	BIJAPUR220- BAGEWADI(ENERCON)	BIJAPUR_220	12:45	17:04	4:19	LINE CLEAR AVAILED
4937	24-Dec-24	BAGALKOTE	110	LINE	CHIKKODI220- NIPPANI (KHADAKALAT)	CHIKKODI_220	15:43	16:01	0:18	TRIPPED ON FAULT
4938	24-Dec-24	BAGALKOTE	220	LINE	GADAG- BAGALKOT1	GADAG_220	11:04	13:17	2:13	LINE CLEAR AVAILED
4939	24-Dec-24	BAGALKOTE	220	LINE	GADAG- BAGALKOT2	GADAG_220	13:26	17:32	4:06	LINE CLEAR AVAILED
4940	24-Dec-24	BAGALKOTE	110	LINE	GADAG220- BETAGERI(RON)	GADAG_220	15:34	17:12	1:38	LINE CLEAR AVAILED
4941	24-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4942	24-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON1	GAJENDRAGAD_110	11:25	16:17	4:52	LINE CLEAR AVAILED
4943	24-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
4944	24-Dec-24	BAGALKOTE	110	LINE	GARAG-NARENDRA	GARAG_110	11:14	16:16	5:02	LINE CLEAR AVAILED
4945	24-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
4946	24-Dec-24	BAGALKOTE	110	LINE	HIREMASALI- F1(INDI220)	HIREMASALI_110	08:48	08:51	0:03	LINE CLEAR AVAILED
4947	24-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4948	24-Dec-24	BAGALKOTE	110	LINE	KERUR- KONNUR	KERUR_110	10:01	10:21	0:20	LINE CLEAR AVAILED
4949	24-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
4950	24-Dec-24	BAGALKOTE	110	LINE	KONNUR- KERUR	KONNUR_110	11:15	13:27	2:12	LINE CLEAR AVAILED
4951	24-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS- KERUR	KULAGERI CROSS_110	10:16	10:57	0:41	LINE CLEAR AVAILED
4952	24-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS- MRN SUGARS	KULAGERI CROSS_110	10:54	10:58	0:04	LINE CLEAR AVAILED
4953	24-Dec-24	BAGALKOTE	110	LINE	KULAGERI CROSS- MRN SUGARS	KULAGERI CROSS_110	16:20	16:24	0:04	TRIPPED ON FAULT
4954	24-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4955	24-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN3(ITNAL1)	MUGALKHOD_220	9:40	11:18	1:38	LINE CLEAR AVAILED
4956	24-Dec-24	BAGALKOTE	110	LINE	NARAGUND- BPCL	NARAGUND_110	09:26	17:27	8:01	LINE CLEAR AVAILED
4957	24-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
4958	24-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
4959	24-Dec-24	BAGALKOTE	110	LINE	RON- GAJENDRAGAD1	RON_110	11:16	16:15	4:59	LINE CLEAR AVAILED
4960	24-Dec-24	BAGALKOTE	110	LINE	RON- GAJENDRAGAD2	RON_110	11:16	16:15	4:59	LINE CLEAR AVAILED
4961	24-Dec-24	BAGALKOTE	110	LINE	RON- GAMESHA	RON_110	10:51	17:16	6:25	LINE CLEAR AVAILED
4962	24-Dec-24	BAGALKOTE	110	LINE	RON- NAREGAL	RON_110	10:46	15:24	4:38	LINE CLEAR AVAILED
4963	24-Dec-24	BAGALKOTE	110	LINE	RON- NAREGAL	RON_110	17:17	17:24	0:07	LINE CLEAR AVAILED
4964	24-Dec-24	BAGALKOTE	110	LINE	TARIHAL-IDLE(KIADB)	TARIHAL_110	10:46 (22.12.2024)	12:55 (24.12.2024)	50:09:00	LINE CLEAR AVAILED
4965	24-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
4966	24-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR1	VAJRAMATTI_220	10:44	12:00	1:16	LINE CLEAR AVAILED
4967	24-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR2	VAJRAMATTI_220	12:06	13:26	1:20	LINE CLEAR AVAILED
4968	24-Dec-24	BAGALKOTE	110	LINE	VAJRAMATTI220-LOKAPUR	VAJRAMATTI_220	15:24	17:03	1:39	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4969	24-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
4970	24-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4971	24-Dec-24	BANGALORE	220	LINE	220KV HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	17:54	20:25	02:31	TRIPPED ON FAULT
4972	24-Dec-24	BANGALORE	220	LINE	220KV HOODY 400 - HAL 2	NO STATION AFFECTED	23:58:00	03:13	03:15	LINE CLEAR AVAILED
4973	24-Dec-24	BANGALORE	220	LINE	220KV KANAKAPURA 220 - TK HALLI 220	NO STATION AFFECTED	10:25	11:39	01:14	LINE CLEAR AVAILED
4974	24-Dec-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	12:48	13:27	00:39	LINE CLEAR AVAILED
4975	24-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
4976	24-Dec-24	BANGALORE	220	LINE	220KV SHOBHA DREAMS 220 - SOMANAHALLI 220	NO STATION AFFECTED	10:44	13:00	02:16	TRIPPED ON FAULT
4977	24-Dec-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	DEVARABISANAHALLI	10:03	10:07	00:04	LINE CLEAR AVAILED
4978	24-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:01	10:05	00:04	LINE CLEAR AVAILED
4979	24-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	NO STATION AFFECTED	18:27	18:41	00:14	LINE CLEAR AVAILED
4980	24-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	NO STATION AFFECTED	18:53	19:06	00:13	LINE CLEAR AVAILED
4981	24-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURVANKARA PALM BEACH	06:14	06:18	00:04	LINE CLEAR AVAILED
4982	24-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	06:30	07:41	01:11	LINE CLEAR AVAILED
4983	24-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
4984	24-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4985	24-Dec-24	BANGALORE	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	DOMMASANDRA	16:05	16:12	00:07	LINE CLEAR AVAILED
4986	24-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	ALLIMARADANAHALLI	15:53	16:57	01:04	LINE CLEAR AVAILED
4987	24-Dec-24	BANGALORE	66	LINE	66KV KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY PUMP HOUSE	12:10	14:07	01:57	LINE CLEAR AVAILED
4988	24-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	20:52	20:58	00:06	LINE CLEAR AVAILED
4989	24-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY _DG3	SHOBHA CITY	23:58:00	07:36	07:38	LINE CLEAR AVAILED
4990	24-Dec-24	BANGALORE	66	LINE	66KV MASTHENAHALLI - TALAGAWARA	NO STATION AFFECTED	19:11	19:14	00:03	LINE CLEAR AVAILED
4991	24-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:52	13:02	00:10	LINE CLEAR AVAILED
4992	24-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	15:48	15:50	00:02	LINE CLEAR AVAILED
4993	24-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:51	13:04	00:13	LINE CLEAR AVAILED
4994	24-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	12:13	14:04	01:51	LINE CLEAR AVAILED
4995	24-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	15:56	16:05	00:09	LINE CLEAR AVAILED
4996	24-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	16:06	16:45	00:39	LINE CLEAR AVAILED
4997	24-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
4998	24-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	15:33	15:39	00:06	LINE CLEAR AVAILED
4999	24-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI) _DG4	HENNUR CROSS, PURVANKARA PALM BEACH	07:53	07:55	00:02	LINE CLEAR AVAILED
5000	24-Dec-24	BANGALORE	66	LINE	66KV VOKKALERI - KC VALLEY (EHT)	NO STATION AFFECTED	14:10	14:45	00:35	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5001	24-Dec-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	13:10	23:59	10:49	LINE CLEAR AVAIED
5002	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKAGANGANAWADI	10:15	15:15	05:00	LINE CLEAR AVAIED
5003	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ELECTRONIC CITY	12:20	12:40	00:20	LINE CLEAR AVAIED
5004	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	17:05	17:32	00:27	LINE CLEAR AVAIED
5005	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SHOBHA CITY	07:48	08:00	00:12	TRIPPED ON FAULT
5006	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	16:05	17:50	01:45	LINE CLEAR AVAIED
5007	24-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	10:35	10:40	00:05	LINE CLEAR AVAIED
5008	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BUDIKOTE	12:05	12:35	00:30	LINE CLEAR AVAIED
5009	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKAGANGANAWADI	10:15	15:15	05:00	LINE CLEAR AVAIED
5010	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ELECTRONIC CITY	12:20	12:40	00:20	LINE CLEAR AVAIED
5011	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	00:15	00:28	00:13	TRIPPED ON FAULT
5012	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	PALLICHERLU	18:00	18:10	00:10	TRIPPED ON FAULT
5013	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAVAREKERE	23:58:00	00:45	00:47	LINE CLEAR AVAIED
5014	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TK HALLI 220	15:12	15:43	00:31	LINE CLEAR AVAIED
5015	24-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VOKKALERI	14:10	14:15	00:05	LINE CLEAR AVAIED
5016	24-Dec-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERDONA_110,BENNUR_110	14:50	18:05	03:15	TRIPPED ON FAULT
5017	24-Dec-24	GULBARGA	110	LINE	HATTIGUDUR-NAGNOOR	NAGNOOR_110	22:10	22:34	00:24	TRIPPED ON FAULT
5018	24-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	11:05	13:55	02:50	LINE CLEAR AVAIED
5019	24-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	15:10	15:20	00:10	LINE CLEAR AVAIED
5020	24-Dec-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	11:36	11:47	00:11	LINE CLEAR AVAIED
5021	24-Dec-24	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	22:25	22:45	00:20	TRIPPED ON FAULT
5022	24-Dec-24	GULBARGA	66	TRANSFORMER	HV2	HOSAHALLI_66	13:45	15:20	01:35	LINE CLEAR AVAIED
5023	24-Dec-24	GULBARGA	220	LINE	ITTAGI-EMBASSY	ITTAGI_220	16:30	18:40	02:10	LINE CLEAR AVAIED
5024	24-Dec-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	16:35	18:20	01:45	LINE CLEAR AVAIED
5025	24-Dec-24	GULBARGA	66	LINE	ITTAGI-KUDLIGI 2	HANSI_66,GUDEKOTE_66, CHORNUR_66,BANAVIKAL_66	13:05	15:05	02:00	LINE CLEAR AVAIED
5026	24-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAIED
5027	24-Dec-24	GULBARGA	110	LINE	RAICHUR-GUGAL	GUGAL_110,GABBUR_110	12:52	13:02	00:10	MAIN SUPPLY FAILURE
5028	24-Dec-24	GULBARGA	110	LINE	RAICHUR-GUGAL	GUGAL_110,GABBUR_110	13:05	13:15	00:10	MAIN SUPPLY FAILURE
5029	24-Dec-24	GULBARGA	110	LINE	SULEKAL-HANAWAL-	HANAWAL_110,MARALIHALLA_110,YERDONA_110,BENNUR_110	18:42	18:47	00:05	MAIN SUPPLY FAILURE
5030	24-Dec-24	GULBARGA	110	LINE	YADGIR-DEVAPUR	DEVAPUR_110,SHORAPUR_110	06:10	06:52	00:42	TRIPPED ON FAULT
5031	24-Dec-24	GULBARGA	110	LINE	YADGIR-DEVAPUR	DEVAPUR_110,SHORAPUR_110	22:11	22:35	00:24	TRIPPED ON FAULT
5032	24-Dec-24	GULBARGA	110	LINE	YADGIR-SHORAPUR	SHORAPUR_110	06:15	06:28	00:13	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5033	24-Dec-24	HASAN	66	LINE	BALLUPE-SKLPR	BALLUPETE_66	11:50	12:23	00:33	LINE CLEAR AVAIED
5034	24-Dec-24	HASAN	220	LINE	CRPATNA-HUYGNH	CRPATNA_220	11:45	14:34	02:49	LINE CLEAR AVAIED
5035	24-Dec-24	HASAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_66	09:55	15:10	05:15	LINE CLEAR AVAIED
5036	24-Dec-24	HASAN	66	LINE	HASSN22-SKPURA1	HASSAN_220	11:48	12:23	00:35	LINE CLEAR AVAIED
5037	24-Dec-24	HASAN	66	LINE	HNPR2-CRPTN	HOLENARASIPURA_220	11:52	12:02	00:10	MAIN SUPPLY FAILURE
5038	24-Dec-24	HASAN	66	LINE	HNPR2-HASS1	HOLENARASIPURA_220	11:52	11:58	00:06	MAIN SUPPLY FAILURE
5039	24-Dec-24	HASAN	66	LINE	HNPR2-HASS2	HOLENARASIPURA_220	11:52	12:00	00:08	MAIN SUPPLY FAILURE
5040	24-Dec-24	HASAN	66	LINE	HNPR2-HASS3	HOLENARASIPURA_220	11:52	12:00	00:08	MAIN SUPPLY FAILURE
5041	24-Dec-24	HASAN	66	LINE	HNPR2-HDVL	HOLENARASIPURA_220	11:52	12:03	00:11	MAIN SUPPLY FAILURE
5042	24-Dec-24	HASAN	66	LINE	HNPR2-HNPR1	HOLENARASIPURA_220	11:52	11:58	00:06	MAIN SUPPLY FAILURE
5043	24-Dec-24	HASAN	66	LINE	HNPR2-MYSOR1	HOLENARASIPURA_220	11:52	12:02	00:10	MAIN SUPPLY FAILURE
5044	24-Dec-24	HASAN	66	LINE	HNPR2-MYSOR2	HOLENARASIPURA_220	11:52	12:02	00:10	MAIN SUPPLY FAILURE
5045	24-Dec-24	HASAN	66	LINE	HNPR2-RNPR1	HOLENARASIPURA_220	11:52	12:02	00:10	MAIN SUPPLY FAILURE
5046	24-Dec-24	HASAN	66	LINE	HNPR2-RNPR2	HOLENARASIPURA_220	11:52	12:00	00:08	MAIN SUPPLY FAILURE
5047	24-Dec-24	HASAN	66	TRANSFORMER	HV1	DODDAHALLI_66	14:25	14:37	00:12	LINE CLEAR AVAIED
5048	24-Dec-24	HASAN	66	TRANSFORMER	HV1	HALLYMYSORE_66	11:49	12:11	00:22	MAIN SUPPLY FAILURE
5049	24-Dec-24	HASAN	66	TRANSFORMER	HV1	HANGRAHALLI_66	11:49	12:07	00:18	MAIN SUPPLY FAILURE
5050	24-Dec-24	HASAN	66	TRANSFORMER	HV1	HNPUA_66	11:45	12:00	00:15	MAIN SUPPLY FAILURE
5051	24-Dec-24	HASAN	220	TRANSFORMER	HV1	HOLENARASIPURA_220	11:47	11:57	00:10	TRIPPED ON FAULT
5052	24-Dec-24	HASAN	110	TRANSFORMER	HV1	JADE_110	10:50	16:00	05:10	LINE CLEAR AVAIED
5053	24-Dec-24	HASAN	110	TRANSFORMER	HV1	NANDIKUR_110	09:28	13:52	04:24	LINE CLEAR AVAIED
5054	24-Dec-24	HASAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	11:48	12:05	00:17	MAIN SUPPLY FAILURE
5055	24-Dec-24	HASAN	66	TRANSFORMER	HV1	SALGAME_66	12:45	13:45	01:00	LINE CLEAR AVAIED
5056	24-Dec-24	HASAN	66	TRANSFORMER	HV1	SINGAPURA_66	10:02	15:40	05:38	LINE CLEAR AVAIED
5057	24-Dec-24	HASAN	66	TRANSFORMER	HV2	HALLYMYSORE_66	11:49	12:11	00:22	MAIN SUPPLY FAILURE
5058	24-Dec-24	HASAN	66	TRANSFORMER	HV2	HNPUA_66	11:45	12:00	00:15	MAIN SUPPLY FAILURE
5059	24-Dec-24	HASAN	220	TRANSFORMER	HV2	HOLENARASIPURA_220	11:47	12:02	00:15	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5060	24-Dec-24	HASAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	11:48	12:05	00:17	MAIN SUPPLY FAILURE
5061	24-Dec-24	HASAN	66	TRANSFORMER	HV2	SALGAME_66	11:00	12:43	01:43	LINE CLEAR AVAILED
5062	24-Dec-24	HASAN	66	TRANSFORMER	HV2	SHANTHIGRAMA_66	18:25	20:05	01:40	LINE CLEAR AVAILED
5063	24-Dec-24	HASAN	66	TRANSFORMER	HV2	SINGAPURA_66	10:02	15:46	05:44	LINE CLEAR AVAILED
5064	24-Dec-24	HASAN	110	TRANSFORMER	HV2	JADE_110	10:50	16:00	05:10	LINE CLEAR AVAILED
5065	24-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
5066	24-Dec-24	HASAN	66	TRANSFORMER	Lv1	HOLENARASIPURA_220	07:28	07:37	00:09	TRIPPED ON FAULT
5067	24-Dec-24	HASAN	66	TRANSFORMER	Lv2	HOLENARASIPURA_220	11:47	11:57	00:10	TRIPPED ON FAULT
5068	24-Dec-24	HASAN	110	LINE	MADHUVANA	HIRIYADKA_110	09:02	16:37	07:35	LINE CLEAR AVAILED
5069	24-Dec-24	HASAN	110	LINE	MADHUV-BRK_HRD	MADHUVANA_110	09:02	16:36	07:34	LINE CLEAR AVAILED
5070	24-Dec-24	HASAN	110	LINE	MADHUV-BRK_MDV	MADHUVANA_110	09:02	16:36	07:34	LINE CLEAR AVAILED
5071	24-Dec-24	HASAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:45	12:00	00:15	MAIN SUPPLY FAILURE
5072	24-Dec-24	HASAN	110	LINE	PUTTUR-SULIA	PUTTUR_220	10:09	14:12	04:03	LINE CLEAR AVAILED
5073	24-Dec-24	HASAN	66	LINE	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	11:48	12:06	00:18	MAIN SUPPLY FAILURE
5074	24-Dec-24	HASAN	66	LINE	SALAGAM-HIREMANGLUR	SALGAME_66	13:35	13:40	00:05	LINE CLEAR AVAILED
5075	24-Dec-24	HASAN	66	LINE	SALAGAM-UDURKOPPLU	SALGAME_66	13:35	13:40	00:05	LINE CLEAR AVAILED
5076	24-Dec-24	HASAN	110	LINE	SORABA-SHR220	SORABA_110	12:14	16:15	04:01	LINE CLEAR AVAILED
5077	24-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5078	24-Dec-24	MYSORE	66	LINE	CHIDRAVALLI -TUMBLA-MEGALAPURA	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66	06:33	06:57	00:24	TRIPPED ON FAULT
5079	24-Dec-24	MYSORE	66	LINE	DR PETE-CR NAGARA 2	NO STATIONS EFFECTED	06:47	06:54	00:06	TRIPPED ON FAULT
5080	24-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5081	24-Dec-24	MYSORE	66	LINE	HOOTAGALLI-HAMPAPURA	KAGGEREHAMPAPURA_66	01:59	02:09	00:10	TRIPPED ON FAULT
5082	24-Dec-24	MYSORE	66	LINE	HOOTAGALLI-HAMPAPURA	KAGGEREHAMPAPURA_66	10:10	14:42	04:32	LINE CLEAR AVAILED
5083	24-Dec-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_220	18:03	18:17	00:14	LINE CLEAR AVAILED
5084	24-Dec-24	MYSORE	66	TRANSFORMER	HV1	MANDAGERE_66	11:45	12:00	00:15	MAIN SUPPLY FAILURE
5085	24-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5086	24-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHEMARAHALLI_66	11:48	15:28	03:39	LINE CLEAR AVAILED
5087	24-Dec-24	MYSORE	66	TRANSFORMER	HV2	SANTHESARAGUR_66	01:35	02:20	00:45	TRIPPED ON FAULT
5088	24-Dec-24	MYSORE	66	TRANSFORMER	HV3	DODDABYADARAHALLI_66	15:58	16:15	00:17	LINE CLEAR AVAILED
5089	24-Dec-24	MYSORE	66	TRANSFORMER	HV3	KRPETE_66	11:22	11:32	00:10	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5090	24-Dec-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	DKMAIDANA_66	18:27	18:35	00:08	TRIPPED ON FAULT
5091	24-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5092	24-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5093	24-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5094	24-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
5095	24-Dec-24	MYSORE	220	LINE	KR PETE 220-YACHENAHALLI	NO STATIONS EFFECTED	11:43	14:35	02:51	LINE CLEAR AVAILED
5096	24-Dec-24	MYSORE	66	LINE	KUNTHUR-BASL IPP	NO STATIONS EFFECTED	06:50	06:55	00:05	TRIPPED ON FAULT
5097	24-Dec-24	MYSORE	66	LINE	MUGUR-THAYUR	TNARASIPURA_66THAYUR_66	18:25	18:30	00:05	TRIPPED ON FAULT
5098	24-Dec-24	MYSORE	66	LINE	PERIYAPATNA-HANGUD	NO STATIONS EFFECTED	23:59 (23/12/2024)	0:05 (24/12/2024)	00:05	TRIPPED ON FAULT
5099	24-Dec-24	MYSORE	66	LINE	SANTHEMARALLI-KUNTHUR	NO STATIONS EFFECTED	06:47	06:55	00:08	TRIPPED ON FAULT
5100	24-Dec-24	MYSORE	66	LINE	SANTHESARGUR-KALSON	NO STATIONS EFFECTED	01:29	01:50	00:20	TRIPPED ON FAULT
5101	24-Dec-24	MYSORE	66	LINE	SANTHESARGUR-KALSON	NO STATIONS EFFECTED	03:10	03:18	00:08	TRIPPED ON FAULT
5102	24-Dec-24	MYSORE	66	LINE	SANTHESARGUR-KALSON	NO STATIONS EFFECTED	03:50	13:10	09:20	TRIPPED ON FAULT
5103	24-Dec-24	MYSORE	66	LINE	SFC SIVA-5MW	NO STATIONS EFFECTED	18:16 (23/12/2024)	6:30 (24/12/2024)	12:14	TRIPPED ON FAULT
5104	24-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	18:10	18:15	0:05	TRIPPED ON FAULT
5105	24-Dec-24	TUMKUR	66	LINE	BHARAMASAGARA-PANDARAHALLI-1_66KV	BHARAMASAGARA_66, VIJAPURA, SIRIGERE	10:30	16:00	5:30	LINE CLEAR AVAILED
5106	24-Dec-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	11:24	13:45	2:21	LINE CLEAR AVAILED
5107	24-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS _MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	11:24	13:44	2:20	LINE CLEAR AVAILED
5108	24-Dec-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU_66KV	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	11:14	12:09	0:55	TRIPPED ON FAULT
5109	24-Dec-24	TUMKUR	66	LINE	HANAGAL-NAGASAMUDRA_66	NAGASAMUDRA_66	10:40	10:45	0:05	TRIPPED ON FAULT
5110	24-Dec-24	TUMKUR	66	LINE	HANAGAL- THALLAK_66	THALLAK_66	10:40	10:45	0:05	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5111	24-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV-THALLAK_220KV	HIRIYUR_220KV	15:10	16:11	1:01	LINE CLEAR AVAILED
5112	24-Dec-24	TUMKUR	66	LINE	HOSADURGA_220KV-BAGUR_66KV	HOSADURGA_220KV	7:55	8:10	0:15	TRIPPED ON FAULT
5113	24-Dec-24	TUMKUR	66	LINE	HOSADURGA_220KV-BAGUR_66KV	HOSADURGA_220KV	12:00	12:25	0:25	TRIPPED ON FAULT
5114	24-Dec-24	TUMKUR	66	LINE	HOSADURGA_220KV-HALURAMESHWARA_66KV	HALURAMESHWARA_66KV	16:55	17:05	0:10	TRIPPED ON FAULT
5115	24-Dec-24	TUMKUR	66	LINE	HOSADURGA66-RAMAGIRI	RAMAGIRI_66	12:00	12:10	0:10	TRIPPED ON FAULT
5116	24-Dec-24	TUMKUR	66	LINE	HOSADURGA66-RAMAGIRI	RAMAGIRI_66	12:15	12:25	0:10	TRIPPED ON FAULT
5117	24-Dec-24	TUMKUR	66	LINE	KB CROSS 220kv-HANDANKERE_110	HANDANKERE_110	11:01	12:52	1:51	LINE CLEAR AVAILED
5118	24-Dec-24	TUMKUR	66	LINE	RAMPURA 66-HANGAL	NAGASAMUDRA_66, RAMPURA_66	10:40	10:45	0:05	TRIPPED ON FAULT
5119	24-Dec-24	TUMKUR	66	LINE	THALLAK 220kv -HIRIYUR	SANEKERE_66, THALLAKK_220	15:11	16:16	1:05	LINE CLEAR AVAILED
5120	24-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	HINDUSGHATTA_66	15:55	16:55	1:00	LINE CLEAR AVAILED
5121	24-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	HINDUSGHATTA_66	15:30	16:55	1:25	LINE CLEAR AVAILED
5122	24-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5 MVA	SASALUHALLA_66	18:25 (24.12.2024)	14:00 (25.12.2024)	20:25	LINE CLEAR AVAILED
5123	24-Dec-24	TUMKUR	66	TRANSFORMER	TR2 8MVA	HANGAL_66	10:40	10:45	0:05	TRIPPED ON FAULT
5124	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5125	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NAVALAGI_110	10:02	13:56	3:54	LINE CLEAR AVAILED
5126	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	SANKESHWAR_110	10:28	10:47	0:19	TRIPPED ON FAULT
5127	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	RATTIHALLI_110	12:29	12:38	0:09	TRIPPED ON FAULT
5128	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	BILAGI_110	11:35	12:19	0:44	LINE CLEAR AVAILED
5129	25-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2 (20MVA)	BILAGI_110	10:14	12:17	2:03	LINE CLEAR AVAILED
5130	25-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5131	25-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	ATHANI_220	05:50	06:18	0:28	TRIPPED ON FAULT
5132	25-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5133	25-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5134	25-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5135	25-Dec-24	BAGALKOTE	110	LINE	ANNIGERI-GADAG	ANNIGERI_110	11:06	13:53	2:47	LINE CLEAR AVAILED
5136	25-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5137	25-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5138	25-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5139	25-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5140	25-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
5141	25-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5142	25-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5143	25-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5144	25-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5145	25-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5146	25-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5147	25-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5148	25-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:06	10:11	00:05	LINE CLEAR AVAILED
5149	25-Dec-24	BANGALORE	66	LINE	66KV D PALYA - GUDIBANDE - MANDIKAL	GUDIBANDE	08:30	12:15	03:45	LINE CLEAR AVAILED
5150	25-Dec-24	BANGALORE	66	LINE	66KV D PALYA - GUDIBANDE - MANDIKAL	GUDIBANDE	12:15	13:00	00:45	LINE CLEAR AVAILED
5151	25-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	08:20	08:40	00:20	TRIPPED ON FAULT
5152	25-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5153	25-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5154	25-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI(HV1 & HV3)	16:09	16:16	00:07	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5155	25-Dec-24	BANGALORE	66	LINE	66KV ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	10:05	15:00	04:55	LINE CLEAR AVAILED
5156	25-Dec-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJUPURA 220 _DG4	GRINDWELL NORTON(EHT) MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	11:37	12:09	00:32	LINE CLEAR AVAILED
5157	25-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	SOMAYAJANAHALLI	18:01	18:06	00:05	LINE CLEAR AVAILED
5158	25-Dec-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - SOMAYAJANAHALLI	MANDIKAL	19:47	20:14	00:27	TRIPPED ON FAULT
5159	25-Dec-24	BANGALORE	66	LINE	66KV MANDIKAL - PERESANDRA	HONDA LTD(EHT)	12:20	12:25	00:05	LINE CLEAR AVAILED
5160	25-Dec-24	BANGALORE	66	LINE	66KV NARASAPURA - HONDA LTD (EHT)	NO STATION AFFECTED	09:30	19:50	10:20	LINE CLEAR AVAILED
5161	25-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	NO STATION AFFECTED	10:03	15:02	04:59	LINE CLEAR AVAILED
5162	25-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5163	25-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI) _DG4	NO STATION AFFECTED	11:45	12:05	00:20	LINE CLEAR AVAILED
5164	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	16:09	16:16	00:07	MAIN SUPPLY FAILURE
5165	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	ISRO LAYOUT	14:05	14:20	00:15	TRIPPED ON FAULT
5166	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAVADI	12:04	12:14	00:10	TRIPPED ON FAULT
5167	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	NARASAPURA	08:00	08:40	00:40	LINE CLEAR AVAILED
5168	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TK HALLI 220	15:43	15:55	00:12	TRIPPED ON FAULT
5169	25-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TUBAGERE	17:01	17:07	00:06	TRIPPED ON FAULT
5170	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	15:55	16:05	00:10	TRIPPED ON FAULT
5171	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	04:10	04:30	00:20	TRIPPED ON FAULT
5172	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	04:30	16:25	11:55	LINE CLEAR AVAILED
5173	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KATTIGENAHALLI	12:01	18:18	06:17	LINE CLEAR AVAILED
5174	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KIADB AEROSPACE 220	11:05	11:40	00:35	TRIPPED ON FAULT
5175	25-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SUBRAMANYAPURA 220	10:50	12:10	01:20	LINE CLEAR AVAILED
5176	25-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAVAREKERE	13:20	13:50	00:30	LINE CLEAR AVAILED
5177	25-Dec-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	16:09	16:16	00:07	MAIN SUPPLY FAILURE
5178	25-Dec-24	GULBARGA	66	LINE	KOTTUR-BADALADUKU	KOTTUR_66	20:40	21:00	00:20	TRIPPED ON FAULT
5179	25-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
5180	25-Dec-24	GULBARGA	110	LINE	RAICHUR-GABBUR	GABBUR_110,GUGAL_110	20:16	20:22	00:06	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5181	25-Dec-24	HASAN	110	LINE	GURUVA-SLVPWR	GURUVAYANAKERE_66	13:33	17:30	03:57	LINE CLEAR AVAILED
5182	25-Dec-24	HASAN	66	TRANSFORMER	HV1	YESLUR_66	16:30	16:55	00:25	TRIPPED ON FAULT
5183	25-Dec-24	HASAN	66	TRANSFORMER	HV1	YESLUR_66	15:30	15:45	00:15	TRIPPED ON FAULT
5184	25-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
5185	25-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5186	25-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5187	25-Dec-24	MYSORE	66	LINE	HOOTAGALLI-BARC2	NO STATIONS EFFECTED	13:21	13:43	00:22	TRIPPED ON FAULT
5188	25-Dec-24	MYSORE	66	LINE	HUNSUR 220-KAMALAPURA	NO STATIONS EFFECTED	10:42	11:08	00:26	TRIPPED ON FAULT
5189	25-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5190	25-Dec-24	MYSORE	66	LINE	KADAKOLA-GOLUR	NO STATIONS EFFECTED	11:00	12:41	01:41	LINE CLEAR AVAILED
5191	25-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5192	25-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5193	25-Dec-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	14:47	14:52	00:05	TRIPPED ON FAULT
5194	25-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	04:16	04:29	00:13	TRIPPED ON FAULT
5195	25-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 2	AKKIHEBBAL_66KIKKERI_66 6KRPET_66	04:16	04:28	00:12	TRIPPED ON FAULT
5196	25-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5197	25-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
5198	25-Dec-24	MYSORE	66	LINE	MAMBALLI -YALANDUR	YELANDUR_66	13:24	13:29	00:05	TRIPPED ON FAULT
5199	25-Dec-24	MYSORE	66	LINE	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66DODDA BYADARAHALLI_66BANAN GADI_66	05:43	05:56	00:13	TRIPPED ON FAULT
5200	25-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:07	10:19	0:12	TRIPPED ON FAULT
5201	25-Dec-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	12:29	12:45	0:16	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5202	25-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	19:41	21:02	1:21	LINE CLEAR AVAILED
5203	25-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS-DAVANGERE	DAVANAGERE_66	19:22	19:41	0:19	TRIPPED ON FAULT
5204	25-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV-THALLAK 220KV	HIRIYUR_220KV	3:43	6:35	2:52	TRIPPED ON FAULT
5205	25-Dec-24	TUMKUR	66	LINE	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:22	11:32	0:10	TRIPPED ON FAULT
5206	25-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BHARAMASAGARA_66	22:15	22:25	0:10	TRIPPED ON FAULT
5207	25-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	BILCHODU_66	23:15	23:20	0:05	TRIPPED ON FAULT
5208	25-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	HANGAL_66	11:50	12:05	0:15	LINE CLEAR AVAILED
5209	25-Dec-24	TUMKUR	66	TRANSFORMER	TR1 12.5MVA	SAVLANGA_66	13:30	14:00	0:30	TRIPPED ON FAULT
5210	25-Dec-24	TUMKUR	66	TRANSFORMER	TR2 8 MVA	BALENAHALLI_66	18:12	18:18	0:06	TRIPPED ON FAULT
5211	25-Dec-24	TUMKUR	66	LINE	YARAGUNTA-DAVANAGERESRS	YARAGUNTA_66	20:17	21:02	0:45	LINE CLEAR AVAILED
5212	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	THORVI_110	10:10	13:47	3:37	LINE CLEAR AVAILED
5213	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	05:50	06:04	0:14	TRIPPED ON FAULT
5214	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	09:20	09:29	0:09	TRIPPED ON FAULT
5215	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	RATTIHALLI_110	15:22	16:39	1:17	LINE CLEAR AVAILED
5216	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TUMMINAKATTI_110	10:01	14:38	#VALUE!	LINE CLEAR AVAILED
5217	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5218	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TUMMINAKATTI_110	10:02	14:32	4:15	LINE CLEAR AVAILED
5219	26-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA-HV2)	VADAGOAN_110	14:05	18:20	4:15	TRIPPED ON FAULT
5220	26-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	ATHANI_220	16:45	17:04	0:19	TRIPPED ON FAULT
5221	26-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5222	26-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2, LV2	CHIKKODI_220	14:07	15:45	1:38	LINE CLEAR AVAILED
5223	26-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5224	26-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5225	26-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5226	26-Dec-24	BAGALKOTE	110	LINE	ATHANI220- AIGALI2	ATHANI_220	16:45	17:16	0:31	TRIPPED ON FAULT
5227	26-Dec-24	BAGALKOTE	110	LINE	ATHANI220- ATHANI2	ATHANI_220	16:45	17:01	0:16	TRIPPED ON FAULT
5228	26-Dec-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	16:45	17:26	0:41	TRIPPED ON FAULT
5229	26-Dec-24	BAGALKOTE	110	LINE	ATHANI220- GHATNATTI	ATHANI_220	16:45	17:13	0:28	TRIPPED ON FAULT
5230	26-Dec-24	BAGALKOTE	220	LINE	DHONI- GADAG1	DHONI_400	10:52	13:06	2:14	LINE CLEAR AVAILED
5231	26-Dec-24	BAGALKOTE	220	LINE	DHONI- GADAG2	DHONI_400	13:09	17:11	4:02	LINE CLEAR AVAILED
5232	26-Dec-24	BAGALKOTE	220	LINE	GADAG-LINGAPUR1(DHONI1)	GADAG_220	10:52	13:03	2:11	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5233	26-Dec-24	BAGALKOTE	220	LINE	GADAG-LINGAPUR2(DHONI2)	GADAG_220	13:09	17:11	4:02	LINE CLEAR AVAILED
5234	26-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5235	26-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5236	26-Dec-24	BAGALKOTE	110	LINE	GARAG-F1 NARENDRA220	GARAG_110	11:12	15:03	3:51	LINE CLEAR AVAILED
5237	26-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5238	26-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5239	26-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
5240	26-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5241	26-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN1(RAIBAG1)	MUGALKHOD_220	10:36	12:55	2:19	LINE CLEAR AVAILED
5242	26-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN2(RAIBAG)2	MUGALKHOD_220	10:36	12:56	2:20	LINE CLEAR AVAILED
5243	26-Dec-24	BAGALKOTE	110	LINE	MUKARTIHAL-SPV (KODANGAL SOLAR)	MUKARTIHAL_110	21:00	23:40	2:40	LINE CLEAR AVAILED
5244	26-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5245	26-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5246	26-Dec-24	BAGALKOTE	110	LINE	RAMANAKOPPA-SVANUR(DHUNDASHI)	RAMANAKOPPA_110	05:15	08:34	3:19	TRIPPED ON FAULT
5247	26-Dec-24	BAGALKOTE	110	LINE	RAMANAKOPPA-SVANUR(DHUNDASHI)	RAMANAKOPPA_110	08:34	08:35	0:01	TRIPPED ON FAULT
5248	26-Dec-24	BAGALKOTE	110	LINE	RAMANAKOPPA-SVANUR(DHUNDASHI)	RAMANAKOPPA_110	08:35	14:05	5:30	TRIPPED ON FAULT
5249	26-Dec-24	BAGALKOTE	110	LINE	RANEBENNUR220-RATTIHALLI(TUMMINKATTI)	RANEBENNUR_220	13:31	14:04	0:33	LINE CLEAR AVAILED
5250	26-Dec-24	BAGALKOTE	110	LINE	RATTIHALLI-RANEBENNUR(TUMMINAKATTI)	RATTIHALLI_110	13:40	14:10	0:30	LINE CLEAR AVAILED
5251	26-Dec-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	10:33	17:27	6:54	LINE CLEAR AVAILED
5252	26-Dec-24	BAGALKOTE	110	LINE	SADALAGA-VPPL	SADALAGA_110	14:05	14:08	0:03	LINE CLEAR AVAILED
5253	26-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN220-LN1(DUNDASI)	SHIGGOAN_220	12:46	13:42	0:56	LINE CLEAR AVAILED
5254	26-Dec-24	BAGALKOTE	110	LINE	THORVI-BHUTNAL	THORVI_110	10:10	13:50	3:40	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5255	26-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL(TAKKALAKI)	TIKOTA_110	9:58 (26.12.2024)			LINE CLEAR AVAILED
5256	26-Dec-24	BAGALKOTE	110	LINE	TUMMINAKATTI-F1(RATTIHALLI)	TUMMINAKATTI_110	13:33	14:06	0:01	LINE CLEAR AVAILED
5257	26-Dec-24	BAGALKOTE	110	LINE	TUMMINAKATTI-F2(RANEHEMMUR)	TUMMINAKATTI_110	13:33	14:10	#VALUE!	LINE CLEAR AVAILED
5258	26-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5259	26-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5260	26-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5261	26-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5262	26-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE	14:30	14:34	00:04	LINE CLEAR AVAILED
5263	26-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	NO STATION AFFECTED	14:35	15:07	00:32	LINE CLEAR AVAILED
5264	26-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	WELCAST	14:22	14:25	00:03	LINE CLEAR AVAILED
5265	26-Dec-24	BANGALORE	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	ATTUR YELAHANKA	14:35	14:51	00:16	LINE CLEAR AVAILED
5266	26-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	17:51	18:01	00:10	TRIPPED ON FAULT
5267	26-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	10:01	10:05	00:04	LINE CLEAR AVAILED
5268	26-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	07:30	07:40	00:10	TRIPPED ON FAULT
5269	26-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURVANKARA PALM BEACH	12:33	12:47	00:14	LINE CLEAR AVAILED
5270	26-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	12:50	13:41	00:51	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5271	26-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	12:55	13:41	00:46	LINE CLEAR AVAILED
5272	26-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL)_DG3	NO STATION AFFECTED	23:58:00	14:30	14:32	LINE CLEAR AVAILED
5273	26-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA	MARALAWADI, GODUR, CHATRA, MANIYAMBAL	02:18	09:48	07:30	TRIPPED ON FAULT
5274	26-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI	SHIVANAHALLI, CHIKKENAHALLI, ALLIMARADANAHALLI	14:17	14:25	00:08	TRIPPED ON FAULT
5275	26-Dec-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - URAGAHALLI	URAGAHALLI	10:10	15:15	05:05	LINE CLEAR AVAILED
5276	26-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	16:58	21:00	04:02	TRIPPED ON FAULT
5277	26-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	17:37	17:42	00:05	LINE CLEAR AVAILED
5278	26-Dec-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLI (HOSKOTE -1)	MALUR IND AREA, BEST STEEL(EHT), ADL(EHT)	12:30	13:15	00:45	LINE CLEAR AVAILED
5279	26-Dec-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY _DG3	SHOBHA CITY	12:40	13:40	01:00	LINE CLEAR AVAILED
5280	26-Dec-24	BANGALORE	66	LINE	66KV MASTHENAHALLI - TALAGAWARA	TALAGAWARA, CHEEMANGALA	01:04	01:21	00:17	TRIPPED ON FAULT
5281	26-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELCAST	15:28	15:31	00:03	LINE CLEAR AVAILED
5282	26-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5283	26-Dec-24	BANGALORE	66	LINE	66KV TALGAWARA - Y HUNESANAHALLI	Y HUNASENAHALLI HALAGURU,	09:15	09:30	00:15	TRIPPED ON FAULT
5284	26-Dec-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALLI 220	HONNIGANAHALLI, ACCHALU	15:42	16:05	00:23	TRIPPED ON FAULT
5285	26-Dec-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURVANKARA PALM BEACH	14:22	14:24	00:02	LINE CLEAR AVAILED
5286	26-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	GLOBAL TECH PARK	08:02	08:06	00:04	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5287	26-Dec-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	08:04	08:09	00:05	LINE CLEAR AVAILED
5288	26-Dec-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	ABBIGERE	15:22	15:26	00:04	LINE CLEAR AVAILED
5289	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHELUR	17:30	17:40	00:10	LINE CLEAR AVAILED
5290	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	14:01	14:06	00:05	TRIPPED ON FAULT
5291	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 66	15:14	15:22	00:08	LINE CLEAR AVAILED
5292	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	14:25	15:25	01:00	LINE CLEAR AVAILED
5293	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	20:20	21:20	01:00	TRIPPED ON FAULT
5294	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	05:10	05:30	00:20	LINE CLEAR AVAILED
5295	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	13:34	14:14	00:40	LINE CLEAR AVAILED
5296	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	08:30	09:00	00:30	LINE CLEAR AVAILED
5297	26-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	11:15	11:20	00:05	LINE CLEAR AVAILED
5298	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	18:27	18:38	00:11	TRIPPED ON FAULT
5299	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	13:05	13:10	00:05	TRIPPED ON FAULT
5300	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	13:10	13:30	00:20	LINE CLEAR AVAILED
5301	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ISKCON	10:50	10:55	00:05	LINE CLEAR AVAILED
5302	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KUNDANA	15:25	15:35	00:10	LINE CLEAR AVAILED
5303	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SRINIVASAPURA 66	14:06	15:38	01:32	TRIPPED ON FAULT
5304	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAYALUR	11:45	12:05	00:20	LINE CLEAR AVAILED
5305	26-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	08:05	08:10	00:05	LINE CLEAR AVAILED
5306	26-Dec-24	BANGALORE	66	TRANSFORMER	HV3	EMBASSY TECH PARK	11:35	11:40	00:05	LINE CLEAR AVAILED
5307	26-Dec-24	BANGALORE	220	TRANSFORMER	HV3	YELAHANKA 220	10:57	13:19	02:22	LINE CLEAR AVAILED
5308	26-Dec-24	BANGALORE	66	TRANSFORMER	HV4	EMBASSY TECH PARK	11:54	12:05	00:11	TRIPPED ON FAULT
5309	26-Dec-24	GULBARGA	66	LINE	BADALADUKU-ACME IPP	BADALADUKU_220	11:30	17:10	05:40	LINE CLEAR AVAILED
5310	26-Dec-24	GULBARGA	66	LINE	BADALADUKU-BANAVIKAL	BANAVIKAL_66	10:05	18:15	08:10	LINE CLEAR AVAILED
5311	26-Dec-24	GULBARGA	66	LINE	BADALADUKU-GUDEKOTE	GUDEKOTE_66,CJ HALLI_66,HOSAHALLI_66, HUDEM_66	10:00	17:45	07:45	LINE CLEAR AVAILED
5312	26-Dec-24	GULBARGA	220	LINE	BADALADUKU- HEREMALLAYANHOLE 1	BADALADUKU_220	12:30	15:25	02:55	LINE CLEAR AVAILED
5313	26-Dec-24	GULBARGA	220	LINE	BADALADUKU- HEREMALLAYANHOLE 1	BADALADUKU_220	15:40	19:50	04:10	LINE CLEAR AVAILED
5314	26-Dec-24	GULBARGA	66	LINE	BADALADUKU-KOTTUR	KOTTUR_66	09:35	18:55	09:20	LINE CLEAR AVAILED
5315	26-Dec-24	GULBARGA	66	LINE	BADALADUKU-UJJINI	UJJINI_66,SOKKE_66,NIMB ALAGERI_66 CJ	09:50	18:20	08:30	LINE CLEAR AVAILED
5316	26-Dec-24	GULBARGA	66	LINE	CJ HALLI-KUDLIGI	HALLI_66,HOSAHALLI_66, HUDEM_66	09:55	18:10	08:15	LINE CLEAR AVAILED
5317	26-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HIREGONNAGAR_110	08:05	11:05	03:00	LINE CLEAR AVAILED
5318	26-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HUDEM_66	18:10	18:30	00:20	LINE CLEAR AVAILED
5319	26-Dec-24	GULBARGA	66	TRANSFORMER	HV1 &2	ITTAGI_220	10:20	16:25	06:05	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5320	26-Dec-24	GULBARGA	110	LINE	KIADB-ALIPUR	KIADB KUDITINI_110,KUDITINI_110,SATHAVAHANA_IPP,TORANGALU_110,KURUGOD_110,METRI_110	19:44	19:55	00:11	TRIPPED ON FAULT
5321	26-Dec-24	GULBARGA	110	LINE	LINGASUGUR-CHAYADEVI_IPP	LINGASUGUR_220	10:28	12:00	01:32	LINE CLEAR AVAILED
5322	26-Dec-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	11:34	12:55	01:21	LINE CLEAR AVAILED
5323	26-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANAHATTI	CHILKANAHATTI_66	21:49	21:54	00:05	TRIPPED ON FAULT
5324	26-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANAHATTI	CHILKANAHATTI_66	22:15(26.12.2024)			TRIPPED ON FAULT
5325	26-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
5326	26-Dec-24	GULBARGA	110	LINE	RAICHUR-GUGAL	GUGAL_110,GABBUR_110	13:05	13:20	00:15	TRIPPED ON FAULT
5327	26-Dec-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	21:27	21:34	00:07	TRIPPED ON FAULT
5328	26-Dec-24	GULBARGA	110	LINE	SHAHAPUR-MKOLLUR	MKOLLUR_110	11:15	13:40	02:25	LINE CLEAR AVAILED
5329	26-Dec-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	DEODURGA_110	11:16	13:40	02:24	LINE CLEAR AVAILED
5330	26-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDDAPUR	MUDDAPUR_110, MASKI_110	13:26	13:36	00:10	TRIPPED ON FAULT
5331	26-Dec-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	23:25	23:40	00:15	TRIPPED ON FAULT
5332	26-Dec-24	GULBARGA	110	LINE	SIRIGUPPA-DHADESUGUR	SIRIGUPPA_110,TEKKALCO TE_110	10:01	10:33	00:32	LINE CLEAR AVAILED
5333	26-Dec-24	GULBARGA	110	LINE	SIRIGUPPA-KURUGOD	SIRIGUPPA_110,TEKKALCO TE_110	16:00	16:15	00:15	LINE CLEAR AVAILED
5334	26-Dec-24	HASAN	110	LINE	AJAMPU-SHIVNI	AJJAMPURA_110	10:30	12:41	02:11	LINE CLEAR AVAILED
5335	26-Dec-24	HASAN	66	LINE	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	14:35	15:55	01:20	MAIN SUPPLY FAILURE
5336	26-Dec-24	HASAN	220	LINE	GOPALAP-BASTIPURA	GOPALPURA_220	11:15	13:05	01:50	LINE CLEAR AVAILED
5337	26-Dec-24	HASAN	66	LINE	HAGARE-HASSAN	HAGARE_66	12:00	12:25	00:25	MAIN SUPPLY FAILURE
5338	26-Dec-24	HASAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	14:35	15:04	00:29	LINE CLEAR AVAILED
5339	26-Dec-24	HASAN	66	LINE	HASSN22-BELUR	HASSAN_220	14:35	15:45	01:10	LINE CLEAR AVAILED
5340	26-Dec-24	HASAN	66	LINE	HASSN22-CHIKAMAGLUR2	HASSAN_220	14:35	15:49	01:14	LINE CLEAR AVAILED
5341	26-Dec-24	HASAN	66	LINE	HASSN22-HN PURA	HASSAN_220	14:35	16:02	01:27	LINE CLEAR AVAILED
5342	26-Dec-24	HASAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	14:35	15:48	01:13	LINE CLEAR AVAILED
5343	26-Dec-24	HASAN	220	TRANSFORMER	HV1	MSEZ_220	10:06	16:16	06:10	LINE CLEAR AVAILED
5344	26-Dec-24	HASAN	110	TRANSFORMER	HV1	NANDIKUR_110	10:46	10:52	00:06	TRIPPED ON FAULT
5345	26-Dec-24	HASAN	66	TRANSFORMER	HV1	SALGAME_66	09:06	15:21	06:15	LINE CLEAR AVAILED
5346	26-Dec-24	HASAN	66	TRANSFORMER	HV2	BAGUR_66	19:35	20:51	01:16	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5347	26-Dec-24	HASAN	66	TRANSFORMER	HV2	BASAVAGHATTA_66	14:37	16:13	01:36	MAIN SUPPLY FAILURE
5348	26-Dec-24	HASAN	110	TRANSFORMER	HV2	JOG_110	19:00	20:10	01:10	LINE CLEAR AVAILED
5349	26-Dec-24	HASAN	66	TRANSFORMER	HV2	SHANTHIGRAMA_66	11:39	12:54	01:15	LINE CLEAR AVAILED
5350	26-Dec-24	HASAN	110	TRANSFORMER	HV2	JADE_110	19:05	20:20	01:15	TRIPPED ON FAULT
5351	26-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
5352	26-Dec-24	HASAN	110	LINE	KADUR-AJJAMPURA	KADUR_220	13:00	13:49	00:49	TRIPPED ON FAULT
5353	26-Dec-24	HASAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	12:30	18:05	05:35	LINE CLEAR AVAILED
5354	26-Dec-24	HASAN	220	LINE	KEMAR-Kavoor1	KEMAR_220	14:50	15:52	01:02	LINE CLEAR AVAILED
5355	26-Dec-24	HASAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	08:30	18:02	09:32	LINE CLEAR AVAILED
5356	26-Dec-24	HASAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	10:02	12:40	02:38	LINE CLEAR AVAILED
5357	26-Dec-24	HASAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	12:18	18:04	05:46	TRIPPED ON FAULT
5358	26-Dec-24	HASAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	12:19	12:48	00:29	MAIN SUPPLY FAILURE
5359	26-Dec-24	HASAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	12:19	12:44	00:25	MAIN SUPPLY FAILURE
5360	26-Dec-24	HASAN	110	TRANSFORMER	LV1	MSEZ_220	10:06	16:16	06:10	LINE CLEAR AVAILED
5361	26-Dec-24	HASAN	66	TRANSFORMER	LV2	HASSAN_220	14:35	15:45	01:10	LINE CLEAR AVAILED
5362	26-Dec-24	HASAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	14:19(26.12.2024)			TRIPPED ON FAULT
5363	26-Dec-24	HASAN	220	LINE	MRSSHM-ANTRSNH	MRSMG_220	11:13	12:53	01:40	LINE CLEAR AVAILED
5364	26-Dec-24	HASAN	220	LINE	MRSSHM-HSN4001	MRSMG_220	10:30	15:10	04:40	LINE CLEAR AVAILED
5365	26-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMG_220	10:47(26.12.2021)			LINE CLEAR AVAILED
5366	26-Dec-24	HASAN	110	LINE	MSEZ-GSS31	MSEZ_220	10:39	20:35	09:56	LINE CLEAR AVAILED
5367	26-Dec-24	HASAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	14:51	15:52	01:01	LINE CLEAR AVAILED
5368	26-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	08:30	18:02	09:32	LINE CLEAR AVAILED
5369	26-Dec-24	HASAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	12:18	18:04	05:46	TRIPPED ON FAULT
5370	26-Dec-24	HASAN	110	LINE	PUTTUR-PUTUR 1	PUTTUR_220	12:21	12:45	00:24	LINE CLEAR AVAILED
5371	26-Dec-24	HASAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	12:21	12:42	00:21	LINE CLEAR AVAILED
5372	26-Dec-24	HASAN	110	LINE	PUTTUR-SLTR	PUTTUR_220	12:21	12:42	00:21	LINE CLEAR AVAILED
5373	26-Dec-24	HASAN	110	LINE	PUTTUR-SULIA	PUTTUR_220	12:21	12:42	00:21	LINE CLEAR AVAILED
5374	26-Dec-24	HASAN	66	LINE	SALAGAM-HIREMANGLUR	SALGAME_66	15:05	15:20	00:15	LINE CLEAR AVAILED
5375	26-Dec-24	HASAN	66	LINE	SALAGAM-UDURKOPPLU	SALGAME_66	13:35	13:40	00:05	LINE CLEAR AVAILED
5376	26-Dec-24	HASAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	12:19	12:44	00:25	MAIN SUPPLY FAILURE
5377	26-Dec-24	HASAN	110	LINE	SHIRAL-SHKARPURA	SHIRALKOPPA_110	11:24	11:42	00:18	TRIPPED ON FAULT
5378	26-Dec-24	HASAN	110	LINE	SHIRAL-SHKARPURA	SHIRALKOPPA_110	13:22	13:56	00:34	TRIPPED ON FAULT
5379	26-Dec-24	HASAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:23	13:51	02:28	LINE CLEAR AVAILED
5380	26-Dec-24	HASAN	66	LINE	UDDURKO-SUZLON	UDDURKOPLU_66	15:20	15:45	00:25	LINE CLEAR AVAILED
5381	26-Dec-24	HASAN	66	LINE	UDDURKO-UDDUR	UDDURKOPLU_66	15:10	15:55	00:45	LINE CLEAR AVAILED
5382	26-Dec-24	HASAN	110	LINE	VITTAL-PUTR_SLTUR	VITLA_110	12:18	12:43	00:25	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5383	26-Dec-24	MYSORE	66	LINE	B MATTAGERE-SARGUR	NO STATIONS EFFECTED	16:30	17:05	00:35	TRIPPED ON FAULT
5384	26-Dec-24	MYSORE	66	LINE	BEGUR 220-SARGUR	NO STATIONS EFFECTED	11:05	16:20	05:15	LINE CLEAR AVAILED
5385	26-Dec-24	MYSORE	66	LINE	BEGUR 220-SARGUR	YEREHALLIHANDPOST_66 ANTHARSANTHE_66HDKO TE_66CHANDRAVADI_66S ANTHESARAGUR_66HURA _66	16:28	16:34	00:06	TRIPPED ON FAULT
5386	26-Dec-24	MYSORE	66	LINE	BEGUR 220-SARGUR	YEREHALLIHANDPOST_66 ANTHARSANTHE_66HDKO TE_66CHANDRAVADI_66S ANTHESARAGUR_66HURA _66HAMPAPURA(K)_66	06:42	06:49	00:07	TRIPPED ON FAULT
5387	26-Dec-24	MYSORE	66	LINE	BEGUR -B MATTAGERE	B MATKERE_66	10:35	16:25	05:50	LINE CLEAR AVAILED
5388	26-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5389	26-Dec-24	MYSORE	66	LINE	GOLUR-DEVANUR NANJANGUDU	DEVANOORNGUDU_66SU TTUR_66	06:57	06:59	00:02	TRIPPED ON FAULT
5390	26-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5391	26-Dec-24	MYSORE	66	LINE	HEBBANI-VAJMANGALA	THUMBLA_66VYASRAJPUR A_66	19:36	19:45	00:09	TRIPPED ON FAULT
5392	26-Dec-24	MYSORE	66	LINE	HEBBANI-VAJMANGALA	THUMBLA_66VYASRAJPUR A_66	20:13	20:24	00:11	TRIPPED ON FAULT
5393	26-Dec-24	MYSORE	66	LINE	HONGANUR-YALANDUR	NO STATIONS EFFECTED	06:42	06:47	00:05	TRIPPED ON FAULT
5394	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	DODDINADUVADI_66	16:05	17:25	01:20	LINE CLEAR AVAILED
5395	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	15:42	16:04	00:22	MAIN SUPPLY FAILURE
5396	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	18:02	18:05	00:03	TRIPPED ON FAULT
5397	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5398	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	SUTTUR_66	11:32	11:34	00:02	LINE CLEAR AVAILED
5399	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	SUTTUR_66	11:35	12:01	00:26	LINE CLEAR AVAILED
5400	26-Dec-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	10:36	12:28	01:52	LINE CLEAR AVAILED
5401	26-Dec-24	MYSORE	66	TRANSFORMER	HV2	DODDINADUVADI_66	16:00	17:22	01:22	LINE CLEAR AVAILED
5402	26-Dec-24	MYSORE	66	TRANSFORMER	HV2	YETHAMBADI_66	12:20	14:25	02:05	LINE CLEAR AVAILED
5403	26-Dec-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA	YEREHALLIHANDPOST_66 ANTHARSANTHE_66HDKO TE_66HAMPAPURA(K)_66	11:37	11:48	00:11	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5404	26-Dec-24	MYSORE	66	LINE	KADAKOLA -DOORA	SANTHESARAGUR_66HUR A_66DOORA_66HULLAHA LLI_66CHANDRAVADI_66	11:36	11:48	00:11	TRIPPED ON FAULT
5405	26-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5406	26-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5407	26-Dec-24	MYSORE	66	LINE	KOPPA -BESAGARAHALLI	BESAGARAHALLI_66DUND ANAHALLI_66	17:29	17:40	00:11	TRIPPED ON FAULT
5408	26-Dec-24	MYSORE	66	LINE	KR PETE 220- BOOKANAKERE	GANJIGERE_66 SHEELUNERE_66 BOOKANAKERE_66	09:16	09:26	00:10	LINE CLEAR AVAILED
5409	26-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	9:26 (26/12/2024)			LINE CLEAR AVAILED
5410	26-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5411	26-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_6 6	2:49 (3/12/2024)			TRIPPED ON FAULT
5412	26-Dec-24	MYSORE	66	LINE	KR PETE-KIKKERI	NO STATIONS EFFECTED	09:14	18:39	09:25	LINE CLEAR AVAILED
5413	26-Dec-24	MYSORE	66	LINE	MANDAKALLI-KADAKOLA	NO STATIONS EFFECTED	18:18	18:52	00:34	TRIPPED ON FAULT
5414	26-Dec-24	MYSORE	66	LINE	MYSORE SOUTH- KADAKOLA	NO STATIONS EFFECTED	09:32	16:22	06:49	LINE CLEAR AVAILED
5415	26-Dec-24	MYSORE	220	LINE	TUBINKERE-GOPALPURA	NO STATIONS EFFECTED	11:14	13:04	01:50	LINE CLEAR AVAILED
5416	26-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV TURUVANUR, BIDARIKERE, JAGALORU	18:37	18:47	0:10	TRIPPED ON FAULT
5417	26-Dec-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV NALLUR, BASAVAPATNA,TYAVANGI	13:00	13:10	0:10	TRIPPED ON FAULT
5418	26-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1	66KV B.G KERE	2:00	2:15	0:15	TRIPPED ON FAULT
5419	26-Dec-24	TUMKUR	220	LINE	400KV HIREMALLANAHOLE- 220kv KUDLIGI-1	220kv KUDLIGI-1	12:30	15:13	2:43	LINE CLEAR AVAILED
5420	26-Dec-24	TUMKUR	220	LINE	400KV HIREMALLANAHOLE- 220kv KUDLIGI-2	220kv KUDLIGI-1	15:30	19:33	4:03	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5421	26-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR	JAGALUR_66	9:40	18:30	8:50	LINE CLEAR AVAILED
5422	26-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV PALLAGATTE	66KV SOKKE-66KV PALLAGATTE,66KV BILICHODU	22:00	22:05	0:05	LINE CLEAR AVAILED
5423	26-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV PALLAGATTE	66KV SOKKE-66KV PALLAGATTE,66KV BILICHODU	9:40	18:30	8:50	LINE CLEAR AVAILED
5424	26-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	UJJINI_66	9:40	18:30	8:50	LINE CLEAR AVAILED
5425	26-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	13:13	13:32	0:19	TRIPPED ON FAULT
5426	26-Dec-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-SHIMOGA	ANTHRASANAHALLI_220	11:13	NOT YET CHARGED		LINE CLEAR AVAILED
5427	26-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV ANAGODU LINE	66KV ANAGODU , ATTIGERE	12:32	12:44	0:12	TRIPPED ON FAULT
5428	26-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV DAVANAGERE LINE	66KV DAVANAGERE LINE	11:17	11:40	0:23	LINE CLEAR AVAILED
5429	26-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV-SHIMOGA1	KBCROSS_220	10:48	NOT YET CHARGED		LINE CLEAR AVAILED
5430	26-Dec-24	TUMKUR	66	LINE	KIADBNP220 I/C LINE-TMTP66-	TMTP_66, THOVINAKERE_66, BRAMASANDRA_66	13:05	14:04	0:59	LINE CLEAR AVAILED
5431	26-Dec-24	TUMKUR	220	LINE	NITTUR 220kv- ARASIKERE	NITTUR_220	11:15	15:53	4:38	LINE CLEAR AVAILED
5432	26-Dec-24	TUMKUR	66	LINE	SIRA_220-GULIGENAHALLI_66(MADHUGIRI)	66KB GULIGENAHALLI,	6:26	6:30	0:04	TRIPPED ON FAULT
5433	26-Dec-24	TUMKUR	66	TRANSFORMER	TR1 10MVA	AMMASANDRA_110	13:14	13:20	0:06	TRIPPED ON FAULT
5434	26-Dec-24	TUMKUR	66	TRANSFORMER	TR1 8MVA	TAVAREKERE(C)_66	4:05	4:10	0:05	TRIPPED ON FAULT
5435	26-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 ANDTR-2-TMTP_66	TMTP_66	13:05	14:04	0:59	LINE CLEAR AVAILED
5436	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	ANANDANAGAR_110	10:39	16:54	6:15	LINE CLEAR AVAILED
5437	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	ATHARGA_110	11:23	15:41	4:18	LINE CLEAR AVAILED
5438	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GAJENDRAGAD_110	10:05	16:55	6:50	LINE CLEAR AVAILED
5439	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KD JAMBAGI_110	15:49	18:52	3:03	LINE CLEAR AVAILED
5440	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	LOKAPUR_110	17:35	17:50	0:15	LINE CLEAR AVAILED
5441	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	MORATAGI_110	14:52	15:49	0:57	LINE CLEAR AVAILED
5442	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	ANANDANAGAR_110	10:39	16:54	6:15	LINE CLEAR AVAILED
5443	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	GAJENDRAGAD_110	10:05	16:55	6:50	LINE CLEAR AVAILED
5444	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TOLAMATTI_110	10:14	14:19	4:05	LINE CLEAR AVAILED
5445	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5446	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YADAWAD_110	03:08	03:09	0:18	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5447	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	ZALKI_110	14:47	15:05	0:18	LINE CLEAR AVAILED
5448	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	SULTANPUR	11:58	12:23	0:25	LINE CLEAR AVAILED
5449	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TAKKALAKI_110	10:03	14:47	4:44	LINE CLEAR AVAILED
5450	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TOLAMATTI_110	10:15	14:19	4:04	LINE CLEAR AVAILED
5451	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 & HV4 (20MVA)	GAJENDRAGAD_110	10:05	16:55	6:50	LINE CLEAR AVAILED
5452	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (10MVA)	LAKAMANAHALLI_110	10:26	10:35	0:09	TRIPPED ON FAULT
5453	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(10MVA)	SHIGGOAN_110	10:00	11:30	1:30	LINE CLEAR AVAILED
5454	27-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(10MVA)	TOLAMATTI_110	10:14	14:19	4:05	LINE CLEAR AVAILED
5455	27-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5456	27-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5457	27-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5458	27-Dec-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	14:59	17:29	2:30	LINE CLEAR AVAILED
5459	27-Dec-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA2	AMBEWADI_220	15:01	17:26	2:25	LINE CLEAR AVAILED
5460	27-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5461	27-Dec-24	BAGALKOTE	110	LINE	ARGA-ANKOLA	ARGA_110	13:48	13:49	0:01	LINE CLEAR AVAILED
5462	27-Dec-24	BAGALKOTE	110	LINE	ATHARGA-FPI(INCHANATTI SOLAR)	ATHARGA_110	18:46	19:01	0:15	LINE CLEAR AVAILED
5463	27-Dec-24	BAGALKOTE	110	LINE	BABALESHWER-MAMADAPUR(TIKOTA)	BABALESHWER_110	10:05	14:51	4:46	LINE CLEAR AVAILED
5464	27-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI(HANAMSAGAR)	GAJENDRAGAD_110	10:05	16:50	6:45	LINE CLEAR AVAILED
5465	27-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5466	27-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON1	GAJENDRAGAD_110	10:04	16:50	6:46	LINE CLEAR AVAILED
5467	27-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5468	27-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	10:05	16:50	6:45	LINE CLEAR AVAILED
5469	27-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5470	27-Dec-24	BAGALKOTE	110	LINE	HUBLI220- TARIHAL1	HUBLI_220	11:00	13:24	2:24	LINE CLEAR AVAILED
5471	27-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5472	27-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)			LINE CLEAR AVAILED
5473	27-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	10:20	10:27	0:07	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5474	27-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	17:24 (27.12.2024)			LINE CLEAR AVAILED
5475	27-Dec-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-TERDAL	MAHALINGAPUR_220	10:42	18:41	7:59	LINE CLEAR AVAILED
5476	27-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5477	27-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5478	27-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5479	27-Dec-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD1	RON_110	10:22	16:48	6:26	LINE CLEAR AVAILED
5480	27-Dec-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD2	RON_110	10:22	16:48	6:26	LINE CLEAR AVAILED
5481	27-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-KNS	TAKKALAKI_110	10:03	14:46	4:43	LINE CLEAR AVAILED
5482	27-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TIK	TAKKALAKI_110	10:03	14:58	4:55	LINE CLEAR AVAILED
5483	27-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-TRV	TAKKALAKI_110	10:03	14:46	4:43	LINE CLEAR AVAILED
5484	27-Dec-24	BAGALKOTE	110	LINE	TAKKALAKI-WRD	TAKKALAKI_110	10:03	14:47	4:44	LINE CLEAR AVAILED
5485	27-Dec-24	BAGALKOTE	110	LINE	TARIHAL-SRS HUBLI-1	TARIHAL_110	11:01	13:24	2:23	LINE CLEAR AVAILED
5486	27-Dec-24	BAGALKOTE	110	LINE	TIKOTA- BHUTNAL(TAKKALAKI)	TIKOTA_110	9:58 (26.12.2024)			LINE CLEAR AVAILED
5487	27-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5488	27-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5489	27-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5490	27-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	KANAKAPURA 220	13:11	13:12	00:01	LINE CLEAR AVAILED
5491	27-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	13:14	23:59	10:45	LINE CLEAR AVAILED
5492	27-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5493	27-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	16:55	17:11	00:16	TRIPPED ON FAULT
5494	27-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - MASTHENAHALLI - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	13:50	14:00	00:10	LINE CLEAR AVAILED
5495	27-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	NO STATION AFFECTED	12:00	16:45	04:45	LINE CLEAR AVAILED
5496	27-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	05:30	05:34	00:04	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5497	27-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	NO STATION AFFECTED	13:26	14:23	00:57	LINE CLEAR AVAILED
5498	27-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA	CHATRA, MARALWADI, GODUR, MANIYAMBAL KUNUR, HAROBELE, HUKUNDA, KODIHALLI, HUNASENAHALLI, BIJJAHALLI	13:09	13:12	00:03	LINE CLEAR AVAILED
5499	27-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR		13:09	13:12	00:03	LINE CLEAR AVAILED
5500	27-Dec-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI DAIRY, DODDALAHALLI	13:09	13:12	00:03	LINE CLEAR AVAILED
5501	27-Dec-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI, GURUVINAPURA, BV HALLI	06:14	06:28	00:14	TRIPPED ON FAULT
5502	27-Dec-24	BANGALORE	66	LINE	66KV KUDURU - SRIGIRIPURA	SRIGIRIPURA	10:30	11:15	00:45	LINE CLEAR AVAILED
5503	27-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	17:43	23:59	06:16	TRIPPED ON FAULT
5504	27-Dec-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	MASTHENAHALLI, TALAGAWARA, CHEEMANGALA	17:29	17:32	00:03	LINE CLEAR AVAILED
5505	27-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	18:50	21:00	02:10	LINE CLEAR AVAILED
5506	27-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	13:26	14:56	01:30	LINE CLEAR AVAILED
5507	27-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5508	27-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	17:14	17:30	00:16	TRIPPED ON FAULT
5509	27-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	12:13	12:31	00:18	TRIPPED ON FAULT
5510	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKABALLAPURA I/A	12:04	13:56	01:52	LINE CLEAR AVAILED
5511	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	11:00	15:30	04:30	LINE CLEAR AVAILED
5512	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	06:47	07:05	00:18	TRIPPED ON FAULT
5513	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MASTHENAHALLI	12:35	14:30	01:55	LINE CLEAR AVAILED
5514	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MATHIKERE	21:40	21:55	00:15	TRIPPED ON FAULT
5515	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	12:48	14:06	01:18	LINE CLEAR AVAILED
5516	27-Dec-24	BANGALORE	66	TRANSFORMER	HV1	WIDIA	11:14	11:15	00:01	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5517	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	C STATION 66	08:10	08:34	00:24	TRIPPED ON FAULT
5518	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DODDABELAVANGALA	15:00	15:15	00:15	TRIPPED ON FAULT
5519	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	DODDABELAVANGALA	14:51	15:00	00:09	TRIPPED ON FAULT
5520	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	11:15	13:45	02:30	LINE CLEAR AVAILED
5521	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	16:15	16:30	00:15	LINE CLEAR AVAILED
5522	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MASTHENAHALLI	12:35	14:55	02:20	LINE CLEAR AVAILED
5523	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	11:05	11:15	00:10	TRIPPED ON FAULT
5524	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SUBRAMANYAPURA 66	11:07	11:15	00:08	LINE CLEAR AVAILED
5525	27-Dec-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	02:46	02:56	00:10	TRIPPED ON FAULT
5526	27-Dec-24	GULBARGA	110	LINE	APMC-CHICKSUGUR	CHICKSUGUR_110,SHAKTI NAGAR_110,KIADB_110	13:35	13:58	00:23	TRIPPED ON FAULT
5527	27-Dec-24	GULBARGA	66	LINE	BADALADUKU-CHORNUR	CHORNUR_66	09:40	12:30	02:50	LINE CLEAR AVAILED
5528	27-Dec-24	GULBARGA	66	LINE	BADALADUKU-UJJJI	UJJINI_66,SOKKE_66,NIMB ALGERI_66	03:45	04:05	00:20	TRIPPED ON FAULT
5529	27-Dec-24	GULBARGA	110	LINE	GABBUR-RAICHUR	GABBUR_110,BHOOMI PRAKASH SOLAR IPP	18:20	18:40	00:20	TRIPPED ON FAULT
5530	27-Dec-24	GULBARGA	110	LINE	HANWAL-MARALAHALLI	YERDONA_110,BENNUR_110	04:38	04:48	00:10	TRIPPED ON FAULT
5531	27-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	22:30	22:35	00:05	TRIPPED ON FAULT
5532	27-Dec-24	GULBARGA	220	TRANSFORMER	HV1	ITTAGI_220	10:42	11:05	00:23	TRIPPED ON FAULT
5533	27-Dec-24	GULBARGA	110	TRANSFORMER	HV1	RAICHUR_220	01:38	01:50	00:12	TRIPPED ON FAULT
5534	27-Dec-24	GULBARGA	220	TRANSFORMER	HV2	ITTAGI_220	10:57	11:05	00:08	LINE CLEAR AVAILED
5535	27-Dec-24	GULBARGA	220	TRANSFORMER	HV2	SEDAM_220	15:41	18:10	02:29	LINE CLEAR AVAILED
5536	27-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHICKSUGUR_110	03:51	04:02	00:11	TRIPPED ON FAULT
5537	27-Dec-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	18:10	19:25	01:15	LINE CLEAR AVAILED
5538	27-Dec-24	GULBARGA	66	LINE	ITTAGI-SUZLON 1&2	ITTAGI_220	10:45	17:42	06:57	LINE CLEAR AVAILED
5539	27-Dec-24	GULBARGA	220	LINE	ITTAGI-VESTAS	ITTAGI_220	12:25	17:07	04:42	LINE CLEAR AVAILED
5540	27-Dec-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	04:25	04:32	00:07	TRIPPED ON FAULT
5541	27-Dec-24	GULBARGA	110	LINE	KHNAPUR-GONDEDAGI	KHANAPUR_110	18:12	18:50	00:38	TRIPPED ON FAULT
5542	27-Dec-24	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI	CHILKANAHTTI_66	22:15(26.12.2024)	17:20(27.12.2024)	19:05	TRIPPED ON FAULT
5543	27-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
5544	27-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHAN GIDURGA_66,BILCHOD_66,ARASIKERE_66	09:55	10:15	00:20	TRIPPED ON FAULT
5545	27-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 2	GUGAL_110,GABBUR_110	02:41	02:46	00:05	TRIPPED ON FAULT
5546	27-Dec-24	GULBARGA	110	LINE	RAICHUR-SINDHANUR 2	KURDICROSS_110	05:12	05:20	00:08	TRIPPED ON FAULT
5547	27-Dec-24	GULBARGA	220	LINE	SHAHAPUR-RTPS1	SHAHAPUR_220	21:57	22:10	00:13	TRIPPED ON FAULT
5548	27-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUDDAPUR	MUDDAPUR_110	23:50	23:59	00:09	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5549	27-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MUKUNDA	MUKUNDA_110	10:35	12:05	01:30	LINE CLEAR AVAILED
5550	27-Dec-24	GULBARGA	110	LINE	SULEKAL-GANGAVATHI	GANGAVATHI_110, VENKA TAGIRI_110	11:17	14:51	03:34	LINE CLEAR AVAILED
5551	27-Dec-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110, SIRIGER ICROSS_110	04:30	04:40	00:10	MAIN SUPPLY FAILURE
5552	27-Dec-24	HASAN	110	LINE	AJAMPU-KADUR	AJJAMPURA_110	06:20	06:50	00:30	MAIN SUPPLY FAILURE
5553	27-Dec-24	HASAN	220	LINE	GERSOPA-TALGUPA1	gerusoppa_gen	13:26	14:32	01:06	TRIPPED ON FAULT
5554	27-Dec-24	HASAN	110	TRANSFORMER	HV1	JOG_110	10:00	16:59	06:59	LINE CLEAR AVAILED
5555	27-Dec-24	HASAN	66	TRANSFORMER	HV1	SALGAME_66	17:06	17:16	00:10	LINE CLEAR AVAILED
5556	27-Dec-24	HASAN	66	TRANSFORMER	HV2	BAGUR_66	10:01	11:38	01:37	LINE CLEAR AVAILED
5557	27-Dec-24	HASAN	66	TRANSFORMER	HV2	HALEBEEDU_66	09:15	11:12	01:57	LINE CLEAR AVAILED
5558	27-Dec-24	HASAN	110	TRANSFORMER	HV2	JOG_110	10:04	16:59	06:55	LINE CLEAR AVAILED
5559	27-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)			TRIPPED ON FAULT
5560	27-Dec-24	HASAN	110	LINE	KADUR-AJAMPURA	KADUR_220	06:20	06:48	00:28	TRIPPED ON FAULT
5561	27-Dec-24	HASAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	10:02	18:23	08:21	LINE CLEAR AVAILED
5562	27-Dec-24	HASAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	14:19(26.12.2024)	11:45(27.12.2024)	21:35 hrs	TRIPPED ON FAULT
5563	27-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMG_220	10:47(26.12.2021)			LINE CLEAR AVAILED
5564	27-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMG_220	13:26	14:32	01:06	TRIPPED ON FAULT
5565	27-Dec-24	HASAN	220	LINE	MRSSHM-VARAH1	MRSMG_220	14:03	17:35	03:32	TRIPPED ON FAULT
5566	27-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:02	18:23	08:21	LINE CLEAR AVAILED
5567	27-Dec-24	HASAN	66	LINE	SALAGAM-HIREMANGLUR	SALGAME_66	17:06	17:16	00:10	LINE CLEAR AVAILED
5568	27-Dec-24	HASAN	66	LINE	SALAGAM-UDURKOPPLU	SALGAME_66	17:06	17:16	00:10	LINE CLEAR AVAILED
5569	27-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA1	varahi_gen	14:03	17:35	03:32	TRIPPED ON FAULT
5570	27-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5571	27-Dec-24	MYSORE	66	LINE	ELAVALA-HOOTAGALLY	NO STATIONS EFFECTED	12:09	12:13	00:03	LINE CLEAR AVAILED
5572	27-Dec-24	MYSORE	66	LINE	GAMANAHALLI-CHAMALAPURA	GAMANAHALLY_66	10:15	17:45	07:30	LINE CLEAR AVAILED
5573	27-Dec-24	MYSORE	66	LINE	HARVEY-KABBALLI	NO STATIONS EFFECTED	00:13	00:30	00:17	TRIPPED ON FAULT
5574	27-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5575	27-Dec-24	MYSORE	66	TRANSFORMER	HV1	DODDINADUVADI_66	14:55	17:25	02:30	LINE CLEAR AVAILED
5576	27-Dec-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	09:36	12:04	02:28	LINE CLEAR AVAILED
5577	27-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5578	27-Dec-24	MYSORE	66	TRANSFORMER	HV1	TARIPURA_66	10:09	17:31	07:21	LINE CLEAR AVAILED
5579	27-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	12:01	13:15	01:13	LINE CLEAR AVAILED
5580	27-Dec-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	13:20	14:44	01:24	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5581	27-Dec-24	MYSORE	66	TRANSFORMER	HV2	TARIPURA_66	10:09	17:31	07:21	LINE CLEAR AVAILED
5582	27-Dec-24	MYSORE	66	LINE	K HONALAGERE-MADDUR	NO STATIONS EFFECTED	09:14	17:10	07:55	LINE CLEAR AVAILED
5583	27-Dec-24	MYSORE	66	LINE	KADAKOLA 220-TVS LINE	NO STATIONS EFFECTED	12:20	19:45	07:25	LINE CLEAR AVAILED
5584	27-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5585	27-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5586	27-Dec-24	MYSORE	66	LINE	KIADB SOMANAHALLI-K HONALGERE	NO STATIONS EFFECTED	09:18	16:04	06:46	LINE CLEAR AVAILED
5587	27-Dec-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66	06:25	06:32	00:07	TRIPPED ON FAULT
5588	27-Dec-24	MYSORE	66	LINE	KR PETE 220-KR PETE 1	NO STATIONS EFFECTED	9:26 (26/12/2024)	16:49 (27/12/2024)	31:22:00	LINE CLEAR AVAILED
5589	27-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5590	27-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
5591	27-Dec-24	MYSORE	66	LINE	KR PETE-KIKKERI	NO STATIONS EFFECTED	06:59	16:50	09:51	LINE CLEAR AVAILED
5592	27-Dec-24	MYSORE	66	LINE	TALAKADU-CHANDAHALLI	THALAKADU_66 PARINAMIPURA_66	06:25	06:37	00:12	TRIPPED ON FAULT
5593	27-Dec-24	TUMKUR	66	LINE	CHITRADURGA_220-66KV TURUVANURU	66KV BIDARIKERE, JAGALUR	0:20	0:30	0:10	TRIPPED ON FAULT
5594	27-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	NO STATION AFFECTED	21:28	21:35	0:07	TRIPPED ON FAULT
5595	27-Dec-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	NO STATION AFFECTED	22:51	23:21	0:30	TRIPPED ON FAULT
5596	27-Dec-24	TUMKUR	66	LINE	66KV SOKKE-66KV PALLAGATTE	66KV PALLAGHATTA , BILCHODU	3:40	4:10	0:30	TRIPPED ON FAULT
5597	27-Dec-24	TUMKUR	66	LINE	ANTHRASANAHALLI_220-KORA_66	66KV KORA	13:13	13:32	0:19	TRIPPED ON FAULT
5598	27-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV-THALLAK_220KV	HIRIYUR_220KV	20:33	20:50	0:17	TRIPPED ON FAULT
5599	27-Dec-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66, PDKOTE_66	20:35	21:00	0:25	TRIPPED ON FAULT
5600	27-Dec-24	TUMKUR	66	LINE	MAYAKONDA_66-SASALUHALLA_66	66KV SASALUHALLA	1:35	1:50	0:15	TRIPPED ON FAULT
5601	27-Dec-24	TUMKUR	66	TRANSFORMER	TR-1, 20MVA KIADPVN PURA	KIADPVN PURA_220KV	10:04	18:01	7:57	LINE CLEAR AVAILED
5602	27-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	SANIKERE_66	13:50	14:08	0:18	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5603	27-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	SAVALANGA_66	13:21	14:40	1:19	TRIPPED ON FAULT
5604	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	ANKOLA_110	06:51	06:54	0:03	TRIPPED ON FAULT
5605	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HUNAGUND_110	10:08	17:05	6:57	LINE CLEAR AVAILED
5606	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KUDALASANGAM_110	10:26	17:09	6:43	LINE CLEAR AVAILED
5607	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	MALAGHAN(B)_110	12:40	12:45	0:05	TRIPPED ON FAULT
5608	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	GAJENDRAGAD_110	08:42	08:56	0:14	TRIPPED ON FAULT
5609	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	HUNAGUND_110	10:08	17:05	6:57	LINE CLEAR AVAILED
5610	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	LAKAMANAHALLI_110	07:43	07:53	0:10	TRIPPED ON FAULT
5611	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	LAKAMANAHALLI_110	12:01	13:33	1:32	LINE CLEAR AVAILED
5612	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5613	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	KADNAKOPPA_110	05:43	05:54	0:11	TRIPPED ON FAULT
5614	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	KADNAKOPPA_110	07:29	07:36	0:07	TRIPPED ON FAULT
5615	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 & HV3 (20MVA)	GUTTAL_110	14:06	16:29	2:23	LINE CLEAR AVAILED
5616	28-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	HUNAGUND_110	10:08	17:05	6:57	LINE CLEAR AVAILED
5617	28-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5618	28-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5619	28-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5620	28-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5621	28-Dec-24	BAGALKOTE	110	LINE	BANAHATTI-JKD (NAVALAGI)	BANAHATTI_110	08:26	08:49	0:23	TRIPPED ON FAULT
5622	28-Dec-24	BAGALKOTE	110	LINE	BYADAGI-RAILWAY	BYADAGI_110	18:11	18:20	0:09	TRIPPED ON FAULT
5623	28-Dec-24	BAGALKOTE	110	LINE	GADAG220-SHIRAHATTI (LAXMESHWAR)	GADAG_220	10:16	17:39	7:23	LINE CLEAR AVAILED
5624	28-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5625	28-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5626	28-Dec-24	BAGALKOTE	110	LINE	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	05:05	05:25	0:20	TRIPPED ON FAULT
5627	28-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5628	28-Dec-24	BAGALKOTE	110	LINE	HIREMASALI-F1 INDI220	HIREMASALI_110	03:38	04:05	0:27	TRIPPED ON FAULT
5629	28-Dec-24	BAGALKOTE	110	LINE	HIREMASALI-F2 ATHARGA	HIREMASALI_110	03:38	04:05	0:27	TRIPPED ON FAULT
5630	28-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5631	28-Dec-24	BAGALKOTE	110	LINE	HUNAGUND-BAGEWADI(KUDALASANGAM)	HUNAGUND_110	10:08	17:09	7:01	LINE CLEAR AVAILED
5632	28-Dec-24	BAGALKOTE	110	LINE	HUNAGUND-ILKAL1	HUNAGUND_110	10:09	17:02	6:53	LINE CLEAR AVAILED
5633	28-Dec-24	BAGALKOTE	110	LINE	HUNAGUND-ILKAL2	HUNAGUND_110	10:09	17:04	6:55	LINE CLEAR AVAILED
5634	28-Dec-24	BAGALKOTE	110	LINE	HUNAGUND-JINDAL	HUNAGUND_110	10:09	17:04	6:55	LINE CLEAR AVAILED
5635	28-Dec-24	BAGALKOTE	110	LINE	HUNAGUND-KBJNL	HUNAGUND_110	10:09	17:04	6:55	LINE CLEAR AVAILED
5636	28-Dec-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	09:54	14:44	4:50	LINE CLEAR AVAILED
5637	28-Dec-24	BAGALKOTE	110	LINE	KIRIVATT-SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRIVATTI_110	14:07 (11.12.2024)	10:20 (28.12.2024)	404:13:00	LINE CLEAR AVAILED
5638	28-Dec-24	BAGALKOTE	110	LINE	KUDALASANGAM-HUNAGUND	KUDALASANGAM_110	10:26	17:09	6:43	LINE CLEAR AVAILED
5639	28-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	17:24 (27.12.2024)			LINE CLEAR AVAILED
5640	28-Dec-24	BAGALKOTE	110	LINE	LAXMESHWER-SHIRHATTI	LAXMESHWER_110	10:26	18:35	8:09	LINE CLEAR AVAILED
5641	28-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5642	28-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5643	28-Dec-24	BAGALKOTE	110	LINE	PGHUNSHYAL-GHTAPRABHA	PGHUNSHYAL_110	05:04	05:25	0:21	TRIPPED ON FAULT
5644	28-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5645	28-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN220-LN3(SHIGGOAN)	SHIGGOAN_220	10:07	11:30	1:23	LINE CLEAR AVAILED
5646	28-Dec-24	BAGALKOTE	110	LINE	SHIGGOAN-RMKP(MUNDAGOD)	SHIGGOAN_110	12:18	13:01	0:43	LINE CLEAR AVAILED
5647	28-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG1	SIRSI_110	19:05 (28.11.2024)	10:11 (28.12.2024)	711:06:00	LINE CLEAR AVAILED
5648	28-Dec-24	BAGALKOTE	110	LINE	TIKOTA-BHUTNAL(TAKKALAKI)	TIKOTA_110	9:58 (26.12.2024)	12:14 (28.12.2024)	50:16:00	LINE CLEAR AVAILED
5649	28-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5650	28-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5651	28-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5652	28-Dec-24	BANGALORE	220	LINE	220KV KIADB HAROHALLI 220 - KANAKAPURA 220	NO STATION AFFECTED	23:58:00	18:00	18:02	LINE CLEAR AVAILED
5653	28-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5654	28-Dec-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	09:36	09:47	00:11	TRIPPED ON FAULT
5655	28-Dec-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI(HV1 & HV3)	08:26	08:35	00:09	TRIPPED ON FAULT
5656	28-Dec-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	17:02	17:07	00:05	LINE CLEAR AVAILED
5657	28-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	23:58:00	13:43	13:45	TRIPPED ON FAULT
5658	28-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	10:45	10:50	00:05	LINE CLEAR AVAILED
5659	28-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	NO STATION AFFECTED	11:27	13:43	02:16	LINE CLEAR AVAILED
5660	28-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA, WIPRO(EHT)	15:04	15:13	00:09	LINE CLEAR AVAILED
5661	28-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NO STATION AFFECTED	16:51	17:21	00:30	LINE CLEAR AVAILED
5662	28-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5663	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	09:41	15:24	05:43	LINE CLEAR AVAILED
5664	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	D CROSS	20:51	20:56	00:05	TRIPPED ON FAULT
5665	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	16:23	17:06	00:43	LINE CLEAR AVAILED
5666	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	15:55	16:00	00:05	TRIPPED ON FAULT
5667	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAYALUR	22:00	22:05	00:05	LINE CLEAR AVAILED
5668	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	THONDEBHAVI	15:15	16:15	01:00	LINE CLEAR AVAILED
5669	28-Dec-24	BANGALORE	66	TRANSFORMER	HV1	VICTORIA HOSPITAL	09:50	09:53	00:03	TRIPPED ON FAULT
5670	28-Dec-24	BANGALORE	66	TRANSFORMER	HV2	THONDEBHAVI	09:55	11:40	01:45	LINE CLEAR AVAILED
5671	28-Dec-24	BANGALORE	66	TRANSFORMER	HV2	VICTORIA HOSPITAL	03:39	03:51	00:12	TRIPPED ON FAULT
5672	28-Dec-24	GULBARGA	66	LINE	BADALADUKU-CHORNUR	CHORNUR_66	06:30	06:45	00:15	TRIPPED ON FAULT
5673	28-Dec-24	GULBARGA	66	LINE	BADALADUKU-KOTTUR	KOTTUR_66	09:30	18:15	08:45	LINE CLEAR AVAILED
5674	28-Dec-24	GULBARGA	110	LINE	HANUMASAGAR-KUSTAGI	HANUMASAGAR_110,HIRE GONNAGAR_110,HANUM ANAL_110	09:25	09:50	00:25	MAIN SUPPLY FAILURE
5675	28-Dec-24	GULBARGA	110	LINE	HANWAL-SULEKAL	HANWAL_110	00:07	00:12	00:05	TRIPPED ON FAULT
5676	28-Dec-24	GULBARGA	110	LINE	HANWAL-SULEKAL	HANWAL_110	00:38	00:43	00:05	TRIPPED ON FAULT
5677	28-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	11:34	12:00	00:26	TRIPPED ON FAULT
5678	28-Dec-24	GULBARGA	220	TRANSFORMER	HV1	HATTIGUDUR_220	15:16	16:48	01:32	LINE CLEAR AVAILED
5679	28-Dec-24	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	10:14	16:34	06:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5680	28-Dec-24	GULBARGA	110	TRANSFORMER	HV2	SOMASAMUNDRA_110	10:12	16:57	06:45	LINE CLEAR AVAILED
5681	28-Dec-24	GULBARGA	110	TRANSFORMER	HV3	SOMASAMUNDRA_110	10:12	17:50	07:38	LINE CLEAR AVAILED
5682	28-Dec-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	06:35	06:45	00:10	TRIPPED ON FAULT
5683	28-Dec-24	GULBARGA	110	LINE	KMALLAPUR-KAMPLI	MALLAPUR_110	21:16	21:24	00:08	MAIN SUPPLY FAILURE
5684	28-Dec-24	GULBARGA	110	LINE	KUSTAGI-ILKALLINE 1&2	ILKAL_110	10:05	16:47	06:42	LINE CLEAR AVAILED
5685	28-Dec-24	GULBARGA	110	LINE	MOKA-PD_HALLI	PD_HALLI_110	19:19	20:17	00:58	TRIPPED ON FAULT
5686	28-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
5687	28-Dec-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	19:51	20:02	00:11	TRIPPED ON FAULT
5688	28-Dec-24	GULBARGA	220	LINE	SHAHAPUR-RTPS1	SHAHAPUR_220	06:07	06:37	00:30	TRIPPED ON FAULT
5689	28-Dec-24	GULBARGA	110	LINE	SOMASAMUNDRA-ALIPUR	SOMASAMUNDRA_110,BE LLARY NORTH_110	15:07	16:00	00:53	LINE CLEAR AVAILED
5690	28-Dec-24	GULBARGA	110	LINE	SULEKAL-ITTAGI	ITTAGI_220	21:16	21:24	00:08	TRIPPED ON FAULT
5691	28-Dec-24	HASAN	220	LINE	GOPALAP-HNPUR22	GOPALPURA_220	08:02	08:25	00:23	TRIPPED ON FAULT
5692	28-Dec-24	HASAN	220	TRANSFORMER	HV1	MRSMSG_220	09:46	10:12	00:26	TRIPPED ON FAULT
5693	28-Dec-24	HASAN	110	TRANSFORMER	HV3	SAGARA_110	8:48(13.12.2024)	20:55(28.12.2024)	372:06 hrs	TRIPPED ON FAULT
5694	28-Dec-24	HASAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	08:24	18:43	10:19	LINE CLEAR AVAILED
5695	28-Dec-24	HASAN	110	TRANSFORMER	LV1	MRSMSG_220	09:46	10:12	00:26	TRIPPED ON FAULT
5696	28-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	10:47(26.12.2021)			LINE CLEAR AVAILED
5697	28-Dec-24	HASAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	10:10	10:24	00:14	LINE CLEAR AVAILED
5698	28-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	09:20	12:58	03:38	LINE CLEAR AVAILED
5699	28-Dec-24	HASAN	110	LINE	MRSSHM-SS1	MRSMSG_220	10:10	10:24	00:14	LINE CLEAR AVAILED
5700	28-Dec-24	HASAN	110	LINE	MRSSHM-SS2	MRSMSG_220	10:10	10:24	00:14	LINE CLEAR AVAILED
5701	28-Dec-24	HASAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	11:17	13:42	02:25	LINE CLEAR AVAILED
5702	28-Dec-24	HASAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	08:24	18:43	10:19	LINE CLEAR AVAILED
5703	28-Dec-24	HASAN	66	LINE	SAKALE-HASSAN	SAKLESH PURA_66	13:35	13:45	00:10	LINE CLEAR AVAILED
5704	28-Dec-24	HASAN	220	LINE	SHRAVITY-SHIMOGA1	sharavathy_gen	09:20	12:58	03:38	LINE CLEAR AVAILED
5705	28-Dec-24	HASAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	09:21	09:30	00:09	TRIPPED ON FAULT
5706	28-Dec-24	HASAN	66	LINE	UDDURKO-NITTUR2	UDDURKOPLU_66	06:55	07:10	00:15	TRIPPED ON FAULT
5707	28-Dec-24	HASAN	220	LINE	VARAHI-SHIMOGA1	varahi_gen	11:17	13:42	02:25	LINE CLEAR AVAILED
5708	28-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5709	28-Dec-24	MYSORE	66	LINE	CRNAGAR-DRPET1	DODDARAYAPET_66	09:05	15:37	06:31	LINE CLEAR AVAILED
5710	28-Dec-24	MYSORE	66	LINE	CRNAGAR-DRPET2	DODDARAYAPET_66	09:06	15:37	06:31	LINE CLEAR AVAILED
5711	28-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5712	28-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5713	28-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5714	28-Dec-24	MYSORE	66	LINE	KADAKOLA- VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5715	28-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5716	28-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_6	2:49 (3/12/2024)			TRIPPED ON FAULT
5717	28-Dec-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	08:10	08:40	00:30	LINE CLEAR AVAILED
5718	28-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI- HEBBANI	NO STATIONS EFFECTED	06:03	16:57	10:54	LINE CLEAR AVAILED
5719	28-Dec-24	MYSORE	66	LINE	NAGAMANGALA 220- ADDIHALLI	ADDIHALLI_66 SANTHEBACHALLI_66 HARIYALDAMMATAMPLE_6	20:04	20:14	00:10	TRIPPED ON FAULT
5720	28-Dec-24	MYSORE	66	LINE	SATHEGALA-KOLLEGALA	NO STATIONS EFFECTED	06:04	16:55	10:51	LINE CLEAR AVAILED
5721	28-Dec-24	TUMKUR	66	LINE	CHITRADURGA_220-66KV TURUVANURU	66KV BIDARIKERE, JAGALUR , TURUVANURU,MADANAYA KANAHALLI_66	18:29	19:25	0:56	TRIPPED ON FAULT
5722	28-Dec-24	TUMKUR	66	LINE	CHITRADURGA_220-66KV TURUVANURU-BIDARIKERE	66KV BIDARIKERE, JAGALUR , TURUVANURU	19:56	20:01	0:05	TRIPPED ON FAULT
5723	28-Dec-24	TUMKUR	220	TRANSFORMER	20MVA POWER TRANSFORMER -1	220KV K B CROSS	12:43	13:00	0:17	TRIPPED ON FAULT
5724	28-Dec-24	TUMKUR	66	LINE	66KV SHYGALE- KEREBILICHI	66KV KEREILICHI,KNNL W/W	12:55	13:05	0:10	TRIPPED ON FAULT
5725	28-Dec-24	TUMKUR	66	TRANSFORMER	TR-2	PANDARAHALLI_66	9:05	9:14	0:09	TRIPPED ON FAULT
5726	28-Dec-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	GARAGA_66	9:55	10:05	0:10	TRIPPED ON FAULT
5727	28-Dec-24	TUMKUR	66	TRANSFORMER	TR2 20MVA	CHANNAGIRI_66	11:23	11:27	0:04	TRIPPED ON FAULT
5728	28-Dec-24	TUMKUR	66	TRANSFORMER	TR-2.20MVA	MALEBENUR_66	20:50	20:55	1:10	LINE CLEAR AVAILED
5729	28-Dec-24	TUMKUR	110	TRANSFORMER	TR3 20MVA	KBCROSS_220	12:43 (28.12.2024)			TRIPPED ON FAULT
5730	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	17:31	17:40	0:09	LINE CLEAR AVAILED
5731	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KULAGERICROSS_110	07:42	15:41	7:59	LINE CLEAR AVAILED
5732	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	MALAGHAN(B)_110	10:50	18:15	7:25	LINE CLEAR AVAILED
5733	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KULAGERICROSS_110	11:08	15:41	4:33	LINE CLEAR AVAILED
5734	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	MATTIHAL_110	10:43	18:46	8:03	LINE CLEAR AVAILED
5735	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	MRUTYUNJAYNAGAR_110	15:15	15:20	0:05	TRIPPED ON FAULT
5736	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	MUDHOL_110	10:23	16:25	6:02	LINE CLEAR AVAILED
5737	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(HV1 20MVA)	MUDHOL_110	10:23	16:25	6:02	LINE CLEAR AVAILED
5738	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR_110	11:21 (20.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5739	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BAGALKOT_220	17:50	18:12	0:22	TRIPPED ON FAULT
5740	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GULEDAGUDDA_110	17:31	17:33	0:02	LINE CLEAR AVAILED
5741	29-Dec-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (10MVA)	LAKAMANAHALLI_110	17:07	17:14	0:07	TRIPPED ON FAULT
5742	29-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5743	29-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5744	29-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5745	29-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5746	29-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F1-BAGALKOT1	BAGALKOT_220	15:30	18:00	2:30	LINE CLEAR AVAILED
5747	29-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F5-GULEDAGUDDA	BAGALKOT_220	09:16	17:28	8:12	LINE CLEAR AVAILED
5748	29-Dec-24	BAGALKOTE	110	LINE	BAGALKOT-SHIGIKERI(BAGALKOT220)	BAGALKOT_110	12:58	13:01	0:03	LINE CLEAR AVAILED
5749	29-Dec-24	BAGALKOTE	110	LINE	BAGALKOT-SHIGIKERI(BAGALKOT220)	BAGALKOT_110	13:21	13:40	0:19	LINE CLEAR AVAILED
5750	29-Dec-24	BAGALKOTE	110	LINE	GADAG220-LAXMESHWAR2(LAXMESH WAR)	GADAG_220	06:39	09:15	2:36	TRIPPED ON FAULT
5751	29-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5752	29-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5753	29-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5754	29-Dec-24	BAGALKOTE	110	LINE	HIREHAL-BADAMI	HIREHAL_110	10:10	14:50	4:40	LINE CLEAR AVAILED
5755	29-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5756	29-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	17:24 (27.12.2024)			LINE CLEAR AVAILED
5757	29-Dec-24	BAGALKOTE	110	LINE	LAXMESHWER-GADAG1	LAXMESHWER_110	06:39	09:15	2:36	TRIPPED ON FAULT
5758	29-Dec-24	BAGALKOTE	110	LINE	MALGHAN(B)-MAMADAPUR(B)	MALAGHAN(B)_110	10:50	18:15	7:25	LINE CLEAR AVAILED
5759	29-Dec-24	BAGALKOTE	110	LINE	MATTIHAL-MALAGHAN(B)	MATTIHAL_110	10:36	18:43	8:07	LINE CLEAR AVAILED
5760	29-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5761	29-Dec-24	BAGALKOTE	110	LINE	MUDHOL-MLPR(VAJJRAMATTI)	MUDHOL_110	10:23	16:51	6:28	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5762	29-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5763	29-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5764	29-Dec-24	BAGALKOTE	110	LINE	SADALAGA-VPPL	SADALAGA_110	14:25	14:41	0:16	LINE CLEAR AVAILED
5765	29-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5766	29-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI-KUDAGI2	VAJRAMATTI_220	23:23 (29.12.2024)			TRIPPED ON FAULT
5767	29-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5768	29-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5769	29-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5770	29-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A2)	NO STATION AFFECTED	12:15	16:25	04:10	LINE CLEAR AVAILED
5771	29-Dec-24	BANGALORE	66	LINE	66KV A STATION 220 - KANTEERAVA	KANTEERAVA	10:10	16:20	06:10	LINE CLEAR AVAILED
5772	29-Dec-24	BANGALORE	66	LINE	66KV EDC 220 - KANTEERAVA	KANTEERAVA	10:10	16:20	06:10	LINE CLEAR AVAILED
5773	29-Dec-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	06:43	07:01	00:18	TRIPPED ON FAULT
5774	29-Dec-24	BANGALORE	66	LINE	66KV EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE HOUSING ORGANISATION	17:30	17:44	00:14	TRIPPED ON FAULT
5775	29-Dec-24	BANGALORE	66	LINE	66KV HOODY 220 - ITI 220	NO STATION AFFECTED	11:35	12:12	00:37	LINE CLEAR AVAILED
5776	29-Dec-24	BANGALORE	66	LINE	66KV KONDASPURA (SAFAL) - NTT GLOBAL DATA NETMAGIC 66/11KV EHT	NO STATION AFFECTED	18:07	18:12	00:05	LINE CLEAR AVAILED
5777	29-Dec-24	BANGALORE	66	LINE	66KV KONDASPURA (SAFAL) - NTT GLOBAL DATA NETMAGIC 66/11KV EHT	NO STATION AFFECTED	19:27	19:32	00:05	LINE CLEAR AVAILED
5778	29-Dec-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANKUNTE	19:50	20:03	00:13	TRIPPED ON FAULT
5779	29-Dec-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	08:15	08:20	00:05	LINE CLEAR AVAILED
5780	29-Dec-24	BANGALORE	66	LINE	66KV SIDDALAGHATTA - MELUR	NO STATION AFFECTED	10:10	18:56	08:46	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5781	29-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5782	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	10:02	17:25	07:23	LINE CLEAR AVAILED
5783	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	10:02	16:55	06:53	LINE CLEAR AVAILED
5784	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	10:02	12:32	02:30	LINE CLEAR AVAILED
5785	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	01:28	01:38	00:10	TRIPPED ON FAULT
5786	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	01:38	09:48	08:10	LINE CLEAR AVAILED
5787	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	20:43	23:23	02:40	LINE CLEAR AVAILED
5788	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	13:00	14:30	01:30	LINE CLEAR AVAILED
5789	29-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	13:00	16:10	03:10	LINE CLEAR AVAILED
5790	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ATTIBELE	15:10	15:15	00:05	LINE CLEAR AVAILED
5791	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHEEMANGALA	12:20	12:35	00:15	TRIPPED ON FAULT
5792	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	21:50	22:00	00:10	TRIPPED ON FAULT
5793	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	22:00	22:02	00:02	LINE CLEAR AVAILED
5794	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	ITI 220	17:35	17:40	00:05	LINE CLEAR AVAILED
5795	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 220	10:38	10:44	00:06	LINE CLEAR AVAILED
5796	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SAHAKARINAGAR 66	22:23	22:30	00:07	LINE CLEAR AVAILED
5797	29-Dec-24	BANGALORE	66	TRANSFORMER	HV2	TAVAREKERE	13:00	16:10	03:10	LINE CLEAR AVAILED
5798	29-Dec-24	BANGALORE	66	TRANSFORMER	HV3	A STATION 66	07:19	07:21	00:02	LINE CLEAR AVAILED
5799	29-Dec-24	BANGALORE	66	TRANSFORMER	HV3	A STATION 66	16:19	16:22	00:03	LINE CLEAR AVAILED
5800	29-Dec-24	BANGALORE	66	TRANSFORMER	HV3	ATTIBELE	15:10	15:20	00:10	LINE CLEAR AVAILED
5801	29-Dec-24	GULBARGA	110	LINE	BHALKI-LADHA	BHALKI_110	12:10	13:30	01:20	TRIPPED ON FAULT
5802	29-Dec-24	GULBARGA	110	LINE	HALWARTHY--GINIGERA	GINIGERA_110	10:00	11:46	01:46	LINE CLEAR AVAILED
5803	29-Dec-24	GULBARGA	110	LINE	HANWAL-SULEKAL	HANWAL_110	19:36	19:41	00:05	TRIPPED ON FAULT
5804	29-Dec-24	GULBARGA	110	LINE	HATTIGUDUR-DEVAPUR	DEVAPUR_110	01:07	01:14	00:07	TRIPPED ON FAULT
5805	29-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	16:55	17:00	00:05	TRIPPED ON FAULT
5806	29-Dec-24	GULBARGA	66	TRANSFORMER	HV1 &2	PUNABHAGATTA_66	13:45	15:30	01:45	LINE CLEAR AVAILED
5807	29-Dec-24	GULBARGA	110	LINE	KUSTAGI-BEVOOR	BEVOOR_110,CHILAKANA HATTI_110	10:25	12:17	01:52	LINE CLEAR AVAILED
5808	29-Dec-24	GULBARGA	110	LINE	MOKA-PD_HALLI	PD_HALLI_110	23:36(29.12.2024)			TRIPPED ON FAULT
5809	29-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
5810	29-Dec-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 2	GABBUR_110,GUGAL_110	13:40	13:50	00:10	TRIPPED ON FAULT
5811	29-Dec-24	GULBARGA	110	LINE	RAMASAMUDRA-SAIDAPUR	SAIDAPUR_110	10:50	17:39	06:49	LINE CLEAR AVAILED
5812	29-Dec-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	04:00	04:10	00:10	TRIPPED ON FAULT
5813	29-Dec-24	GULBARGA	220	LINE	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	06:29	06:39	00:10	TRIPPED ON FAULT
5814	29-Dec-24	GULBARGA	220	LINE	SINDHANOOR-NIRLOOTI IPP	SINDHANOOR_220	18:21	18:31	00:10	TRIPPED ON FAULT
5815	29-Dec-24	GULBARGA	110	LINE	TORANGALU-KUDITINI	TORANGALU_110	09:40	09:45	00:05	TRIPPED ON FAULT
5816	29-Dec-24	HASAN	220	LINE	GERSOPA-TALGUPA2	gerusoppa_gen	10:16	17:29	07:13	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5817	29-Dec-24	HASAN	110	TRANSFORMER	HV1	ARASIKERE_110	14:05	16:02	01:57	TRIPPED ON FAULT
5818	29-Dec-24	HASAN	110	TRANSFORMER	HV1	CHANDRAGUTT_110	10:05	15:20	05:15	LINE CLEAR AVAILED
5819	29-Dec-24	HASAN	66	TRANSFORMER	HV1	HAGARE_66	09:15	13:01	03:46	LINE CLEAR AVAILED
5820	29-Dec-24	HASAN	110	TRANSFORMER	HV1	SHIKARIPURA_110	17:05	18:31	01:26	LINE CLEAR AVAILED
5821	29-Dec-24	HASAN	110	TRANSFORMER	HV2	SHIKARIPURA_110	15:30	17:14	01:44	LINE CLEAR AVAILED
5822	29-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	10:47(26.12.2021)			LINE CLEAR AVAILED
5823	29-Dec-24	HASAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	10:16	17:29	07:13	LINE CLEAR AVAILED
5824	29-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5825	29-Dec-24	MYSORE	66	LINE	CRNAGAR-KOLLEGALA	JANNUR_66 TNARASIPURA_66 THAYURU_66	17:17	18:45	01:27	LINE CLEAR AVAILED
	29-Dec-24	MYSORE	66	LINE	DR PETE-SATHEMARALLI	SANTHEMARAHALLI_66	12:08	18:44	06:35	TRIPPED ON FAULT
5827	29-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5828	29-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5829	29-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5830	29-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5831	29-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5832	29-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATEMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
5833	29-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA Transformer 1 AND TR2 ,PAVAGADA 220kV-	PAVAGADA 220kV-	10:00	15:10	5:10	LINE CLEAR AVAILED
5834	29-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA Transformer 1 HV SIDE AND LV SIDE	MADHUGIRI_220, AND O/G LINES,NITHRAHALLI,MIDIGESHI_66,MADHUGIRI_66 ,KORATGERE_66,SIRALINE-1	11:20	16:56	5:36	LINE CLEAR AVAILED
5835	29-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA Transformer 1HOSADURGA(MADHURE) 220KV	HOSADURGA(MADHURE) 220KV	11:05	11:30	0:25	MAIN SUPPLY FAILURE
5836	29-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA Transformer 2 LV SIDE	MADHUGIRI_220	11:20	16:56	5:36	LINE CLEAR AVAILED
5837	29-Dec-24	TUMKUR	220	LINE	100 MVA Transformer 2HOSADURGA(MADHURE) 220KV	HOSADURGA(MADHURE) 220KV	11:05	11:30	0:25	MAIN SUPPLY FAILURE
5838	29-Dec-24	TUMKUR	220	TRANSFORMER	100 MVA Transformer 3	ANTHRASANAHALLI_220	0:55	13:11	12:16	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5839	29-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV GOPPENAHALLI	66KV GOPPENAHALLI	14:36	14:44	0:08	LINE CLEAR AVAILED
5840	29-Dec-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV MALLADIHALLI	66KV MALLADIHALLI	14:36	14:44	0:08	LINE CLEAR AVAILED
5841	29-Dec-24	TUMKUR	220	LINE	220KV HONNALI-BENKIKER_220KV LINE-1	220KV BENKIKERE, AND 66 O/G LINES ,BENKIKERE_66,MALLADIHALLI,DEVARAHALLI,NALLUR,CHANNAGIRI,GOPPENAHALLI, AND 220KV HOSDURGA (MADHURE) AND 66 O/G LINES RAMAGIRI_66,BAGUR_66, HALURAMESHWARA&MAD	11:03	11:19	0:16	TRIPPED ON FAULT
5842	29-Dec-24	TUMKUR	220	LINE	220KV HONNALI-BENKIKER_220KV LINE-2	220KV BENKIKERE, AND 66 O/G LINES ,BENKIKERE_66,MALLADIHALLI,DEVARAHALLI,NALLUR,CHANNAGIRI,GOPPENAHALLI, AND 220KV HOSDURGA (MADHURE) AND 66 O/G LINES RAMAGIRI_66,BAGUR_66, HALURAMESHWARA&MAD	11:03	11:19	0:16	TRIPPED ON FAULT
5843	29-Dec-24	TUMKUR	220	LINE	220KV HONNALI-BENKIKER_220KV LINE-2	BENKIKER_220KV LINE-2	11:03	11:19	0:16	TRIPPED ON FAULT
5844	29-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV HALURAMESHWARA LINE-1	66KV HALRAMESHWARA,MADADAKERE	6:00	6:15	0:15	TRIPPED ON FAULT
5845	29-Dec-24	TUMKUR	220	LINE	400KV GUTTUR - 220KVCHITRADURGA LINE	220KVCHITRADURGA LINE	6:20	9:15	2:55	TRIPPED ON FAULT
5846	29-Dec-24	TUMKUR	66	LINE	66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE	66KV GARAGA ,PANCHANAHALLI, MATHOD	6:25	6:35	0:10	TRIPPED ON FAULT
5847	29-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV HARIHAR HOSPET LINE	66KV HARIHAR HOSPET LINE	11:41	11:51	0:10	TRIPPED ON FAULT
5848	29-Dec-24	TUMKUR	66	LINE	KORATAGERE-ANTHARASANA HALLI	KORATAGERE_66	10:00	17:20	7:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5849	29-Dec-24	TUMKUR	66	LINE	PAVAGADA 220kV-MADHUGIRI 1	PAVAGADA LINE-1 &LINE-2 PAVAGADA_66, VENKATAPURA_66, NAGALMADIKE_66, MAGALAWADA_66, Y.N. KOTE, KILARAHALLI, SHALAPURA_66, A	10:00	16:50	6:50	LINE CLEAR AVAILED
5850	29-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	MADHUGIRI_66	10:05	16:00	5:55	LINE CLEAR AVAILED
5851	29-Dec-24	TUMKUR	110	TRANSFORMER	TR1 20MVA	KBCROSS_220	12:43 (28.12.2024)	16:54 (29.12.2024)	1DAY 4:11 HR	TRIPPED ON FAULT
5852	29-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 8MVA	PULAMGHATTA_66	10:00	16:00	6:00	LINE CLEAR AVAILED
5853	29-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	GULGENAHALLI_66	10:05	17:55	7:50	LINE CLEAR AVAILED
5854	29-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MADHUGIRI_66	10:05	16:00	5:55	LINE CLEAR AVAILED
5855	29-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	PULAMGHATTA_66	10:00	16:00	6:00	LINE CLEAR AVAILED
5856	29-Dec-24	TUMKUR	110	TRANSFORMER	TR3 10MVA	AMMASANDRA_110	12:23	14:10	1:47	LINE CLEAR AVAILED
5857	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	MALAGHAN(B)_110	08:50	08:55	0:05	TRIPPED ON FAULT
5858	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALAGHATAGI_1110	13:02	13:15	0:13	LINE CLEAR AVAILED
5859	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	TALIKOTI_110	08:53	08:59	0:06	TRIPPED ON FAULT
5860	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KALAGHATAGI_1110	13:02	13:15	0:13	LINE CLEAR AVAILED
5861	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	UCHAGAON_110	12:00	14:35	2:35	LINE CLEAR AVAILED
5862	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	YARAGATTI_110	18:25	19:16	0:51	TRIPPED ON FAULT
5863	30-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	MAMADAPUR(B)_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5864	30-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	CHIKKODI_220	13:42	13:54	0:12	TRIPPED ON FAULT
5865	30-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	MAHALINGAPUR_220	10:55	11:03	0:08	TRIPPED ON FAULT
5866	30-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	CHIKKODI_220	13:46	13:54	0:08	LINE CLEAR AVAILED
5867	30-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5868	30-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5869	30-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1 (LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5870	30-Dec-24	BAGALKOTE	110	LINE	AEQUS220-HUKKERI	AEQUS_220	15:32	15:40	0:08	TRIPPED ON FAULT
5871	30-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5872	30-Dec-24	BAGALKOTE	110	LINE	GADAG220-DAMBAL2(DAMBAL)	GADAG_220	06:37	11:17	4:40	TRIPPED ON FAULT
5873	30-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5874	30-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5875	30-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
5876	30-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5877	30-Dec-24	BAGALKOTE	110	LINE	HUKKERI-HATTARGI	HUKKERI_110	15:32	15:40	0:08	LINE CLEAR AVAILED
5878	30-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	17:24 (27.12.2024)			LINE CLEAR AVAILED
5879	30-Dec-24	BAGALKOTE	110	LINE	MALGHAN(B)-BASAVESHWER SUGARS	MALAGHAN(B)_110	14:59	15:04	0:05	TRIPPED ON FAULT
5880	30-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5881	30-Dec-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN9(HALLUR)	MUGALKHOD_220	23:00	23:11	0:11	TRIPPED ON FAULT
5882	30-Dec-24	BAGALKOTE	220	LINE	NARENDRA- KANABARGI2	NARENDRA_220	21:08	21:12	0:04	TRIPPED ON FAULT
5883	30-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
5884	30-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
5885	30-Dec-24	BAGALKOTE	110	LINE	RANEBENNUR220-HUKKERI	RANEBENNUR_220	7:07	19:23	12:16	LINE CLEAR AVAILED
5886	30-Dec-24	BAGALKOTE	110	LINE	SALAHALLI-SHIVSAGAR SUGARS	SALAHALLI_110	07:00	07:31	0:31	TRIPPED ON FAULT
5887	30-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	SIRSI_110	10:18	14:45	4:27	LINE CLEAR AVAILED
5888	30-Dec-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	SIRSI_110	10:18	14:46	4:28	LINE CLEAR AVAILED
5889	30-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
5890	30-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI-KUDAGI2	VAJRAMATTI_220	23:23 (29.12.2024)			TRIPPED ON FAULT
5891	30-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5892	30-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5893	30-Dec-24	BANGALORE	220	LINE	220KV HOODY 400 - HAL 2	NO STATION AFFECTED	22:16	23:59	01:43	LINE CLEAR AVAILED
5894	30-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
5895	30-Dec-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLLAHALLI 2	NO STATION AFFECTED	16:00	17:06	01:06	LINE CLEAR AVAILED
5896	30-Dec-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	12:00	12:14	00:14	TRIPPED ON FAULT

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5897	30-Dec-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE	09:26	09:35	00:09	TRIPPED ON FAULT
5898	30-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	15:39	17:20	01:41	TRIPPED ON FAULT
5899	30-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	10:20	11:10	00:50	TRIPPED ON FAULT
5900	30-Dec-24	BANGALORE	66	LINE	66KV MEI LAYOUT - WIDIA	NO STATION AFFECTED	06:45	09:13	02:28	TRIPPED ON FAULT
5901	30-Dec-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELCAST	18:05	18:08	00:03	LINE CLEAR AVAILED
5902	30-Dec-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	13:13	13:22	00:09	LINE CLEAR AVAILED
5903	30-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
5904	30-Dec-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	ABBIGERE	14:30	14:34	00:04	LINE CLEAR AVAILED
5905	30-Dec-24	BANGALORE	220	TRANSFORMER	HV1	SAHAKARINAGAR 220	12:02	16:43	04:41	LINE CLEAR AVAILED
5906	30-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SHOBHA DREAMS 66	10:45	10:50	00:05	LINE CLEAR AVAILED
5907	30-Dec-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR_66	10:30	10:50	00:20	TRIPPED ON FAULT
5908	30-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	16:05	16:25	00:20	LINE CLEAR AVAILED
5909	30-Dec-24	BANGALORE	66	TRANSFORMER	HV1	TAVAREKERE	17:50	18:05	00:15	LINE CLEAR AVAILED
5910	30-Dec-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	17:30	18:00	00:30	LINE CLEAR AVAILED
5911	30-Dec-24	BANGALORE	66	TRANSFORMER	HV2	SHOBHA DREAMS 66	12:20	12:25	00:05	LINE CLEAR AVAILED
5912	30-Dec-24	BANGALORE	400	LINE	ICT 1	MYLASANDRA 400	18:10	18:58	00:48	LINE CLEAR AVAILED
5913	30-Dec-24	BANGALORE	400	LINE	ICT 1	MYLASANDRA 400	18:59	20:24	01:25	LINE CLEAR AVAILED
5914	30-Dec-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGGI	BENNEHALLI_66,KOTTUR_66,UJJANI_66	17:35	17:40	00:05	MAIN SUPPLY FAILURE
5915	30-Dec-24	GULBARGA	110	LINE	BETAGERA-TALKAL	TALKAL_110	05:55	06:26	00:31	TRIPPED ON FAULT
5916	30-Dec-24	GULBARGA	400	LINE	BTPS-GUTTUR	GUTTUR_400	09:11	19:06	09:55	LINE CLEAR AVAILED
5917	30-Dec-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	09:30	09:36	00:06	TRIPPED ON FAULT
5918	30-Dec-24	GULBARGA	110	TRANSFORMER	HV1	SIRIGERICROSS_110	04:02	04:07	00:05	TRIPPED ON FAULT
5919	30-Dec-24	GULBARGA	220	TRANSFORMER	HV2	ITTAGI_220	17:45	17:50	00:05	LINE CLEAR AVAILED
5920	30-Dec-24	GULBARGA	110	TRANSFORMER	HV3	CHICKSUGUR_110	06:55	07:05	00:10	TRIPPED ON FAULT
5921	30-Dec-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY TRACTION LINE	KHANAPUR_110	19:35	19:40	00:05	TRIPPED ON FAULT
5922	30-Dec-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY TRACTION LINE	RAILWAY TRACTION LINE_110	15:14	16:54	01:40	LINE CLEAR AVAILED
5923	30-Dec-24	GULBARGA	110	LINE	MOKA-PD_HALLI(I/C SOMASAMUNDRA)	PD_HALLI_110,MOKA_110, BISIHALLI_110	23:36(29.12.2024)	0:21(30.12.2024)	0:45HRS	TRIPPED ON FAULT
5924	30-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5925	30-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHAN GIDURGA_66,BILCHOD_6 6,ARASIKERE_66	21:05	21:12	00:07	TRIPPED ON FAULT
5926	30-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHAN GIDURGA_66,BILCHOD_6 6,ARASIKERE_66	21:59	22:16	00:17	TRIPPED ON FAULT
5927	30-Dec-24	GULBARGA	66	LINE	TELAGI-KURUBARAHALLI	KURUBARAHALLI_66,SHA MANUR SUGAR_IPP	21:05	21:15	00:10	TRIPPED ON FAULT
5928	30-Dec-24	GULBARGA	66	LINE	TELAGI-KURUBARAHALLI	KURUBARAHALLI_66,SHA MANUR SUGAR_IPP	22:00	22:10	00:10	TRIPPED ON FAULT
5929	30-Dec-24	HASAN	110	LINE	ESSUR-BELIGAVI	ESSUR_110	10:35	18:49	08:14	LINE CLEAR AVAILED
5930	30-Dec-24	HASAN	110	LINE	ESSUR-MADHUVANA	HIRIYADKA_110	12:48	12:59	00:11	LINE CLEAR AVAILED
5931	30-Dec-24	HASAN	110	LINE	ESSUR-MADHUVANA	HIRIYADKA_110	13:43	13:44	00:01	LINE CLEAR AVAILED
5932	30-Dec-24	HASAN	66	LINE	HNPR2-HASS3	HOLENARASIPURA_220	11:43	11:58	00:15	LINE CLEAR AVAILED
5933	30-Dec-24	HASAN	66	LINE	HNPR2-MYSOR2	HOLENARASIPURA_220	13:27	13:33	00:06	LINE CLEAR AVAILED
5934	30-Dec-24	HASAN	110	TRANSFORMER	HV1	BAIKAMPADY_110	09:53	17:18	07:25	LINE CLEAR AVAILED
5935	30-Dec-24	HASAN	66	TRANSFORMER	HV1	KANDLI_66	12:39	13:40	01:01	LINE CLEAR AVAILED
5936	30-Dec-24	HASAN	66	TRANSFORMER	HV1	MALLAPURA_66	10:30	11:45	01:15	LINE CLEAR AVAILED
5937	30-Dec-24	HASAN	66	TRANSFORMER	HV2	KANDLI_66	11:39	12:47	01:08	LINE CLEAR AVAILED
5938	30-Dec-24	HASAN	110	LINE	JOG-NK1	mghejog_gen	10:50	14:32	03:42	LINE CLEAR AVAILED
5939	30-Dec-24	HASAN	110	LINE	KADUR-BANVR	KADUR_220	11:42	12:51	01:09	LINE CLEAR AVAILED
5940	30-Dec-24	HASAN	110	LINE	KADUR-BANVR	KADUR_220	18:02	18:05	00:03	LINE CLEAR AVAILED
5941	30-Dec-24	HASAN	110	LINE	KADUR-NERELEKERE	KADUR_220	11:50	12:00	00:10	LINE CLEAR AVAILED
5942	30-Dec-24	HASAN	220	LINE	KEMAR-BAJPE1	KEMAR_220	09:23	21:08	11:45	LINE CLEAR AVAILED
5943	30-Dec-24	HASAN	220	LINE	MRSSHM-ANTRSNH	MRSMSG_220	11:59	13:37	01:38	LINE CLEAR AVAILED
5944	30-Dec-24	HASAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	10:47(26.12.2021)	13:50(30.12.2024)	99:02 hrs	LINE CLEAR AVAILED
5945	30-Dec-24	HASAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	09:53	13:16	03:23	LINE CLEAR AVAILED
5946	30-Dec-24	HASAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	09:23	21:09	11:46	LINE CLEAR AVAILED
5947	30-Dec-24	HASAN	110	LINE	NANDIKU-KEMAR1	NANDIKUR_110	14:08	16:08	02:00	LINE CLEAR AVAILED
5948	30-Dec-24	HASAN	110	LINE	SAGARA-SS2	SAGARA_110	11:47	12:02	00:15	TRIPPED ON FAULT
5949	30-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
5950	30-Dec-24	MYSORE	66	LINE	GOLUR-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	20:06	20:11	00:05	TRIPPED ON FAULT
5951	30-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
5952	30-Dec-24	MYSORE	66	TRANSFORMER	HV1	HADLI_66	08:55	15:23	06:28	LINE CLEAR AVAILED
5953	30-Dec-24	MYSORE	66	TRANSFORMER	HV1	HOSURGATE_66	12:28	13:59	01:30	LINE CLEAR AVAILED
5954	30-Dec-24	MYSORE	66	TRANSFORMER	HV1	MANDGERE_66	13:30	13:35	00:05	MAIN SUPPLY FAILURE
5955	30-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5956	30-Dec-24	MYSORE	66	TRANSFORMER	HV2	DODDINADUVADI_66	13:26	15:14	01:47	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5957	30-Dec-24	MYSORE	66	TRANSFORMER	HV2	HOSURGATE_66	14:00	15:00	01:00	LINE CLEAR AVAILED
5958	30-Dec-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	15:24	18:43	03:18	LINE CLEAR AVAILED
5959	30-Dec-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	13:19	13:24	00:05	LINE CLEAR AVAILED
5960	30-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5961	30-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
5962	30-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
5963	30-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
5964	30-Dec-24	MYSORE	66	LINE	PERIAPATNA-HANGUD	NO STATIONS EFFECTED	09:06	19:10	10:04	LINE CLEAR AVAILED
5965	30-Dec-24	MYSORE	66	LINE	SANTESARGUR-MASTER POWER (KALSON)	NO STATIONS EFFECTED	06:14	06:20	00:06	TRIPPED ON FAULT
5966	30-Dec-24	MYSORE	66	LINE	SANTESARGUR-SUBHASH KABINI 2	NO STATIONS EFFECTED	05:18	05:23	00:05	TRIPPED ON FAULT
5967	30-Dec-24	TUMKUR	66	LINE	CHITRADURGA_220-66KV TURUVANURU	66KV BIDARIKERE, JAGALUR , TURUVANURU,	2:20	2:25	0:05	TRIPPED ON FAULT
5968	30-Dec-24	TUMKUR	66	LINE	220KV GUTTUR-66KV HALASABALU LINE	66KV GUTTUR 66KV HARIHAR HOSPETE POLY FIBER	10:56	11:09	0:13	TRIPPED ON FAULT
5969	30-Dec-24	TUMKUR	66	LINE	66 KV INCOMING LINE (TELIGI LINE EXPORT)	66KV KURUBARAHALLI	15:00	15:22	0:22	TRIPPED ON FAULT
5970	30-Dec-24	TUMKUR	66	LINE	66KV NAGASAMUDRA-66KV RAMPURA-1	66KV RAMPURA-1,HANAGAL_66	17:38	17:56	0:18	TRIPPED ON FAULT
5971	30-Dec-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-SHIMOGA	ANTHRASANAHALLI_220	11:13 (26.12.2024)	13:41 (30.12.2024)	4DAYS 2:28HR	LINE CLEAR AVAILED
5972	30-Dec-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KERECHILCHI 66	15:10	15:20	0:10	LINE CLEAR AVAILED
5973	30-Dec-24	TUMKUR	66	LINE	CHITRADURGA 66KV-PANDARAHALLI - HOLALKERE LINE	PANDARAHALLI - HOLALKERE LINE, SASALUHALLA_66,KUTTIGAHALLI WATERHOUSE	9:05	14:00	4:55	LINE CLEAR AVAILED
5974	30-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV MAYAKONDA LINE	66KV MAYAKONDA, SASALU, CHICKIAJUR	7:19	7:29	0:10	TRIPPED ON FAULT
5975	30-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS LINE	GUTTUR_400	9:11	19:05	9:54	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
5976	30-Dec-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	SANIKERE_66	6:38	6:48	0:10	TRIPPED ON FAULT
5977	30-Dec-24	TUMKUR	66	TRANSFORMER	HV1 12.5 MVA	BRAHMASANDRA_66	8:40	19:22	10:42	LINE CLEAR AVAILED
5978	30-Dec-24	TUMKUR	66	TRANSFORMER	HV1 12.5 MVA SAVALANGA	SAVALANGA_66	12:49	17:30	4:41	LINE CLEAR AVAILED
5979	30-Dec-24	TUMKUR	66	TRANSFORMER	HV1 20 MVA	BRAHMASANDRA_66	8:40	19:22	10:42	LINE CLEAR AVAILED
5980	30-Dec-24	TUMKUR	220	LINE	KB CROSS 220KV-SHIMOGA1	KBCROSS_220	10:48 (26.12.2024)	13:52 (30.12.2024)	4DAYS 3:04HR	LINE CLEAR AVAILED
5981	30-Dec-24	TUMKUR	66	LINE	TMTP66-BRAHMASANDRA	BRAHMASANDRA_66, ANANKSANDRA_66, SUNVIK 66	8:05	19:14	11:09	LINE CLEAR AVAILED
5982	30-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 &TR-2 12.5MVA	SASALUHALLA_66	9:01	14:10	5:09	LINE CLEAR AVAILED
5983	30-Dec-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA	PAVAGADA_220	13:11	13:43	0:32	LINE CLEAR AVAILED
5984	30-Dec-24	TUMKUR	66	TRANSFORMER	TR-1 20MVA	PAVAGADA_66	11:45	13:25	1:40	TRIPPED ON FAULT
5985	30-Dec-24	TUMKUR	220	TRANSFORMER	TR-2 100MVA	PAVAGADA_220	13:44	14:28	0:44	LINE CLEAR AVAILED
5986	30-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA	HIREHALLI_66	15:10	18:24	3:14	LINE CLEAR AVAILED
5987	31-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BAGALKOT_220	16:12	17:35	1:23	LINE CLEAR AVAILED
5988	31-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MAMADAPUR(B)_110	11:21 (20.12.2024)			LINE CLEAR AVAILED
5989	31-Dec-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	LAKAMANAHALLI_110	00:04	00:10	0:06	TRIPPED ON FAULT
5990	31-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	CHIKKODI_220	10:25	12:32	2:07	TRIPPED ON FAULT
5991	31-Dec-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5992	31-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:06 (13.12.2024)			LINE CLEAR AVAILED
5993	31-Dec-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1(LV2)	GADAG_220	10:40 (21.12.2024)			LINE CLEAR AVAILED
5994	31-Dec-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2	AMBEWADI_220	9:23 (25.12.2024)			TRIPPED ON FAULT
5995	31-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-F3-NAVANAGAR-1	BAGALKOT_220	08:47	10:43	1:56	LINE CLEAR AVAILED
5996	31-Dec-24	BAGALKOTE	110	LINE	BAGALKOT220-NAVANAGAR-2	BAGALKOT_220	8:52	10:44	1:52	LINE CLEAR AVAILED
5997	31-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI	GAJENDRAGAD_110	16:17 (24.12.2024)			LINE CLEAR AVAILED
5998	31-Dec-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON2	GAJENDRAGAD_110	11:03 (24.12.2024)			LINE CLEAR AVAILED
5999	31-Dec-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI(GUTTAL SWITCHING 1)	STATION NOT AFFECTED GUTTAL_110	12:47 (10.10.2024)			LINE CLEAR AVAILED
6000	31-Dec-24	BAGALKOTE	110	LINE	HUBLI220-ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
6001	31-Dec-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	17:24 (27.12.2024)			LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6002	31-Dec-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
6003	31-Dec-24	BAGALKOTE	110	LINE	PG HUNSYAL-MUDALAGI (MUGHALKHOD)	STATION NOT AFFECTED PG HUNSYAL_110	17:10 (12.10.2024)			LINE CLEAR AVAILED
6004	31-Dec-24	BAGALKOTE	110	LINE	RAIBAG-ITNAL (MUGHALKHOD)	RAIBAG_110	12:15 (23.12.2024}			LINE CLEAR AVAILED
6005	31-Dec-24	BAGALKOTE	110	LINE	UGAR KHUD-KUDACHI	STATION NOT AFFECTED UGAR KHUD_110	16:43 (25.11.2024)			LINE CLEAR AVAILED
6006	31-Dec-24	BAGALKOTE	220	LINE	VAJRAMATTI-KUDAGI2	VAJRAMATTI_220	23:23 (29.12.2024)			TRIPPED ON FAULT
6007	31-Dec-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	15:46	17:50	02:04	LINE CLEAR AVAILED
6008	31-Dec-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
6009	31-Dec-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
6010	31-Dec-24	BANGALORE	220	LINE	220KV HARALRU MUDDENAHALLI 220 - KIADB HARDWARE PARK 220 LINE 2	NO STATION AFFECTED	10:48	23:59	13:11	LINE CLEAR AVAILED
6011	31-Dec-24	BANGALORE	220	LINE	220KV HARALURU MUDDENAHALLI 220 - KIADB HARDWARE PARK 220 LINE 1	NO STATION AFFECTED	10:48	23:59	13:11	LINE CLEAR AVAILED
6012	31-Dec-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	NO STATION AFFECTED	23:58:00	23:59	00:01	TRIPPED ON FAULT
6013	31-Dec-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	07:23	07:40	00:17	TRIPPED ON FAULT
6014	31-Dec-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	NO STATION AFFECTED	10:19	12:03	01:44	TRIPPED ON FAULT
6015	31-Dec-24	BANGALORE	66	LINE	66KV Kengeri SATELLITE TOWN - SIR MV LAYOUT	Kengeri SATELLITE TOWN	14:05	14:09	00:04	LINE CLEAR AVAILED
6016	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE, DODDERI	12:37	13:05	00:28	MAIN SUPPLY FAILURE
6017	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	12:37	12:57	00:20	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6018	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	NO STATION AFFECTED	12:57	15:10	02:13	LINE CLEAR AVAILED
6019	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KAMBIPURA	KAMBIPURA	12:37	13:00	00:23	MAIN SUPPLY FAILURE
6020	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	12:37	23:59	11:22	TRIPPED ON FAULT
6021	31-Dec-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	12:37	12:48	00:11	LINE CLEAR AVAILED
6022	31-Dec-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISc	06:17	06:20	00:03	LINE CLEAR AVAILED
6023	31-Dec-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - KUMBALAGODU 220	NO STATION AFFECTED	12:37	12:57	00:20	MAIN SUPPLY FAILURE
6024	31-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	NO STATION AFFECTED	23:58:00	23:59	00:01	LINE CLEAR AVAILED
6025	31-Dec-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML(EHT)	12:26	12:37	00:11	TRIPPED ON FAULT
6026	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	14:25	14:30	00:05	LINE CLEAR AVAILED
6027	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	GUDIBANDE	18:00	18:45	00:45	LINE CLEAR AVAILED
6028	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBALAGODU 220	12:37	12:57	00:20	MAIN SUPPLY FAILURE
6029	31-Dec-24	BANGALORE	220	TRANSFORMER	HV1	KUMBALAGODU 220	10:15	15:00	04:45	LINE CLEAR AVAILED
6030	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	11:23	11:28	00:05	TRIPPED ON FAULT
6031	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	12:40	12:50	00:10	LINE CLEAR AVAILED
6032	31-Dec-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	12:00	16:15	04:15	LINE CLEAR AVAILED
6033	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	15:15	15:35	00:20	TRIPPED ON FAULT
6034	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	G KODIHALLI	16:03	16:57	00:54	LINE CLEAR AVAILED
6035	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	03:55	04:05	00:10	TRIPPED ON FAULT
6036	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	16:30	18:45	02:15	LINE CLEAR AVAILED
6037	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	HOSUR RAMAPURA	11:05	11:20	00:15	TRIPPED ON FAULT
6038	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	KUMBALAGODU 220	12:37	12:57	00:20	MAIN SUPPLY FAILURE
6039	31-Dec-24	BANGALORE	220	TRANSFORMER	HV2	KUMBALAGODU 220	12:37	12:57	00:20	TRIPPED ON FAULT
6040	31-Dec-24	BANGALORE	66	TRANSFORMER	HV2	MALLASANDRA	14:10	14:35	00:25	LINE CLEAR AVAILED
6041	31-Dec-24	BANGALORE	220	TRANSFORMER	HV2	SAHAKARINAGAR 220	11:32	13:56	02:24	LINE CLEAR AVAILED
6042	31-Dec-24	BANGALORE	66	TRANSFORMER	HV3	KUMBALAGODU 220	12:37	12:57	00:20	MAIN SUPPLY FAILURE
6043	31-Dec-24	GULBARGA	110	LINE	APMC-CHICKSUGUR	CHICKSUGUR_110,SHAKTI NAGAR_110,KIADB	12:20	13:45	01:25	LINE CLEAR AVAILED
6044	31-Dec-24	GULBARGA	400	LINE	BTPS-GUTTUR	GUTTUR_400	08:02	20:06	12:04	LINE CLEAR AVAILED
6045	31-Dec-24	GULBARGA	110	LINE	GURMITKAL-SEDAM	GURMITKAL_110	23:15	23:30	00:15	TRIPPED ON FAULT
6046	31-Dec-24	GULBARGA	110	LINE	HALKUNDI-BISILAHALLI	BISIHALLI_110	17:09	17:50	00:41	MAIN SUPPLY FAILURE

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6047	31-Dec-24	GULBARGA	220	TRANSFORMER	HV&LV1	KUSTAGI_220	12:30	14:35	02:05	LINE CLEAR AVAILED
6048	31-Dec-24	GULBARGA	110	TRANSFORMER	HV1	GINIGERA_110	13:00	16:50	03:50	LINE CLEAR AVAILED
6049	31-Dec-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	16:30	16:35	00:05	TRIPPED ON FAULT
6050	31-Dec-24	GULBARGA	220	TRANSFORMER	HV1	SINDHANOOR_220	11:25	13:35	02:10	LINE CLEAR AVAILED
6051	31-Dec-24	GULBARGA	66	TRANSFORMER	HV2	CHORNUR_66	07:55	08:00	00:05	TRIPPED ON FAULT
6052	31-Dec-24	GULBARGA	66	TRANSFORMER	HV2	CHORNUR_66	09:20	09:25	00:05	TRIPPED ON FAULT
6053	31-Dec-24	GULBARGA	110	TRANSFORMER	HV2	GINIGERA_110	11:45	13:30	01:45	LINE CLEAR AVAILED
6054	31-Dec-24	GULBARGA	110	TRANSFORMER	HV3	GINIGERA_110	10:05	12:45	02:40	LINE CLEAR AVAILED
6055	31-Dec-24	GULBARGA	110	TRANSFORMER	HV5	MUNIRABAD_220	12:02	12:22	00:20	LINE CLEAR AVAILED
6056	31-Dec-24	GULBARGA	110	LINE	KIADB KUDITINI-KUDITINI	KUDITINI_110,TORANGAL U_110,METRI_110,KURUG OD_110,SATHAVAHANA_I PP,SIRIGERICROSS_110	19:09	19:30	00:21	TRIPPED ON FAULT
6057	31-Dec-24	GULBARGA	220	LINE	LINGAPUR-GUDDAHALLI1	LINGAPUR_220	10:00	15:07	05:07	LINE CLEAR AVAILED
6058	31-Dec-24	GULBARGA	110	LINE	MALLAT-KAVITHAL1	KAVITHAL_110	04:33	04:38	00:05	TRIPPED ON FAULT
6059	31-Dec-24	GULBARGA	110	LINE	MALLAT-MADLAPUR	ADAVIAMARESHWARA_110,MANVI,_MADLAPUR_110	03:45	03:50	00:05	TRIPPED ON FAULT
6060	31-Dec-24	GULBARGA	220	LINE	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	11:25(19.10.2024)			LINE CLEAR AVAILED
6061	31-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,ARASIKERE_66	02:43	02:49	00:06	TRIPPED ON FAULT
6062	31-Dec-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHANGIDURGA_66,BILCHOD_66,ARASIKERE_66	05:36	05:44	00:08	TRIPPED ON FAULT
6063	31-Dec-24	GULBARGA	66	LINE	PUNABHAGATTA-UCCHANGIDURGA	PUNABHAGATTA_66,UCC HANGIDURGA_66.ARASIKERE_66	16:15	17:40	01:25	LINE CLEAR AVAILED
6064	31-Dec-24	GULBARGA	110	LINE	RAICHUR-MATAMARI	MATAMARI_110	11:34	17:09	05:35	LINE CLEAR AVAILED
6065	31-Dec-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR-2	DEODURGA_110	04:49	05:01	00:12	TRIPPED ON FAULT
6066	31-Dec-24	GULBARGA	220	LINE	SULEKAL-AMPYIR SOLAR_IPP	SULEKAL_220	17:25	21:00	03:35	LINE CLEAR AVAILED
6067	31-Dec-24	HASAN	110	TRANSFORMER	HV1	GURUPURA_110	10:32	17:25	06:53	LINE CLEAR AVAILED
6068	31-Dec-24	HASAN	110	TRANSFORMER	HV1	KONDENALU_110	10:03	19:20	09:17	LINE CLEAR AVAILED
6069	31-Dec-24	HASAN	220	LINE	SHRAVITY-SHIRALKOPPA	sharavathy_gen	12:20	19:40	07:20	LINE CLEAR AVAILED
6070	31-Dec-24	HASAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	12:22	12:54	00:32	MAIN SUPPLY FAILURE
6071	31-Dec-24	HASAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	12:20	19:40	07:20	TRIPPED ON FAULT
6072	31-Dec-24	HASAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:22	12:45	00:23	MAIN SUPPLY FAILURE
6073	31-Dec-24	HASAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:53	13:45	02:52	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6074	31-Dec-24	HASAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	12:22	12:47	00:25	MAIN SUPPLY FAILURE
6075	31-Dec-24	MYSORE	66	LINE	ARAKERE-TUBINKERE	ARAKERE_66	09:46	14:23	04:36	LINE CLEAR AVAILED
6076	31-Dec-24	MYSORE	66	LINE	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66	09:25	09:39	00:14	TRIPPED ON FAULT
6077	31-Dec-24	MYSORE	66	LINE	BILIKERE-GV GUDI	NO STATIONS EFFECTED	11:54 (09/08/2024)			LINE CLEAR AVAILED
6078	31-Dec-24	MYSORE	66	LINE	DR PETE-SANTHEMARALLI	SANTHEMARAHALLI_66	22:43	22:57	00:13	TRIPPED ON FAULT
6079	31-Dec-24	MYSORE	66	LINE	HEBBANI-MEGALAPURA-CHIDRAVALLI	NO STATIONS EFFECTED	10:36	13:22	02:46	LINE CLEAR AVAILED
6080	31-Dec-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	19:21 (04/12/2024)			TRIPPED ON FAULT
6081	31-Dec-24	MYSORE	220	TRANSFORMER	HV1	KADAKOLA_220	08:21	09:08	00:47	LINE CLEAR AVAILED
6082	31-Dec-24	MYSORE	66	TRANSFORMER	HV1	KAGGERE HAMPAPURA_66	13:10	14:45	01:35	LINE CLEAR AVAILED
6083	31-Dec-24	MYSORE	66	TRANSFORMER	HV1	MARTAHALLI_66	12:12	12:15	00:02	LINE CLEAR AVAILED
6084	31-Dec-24	MYSORE	66	TRANSFORMER	HV1	MARTAHALLI_66	15:15	15:20	00:05	LINE CLEAR AVAILED
6085	31-Dec-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
6086	31-Dec-24	MYSORE	220	TRANSFORMER	HV2	KADAKOLA_220	06:13	08:20	02:06	LINE CLEAR AVAILED
6087	31-Dec-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	05:27	09:20	03:52	LINE CLEAR AVAILED
6088	31-Dec-24	MYSORE	66	LINE	KADAKOLA-GOLUR	NO STATIONS EFFECTED	05:25	09:22	03:57	LINE CLEAR AVAILED
6089	31-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-1	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
6090	31-Dec-24	MYSORE	66	LINE	KADAKOLA-VAJAMANAGALA-2	NO STATIONS EFFECTED	9:30 (27/11/2024)			LINE CLEAR AVAILED
6091	31-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	NO STATIONS EFFECTED	2:49 (3/12/2024)			TRIPPED ON FAULT
6092	31-Dec-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	ADDIHALLI_66, HARIYALDAMMATAMPLE_66	2:49 (3/12/2024)			TRIPPED ON FAULT
6093	31-Dec-24	MYSORE	66	LINE	MADHUVANAHALLI 220-HANNUR 2	NO STATIONS EFFECTED	19:46	19:51	00:04	TRIPPED ON FAULT
6094	31-Dec-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	05:23	09:16	03:52	LINE CLEAR AVAILED
6095	31-Dec-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	GUDDENAHALLI_66BOGADHI MANDYA_66	17:54	18:01	00:07	TRIPPED ON FAULT
6096	31-Dec-24	MYSORE	66	LINE	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66BSEEHALLI_66	11:05	12:44	01:39	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6097	31-Dec-24	TUMKUR	220	LINE	100MVA POWER TR-03 HIRIYUR 220KV	HIRIYUR 220KV	23:40 (31.12.24)	0:22 (01.01.2025)	0:42	TRIPPED ON FAULT
6098	31-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV BIDARIKERE & HOLALKERE	9:14	9:24	0:10	TRIPPED ON FAULT
6099	31-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV BIDARIKERE & HOLALKERE	13:13	13:40	0:27	TRIPPED ON FAULT
6100	31-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV BIDARIKERE & HOLALKERE	14:56	15:06	0:10	TRIPPED ON FAULT
6101	31-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV BIDARIKERE & HOLALKERE	15:09	16:09	1:00	TRIPPED ON FAULT
6102	31-Dec-24	TUMKUR	66	LINE	220KV CTA- 66KVTURUVANUR-66KV JAGALUR	66KV BIDARIKERE & HOLALKERE	16:20	22:40	6:20	LINE CLEAR AVAILED
6103	31-Dec-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV PARSHURAMPURA	66KV HARIYABBE,KALAMARANA HALLI	23:40	23:55	0:15	TRIPPED ON FAULT
6104	31-Dec-24	TUMKUR	66	LINE	220KV HOSADURGA-66KV BAGUR	66KV BAGURU	15:35	15:50	0:15	TRIPPED ON FAULT
6105	31-Dec-24	TUMKUR	66	LINE	66 KV INCOMING LINE (TELIGI LINE EXPORT)	66KV KURUBARAHALLI	2:40	2:55	0:15	TRIPPED ON FAULT
6106	31-Dec-24	TUMKUR	66	LINE	66 KV INCOMING LINE (TELIGI LINE EXPORT)	66KV KURUBARAHALLI	5:35	5:45	0:10	TRIPPED ON FAULT
6107	31-Dec-24	TUMKUR	66	LINE	66KV BILICHODU-66KV PALLAGATTE-66KV SOKKE	66KV PALLAGATTE,BILICHODU, SOKKE, JAGALURU	21:00	21:05	0:05	TRIPPED ON FAULT
6108	31-Dec-24	TUMKUR	66	LINE	CHITRADURGA 66KV- PANDARAHALLI - HOLALKERE LINE	PANDARAHALLI - HOLALKERE LINE, SASALUHALLA_66,KUTTIG AHALLI WATERHOUSE	9:00	14:00	5:00	LINE CLEAR AVAILED
6109	31-Dec-24	TUMKUR	66	LINE	DAVANGERE SRS 220-66KV KUKKAWADA 2 LINE	66KV KUKKAWADA 1 , SHYAGLE, THYAVANAGI,,BASAVAPAT NA, KEREILACHI, KNNL WW	21:12	21:33	0:21	TRIPPED ON FAULT
6110	31-Dec-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS LINE	GUTTUR_400	8:02	20:05	12:03	LINE CLEAR AVAILED
6111	31-Dec-24	TUMKUR	66	LINE	HOLALKERE- RAMGIRI 1	HOLALKERE_66	9:00	13:20	4:20	LINE CLEAR AVAILED

SL NO	Date	Tr_ZONE	Voltage	LINE/ TRANSFORMER	LINE	Station_Name	Open_At	Closed_At	Duration	REASON FOR INTERRUPTION
6112	31-Dec-24	TUMKUR	66	LINE	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKO NDA_66,SASALUHALLA_66	9:00	13:20	4:20	LINE CLEAR AVAILED
6113	31-Dec-24	TUMKUR	66	LINE	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	9:00	13:20	4:20	LINE CLEAR AVAILED
6114	31-Dec-24	TUMKUR	110	LINE	K.B.CROSS_220KV-KADEHALLI_110	KADEHALLI_110	16:55	16:58	0:03	LINE CLEAR AVAILED
6115	31-Dec-24	TUMKUR	110	LINE	K.B.CROSS_220KV-MAYASANDRA_110	110KV MAYSANDRA , KADEHALLI , TALKERE	16:55	16:58	0:03	LINE CLEAR AVAILED
6116	31-Dec-24	TUMKUR	110	LINE	K.B.CROSS_220KV-TALKERE110	TALKERE110	16:55	16:58	0:03	LINE CLEAR AVAILED
6117	31-Dec-24	TUMKUR	110	LINE	K.B.CROSS_220KV-THIMMANAHALLI_110	110KV THIMMANAHALLI, KATHRIKEHAL	16:45	16:52	0:07	LINE CLEAR AVAILED
6118	31-Dec-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMGHATTA,	6:09	6:17	0:08	TRIPPED ON FAULT
6119	31-Dec-24	TUMKUR	66	LINE	SIRA_220-SIRA_66 2 (KIADB-2)	66KV KIADB, DODDAAGRAHARA , ANKASANDRA	6:02	6:12	0:10	TRIPPED ON FAULT
6120	31-Dec-24	TUMKUR	66	LINE	SIRA_220-SIRA_66 2 (KIADB-2)	66KV KIADB, DODDAAGRAHARA , ANKASANDRA	18:09	18:20	0:11	TRIPPED ON FAULT
6121	31-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA	6:02	6:12	0:10	TRIPPED ON FAULT
6122	31-Dec-24	TUMKUR	66	LINE	SIRA220-SIRA66 1 (KIADB-1)	66KV KIADB, KALLAMBELLA	18:09	18:20	0:11	TRIPPED ON FAULT
6123	31-Dec-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	CHITRAHALLI_66	20:30	20:35	0:05	TRIPPED ON FAULT