

400/220/110/66 kV TRANSMISSION OUTAGES FOR THE MONTH OF APRIL-2024

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1	01-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV3	ATHANI_220	06:43	06:47	00:04	LINE CLEAR AVAILED
2	01-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV3	ATHANI_220	12:13	12:16	00:03	LINE CLEAR AVAILED
3	01-Apr-24	BAGALKOTE	LINE	110	AEQUS220-LN4(HATTARGI)	STATION NOT AFFECTED AEQUS_220	17:21	17:34	00:13	TRIPPED ON FAULT
4	01-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
5	01-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
6	01-Apr-24	BAGALKOTE	LINE	110	BABLESHW-MAMADAPURA	BABLESHWAR_110	16:26	18:54	02:28	LINE CLEAR AVAILED
7	01-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
8	01-Apr-24	BAGALKOTE	LINE	110	DAMBAL-EILS(L1)	ENRGON_110 DAMBAL_110	04:29	04:47	00:18	TRIPPED ON FAULT
9	01-Apr-24	BAGALKOTE	LINE	110	GADAG ROAD- BIDNAL(GOPANAKOPPA)	GADAG ROAD_110	14:28	17:06	02:38	TRIPPED ON FAULT
10	01-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	10:55	17:35	06:40	LINE CLEAR AVAILED
11	01-Apr-24	BAGALKOTE	LINE	110	GOPANAKOPPA- GADAG ROAD	GOPANAKOPPA_110	14:36	17:47	03:11	LINE CLEAR AVAILED
12	01-Apr-24	BAGALKOTE	LINE	110	GOPANA-MRNAGAR2 (MRT 1)	GOPANKOPPA_110	17:19 (30.03.2024)	14:36 (01.04.2024)	21:17:00	LINE CLEAR AVAILED
13	01-Apr-24	BAGALKOTE	LINE	110	HIDIKAL DAM- GHATAPRABHA	HIDIKAL DAM_110	17:28	17:48	00:20	LINE CLEAR AVAILED
14	01-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI	HIDIKAL DAM _110	13:31 (31.03.2024)	17:28 (01.04.2024)	27:57:00	LINE CLEAR AVAILED
15	01-Apr-24	BAGALKOTE	LINE	110	HIREBEVNUR- INDI-LACHYAN (RODAGI)	HIREBEVNUR_110	15:46	15:57	00:11	TRIPPED ON FAULT
16	01-Apr-24	BAGALKOTE	LINE	110	HUBLI- SIRSI1	HUBLI_220	10:32	16:21	05:49	LINE CLEAR AVAILED
17	01-Apr-24	BAGALKOTE	LINE	110	HUBLI- SIRSI2	HUBLI_220	10:32	16:23	05:51	LINE CLEAR AVAILED
18	01-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
19	01-Apr-24	BAGALKOTE	LINE	110	KALGHATAGI- ABS SOLAR	KALGHATAGI_110	18:01	18:02	00:01	LINE CLEAR AVAILED
20	01-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
21	01-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
22	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BABLESHWAR	MAMDAPUR(B)_110	16:45	18:14	01:29	LINE CLEAR AVAILED
23	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI1	MAMDAPUR(B)_110	04:37	04:42	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
24	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI1	MAMDAPUR(B)_110	16:45	18:14	01:29	LINE CLEAR AVAILED
25	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI2	MAMDAPUR(B)_110	06:26	06:32	00:06	LINE CLEAR AVAILED
26	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI2	MAMDAPUR(B)_110	16:35	18:14	01:39	LINE CLEAR AVAILED
27	01-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- TODALBAGI	MAMDAPUR(B)_110	18:14	18:37	00:23	LINE CLEAR AVAILED
28	01-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
29	01-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
30	01-Apr-24	BAGALKOTE	LINE	110	RONIHAL- F1(BAGEWADI)	RONIHAL_110	06:05	06:33	00:28	TRIPPED ON FAULT
31	01-Apr-24	BAGALKOTE	LINE	110	RONIHAL- F2(MAMDAPUR)	RONIHAL_110	16:32	18:09	01:37	LINE CLEAR AVAILED
32	01-Apr-24	BAGALKOTE	LINE	110	SANKESHWAR-HIRASUGARS	SANKESHWAR_110	17:23	18:30	01:07	LINE CLEAR AVAILED
33	01-Apr-24	BAGALKOTE	LINE	110	SANKESHWAR-HIRASUGARS	SANKESHWAR_110	18:33	18:48	00:15	LINE CLEAR AVAILED
34	01-Apr-24	BAGALKOTE	LINE	110	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 TODALBAGI_110	23:41	23:55	00:14	TRIPPED ON FAULT
35	01-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
36	01-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
37	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	BISNAL_110	10:50	10:59	00:09	TRIPPED ON FAULT
38	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(20MVA)	MRUTHYUNJAY NAGAR_110	10:40	11:48	01:08	LINE CLEAR AVAILED
39	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	BISNAL_110	10:50	10:59	00:09	TRIPPED ON FAULT
40	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	08:10	08:50	00:40	TRIPPED ON FAULT
41	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	TUMMINAKATTI_110	10:00	10:20	00:20	LINE CLEAR AVAILED
42	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	ALNAVAR_110	13:52	14:27	00:35	LINE CLEAR AVAILED
43	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	ANAND NAGAR_110	08:17	10:34	02:17	LINE CLEAR AVAILED
44	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV1 (20MVA)	BISNAL_110	10:50	10:59	00:09	TRIPPED ON FAULT
45	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (10MVA)	ZALKI_110	14:30	15:23	00:53	TRIPPED ON FAULT
46	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4 (20MVA)	ZALKI_110	15:03	15:13	00:10	TRIPPED ON FAULT
47	01-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV2(20MVA)	RATHIHAL_110	23:28	23:31	00:03	TRIPPED ON FAULT
48	01-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	ATHANI_220	02:15	06:44	04:29	TRIPPED ON FAULT
49	01-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	ATHANI_220	12:54	13:14	00:20	TRIPPED ON FAULT
50	01-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	07:32	07:53	00:21	TRIPPED ON FAULT
51	01-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - VIDYANAGAR	VIDYANAGARA	13:13	13:15	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
52	01-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	13:17	14:51	01:34	TRIPPED ON FAULT
53	01-Apr-24	BENGALURU	LINE	66	66KV GOKULA - HMT EHT	HMT(EHT)	07:02	08:09	01:07	TRIPPED ON FAULT
54	01-Apr-24	BENGALURU	LINE	66	66KV GUNDLU KOTHUR - BAGEPALLI	BAGEPALLI	17:05	17:15	00:10	LINE CLEAR AVAILED
55	01-Apr-24	BENGALURU	LINE	66	66KV HEBBAL 220 - C STATION 1	C STATION	13:13	13:38	00:25	MAIN SUPPLY FAILURE
56	01-Apr-24	BENGALURU	LINE	66	66KV HEBBAL 220 - C STATION 2	C STATION	13:13	13:38	00:25	MAIN SUPPLY FAILURE
57	01-Apr-24	BENGALURU	LINE	66	66KV HEBBAL 220 - IISC	IISc	13:13	13:19	00:06	MAIN SUPPLY FAILURE
58	01-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	06:01	06:56	00:55	TRIPPED ON FAULT
59	01-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	16:44	16:47	00:03	LINE CLEAR AVAILED
60	01-Apr-24	BENGALURU	LINE	66	66KV NRS 220 - IISC	IISc	22:14	22:20	00:06	LINE CLEAR AVAILED
61	01-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR	17:35	18:35	01:00	TRIPPED ON FAULT
62	01-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	14:21	14:29	00:08	MAIN SUPPLY FAILURE
63	01-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	14:21	14:31	00:10	TRIPPED ON FAULT
64	01-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	14:21	14:29	00:08	MAIN SUPPLY FAILURE
65	01-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO(HV1), GLOBAL TECH PARK	14:21	14:29	00:08	MAIN SUPPLY FAILURE
66	01-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	14:21	14:29	00:08	MAIN SUPPLY FAILURE
67	01-Apr-24	BENGALURU	LINE	66	66KV SULIBELE - CHANNARAYAPATNA	CHANNARAYAPATNA	13:17	14:51	01:34	TRIPPED ON FAULT
68	01-Apr-24	BENGALURU	LINE	220	220KV KHODAYS 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 220	14:21	14:29	00:08	TRIPPED ON FAULT
69	01-Apr-24	BENGALURU	LINE	220	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	HEBBALA 220	13:13	13:41	00:28	MAIN SUPPLY FAILURE
70	01-Apr-24	BENGALURU	LINE	220	220KV NELAMANGALA 400 - SAHAKARNAGAR 220	HEBBALA 220, CPRI 220	13:13	13:25	00:12	TRIPPED ON FAULT
71	01-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUMBALAGODU 220	14:10	14:23	00:13	TRIPPED ON FAULT
72	01-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TALAGAWARA	11:49	12:00	00:11	LINE CLEAR AVAILED
73	01-Apr-24	BENGALURU	TRANSFORMER	66	HV1	CHELUR	13:30	13:40	00:10	TRIPPED ON FAULT
74	01-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BRIGADE METROPOLIS	17:45	17:47	00:02	LINE CLEAR AVAILED
75	01-Apr-24	BENGALURU	TRANSFORMER	66	HV2	RBI	12:24	12:50	00:26	TRIPPED ON FAULT
76	01-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KOLAR 220	15:03	17:35	02:32	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
77	01-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NANGLI	23:01	23:08	00:07	TRIPPED ON FAULT
78	01-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MALUR 220	06:01	06:27	00:26	TRIPPED ON FAULT
79	1-Apr-2024	GULBARGA	LINE	66	HALVAGALU-LIS EHT	LIS NITTUR(EHT)KNNL	22:33	23:05	00:32	TRIPPED ON FAULT
80	1-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66, TBPCL	18:54	19:06	00:12	TRIPPED ON FAULT
81	1-Apr-2024	GULBARGA	LINE	66	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_ HALLI_66	18:53	19:03	00:10	TRIPPED ON FAULT
82	1-Apr-2024	GULBARGA	LINE	110	CHOWDAPUR-SAGNOOR	KAPNOOR_110	01:16	01:21	00:05	MAIN SUPPLY FAILURE
83	1-Apr-2024	GULBARGA	LINE	110	KADECHUR-SAIDAPUR	SAIDAPUR_110	06:02	06:07	00:05	TRIPPED ON FAULT
84	1-Apr-2024	GULBARGA	LINE	110	KADECHUR-SAIDAPUR	SAIDAPUR_110	04:15	04:25	00:10	TRIPPED ON FAULT
85	1-Apr-2024	GULBARGA	LINE	110	MALLAT-KAVITAL	KAVITAL_110	04:28	04:36	00:08	TRIPPED ON FAULT
86	1-Apr-2024	GULBARGA	LINE	110	MALLAT-MADALAPUR	ADAVIAMARESHWAR_1 10, MANVI_110, MADLAPUR_110	21:06	21:12	00:06	TRIPPED ON FAULT
87	1-Apr-2024	GULBARGA	LINE	110	SEDAM-KURKUNTA	KURKUNTA_110	13:55	14:10	00:15	TRIPPED ON FAULT
88	1-Apr-2024	GULBARGA	TRANSFORMER	110	HV3	SOMASAMUNDRA_110	13:27	13:40	00:13	TRIPPED ON FAULT
89	01-Apr-24	HASSAN	LINE	66	HNPR2-HNPR1	HNPURA_220	22:21	22:36	00:15	TRIPPED ON FAULT
90	01-Apr-24	HASSAN	LINE	66	HNPURA-SOMANAHALLI	HNPURA_66	22:20	22:41	00:21	MAIN SUPPLY FAILURE
91	01-Apr-24	HASSAN	LINE	66	TAVAREC-HONALI	TAVARECHETTANAHAL LY_66	12:05	12:20	00:15	TRIPPED ON FAULT
92	01-Apr-24	HASSAN	LINE	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:32	11:44	00:12	TRIPPED ON FAULT
93	01-Apr-24	HASSAN	LINE	110	BAIKAM-KAVOOR	BAIKAMPADY_110	06:57	07:08	00:11	TRIPPED ON FAULT
94	01-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 1	PUTTUR_220	21:06	21:41	00:35	TRIPPED ON FAULT
95	01-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 2	PUTTUR_220	21:06	21:41	00:35	TRIPPED ON FAULT
96	01-Apr-24	HASSAN	TRANSFORMER	110	HV1	GANDASI_110	12:03	15:15	03:12	LINE CLEAR AVAILED
97	01-Apr-24	HASSAN	TRANSFORMER	110	HV1	KONAJE_110	14:29	16:21	01:52	LINE CLEAR AVAILED
98	01-Apr-24	HASSAN	TRANSFORMER	110	HV3	PUTTUR_110	21:05(1.04.2024)			TRIPPED ON FAULT
99	1-Apr-24	MYSORE	LINE	66	BEGUR 220-SARGUR	BGPURA_66CHIDRAVAL LI_66THUMBLA_66GAR GESHWARI_66VYASRAJ PURA_66SANTHESARA GUR_66HDKOTE_66CHA NDRAVADI_66HURA_66 HAMPAPURA(K)_66ANT HARSANTHE_66	10:08:00	10:19:00	00:11:00	TRIPPED ON FAULT
100	1-Apr-24	MYSORE	LINE	66	CR NAGARA-KOLLEGALA	JANNUR_66TNARASIPU RA_66THAYUR_66MUG UR_66	19:01:00	19:10:00	00:09:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
101	1-Apr-24	MYSORE	LINE	66	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
102	1-Apr-24	MYSORE	LINE	66	HAMPAPURA-SARGUR	YEREHALLIHANDPOST_66,HDKOTE_66,ANTHAR SANTHE_66	05:03:00	05:13:00	00:10:00	TRIPPED ON FAULT
103	1-Apr-24	MYSORE	LINE	66	HEBBANI-MEGALAPURA	BGPURA_66CHIDRAVALI_66THUMBLA_66GARGESHWARI_66VYASRAJ PURA_66	05:39:00	05:52:00	00:13:00	TRIPPED ON FAULT
104	1-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
105	1-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	07:55:00	09:23:00	01:28:00	TRIPPED ON FAULT
106	1-Apr-24	MYSORE	LINE	66	KABALLI-GUNDLUPETE	NO STATIONS EFFECTED	23:15 (1/04/2024)			TRIPPED ON FAULT
107	1-Apr-24	MYSORE	LINE	66	KADAKOLA -KOZHIKODE	NO STATIONS EFFECTED	20:43 (1/04/2024)			LINE CLEAR AVAILED
108	1-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
109	1-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
110	1-Apr-24	MYSORE	LINE	66	MUGUR-CR NAGARA	JANNUR_66TNARASIPURA_66THAYUR_66	19:00:00	19:09:00	00:09:00	TRIPPED ON FAULT
111	1-Apr-24	MYSORE	LINE	66	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	02:16:00	02:21:00	00:05:00	TRIPPED ON FAULT
112	1-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	22:30:00	22:35:00	00:05:00	TRIPPED ON FAULT
113	1-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:38 (31/03/2024)	7:48 (1/04/2024)	11:10 HRs	LINE CLEAR AVAILED
114	1-Apr-24	MYSORE	TRANSFORMER	66	HV1	ADICHUNCHANAGIRI_66	7:45 (31/03/2024)	12:30 (01/04/2024)	28:45 HRs	LINE CLEAR AVAILED
115	1-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
116	1-Apr-24	MYSORE	TRANSFORMER	220	HV1	CRNAGARA_220	08:45:00	14:12:00	05:27:00	LINE CLEAR AVAILED
117	1-Apr-24	MYSORE	TRANSFORMER	220	HV2	CRNAGARA_220	14:45:00	18:19:00	03:34:00	LINE CLEAR AVAILED
118	01-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	22:36	22:42	00:06	TRIPPED ON FAULT
119	01-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	09:50	09:55	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
120	01-Apr-24	TUMKUR	LINE	66	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	04:31	04:41	00:10	TRIPPED ON FAULT
121	01-Apr-24	TUMKUR	LINE	66	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	06:02	06:12	00:09	TRIPPED ON FAULT
122	01-Apr-24	TUMKUR	LINE	66	KOLALA- ANTHRASANAHALLI	URDIGERE_66, KOLALA_66	17:55	18:05	00:10	MAIN SUPPLY FAILURE
123	01-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- PULLAMAGATTA	PULLAMGATTA_66	06:03	06:18	00:15	TRIPPED ON FAULT
124	01-Apr-24	TUMKUR	LINE	66	PDKOTE-HARIYABBE	PDKOTE_66	14:02	14:10	00:07	LINE CLEAR AVAILED
125	01-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- BTPS	GUTTUR_400	8:05(29.03.2024)		-	LINE CLEAR AVAILED
126	01-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	12:07	16:42	04:34	TRIPPED ON FAULT
127	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHANNAGIRI_66	02:15	02:42	00:26	TRIPPED ON FAULT
128	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	LOKIKERE_66	19:28	19:37	00:09	TRIPPED ON FAULT
129	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	MADAKERE_66	12:54	13:04	00:09	TRIPPED ON FAULT
130	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	PANDARAHALLI_66	17:57	18:10	00:12	LINE CLEAR AVAILED
131	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	SOKKE_66	07:32	07:42	00:09	TRIPPED ON FAULT
132	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	URDIGERE_66	15:22	18:11	02:48	LINE CLEAR AVAILED
133	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KOLALA_66	08:30	08:38	00:08	TRIPPED ON FAULT
134	01-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	08:33	08:37	00:04	TRIPPED ON FAULT
135	02-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
136	02-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
137	02-Apr-24	BAGALKOTE	LINE	110	BAGEWADI220- DEVARHIPPARAGI	BAGEWADI_220	13:30	16:35	03:05	TRIPPED ON FAULT
138	02-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
139	02-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
140	02-Apr-24	BAGALKOTE	LINE	110	KERUR- BADAMI	KERUR_110	09:06	09:22	00:16	TRIPPED ON FAULT
141	02-Apr-24	BAGALKOTE	LINE	110	KULAGERI CROSS- MRN SUGARS	KULAGERI CROSS_110	09:06	09:14	00:08	TRIPPED ON FAULT
142	02-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
143	02-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
144	02-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
145	02-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
146	02-Apr-24	BAGALKOTE	LINE	110	SANKESHWAR- HSFCG1	SANKESHWAR_110	14:25	16:07	01:42	LINE CLEAR AVAILED
147	02-Apr-24	BAGALKOTE	LINE	110	SANKESHWAR- HSFCG2	SANKESHWAR_110	14:23	16:45	02:22	LINE CLEAR AVAILED
148	02-Apr-24	BAGALKOTE	LINE	110	THORVI- BHUTNAL	THORVI_110	13:17	13:28	00:11	TRIPPED ON FAULT
149	02-Apr-24	BAGALKOTE	LINE	110	THORVI- TIKOTA	THORVI_110	01:42	01:50	00:08	TRIPPED ON FAULT
150	02-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
151	02-Apr-24	BAGALKOTE	LINE	220	DHONI- HALVARTHI	DHONI_400	13:39	17:47	04:08	TRIPPED ON FAULT
152	02-Apr-24	BAGALKOTE	LINE	220	KARWAR- KADRA1	KARWAR_220	16:34	18:15	01:41	LINE CLEAR AVAILED
153	02-Apr-24	BAGALKOTE	LINE	220	KARWAR- KADRA2	KARWAR_220	16:35	17:40	01:05	LINE CLEAR AVAILED
154	02-Apr-24	BAGALKOTE	LINE	220	NARENDRA- BIDNAL	NARENDRA_220	06:18	14:14	07:56	TRIPPED ON FAULT
155	02-Apr-24	BAGALKOTE	LINE	220	NARENDRA- SHIGGOAN	NARENDRA_220	10:55	14:16	03:21	LINE CLEAR AVAILED
156	02-Apr-24	BAGALKOTE	LINE	220	SHIGGOAN- NARENDRA	SHIGGOAN_220	10:56	14:16	03:20	LINE CLEAR AVAILED
157	02-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
158	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	ITANAL_110	13:00	13:27	00:27	LINE CLEAR AVAILED
159	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	GANESHGUDI_110	15:42	16:24	00:42	LINE CLEAR AVAILED
160	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	CHIKKODI_110	16:05	17:15	01:10	LINE CLEAR AVAILED
161	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	GOPANAKOPPA_110	14:00	15:13	01:13	LINE CLEAR AVAILED
162	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	CHIKKODI_110	18:10	18:30	00:20	LINE CLEAR AVAILED
163	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV3 (10 MVA)	SINDAGI_110	8:20 (02.04.2024)			LINE CLEAR AVAILED
164	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV1(20MVA)	MK HUBLI_110	05:53	07:24	01:31	TRIPPED ON FAULT
165	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV2(20MVA)	GANESHGUDI_110	14:57	15:43	00:46	LINE CLEAR AVAILED
166	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4(20MVA)	GOPANAKOPPA_110	13:36	15:28	01:52	LINE CLEAR AVAILED
167	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV1(20MVA)	TIKOTA_110	19:15	19:20	00:05	TRIPPED ON FAULT
168	02-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3(10 MVA)	ZALKI_110	15:01	15:29	00:28	TRIPPED ON FAULT
169	02-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	ATHANI_220	15:58	16:04	00:06	TRIPPED ON FAULT
170	02-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
171	02-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - VIDYANAGARA	VIDYANAGARA	17:45	17:50	00:05	LINE CLEAR AVAILED
172	02-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	06:33	09:52	03:19	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
173	02-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	07:37	07:48	00:11	TRIPPED ON FAULT
174	02-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	18:54	19:09	00:15	TRIPPED ON FAULT
175	02-Apr-24	BENGALURU	LINE	66	66KV KANAKAPURA 220 - ACCHALU	ACHALU, HONNIGANAHALLI, HALAGUR	20:07	20:17	00:10	TRIPPED ON FAULT
176	02-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVENAGUNDHI	17:50	18:00	00:10	LINE CLEAR AVAILED
177	02-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	13:26	13:35	00:09	TRIPPED ON FAULT
178	02-Apr-24	BENGALURU	LINE	66	66KV MELEHALLI - JALAMANGALA	JALAMANGALA, CHIKKAGANGANAWADI, KUTAGAL, MATHIKERE	18:23	18:39	00:16	TRIPPED ON FAULT
179	02-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLI	17:12	17:18	00:06	LINE CLEAR AVAILED
180	02-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	03:00	03:16	00:16	TRIPPED ON FAULT
181	02-Apr-24	BENGALURU	LINE	66	66KV T D HALLI (MALLASANDRA) - DALASANUR	DALASANUR	16:25	16:30	00:05	LINE CLEAR AVAILED
182	02-Apr-24	BENGALURU	LINE	66	66KV TUBAGERE - CB PURA I/A 1	TUBAGERE	03:00	03:17	00:17	TRIPPED ON FAULT
183	02-Apr-24	BENGALURU	LINE	220	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	15:20	15:39	00:19	TRIPPED ON FAULT
184	02-Apr-24	BENGALURU	TRANSFORMER	66	HV1	JADIGENAHALLI	14:45	16:00	01:15	LINE CLEAR AVAILED
185	02-Apr-24	BENGALURU	TRANSFORMER	66	HV1	CHELUR	15:45	15:50	00:05	LINE CLEAR AVAILED
186	02-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MALLASANDRA	08:50	08:51	00:01	LINE CLEAR AVAILED
187	02-Apr-24	BENGALURU	TRANSFORMER	66	HV1	S M MANGALA	15:06	15:27	00:21	TRIPPED ON FAULT
188	02-Apr-24	BENGALURU	TRANSFORMER	66	HV2	PILLAGUMPA	09:40	10:20	00:40	TRIPPED ON FAULT
189	02-Apr-24	BENGALURU	TRANSFORMER	66	HV2	PILLAGUMPA	10:35	12:15	01:40	LINE CLEAR AVAILED
190	02-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VIDYANAGARA	17:13	17:50	00:37	LINE CLEAR AVAILED
191	02-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	17:05	17:20	00:15	TRIPPED ON FAULT
192	02-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BEVOOR	03:56	04:01	00:05	TRIPPED ON FAULT
193	2-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66, TBPCL	18:57	19:11	00:14	TRIPPED ON FAULT
194	2-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	12:30	13:02	00:32	LINE CLEAR AVAILED
195	2-Apr-2024	GULBARGA	LINE	110	ADAVIAMARESHWAR-JAWALGERA	JAWALGERA_110	14:44	15:26	00:42	TRIPPED ON FAULT
196	2-Apr-2024	GULBARGA	LINE	110	JAWALGERA-WALABALLARI	JAWALGERA_110	04:06	04:16	00:10	TRIPPED ON FAULT
197	2-Apr-2024	GULBARGA	LINE	110	MANVI-MALLAT	MANVI_110	14:43	14:50	00:07	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
198	2-Apr-2024	GULBARGA	LINE	110	RAMASAMUDRA-YADGIR	YADGIR_110	05:15	05:25	00:10	TRIPPED ON FAULT
199	2-Apr-2024	GULBARGA	LINE	110	SANTHAPUR-JANAWADA	JANAWADA_110	08:40	00:00	15:20	LINE CLEAR AVAILED
200	2-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-MARALIHALLA	MUKUNDA_110	11:05	11:15	00:10	TRIPPED ON FAULT
201	2-Apr-2024	GULBARGA	LINE	220	HALWARTHY-DONI2	HALWARTHY_220	13:40	17:46	04:06	TRIPPED ON FAULT
202	2-Apr-2024	GULBARGA	LINE	220	KUDALGI-HMH1	KUDALGI_220	04:15	04:45	00:30	TRIPPED ON FAULT
203	2-Apr-2024	GULBARGA	LINE	220	LINGAPUR-JVSL1	LINGAPUR_220	08:45	19:08	10:23	LINE CLEAR AVAILED
204	2-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-MALLAT	MALLAT_220	10:54	11:15	00:21	TRIPPED ON FAULT
205	2-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-FEROZABAD2	SHAHAPUR_220	11:09	14:25	03:16	TRIPPED ON FAULT
206	02-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	04:57	05:19	00:22	TRIPPED ON FAULT
207	02-Apr-24	HASSAN	LINE	110	ANAVATI-JADE	ANAVATTI_110	11:35	13:00	01:25	LINE CLEAR AVAILED
208	02-Apr-24	HASSAN	LINE	110	ANVATTI-BARANG	SHIRALKOPPA_220	12:10	12:21	00:11	LINE CLEAR AVAILED
209	02-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	16:06	16:12	00:06	TRIPPED ON FAULT
210	02-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	07:52	08:46	00:54	TRIPPED ON FAULT
211	02-Apr-24	HASSAN	LINE	110	MADHUV-KUNDAPURA	MADHUVANA_110	15:04	15:33	00:29	LINE CLEAR AVAILED
212	02-Apr-24	HASSAN	LINE	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:10	12:22	00:12	LINE CLEAR AVAILED
213	02-Apr-24	HASSAN	TRANSFORMER	66	HV1	ALDUR_66	07:30	07:54	00:24	TRIPPED ON FAULT
214	02-Apr-24	HASSAN	TRANSFORMER	66	HV1	MALLIPATNA_66	04:55	05:15	00:20	MAIN SUPPLY FAILURE
215	02-Apr-24	HASSAN	TRANSFORMER	66	HV2	BELUR_66	10:10	10:20	00:10	TRIPPED ON FAULT
216	02-Apr-24	HASSAN	TRANSFORMER	66	HV2	BELUR_66	14:50	14:55	00:05	TRIPPED ON FAULT
217	02-Apr-24	HASSAN	TRANSFORMER	66	HV2	HOLEHONNUR_66	10:25	10:51	00:26	LINE CLEAR AVAILED
218	02-Apr-24	HASSAN	TRANSFORMER	110	HV2	ANAVATTI_110	13:00	13:05	00:05	TRIPPED ON FAULT
219	02-Apr-24	HASSAN	TRANSFORMER	110	HV3	PUTTUR_110	21:05(1.04.2024)	14:05(2.04.2024)	18:00HRS	LINE CLEAR AVAILED
220	2-Apr-24	MYSORE	LINE	66	BILIKERE-KR NAGARA	BILIKERE_66	19:30:00	19:51	00:21	TRIPPED ON FAULT
221	2-Apr-24	MYSORE	LINE	66	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
222	2-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
223	2-Apr-24	MYSORE	LINE	66	KABALLI-GUNDLUPETE	NO STATIONS EFFECTED	23:15 (1/04/2024)	20:00:00 (2/4/24)	20:45 HRs	TRIPPED ON FAULT
224	2-Apr-24	MYSORE	LINE	66	KADAKOLA -KOZHIKODE	NO STATIONS EFFECTED	20:43 (1/04/2024)	6:25:00 (2/4/2024)	9:42 HRS	LINE CLEAR AVAILED
225	2-Apr-24	MYSORE	LINE	66	KADAKOLA -KOZHIKODE	NO STATIONS EFFECTED	20:49:00 (2/4/2024)			LINE CLEAR AVAILED
226	2-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
227	2-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MADIKERI 1	MADIKERI_66 SUNTIKOPPA_66	8:38:00	09:57	01:19	LINE CLEAR AVAILED
228	2-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MADIKERI 2	MADIKERI_66 SUNTIKOPPA_66	8:39:00	09:57	01:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
229	2-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
230	2-Apr-24	MYSORE	LINE	66	LOKKANAHALLI-PG PALYA	PG PALYA_66	14:00:00	14:05	00:05	TRIPPED ON FAULT
231	2-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	23:11:00	23:21	00:10	LINE CLEAR AVAILED
232	2-Apr-24	MYSORE	TRANSFORMER	66	HV1	MUGUR_66	22:22:00	22:27	00:05	TRIPPED ON FAULT
233	2-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
234	2-Apr-24	MYSORE	TRANSFORMER	66	HV2	HALAGURU_66	20:06:00			TRIPPED ON FAULT
235	2-Apr-24	MYSORE	TRANSFORMER	66	HV2	BILIKERE_66	19:30:00			TRIPPED ON FAULT
236	2-Apr-24	MYSORE	TRANSFORMER	66	HV2	HALAGURU_66	20:06 (02/04/2024)	14:45 (03/04/2024)	18:39 HRs	TRIPPED ON FAULT
237	02-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	16:42	17:39	00:57	LINE CLEAR AVAILED
238	02-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	15:15	16:27	01:11	TRIPPED ON FAULT
239	02-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALI 220KV- BELLAVI	BELLAVI_66	10:55	11:17	00:22	TRIPPED ON FAULT
240	02-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66	18:42	19:03	00:21	TRIPPED ON FAULT
241	02-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	21:05	21:15	00:10	TRIPPED ON FAULT
242	02-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	01:36	01:49	00:13	LINE CLEAR AVAILED
243	02-Apr-24	TUMKUR	LINE	66	CHAWDANKUPPE-ESENGY_SLR	ESENGY_SLR	15:23	16:28	01:04	MAIN SUPPLY FAILURE
244	02-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	13:13	13:24	00:11	TRIPPED ON FAULT
245	02-Apr-24	TUMKUR	LINE	66	HARIYABBE-HIRIYUR	HARIYABBE_66	07:02	17:30	10:28	LINE CLEAR AVAILED
246	02-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	07:12	15:57	08:45	LINE CLEAR AVAILED
247	02-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	HARIYABBE_66,PDKOT E_66	07:12	15:57	08:45	LINE CLEAR AVAILED
248	02-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:44	11:54	00:10	TRIPPED ON FAULT
249	02-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	12:21	12:31	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
250	02-Apr-24	TUMKUR	LINE	66	KEREBILCHI-DAVANGERE 220	KEREBILCHI_66	03:30	03:35	00:05	MAIN SUPPLY FAILURE
251	02-Apr-24	TUMKUR	LINE	66	KEREBILCHI-DAVANGERE 220	KEREBILCHI_66	21:05	21:15	00:10	MAIN SUPPLY FAILURE
252	02-Apr-24	TUMKUR	LINE	66	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	12:22	14:01	01:38	TRIPPED ON FAULT
253	02-Apr-24	TUMKUR	LINE	66	TMTP66-BRAHMASANDRA	BRAHMASANDRA_66, ANANKSANDRA_66	15:56	16:05	00:09	TRIPPED ON FAULT
254	02-Apr-24	TUMKUR	LINE	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,THA LKERE_110	13:29	13:56	00:27	TRIPPED ON FAULT
255	02-Apr-24	TUMKUR	LINE	220	JAGALUR 400kV-KODLIGI1	JAGALUR 400kV	04:15	06:03	01:47	TRIPPED ON FAULT
256	02-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- BTPS	GUTTUR_400	8:05(29.03.2024)	17:34 (2.4.2024)	4days 9:29 Hrs	LINE CLEAR AVAILED
257	02-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHANNAGIRI_66	10:00	10:05	00:05	TRIPPED ON FAULT
258	02-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRADURGA_66	09:28	09:40	00:11	TRIPPED ON FAULT
259	02-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	KORATAGERE_66	19:30	19:35	00:05	TRIPPED ON FAULT
260	02-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	LINGADAHALLI_66	09:50	10:40	00:50	LINE CLEAR AVAILED
261	02-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	SIRA_220	11:53	12:08	00:15	TRIPPED ON FAULT
262	03-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
263	03-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
264	03-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	06:05	06:21	00:16	TRIPPED ON FAULT
265	03-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
266	03-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
267	03-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
268	03-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
269	03-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
270	03-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- ITANAL2	MUGALKHOD_220	09:31	11:28	01:57	LINE CLEAR AVAILED
271	03-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
272	03-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
273	03-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
274	03-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2	CHIKKODI_110	12:00	16:20	04:20	LINE CLEAR AVAILED
275	03-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV3 (10 MVA)	SINDAGI_110	8:20 (02.04.2024)			LINE CLEAR AVAILED
276	03-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4(20MVA)	ANKALI_110	06:10	06:42	00:32	TRIPPED ON FAULT
277	03-Apr-24	BENGALURU	LINE	66	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	23:13	23:42	00:29	TRIPPED ON FAULT
278	03-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
279	03-Apr-24	BENGALURU	LINE	66	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	05:50	06:00	00:10	TRIPPED ON FAULT
280	03-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDLAGHATTA, MELUR	09:32	09:50	00:18	TRIPPED ON FAULT
281	03-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDLAGHATTA, MELUR	13:03	13:32	00:29	LINE CLEAR AVAILED
282	03-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDLAGHATTA, MELUR	05:54	06:06	00:12	TRIPPED ON FAULT
283	03-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDLAGHATTA, MELUR	13:02	13:32	00:30	LINE CLEAR AVAILED
284	03-Apr-24	BENGALURU	LINE	66	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL NORTON(EHT)	08:48	09:08	00:20	TRIPPED ON FAULT
285	03-Apr-24	BENGALURU	LINE	66	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	13:30	13:35	00:05	LINE CLEAR AVAILED
286	03-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	11:40	11:50	00:10	LINE CLEAR AVAILED
287	03-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - ITI (POTTERYROAD)	HOSKOTE 66	11:30	11:50	00:20	TRIPPED ON FAULT
288	03-Apr-24	BENGALURU	LINE	66	66KV JADIGENAHALLI - HOSKOTE	NO STATION AFFECTED	08:30	09:05	00:35	TRIPPED ON FAULT
289	03-Apr-24	BENGALURU	LINE	66	66KV JADIGENAHALLI - HOSKOTE	NO STATION AFFECTED	09:05	23:59	14:54	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
290	03-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	13:05	14:00	00:55	LINE CLEAR AVAILED
291	03-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	NO STATION AFFECTED	12:20	14:45	02:25	LINE CLEAR AVAILED
292	03-Apr-24	BENGALURU	LINE	66	66KV SIDDALAGHATTA - MELUR	MELUR	06:33	06:40	00:07	TRIPPED ON FAULT
293	03-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	05:15	05:40	00:25	TRIPPED ON FAULT
294	03-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	06:03	06:13	00:10	TRIPPED ON FAULT
295	03-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	09:52	10:18	00:26	LINE CLEAR AVAILED
296	03-Apr-24	BENGALURU	LINE	220	220KV SHOBHA DREAMS 220 - SOMANAHALLI 220	NO STATION AFFECTED	09:05	12:33	03:28	TRIPPED ON FAULT
297	03-Apr-24	BENGALURU	TRANSFORMER	66	HV1	PERESANDRA	12:00	12:05	00:05	LINE CLEAR AVAILED
298	03-Apr-24	BENGALURU	TRANSFORMER	66	HV1	WELCAST	23:13	23:36	00:23	TRIPPED ON FAULT
299	03-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MALLASANDRA	13:10	15:20	02:10	LINE CLEAR AVAILED
300	03-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MALLASANDRA	18:05	18:55	00:50	LINE CLEAR AVAILED
301	03-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KYASAMBALLI	11:35	11:45	00:10	TRIPPED ON FAULT
302	03-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ALUR	18:49	19:23	00:34	LINE CLEAR AVAILED
303	03-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KODIGEHALI	16:36	17:14	00:38	TRIPPED ON FAULT
304	03-Apr-24	BENGALURU	TRANSFORMER	66	HV3	CHIKKABALLAPURA I/A	11:55	12:20	00:25	LINE CLEAR AVAILED
305	03-Apr-24	BENGALURU	TRANSFORMER	66	HV3	YARANDANAHALLI 220	15:35	15:45	00:10	TRIPPED ON FAULT
306	3-Apr-2024	GULBARGA	LINE	110	ALIPUR-BELLARY NORTH	BELLARY NORTH_110,SOMASAMUNDRA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110,MOKA_110,SIRIGERICROSS_110	18:44	19:17	00:33	TRIPPED ON FAULT
307	3-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	METRI_110	16:00	17:00	01:00	LINE CLEAR AVAILED
308	3-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	SHAHAPUR_220	08:53	09:33	00:40	TRIPPED ON FAULT
309	3-Apr-2024	GULBARGA	TRANSFORMER	110	HV3	KURUGOD_110	07:20	07:30	00:10	TRIPPED ON FAULT
310	3-Apr-2024	GULBARGA	TRANSFORMER	110	HV3	KURUGOD_110	19:35	19:40	00:05	TRIPPED ON FAULT
311	3-Apr-2024	GULBARGA	TRANSFORMER	220	HV1 & HV2	LINGASUGUR_220	09:25	11:06	01:41	TRIPPED ON FAULT
312	03-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	08:26	08:35	00:09	TRIPPED ON FAULT
313	03-Apr-24	HASSAN	LINE	110	BANTWA-SALATTUR	BANTWALA_110	11:51	13:56	02:05	LINE CLEAR AVAILED
314	03-Apr-24	HASSAN	LINE	110	KONAJE-BCROAD	KONAJE_110	10:25	13:35	03:10	LINE CLEAR AVAILED
315	03-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	15:01	19:40	04:39	MAIN SUPPLY FAILURE
316	03-Apr-24	HASSAN	LINE	110	KONAJE-SALATHUR	KONAJE_110	15:01	15:32	00:31	MAIN SUPPLY FAILURE
317	03-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 2	PUTTUR_220	15:00	19:19	04:19	TRIPPED ON FAULT
318	03-Apr-24	HASSAN	LINE	110	SALATHU-KONAJE	SALATHUR_110	15:01	15:38	00:37	MAIN SUPPLY FAILURE
319	03-Apr-24	HASSAN	LINE	110	SALATHU-NTMDNOR	SALATHUR_110	19:19	19:24	00:05	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
320	03-Apr-24	HASSAN	LINE	110	VITTAL-PUTR_SLTUR	VITTALA_110	15:01	15:40	00:39	TRIPPED ON FAULT
321	03-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY4	MRSMSG_220	16:49	19:46	02:57	LINE CLEAR AVAILED
322	03-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA4	gen_sharavaty	16:49	19:46	02:57	LINE CLEAR AVAILED
323	03-Apr-24	HASSAN	TRANSFORMER	66	HV1	HAGARE_66	15:15	16:55	01:40	MAIN SUPPLY FAILURE
324	03-Apr-24	HASSAN	TRANSFORMER	66	HV1	HANUBALU_66	17:20	17:31	00:11	TRIPPED ON FAULT
325	03-Apr-24	HASSAN	TRANSFORMER	66	HV2	SAKALESHPURA_66	15:00	15:07	00:07	LINE CLEAR AVAILED
326	03-Apr-24	HASSAN	TRANSFORMER	110	HV2	KARAYA_110	08:44	08:53	00:09	TRIPPED ON FAULT
327	03-Apr-24	HASSAN	TRANSFORMER	110	HV2	KONAJE_110	10:25	13:31	03:06	LINE CLEAR AVAILED
328	3-Apr-24	MYSORE	LINE	66	BANNUR-HEBBANI	NO STATIONS EFFECTED	23:22			LINE CLEAR AVAILED
329	3-Apr-24	MYSORE	LINE	66	BEGUR 220-SARAGURU	ANTHARSANTHE_66 CHANDRAVADI_66 HDKOTE_66 HURA_66 SANTHESARAGUR_66 YERALLI HAND POST_66	08:34	08:40	00:06	TRIPPED ON FAULT
330	3-Apr-24	MYSORE	LINE	66	BOGADHI-HOOTAGALLY	NO STATIONS EFFECTED	16:17	17:08	00:51	LINE CLEAR AVAILED
331	3-Apr-24	MYSORE	LINE	66	CHANDRAVADI-HURA	HURA_66	04:16	04:21	00:05	TRIPPED ON FAULT
332	3-Apr-24	MYSORE	LINE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	19:45			TRIPPED ON FAULT
333	3-Apr-24	MYSORE	LINE	66	CR NAGARA-HONGANURU	HONAGANURU_66	06:38	06:46	00:08	TRIPPED ON FAULT
334	3-Apr-24	MYSORE	LINE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66	02:53	02:57	00:04	TRIPPED ON FAULT
335	3-Apr-24	MYSORE	LINE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66	20:28	20:34	00:05	TRIPPED ON FAULT
336	3-Apr-24	MYSORE	LINE	66	DUNDANAHALLI-HULIYURDURGA	NO STATIONS EFFECTED	12:30	13:36	01:06	LINE CLEAR AVAILED
337	3-Apr-24	MYSORE	LINE	66	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
338	3-Apr-24	MYSORE	LINE	66	HANNUR-AJJIPURA	AJJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	18:51	18:57	00:06	TRIPPED ON FAULT
339	3-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
340	3-Apr-24	MYSORE	LINE	66	JAIPURA-KADAKOLA	HAMPAPURA(K)_66	08:33	08:40	00:06	TRIPPED ON FAULT
341	3-Apr-24	MYSORE	LINE	66	JAKKANAHALLI-NAGAMANGLA	G_MALLIGERE_66	06:14	06:23	00:08	TRIPPED ON FAULT
342	3-Apr-24	MYSORE	LINE	66	KADAKOLA -KOZHIKODE	NO STATIONS EFFECTED	20:49 (02/04/2024)	6:32 (03/04/2024)	9:43 HRs	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
343	3-Apr-24	MYSORE	LINE	66	KADAKOLA-SARAGURU 2	DOORA_66 HULLAHALLI_66	00:09	00:17	00:07	TRIPPED ON FAULT
344	3-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
345	3-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
346	3-Apr-24	MYSORE	LINE	66	MAMBALLI-YELANDURU	YELANDUR_66	02:35	02:40	00:05	TRIPPED ON FAULT
347	3-Apr-24	MYSORE	LINE	66	MUGUR-JANNUR	JANNUR_66	03:37	03:42	00:05	TRIPPED ON FAULT
348	3-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS	NO STATIONS EFFECTED	17:08	21:47	04:39	LINE CLEAR AVAILED
349	3-Apr-24	MYSORE	LINE	66	NAGAMANGALA 220-ADDIHALLI	NO STATIONS EFFECTED	00:29	00:37	00:08	TRIPPED ON FAULT
350	3-Apr-24	MYSORE	LINE	66	NAGAMANGALA 220-ADDIHALLI	NO STATIONS EFFECTED	03:48	06:28	02:40	TRIPPED ON FAULT
351	3-Apr-24	MYSORE	LINE	66	TUBINAKERE-MC- 2	CHIKKA_MANDYA_66 KIADB SOMANAHALLI_66 MADDUR_66 MANDYA_66	18:48	19:05	00:17	TRIPPED ON FAULT
352	3-Apr-24	MYSORE	LINE	66	TUBINAKERE-MC- 4	CHIKKA_MANDYA_66 KIADB SOMANAHALLI_66 MADDUR_66 MANDYA_66	18:48	19:06	00:17	TRIPPED ON FAULT
353	3-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48			LINE CLEAR AVAILED
354	3-Apr-24	MYSORE	TRANSFORMER	66	HV1	HALAGUR_66	11:23	11:27	00:04	LINE CLEAR AVAILED
355	3-Apr-24	MYSORE	TRANSFORMER	66	HV1	HALAGUR_66	13:16	13:25	00:09	LINE CLEAR AVAILED
356	3-Apr-24	MYSORE	TRANSFORMER	66	HV1	MEGHALAPURA-	12:44	13:20	00:35	LINE CLEAR AVAILED
357	3-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDYA_66	18:48			TRIPPED ON FAULT
358	3-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
359	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	AKKIHEBBAL_66	09:53	10:01	00:08	TRIPPED ON FAULT
360	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	AKKIHEBBAL_66	12:54	13:01	00:06	TRIPPED ON FAULT
361	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	AKKIHEBBAL_66	15:07	15:22	00:14	TRIPPED ON FAULT
362	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	09:31	09:47	00:16	TRIPPED ON FAULT
363	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	12:12	12:50	00:37	LINE CLEAR AVAILED
364	3-Apr-24	MYSORE	TRANSFORMER	66	HV2	BILIKERE_66	19:30 (02/04/2024)	19:25 (03/04/2024)	23:55 HRs	TRIPPED ON FAULT
365	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-BENKIKERE	BENKIKERE_66	19:02	19:28	00:26	LINE CLEAR AVAILED
366	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-CHANNAGIRI	LINGADAHALLI_66, CHANNAGIRI_66	12:16	12:25	00:09	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
367	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREKILCHI_66	19:02	19:29	00:27	LINE CLEAR AVAILED
368	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	19:02	19:29	00:27	LINE CLEAR AVAILED
369	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-HONNALLI	BENKIKERE_220	19:00	19:26	00:26	MAIN SUPPLY FAILURE
370	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	19:02	19:28	00:26	LINE CLEAR AVAILED
371	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	12:16	12:25	00:09	LINE CLEAR AVAILED
372	03-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	19:02	19:30	00:28	LINE CLEAR AVAILED
373	03-Apr-24	TUMKUR	LINE	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	19:02	19:29	00:27	LINE CLEAR AVAILED
374	03-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	15:39	15:55	00:16	TRIPPED ON FAULT
375	03-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	12:05	12:40	00:35	LINE CLEAR AVAILED
376	03-Apr-24	TUMKUR	LINE	66	DEVARABELEKERE-ANGODU	ANGODU_66	16:04	18:35	02:31	LINE CLEAR AVAILED
377	03-Apr-24	TUMKUR	LINE	66	DEVARABELEKERE-ANGODU	ANGODU_66, ATTIGERE MUSS	12:45	12:55	00:10	TRIPPED ON FAULT
378	03-Apr-24	TUMKUR	LINE	66	KEREKILCHI-DAVANGERE 220	KEREKILCHI_66	19:00	19:30	00:30	MAIN SUPPLY FAILURE
379	03-Apr-24	TUMKUR	LINE	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	15:42	15:54	00:12	TRIPPED ON FAULT
380	03-Apr-24	TUMKUR	LINE	66	KUKKAWADA- SRS DAVANGERE1	KUKKAWADA_66,,SHYA GALDSC, THYAVANAGI, WATER WORKS	11:55	12:05	00:10	TRIPPED ON FAULT
381	03-Apr-24	TUMKUR	LINE	66	KUKKAWADA- SRS DAVANGERE2	KUKKAWADA_66,,SHYA GALDSC, THYAVANAGI, WATER WORKS	11:55	12:05	00:10	TRIPPED ON FAULT
382	03-Apr-24	TUMKUR	LINE	66	MADHURE_220- HOSADURGA_66	HOSADURGA_66, NEERGUNDA_66	02:00	02:15	00:15	TRIPPED ON FAULT
383	03-Apr-24	TUMKUR	LINE	66	MADHURE_220- HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	04:45	04:55	00:10	TRIPPED ON FAULT
384	03-Apr-24	TUMKUR	LINE	66	THALLAK 220kV- NAYAKANHATTI	NERALAGUNTE_66,NAY AKAHATTI_66, HIREMALLANAHOLE_66	06:30	06:43	00:13	TRIPPED ON FAULT
385	03-Apr-24	TUMKUR	LINE	66	THALLAK 220kV- NAYAKANHATTI	NERALAGUNTE_66,NAY AKAHATTI_66, HIREMALLANAHOLE_66	07:53	08:56	01:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
386	03-Apr-24	TUMKUR	LINE	66	THALLAK 220kV- NAYAKANHATTI	NERALAGUNTE_66,NAYAKANHATTI_66, HIREMALLANAHOLE_66	10:53	15:51	04:58	LINE CLEAR AVAILED
387	03-Apr-24	TUMKUR	LINE	220	ANTHRASANAHALLI 220KV- WIPRO1	WIPRO_EHT	15:45	16:16	00:31	LINE CLEAR AVAILED
388	03-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI1	220KV BENKIKERE,220KV HOSADURGA, 66KV BENKIKERE, CHANNAGIRI, MALLADIHALLI,GOPPENAHALLI, TAVAREKERE, NALLURU,LINGADAHALLI, DEVARAHALLI, SANTHEBENNUR,KERE BILCHI,HALURAMESHWARA,MADADKERE, RAMAGIRI,BAGUR, HOSADURGA, NEERAGUNDA GATE, SASVEHALLI, ASAVAPATNA, T	19:00	19:14	00:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
389	03-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI2	220KV BENKIKERE,220KV HOSADURGA, 66KV BENKIKERE, CHANNAGIRI, MALLADIHALLI,GOPPEN AHALLI, TAVAREKERE, NALLURU,LINGADAHALLI, DEVARAHALLI, SANTHEBENNUR,KERE BILCHI,HALURAMESHWARA, MADADKERE, RAMAGIRI,BAGUR, HOSADURGA, NEERAGUNDA GATE, SASVEHALLI, ASAVAPATNA, T	19:00	20:01	01:01	TRIPPED ON FAULT
390	03-Apr-24	TUMKUR	TRANSFORMER	66	TR-1(HV&LV)	BENKIKERE_66	19:01	19:27	00:26	MAIN SUPPLY FAILURE
391	04-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV2(LV3)	BIJAPUR_220	14:04	14:07	00:03	TRIPPED ON FAULT
392	04-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
393	04-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
394	04-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
395	04-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
396	04-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
397	04-Apr-24	BAGALKOTE	LINE	110	KUMATA- SIRSI1(RAILWAY)	KUMATA_110	11:55	14:04	02:09	LINE CLEAR AVAILED
398	04-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
399	04-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
400	04-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- LN2(RAIBAG2)	MUGALKHOD_220	10:29	12:21	01:52	LINE CLEAR AVAILED
401	04-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- LN3(ITANAL1)	MUGALKHOD_220	09:32	11:42	02:10	LINE CLEAR AVAILED
402	04-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
403	04-Apr-24	BAGALKOTE	LINE	110	SHIGGOAN220- SAVANUR	SHIGGOAN_220	23:39	23:53	00:14	TRIPPED ON FAULT
404	04-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
405	04-Apr-24	BAGALKOTE	LINE	220	AMBEWADI- PONDA1	AMBEWADI_220	11:10	11:39	00:29	TRIPPED ON FAULT
406	04-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	16:03	20:01	03:58	TRIPPED ON FAULT
407	04-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI2	HUBLI_220	17:55	19:56	02:01	LINE CLEAR AVAILED
408	04-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	11:09	12:34	01:25	LINE CLEAR AVAILED
409	04-Apr-24	BAGALKOTE	LINE	220	SHIGGOAN- NARENDRA	SHIGGOAN_220	10:51	16:10	05:19	LINE CLEAR AVAILED
410	04-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
411	04-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(20MVA)	SADALAGA_110	15:35	17:50	02:15	LINE CLEAR AVAILED
412	04-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	KULIGOD_110	15:52	16:25	00:33	LINE CLEAR AVAILED
413	04-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV3 (10 MVA)	SINDAGI_110	8:20 (02.04.2024)	14:50 (04.04.2024)	54:30:00	LINE CLEAR AVAILED
414	04-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	ATHANI_220	11:55	13:15	01:20	LINE CLEAR AVAILED
415	04-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2(HV3)	BIJAPUR_220	14:04	14:06	00:02	TRIPPED ON FAULT
416	04-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
417	04-Apr-24	BENGALURU	LINE	66	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	13:17	13:28	00:11	TRIPPED ON FAULT
418	04-Apr-24	BENGALURU	LINE	66	66KV GOKULA - HMT EHT	HMT(EHT)	19:56	21:03	01:07	TRIPPED ON FAULT
419	04-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	10:40	10:49	00:09	TRIPPED ON FAULT
420	04-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	11:21	11:39	00:18	MAIN SUPPLY FAILURE
421	04-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	12:48	12:55	00:07	LINE CLEAR AVAILED
422	04-Apr-24	BENGALURU	LINE	66	66KV HONNIGANAHALLI - HALAGURU	HALAGUR	11:05	11:10	00:05	LINE CLEAR AVAILED
423	04-Apr-24	BENGALURU	LINE	66	66KV HULLENAHALLI - KUDURU	KUDUR, SRIGIRIPURA	01:45	02:02	00:17	TRIPPED ON FAULT
424	04-Apr-24	BENGALURU	LINE	66	66KV JADIGENAHALLI - HOSKOTE	NO STATION AFFECTED	00:00	13:40	13:40	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
425	04-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	14:25	14:35	00:10	MAIN SUPPLY FAILURE
426	04-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	14:21	14:52	00:31	MAIN SUPPLY FAILURE
427	04-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	14:57	16:02	01:05	TRIPPED ON FAULT
428	04-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - FALSON CITY	PRESTIGE FALCON CITY	14:25	14:47	00:22	MAIN SUPPLY FAILURE
429	04-Apr-24	BENGALURU	LINE	66	66KV KIADB HAROHALI 220 - VR DODDI	VR DODDI	11:17	12:30	01:13	LINE CLEAR AVAILED
430	04-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 1	NO STATION AFFECTED	16:08	16:19	00:11	TRIPPED ON FAULT
431	04-Apr-24	BENGALURU	LINE	66	66KV KOTHIPURA - MELEHALI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	06:00	06:05	00:05	TRIPPED ON FAULT
432	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	11:21	11:39	00:18	MAIN SUPPLY FAILURE
433	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	14:33	14:36	00:03	MAIN SUPPLY FAILURE
434	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	10:40	10:49	00:09	TRIPPED ON FAULT
435	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	11:21	11:39	00:18	MAIN SUPPLY FAILURE
436	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	14:35	14:43	00:08	MAIN SUPPLY FAILURE
437	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	15:48	16:05	00:17	MAIN SUPPLY FAILURE
438	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, GULUR, THIMAMPALLI	11:21	11:39	00:18	MAIN SUPPLY FAILURE
439	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, GULUR, THIMAMPALLI	15:48	16:06	00:18	MAIN SUPPLY FAILURE
440	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, GULUR, THIMAMPALLI	15:05	15:10	00:05	LINE CLEAR AVAILED
441	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA,CHELUR, CHAKAVELU	11:21	11:39	00:18	MAIN SUPPLY FAILURE
442	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA,CHELUR, CHAKAVELU	15:48	16:10	00:22	MAIN SUPPLY FAILURE
443	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	11:21	11:39	00:18	MAIN SUPPLY FAILURE
444	04-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 2	NALLIMARADANAHALLI	11:21	11:39	00:18	MAIN SUPPLY FAILURE
445	04-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALI - SADLI	SADALI	10:40	10:49	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
446	04-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	SADALI	11:21	11:39	00:18	MAIN SUPPLY FAILURE
447	04-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	06:07	06:26	00:19	LINE CLEAR AVAILED
448	04-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	14:21	14:51	00:30	MAIN SUPPLY FAILURE
449	04-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	14:20	14:52	00:32	MAIN SUPPLY FAILURE
450	04-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO	14:20	14:45	00:25	MAIN SUPPLY FAILURE
451	04-Apr-24	BENGALURU	LINE	66	66KV TALAGUNDA - VEMGAL	VEMGAL, KYALANUR	13:30	14:20	00:50	LINE CLEAR AVAILED
452	04-Apr-24	BENGALURU	LINE	66	66KV WELCAST - ABBIGERE	ABBIGERE	00:30	00:35	00:05	LINE CLEAR AVAILED
453	04-Apr-24	BENGALURU	LINE	66	66KV WELCAST - ABBIGERE	WELCAST	12:30	12:50	00:20	LINE CLEAR AVAILED
454	04-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - MYLASANDRA 2	KHODAYS 220	14:29	14:44	00:15	LINE CLEAR AVAILED
455	04-Apr-24	BENGALURU	LINE	220	66KV SAHAKARNAGAR 220 - SAHAKARNAGAR 66	SAHAKARNAGAR 66	19:55	21:28	01:33	TRIPPED ON FAULT
456	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ISRO LAYOUT	13:13	13:15	00:02	LINE CLEAR AVAILED
457	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KYALANUR	07:20	08:00	00:40	LINE CLEAR AVAILED
458	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VOKKALERI	13:15	13:45	00:30	LINE CLEAR AVAILED
459	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VOKKALERI	15:30	15:40	00:10	LINE CLEAR AVAILED
460	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BUDIKOTE	16:15	16:20	00:05	LINE CLEAR AVAILED
461	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSPALYA CIRCLE	13:50	14:00	00:10	TRIPPED ON FAULT
462	04-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MATHIKERE	14:10	16:40	02:30	LINE CLEAR AVAILED
463	04-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KENGERI SATELLITE TOWN	17:06	17:10	00:04	LINE CLEAR AVAILED
464	04-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUNDAMGERE	16:56	17:44	00:48	LINE CLEAR AVAILED
465	04-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VOKKALERI	15:40	16:30	00:50	LINE CLEAR AVAILED
466	04-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	19:04	19:11	00:07	TRIPPED ON FAULT
467	04-Apr-24	BENGALURU	TRANSFORMER	220	HV1	HBR LAYOUT 220(NO LOAD AFFECTED)	17:40	18:28	00:48	TRIPPED ON FAULT
468	04-Apr-24	BENGALURU	TRANSFORMER	220	HV2	MITTEMARI 220	11:21	11:37	00:16	TRIPPED ON FAULT
469	04-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MITTEMARI 220	10:37	10:48	00:11	TRIPPED ON FAULT
470	04-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MITTEMARI 220	11:20	11:40	00:20	TRIPPED ON FAULT
471	04-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MITTEMARI 220	15:48	16:31	00:43	TRIPPED ON FAULT
472	4-Apr-2024	GULBARGA	LINE	110	SULEKAL-TAVARGERA	TAVARGERA_110	12:55	14:00	01:05	LINE CLEAR AVAILED
473	4-Apr-2024	GULBARGA	LINE	110	WALKAMDINI-SINDHANOOR	WALKAMDINI_110	16:20	16:30	00:10	LINE CLEAR AVAILED
474	4-Apr-2024	GULBARGA	LINE	220	KAPNOOR-HUMNABAD LINE-2	KAONOOR_220	17:42	18:18	00:36	TRIPPED ON FAULT
475	4-Apr-2024	GULBARGA	LINE	220	LINGAPUR-SULEKAL1	LINGAPUR_220	13:26	15:32	02:06	TRIPPED ON FAULT
476	4-Apr-2024	GULBARGA	LINE	220	LINGAPUR-SULEKAL2	LINGAPUR_220	12:58	16:29	03:31	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
477	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	12:13	12:28	00:15	TRIPPED ON FAULT
478	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SIRIGERICROSS_110	13:58	14:08	00:10	TRIPPED ON FAULT
479	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SHAHBAD_110	08:06	08:11	00:05	LINE CLEAR AVAILED
480	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SHAHBAD_110	19:55	20:11	00:16	LINE CLEAR AVAILED
481	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	WALKAMDINI_110	00:00	16:40	16:40	LINE CLEAR AVAILED
482	4-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	WALKAMDINI_110	17:05	18:20	01:15	LINE CLEAR AVAILED
483	4-Apr-2024	GULBARGA	TRANSFORMER	220	HV1 & HV2	KAPNOOR_220	17:40	19:37	01:57	TRIPPED ON FAULT
484	04-Apr-24	HASSAN	LINE	66	BHADRA-BASAVAGHATTA	DUDDA_66	20:56	21:40	00:44	TRIPPED ON FAULT
485	04-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	BHADRAVATI_110	09:30	09:35	00:05	TRIPPED ON FAULT
486	04-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	BHADRAVATI_110	12:51	12:53	00:02	TRIPPED ON FAULT
487	04-Apr-24	HASSAN	LINE	66	SIGEBAG-KDLGRE	SIGEBAGI_66	08:45	09:06	00:21	TRIPPED ON FAULT
488	04-Apr-24	HASSAN	LINE	66	TAVAREC-HONNLI	TAVARECHETTANAHAL LY_66	22:00	22:15	00:15	TRIPPED ON FAULT
489	04-Apr-24	HASSAN	LINE	110	BARANG	SHIRALKOPPA_220	13:09	13:42	00:33	LINE CLEAR AVAILED
490	04-Apr-24	HASSAN	LINE	110	MRSSHM-TRKER	MRSMSG_220	13:05	16:27	03:22	TRIPPED ON FAULT
491	04-Apr-24	HASSAN	LINE	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:09	13:31	00:22	LINE CLEAR AVAILED
492	04-Apr-24	HASSAN	LINE	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:09	13:25	00:16	LINE CLEAR AVAILED
493	04-Apr-24	HASSAN	LINE	110	SHRLKP-SHIRALKOPA	SHIRALKOPPA_220	13:09	13:27	00:18	LINE CLEAR AVAILED
494	04-Apr-24	HASSAN	LINE	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:09	13:39	00:30	LINE CLEAR AVAILED
495	04-Apr-24	HASSAN	LINE	220	MRSSHM-CHKML	MRSMSG_220	16:34	19:54	03:20	LINE CLEAR AVAILED
496	04-Apr-24	HASSAN	LINE	220	SHRLKP-SGS	SHIRALKOPPA_220	13:05	16:39	03:34	TRIPPED ON FAULT
497	04-Apr-24	HASSAN	TRANSFORMER	66	HV2	BELUR_66	15:30	15:40	00:10	TRIPPED ON FAULT
498	04-Apr-24	HASSAN	TRANSFORMER	66	HV2	KANDLI_66	00:42	01:10	00:28	TRIPPED ON FAULT
499	04-Apr-24	HASSAN	TRANSFORMER	110	HV1	BHADRAVATI_110	14:25	19:00	04:35	TRIPPED ON FAULT
500	04-Apr-24	HASSAN	TRANSFORMER	110	HV1	KADUR_220	21:08	21:13	00:05	TRIPPED ON FAULT
501	04-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	19:04	20:33	01:29	TRIPPED ON FAULT
502	4-Apr-24	MYSORE	LINE	66	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	19:45 (03/04/2024)	0:34 (04/04/2024)	4:48 HRs	TRIPPED ON FAULT
503	4-Apr-24	MYSORE	LINE	66	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)	6:07 (04/04/2024)	944:00 HRs	LINE CLEAR AVAILED
504	4-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53			LINE CLEAR AVAILED
505	4-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
506	4-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
507	4-Apr-24	MYSORE	LINE	66	KUSHALANAGARA 220-MYSORE-2	NO STATIONS EFFECTED	15:17	15:19	00:02	LINE CLEAR AVAILED
508	4-Apr-24	MYSORE	LINE	66	KUSHALANAGARA 220-MYSORE-2	NO STATIONS EFFECTED	18:21	18:23	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
509	4-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
510	4-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	23:55	00:00	00:04	TRIPPED ON FAULT
511	4-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	23:49	23:54	00:05	TRIPPED ON FAULT
512	4-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	17:09	22:17	05:07	LINE CLEAR AVAILED
513	4-Apr-24	MYSORE	LINE	66	TUBINAKERE-MANDYA 2	MANDYA_66	06:35	07:42	01:07	LINE CLEAR AVAILED
514	4-Apr-24	MYSORE	LINE	66	TUBINAKERE-MANDYA 4	MANDYA_66	06:35	07:42	01:07	LINE CLEAR AVAILED
515	4-Apr-24	MYSORE	LINE	66	VAJAMANGALA-JYOTHINAGARA	DKMAIDANA_66 JYOTHINAGARA_66	06:16	06:22	00:06	TRIPPED ON FAULT
516	4-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36			LINE CLEAR AVAILED
517	4-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48 (03/04/2024)	7:21 (04/04/2024)	10:33 HRs	LINE CLEAR AVAILED
518	4-Apr-24	MYSORE	TRANSFORMER	66	HV1	KUSHALANAGARA_66	15:30	15:33	00:03	LINE CLEAR AVAILED
519	4-Apr-24	MYSORE	TRANSFORMER	66	HV1	KUSHALANAGARA_66	18:30	18:35	00:05	LINE CLEAR AVAILED
520	4-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDYA_66	18:48 (03/04/204)	13:59 (04/04/2024)	19:10 HRs	TRIPPED ON FAULT
521	4-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
522	4-Apr-24	MYSORE	TRANSFORMER	66	HV2	HARVEY_66	17:31	18:00	00:29	LINE CLEAR AVAILED
523	4-Apr-24	MYSORE	TRANSFORMER	66	HV2	ARAKERE_66	19:50			TRIPPED ON FAULT
524	4-Apr-24	MYSORE	TRANSFORMER	66	HV3	KUSHALANAGARA_66	15:30	15:33	00:03	LINE CLEAR AVAILED
525	4-Apr-24	MYSORE	TRANSFORMER	66	HV3	KUSHALANAGARA_66	18:30	18:35	00:05	LINE CLEAR AVAILED
526	4-Apr-24	MYSORE	TRANSFORMER	66	HV4	KUSHALANAGARA_66	15:30	15:34	00:04	LINE CLEAR AVAILED
527	4-Apr-24	MYSORE	TRANSFORMER	66	HV4	KUSHALANAGARA_66	18:30	18:35	00:05	LINE CLEAR AVAILED
528	4-Apr-24	MYSORE	TRANSFORMER	220	HV2	KUSHALNAGARA_220	15:42	18:24	02:42	LINE CLEAR AVAILED
529	04-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	06:28	07:02	00:34	TRIPPED ON FAULT
530	04-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	12:32	12:46	00:14	TRIPPED ON FAULT
531	04-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	07:32	18:09	10:37	LINE CLEAR AVAILED
532	04-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	HARIYABBE_66,PDKOT E_66	07:25	18:09	10:44	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
533	04-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- PULLAMAGATTA	PULLAMGATTA_66	05:56	06:06	00:10	TRIPPED ON FAULT
534	04-Apr-24	TUMKUR	LINE	66	MADHURE_220- HOSADURGA_66	HOSADURGA_66, NEERGUNDA_66	00:20	00:35	00:15	TRIPPED ON FAULT
535	04-Apr-24	TUMKUR	LINE	66	PDKOTE-HARIYABBE	PDKOTE_66	07:02	07:55	00:53	MAIN SUPPLY FAILURE
536	04-Apr-24	TUMKUR	LINE	66	PDKOTE-HARIYABBE	PDKOTE_66	18:10	18:25	00:15	MAIN SUPPLY FAILURE
537	04-Apr-24	TUMKUR	LINE	110	HV-3	KB CROSS_220	00:06	00:10	00:04	TRIPPED ON FAULT
538	04-Apr-24	TUMKUR	LINE	220	GUTTUR220-DITTUR LINE	KNNL DITTUR_66 , KNNL HALASABALU_66	18:50	19:11	00:21	TRIPPED ON FAULT
539	04-Apr-24	TUMKUR	LINE	220	NITTUR 220kV- NELAMANGALA	NITTUR_220	16:18	18:29	02:11	LINE CLEAR AVAILED
540	04-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- KAIGA1 400KV	GUTUR_400	14:04	20:05	06:00	TRIPPED ON FAULT
541	04-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- KAIGA2 400KV	GUTUR_400	19:56(4.4.24)		-	TRIPPED ON FAULT
542	04-Apr-24	TUMKUR	TRANSFORMER	220	HV-3	HIRIYUR_220	11:35	14:38	03:03	LINE CLEAR AVAILED
543	04-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	KOLALA_66	15:07	15:22	00:14	TRIPPED ON FAULT
544	04-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	MELLEKATTE_66	14:03	14:10	00:06	TRIPPED ON FAULT
545	04-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	MELLEKATTE_66	14:23	14:30	00:07	TRIPPED ON FAULT
546	04-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	PDKOTE_66	14:20	16:40	02:20	LINE CLEAR AVAILED
547	04-Apr-24	TUMKUR	TRANSFORMER	220	TR-3	CHITRAHALLI_66	15:05	15:10	00:05	TRIPPED ON FAULT
548	05-Apr-24	BAGALKOTE	LINE	110	ATHANI220- KARIMASUTI	ATHANI_220	10:07	22:48	12:41	LINE CLEAR AVAILED
549	05-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
550	05-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
551	05-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
552	05-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	21:24	21:43	00:19	TRIPPED ON FAULT
553	05-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
554	05-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
555	05-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
556	05-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
557	05-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
558	05-Apr-24	BAGALKOTE	LINE	110	SIRSI220- KAVALWADA	SIRSI_220	20:00	20:05	00:05	LINE CLEAR AVAILED
559	05-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
560	05-Apr-24	BAGALKOTE	LINE	220	HUBLI- NARENDRA2	HUBLI_220	14:15	16:58	02:43	TRIPPED ON FAULT
561	05-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
562	05-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-ENERGON	VAJRAMATTI_220	20:00	22:38	02:38	LINE CLEAR AVAILED
563	05-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SIRSI_220	10:32	14:17	03:45	LINE CLEAR AVAILED
564	05-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SIRSI_220	21:08	21:15	00:07	TRIPPED ON FAULT
565	05-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	12:30	12:52	00:22	LINE CLEAR AVAILED
566	05-Apr-24	BENGALURU	LINE	66	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	12:05	12:10	00:05	LINE CLEAR AVAILED
567	05-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
568	05-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	MULBAGAL	18:20	18:30	00:10	LINE CLEAR AVAILED
569	05-Apr-24	BENGALURU	LINE	66	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:50	14:55	00:05	LINE CLEAR AVAILED
570	05-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	06:13	06:24	00:11	TRIPPED ON FAULT
571	05-Apr-24	BENGALURU	LINE	66	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	DASHAVARA, SANKALGERE, BEVOOR, VANDARGUPPE	13:21	13:37	00:16	MAIN SUPPLY FAILURE
572	05-Apr-24	BENGALURU	LINE	66	66KV DG2 PUTTENAHALLI 220- SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	07:20	07:30	00:10	TRIPPED ON FAULT
573	05-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	19:57	21:40	01:43	TRIPPED ON FAULT
574	05-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	21:40	22:34	00:54	LINE CLEAR AVAILED
575	05-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - BRIGADE METROPIS	BRIGADE METROPOLIS	12:54	13:04	00:10	LINE CLEAR AVAILED
576	05-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 2	BANGARPET	12:20	12:30	00:10	LINE CLEAR AVAILED
577	05-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA - DRDO	DRDO, MALLASANDRA	08:25	08:38	00:13	TRIPPED ON FAULT
578	05-Apr-24	BENGALURU	LINE	66	66KV LAKKUR - DEVANAGUNDHI	DEVANAGUNDHI	14:40	14:58	00:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
579	05-Apr-24	BENGALURU	LINE	66	66KV MALGUDI - CHOKKASANDRA	ELECTRONIC CITY PH2 SEC 2, HUSKUR	10:35	10:42	00:07	LINE CLEAR AVAILED
580	05-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPET	14:20	14:25	00:05	LINE CLEAR AVAILED
581	05-Apr-24	BENGALURU	LINE	66	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY PH2 SEC 2, HUSKUR	06:58	08:25	01:27	TRIPPED ON FAULT
582	05-Apr-24	BENGALURU	LINE	66	66KV PATHPALYA - THIMMAMPALLI	THIMMAMPALLI	17:40	18:00	00:20	TRIPPED ON FAULT
583	05-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	08:38	08:48	00:10	TRIPPED ON FAULT
584	05-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II	BIEC, ALUR	06:36	09:10	02:34	TRIPPED ON FAULT
585	05-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	11:36	12:00	00:24	TRIPPED ON FAULT
586	05-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO & GLOBAL TECH PARK	11:28	11:36	00:08	LINE CLEAR AVAILED
587	05-Apr-24	BENGALURU	LINE	66	66KV SURYA CITY - ANEKAL 1	SURYA CITY, ANEKAL	08:08	08:20	00:12	LINE CLEAR AVAILED
588	05-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	10:15	13:10	02:55	MAIN SUPPLY FAILURE
589	05-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, MALLANAYAKANAHALLI , NG HULKUR	10:15	13:10	02:55	MAIN SUPPLY FAILURE
590	05-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, MALLANAYAKANAHALLI , NG HULKUR	15:07	15:17	00:10	TRIPPED ON FAULT
591	05-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	10:15	13:10	02:55	MAIN SUPPLY FAILURE
592	05-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	10:15	13:10	02:55	MAIN SUPPLY FAILURE
593	05-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE, SAMANDURU	08:08	08:20	00:12	LINE CLEAR AVAILED
594	05-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON	08:01	08:18	00:17	LINE CLEAR AVAILED
595	05-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA	08:13	08:20	00:07	LINE CLEAR AVAILED
596	05-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	18:00	18:05	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
597	05-Apr-24	BENGALURU	TRANSFORMER	66	HV1	THAYALUR	13:30	13:40	00:10	LINE CLEAR AVAILED
598	05-Apr-24	BENGALURU	TRANSFORMER	66	HV1	YELDUR	07:40	08:15	00:35	LINE CLEAR AVAILED
599	05-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MATHIKERE RMG	09:26	09:40	00:14	TRIPPED ON FAULT
600	05-Apr-24	BENGALURU	TRANSFORMER	66	HV1	YARANDANAHALLI 220	08:01	08:07	00:06	LINE CLEAR AVAILED
601	05-Apr-24	BENGALURU	TRANSFORMER	66	HV2	THAYALUR	13:10	13:35	00:25	LINE CLEAR AVAILED
602	05-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VEMGAL	20:40	21:15	00:35	TRIPPED ON FAULT
603	05-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YARANDANAHALLI 220	08:10	08:20	00:10	LINE CLEAR AVAILED
604	05-Apr-24	BENGALURU	TRANSFORMER	66	HV3	BANASAWADI	05:19	06:50	01:31	LINE CLEAR AVAILED
605	05-Apr-24	BENGALURU	TRANSFORMER	220	HV1	SOMANAHALLI 220(NO LOAD AFFECTED)	17:40	18:28	00:48	TRIPPED ON FAULT
606	05-Apr-24	BENGALURU	TRANSFORMER	220	HV1	CHANNAPATNA 220	13:21	13:34	00:13	TRIPPED ON FAULT
607	05-Apr-24	BENGALURU	TRANSFORMER	220	HV1	YARANDANAHALLI 220	08:13	08:17	00:04	LINE CLEAR AVAILED
608	05-Apr-24	BENGALURU	TRANSFORMER	220	HV2	T GOLLAHALLI 220	10:15	13:10	02:55	TRIPPED ON FAULT
609	5-Apr-2024	GULBARGA	LINE	66	ITTAGGI-CJHALLI	CJHALLI_66,HUDEM_66, HOSAHALLI_66	11:15	12:02	00:47	LINE CLEAR AVAILED
610	5-Apr-2024	GULBARGA	LINE	66	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBAJ JIHALLI_66	06:35	06:45	00:10	TRIPPED ON FAULT
611	5-Apr-2024	GULBARGA	LINE	110	ALAND-KADGANCHI	KADGANCHI_110	22:35	22:45	00:10	TRIPPED ON FAULT
612	5-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110,MARG UTTI_110	12:46	13:07	00:21	TRIPPED ON FAULT
613	5-Apr-2024	GULBARGA	LINE	110	KOLHAR-JANAWADA	KOLHAR_110	16:20	19:30	03:10	LINE CLEAR AVAILED
614	5-Apr-2024	GULBARGA	LINE	110	KOLURU-DEODURGA-2	DEODURGA_110	03:24	04:10	00:46	TRIPPED ON FAULT
615	5-Apr-2024	GULBARGA	LINE	110	KOLURU-DEODURGA-2	DEODURGA_110	04:05	13:06	09:01	MAIN SUPPLY FAILURE
616	5-Apr-2024	GULBARGA	LINE	110	KOLURU-DEODURGA-2	DEODURGA_110	11:10	13:25	02:15	LINE CLEAR AVAILED
617	5-Apr-2024	GULBARGA	LINE	110	MAHAGOAN-MARGUTTI	MAHAGOAN_110	12:46	13:07	00:21	TRIPPED ON FAULT
618	5-Apr-2024	GULBARGA	LINE	110	MAHAGOAN-MARGUTTI	MARGUTTI_110	12:46	13:07	00:21	TRIPPED ON FAULT
619	5-Apr-2024	GULBARGA	LINE	110	MALLAT-SIRWAR	SIRWAR_110	02:24	02:39	00:15	TRIPPED ON FAULT
620	5-Apr-2024	GULBARGA	LINE	110	MUNIRABAD-RAYARAKERE	DONIMALAI_110,NMDC_FACTORY	10:08	15:26	05:18	LINE CLEAR AVAILED
621	5-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR1,2	GUGAL_110,GABUR_110 ,DEODURGA_110	12:31	12:40	00:09	LINE CLEAR AVAILED
622	5-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-MKOLLUR	M.KOLLUR_110	04:37	13:06	08:29	LINE CLEAR AVAILED
623	5-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-RAICHUR2	GUGAL_110,GABUR_110 ,DEODURGA_110	10:58	13:05	02:07	LINE CLEAR AVAILED
624	5-Apr-2024	GULBARGA	LINE	110	SOUTH-UNIVERSITY 1	UNIVERSITY_110,KIADB _110	11:55	12:05	00:10	TRIPPED ON FAULT
625	5-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-BAGEWADI-2	LINGASUGUR_220	15:42	15:58	00:16	TRIPPED ON FAULT
626	5-Apr-2024	GULBARGA	LINE	220	LINGASUGURRTPS-2	LINGASUGUR_220	11:47	12:30	00:43	TRIPPED ON FAULT
627	5-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	05:30	05:58	00:28	TRIPPED ON FAULT
628	5-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	05:30	06:22	00:52	TRIPPED ON FAULT
629	5-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	12:06	12:14	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
630	05-Apr-24	HASSAN	LINE	66	CHIKKAKONDAGOLA-DUDDA	CHIKKAKONDAGOLA_66	06:03	06:35	00:32	TRIPPED ON FAULT
631	05-Apr-24	HASSAN	LINE	66	DODDAHALLY-HOOTGALLI	DODDAHALLY_66	17:20	17:24	00:04	LINE CLEAR AVAILED
632	05-Apr-24	HASSAN	LINE	66	DODDAHALLY-HOOTGALLI	DODDAHALLY_66	17:38	17:41	00:03	LINE CLEAR AVAILED
633	05-Apr-24	HASSAN	LINE	66	DUDDA-BASAVAGHATTA	DUDDA_66	06:03	08:25	02:22	TRIPPED ON FAULT
634	05-Apr-24	HASSAN	LINE	66	HIREMANGLUR-CHIKAMANGALUR	HIREMANGLUR_66	16:21	16:48	00:27	TRIPPED ON FAULT
635	05-Apr-24	HASSAN	LINE	66	HIREMANGLUR-CKM220	HIREMANGLUR_66	16:21	16:48	00:27	LINE CLEAR AVAILED
636	05-Apr-24	HASSAN	LINE	66	HIREMANGLUR-RDL	HIREMANGLUR_66	16:21	16:48	00:27	LINE CLEAR AVAILED
637	05-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	23:09	23:34	00:25	TRIPPED ON FAULT
638	05-Apr-24	HASSAN	LINE	66	KUDLIGERE-ANVRPP	KUDLIGERE_66	14:11	14:16	00:05	LINE CLEAR AVAILED
639	05-Apr-24	HASSAN	LINE	66	SAKALESHPURA-HASSAN	SAKALESHPURA_66	23:09	23:35	00:26	TRIPPED ON FAULT
640	05-Apr-24	HASSAN	LINE	66	SAKALESHPURA-IPCL1	SAKALESHPURA_66	07:45	19:28	11:43	LINE CLEAR AVAILED
641	05-Apr-24	HASSAN	LINE	66	SAKALESHPURA-IPCL2	SAKALESHPURA_66	07:12	19:28	12:16	TRIPPED ON FAULT
642	05-Apr-24	HASSAN	LINE	110	BANTWAL-SALATTUR	BANTWAL_110	10:14	13:46	03:32	LINE CLEAR AVAILED
643	05-Apr-24	HASSAN	LINE	220	CRPATNA-HSN400	CRPATNA_220	17:16	20:51	03:35	LINE CLEAR AVAILED
644	05-Apr-24	HASSAN	LINE	220	HASSAN4-CR PATNA	SHANTIGRAMA_400	17:16	20:51	03:35	LINE CLEAR AVAILED
645	05-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMSG_220	01:46	14:21	12:35	TRIPPED ON FAULT
646	05-Apr-24	HASSAN	TRANSFORMER	66	HV1	HIREMANGLUR_66	16:19(5.4.2024)			TRIPPED ON FAULT
647	05-Apr-24	HASSAN	TRANSFORMER	66	HV1	HIREMANGLUR_66	16:19(5.4.2024)	11:35 (6.05.2024)	19:54 hrs	LINE CLEAR AVAILED
648	05-Apr-24	HASSAN	TRANSFORMER	110	HV1	ANANDAPURA_110	18:55	19:05	00:10	TRIPPED ON FAULT
649	5-Apr-24	MYSORE	LINE	66	BEGUR 220 -SARGUR	ANTHARSANTE_66 CHANDRAWADI_66 HD KOTE_66 HURA_66 HULLALLI_66 SARGUR_66 YEREHALLI HAND POST_66	13:59	14:06:00	0:07:00	TRIPPED ON FAULT
650	5-Apr-24	MYSORE	LINE	66	DR PETE-KUNTHUR	KUNTHUR_66 SANTHEMARALLI_66	14:32	14:41	0:09:00	TRIPPED ON FAULT
651	5-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53			LINE CLEAR AVAILED
652	5-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
653	5-Apr-24	MYSORE	LINE	66	HOOTGALLY-KAGGERE	NO STATIONS EFFECTED	17:28	17:34	00:06	LINE CLEAR AVAILED
654	5-Apr-24	MYSORE	LINE	66	JAYAPURA-HAMPAPURA	HAMPAPURA(K)_66	13:59	14:07:00	0:08:00	TRIPPED ON FAULT
655	5-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
656	5-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
657	5-Apr-24	MYSORE	LINE	66	S B HALLI-HARIYALDAMMA	HARIYALDAMMATEMPLE_66	20:00	20:10	00:10	TRIPPED ON FAULT
658	5-Apr-24	MYSORE	LINE	220	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	13:18:00	17:00	03:42	TRIPPED ON FAULT
659	5-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:43:00 (5/4/2024)			LINE CLEAR AVAILED
660	5-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36:00 (4/4/24)	7:45:00 (5/4/2024)	11:08:56	LINE CLEAR AVAILED
661	5-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
662	5-Apr-24	MYSORE	TRANSFORMER	66	HV2	ARAKERE_66	19:50:00 (4/4/24)	1:25:00 (5/4/24)	5:35:00	TRIPPED ON FAULT
663	5-Apr-24	MYSORE	TRANSFORMER	220	MADHUVANAHALLI-HV1	DODDINDUVADI_66 HANNUR_66 RAMAPURA_66 COWDALLI_66 AJJIPURA_66 MARTHALLI_66 BANDALLI_66 YELANDUR_66 MAMBALLI_66 LOKKANAHALLI_66 PG PALYA_66 KOTHNUR_66 SANTHEMARHALLI_66	14:32	14:45	00:13	TRIPPED ON FAULT
664	05-Apr-24	TUMKUR	LINE	66	BILCHODE-SOKKEPALLAGATTE	SOKKE-66kV Pallagatte-66kV	09:20	09:25	00:05	TRIPPED ON FAULT
665	05-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	17:43	17:53	00:10	TRIPPED ON FAULT
666	05-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-BEVINAHALLI	DASUDI_66	18:40	19:00	00:20	TRIPPED ON FAULT
667	05-Apr-24	TUMKUR	LINE	66	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	12:11	12:33	00:22	TRIPPED ON FAULT
668	05-Apr-24	TUMKUR	LINE	66	KADAJJI_66-DAVANGERE_220	KADAJJI_66	11:39	11:40	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
669	05-Apr-24	TUMKUR	LINE	110	KB CROSS 220kV- BANDIHALLI(TIPTUR)	BANDIHALLI_110, TIPTUR_110, HALKURKE_110, HUNASEGHTT_110, KEREGODI_110, KARADI_110	09:05	09:50	00:45	TRIPPED ON FAULT
670	05-Apr-24	TUMKUR	LINE	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	06:58	07:18	00:20	TRIPPED ON FAULT
671	05-Apr-24	TUMKUR	LINE	220	SIRA220-HIRIYUR1 220 LINE 1 & 2	SIRA_220	13:18 (02.3.24)		-	LINE CLEAR AVAILED
672	05-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- KAIGA2 400KV	GUTUR_400	19:56(4.4.24)	18:21(05.04.24)	22:25	LINE CLEAR AVAILED
673	06-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
674	06-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
675	06-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
676	06-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- GHATAPRABHA	GHATAPRABHA_220	13:30	15:25	01:55	LINE CLEAR AVAILED
677	06-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
678	06-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
679	06-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
680	06-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
681	06-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- BOMMANAL	MUGALKHOD_220	09:31	11:00	01:29	LINE CLEAR AVAILED
682	06-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- HIDIKAL	MUGALKHOD_220	10:28	11:51	01:23	LINE CLEAR AVAILED
683	06-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
684	06-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
685	06-Apr-24	BAGALKOTE	LINE	220	AMBEWADI- PONDA2	AMBEWADI_220	09:45	10:30	00:45	TRIPPED ON FAULT
686	06-Apr-24	BAGALKOTE	LINE	220	AMBEWADI- PONDA2	AMBEWADI_220	12:08	18:03	05:55	TRIPPED ON FAULT
687	06-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
688	06-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SIRSI_220	21:25	21:30	00:05	TRIPPED ON FAULT
689	06-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
690	06-Apr-24	BENGALURU	LINE	66	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	NO STATION AFFECTED	19:51	23:59	04:08	TRIPPED ON FAULT
691	06-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - AVERAHALLI	AVERAHALLI, T BEGUR	12:37	13:25	00:48	LINE CLEAR AVAILED
692	06-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	13:15	13:38	00:23	TRIPPED ON FAULT
693	06-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - ACC PLANT	ACC PLATN	16:06	16:24	00:18	MAIN SUPPLY FAILURE
694	06-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - ALLIPURA	ALIPURA, THONDEBHAVI	16:06	16:40	00:34	MAIN SUPPLY FAILURE
695	06-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI, GUDIBANDE, MANDIKAL	16:06	16:30	00:24	MAIN SUPPLY FAILURE
696	06-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	16:06	16:30	00:24	MAIN SUPPLY FAILURE
697	06-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDHURASHWATHA, GUNDLU KOTTUR	16:06	16:30	00:24	MAIN SUPPLY FAILURE
698	06-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	KADUBISANAHALLI	22:39	23:05	00:26	TRIPPED ON FAULT
699	06-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - BAGAMANE WTC 1	BAGHMANE WORLD TECH PARK	19:55	21:05	01:10	TRIPPED ON FAULT
700	06-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - BAGAMANE WTC 2	BAGHMANE WORLD TECH PARK	19:55	21:05	01:10	TRIPPED ON FAULT
701	06-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - BRIGADE METROPIS	BRIGADE METROPOLIS	19:51	20:32	00:41	TRIPPED ON FAULT
702	06-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	07:27	07:31	00:04	LINE CLEAR AVAILED
703	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 2	BANGARPETE	14:08	14:15	00:07	LINE CLEAR AVAILED
704	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 2	BANGARPETE	13:30	13:37	00:07	LINE CLEAR AVAILED
705	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 2	BANGARPETE	14:30	14:32	00:02	LINE CLEAR AVAILED
706	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - KEMBODI	KEMBODI	14:08	14:15	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
707	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NARASAPURA, HONDA, KC VALLEY, WISTRON EHT	14:10	14:19	00:09	LINE CLEAR AVAILED
708	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NARASAPURA	14:10	14:19	00:09	LINE CLEAR AVAILED
709	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	14:09	14:18	00:09	LINE CLEAR AVAILED
710	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA	TAMAKA	14:08	14:16	00:08	LINE CLEAR AVAILED
711	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA - DRDO	DRDO, MALLASANDRA	14:08	14:16	00:08	LINE CLEAR AVAILED
712	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	14:09	14:16	00:07	LINE CLEAR AVAILED
713	06-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	16:00	16:10	00:10	TRIPPED ON FAULT
714	06-Apr-24	BENGALURU	LINE	66	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	14:24	18:05	03:41	TRIPPED ON FAULT
715	06-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	02:22	02:50	00:28	TRIPPED ON FAULT
716	06-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	15:23	15:43	00:20	TRIPPED ON FAULT
717	06-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	15:23	15:33	00:10	TRIPPED ON FAULT
718	06-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	06:21	06:26	00:05	LINE CLEAR AVAILED
719	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	GUNDAMGERE, SASALU, AIR(EHT)	15:01	15:13	00:12	MAIN SUPPLY FAILURE
720	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	15:01	15:13	00:12	MAIN SUPPLY FAILURE
721	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 2	DODDABELAVANGALA	15:01	15:13	00:12	MAIN SUPPLY FAILURE
722	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - DEVANAHALLI 2	KUNDANA	15:01	15:10	00:09	MAIN SUPPLY FAILURE
723	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI, BRIGADE ORCHARDS	15:01	15:10	00:09	MAIN SUPPLY FAILURE
724	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	15:01	15:14	00:13	MAIN SUPPLY FAILURE
725	06-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	16:50	16:52	00:02	LINE CLEAR AVAILED
726	06-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	14:09	14:15	00:06	LINE CLEAR AVAILED
727	06-Apr-24	BENGALURU	LINE	66	66KV SHOBHA DREAMS 220 - BRIGADE UTOPIA GIS	BRIGADE CORNER STONE UTOPIA	14:10	15:09	00:59	LINE CLEAR AVAILED
728	06-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	10:19	10:24	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
729	06-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	18:16	18:20	00:04	LINE CLEAR AVAILED
730	06-Apr-24	BENGALURU	LINE	66	66KV SURYA CITY - ANEKAL 1	SURYA CITY	06:19	06:30	00:11	LINE CLEAR AVAILED
731	06-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	10:40	10:51	00:11	TRIPPED ON FAULT
732	06-Apr-24	BENGALURU	LINE	66	66KV TEKAL - BUDIKOTE	BUDIKOTE	16:55	17:05	00:10	LINE CLEAR AVAILED
733	06-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	04:30	04:50	00:20	TRIPPED ON FAULT
734	06-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	06:00	23:59	17:59	TRIPPED ON FAULT
735	06-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	06:19	06:30	00:11	LINE CLEAR AVAILED
736	06-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA I/A	17:32	18:07	00:35	TRIPPED ON FAULT
737	06-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	06:20	06:30	00:10	LINE CLEAR AVAILED
738	06-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	06:20	06:30	00:10	LINE CLEAR AVAILED
739	06-Apr-24	BENGALURU	LINE	220	220KV KOLAR 220 - MALUR 2	NO STATION AFFECTED	13:09	13:47	00:38	TRIPPED ON FAULT
740	06-Apr-24	BENGALURU	LINE	220	220KV NRS DB PURA 220 - BIAL BEGUR 220	NRS DB PURA 220	15:00	15:05	00:05	TRIPPED ON FAULT
741	06-Apr-24	BENGALURU	LINE	220	220KV NRS DB PURA 220 - BIAL BEGUR 220	NRS DB PURA 220	15:01	15:10	00:09	MAIN SUPPLY FAILURE
742	06-Apr-24	BENGALURU	LINE	400	DEVANAHALLI HARDWARE PARK 400 - PAVAGADA 2	NO STATION AFFECTED	13:48	14:59	01:11	TRIPPED ON FAULT
743	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TELECOM LAYOUT	17:45	18:35	00:50	TRIPPED ON FAULT
744	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ISKON	16:11	16:13	00:02	LINE CLEAR AVAILED
745	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NALLIMARADANAHALLI	05:05	05:20	00:15	TRIPPED ON FAULT
746	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NALLIMARADANAHALLI	08:10	08:15	00:05	LINE CLEAR AVAILED
747	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	16:06	16:24	00:18	MAIN SUPPLY FAILURE
748	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	AVANI	16:30	17:45	01:15	LINE CLEAR AVAILED
749	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DALASANUR	13:50	14:20	00:30	TRIPPED ON FAULT
750	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SUGUTUR	21:48	22:00	00:12	TRIPPED ON FAULT
751	06-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA I/A	17:28	18:26	00:58	TRIPPED ON FAULT
752	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KENGERI SATELLITE TOWN	08:37	08:42	00:05	LINE CLEAR AVAILED
753	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	PRESTIGE SHANTINIKETHAN	15:13	19:07	03:54	TRIPPED ON FAULT
754	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BRIGADE MEADOWS	16:18	16:27	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
755	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	JADIGENAHALLI	09:05	09:35	00:30	LINE CLEAR AVAILED
756	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVANAHALLI 66	22:10	22:15	00:05	TRIPPED ON FAULT
757	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GOWRIBIDANUR 220	16:06	16:24	00:18	MAIN SUPPLY FAILURE
758	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ADDAGAL	17:50	18:15	00:25	TRIPPED ON FAULT
759	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DALASANUR	17:00	17:10	00:10	TRIPPED ON FAULT
760	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KYASAMBALLI	16:50	18:00	01:10	LINE CLEAR AVAILED
761	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	LAKKUR	02:55	02:57	00:02	TRIPPED ON FAULT
762	06-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YARANDANAHALLI 220	06:20	06:30	00:10	LINE CLEAR AVAILED
763	06-Apr-24	BENGALURU	TRANSFORMER	66	HV3	CHIKKABALLAPURA I/A	14:40	15:40	01:00	LINE CLEAR AVAILED
764	06-Apr-24	BENGALURU	TRANSFORMER	220	HV1	NRS DB PURA 220	15:01	15:10	00:09	MAIN SUPPLY FAILURE
765	06-Apr-24	BENGALURU	TRANSFORMER	220	HV1	GOWRIBIDANUR 220	16:06	16:21	00:15	TRIPPED ON FAULT
766	06-Apr-24	BENGALURU	TRANSFORMER	220	HV1	KOLAR 220	14:11	14:13	00:02	LINE CLEAR AVAILED
767	06-Apr-24	BENGALURU	TRANSFORMER	220	HV2	GOWRIBIDANUR 220	16:06	16:21	00:15	TRIPPED ON FAULT
768	06-Apr-24	BENGALURU	TRANSFORMER	220	HV3	NRS DB PURA 220	15:01	15:10	00:09	MAIN SUPPLY FAILURE
769	6-Apr-2024	GULBARGA	LINE	66	TELAGI-GREEN INFRA WIND	TELAGI_66	14:45	19:55	05:10	LINE CLEAR AVAILED
770	6-Apr-2024	GULBARGA	LINE	110	KAPNOOR-GULBARGA WEST2	GULBARGA WEST_110	09:42	11:12	01:30	LINE CLEAR AVAILED
771	6-Apr-2024	GULBARGA	LINE	110	MYLAR-GUTLA1,2	MYLAR_110	19:50	20:15	00:25	MAIN SUPPLY FAILURE
772	6-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR1	SIRWAR_110	08:05	09:46	01:41	LINE CLEAR AVAILED
773	6-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR1	SIRWAR_110	14:04	14:47	00:43	LINE CLEAR AVAILED
774	6-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR2	GUGAL_110	02:15	02:22	00:07	TRIPPED ON FAULT
775	6-Apr-2024	GULBARGA	LINE	110	SANTHAPUR-HALBARGA	SANTHAPUR_110	17:40	19:20	01:40	LINE CLEAR AVAILED
776	6-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-RAICHUR2	GUGAL_110,GABUR_110 ,DEODURGA_110	20:21	20:30	00:09	LINE CLEAR AVAILED
777	6-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	10:55	13:05	02:10	LINE CLEAR AVAILED
778	6-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	11:06	13:13	02:07	LINE CLEAR AVAILED
779	6-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KURUGOD_110	11:45	11:50	00:05	TRIPPED ON FAULT
780	6-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KURUGOD_110	13:30	13:35	00:05	TRIPPED ON FAULT
781	6-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KURUGOD_110	18:00	18:05	00:05	TRIPPED ON FAULT
782	6-Apr-2024	GULBARGA	TRANSFORMER	220	HV1	RAICHUR_220	19:10(06.04.2024)			LINE CLEAR AVAILED
783	6-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	RAICHUR_220	19:10	20:45	01:35	TRIPPED ON FAULT
784	06-Apr-24	HASSAN	LINE	66	BHADRA-SHMG 2	bhadra_gen	12:30	16:20	03:50	TRIPPED ON FAULT
785	06-Apr-24	HASSAN	LINE	66	HASSN22-MALLALI	HASSAN_220	15:48	18:25	02:37	LINE CLEAR AVAILED
786	06-Apr-24	HASSAN	LINE	66	HASSN22-R R NAGAR	HASSAN_220	15:48	15:59	00:11	LINE CLEAR AVAILED
787	06-Apr-24	HASSAN	LINE	66	HASSN22-R R NAGAR	HASSAN_220	18:15	18:24	00:09	LINE CLEAR AVAILED
788	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_220	06:57	07:30	00:33	TRIPPED ON FAULT
789	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_220	09:11	09:15	00:04	TRIPPED ON FAULT
790	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_220	15:34:00	16:32	00:58	LINE CLEAR AVAILED
791	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_220	18:29	18:36	00:07	LINE CLEAR AVAILED
792	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA2	HASSAN_220	06:01	06:57	00:56	TRIPPED ON FAULT
793	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA2	HASSAN_220	06:56	07:56	01:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
794	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA2	HASSAN_220	07:56	09:17	01:21	TRIPPED ON FAULT
795	06-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA2	HASSAN_220	15:34	18:36	03:02	LINE CLEAR AVAILED
796	06-Apr-24	HASSAN	LINE	66	KANDLI-HASSAN	KANDLI_66	06:50	08:00	01:10	MAIN SUPPLY FAILURE
797	06-Apr-24	HASSAN	LINE	66	KANDLI-HASSAN	KANDLI_66	09:00	09:25	00:25	MAIN SUPPLY FAILURE
798	06-Apr-24	HASSAN	LINE	66	KANDLI-HASSAN	KANDLI_66	15:35	16:30	00:55	MAIN SUPPLY FAILURE
799	06-Apr-24	HASSAN	LINE	66	KANDLI-HASSAN	KANDLI_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
800	06-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	06:50	08:00	01:10	MAIN SUPPLY FAILURE
801	06-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	09:00	09:25	00:25	MAIN SUPPLY FAILURE
802	06-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	15:35	16:30	00:55	MAIN SUPPLY FAILURE
803	06-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
804	06-Apr-24	HASSAN	LINE	66	SAKALE-HASSAN1	SAKALESHPURA_66	06:55	07:35	00:40	MAIN SUPPLY FAILURE
805	06-Apr-24	HASSAN	LINE	66	SAKALE-HASSAN1	SAKALESHPURA_66	15:35	16:30	00:55	MAIN SUPPLY FAILURE
806	06-Apr-24	HASSAN	LINE	66	SAKALE-HASSAN1	SAKALESHPURA_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
807	06-Apr-24	HASSAN	LINE	66	SAKALE-IPCL1	SAKALESHPURA_66	06:55	19:55	13:00	MAIN SUPPLY FAILURE
808	06-Apr-24	HASSAN	LINE	66	SAKALE-IPCL2	SAKALESHPURA_66	06:55	19:55	13:00	MAIN SUPPLY FAILURE
809	06-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	08:41	08:57	00:16	TRIPPED ON FAULT
810	06-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	12:01	12:13	00:12	TRIPPED ON FAULT
811	06-Apr-24	HASSAN	LINE	110	GURUPUR-KAVOOR	GURUPURA_110	18:19	18:36	00:17	MAIN SUPPLY FAILURE
812	06-Apr-24	HASSAN	LINE	110	GURUPUR-MDBDRE	GURUPURA_110	18:19	18:36	00:17	MAIN SUPPLY FAILURE
813	06-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	17:52	18:13	00:21	MAIN SUPPLY FAILURE
814	06-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	18:18	19:21	01:03	MAIN SUPPLY FAILURE
815	06-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	20:17	20:55	00:38	MAIN SUPPLY FAILURE
816	06-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	17:52	18:13	00:21	MAIN SUPPLY FAILURE
817	06-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	20:17	20:49	00:32	MAIN SUPPLY FAILURE
818	06-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	17:52	18:13	00:21	MAIN SUPPLY FAILURE
819	06-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	18:18	19:21	01:03	MAIN SUPPLY FAILURE
820	06-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANAKERE_110	20:17	20:49	00:32	MAIN SUPPLY FAILURE
821	06-Apr-24	HASSAN	LINE	110	JMSEZ-OKATTE	MSEZ_220	18:19	18:47	00:28	MAIN SUPPLY FAILURE
822	06-Apr-24	HASSAN	LINE	110	KAVOOR-BANTWAL	KAVOOR_220	18:19	18:37	00:18	MAIN SUPPLY FAILURE
823	06-Apr-24	HASSAN	LINE	110	KAVOOR-KLSKR2	KAVOOR_220	18:19	18:37	00:18	MAIN SUPPLY FAILURE
824	06-Apr-24	HASSAN	LINE	110	KEMAR-BELMAN1	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
825	06-Apr-24	HASSAN	LINE	110	KEMAR-BELMAN1	KEMAR_220	20:14	20:39	00:25	MAIN SUPPLY FAILURE
826	06-Apr-24	HASSAN	LINE	110	KEMAR-BELMAN2	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE
827	06-Apr-24	HASSAN	LINE	110	KEMAR-BELMAN2	KEMAR_220	20:14	20:38	00:24	MAIN SUPPLY FAILURE
828	06-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE
829	06-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	20:14	20:35	00:21	MAIN SUPPLY FAILURE
830	06-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE
831	06-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	20:14	20:35	00:21	MAIN SUPPLY FAILURE
832	06-Apr-24	HASSAN	LINE	110	KEMAR-KARKALA	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE
833	06-Apr-24	HASSAN	LINE	110	KEMAR-KARKALA	KEMAR_220	20:14	20:52	00:38	MAIN SUPPLY FAILURE
834	06-Apr-24	HASSAN	LINE	110	KEMAR-Manipal1	KEMAR_220	18:19	18:46	00:27	MAIN SUPPLY FAILURE
835	06-Apr-24	HASSAN	LINE	110	KEMAR-Manipal1	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
836	06-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	18:19	18:46	00:27	MAIN SUPPLY FAILURE
837	06-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
838	06-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
839	06-Apr-24	HASSAN	LINE	110	KEMAR-MOODBIDRE	KEMAR_220	17:54	19:23	01:29	MAIN SUPPLY FAILURE
840	06-Apr-24	HASSAN	LINE	110	KEMAR-MOODBIDRE	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
841	06-Apr-24	HASSAN	LINE	110	MANIPAL-BRAMVR	MANIPAL_110	18:19	18:46	00:27	MAIN SUPPLY FAILURE
842	06-Apr-24	HASSAN	LINE	110	MANIPAL-BRAMVR	MANIPAL_110	20:14	20:37	00:23	MAIN SUPPLY FAILURE
843	06-Apr-24	HASSAN	LINE	110	MANIPAL-HIRIYADKA	MANIPAL_110	18:19	18:46	00:27	MAIN SUPPLY FAILURE
844	06-Apr-24	HASSAN	LINE	110	MANIPAL-HIRIYADKA	MANIPAL_110	20:14	20:38	00:24	MAIN SUPPLY FAILURE
845	06-Apr-24	HASSAN	LINE	110	MANIPAL-KEMAR1	MANIPAL_110	18:19	18:46	00:27	MAIN SUPPLY FAILURE
846	06-Apr-24	HASSAN	LINE	110	MANIPAL-KEMAR1	MANIPAL_110	20:14	20:32	00:18	MAIN SUPPLY FAILURE
847	06-Apr-24	HASSAN	LINE	110	MSEZ-BAIKAMPADI	MSEZ_220	18:19	18:49	00:30	MAIN SUPPLY FAILURE
848	06-Apr-24	HASSAN	LINE	110	MSEZ-GSS1	MSEZ_220	18:19	18:42	00:23	MAIN SUPPLY FAILURE
849	06-Apr-24	HASSAN	LINE	110	MSEZ-GSS2	MSEZ_220	18:19	18:42	00:23	MAIN SUPPLY FAILURE
850	06-Apr-24	HASSAN	LINE	110	MSEZ-KAVOOR	MSEZ_220	18:19	18:49	00:30	MAIN SUPPLY FAILURE
851	06-Apr-24	HASSAN	LINE	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:14	14:20	01:06	TRIPPED ON FAULT
852	06-Apr-24	HASSAN	LINE	220	KAVOOR-KEMAR3	KAVOOR_220	18:19	18:36	00:17	MAIN SUPPLY FAILURE
853	06-Apr-24	HASSAN	LINE	220	KAVOOR-KEMR1	KAVOOR_220	18:19	18:44	00:25	MAIN SUPPLY FAILURE
854	06-Apr-24	HASSAN	LINE	220	KEMAR-BAJPE1	KEMAR_220	18:19	18:36	00:17	TRIPPED ON FAULT
855	06-Apr-24	HASSAN	LINE	220	KEMAR-BAJPE1	KEMAR_220	18:19	18:36	00:17	TRIPPED ON FAULT
856	06-Apr-24	HASSAN	LINE	220	KEMAR-KAVOOR	KEMAR_220	18:19	18:35	00:16	TRIPPED ON FAULT
857	06-Apr-24	HASSAN	LINE	220	KEMAR-UPCL1	KEMAR_220	18:19	18:34	00:15	TRIPPED ON FAULT
858	06-Apr-24	HASSAN	LINE	220	KEMAR-UPCL2	KEMAR_220	18:19	18:34	00:15	TRIPPED ON FAULT
859	06-Apr-24	HASSAN	LINE	220	MSEZ-KAVOOR1	MSEZ_220	18:19	18:40	00:21	MAIN SUPPLY FAILURE
860	06-Apr-24	HASSAN	LINE	220	MSEZ-KAVOOR2	MSEZ_220	18:19	18:40	00:21	MAIN SUPPLY FAILURE
861	06-Apr-24	HASSAN	LINE	220	MSEZ-KEMAR1	MSEZ_220	18:19	18:37	00:18	MAIN SUPPLY FAILURE
862	06-Apr-24	HASSAN	LINE	220	MSEZ-KEMAR1	MSEZ_220	18:19	18:37	00:18	MAIN SUPPLY FAILURE
863	06-Apr-24	HASSAN	LINE	220	SGS1	TALAGUPPA_400	15:07	16:21	01:14	LINE CLEAR AVAILED
864	06-Apr-24	HASSAN	LINE	220	SHRAVITY-TALAGUPPA1	gen_sharavathy	16:56(6.04.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
865	06-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	15:07	16:21	01:14	LINE CLEAR AVAILED
866	06-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA1	gen_sharavathy	16:56(6.04.2024)	15:24 (7.04.2024)	22:27 hrs	TRIPPED ON FAULT
867	06-Apr-24	HASSAN	LINE	220	TALAGU-STRP2	TALAGUPPA_400	16:56(6.04.2024)			TRIPPED ON FAULT
868	06-Apr-24	HASSAN	LINE	220	TALAGU-STRP2	TALAGUPPA_400	16:56(6.04.2024)	15:24 (7.04.2024)	22:27 hrs	TRIPPED ON FAULT
869	06-Apr-24	HASSAN	TRANSFORMER	66	HV2	HIEMAGALUR_66	16:25	17:39	01:14	LINE CLEAR AVAILED
870	06-Apr-24	HASSAN	TRANSFORMER	66	HV2	HIEMAGALUR_66	08:40	09:40	01:00	LINE CLEAR AVAILED
871	06-Apr-24	HASSAN	TRANSFORMER	66	LV1	HASSAN_220	15:54	18:22	02:28	LINE CLEAR AVAILED
872	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	MSEZ_220	18:19	18:45	00:26	MAIN SUPPLY FAILURE
873	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	KEMAR_220	17:54	18:53	00:59	MAIN SUPPLY FAILURE
874	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	KEMAR_220	17:54	19:01	01:07	MAIN SUPPLY FAILURE
875	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
876	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
877	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	SALATHUR_110	15:53	15:59	00:06	TRIPPED ON FAULT
878	06-Apr-24	HASSAN	TRANSFORMER	110	HV1	SHIRALKOPPA_220	10:00	15:30	05:30	LINE CLEAR AVAILED
879	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	MSEZ_220	18:19	18:45	00:26	MAIN SUPPLY FAILURE
880	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	KEMAR_220	17:54	18:53	00:59	MAIN SUPPLY FAILURE
881	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	KEMAR_220	17:54	19:01	01:07	MAIN SUPPLY FAILURE
882	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
883	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	KEMAR_220	20:14	20:31	00:17	MAIN SUPPLY FAILURE
884	06-Apr-24	HASSAN	TRANSFORMER	110	HV2	SHIRALKOPPA_220	15:45	17:55	02:10	LINE CLEAR AVAILED
885	06-Apr-24	HASSAN	TRANSFORMER	110	LV1	KEMAR_220	18:19	18:44	00:25	TRIPPED ON FAULT
886	06-Apr-24	HASSAN	TRANSFORMER	110	LV1	KEMAR_220	20:14	20:30	00:16	TRIPPED ON FAULT
887	06-Apr-24	HASSAN	TRANSFORMER	110	LV2	KEMAR_220	17:54	19:18	01:24	TRIPPED ON FAULT
888	06-Apr-24	HASSAN	TRANSFORMER	110	LV2	KEMAR_220	20:14	20:31	00:17	TRIPPED ON FAULT
889	06-Apr-24	HASSAN	TRANSFORMER	110	LV3	KEMAR_220	17:54	20:44	02:50	TRIPPED ON FAULT
890	06-Apr-24	HASSAN	TRANSFORMER	220	HV1	HASSAN_220	15:54	18:22	02:28	LINE CLEAR AVAILED
891	06-Apr-24	HASSAN	TRANSFORMER	220	HV1	KEMAR_220	18:19	18:44	00:25	TRIPPED ON FAULT
892	06-Apr-24	HASSAN	TRANSFORMER	220	HV1	KEMAR_220	20:14	20:30	00:16	TRIPPED ON FAULT
893	06-Apr-24	HASSAN	TRANSFORMER	220	HV2	KEMAR_220	17:54	19:18	01:24	TRIPPED ON FAULT
894	06-Apr-24	HASSAN	TRANSFORMER	220	HV2	KEMAR_220	20:14	20:31	00:17	TRIPPED ON FAULT
895	06-Apr-24	HASSAN	TRANSFORMER	220	HV3	KEMAR_220	17:54	20:44	02:50	TRIPPED ON FAULT
896	6-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-BANNARIAMMAN 1	NO STATIONS EFFECTED	13:56	18:28	04:31	LINE CLEAR AVAILED
897	6-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-BANNARIAMMAN 2	NO STATIONS EFFECTED	13:56	18:24	04:28	LINE CLEAR AVAILED
898	6-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-KADKOLA	NO STATIONS EFFECTED	10:22	14:16	03:53	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
899	6-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53			LINE CLEAR AVAILED
900	6-Apr-24	MYSORE	LINE	66	HEBBANI-MEGHALAPURA	CHIDRAVALLI_66 THUMBLA_66 VYASARAJAPURA_66 GARGESHWARI_66	15:30	15:41	00:11	TRIPPED ON FAULT
901	6-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
902	6-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66	08:49	08:59	00:09	TRIPPED ON FAULT
903	6-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	10:34	14:11	03:37	LINE CLEAR AVAILED
904	6-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66	17:06	17:15	00:08	TRIPPED ON FAULT
905	6-Apr-24	MYSORE	LINE	66	KADAKOLA-DEVANUR	NO STATIONS EFFECTED	10:37	14:14	03:36	LINE CLEAR AVAILED
906	6-Apr-24	MYSORE	LINE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	18:43	18:46	00:03	TRIPPED ON FAULT
907	6-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
908	6-Apr-24	MYSORE	LINE	66	KRPETE-AKIHEBAL1	AKKIHEBBAL_66	10:05	14:21	04:16	LINE CLEAR AVAILED
909	6-Apr-24	MYSORE	LINE	66	KRPETE-AKIHEBAL2	AKKIHEBBAL_66	10:05	11:27	01:21	LINE CLEAR AVAILED
910	6-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
911	6-Apr-24	MYSORE	LINE	66	VAJMANGALA-KADKOLA1	AYRAHALLI-66 MARADIHUNDI_66	20:05	20:14	00:09	TRIPPED ON FAULT
912	6-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:50:00 (6/4/24)			LINE CLEAR AVAILED
913	6-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:43:00 (5/4/2024)	7:41:00 (6/4/24)	10:58:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
914	6-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGOD_66	12:23	12:26	00:02	TRIPPED ON FAULT
915	6-Apr-24	MYSORE	TRANSFORMER	66	HV1	HUNSUR_66	08:39	08:51	00:12	TRIPPED ON FAULT
916	6-Apr-24	MYSORE	TRANSFORMER	66	HV1	KOPPA_66	11:30	11:55	00:25	TRIPPED ON FAULT
917	6-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
918	6-Apr-24	MYSORE	TRANSFORMER	66	HV2	BETTADPURA_66	06:14	06:19	00:04	TRIPPED ON FAULT
919	6-Apr-24	MYSORE	TRANSFORMER	220	KADAKOLA-HV1	NO STATIONS EFFECTED	12:45	14:07	01:22	LINE CLEAR AVAILED
920	6-Apr-24	MYSORE	TRANSFORMER	220	KADAKOLA-HV2	NO STATIONS EFFECTED	10:39	12:41	02:02	LINE CLEAR AVAILED
921	06-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA LINE-1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	03:50	05:06	01:16	TRIPPED ON FAULT
922	06-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA-LINE-1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	00:00	00:15	00:15	TRIPPED ON FAULT
923	06-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV-CHALLAKERE_66	CHALLAKERE_66, SANIKERE_66	03:16	08:55	05:39	LINE CLEAR AVAILED
924	06-Apr-24	TUMKUR	LINE	66	HIRIYUR220kv-BEVINAHALLI_66	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASU DI_66,CHANGAVARA_66	17:40	19:55	02:15	TRIPPED ON FAULT
925	06-Apr-24	TUMKUR	LINE	66	HIRIYUR220kv-BEVINAHALLI_66	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASU DI_66,CHANGAVARA_66	17:40	19:55	02:15	TRIPPED ON FAULT
926	06-Apr-24	TUMKUR	LINE	66	HIRIYUR220kv-P R PURA	P R PURA_66	07:10	17:15	10:05	LINE CLEAR AVAILED
927	06-Apr-24	TUMKUR	LINE	66	HIRIYUR220kv-SIRA_66	SIRA_66	08:07	08:17	00:10	LINE CLEAR AVAILED
928	06-Apr-24	TUMKUR	LINE	66	HIRIYUR220kv-THALLAK_66	THALLAK_66	07:10	17:15	10:05	LINE CLEAR AVAILED
929	06-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kv- MADHUGIRI_66	MADHUGIRI_66, BADAVANAHALLI_66	11:15	11:22	00:07	TRIPPED ON FAULT
930	06-Apr-24	TUMKUR	LINE	66	MADHUGIRI_66- BADAVANAHALLI_66	BADAVANAHALLI_66	11:35	13:02	01:27	TRIPPED ON FAULT
931	06-Apr-24	TUMKUR	LINE	66	MADHURE_220KV-HOSADURGA_66	HOSADURGA_66,NEER GUNDAGATE	05:40	05:55	00:15	TRIPPED ON FAULT
932	06-Apr-24	TUMKUR	LINE	66	PAVAGADA 220kv- SHYLAPURA	SHYLAPURA_66	18:06	18:10	00:04	TRIPPED ON FAULT
933	06-Apr-24	TUMKUR	LINE	66	TMTP_66- THOVINKERE_66	THOVINAKERE_66,	19:05	20:25	01:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
934	06-Apr-24	TUMKUR	LINE	220	SIRA220-HIRIYUR1 220 LINE 1 & 2	SIRA_220	13:18 (02.3.24)		-	LINE CLEAR AVAILED
935	06-Apr-24	TUMKUR	TRANSFORMER	66	HV-1 (HV SIDE)	HIRIYUR_220	14:09	14:22	00:13	TRIPPED ON FAULT
936	06-Apr-24	TUMKUR	TRANSFORMER	66	HV-3 (HV SIDE)	HIRIYUR_220	08:17	09:03	00:46	LINE CLEAR AVAILED
937	06-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	ANTHRASANAHALLI_220	16:25	17:55	01:30	LINE CLEAR AVAILED
938	07-Apr-24	BAGALKOTE	LINE	110	ATHANI220- GHATANATTI	ATHANI_220	06:28	06:47	00:19	TRIPPED ON FAULT
939	07-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
940	07-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
941	07-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
942	07-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- BHOJ	CHIKKODI_220	09:00	10:23	01:23	LINE CLEAR AVAILED
943	07-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- RAIBAG1	CHIKKODI_220	09:32	11:10	01:38	LINE CLEAR AVAILED
944	07-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	05:27	05:35	00:08	TRIPPED ON FAULT
945	07-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
946	07-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
947	07-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
948	07-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
949	07-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- KULIGOD	MUGALKHOD_220	01:41	01:52	00:11	TRIPPED ON FAULT
950	07-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
951	07-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
952	07-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
953	07-Apr-24	BENGALURU	LINE	66	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	06:17	06:46	00:29	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
954	07-Apr-24	BENGALURU	LINE	66	66KV AREHALLI - BANASHANKARI	AREHALLI	16:27	16:33	00:06	LINE CLEAR AVAILED
955	07-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
956	07-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI, BURUDAGUNTE	04:40	04:46	00:06	TRIPPED ON FAULT
957	07-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA 66, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	10:20	10:27	00:07	LINE CLEAR AVAILED
958	07-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA 66, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	09:23	09:39	00:16	MAIN SUPPLY FAILURE
959	07-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	13:33	16:10	02:37	TRIPPED ON FAULT
960	07-Apr-24	BENGALURU	LINE	66	66KV EPIP 220 - BRIGADE TECH GARDEN	BRIGADE TECH GARDEN	19:14	20:31	01:17	TRIPPED ON FAULT
961	07-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	14:20	14:30	00:10	LINE CLEAR AVAILED
962	07-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	11:26	11:34	00:08	LINE CLEAR AVAILED
963	07-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SOUDELA, ANNABEL(DLF)	14:02	15:41:00	01:39	MAIN SUPPLY FAILURE
964	07-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - FALSON CITY	PRESTIGE FALCON CITY	14:02	15:41:00	01:39	MAIN SUPPLY FAILURE
965	07-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NO STATION AFFECTED	20:32	20:47	00:15	TRIPPED ON FAULT
966	07-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NO STATION AFFECTED	21:24	21:35	00:11	TRIPPED ON FAULT
967	07-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	14:22	14:35	00:13	TRIPPED ON FAULT
968	07-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA, KHODAYS 220	09:34	10:03	00:29	TRIPPED ON FAULT
969	07-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, GOWNIPALLI, RAYALPADU, SOMAYAJANAHALLI	07:51	08:32	00:41	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
970	07-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	09:40	09:44	00:04	LINE CLEAR AVAILED
971	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	14:02	14:31	00:29	MAIN SUPPLY FAILURE
972	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	10:10	10:14	00:04	LINE CLEAR AVAILED
973	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	11:20	11:25	00:05	LINE CLEAR AVAILED
974	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO	10:51	10:53	00:02	LINE CLEAR AVAILED
975	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	GLOBAL TECH PARK(EHT)	11:40	11:48	00:08	LINE CLEAR AVAILED
976	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	14:03	15:51	01:48	MAIN SUPPLY FAILURE
977	07-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	SUBRAMANYAPURA 66	15:53	15:58	00:05	LINE CLEAR AVAILED
978	07-Apr-24	BENGALURU	LINE	66	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	11:00	11:30	00:30	LINE CLEAR AVAILED
979	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	09:23	09:34	00:11	MAIN SUPPLY FAILURE
980	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	10:26	10:32	00:06	LINE CLEAR AVAILED
981	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	09:23	09:34	00:11	MAIN SUPPLY FAILURE
982	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	10:26	10:32	00:06	LINE CLEAR AVAILED
983	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	09:23	09:32	00:09	MAIN SUPPLY FAILURE
984	07-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	10:27	10:33	00:06	LINE CLEAR AVAILED
985	07-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
986	07-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA I/A	12:10	13:26	01:16	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
987	07-Apr-24	BENGALURU	LINE	220	220KV HOODY 220 - MALUR 220	VIKAS TECH PARK 220, EXORA 220, SARJAPURA 220	09:24	09:31	00:07	TRIPPED ON FAULT
988	07-Apr-24	BENGALURU	LINE	220	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	14:04	14:36	00:32	TRIPPED ON FAULT
989	07-Apr-24	BENGALURU	LINE	220	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220, KHODAYS 220	14:42	15:19	00:37	TRIPPED ON FAULT
990	07-Apr-24	BENGALURU	LINE	220	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220, KHODAYS 220	15:26	15:50	00:24	TRIPPED ON FAULT
991	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ATTUR YELAHANKA	08:51	09:02	00:11	LINE CLEAR AVAILED
992	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	WELCAST	11:08	11:17	00:09	LINE CLEAR AVAILED
993	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	S M MANGALA	09:05	09:18	00:13	TRIPPED ON FAULT
994	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TEKAL	13:25	13:50	00:25	TRIPPED ON FAULT
995	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	09:24	09:43	00:19	LINE CLEAR AVAILED
996	07-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	17:25	17:35	00:10	LINE CLEAR AVAILED
997	07-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ATTUR YELAHANKA	08:51	09:02	00:11	LINE CLEAR AVAILED
998	07-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUNDAMGERE	07:12	07:17	00:05	TRIPPED ON FAULT
999	07-Apr-24	BENGALURU	TRANSFORMER	66	HV2	LAKSHMIPURA	14:22	16:00	01:38	TRIPPED ON FAULT
1000	07-Apr-24	BENGALURU	TRANSFORMER	66	HV2	S M MANGALA	21:43	22:12	00:29	TRIPPED ON FAULT
1001	07-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TAVAREKERE	12:28	13:35	01:07	LINE CLEAR AVAILED
1002	07-Apr-24	BENGALURU	TRANSFORMER	66	HV3	A STATION 66	08:34	08:37	00:03	LINE CLEAR AVAILED
1003	07-Apr-24	BENGALURU	TRANSFORMER	66	HV3	A STATION 66	20:30	20:34	00:04	LINE CLEAR AVAILED
1004	07-Apr-24	BENGALURU	TRANSFORMER	66	HV3	TAVAREKERE	19:05	19:15	00:10	LINE CLEAR AVAILED
1005	07-Apr-24	BENGALURU	TRANSFORMER	66	HV4	A STATION 66	08:34	08:37	00:03	LINE CLEAR AVAILED
1006	07-Apr-24	BENGALURU	TRANSFORMER	66	HV4	A STATION 66	20:30	20:34	00:04	LINE CLEAR AVAILED
1007	07-Apr-24	BENGALURU	TRANSFORMER	220	HV1	SUBRAMANYAPURA 220	14:03	14:54	00:51	MAIN SUPPLY FAILURE
1008	07-Apr-24	BENGALURU	TRANSFORMER	220	HV2	SUBRAMANYAPURA 220	14:03	14:54	00:51	MAIN SUPPLY FAILURE
1009	07-Apr-24	BENGALURU	TRANSFORMER	220	HV3	SUBRAMANYAPURA 220	14:03	14:54	00:51	MAIN SUPPLY FAILURE
1010	7-Apr-2024	GULBARGA	LINE	110	ALIPUR-PDHALLI	PD_HALLI_110	06:58	18:16	11:18	LINE CLEAR AVAILED
1011	7-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-PDHALLI	MOKA_110,SOMASAMU NDRA_110,BISIHALLI_110	06:50	08:55	02:05	LINE CLEAR AVAILED
1012	7-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-PDHALLI	MOKA_110,SOMASAMU NDRA_110,BISIHALLI_110	16:51	18:13	01:22	LINE CLEAR AVAILED
1013	7-Apr-2024	GULBARGA	LINE	110	HALWARTHY-GINIGERA	GINIGERA_110	17:38	18:05	00:27	LINE CLEAR AVAILED
1014	7-Apr-2024	GULBARGA	LINE	110	KAPNOOR-KAPNOOR	KAPNOOR_110	08:30	13:10	04:40	LINE CLEAR AVAILED
1015	7-Apr-2024	GULBARGA	LINE	110	KAPNOOR-KAPNOOR	KAPNOOR_110	13:22	13:25	00:03	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1016	7-Apr-2024	GULBARGA	LINE	110	KAPNOOR-KAPNOOR	KAPNOOR_110	13:56	14:14	00:18	LINE CLEAR AVAILED
1017	7-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-HATTI	HATTI_110	13:20	15:54	02:34	LINE CLEAR AVAILED
1018	7-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-MUDAGAL	MUDAGAL_110	09:42	14:25	04:43	LINE CLEAR AVAILED
1019	7-Apr-2024	GULBARGA	LINE	110	NALWAR-SHAHBAD	NALWAR_110	12:37	13:30	00:53	LINE CLEAR AVAILED
1020	7-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR2	GUGAL_110	03:05	03:15	00:10	TRIPPED ON FAULT
1021	7-Apr-2024	GULBARGA	LINE	110	SANTHPUR-JANAWADA	JANAWADA_110	00:00	12:50	12:50	LINE CLEAR AVAILED
1022	7-Apr-2024	GULBARGA	LINE	110	WADI-YADGIR	WADI_110	09:35	10:27	00:52	LINE CLEAR AVAILED
1023	7-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	BISIHALLI_110	14:06	14:19	00:13	TRIPPED ON FAULT
1024	7-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	LINGASUGUR_220	09:42	14:25	04:43	LINE CLEAR AVAILED
1025	07-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	04:17	04:26	00:09	TRIPPED ON FAULT
1026	07-Apr-24	HASSAN	LINE	66	HNPR2-CRPTN	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1027	07-Apr-24	HASSAN	LINE	66	HNPR2-HASS1	HOLENARASIPURA_220	04:00	07:15	03:15	MAIN SUPPLY FAILURE
1028	07-Apr-24	HASSAN	LINE	66	HNPR2-HASS2	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1029	07-Apr-24	HASSAN	LINE	66	HNPR2-HASS3	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1030	07-Apr-24	HASSAN	LINE	66	HNPR2-HNPR1	HOLENARASIPURA_220	02:45	03:05	00:20	TRIPPED ON FAULT
1031	07-Apr-24	HASSAN	LINE	66	HNPR2-HNPR1	HOLENARASIPURA_220	04:00	07:13	03:13	MAIN SUPPLY FAILURE
1032	07-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR1	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1033	07-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR2	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1034	07-Apr-24	HASSAN	LINE	66	HNPR2-RNPR1	HOLENARASIPURA_220	04:00	07:18	03:18	MAIN SUPPLY FAILURE
1035	07-Apr-24	HASSAN	LINE	66	HNPR2-RNPR2	HOLENARASIPURA_220	04:00	07:17	03:17	MAIN SUPPLY FAILURE
1036	07-Apr-24	HASSAN	LINE	66	KIADB H-RAMESWARNAGAR	KIADB HASSAN_66	04:52	05:25	00:33	TRIPPED ON FAULT
1037	07-Apr-24	HASSAN	LINE	66	MALALI-CRPATNA	MALALI_66	04:00	07:25	03:25	MAIN SUPPLY FAILURE
1038	07-Apr-24	HASSAN	LINE	66	MALALI-HASSAN	MALALI_66	04:00	07:25	03:25	MAIN SUPPLY FAILURE
1039	07-Apr-24	HASSAN	LINE	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	04:00	04:30	00:30	MAIN SUPPLY FAILURE
1040	07-Apr-24	HASSAN	LINE	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	04:00	04:30	00:30	MAIN SUPPLY FAILURE
1041	07-Apr-24	HASSAN	LINE	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	07:20	07:25	00:05	LINE CLEAR AVAILED
1042	07-Apr-24	HASSAN	LINE	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	04:50	05:25	00:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1043	07-Apr-24	HASSAN	LINE	66	SAKALE-IPCL1	SAKALESH PURA_66	09:30	13:45	04:15	LINE CLEAR AVAILED
1044	07-Apr-24	HASSAN	LINE	220	HNPR2-GPLPR1	HOLENARASIPURA_220	04:00	07:10	03:10	MAIN SUPPLY FAILURE
1045	07-Apr-24	HASSAN	LINE	220	HNPR2-GPLPR2	HOLENARASIPURA_220	04:00	07:10	03:10	MAIN SUPPLY FAILURE
1046	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	HANGARANAHALLI_66	04:00	07:16	22:27 hrs	MAIN SUPPLY FAILURE
1047	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	HARIHAR PURA_66	04:00	07:23	03:23	MAIN SUPPLY FAILURE
1048	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_66	04:00	07:14	03:14	MAIN SUPPLY FAILURE
1049	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	MALALI_66	04:00	07:25	03:25	MAIN SUPPLY FAILURE
1050	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	MOSALEHOSAHALLI_66	04:00	04:30	00:30	MAIN SUPPLY FAILURE
1051	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	MOSALEHOSAHALLI_66	07:20	07:25	00:05	MAIN SUPPLY FAILURE
1052	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATH PURA_66	14:14	14:32	00:18	MAIN SUPPLY FAILURE
1053	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATH PURA_66	20:25	20:41	00:16	MAIN SUPPLY FAILURE
1054	07-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATH PURA_66	23:42	23:48	00:06	MAIN SUPPLY FAILURE
1055	07-Apr-24	HASSAN	TRANSFORMER	66	HV2	HNPURA_66	04:07	07:15	03:08	MAIN SUPPLY FAILURE
1056	07-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATH PURA_66	14:14	14:32	00:18	MAIN SUPPLY FAILURE
1057	07-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATH PURA_66	20:25	20:41	00:16	MAIN SUPPLY FAILURE
1058	07-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATH PURA_66	23:42	23:48	00:06	MAIN SUPPLY FAILURE
1059	07-Apr-24	HASSAN	TRANSFORMER	66	Lv1	HOLENARASIPURA_220	04:00	07:13	03:13	MAIN SUPPLY FAILURE
1060	07-Apr-24	HASSAN	TRANSFORMER	66	Lv2	HOLENARASIPURA_220	04:00	07:13	03:13	MAIN SUPPLY FAILURE
1061	7-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53			LINE CLEAR AVAILED
1062	7-Apr-24	MYSORE	LINE	66	HONGANUR-YELANDUR	NO STATIONS EFFECTED	21:57	22:52	00:55	TRIPPED ON FAULT
1063	7-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)	8:02 (7/04/2024)	1732:05	LINE CLEAR AVAILED
1064	7-Apr-24	MYSORE	LINE	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	07:39	07:41	00:02	LINE CLEAR AVAILED
1065	7-Apr-24	MYSORE	LINE	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	17:24	17:28	00:03	LINE CLEAR AVAILED
1066	7-Apr-24	MYSORE	LINE	66	HUNSUR 220-HUNSUR 2	HUNSUR_66	15:08	15:27	00:19	TRIPPED ON FAULT
1067	7-Apr-24	MYSORE	LINE	66	HUNSUR-220 HUNSUR 1	BANNIKUPPE_66ELAVALA_66 GAVADAGERE_66BILIKERE_66GVGUDI_66	15:08	15:53	00:45	TRIPPED ON FAULT
1068	7-Apr-24	MYSORE	LINE	66	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	16:23	16:57	00:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1069	7-Apr-24	MYSORE	LINE	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	08:37	15:26	06:48	LINE CLEAR AVAILED
1070	7-Apr-24	MYSORE	LINE	66	HUNSUR-HUNSUR 2	HUNSUR_66	15:50	15:53	00:02	LINE CLEAR AVAILED
1071	7-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1072	7-Apr-24	MYSORE	LINE	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	08:33	15:13	06:40	LINE CLEAR AVAILED
1073	7-Apr-24	MYSORE	LINE	66	KR NAGARA-KUSHALNAGARA	NO STATIONS EFFECTED	08:33	15:15	06:41	LINE CLEAR AVAILED
1074	7-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1075	7-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANATHAPURA	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66	15:07	17:29	02:22	TRIPPED ON FAULT
1076	7-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANATHAPURA	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66	20:01	23:54	03:53	TRIPPED ON FAULT
1077	7-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	14:50	14:54	00:04	TRIPPED ON FAULT
1078	7-Apr-24	MYSORE	LINE	220	HUNSUR 220-BASTIPURA 1	NO STATIONS EFFECTED	09:28	14:42	05:14	LINE CLEAR AVAILED
1079	7-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:50:00 (6/4/24)	7:07 (7/04/2024)	10:16	LINE CLEAR AVAILED
1080	7-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:40 (7/04/2024)			LINE CLEAR AVAILED
1081	7-Apr-24	MYSORE	LINE	220	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	04:02	07:12	03:10	LINE CLEAR AVAILED
1082	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGODU_66	11:20	13:07	01:47	LINE CLEAR AVAILED
1083	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGODU_66	13:42	13:46	00:03	TRIPPED ON FAULT
1084	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDGERE_66	04:05	07:20	03:15	MAIN SUPPLY FAILURE
1085	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	SHIVALLY_66	14:50	15:38	00:48	LINE CLEAR AVAILED
1086	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1087	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	SINDHUVALI_66	16:26	16:45	00:19	LINE CLEAR AVAILED
1088	7-Apr-24	MYSORE	TRANSFORMER	66	HV1	HURA_66	10:40	10:45	00:05	TRIPPED ON FAULT
1089	7-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	07:39	07:46	00:07	TRIPPED ON FAULT
1090	07-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	16:17	20:20	04:03	TRIPPED ON FAULT
1091	07-Apr-24	TUMKUR	LINE	66	BADALADAKU_220-BILCHODU_66,PALLAGHATTE_66	BILCHODU_66,PALLAGHATTE_66,SOKKE_66	05:55	06:05	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1092	07-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- PANDARAHALLI 1	SIRIGERE_66, VIJAPURA_66, BRAHMASAGARA_IPP_66	12:25	12:38	00:13	TRIPPED ON FAULT
1093	07-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA LINE-1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	06:01	06:11	00:10	TRIPPED ON FAULT
1094	07-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA LINE-2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE,WATER WORKS,DSCL_66,	20:37	20:45	00:08	TRIPPED ON FAULT
1095	07-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV-CHALLAKERE_66	CHALLAKERE_66, SANIKERE_66	22:50	23:00	00:10	TRIPPED ON FAULT
1096	07-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV-CHALLAKERE_66	CHALLAKERE_66, SANIKERE_66	22:55	23:07	00:12	TRIPPED ON FAULT
1097	07-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	P R PURA_66	07:30	17:40	10:10	LINE CLEAR AVAILED
1098	07-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-THALLAK_66	THALLAK_66	07:30	17:46	10:16	LINE CLEAR AVAILED
1099	07-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66	10:53	11:09	00:16	TRIPPED ON FAULT
1100	07-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66	22:59	23:10	00:11	TRIPPED ON FAULT
1101	07-Apr-24	TUMKUR	LINE	66	KUKKAWADA_66- BASAVAPATNA_66,	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66,	10:04	10:14	00:10	TRIPPED ON FAULT
1102	07-Apr-24	TUMKUR	LINE	66	KUKKAWADA_66- BASAVAPATNA_66,	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66,	17:11	17:16	00:05	TRIPPED ON FAULT
1103	07-Apr-24	TUMKUR	LINE	66	TAVAREKERE_66 JAVAGONDANAHALLI_66,	TAVAREKERE_66	10:35	10:45	00:10	TRIPPED ON FAULT
1104	07-Apr-24	TUMKUR	LINE	66	TAVAREKERE - JAVAGONDANAHALLI_66,	TAVAREKERE_66	10:50	11:00	00:10	TRIPPED ON FAULT
1105	07-Apr-24	TUMKUR	LINE	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	11:15	13:45	02:30	LINE CLEAR AVAILED
1106	07-Apr-24	TUMKUR	LINE	220	SIRA220-HIRIYUR1 220 LINE 1 & 2	SIRA_220	13:18 (02.3.24)		-	LINE CLEAR AVAILED
1107	07-Apr-24	TUMKUR	LINE	400	GUTUR_400-BEERANAHALLI-1	GUTUR_400	10:36	16:59	06:23	LINE CLEAR AVAILED
1108	07-Apr-24	TUMKUR	TRANSFORMER	110	TR-1	NITTUR_110	18:04	18:14	00:10	TRIPPED ON FAULT
1109	08-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1110	08-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1111	08-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1112	08-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	00:30	00:39	00:09	TRIPPED ON FAULT
1113	08-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	04:30	04:35	00:05	TRIPPED ON FAULT
1114	08-Apr-24	BAGALKOTE	LINE	110	HAVERI220- BASAVANAKATTI	HAVERI_220	03:59	12:37	08:38	TRIPPED ON FAULT
1115	08-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1116	08-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
1117	08-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1118	08-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1119	08-Apr-24	BAGALKOTE	LINE	110	MUGALKHID220- MAHALINGAPUR	MUGALKHOD_220	10:51	12:26	01:35	LINE CLEAR AVAILED
1120	08-Apr-24	BAGALKOTE	LINE	110	MUGALKHID220- PG HUNSHYAL	MUGALKHOD_220	09:33	11:07	01:34	LINE CLEAR AVAILED
1121	08-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1122	08-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220- HONNATTI	RANEBENNUR_220	16:05	16:18	00:13	LINE CLEAR AVAILED
1123	08-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- KATARAKI	VAJRAMATTI_220	20:18 (08.04.2024)			LINE CLEAR AVAILED
1124	08-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1125	08-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	10:45	16:30	05:45	LINE CLEAR AVAILED
1126	08-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1127	08-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI220- ENERCON	VAJRAMATTI_220	12:58	13:08	00:10	TRIPPED ON FAULT
1128	08-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(5MVA)	ANMOD_110	10:10	10:15	00:05	TRIPPED ON FAULT
1129	08-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(5MVA)	ANMOD_110	10:40	15:35	04:55	LINE CLEAR AVAILED
1130	08-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1131	08-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - IRGAMPALLY	IRAGAMPALLI, M GOLLAHALLI	10:05	10:10	00:05	LINE CLEAR AVAILED
1132	08-Apr-24	BENGALURU	LINE	66	66KV HANUMANTHANAGARA - YEDAMADU	HANUMANTHNAGARA	08:20	08:25	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1133	08-Apr-24	BENGALURU	LINE	66	66KV KANAKAPURA 220 - CHATHRA MARALAVADI - HANUMANTHANAGARA	HANUMANTHANAGARA	09:15	09:20	00:05	LINE CLEAR AVAILED
1134	08-Apr-24	BENGALURU	LINE	66	66KV MANDIKAL - PERESANDRA	MANDIKAL	15:30	15:35	00:05	LINE CLEAR AVAILED
1135	08-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SADHALI	SADALI, JULUPALYA	09:05	09:10	00:05	LINE CLEAR AVAILED
1136	08-Apr-24	BENGALURU	LINE	66	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY PH2 SEC 2, HUSKUR, TATA BP SOLAR	12:19	12:22	00:03	MAIN SUPPLY FAILURE
1137	08-Apr-24	BENGALURU	LINE	66	66KV NAGANATHPURA 220 - ELECTRONIC CITY PHASE-2 SECTOR-1 (VELANKANI)	ELECTRONIC CITY PH2 SEC 1, HULIMANGALA, ELECTRONIC CITY, TECH MAHINDRA(EHT)	12:19	12:23	00:04	MAIN SUPPLY FAILURE
1138	08-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLI	09:18	09:36	00:18	LINE CLEAR AVAILED
1139	08-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	06:12	06:16	00:04	LINE CLEAR AVAILED
1140	08-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - YEDAMADU	YEDUMADU, HANUMANTHANAGARA	19:34	20:00	00:26	TRIPPED ON FAULT
1141	08-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1142	08-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KENGERI SATELLITE TOWN	08:36	08:40	00:04	LINE CLEAR AVAILED
1143	08-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SIDLAGHATTA	09:05	10:05	01:00	TRIPPED ON FAULT
1144	08-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SM MANGALA	14:09	14:30	00:21	TRIPPED ON FAULT
1145	08-Apr-24	BENGALURU	TRANSFORMER	66	HV1	LAKKUR	08:00	10:35	02:35	LINE CLEAR AVAILED
1146	08-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TAVAREKERE	10:52	11:20	00:28	TRIPPED ON FAULT
1147	08-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BRIGADE METROPOLIS	18:26	18:31	00:05	LINE CLEAR AVAILED
1148	08-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SULIBELE	13:07	13:35	00:28	LINE CLEAR AVAILED
1149	08-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NARASAPURA	16:00	16:10	00:10	LINE CLEAR AVAILED
1150	08-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KYASAMBALLI	12:35	12:45	00:10	TRIPPED ON FAULT
1151	08-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KANAKAPURA 66	21:10	21:30	00:20	TRIPPED ON FAULT
1152	08-Apr-24	BENGALURU	TRANSFORMER	66	HV5	NRS 220	12:52	14:03	01:11	LINE CLEAR AVAILED
1153	08-Apr-24	BENGALURU	TRANSFORMER	220	HV1	NAGANATHPURA 220	12:19	12:20	00:01	TRIPPED ON FAULT
1154	08-Apr-24	BENGALURU	TRANSFORMER	220	HV2	NAGANATHPURA 220	12:19	12:22	00:03	TRIPPED ON FAULT
1155	8-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	05:55	06:16	00:21	TRIPPED ON FAULT
1156	8-Apr-2024	GULBARGA	LINE	66	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBAJ JIHALLI_66	10:10	10:20	00:10	TRIPPED ON FAULT
1157	8-Apr-2024	GULBARGA	LINE	110	ADAVIAMARESHWAR-MALLAT	ADAVIAMARESHWAR_110	12:38	13:25	00:47	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1158	8-Apr-2024	GULBARGA	LINE	110	CHICKSUGUR-APMC	CHICKSUGUR_110, SHAKTINAGAR_110	18:29	18:50	00:21	LINE CLEAR AVAILED
1159	8-Apr-2024	GULBARGA	LINE	110	CHICKSUGUR-VADAVATTI	VADAVATTI_110	11:10	20:05	08:55	LINE CLEAR AVAILED
1160	8-Apr-2024	GULBARGA	LINE	110	GUGAL-GABUR	GUGAL_110	03:05	03:15	00:10	MAIN SUPPLY FAILURE
1161	8-Apr-2024	GULBARGA	LINE	110	HALBARGA-DUBALGUNDI	DUBALGUNDI_110	04:07	04:15	00:08	TRIPPED ON FAULT
1162	8-Apr-2024	GULBARGA	LINE	110	HUMNABAD-BHALKI	BHALKI_110	04:04	04:15	00:11	TRIPPED ON FAULT
1163	8-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MADIYAL	MADIYAL_110, CHOWDAPUR_110	02:40	02:54	00:14	TRIPPED ON FAULT
1164	8-Apr-2024	GULBARGA	LINE	110	RAICHUR-APMC	APMC_110	22:15	22:20	00:05	TRIPPED ON FAULT
1165	8-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-KHANAPUR2	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SANNATHI_IPP,CORE GREEN SUGAR_IPP	02:22	02:36	00:14	TRIPPED ON FAULT
1166	8-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-SHORAPUR(DEVAPUR)	SHORAPUR_110,DEVAPUR_110	04:43	04:56	00:13	TRIPPED ON FAULT
1167	8-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	14:28	14:33	00:05	TRIPPED ON FAULT
1168	8-Apr-2024	GULBARGA	LINE	110	WALKAMDINI-BYAGWAT	WALKAMDINI_110, BYAGWAT_110	15:35	16:35	01:00	LINE CLEAR AVAILED
1169	8-Apr-2024	GULBARGA	LINE	110	WALKAMDINI-SINDHANOOR	WALKAMDINI_110	10:25	11:35	01:10	LINE CLEAR AVAILED
1170	8-Apr-2024	GULBARGA	LINE	220	LINGAPUR-JVSL2	LINGAPUR_220	07:54	16:43	08:49	LINE CLEAR AVAILED
1171	8-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	12:40	13:45	01:05	TRIPPED ON FAULT
1172	8-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	13:45	18:16	04:31	TRIPPED ON FAULT
1173	8-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	TAMBRAHALLI_66	23:40	23:45	00:05	TRIPPED ON FAULT
1174	8-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	APMC_110	10:05	12:49	02:44	LINE CLEAR AVAILED
1175	8-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	KURDICROSS	11:03	12:05	01:02	LINE CLEAR AVAILED
1176	8-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GABUR_110	11:15	11:40	00:25	LINE CLEAR AVAILED
1177	8-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	T B HALLI_66	23:40	23:45	00:05	TRIPPED ON FAULT
1178	8-Apr-2024	GULBARGA	TRANSFORMER	110	HV4	AFZALPUR_110	12:40	14:15	01:35	LINE CLEAR AVAILED
1179	8-Apr-2024	GULBARGA	TRANSFORMER	220	HV1	KAPNOOR_220	12:53	14:31	01:38	LINE CLEAR AVAILED
1180	08-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_22	15:52	17:05	01:13	LINE CLEAR AVAILED
1181	08-Apr-24	HASSAN	LINE	110	HIRIYA-MADHUVANA	HIRIYADKA_110	00:12	00:24	00:12	TRIPPED ON FAULT
1182	08-Apr-24	HASSAN	LINE	110	HIRIYA-MADHUVANA	HIRIYADKA_110	01:55	04:55	03:00	LINE CLEAR AVAILED
1183	08-Apr-24	HASSAN	LINE	110	JOG-NK2	JOG_110	23:32	23:46	00:14	TRIPPED ON FAULT
1184	08-Apr-24	HASSAN	LINE	110	MADHUV-HIRIYADKA	MADHUVANA_110	00:12	00:24	00:12	MAIN SUPPLY FAILURE
1185	08-Apr-24	HASSAN	LINE	110	NAVUNDA-MADHUVANA	NAVUNDA_110	00:35	05:05	04:30	TRIPPED ON FAULT
1186	08-Apr-24	HASSAN	TRANSFORMER	66	HV2	BELUR_66	06:55	07:03	00:08	TRIPPED ON FAULT
1187	08-Apr-24	HASSAN	TRANSFORMER	110	HV1	ANANDAPURA_110	19:00	19:05	00:05	TRIPPED ON FAULT
1188	08-Apr-24	HASSAN	TRANSFORMER	110	HV1	MADHUVANA_110	01:55	04:55	03:00	LINE CLEAR AVAILED
1189	08-Apr-24	HASSAN	TRANSFORMER	110	HV2	BIRUR_110	10:17	10:24	00:07	LINE CLEAR AVAILED
1190	08-Apr-24	HASSAN	TRANSFORMER	110	HV2	KUNDAPURA_110	00:12	00:24	00:12	MAIN SUPPLY FAILURE
1191	08-Apr-24	HASSAN	TRANSFORMER	110	HV2	KUNDAPURA_110	00:58	05:01	04:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1192	08-Apr-24	HASSAN	TRANSFORMER	110	HV2	NAVUNDA_110	00:26	00:35	00:09	TRIPPED ON FAULT
1193	8-Apr-24	MYSORE	LINE	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66	16:16	16:23	00:06	TRIPPED ON FAULT
1194	8-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53			LINE CLEAR AVAILED
1195	8-Apr-24	MYSORE	LINE	66	HUNSUR 220-HANAGODU	HANAGODU_66	09:10	09:28	00:18	LINE CLEAR AVAILED
1196	8-Apr-24	MYSORE	LINE	66	HUNSUR 220-HOSURGATE	NO STATIONS EFFECTED	09:10	09:28	00:18	LINE CLEAR AVAILED
1197	8-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66CHAN DRAVADI_66HURA_66	15:25	15:33	00:08	TRIPPED ON FAULT
1198	8-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66CHAN DRAVADI_66HURA_66	15:38	15:46	00:08	TRIPPED ON FAULT
1199	8-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1200	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1201	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66RUDRAP ATNA_66	00:30	04:35	04:05	TRIPPED ON FAULT
1202	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66RUDRAP ATNA_66	07:14	09:26	02:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1203	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66RUDRAPATNA_66	10:29	10:47	00:18	TRIPPED ON FAULT
1204	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66RUDRAPATNA_66	11:12	11:34	00:21	TRIPPED ON FAULT
1205	8-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPUR_66KANAGAL_66CBHALLI_66RUDRAPATNA_66	11:50	15:31	03:41	TRIPPED ON FAULT
1206	8-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	00:03	00:24	00:21	TRIPPED ON FAULT
1207	8-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	16:12	21:51	05:39	LINE CLEAR AVAILED
1208	8-Apr-24	MYSORE	LINE	220	CR NAGARA-MADHUVANAHALLI 1	MADHUVANAHALLI_220COWDALLI_66BANDALLI_66AJJIPURA_66RAMAPURA_MYS_66MARTAHALLI_66HEBBANI_220HANUR_66DODDINADUVA DI_66KOTTANUR_66PGPALYA_66LOKKANAHALLI_66YELANDUR_66MAMBALLI_66KIRUGAVALU_66MALIYURU_66VADKEPURA_66KOLLEGALA_66KUNTHUR_66	16:16	16:43	00:27	TRIPPED ON FAULT
1209	8-Apr-24	MYSORE	LINE	220	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	16:15	16:50	00:34	TRIPPED ON FAULT
1210	8-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:40 (7/04/2024)	7:30 (08/04/2024)	10:50	LINE CLEAR AVAILED
1211	8-Apr-24	MYSORE	TRANSFORMER	66	HV1	SHIVALLY_66	09:08	10:15	01:06	LINE CLEAR AVAILED
1212	8-Apr-24	MYSORE	TRANSFORMER	66	HV1	HURA_66	13:40	13:45	00:05	TRIPPED ON FAULT
1213	8-Apr-24	MYSORE	TRANSFORMER	66	HV1	MADHUVANAHALLI_220	11:20	14:11	02:51	LINE CLEAR AVAILED
1214	8-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGODU_66	09:50	09:53	00:03	TRIPPED ON FAULT
1215	8-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1216	08-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66,	18:24	19:01	00:36	TRIPPED ON FAULT
1217	08-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	09:26	11:43	02:16	LINE CLEAR AVAILED
1218	08-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	12:00	12:09	00:08	LINE CLEAR AVAILED
1219	08-Apr-24	TUMKUR	LINE	66	BEVINAHALLI-HIRIYUR2	BEVINAHALLI_66, CHANGAVARA_66	18:10	19:20	01:10	TRIPPED ON FAULT
1220	08-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220- GUTTUR 220	GUTTUR 220	18:12	19:18	01:06	LINE CLEAR AVAILED
1221	08-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	11:48	12:06	00:18	TRIPPED ON FAULT
1222	08-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	12:22	13:22	01:00	TRIPPED ON FAULT
1223	08-Apr-24	TUMKUR	LINE	66	HARIYABBE-HIRIYUR	HARIYABBE_66	08:14	18:08	09:53	LINE CLEAR AVAILED
1224	08-Apr-24	TUMKUR	LINE	66	HEBBUR-THIMMADANDRA	HONNENAHALLI_66, THIMMASANDRA_66	03:20	03:45	00:25	MAIN SUPPLY FAILURE
1225	08-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NALLUR_66	NALLUR_66, BASAVAPATNA_66, TYAVANAGI_66	12:17	12:47	00:30	TRIPPED ON FAULT
1226	08-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	12:38	13:16	00:38	TRIPPED ON FAULT
1227	08-Apr-24	TUMKUR	LINE	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	08:35	17:28	08:53	LINE CLEAR AVAILED
1228	08-Apr-24	TUMKUR	LINE	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	08:35	17:28	08:53	LINE CLEAR AVAILED
1229	08-Apr-24	TUMKUR	LINE	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	17:01	17:26	00:25	LINE CLEAR AVAILED
1230	08-Apr-24	TUMKUR	LINE	66	PDKOTE-HARIYABBE	PDKOTE_66	08:05	08:10	00:05	MAIN SUPPLY FAILURE
1231	08-Apr-24	TUMKUR	LINE	66	PDKOTE-HARIYABBE	PDKOTE_66	17:57	18:10	00:13	MAIN SUPPLY FAILURE
1232	08-Apr-24	TUMKUR	LINE	66	THIPPUR-ANCHEPALYA220	THIPPUR_66	18:25	19:05	00:40	MAIN SUPPLY FAILURE
1233	08-Apr-24	TUMKUR	LINE	220	GUTTUR220-DITTUR LINE	KNNL DITTUR_66 , HALASABALU_66	23:07	23:21	00:14	TRIPPED ON FAULT
1234	08-Apr-24	TUMKUR	LINE	220	GUTTUR220-HALASABALU	GUTTUR_66, HARIHARA HOSPET_66	20:11	20:21	00:10	TRIPPED ON FAULT
1235	08-Apr-24	TUMKUR	LINE	220	KDBVNP- MADHUGIRI220	MADHUGIRI_220	01:14	01:50	00:36	TRIPPED ON FAULT
1236	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHENNAGIRI_66	22:06	22:08	00:02	TRIPPED ON FAULT
1237	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRAHALLI_66	16:35	16:40	00:05	TRIPPED ON FAULT
1238	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	KUNDUR_66	12:19	13:36	01:17	LINE CLEAR AVAILED
1239	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	PDKOTE_66	12:15	12:20	00:05	TRIPPED ON FAULT
1240	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	TYAVANAGI_66	06:20	06:56	00:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1241	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	GARAGA_66	09:40	15:46	06:05	LINE CLEAR AVAILED
1242	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KOLALA_66	13:12	15:17	02:05	LINE CLEAR AVAILED
1243	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KOLALA_66	16:27	18:07	01:40	LINE CLEAR AVAILED
1244	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	SHYLAPURA_66	07:28	07:41	00:12	TRIPPED ON FAULT
1245	08-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	THOVINAKERE_110	08:03	08:17	00:13	LINE CLEAR AVAILED
1246	09-Apr-24	BAGALKOTE	LINE	110	AMBEWADI220-NK-2 (KAWALWADA)	AMBEWADI_220	05:15	05:26	00:11	TRIPPED ON FAULT
1247	09-Apr-24	BAGALKOTE	LINE	110	ATHANI220- GHATANATTI	ATHANI_220	18:10	18:20	00:10	TRIPPED ON FAULT
1248	09-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1249	09-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
1250	09-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1251	09-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1252	09-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
1253	09-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1254	09-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1255	09-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1256	09-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220- BYADAGI	RANEBENNUR_220	13:55	14:19	00:24	TRIPPED ON FAULT
1257	09-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- KATARAKI	VAJRAMATTI_220	20:18 (08.04.2024)	0:22 (09.04.2024)	04:05	TRIPPED ON FAULT
1258	09-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1259	09-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	09:34	12:48	03:14	LINE CLEAR AVAILED
1260	09-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	17:46	19:53	02:07	TRIPPED ON FAULT
1261	09-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1262	09-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	GANESHGUDI_110	09:35	10:03	00:28	TRIPPED ON FAULT
1263	09-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	BAGALKOT_220	20:21	20:40	00:19	TRIPPED ON FAULT
1264	09-Apr-24	BENGALURU	LINE	66	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	11:12	11:30	00:18	TRIPPED ON FAULT
1265	09-Apr-24	BENGALURU	LINE	66	66KV AERO SPACE 220 - BOEING (EHT)	BOEING(EHT)	21:04	21:23	00:19	LINE CLEAR AVAILED
1266	09-Apr-24	BENGALURU	LINE	66	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	ATTUR YELAHANKA	11:37	13:12	01:35	TRIPPED ON FAULT
1267	09-Apr-24	BENGALURU	LINE	66	66KV BAIL BEGUR 220 - 66 KV ITC AIRPORT ROAD (EHT)	ITC(EHT)	21:04	21:36	00:32	LINE CLEAR AVAILED
1268	09-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - BIAL 1 (EHT)	BIAL(EHT)	21:04	23:22	02:18	LINE CLEAR AVAILED
1269	09-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - BIAL 2 (EHT)	BIAL(EHT)	21:04	23:22	02:18	LINE CLEAR AVAILED
1270	09-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	21:04	21:39	00:35	LINE CLEAR AVAILED
1271	09-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	06:04	06:12	00:08	TRIPPED ON FAULT
1272	09-Apr-24	BENGALURU	LINE	66	66KV DG4_ VIDYANAGAR - HENNUR	VIDYANAGARA	21:04	21:38	00:34	LINE CLEAR AVAILED
1273	09-Apr-24	BENGALURU	LINE	66	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL(EHT)	17:39	18:21	00:42	TRIPPED ON FAULT
1274	09-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	21:04	21:57	00:53	LINE CLEAR AVAILED
1275	09-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - ADUGODI	ADUGODI	10:04	10:17	00:13	TRIPPED ON FAULT
1276	09-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLY - M GOLLAHALLY	IRAGAMAPALLI, M GOLLAHALLI	18:00	18:05	00:05	LINE CLEAR AVAILED
1277	09-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NO STATION AFFECTED	06:02	06:32	00:30	TRIPPED ON FAULT
1278	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVNAGALA, SASALU, GUNDAMGERE	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1279	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1280	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1281	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - DEVANAHALLI 2	KUNDANA	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1282	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAGALLI, BRIGADE ORCHARD	21:04	21:29	00:25	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1283	09-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1284	09-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA	11:44	11:56	00:12	TRIPPED ON FAULT
1285	09-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1286	09-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1287	09-Apr-24	BENGALURU	LINE	220	220KV HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	00:32	02:30	01:58	TRIPPED ON FAULT
1288	09-Apr-24	BENGALURU	LINE	220	220KV HOODY 220 - BIAL BEGUR 220	BIAL BEGUR 220	21:08	23:59	02:51	LINE CLEAR AVAILED
1289	09-Apr-24	BENGALURU	LINE	220	220KV KIADB DEVANAHALLI HP 220 - AERO SPACE 220	AERO SPACE PARK 220	21:04	21:23	00:19	LINE CLEAR AVAILED
1290	09-Apr-24	BENGALURU	LINE	220	220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 1	BIAL BEGUR 220	21:04	21:20	00:16	LINE CLEAR AVAILED
1291	09-Apr-24	BENGALURU	LINE	220	220KV NRS DB PURA 220 - KIADB DB PURA 220	NRS DB PURA 220	21:04	21:29	00:25	LINE CLEAR AVAILED
1292	09-Apr-24	BENGALURU	LINE	400	NELAMANGALA 400 - MYSORE 2	NO STATION AFFECTED	18:02	21:41	03:39	TRIPPED ON FAULT
1293	09-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BIAL BEGUR 220	21:04	21:25	00:21	LINE CLEAR AVAILED
1294	09-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SUGUTUR	17:25	17:55	00:30	TRIPPED ON FAULT
1295	09-Apr-24	BENGALURU	TRANSFORMER	66	HV1	LAKKUR	16:00	16:10	00:10	TRIPPED ON FAULT
1296	09-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HAL 220	23:15	23:30	00:15	TRIPPED ON FAULT
1297	09-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BIAL BEGUR 220	21:04	21:33	00:29	LINE CLEAR AVAILED
1298	09-Apr-24	BENGALURU	TRANSFORMER	220	HV1	BIAL BEGUR 220	21:04	21:30	00:26	LINE CLEAR AVAILED
1299	09-Apr-24	BENGALURU	TRANSFORMER	220	HV1	NRS DB PURA 220	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1300	09-Apr-24	BENGALURU	TRANSFORMER	220	HV2	BIAL BEGUR 220	21:04	21:24	00:20	LINE CLEAR AVAILED
1301	09-Apr-24	BENGALURU	TRANSFORMER	220	HV3	BIAL BEGUR 220	21:04	23:22	02:18	LINE CLEAR AVAILED
1302	09-Apr-24	BENGALURU	TRANSFORMER	220	HV3	NRS DB PURA 220	21:04	21:29	00:25	MAIN SUPPLY FAILURE
1303	9-Apr-2024	GULBARGA	LINE	66	KUDALGI-KOTTUR	UJJINI_66, KOTTUR_66, SOKKE_66, PALLANGATTA_66, BELICHOD_66	09:00	09:15	00:15	TRIPPED ON FAULT
1304	9-Apr-2024	GULBARGA	LINE	66	KUDALGI-KOTTUR	UJJINI_66, KOTTUR_66, SOKKE_66, PALLANGATTA_66, BELICHOD_66	18:55	19:05	00:10	TRIPPED ON FAULT
1305	9-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	04:45	04:53	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1306	9-Apr-2024	GULBARGA	LINE	110	ALIPUR-MUNIRABAD	KIADB KUDITINI_110,KUDITINI_110,METRI_110,KURUGOD_110	04:14	04:23	00:09	TRIPPED ON FAULT
1307	9-Apr-2024	GULBARGA	LINE	110	KHANAPUR-YADGIR	KHANAPUR_110	02:48	02:53	00:05	TRIPPED ON FAULT
1308	9-Apr-2024	GULBARGA	LINE	110	RAICHUR-GABUR	GABUR_110	01:47	01:55	00:08	TRIPPED ON FAULT
1309	9-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	23:11	23:22	00:11	TRIPPED ON FAULT
1310	9-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	RAICHUR_220	19:25	19:49	00:24	LINE CLEAR AVAILED
1311	9-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	CHICKSUGUR_110	17:42	17:50	00:08	TRIPPED ON FAULT
1312	9-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GABUR_110	13:05	13:15	00:10	TRIPPED ON FAULT
1313	9-Apr-2024	GULBARGA	TRANSFORMER	110	HV1,HV2 ,HV7	MUNIRABAD_220	03:38	03:50	00:12	TRIPPED ON FAULT
1314	09-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	gen_bhadra	08:02	08:17	00:15	TRIPPED ON FAULT
1315	09-Apr-24	HASSAN	LINE	66	HNPURA-MYSOR2	HNPURA_66	05:37	05:44	00:07	TRIPPED ON FAULT
1316	09-Apr-24	HASSAN	LINE	110	MRSSHM-BADRAVATY1	MRSMSG_220	12:13	13:26	01:13	TRIPPED ON FAULT
1317	09-Apr-24	HASSAN	LINE	110	MRSSHM-BADRAVATY2	MRSMSG_220	12:13	13:31	01:18	TRIPPED ON FAULT
1318	09-Apr-24	HASSAN	TRANSFORMER	66	HV1	CHIKKAKONDAGOLA_66	12:44	17:18	04:34	TRIPPED ON FAULT
1319	09-Apr-24	HASSAN	TRANSFORMER	66	HV1	CHIKKAKONDAGOLA_66	17:33	19:18	01:45	TRIPPED ON FAULT
1320	09-Apr-24	HASSAN	TRANSFORMER	110	HV2	BARANGI_110	08:10	08:35	00:25	LINE CLEAR AVAILED
1321	09-Apr-24	HASSAN	TRANSFORMER	110	HV2	NERALEKERE_110	11:48	11:52	00:04	TRIPPED ON FAULT
1322	9-Apr-24	MYSORE	LINE	66	220KV THAMMADIHALLI 66KV LINE-GAVADAGERE	NO STATIONS EFFECTED	05:05	05:14	00:09	TRIPPED ON FAULT
1323	9-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
1324	9-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1325	9-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1326	9-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	17:08	22:00	04:51	LINE CLEAR AVAILED
1327	9-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:38			MAIN SUPPLY FAILURE
1328	9-Apr-24	MYSORE	TRANSFORMER	66	HV1	HURA_66	12:40	12:50	00:10	TRIPPED ON FAULT
1329	9-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHANDRAVADI_66	16:05	16:10	00:05	TRIPPED ON FAULT
1330	9-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1331	9-Apr-24	MYSORE	TRANSFORMER	66	HV2	BETTADHAPURA_66	18:00	18:33	00:32	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1332	9-Apr-24	MYSORE	TRANSFORMER	66	HV2	HAMPAPURA_66	20:10	20:20	00:09	TRIPPED ON FAULT
1333	9-Apr-24	MYSORE	TRANSFORMER	66	HV2	HAMPAPURA_66	20:32	20:49	00:16	TRIPPED ON FAULT
1334	9-Apr-24	MYSORE	TRANSFORMER	66	HV2	HARVEY_66	09:55	10:09	00:14	TRIPPED ON FAULT
1335	09-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	05:46	05:58	00:11	TRIPPED ON FAULT
1336	09-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	16:55	17:00	00:05	TRIPPED ON FAULT
1337	09-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	PALLAGATTE_66,BILCH ODU_66, SOKKE_66	09:05	09:15	00:10	TRIPPED ON FAULT
1338	09-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	PALLAGATTE_66,BILCH ODU_66, SOKKE_66	08:55	09:05	00:10	TRIPPED ON FAULT
1339	09-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- KARAD IPP	KARAD IPP	15:26	15:33	00:07	TRIPPED ON FAULT
1340	09-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- SUZLON 1	SUZLON1_IPP_66	13:14	14:43	01:29	TRIPPED ON FAULT
1341	09-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- SUZLON 2	SUZLON2_IPP_66	13:14	14:43	01:29	TRIPPED ON FAULT
1342	09-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	09:45	10:00	00:15	TRIPPED ON FAULT
1343	09-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	13:20	13:30	00:10	TRIPPED ON FAULT
1344	09-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	18:45	19:20	00:35	TRIPPED ON FAULT
1345	09-Apr-24	TUMKUR	LINE	66	GUTTUR220-HALASABALU	GUTTUR_66, HARIHARA HOSPET_66, POLY FIBER	03:15	03:26	00:11	TRIPPED ON FAULT
1346	09-Apr-24	TUMKUR	LINE	66	GUTTUR220-HALASABALU	GUTTUR_66, HARIHARA HOSPET_66, POLY FIBER	09:29	09:39	00:10	TRIPPED ON FAULT
1347	09-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	16:14	16:25	00:10	TRIPPED ON FAULT
1348	09-Apr-24	TUMKUR	LINE	66	HOSADURGA_220KV- HOSADURGA_66KV	HOSADURGA_66KV, NEERAGUNDA_66	02:15	02:30	00:15	TRIPPED ON FAULT
1349	09-Apr-24	TUMKUR	LINE	66	LOKIKERE-KEREBILCHI_66	KEREBILCHI_66, SANTHEBENNURU_66	18:45	18:51	00:05	TRIPPED ON FAULT
1350	09-Apr-24	TUMKUR	LINE	66	MADHURE_220- HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	05:35	05:45	00:10	TRIPPED ON FAULT
1351	09-Apr-24	TUMKUR	LINE	66	SHYAGALE- KEREBILCHI	WATER WORKS	18:45	18:52	00:07	TRIPPED ON FAULT
1352	09-Apr-24	TUMKUR	LINE	66	TMTP66-BRAHMASANDRA	BRAHMASANDRA_66, ANANKSANDRA_66, SUNVIK_66	07:04	07:24	00:20	TRIPPED ON FAULT
1353	09-Apr-24	TUMKUR	LINE	66	TMTP66-KORA	KORA_66	07:02	07:23	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1354	09-Apr-24	TUMKUR	LINE	400	GUTTUR 400-DONI_400(GUBBAHALI)	GUDDABAHALLI_400	14:42	19:49	05:07	TRIPPED ON FAULT
1355	09-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- BTPS	GUTTUR_400	18:05:00		-	MAIN SUPPLY FAILURE
1356	09-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	TAVAREKERE_66	09:07	09:14	00:07	TRIPPED ON FAULT
1357	09-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	SHYLAPURA_66	14:45	14:54	00:09	TRIPPED ON FAULT
1358	10-Apr-24	BAGALKOTE	LINE	110	AEQUS220- SANKESHWAR	STATION NOT AFFECTED AEQUS_220	17:33	17:47	00:14	TRIPPED ON FAULT
1359	10-Apr-24	BAGALKOTE	LINE	110	ATHANI220- AIGALI	ATHANI_220	09:08	19:52	10:44	LINE CLEAR AVAILED
1360	10-Apr-24	BAGALKOTE	LINE	110	ATHANI220- BALIGERI	ATHANI_220	17:05	20:12	03:07	LINE CLEAR AVAILED
1361	10-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1362	10-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
1363	10-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1364	10-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- BHOJ	CHIKKODI_220	08:48	10:38	01:50	LINE CLEAR AVAILED
1365	10-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- RAIBAG1	CHIKKODI_220	09:17	12:00	02:43	LINE CLEAR AVAILED
1366	10-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1367	10-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
1368	10-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1369	10-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1370	10-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1371	10-Apr-24	BAGALKOTE	LINE	110	SOUDATTI220- RAMADURGA-1	SOUDATTI_220	21:05	21:51	00:46	TRIPPED ON FAULT
1372	10-Apr-24	BAGALKOTE	LINE	110	SOUDATTI220- RAMADURGA-2	SOUDATTI_220	21:05	21:37	00:32	TRIPPED ON FAULT
1373	10-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1374	10-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220-KATARKI	VAJRAMATTI_220	12:20	16:41	04:21	LINE CLEAR AVAILED
1375	10-Apr-24	BAGALKOTE	LINE	220	AEQUS-KANAGALA1	KANAGALA_220	17:23	17:58	00:35	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1376	10-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	11:08	12:08	01:00	LINE CLEAR AVAILED
1377	10-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1378	10-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	MUGALKHOD_220	09:29	11:33	02:04	LINE CLEAR AVAILED
1379	10-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	CHIKKODI_220	10:40	12:10	01:30	LINE CLEAR AVAILED
1380	10-Apr-24	BENGALURU	LINE	66	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE	07:32	07:36	00:04	LINE CLEAR AVAILED
1381	10-Apr-24	BENGALURU	LINE	66	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	ATTUR YELAHANKA	12:29	12:39	00:10	TRIPPED ON FAULT
1382	10-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1383	10-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	06:40	08:23	01:43	TRIPPED ON FAULT
1384	10-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NO STATION AFFECTED	05:50	07:00	01:10	TRIPPED ON FAULT
1385	10-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	05:51	06:59	01:08	TRIPPED ON FAULT
1386	10-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	18:30	18:35	00:05	LINE CLEAR AVAILED
1387	10-Apr-24	BENGALURU	LINE	66	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	08:45	08:55	00:10	LINE CLEAR AVAILED
1388	10-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	17:43	17:59	00:16	TRIPPED ON FAULT
1389	10-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 1	SARAKKI	10:09	10:15	00:06	LINE CLEAR AVAILED
1390	10-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 2	SARAKKI	10:09	10:15	00:06	LINE CLEAR AVAILED
1391	10-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	07:43	07:48	00:05	LINE CLEAR AVAILED
1392	10-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	18:30	18:35	00:05	LINE CLEAR AVAILED
1393	10-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	04:58	05:00	00:02	LINE CLEAR AVAILED
1394	10-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	12:35	12:37	00:02	LINE CLEAR AVAILED
1395	10-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1396	10-Apr-24	BENGALURU	LINE	220	220KV MYLASANDRA 400 - HSR LAYOUT 2	NO STATION AFFECTED	03:12	12:32	09:20	TRIPPED ON FAULT
1397	10-Apr-24	BENGALURU	LINE	220	220KV NAGANATHAPURA 220 - HSR LAYOUT 220	NO STATION AFFECTED	03:22	12:48	09:26	TRIPPED ON FAULT
1398	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ATTUR YELAHANKA	05:45	05:58	00:13	LINE CLEAR AVAILED
1399	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HAL 220	09:15	09:30	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1400	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	RMZ	11:00	11:04	00:04	TRIPPED ON FAULT
1401	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	RMZ	11:04	11:06	00:02	LINE CLEAR AVAILED
1402	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARAKKI	18:50	19:00	00:10	TRIPPED ON FAULT
1403	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	RR NAGAR	16:40	16:45	00:05	LINE CLEAR AVAILED
1404	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VOLVO	15:32	15:45	00:13	TRIPPED ON FAULT
1405	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	JANGAMKOTE	08:11	08:23	00:12	TRIPPED ON FAULT
1406	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUDIBANDE	07:35	08:05	00:30	LINE CLEAR AVAILED
1407	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SOMAYAJANAHALLI	00:04	00:21	00:17	TRIPPED ON FAULT
1408	10-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HUKUNDA	09:50	09:55	00:05	TRIPPED ON FAULT
1409	10-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ATTUR YELAHANKA	05:45	05:58	00:13	LINE CLEAR AVAILED
1410	10-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ATTUR YELAHANKA	05:58	06:31	00:33	LINE CLEAR AVAILED
1411	10-Apr-24	BENGALURU	TRANSFORMER	66	HV2	RR NAGAR	12:35	12:40	00:05	LINE CLEAR AVAILED
1412	10-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DALASANUR	13:05	13:15	00:10	TRIPPED ON FAULT
1413	10-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SUGUTUR	05:15	06:00	00:45	TRIPPED ON FAULT
1414	10-Apr-24	BENGALURU	TRANSFORMER	66	HV3	HEBBALA 220	05:28	07:23	01:55	TRIPPED ON FAULT
1415	10-Apr-2024	GULBARGA	LINE	110	GANGAVATI-VENKATAGIRI	VENKATAGIRI_110	15:35	15:45	00:10	MAIN SUPPLY FAILURE
1416	10-Apr-2024	GULBARGA	LINE	110	GANGAVATI-VENKATAGIRI	VENKATAGIRI_110	16:13	16:16	00:03	MAIN SUPPLY FAILURE
1417	10-Apr-2024	GULBARGA	LINE	110	KURUGOD-SUZLON	KURUGOD_110	11:15	17:30	06:15	LINE CLEAR AVAILED
1418	10-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HUDEM_66	12:25	13:50	01:25	LINE CLEAR AVAILED
1419	10-Apr-24	HASSAN	LINE	66	HIEMAN-CHIKAMANGALUR	HIEMAGALUR_66	12:46	13:08	00:22	TRIPPED ON FAULT
1420	10-Apr-24	HASSAN	LINE	66	SAKALE-HANBAL	SAKALESHPUA_66	06:58	07:12	00:14	TRIPPED ON FAULT
1421	10-Apr-24	HASSAN	LINE	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	07:22	07:42	00:20	TRIPPED ON FAULT
1422	10-Apr-24	HASSAN	LINE	110	ALKOLA-SAGAR	ALKOLA_110	17:50	19:15	01:25	TRIPPED ON FAULT
1423	10-Apr-24	HASSAN	LINE	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	15:54	16:37	00:43	TRIPPED ON FAULT
1424	10-Apr-24	HASSAN	LINE	220	MRSSHM-ANTRSNH	MRSMSG_220	16:40	19:35	02:55	LINE CLEAR AVAILED
1425	10-Apr-24	HASSAN	TRANSFORMER	66	HV1	AREHALLI_66	07:00	08:10	01:10	MAIN SUPPLY FAILURE
1426	10-Apr-24	HASSAN	TRANSFORMER	66	HV1	AREHALLI_66	08:25	08:52	00:27	LINE CLEAR AVAILED
1427	10-Apr-24	HASSAN	TRANSFORMER	66	HV1	HAGARE_66	06:35	06:45	00:10	MAIN SUPPLY FAILURE
1428	10-Apr-24	HASSAN	TRANSFORMER	66	HV1	HIEMAGALUR_66	12:47	13:11	00:24	MAIN SUPPLY FAILURE
1429	10-Apr-24	HASSAN	TRANSFORMER	66	HV1	MALLAPURA_66	20:54	21:05	00:11	TRIPPED ON FAULT
1430	10-Apr-24	HASSAN	TRANSFORMER	110	HV1	ANANDAPURA_110	15:40	15:50	00:10	TRIPPED ON FAULT
1431	10-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
1432	10-Apr-24	MYSORE	LINE	66	HEBBANI 220KV-VADAKERUPA	VADKEPURA_66 KIRUGAVALU_66 MALIYURU_66	06:31	06:41	00:10	TRIPPED ON FAULT
1433	10-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1434	10-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1435	10-Apr-24	MYSORE	LINE	66	MADIKERI-VIRAJPET	VIRAJPET_66 33KV MURNAD_33 SIDDAPURA_33	07:40	08:00	00:20	TRIPPED ON FAULT
1436	10-Apr-24	MYSORE	LINE	66	MYSORE-BOGADHI	NO STATIONS EFFECTED	17:04	22:06	05:02	MAIN SUPPLY FAILURE
1437	10-Apr-24	MYSORE	LINE	66	PONNAMPETE-VIRAJPET	VIRAJPET_66 33KV MURNAD_33 SIDDAPURA_33	07:40	07:51	00:10	TRIPPED ON FAULT
1438	10-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:43			MAIN SUPPLY FAILURE
1439	10-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:38 (09/04/2024)	6:44 (10/04/2024)	10:05 HRs	MAIN SUPPLY FAILURE
1440	10-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1441	10-Apr-24	MYSORE	TRANSFORMER	66	HV2	PERIYAPATNA_66	13:43	14:16	00:33	LINE CLEAR AVAILED
1442	10-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	16:40	16:51	00:11	LINE CLEAR AVAILED
1443	10-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- BTPS	GUTTUR_400	6:05:00 PM(09.04.2024)	14:49(10.04.2024)	20:27	LINE CLEAR AVAILED
1444	10-Apr-24	TUMKUR	LINE	220	ANTHRASANAHALLI 220kV-SHIMOGA	ANTHRASANAHALLI_220	16:41	19:17	02:36	LINE CLEAR AVAILED
1445	11-Apr-24	BAGALKOTE	LINE	110	AEQUS220- SANKESHWAR	STATION NOT AFFECTED AEQUS_220	17:33	17:47	00:14	TRIPPED ON FAULT
1446	11-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1447	11-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
1448	11-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1449	11-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- HUKKERI	CHIKKODI_220	10:20	11:40	01:20	LINE CLEAR AVAILED
1450	11-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABAH_220	12:45	12:55	00:10	TRIPPED ON FAULT
1451	11-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1452	11-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1453	11-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1454	11-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1455	11-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- KULIGOD	MUGALKHOD_220	01:59	02:12	00:13	TRIPPED ON FAULT
1456	11-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1457	11-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1458	11-Apr-24	BAGALKOTE	LINE	220	AEQUS-KANAGALA LINE 1	AEQUS_220	08:14	12:30	04:16	TRIPPED ON FAULT
1459	11-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI-1	BAGALKOT_220	17:03			TRIPPED ON FAULT
1460	11-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI-2	BAGALKOT_220	17:51	18:15	00:24	TRIPPED ON FAULT
1461	11-Apr-24	BAGALKOTE	LINE	220	CHIKKODI- KANAGALA1	CHIKKODI_220	08:15	08:27	00:12	TRIPPED ON FAULT
1462	11-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1463	11-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1464	11-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - AVERAHALLI	T BEGUR, AVERAHALLI	06:02	06:22	00:20	TRIPPED ON FAULT
1465	11-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	06:33	06:44	00:11	TRIPPED ON FAULT
1466	11-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	03:20	03:37	00:17	TRIPPED ON FAULT
1467	11-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NARASAPURA	08:45	11:15	02:30	LINE CLEAR AVAILED
1468	11-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NO STATION AFFECTED	06:10	08:45	02:35	TRIPPED ON FAULT
1469	11-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NARASAPURA	08:45	11:15	02:30	LINE CLEAR AVAILED
1470	11-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA	17:10	17:24	00:14	TRIPPED ON FAULT
1471	11-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	18:36	18:51	00:15	TRIPPED ON FAULT
1472	11-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	05:45	06:20	00:35	TRIPPED ON FAULT
1473	11-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1474	11-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUDIBANDE	17:15	17:45	00:30	LINE CLEAR AVAILED
1475	11-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DALASANUR	16:10	16:30	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1476	11-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	06:10	07:45	01:35	TRIPPED ON FAULT
1477	11-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SANKALGERE	08:25	08:30	00:05	TRIPPED ON FAULT
1478	11-Apr-24	BENGALURU	TRANSFORMER	66	HV1	CHANDAPURA	11:53	12:05	00:12	LINE CLEAR AVAILED
1479	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GANJIGUNTE	07:10	07:15	00:05	LINE CLEAR AVAILED
1480	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SUGUTUR	06:10	06:30	00:20	TRIPPED ON FAULT
1481	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MALUR I/A	20:25	20:30	00:05	TRIPPED ON FAULT
1482	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HUKUNDA	14:30	14:35	00:05	TRIPPED ON FAULT
1483	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KUDUR	14:50	14:58	00:08	TRIPPED ON FAULT
1484	11-Apr-24	BENGALURU	TRANSFORMER	66	HV2	CHANDAPURA	12:13	12:30	00:17	LINE CLEAR AVAILED
1485	11-Apr-2024	GULBARGA	LINE	110	BYGWAT-WALKAMDINI	BYAGWAT_110	21:04	24:00:00	02:56	TRIPPED ON FAULT
1486	11-Apr-2024	GULBARGA	LINE	110	CHITAPUR-SHAHBAD	CHITAPUR_110	18:45	19:28	00:43	TRIPPED ON FAULT
1487	11-Apr-2024	GULBARGA	LINE	110	ITTAGI-HUVINHADAGALI	HUVINAHADAGALI_66, HOLAGUNDI_66	20:03	20:19	00:16	TRIPPED ON FAULT
1488	11-Apr-2024	GULBARGA	LINE	110	KEMBHAVI-HUNASAGI	HUNASAGI_110	01:45	01:50	00:05	TRIPPED ON FAULT
1489	11-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-LATUR GAMESH	LINGASUGUR_220	11:08	18:24	07:16	LINE CLEAR AVAILED
1490	11-Apr-2024	GULBARGA	LINE	110	LINGASUGUT-GURGUNTA	GURGUNTA_110	19:42	20:03	00:21	TRIPPED ON FAULT
1491	11-Apr-2024	GULBARGA	LINE	110	MANDEWAL-SHAHBAD	MANDEWAL_110	18:20	19:53	01:33	TRIPPED ON FAULT
1492	11-Apr-2024	GULBARGA	LINE	110	MANDEWAL-SHAHBAD	MANDEWAL_110	20:35	22:30	01:55	LINE CLEAR AVAILED
1493	11-Apr-2024	GULBARGA	LINE	110	NAGNOOR-KEMBHAVI	NANDOOR_110	21:58	22:09	00:11	TRIPPED ON FAULT
1494	11-Apr-2024	GULBARGA	LINE	110	NANDOOR-SHAHBAD	NANDOOR_110	06:30	20:30	14:00	TRIPPED ON FAULT
1495	11-Apr-2024	GULBARGA	LINE	110	NANDOOR-SHAHBAD	NANDOOR_110	20:00	00:00	04:00	LINE CLEAR AVAILED
1496	11-Apr-2024	GULBARGA	LINE	110	NANDOOR-SHAHBAD	NANDOOR_110	18:28	20:42	02:14	TRIPPED ON FAULT
1497	11-Apr-2024	GULBARGA	LINE	110	RAMASAMUDRA-KONKAL	KONKAL_110	03:54	04:03	00:09	TRIPPED ON FAULT
1498	11-Apr-2024	GULBARGA	LINE	110	RAMASAMUDRA-KONKAL	KONKAL_110	05:52	05:57	00:05	TRIPPED ON FAULT
1499	11-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	18:55	19:33	00:38	TRIPPED ON FAULT
1500	11-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-SHAHAPUR	SHAHAPUR_220	19:23	20:00	00:37	TRIPPED ON FAULT
1501	11-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	19:23	23:59	04:36	TRIPPED ON FAULT
1502	11-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	WALKAMDINI_110	21:00	21:05	00:05	TRIPPED ON FAULT
1503	11-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	WALKAMDINI_110	21:30	21:35	00:05	TRIPPED ON FAULT
1504	11-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KURUGOD_110	15:20	15:25	00:05	TRIPPED ON FAULT
1505	11-Apr-2024	GULBARGA	TRANSFORMER	110	HV7	MUNIRABAD_220	22:19	22:29	00:10	TRIPPED ON FAULT
1506	11-Apr-2024	GULBARGA	TRANSFORMER	110	LV3	KUSHTAGI_220	11:45	13:10	01:25	LINE CLEAR AVAILED
1507	11-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA1	CHANNARAYAPATNA_6 6	21:20(11.04.20 24)			TRIPPED ON FAULT
1508	11-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA2	CHANNARAYAPATNA_6 6	21:20(11.04.20 24)			TRIPPED ON FAULT
1509	11-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA1	CHANNARAYAPATNA_2 20	23:46(11.04.20 24)			LINE CLEAR AVAILED
1510	11-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA1	CHANNARAYAPATNA_2 20	21:13	22:33	01:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1511	11-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA2	CHANNARAYAPATNA_220	23:46(11.04.2024)			TRIPPED ON FAULT
1512	11-Apr-24	HASSAN	LINE	66	CHANNAR-SHETTIHALLI	CHANNARAYAPATNA_66	21:20	23:55	02:35	TRIPPED ON FAULT
1513	11-Apr-24	HASSAN	LINE	66	CHANNAR-UDAYAPURA1	CHANNARAYAPATNA_66	21:20(11.04.2024)			TRIPPED ON FAULT
1514	11-Apr-24	HASSAN	LINE	66	CHANNAR-UDAYAPURA2	CHANNARAYAPATNA_66	21:20(11.04.2024)			TRIPPED ON FAULT
1515	11-Apr-24	HASSAN	LINE	66	MALALI-CRPATNA	MALALI_66	17:05	18:46	01:41	TRIPPED ON FAULT
1516	11-Apr-24	HASSAN	LINE	66	MRSSHM-HOLUR	MRSMSG_220	11:33	11:40	00:07	TRIPPED ON FAULT
1517	11-Apr-24	HASSAN	LINE	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	17:05	18:51	01:46	MAIN SUPPLY FAILURE
1518	11-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	11:33	11:40	00:07	LINE CLEAR AVAILED
1519	11-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	11:50	12:00	00:10	MAIN SUPPLY FAILURE
1520	11-Apr-24	HASSAN	LINE	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	14:38	14:45	00:07	LINE CLEAR AVAILED
1521	11-Apr-24	HASSAN	LINE	110	ALKOLA-SAGAR	ALKOLA_110	17:51	19:15	01:24	TRIPPED ON FAULT
1522	11-Apr-24	HASSAN	TRANSFORMER	66	HV2	SHANTHIGRAMA_66	17:05(11.04.2024)			TRIPPED ON FAULT
1523	11-Apr-24	HASSAN	TRANSFORMER	66	HV2	HOLEHONNUR_66	14:25	15:00	00:35	LINE CLEAR AVAILED
1524	11-Apr-24	MYSORE	LINE	66	BEGUR 220-SARAGUR	ANTHARSANTHE_66 CHANDRAVADI_66 HDKOTE_66 HURA_66 SANTHESARAGUR_66 YERALLI HAND POST_66	15:30	15:35	00:05	TRIPPED ON FAULT
1525	11-Apr-24	MYSORE	LINE	66	GUNDLUPETE-KABBALLI	NO STATIONS EFFECTED	06:18	06:25	00:07	TRIPPED ON FAULT
1526	11-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
1527	11-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA(K)	HAMPAPURA(K)_66	15:30	15:42	00:11	TRIPPED ON FAULT
1528	11-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1529	11-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1530	11-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:52	19:02	00:09	TRIPPED ON FAULT
1531	11-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	17:04	22:01	04:57	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1532	11-Apr-24	MYSORE	LINE	220	KADAKOLA-BASTIPURA 2	NO STATIONS EFFECTED	11:17	11:47	00:30	TRIPPED ON FAULT
1533	11-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36 (11/04/2024)			LINE CLEAR AVAILED
1534	11-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:43 (10/04/2024)	6:27 (11/04/2024)	9:44 HRs	LINE CLEAR AVAILED
1535	11-Apr-24	MYSORE	LINE	220	MADHUVANAHALLI-WARDSLR	NO STATIONS EFFECTED	15:30	16:21	00:50	TRIPPED ON FAULT
1536	11-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGODU_66	13:19	13:25	00:06	TRIPPED ON FAULT
1537	11-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1538	11-Apr-24	MYSORE	TRANSFORMER	66	HV2	KIRUGAVALU_66	10:35	13:23	02:47	LINE CLEAR AVAILED
1539	11-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	06:10	06:31	00:21	TRIPPED ON FAULT
1540	11-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- HIRIYUR	SANEKERE_66, CHALKERE_66, IMANGALA_66	13:58	14:10	00:12	TRIPPED ON FAULT
1541	11-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS - HARIHARA	HARIHARA_66	12:10	12:20	00:10	TRIPPED ON FAULT
1542	11-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	03:17	03:31	00:14	TRIPPED ON FAULT
1543	11-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	15:45	15:50	00:05	TRIPPED ON FAULT
1544	11-Apr-24	TUMKUR	LINE	66	KUKKAWADA- BASAVAPATNA 66	BASAVAPATNA_66,TYA VANAGI_66	21:27	21:32	00:05	TRIPPED ON FAULT
1545	11-Apr-24	TUMKUR	LINE	66	KUKKAWADA- BASAVAPATNA 66	BASAVAPATNA_66,TYA VANAGI_66	22:08	22:18	00:10	TRIPPED ON FAULT
1546	11-Apr-24	TUMKUR	LINE	66	KUKKAWADA- BASAVAPATNA 66	BASAVAPATNA_66,TYA VANAGI_66	23:35	23:55	00:20	TRIPPED ON FAULT
1547	12-Apr-24	BAGALKOTE	LINE	110	AMBEWADI220- NK2(KAVALWADA)	AMBEWADI_220	15:13	15:38	00:25	TRIPPED ON FAULT
1548	12-Apr-24	BAGALKOTE	LINE	110	ATHANI220- GHATANATTI	ATHANI_220	10:35	10:46	00:11	TRIPPED ON FAULT
1549	12-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1550	12-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1551	12-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1552	12-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	12:45	12:55	00:10	TRIPPED ON FAULT
1553	12-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1554	12-Apr-24	BAGALKOTE	LINE	110	HUBLI220-RAMANKOPPA	HUBLI_220	06:25	07:34	01:09	TRIPPED ON FAULT
1555	12-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
1556	12-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1557	12-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1558	12-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- KULIGOD	MUGALKHOD_220	11:02	12:40	01:38	LINE CLEAR AVAILED
1559	12-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- NAGNUR	MUGALKHOD_220	09:41	11:01	01:20	LINE CLEAR AVAILED
1560	12-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- SULTANPUR	MUGALKHOD_220	07:37	07:58	00:21	TRIPPED ON FAULT
1561	12-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- SULTANPUR	MUGALKHOD_220	17:27	18:08	00:41	TRIPPED ON FAULT
1562	12-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1563	12-Apr-24	BAGALKOTE	LINE	110	RANEENNUR220- HIREKERUR	RANEENNUR_220	17:55	18:04	00:09	TRIPPED ON FAULT
1564	12-Apr-24	BAGALKOTE	LINE	110	RANEENNUR220- TUMMINKATTE	RANEENNUR_220	14:30	18:01	03:31	LINE CLEAR AVAILED
1565	12-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1566	12-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI1	BAGALKOT_220	00:00	10:25	10:25	TRIPPED ON FAULT
1567	12-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI1	BAGALKOT_220	10:25	12:15	01:50	LINE CLEAR AVAILED
1568	12-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI1	BAGALKOT_220	13:17	13:47	00:30	TRIPPED ON FAULT
1569	12-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI2	BAGALKOT_220	09:22	12:26	03:04	LINE CLEAR AVAILED
1570	12-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI2	BAGALKOT_220	13:17	13:47	00:30	TRIPPED ON FAULT
1571	12-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI2	HUBLI_220	14:01	16:43	02:42	TRIPPED ON FAULT
1572	12-Apr-24	BAGALKOTE	LINE	220	HUBLI220-NAGZARI-3	HUBLI_220	15:48	16:49	01:01	TRIPPED ON FAULT
1573	12-Apr-24	BAGALKOTE	LINE	220	HUBLI-NAGZARI1	HUBLI_220	16:56 (11.04.2024)	15:39 (12.04.2024)		TRIPPED ON FAULT
1574	12-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1575	12-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(20MVA)	HUBLI_220	12:37	13:06	00:29	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1576	12-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	CHIKKODI_220	10:25	12:40	02:15	LINE CLEAR AVAILED
1577	12-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	KUDUR, SIRIGIRIPURA, HULLENAHALLI	23:40	23:51	00:11	TRIPPED ON FAULT
1578	12-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	KUDUR, SIRIGIRIPURA, HULLENAHALLI	13:30	13:33	00:03	LINE CLEAR AVAILED
1579	12-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	MULBAGAL, SOLAR IPP	18:05	18:20	00:15	LINE CLEAR AVAILED
1580	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - CESSNA BUSINESS EHT	CESSNA 66	08:39	08:51	00:12	MAIN SUPPLY FAILURE
1581	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - CESSNA BUSINESS EHT	CESSNA 66	09:41	09:46	00:05	LINE CLEAR AVAILED
1582	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	EXORA 66	08:39	08:51	00:12	MAIN SUPPLY FAILURE
1583	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	EXORA 66	09:41	09:46	00:05	LINE CLEAR AVAILED
1584	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - KALYANI TECH PARK	KALYANI TECH PARK	08:39	08:51	00:12	MAIN SUPPLY FAILURE
1585	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - KALYANI TECH PARK	KALYANI TECH PARK	09:41	09:46	00:05	LINE CLEAR AVAILED
1586	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - ORACLE EHT	ORACLE EHT	08:39	08:51	00:12	MAIN SUPPLY FAILURE
1587	12-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - ORACLE EHT	ORACLE EHT	09:41	09:46	00:05	LINE CLEAR AVAILED
1588	12-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	66/25KV RAILWAY TRACTION S/S	09:47	09:54	00:07	TRIPPED ON FAULT
1589	12-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - HIREHALLI	66KV HIREHALLI AND 66KV HONNUDIKE	21:09	21:28	00:19	TRIPPED ON FAULT
1590	12-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	66KV DODDABELE RAILWAY LINE AND 66KV THYAMGONDLU	09:23	09:41	00:18	TRIPPED ON FAULT
1591	12-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	66KV SULIBELE, CHANNARAYAPATNA	00:06	00:19	00:13	TRIPPED ON FAULT
1592	12-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	66KV SULIBELE, CHANNARAYAPATNA	00:33	02:45	02:12	TRIPPED ON FAULT
1593	12-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGMANE TECH PARK	06:09	07:46	01:37	TRIPPED ON FAULT
1594	12-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)	66 KV BANASWADI (PARTIAL LOAD) HV2	11:35	12:32	00:57	TRIPPED ON FAULT
1595	12-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NARSAPURA	06:55	08:08	01:13	TRIPPED ON FAULT
1596	12-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NO STATION AFFECTED	08:08	08:40	00:32	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1597	12-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NARSAPURA	06:56	08:03	01:07	TRIPPED ON FAULT
1598	12-Apr-24	BENGALURU	LINE	66	66KV MARALAVADI - GODUR	GODUR	18:41	18:51	00:10	TRIPPED ON FAULT
1599	12-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	12:26	12:45	00:19	LINE CLEAR AVAILED
1600	12-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 2	NALLIMARDANAHALLI	12:26	12:45	00:19	LINE CLEAR AVAILED
1601	12-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLY	08:57	09:04	00:07	LINE CLEAR AVAILED
1602	12-Apr-24	BENGALURU	LINE	66	66KV NRS 220 - NANDINI LAYOUT	66 KV NANDINI	09:40	09:44	00:04	LINE CLEAR AVAILED
1603	12-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	66KV ATTIBELE STATION	15:15	15:55	00:40	TRIPPED ON FAULT
1604	12-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	66KV BANNERAGATTA	12:15	12:31	00:16	LINE CLEAR AVAILED
1605	12-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR, YELDUR	09:45	10:40	00:55	LINE CLEAR AVAILED
1606	12-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - BRINDAVANA 220	66 KV NANDINI	08:10	08:20	00:10	TRIPPED ON FAULT
1607	12-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	66KV MAHALAKSHMI LAYOUT	08:10	08:17	00:07	TRIPPED ON FAULT
1608	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	08:39	08:49	00:10	LINE CLEAR AVAILED
1609	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	09:49	09:54	00:05	LINE CLEAR AVAILED
1610	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	08:39	08:49	00:10	LINE CLEAR AVAILED
1611	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	09:49	09:54	00:05	LINE CLEAR AVAILED
1612	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	08:38	08:49	00:11	MAIN SUPPLY FAILURE
1613	12-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	09:49	09:54	00:05	LINE CLEAR AVAILED
1614	12-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL (EHT)	11:18	11:45	00:27	MAIN SUPPLY FAILURE
1615	12-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON(EHT)	11:18	11:35	00:17	MAIN SUPPLY FAILURE
1616	12-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	BOMMASANDRA,	11:18	11:35	00:17	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1617	12-Apr-24	BENGALURU	LINE	220	220KV HOODY 220 - MALUR 220	220KV VTP & 220KV EXORA STATION	08:33	08:51	00:18	TRIPPED ON FAULT
1618	12-Apr-24	BENGALURU	TRANSFORMER	66	HV1	JADIGENAHALLI	10:30	10:55	00:25	LINE CLEAR AVAILED
1619	12-Apr-24	BENGALURU	TRANSFORMER	66	HV1	K RAGHUTTAHALLI	16:30	16:35	00:05	LINE CLEAR AVAILED
1620	12-Apr-24	BENGALURU	TRANSFORMER	66	HV1	K RAGHUTTAHALLI	17:25	17:30	00:05	LINE CLEAR AVAILED
1621	12-Apr-24	BENGALURU	TRANSFORMER	66	HV2	JADIGENAHALLI	05:40	06:10	00:30	TRIPPED ON FAULT
1622	12-Apr-24	BENGALURU	TRANSFORMER	66	HV3	HEBBAL 220	04:30	06:57	02:27	TRIPPED ON FAULT
1623	12-Apr-24	BENGALURU	TRANSFORMER	66	HV3	DEVANAHALLI 66	09:15	09:20	00:05	TRIPPED ON FAULT
1624	12-Apr-24	BENGALURU	TRANSFORMER	220	HV2	YARANDANAHALLI 220	11:18	11:30	00:12	TRIPPED ON FAULT
1625	12-Apr-2024	GULBARGA	LINE	66	KUDALGI-BANAVEKAL	BANAVEKAL_66, SOLARSYS_66, ABRSL_IPP	17:25	18:15	00:50	TRIPPED ON FAULT
1626	12-Apr-2024	GULBARGA	LINE	66	KUDALGI-BANAVEKAL	BANAVEKAL_66, SOLARSYS_66, ABRSL_IPP	17:50	18:15	00:25	TRIPPED ON FAULT
1627	12-Apr-2024	GULBARGA	LINE	66	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBAJ JIHALLI_66	10:25	10:35	00:10	TRIPPED ON FAULT
1628	12-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-SOMASAMUNDRA	SOMASAMUNDRA_110, KURUGOD_110	01:42	01:56	00:14	TRIPPED ON FAULT
1629	12-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	05:23	05:40	00:17	TRIPPED ON FAULT
1630	12-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	11:06	12:26	01:20	LINE CLEAR AVAILED
1631	12-Apr-2024	GULBARGA	LINE	110	KURUGOD-KIADB KUDITINI	KURUGOD_110	01:56	02:52	00:56	LINE CLEAR AVAILED
1632	12-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-SHORAPUR(DEVAPUR)	SHORAPUR_110,DEVAP UR_110	00:18	00:28	00:10	TRIPPED ON FAULT
1633	12-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110, TURVIHAL_110	03:05	03:25	00:20	TRIPPED ON FAULT
1634	12-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SUZALON	SINDHANOOR_220	11:58	16:05	04:07	LINE CLEAR AVAILED
1635	12-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-LINGASUGUR	LINGASUGUR_220	10:15	10:53	00:38	TRIPPED ON FAULT
1636	12-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-SULEKAL	SULEKAL_220	10:05	10:55	00:50	LINE CLEAR AVAILED
1637	12-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGASUGUR	SHAHAPUR_220	19:23(11.04.20 24)	9:41(12.04.202 4)	14:18	TRIPPED ON FAULT
1638	12-Apr-2024	GULBARGA	TRANSFORMER	66	HV3	TELAGI_66	16:25	16:30	00:05	TRIPPED ON FAULT
1639	12-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	BISIHALLI_110	16:00	20:15	04:15	TRIPPED ON FAULT
1640	12-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	ALIPUR_220	08:12	09:20	01:08	TRIPPED ON FAULT
1641	12-Apr-24	HASSAN	LINE	66	ALDUR-BALEHONNUR	ALDUR_66	15:03	15:45	00:42	TRIPPED ON FAULT
1642	12-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	gen_bhadra	10:05	14:03	03:58	LINE CLEAR AVAILED
1643	12-Apr-24	HASSAN	LINE	66	BHADRA-SHMG 1	gen_bhadra	10:01	14:04	04:03	LINE CLEAR AVAILED
1644	12-Apr-24	HASSAN	LINE	66	BHADRA-SHMG 2	gen_bhadra	09:55	14:03	04:08	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1645	12-Apr-24	HASSAN	LINE	66	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	21:20 (11.4.2024)	0:46(12.4.2024)	3:25 hrs	TRIPPED ON FAULT
1646	12-Apr-24	HASSAN	LINE	66	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	21:20 (11.4.2024)	1:00 (12.04.2024)	3:39 hrs	TRIPPED ON FAULT
1647	12-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA1	CHANNARAYAPATNA_220	23:46(11.04.2024)	00:43(12.04.2024)	0:56 hrs	LINE CLEAR AVAILED
1648	12-Apr-24	HASSAN	LINE	66	CHANNAR-CRPTNA2	CHANNARAYAPATNA_220	23:46(11.04.2024)	00:43(12.04.2024)	0:56 hrs	LINE CLEAR AVAILED
1649	12-Apr-24	HASSAN	LINE	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	00:46	08:12	07:26	TRIPPED ON FAULT
1650	12-Apr-24	HASSAN	LINE	66	CHANNAR-UDAYAPURA1	CHANNARAYAPATNA_66	21:20 (11.4.2024)	8:00 (12.4.2024)	10:39 hrs	TRIPPED ON FAULT
1651	12-Apr-24	HASSAN	LINE	66	CHANNAR-UDAYAPURA2	CHANNARAYAPATNA_66	21:20 (11.4.2024)	8:12 (12.4.2024)	10:51 hrs	TRIPPED ON FAULT
1652	12-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA1	HASSAN_220	11:02	11:18	00:16	TRIPPED ON FAULT
1653	12-Apr-24	HASSAN	LINE	66	HIEMAN-CHIKAMANGALUR	HIEMANGALUR_66	04:00	04:17	00:17	TRIPPED ON FAULT
1654	12-Apr-24	HASSAN	LINE	66	KANDLI-HASSAN	KANDLI_66	11:00	11:19	00:19	MAIN SUPPLY FAILURE
1655	12-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	11:00	11:19	00:19	MAIN SUPPLY FAILURE
1656	12-Apr-24	HASSAN	LINE	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:20	10:55	00:35	LINE CLEAR AVAILED
1657	12-Apr-24	HASSAN	LINE	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	12:40	12:50	00:10	LINE CLEAR AVAILED
1658	12-Apr-24	HASSAN	LINE	66	RMWNGR-HASSAN	RAMESHWARNAGARA_66	15:28	15:42	00:14	LINE CLEAR AVAILED
1659	12-Apr-24	HASSAN	LINE	66	SBELAG-SNTBCHL	SBELAGOLA_66	18:31	19:14	00:43	TRIPPED ON FAULT
1660	12-Apr-24	HASSAN	LINE	66	SHANTHI-MALALI	SHANTHIGRAMA_66	10:35	11:05	00:30	LINE CLEAR AVAILED
1661	12-Apr-24	HASSAN	LINE	66	SHANTHI-MALALI	SHANTHIGRAMA_66	11:50	12:20	00:30	LINE CLEAR AVAILED
1662	12-Apr-24	HASSAN	LINE	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:35	11:07	00:32	MAIN SUPPLY FAILURE
1663	12-Apr-24	HASSAN	LINE	66	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	12:30	12:40	00:10	LINE CLEAR AVAILED
1664	12-Apr-24	HASSAN	LINE	66	UDAYAP-BAGUR	UDAYAPURA_66	00:01	00:45	00:44	MAIN SUPPLY FAILURE
1665	12-Apr-24	HASSAN	LINE	66	UDAYAP-BAGUR	UDAYAPURA_66	01:05	01:13	00:08	TRIPPED ON FAULT
1666	12-Apr-24	HASSAN	LINE	66	UDAYAP-BAGUR	UDAYAPURA_66	01:20	01:42	00:22	TRIPPED ON FAULT
1667	12-Apr-24	HASSAN	LINE	66	UDAYAP-BAGUR	UDAYAPURA_66	07:20	08:00	00:40	MAIN SUPPLY FAILURE
1668	12-Apr-24	HASSAN	LINE	110	ALKOLA-SAGAR	ALKOLA_110	12:35	16:20	03:45	LINE CLEAR AVAILED
1669	12-Apr-24	HASSAN	LINE	110	KEMAR-Manipal1	KEMAR_220	14:51	14:58	00:07	MAIN SUPPLY FAILURE
1670	12-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	14:51	14:58	00:07	MAIN SUPPLY FAILURE
1671	12-Apr-24	HASSAN	LINE	110	MANIPAL-BRAMVR	MANIPAL_110	14:51	14:58	00:07	MAIN SUPPLY FAILURE
1672	12-Apr-24	HASSAN	LINE	110	MANIPAL-KEMAR1	MANIPAL_110	14:51	14:58	00:07	MAIN SUPPLY FAILURE
1673	12-Apr-24	HASSAN	LINE	110	SAGARA-ALKLA	SAGARA_110	12:35	16:20	03:45	LINE CLEAR AVAILED
1674	12-Apr-24	HASSAN	LINE	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:42	19:18	00:36	TRIPPED ON FAULT
1675	12-Apr-24	HASSAN	LINE	220	MRSSHM-VARAH13	MRSMG_220	15:08	17:22	02:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1676	12-Apr-24	HASSAN	LINE	220	VARAHI-SHMG3	gen_varahi	15:08	17:22	02:14	TRIPPED ON FAULT
1677	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	CHIKMAGLUR_66	09:37	09:47	00:10	MAIN SUPPLY FAILURE
1678	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	HIREMANGALUR_66	04:00	04:18	00:18	MAIN SUPPLY FAILURE
1679	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_66	09:05	09:50	00:45	TRIPPED ON FAULT
1680	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_66	23:15	23:28	00:13	LINE CLEAR AVAILED
1681	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMESHWARNAGARA_66	10:20	10:55	00:35	LINE CLEAR AVAILED
1682	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMESHWARNAGARA_66	12:40	12:50	00:10	LINE CLEAR AVAILED
1683	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	SHANTHIGRAMA_66	10:35	11:07	00:32	MAIN SUPPLY FAILURE
1684	12-Apr-24	HASSAN	TRANSFORMER	66	HV1	SHANTHIGRAMA_66	11:50	12:23	00:33	MAIN SUPPLY FAILURE
1685	12-Apr-24	HASSAN	TRANSFORMER	66	HV2	SHANTHIGRAMA_66	17:05(11.04.2024)	13:25(12.04.2024)	20:19 hrs	LINE CLEAR AVAILED
1686	12-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMESHWARNAGARA_66	10:20	10:55	00:35	LINE CLEAR AVAILED
1687	12-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMESHWARNAGARA_66	12:40	12:50	00:10	LINE CLEAR AVAILED
1688	12-Apr-24	HASSAN	TRANSFORMER	66	HV4	BALEHONNUR_66	23:54 (12.4.2024)			TRIPPED ON FAULT
1689	12-Apr-24	HASSAN	TRANSFORMER	110	LV2	KEMAR_220	14:51	14:58	00:07	TRIPPED ON FAULT
1690	12-Apr-24	HASSAN	TRANSFORMER	220	HV2	KEMAR_220	14:51	14:58	00:07	TRIPPED ON FAULT
1691	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-HANAGODU	HANGODU_66	15:41	16:11	00:30	TRIPPED ON FAULT
1692	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-HOSURGATE	HOSURGATE_66	15:41	16:11	00:30	TRIPPED ON FAULT
1693	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-HUNSUR 1	HUNSUR_66	15:41	16:11	00:30	TRIPPED ON FAULT
1694	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-HUNSUR 2	NO STATIONS EFFECTED	15:41	16:11	00:30	TRIPPED ON FAULT
1695	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-KAMPLAPURA	KAMPLAPURA_66	15:41	16:11	00:30	TRIPPED ON FAULT
1696	12-Apr-24	MYSORE	LINE	66	220 HUNSUR-YELWALA	ELAVALA_66HUNSUR_66	15:42	16:06	00:24	TRIPPED ON FAULT
1697	12-Apr-24	MYSORE	LINE	66	BANNIKUPPE-GV GUDI	GVGUDI_66	20:47	21:20	00:33	TRIPPED ON FAULT
1698	12-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	05:44	05:55	00:10	TRIPPED ON FAULT
1699	12-Apr-24	MYSORE	LINE	66	HALAGUR-TK HALLI	NO STATIONS EFFECTED	10:53	13:11	02:17	LINE CLEAR AVAILED
1700	12-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
1701	12-Apr-24	MYSORE	LINE	66	HUNSUR-ELWALA	ELAVALA_66	20:54	21:05	00:11	TRIPPED ON FAULT
1702	12-Apr-24	MYSORE	LINE	66	HUNSUR-HOOTAGALLI	GVGUDI_66BANNIKUPPE_66	21:42	21:52	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1703	12-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66CHAN DRAVADI_66HURA_66	15:03	15:10	00:07	TRIPPED ON FAULT
1704	12-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA	HAMPAPURA(K)_66 YERHALLI HAND POST_66 SANTESARGUR_66 HDKOTE_66 BMATKERE_66 ANTARSANTE_66CHAN DRAVADI_66HURA_66	15:18	15:27	00:09	TRIPPED ON FAULT
1705	12-Apr-24	MYSORE	LINE	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	15:12	15:48	00:35	LINE CLEAR AVAILED
1706	12-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1707	12-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MADIKERI	NO STATIONS EFFECTED	17:08	17:30	00:22	TRIPPED ON FAULT
1708	12-Apr-24	MYSORE	LINE	66	KUSHALNAGARA- MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1709	12-Apr-24	MYSORE	LINE	66	MYSORE-GIS	NO STATIONS EFFECTED	16:09	21:53	05:43	LINE CLEAR AVAILED
1710	12-Apr-24	MYSORE	LINE	66	PANDAVAPURA-TUBINKERE	DODDABYADARAHALLI_66	21:58	22:08	00:09	LINE CLEAR AVAILED
1711	12-Apr-24	MYSORE	LINE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	19:11	19:30	00:19	TRIPPED ON FAULT
1712	12-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36 (11/04/2024)	7:01 (12/04/2024)	10:24	LINE CLEAR AVAILED
1713	12-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:13 (12/04/2024)			TRIPPED ON FAULT
1714	12-Apr-24	MYSORE	TRANSFORMER	66	HV1	GAMANAHALLY_66	10:12	11:58	01:45	LINE CLEAR AVAILED
1715	12-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1716	12-Apr-24	MYSORE	TRANSFORMER	66	HV2	BETTADAPURA_66	15:15	16:37:57	01:22	LINE CLEAR AVAILED
1717	12-Apr-24	MYSORE	TRANSFORMER	66	HV2	GAMANAHALLY_66	12:00	13:12	01:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1718	12-Apr-24	MYSORE	TRANSFORMER	66	HV2	NAGAMANGALA_66	10:15	10:34	00:18	LINE CLEAR AVAILED
1719	12-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANGODU_66	22:28	22:33	00:05	TRIPPED ON FAULT
1720	12-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	SOKKE_66KV, PALLAGATTE_66, BILCHODU_66	15:10	15:20	00:10	TRIPPED ON FAULT
1721	12-Apr-24	TUMKUR	LINE	66	DYAVARANAHALLI- PR PURA	PR PURA_66	09:48	10:20	00:32	TRIPPED ON FAULT
1722	12-Apr-24	TUMKUR	LINE	66	HANAGAL- NAGASAMUDRA_66	NAGASAMUDRA_66	18:55	19:10	00:15	TRIPPED ON FAULT
1723	12-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-P R PURA	HARIAYABBE,P.D KOTE	08:00	16:00	08:00	LINE CLEAR AVAILED
1724	12-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-THALLAK	KALAMARANAHALLI_66, THALLAK_66,RANGENA HALLI_66	08:00	16:00	08:00	LINE CLEAR AVAILED
1725	12-Apr-24	TUMKUR	LINE	66	MAYAKONDA- SASLUHALLA	SASALUHALLA_66	06:30	06:40	00:10	TRIPPED ON FAULT
1726	13-Apr-24	BAGALKOTE	LINE	110	AMBEWADI220- GANESHGUDI	AMBEWADI_220	19:02	20:16	01:14	LINE CLEAR AVAILED
1727	13-Apr-24	BAGALKOTE	LINE	110	AMBEWADI-SUPA1	AMBEWADI_220	19:01	19:27	00:26	TRIPPED ON FAULT
1728	13-Apr-24	BAGALKOTE	LINE	110	ANKALAGI- ISLAMPUR	ANKALAGI_110	18:46	19:00	00:14	TRIPPED ON FAULT
1729	13-Apr-24	BAGALKOTE	LINE	110	ATHANI220- GHATANATTI	ATHANI_220	06:05	06:12	00:07	TRIPPED ON FAULT
1730	13-Apr-24	BAGALKOTE	LINE	110	ATHANI220- KARIMASUTI	ATHANI_220	15:29	18:17	02:48	LINE CLEAR AVAILED
1731	13-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
1732	13-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
1733	13-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
1734	13-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	06:32	06:57	00:25	TRIPPED ON FAULT
1735	13-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1736	13-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
1737	13-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1738	13-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1739	13-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1740	13-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1741	13-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220-MANTUR1	VAJRAMATTI_220	15:33	16:01	00:28	LINE CLEAR AVAILED
1742	13-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1743	13-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1&HV2(10MVA)	SIRSI_220	11:03	11:20	00:17	LINE CLEAR AVAILED
1744	13-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1&HV2(10MVA)	SIRSI_220	20:23	20:34	00:11	LINE CLEAR AVAILED
1745	13-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(20MVA)	RANNABELAGALI_110	06:10	10:23	04:13	TRIPPED ON FAULT
1746	13-Apr-24	BENGALURU	LINE	66	220KV KOTHIPURA 220 - BIDADI 2	NO STATION AFFECTED	18:09	19:14	01:05	TRIPPED ON FAULT
1747	13-Apr-24	BENGALURU	LINE	66	66KV ABBIGERE - ATTURU - MANYATA DG-3	ATTUR YELAHANKA	08:30	08:35	00:05	LINE CLEAR AVAILED
1748	13-Apr-24	BENGALURU	LINE	66	66KV ANEKAL - ATTIBELE	ATTIBELE	08:26	08:28	00:02	LINE CLEAR AVAILED
1749	13-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1750	13-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	MULBAGAL	10:05	11:35	01:30	LINE CLEAR AVAILED
1751	13-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA, KALYANI TECH PARK, ORACLE(EHT)	18:12	18:18	00:06	LINE CLEAR AVAILED
1752	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - ACC PLANT	ACC PLANT	12:38	13:27	00:49	MAIN SUPPLY FAILURE
1753	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - ALLIPURA	THONDEBHAVI, ALIPURA	12:38	13:49	01:11	MAIN SUPPLY FAILURE
1754	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	12:38	13:42	01:04	MAIN SUPPLY FAILURE
1755	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	12:38	13:40	01:02	MAIN SUPPLY FAILURE
1756	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	12:38	13:40	01:02	MAIN SUPPLY FAILURE
1757	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - RAMAPURA	HOSUR RAMAPURA	12:38	13:40	01:02	MAIN SUPPLY FAILURE
1758	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	12:38	13:40	01:02	MAIN SUPPLY FAILURE
1759	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDHURASHWATHA, GUNDLU KOTTUR	12:38	13:40	01:02	MAIN SUPPLY FAILURE
1760	13-Apr-24	BENGALURU	LINE	66	66KV GOWRIDIDANUR 220 - KUDUMULAKUNTE	KUDUMULKUNTE, THRIYURU, VENKATAPURA	12:38	13:27	00:49	MAIN SUPPLY FAILURE
1761	13-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - ADUGODI	ADUGODI	06:30	06:41	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1762	13-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	15:15	16:30	01:15	LINE CLEAR AVAILED
1763	13-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	18:36	18:57	00:21	TRIPPED ON FAULT
1764	13-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	12:35	13:05	00:30	MAIN SUPPLY FAILURE
1765	13-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	13:35	13:40	00:05	MAIN SUPPLY FAILURE
1766	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	12:38	13:28	00:50	MAIN SUPPLY FAILURE
1767	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	12:38	13:26	00:48	MAIN SUPPLY FAILURE
1768	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, THIMAMPALLI, GULUR	12:38	13:28	00:50	MAIN SUPPLY FAILURE
1769	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SADHALI	SADALI	12:38	13:27	00:49	MAIN SUPPLY FAILURE
1770	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA, CHELUR, CHAKAVELU	12:38	13:27	00:49	MAIN SUPPLY FAILURE
1771	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	12:38	13:26	00:48	MAIN SUPPLY FAILURE
1772	13-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SOMENAHALLI 2	NALLIMARADANAHALLI	12:38	13:27	00:49	MAIN SUPPLY FAILURE
1773	13-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	SADALI	13:47	13:52	00:05	LINE CLEAR AVAILED
1774	13-Apr-24	BENGALURU	LINE	66	66KV NRS 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	06:26	06:31	00:05	LINE CLEAR AVAILED
1775	13-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	13:36	13:40	00:04	LINE CLEAR AVAILED
1776	13-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	19:10	19:14	00:04	LINE CLEAR AVAILED
1777	13-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, JIGANI LINK ROAD	21:19	22:02	00:43	TRIPPED ON FAULT
1778	13-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	18:51	19:15	00:24	TRIPPED ON FAULT
1779	13-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	05:12	05:23	00:11	TRIPPED ON FAULT
1780	13-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	05:58	06:15	00:17	TRIPPED ON FAULT
1781	13-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	06:17	09:50	03:33	TRIPPED ON FAULT
1782	13-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	09:50	11:33	01:43	LINE CLEAR AVAILED
1783	13-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	15:01	15:11	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1784	13-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	18:12	18:16	00:04	LINE CLEAR AVAILED
1785	13-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	18:12	18:16	00:04	LINE CLEAR AVAILED
1786	13-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	18:13	18:16	00:03	LINE CLEAR AVAILED
1787	13-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
1788	13-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	14:00	14:05	00:05	LINE CLEAR AVAILED
1789	13-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	20:15	20:20	00:05	LINE CLEAR AVAILED
1790	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - KIADB DODDABALLAPURA	KIADB DB PURA 220	12:37	13:04	00:27	MAIN SUPPLY FAILURE
1791	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - MADHUGIRI	GOWRIBIDANUR 220, MITTEMARI 220	12:38	13:20	00:42	TRIPPED ON FAULT
1792	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1793	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1794	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 1	RVNL SOMESHWARA	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1795	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 2	RVNL SOMESHWARA	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1796	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - SIRA 1	GOWRIBIDANUR 220, MITTEMARI 220	12:38	13:23	00:45	TRIPPED ON FAULT
1797	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - SIRA 1	NO STATION AFFECTED	17:01	19:32	02:31	TRIPPED ON FAULT
1798	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - SIRA 2	GOWRIBIDANUR 220, MITTEMARI 220	12:38	13:36	00:58	TRIPPED ON FAULT
1799	13-Apr-24	BENGALURU	LINE	220	220KV GOWRIBIDANUR 220 - SIRA 2	NO STATION AFFECTED	17:01	19:33	02:32	LINE CLEAR AVAILED
1800	13-Apr-24	BENGALURU	LINE	220	220KV NRS DB PURA 220 - KIADB DB PURA 220	KIADB DB PURA 220	13:33	13:37	00:04	LINE CLEAR AVAILED
1801	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	M GOLLAHALLI	00:47	01:05	00:18	TRIPPED ON FAULT
1802	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	M GOLLAHALLI	23:55	23:59	00:04	TRIPPED ON FAULT
1803	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KANASAWADI	07:35	07:45	00:10	LINE CLEAR AVAILED
1804	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	12:38	13:26	00:48	MAIN SUPPLY FAILURE
1805	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MITTEMARI 220	12:38	13:24	00:46	MAIN SUPPLY FAILURE
1806	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KAMASAMUDRA	15:15	18:45	03:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1807	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA	11:40	12:10	00:30	TRIPPED ON FAULT
1808	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA	16:58	17:25	00:27	TRIPPED ON FAULT
1809	13-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	18:38	18:53	00:15	LINE CLEAR AVAILED
1810	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KANASAWADI	07:35	07:45	00:10	LINE CLEAR AVAILED
1811	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KUNDANA	14:40	14:45	00:05	TRIPPED ON FAULT
1812	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GOWRIBIDANUR 220	12:38	13:26	00:48	MAIN SUPPLY FAILURE
1813	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUDIBANDE	10:20	11:15	00:55	LINE CLEAR AVAILED
1814	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NANGLI	11:40	13:15	01:35	LINE CLEAR AVAILED
1815	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KAMASAMUDRA	19:55	20:00	00:05	TRIPPED ON FAULT
1816	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	18:20	18:30	00:10	LINE CLEAR AVAILED
1817	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	19:55	20:15	00:20	LINE CLEAR AVAILED
1818	13-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TYAMAGONDLU	09:05	10:00	00:55	TRIPPED ON FAULT
1819	13-Apr-24	BENGALURU	TRANSFORMER	220	HV1	GOWRIBIDANUR 220	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1820	13-Apr-24	BENGALURU	TRANSFORMER	220	HV2	GOWRIBIDANUR 220	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1821	13-Apr-24	BENGALURU	TRANSFORMER	220	HV3	GOWRIBIDANUR 220	12:38	13:23	00:45	MAIN SUPPLY FAILURE
1822	13-Apr-2024	GULBARGA	LINE	66	ITTAGI-HB HALLI	HB HALLI_66, KOTTUR_66	16:35	17:11	00:36	TRIPPED ON FAULT
1823	13-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI2	SOVENHALLI_66	06:08	06:15	00:07	TRIPPED ON FAULT
1824	13-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	16:32	16:43	00:11	TRIPPED ON FAULT
1825	13-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	17:48(13.04.20 24)			TRIPPED ON FAULT
1826	13-Apr-2024	GULBARGA	LINE	66	TELAGI-GREEN INFRA WIND ENERGY	TELAGI_66	17:30	17:55	00:25	TRIPPED ON FAULT
1827	13-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-SOMASAMUNDRA	SOMASAMUNDRA_110, KURUGOD_110	05:50	06:08	00:18	TRIPPED ON FAULT
1828	13-Apr-2024	GULBARGA	LINE	110	KAMLAPUR-SANKLAPUR	KAMLAPUR_110	12:55	13:45	00:50	MAIN SUPPLY FAILURE
1829	13-Apr-2024	GULBARGA	LINE	110	KAPNOOR-ALAND	ALAND_110	05:45	06:02	00:17	TRIPPED ON FAULT
1830	13-Apr-2024	GULBARGA	LINE	110	KAPNOOR-GULBARGA NORTH 1	GULBARGA NORTH_110	07:37	09:44	02:07	LINE CLEAR AVAILED
1831	13-Apr-2024	GULBARGA	LINE	110	KAPNOOR-GULBARGA NORTH 2	GULBARGA NORTH_110	07:38	09:44	02:06	LINE CLEAR AVAILED
1832	13-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MADIYAL	MADIYAL_110	18:34	18:50	00:16	TRIPPED ON FAULT
1833	13-Apr-2024	GULBARGA	LINE	110	SANTHAPUR-HALBARGA	SANTHAPUR_110	13:57	14:04	00:07	TRIPPED ON FAULT
1834	13-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-KHANAPUR1	KHANAPUR_110,SAIDAP UR_110,WADAGERA_11 0,SANNATHI_IPP,CORE GREEN SUGAR_IPP	03:45	04:05	00:20	TRIPPED ON FAULT
1835	13-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-MUKUNDA	JAWALGERA_110, MUKUNDA_110, WALABALLARY_110	14:40	15:15	00:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1836	13-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SR NAGAR	KARATAGI_110, WALKAMDINI_110	14:40	15:15	00:35	MAIN SUPPLY FAILURE
1837	13-Apr-2024	GULBARGA	LINE	110	SULEKAL-TAVARGERA	TAVARGERA_110	14:54	15:03	00:09	TRIPPED ON FAULT
1838	13-Apr-2024	GULBARGA	LINE	110	YADGIR-BAGEWADI 1	YADGIR_110	05:40	05:52	00:12	TRIPPED ON FAULT
1839	13-Apr-2024	GULBARGA	LINE	220	KUDALGI-HM HOLE1	KUDALGI_220	16:45	18:00:00	01:15	TRIPPED ON FAULT
1840	13-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-SULEKAL	SULEKAL_220	15:04	24:00:00	08:56	TRIPPED ON FAULT
1841	13-Apr-2024	GULBARGA	LINE	220	NEELAGUNDA-GUTTUR	NEELAGUNDA_220	06:03	12:10	06:07	TRIPPED ON FAULT
1842	13-Apr-2024	GULBARGA	LINE	220	SEADM-FEROZABAD	SEDAM_220	00:00	14:04	14:04	LINE CLEAR AVAILED
1843	13-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	NEELAGUNDA_220	17:20	17:25	00:05	TRIPPED ON FAULT
1844	13-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	CJ HALLI_66	16:09	16:21	00:12	TRIPPED ON FAULT
1845	13-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	HALVAGALU_66	19:00	19:05	00:05	TRIPPED ON FAULT
1846	13-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	TELAGE_66	17:10	17:25	00:15	TRIPPED ON FAULT
1847	13-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GANADAL_110	15:50	16:25	00:35	TRIPPED ON FAULT
1848	13-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	10:34	10:48	00:14	TRIPPED ON FAULT
1849	13-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	SOMASAMUNDRA_110	05:27	05:37	00:10	TRIPPED ON FAULT
1850	13-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	11:51	12:02	00:11	TRIPPED ON FAULT
1851	13-Apr-24	HASSAN	LINE	66	DODDAHA-HOOTGALLI	DODDAHALLI_66	00:05	00:37	00:32	TRIPPED ON FAULT
1852	13-Apr-24	HASSAN	LINE	66	DODDAKA-KRNAGARA	DODDAKADNUR_66	00:05	00:25	00:20	TRIPPED ON FAULT
1853	13-Apr-24	HASSAN	LINE	66	HNPR2-HASS1	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1854	13-Apr-24	HASSAN	LINE	66	HNPR2-HASS2	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1855	13-Apr-24	HASSAN	LINE	66	HNPR2-HASS3	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1856	13-Apr-24	HASSAN	LINE	66	HNPR2-HNPR1	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1857	13-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR1	HNPURA_220	18:10	20:25	02:15	MAIN SUPPLY FAILURE
1858	13-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR2	HNPURA_220	18:10	20:25	02:15	MAIN SUPPLY FAILURE
1859	13-Apr-24	HASSAN	LINE	66	HNPR2-RNPR1	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1860	13-Apr-24	HASSAN	LINE	66	HNPR2-RNPR2	HNPURA_220	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1861	13-Apr-24	HASSAN	LINE	66	HNPURA-HNPR2	HNPURA_66	18:10	20:50	02:40	MAIN SUPPLY FAILURE
1862	13-Apr-24	HASSAN	LINE	66	HNPURA-RAMNATHPURA	HNPURA_66	18:10	20:10	02:00	MAIN SUPPLY FAILURE
1863	13-Apr-24	HASSAN	LINE	66	HNPURA-SOMANAHALLI	HNPURA_66	18:10	20:40	02:30	MAIN SUPPLY FAILURE
1864	13-Apr-24	HASSAN	LINE	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:55	16:15	00:20	TRIPPED ON FAULT
1865	13-Apr-24	HASSAN	LINE	66	MALALI-CRPATNA	MALALI_66	18:10	20:35	02:25	MAIN SUPPLY FAILURE
1866	13-Apr-24	HASSAN	LINE	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	20:40	20:45	00:05	LINE CLEAR AVAILED
1867	13-Apr-24	HASSAN	LINE	66	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	18:10	19:53	01:43	MAIN SUPPLY FAILURE
1868	13-Apr-24	HASSAN	LINE	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	18:10	20:47	02:37	MAIN SUPPLY FAILURE
1869	13-Apr-24	HASSAN	LINE	66	RMWNGR-SHANTI	RAMESHWARNAGARA_66	20:20	20:50	00:30	LINE CLEAR AVAILED
1870	13-Apr-24	HASSAN	LINE	66	SAKALE-IPCL1	SAKALESHPURA_66	09:12	14:35	05:23	LINE CLEAR AVAILED
1871	13-Apr-24	HASSAN	LINE	66	SHANTHI-MALALI	SHANTHIGRAMA_66	18:10	20:21	02:11	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1872	13-Apr-24	HASSAN	LINE	66	SHANTHI-MALALI	SHANTHIGRAMA_66	20:50	21:00	00:10	LINE CLEAR AVAILED
1873	13-Apr-24	HASSAN	LINE	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	13:24	13:28	00:04	LINE CLEAR AVAILED
1874	13-Apr-24	HASSAN	LINE	110	ALKOLA-SAGAR	ALKOLA_110	17:24	19:38	02:14	TRIPPED ON FAULT
1875	13-Apr-24	HASSAN	LINE	110	ANAND-LPH(LST-4)	ANANDAPURA_110	17:24	18:13	00:49	TRIPPED ON FAULT
1876	13-Apr-24	HASSAN	LINE	110	BAIKAM-KAVOOR	BAIKAMPADI_110	18:26	19:07	00:41	MAIN SUPPLY FAILURE
1877	13-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANKERE_110	17:01	17:50	00:49	TRIPPED ON FAULT
1878	13-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANKERE_110	18:26	19:29	01:03	MAIN SUPPLY FAILURE
1879	13-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANKERE_110	17:01	17:45	00:44	TRIPPED ON FAULT
1880	13-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANKERE_110	18:26	19:29	01:03	MAIN SUPPLY FAILURE
1881	13-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANKERE_110	17:01	17:50	00:49	TRIPPED ON FAULT
1882	13-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANKERE_110	18:26	19:29	01:03	MAIN SUPPLY FAILURE
1883	13-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	01:35	01:38	00:03	TRIPPED ON FAULT
1884	13-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	04:08	04:20	00:12	TRIPPED ON FAULT
1885	13-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	15:47	15:53	00:06	TRIPPED ON FAULT
1886	13-Apr-24	HASSAN	LINE	110	KARAYA-PUTTUR	KARAYA_110	20:37	21:00	00:23	MAIN SUPPLY FAILURE
1887	13-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	17:01	17:50	00:49	TRIPPED ON FAULT
1888	13-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	18:26	19:29	01:03	MAIN SUPPLY FAILURE
1889	13-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	17:05	17:45	00:40	TRIPPED ON FAULT
1890	13-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	18:26	20:57	02:31	MAIN SUPPLY FAILURE
1891	13-Apr-24	HASSAN	LINE	110	KEMAR-Manipal1	KEMAR_220	18:26	19:15	00:49	MAIN SUPPLY FAILURE
1892	13-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	18:26	19:15	00:49	MAIN SUPPLY FAILURE
1893	13-Apr-24	HASSAN	LINE	110	KEMAR-NANDHIKUR1	KEMAR_220	18:26	19:21	00:55	MAIN SUPPLY FAILURE
1894	13-Apr-24	HASSAN	LINE	110	KEMAR-NANDHIKUR1	KEMAR_220	21:10	21:42	00:32	LINE CLEAR AVAILED
1895	13-Apr-24	HASSAN	LINE	110	KEMAR-NANDHIKUR2	KEMAR_220	18:26	19:19	00:53	MAIN SUPPLY FAILURE
1896	13-Apr-24	HASSAN	LINE	110	KEMAR-NANDHIKUR2	KEMAR_220	21:10	21:44	00:34	MAIN SUPPLY FAILURE
1897	13-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	20:37	20:59	00:22	MAIN SUPPLY FAILURE
1898	13-Apr-24	HASSAN	LINE	110	LPH-LST4	gen_lph	19:17 (13.04.2024)			TRIPPED ON FAULT
1899	13-Apr-24	HASSAN	LINE	110	MANIPAL-BRAMVR	MANIPAL_110	18:26	19:19	00:53	MAIN SUPPLY FAILURE
1900	13-Apr-24	HASSAN	LINE	110	MANIPAL-KEMAR1	MANIPAL_110	18:26	19:16	00:50	MAIN SUPPLY FAILURE
1901	13-Apr-24	HASSAN	LINE	110	MSEZ-GSS1	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1902	13-Apr-24	HASSAN	LINE	110	MSEZ-GSS2	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1903	13-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 1	PUTTUR_220	20:37	20:57	00:20	TRIPPED ON FAULT
1904	13-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 2	PUTTUR_220	20:37	20:52	00:15	TRIPPED ON FAULT
1905	13-Apr-24	HASSAN	LINE	110	PUTTUR-SLTR	PUTTUR_220	20:37	20:57	00:20	TRIPPED ON FAULT
1906	13-Apr-24	HASSAN	LINE	110	PUTTUR-SULIA	PUTTUR_220	20:37	20:52	00:15	TRIPPED ON FAULT
1907	13-Apr-24	HASSAN	LINE	110	SAGARA-SORABA	SAGARA_110	17:24	18:10	00:46	TRIPPED ON FAULT
1908	13-Apr-24	HASSAN	LINE	110	SAGARA-SS1	SAGARA_110	17:25	19:40	02:15	TRIPPED ON FAULT
1909	13-Apr-24	HASSAN	LINE	110	SAGARA-TAL	SAGARA_110	17:24	18:20	00:56	MAIN SUPPLY FAILURE
1910	13-Apr-24	HASSAN	LINE	110	SALATHU-BNTWAL	SALATHUr_110	20:37	20:55	00:18	MAIN SUPPLY FAILURE
1911	13-Apr-24	HASSAN	LINE	110	SHRLKP-BARANG	SHIRALKOPPA_220	18:08:00	19:13	01:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1912	13-Apr-24	HASSAN	LINE	110	VITTAL-PUTR_SLTUR	VITTALA_110	20:37	20:57	00:20	MAIN SUPPLY FAILURE
1913	13-Apr-24	HASSAN	LINE	220	GOPALAP-HNPUR21	GOPALAPURA_220	18:10	20:00	01:50	TRIPPED ON FAULT
1914	13-Apr-24	HASSAN	LINE	220	GOPALAP-HNPUR22	GOPALAPURA_220	18:10	20:00	01:50	TRIPPED ON FAULT
1915	13-Apr-24	HASSAN	LINE	220	GOPALAP-TUBINKERE	GOPALAPURA_220	18:10	19:47	01:37	TRIPPED ON FAULT
1916	13-Apr-24	HASSAN	LINE	220	HNPR2-GOPALPURA1	HNPURA_220	18:10	20:10	02:00	MAIN SUPPLY FAILURE
1917	13-Apr-24	HASSAN	LINE	220	HNPR2-GOPALPURA2	HNPURA_220	18:10	20:10	02:00	MAIN SUPPLY FAILURE
1918	13-Apr-24	HASSAN	LINE	220	KAVOOR-KEMAR3	KAVOOR_220	18:26	19:05	00:39	MAIN SUPPLY FAILURE
1919	13-Apr-24	HASSAN	LINE	220	KAVOOR-KEMR1	KAVOOR_220	18:26	19:16	00:50	MAIN SUPPLY FAILURE
1920	13-Apr-24	HASSAN	LINE	220	KAVOOR-KEMR2	KAVOOR_220	18:26	19:16	00:50	MAIN SUPPLY FAILURE
1921	13-Apr-24	HASSAN	LINE	220	KEMAR-BJPE1	KEMAR_220	18:26	19:08	00:42	MAIN SUPPLY FAILURE
1922	13-Apr-24	HASSAN	LINE	220	KEMAR-BJPE2	KEMAR_220	18:26	19:08	00:42	MAIN SUPPLY FAILURE
1923	13-Apr-24	HASSAN	LINE	220	KEMAR-Kavoor	KEMAR_220	18:26	19:05	00:39	MAIN SUPPLY FAILURE
1924	13-Apr-24	HASSAN	LINE	220	KEMAR-UPCL1	KEMAR_220	18:26	21:52	03:26	TRIPPED ON FAULT
1925	13-Apr-24	HASSAN	LINE	220	KEMAR-UPCL2	KEMAR_220	18:26	18:58	00:32	TRIPPED ON FAULT
1926	13-Apr-24	HASSAN	LINE	220	MRSSHM-CHKMNGLR	MRSMSG_220	16:13	20:10	03:57	TRIPPED ON FAULT
1927	13-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:17(13.04.2024)			TRIPPED ON FAULT
1928	13-Apr-24	HASSAN	LINE	220	MSEZ-KAVOOR1	MSEZ_220	18:26	19:15	00:49	MAIN SUPPLY FAILURE
1929	13-Apr-24	HASSAN	LINE	220	MSEZ-KAVOOR2	MSEZ_220	18:26	19:15	00:49	MAIN SUPPLY FAILURE
1930	13-Apr-24	HASSAN	LINE	220	MSEZ-KEMAR2	MSEZ_220	18:26	19:15	00:49	MAIN SUPPLY FAILURE
1931	13-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA1	gen_sharavathy	19:16(13.04.2024)			TRIPPED ON FAULT
1932	13-Apr-24	HASSAN	LINE	220	TALAGU-SGS1	TALAGUPPA_400	19:16(13.04.2024)			TRIPPED ON FAULT
1933	13-Apr-24	HASSAN	LINE	220	UPCL-KEMAR1	gen_upcl	18:26	21:53	03:27	TRIPPED ON FAULT
1934	13-Apr-24	HASSAN	LINE	220	UPCL-KEMAR2	gen_upcl	18:26	18:58	00:32	TRIPPED ON FAULT
1935	13-Apr-24	HASSAN	TRANSFORMER	66	HV1	HARIHARPURA_66	18:10	20:25	02:15	MAIN SUPPLY FAILURE
1936	13-Apr-24	HASSAN	TRANSFORMER	66	HV1	MOSALEHOSAHALLI_66	18:10	19:53	01:43	MAIN SUPPLY FAILURE
1937	13-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1938	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	BELUR_66	14:15	14:21	00:06	TRIPPED ON FAULT
1939	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	HALEBEEDU_66	14:45	16:10	01:25	TRIPPED ON FAULT
1940	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	MOSALEHOSAHALLI_66	18:10	19:53	01:43	MAIN SUPPLY FAILURE
1941	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	MOSALEHOSAHALLI_66	20:40	20:45	00:05	LINE CLEAR AVAILED
1942	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	MOSALEHOSAHALLI_66	20:40	20:45	00:05	LINE CLEAR AVAILED
1943	13-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	18:10	20:20	02:10	MAIN SUPPLY FAILURE
1944	13-Apr-24	HASSAN	TRANSFORMER	66	HV4	BALEHONNUR_66	23:54 (12.4.2024)	0:08(13.4.2024)	0:14 hrs	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1945	13-Apr-24	HASSAN	TRANSFORMER	66	HV4	BALEHONNUR_66	15:41	15:51	00:10	TRIPPED ON FAULT
1946	13-Apr-24	HASSAN	TRANSFORMER	66	Lv1	HNPURA_220	18:10	20:01	01:51	MAIN SUPPLY FAILURE
1947	13-Apr-24	HASSAN	TRANSFORMER	66	Lv2	HNPURA_220	18:10	20:04	01:54	MAIN SUPPLY FAILURE
1948	13-Apr-24	HASSAN	TRANSFORMER	110	HV1	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1949	13-Apr-24	HASSAN	TRANSFORMER	110	HV1	ANAVATTI_110	09:05	11:00	01:55	LINE CLEAR AVAIED
1950	13-Apr-24	HASSAN	TRANSFORMER	110	HV1	KEMAR_220	18:26	19:05	00:39	MAIN SUPPLY FAILURE
1951	13-Apr-24	HASSAN	TRANSFORMER	110	HV1	VITTALA_110	20:37	20:57	00:20	MAIN SUPPLY FAILURE
1952	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1953	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1954	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	MSEZ_220	18:26	19:30	01:04	MAIN SUPPLY FAILURE
1955	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	ANAVATTI_110	17:38	19:24	01:46	TRIPPED ON FAULT
1956	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	ANAVATTI_110	21:00	21:22	00:22	LINE CLEAR AVAIED
1957	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	KEMAR_220	18:26	19:17	00:51	MAIN SUPPLY FAILURE
1958	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	KONAJE_110	18:26	19:21	00:55	MAIN SUPPLY FAILURE
1959	13-Apr-24	HASSAN	TRANSFORMER	110	HV2	VITTALA_110	20:37	20:57	00:20	MAIN SUPPLY FAILURE
1960	13-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	18:20	18:50	00:30	TRIPPED ON FAULT
1961	13-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	19:15	19:55	00:40	TRIPPED ON FAULT
1962	13-Apr-24	HASSAN	TRANSFORMER	110	LV1	KEMAR_220	14:51	14:58	00:07	TRIPPED ON FAULT
1963	13-Apr-24	HASSAN	TRANSFORMER	110	LV1	KEMAR_220	18:26	19:04	00:38	MAIN SUPPLY FAILURE
1964	13-Apr-24	HASSAN	TRANSFORMER	110	LV2	KEMAR_220	18:26	19:12	00:46	MAIN SUPPLY FAILURE
1965	13-Apr-24	HASSAN	TRANSFORMER	110	LV3	KEMAR_220	18:26	19:24	00:58	MAIN SUPPLY FAILURE
1966	13-Apr-24	HASSAN	TRANSFORMER	220	HV1	HNPURA_220	18:10	20:00	01:50	MAIN SUPPLY FAILURE
1967	13-Apr-24	HASSAN	TRANSFORMER	220	HV1	MSEZ_220	18:26	19:20	00:54	MAIN SUPPLY FAILURE
1968	13-Apr-24	HASSAN	TRANSFORMER	220	HV1	KEMAR_220	18:26	19:03	00:37	MAIN SUPPLY FAILURE
1969	13-Apr-24	HASSAN	TRANSFORMER	220	HV2	HEGGUNJE_220	14:30	15:00	00:30	LINE CLEAR AVAIED
1970	13-Apr-24	HASSAN	TRANSFORMER	220	HV2	HNPURA_220	18:10	20:10	02:00	MAIN SUPPLY FAILURE
1971	13-Apr-24	HASSAN	TRANSFORMER	220	HV2	HNPURA_220	18:10	20:00	01:50	MAIN SUPPLY FAILURE
1972	13-Apr-24	HASSAN	TRANSFORMER	220	HV2	MSEZ_220	18:26	19:20	00:54	MAIN SUPPLY FAILURE
1973	13-Apr-24	HASSAN	TRANSFORMER	220	HV2	KEMAR_220	18:26	19:11	00:45	MAIN SUPPLY FAILURE
1974	13-Apr-24	HASSAN	TRANSFORMER	220	HV3	KEMAR_220	18:26	19:17	00:51	MAIN SUPPLY FAILURE
1975	13-Apr-24	MYSORE	LINE	66	AJJIPURA-COWDALLI	COWDALLI_66 RAMAPURA_66 MARTHALLI_66	23:10	23:25	00:15	TRIPPED ON FAULT
1976	13-Apr-24	MYSORE	LINE	66	BEGUR 220-SANTHESARGUR	SANTHESARGUR_66 CHANDRAWADI-66 HURA_66 YEREHALLI HAND POST_66 HDKOTE_66 ANTARSANTHE_66 HAMAPAPURA_66	16:01	16:08	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1977	13-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
1978	13-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1979	13-Apr-24	MYSORE	LINE	66	KOTTANUR-DODDINDUVADI	DODDINDUVADI_66	06:21	06:39	00:18	TRIPPED ON FAULT
1980	13-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
1981	13-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-DODDINDUVADI	DODDINDUVADI_66	06:21	06:36	00:15	TRIPPED ON FAULT
1982	13-Apr-24	MYSORE	LINE	66	MAMBALLI-YELANDUR	YELANDUR_66	18:55	19:00	00:05	TRIPPED ON FAULT
1983	13-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	16:23	22:02	05:39	LINE CLEAR AVAILED
1984	13-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:47:00 (13/4/2024)			TRIPPED ON FAULT
1985	13-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:13 (12/04/2024)	7:58:00 (13/4/2024)	11:44:24	TRIPPED ON FAULT
1986	13-Apr-24	MYSORE	LINE	220	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	18:10	19:47	01:37	TRIPPED ON FAULT
1987	13-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDGERE_66	18:10	20:20	02:10	LINE CLEAR AVAILED
1988	13-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1989	13-Apr-24	MYSORE	TRANSFORMER	66	HV2	HDKOTE_66	10:09	10:22	00:13	TRIPPED ON FAULT
1990	13-Apr-24	TUMKUR	LINE	66	400KV GUTTUR-220KV DAVANGERE LINE 1	DAVANGERE_220	10:27	13:45	03:18	LINE CLEAR AVAILED
1991	13-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-CHITRADURGA 3	CHITRADURGA_220	11:11 (13.4.24)		-	TRIPPED ON FAULT
1992	13-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV-CHITRADURGA 1,3 & 4	PANDRAHALLI_66, HD PURA,CHITRAHALLI, HOLALKERE, MALLAPPANAHALLI, JAGALURU, BIDARIKERE, TURUEKERE	23:10	23:38	00:28	TRIPPED ON FAULT
1993	13-Apr-24	TUMKUR	LINE	66	HANAGAL - NAGASAMUDRA_66	NAGASAMUDRA_66, RAMPURA	18:40	19:05	00:25	TRIPPED ON FAULT
1994	13-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-P R PURA	HARIAYABBE,P.D KOTE	08:00	14:00	06:00	LINE CLEAR AVAILED
1995	13-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-THALLAK	KALAMARANAHALLI_66, THALLAK_66,RANGENAHALLI_66	08:00	14:00	06:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1996	13-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	12:18	12:28	00:10	TRIPPED ON FAULT
1997	13-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NALLUR_66	NALLUR_66, BASAVAPATNA, TYVANAGI	13:00	13:10	00:10	TRIPPED ON FAULT
1998	13-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	16:37	17:07	00:30	TRIPPED ON FAULT
1999	13-Apr-24	TUMKUR	LINE	66	MALLAPANAHALLI_66-JN KOTE_66	MALLAPPANAHALLI_66, JN KOTE	17:01	17:25	00:24	TRIPPED ON FAULT
2000	13-Apr-24	TUMKUR	LINE	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	08:35	11:30	02:55	LINE CLEAR AVAILED
2001	13-Apr-24	TUMKUR	LINE	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	07:01	08:35	01:34	TRIPPED ON FAULT
2002	13-Apr-24	TUMKUR	LINE	220	GUTUR_400-NEELAGUNDA	GUTTUR_220	06:03	12:12	06:09	TRIPPED ON FAULT
2003	13-Apr-24	TUMKUR	LINE	220	SIRA220-GOWRIBIDANUR220 LINE 1	SIRA_220	13:20	17:20	04:00	LINE CLEAR AVAILED
2004	13-Apr-24	TUMKUR	LINE	220	SIRA220-GOWRIBIDANUR220 LINE 1	SIRA_220	17:20	19:32	02:12	LINE CLEAR AVAILED
2005	13-Apr-24	TUMKUR	LINE	220	SIRA220-GOWRIBIDANUR220 LINE 2	SIRA_220	12:37	13:33	00:56	TRIPPED ON FAULT
2006	13-Apr-24	TUMKUR	LINE	220	SIRA220-GOWRIBIDANUR220 LINE 2	SIRA_220	17:20	19:33	02:13	LINE CLEAR AVAILED
2007	13-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- GUDDADAHALLI	GUDDADAHALLI_400	14:56	17:27	02:31	TRIPPED ON FAULT
2008	13-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- RTPS	GUTTUR_400	5:27 (13.4.24)		-	TRIPPED ON FAULT
2009	13-Apr-24	TUMKUR	TRANSFORMER	66	TR-1&2	CHITRADURGA_220	23:10	23:21	00:11	TRIPPED ON FAULT
2010	13-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KIADB_220	12:08	12:18	00:10	TRIPPED ON FAULT
2011	13-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KIADB_220	12:23	12:45	00:22	TRIPPED ON FAULT
2012	13-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	KIADB_220	12:45	16:02	03:17	LINE CLEAR AVAILED
2013	14-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2014	14-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
2015	14-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2016	14-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2017	14-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
2018	14-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2019	14-Apr-24	BAGALKOTE	LINE	110	MAHALINGAPUR220- RABAKAVI	MAHALINGAPUR_220	12:05	19:31	07:26	TRIPPED ON FAULT
2020	14-Apr-24	BAGALKOTE	LINE	110	MK HUBLI220- KITTUR	MK HUBLI_220	00:50	01:15	00:25	TRIPPED ON FAULT
2021	14-Apr-24	BAGALKOTE	LINE	110	MK HUBLI220- KITTUR	MK HUBLI_220	04:55	06:05	01:10	TRIPPED ON FAULT
2022	14-Apr-24	BAGALKOTE	LINE	110	MK HUBLI220- MK HUBLI2	MK HUBLI_220	04:55	09:05	04:10	TRIPPED ON FAULT
2023	14-Apr-24	BAGALKOTE	LINE	110	MK HUBLI220-MK HUBLI2	MK HUBLI_220	04:55	09:05	04:10	TRIPPED ON FAULT
2024	14-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2025	14-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2026	14-Apr-24	BAGALKOTE	LINE	110	RON- HIREHAL	RON_110	06:01	06:37	00:36	TRIPPED ON FAULT
2027	14-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- KATARKI	VAJRAMATTI_220	05:47	06:06	00:19	TRIPPED ON FAULT
2028	14-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2029	14-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR1	VAJRAMATTI_220	10:20	10:27	00:07	TRIPPED ON FAULT
2030	14-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR1	VAJRAMATTI_220	10:45	10:55	00:10	TRIPPED ON FAULT
2031	14-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR2	VAJRAMATTI_220	21:49 (12.04.2024)	12:03 (14.04.2024)		LINE CLEAR AVAILED
2032	14-Apr-24	BAGALKOTE	LINE	220	HAVERI- GUTTUR1	HAVERI_220	6:59 (14.04.2024)			LINE CLEAR AVAILED
2033	14-Apr-24	BAGALKOTE	LINE	220	HUBLI- NARENDRA2	HUBLI_220	13:40	18:08	04:28	TRIPPED ON FAULT
2034	14-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2035	14-Apr-24	BENGALURU	LINE	66	66KV ANEKAL - SAMANDURU	SAMANDURU, ATTIBELE	10:08	10:20	00:12	LINE CLEAR AVAILED
2036	14-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2037	14-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	12:52	13:04	00:12	TRIPPED ON FAULT
2038	14-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220- DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	00:14	00:18	00:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2039	14-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	10:00	10:33	00:33	TRIPPED ON FAULT
2040	14-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - POTTERY ROAD MUSS	POTTERY ROAD	04:55	05:02	00:07	LINE CLEAR AVAILED
2041	14-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	SADALI	06:40	06:50	00:10	LINE CLEAR AVAILED
2042	14-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	03:24	03:42	00:18	TRIPPED ON FAULT
2043	14-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - SANJEEVANADODDI	NO STATION AFFECTED	17:43	23:59	06:16	TRIPPED ON FAULT
2044	14-Apr-24	BENGALURU	LINE	66	66KV SURYA CITY - ANEKAL 1	SURYANAGAR	18:20	18:31:00	00:11	LINE CLEAR AVAILED
2045	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	14:48	14:57	00:09	MAIN SUPPLY FAILURE
2046	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - BWSSB 1	BWSSB 1	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2047	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - BWSSB 2	BWSSB 2	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2048	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - BWSSB 3	BWSSB 3	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2049	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - BWSSB 4	BWSSB 4	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2050	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	14:48	14:56	00:08	MAIN SUPPLY FAILURE
2051	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	08:41	10:16	01:35	LINE CLEAR AVAILED
2052	14-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETTAMBADI, K HONALGERE	14:48	14:57	00:09	MAIN SUPPLY FAILURE
2053	14-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	00:22	00:32	00:10	LINE CLEAR AVAILED
2054	14-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	00:22	00:32	00:10	LINE CLEAR AVAILED
2055	14-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	00:20	00:23	00:03	LINE CLEAR AVAILED
2056	14-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
2057	14-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 200 - SURYA CITY	SURYANAGAR, ANEKAL	10:10	10:16	00:06	LINE CLEAR AVAILED
2058	14-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 200 - SURYA CITY	SURYANAGAR, ANEKAL	11:10	11:20	00:10	LINE CLEAR AVAILED
2059	14-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	10:10	10:18	00:08	LINE CLEAR AVAILED
2060	14-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	10:12	10:16	00:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2061	14-Apr-24	BENGALURU	LINE	66	TK HALLI 220 - HEBBANI	NO STATION AFFECTED	14:48	14:57	00:09	TRIPPED ON FAULT
2062	14-Apr-24	BENGALURU	LINE	66	TK HALLI 220 - MANDYA 1	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMBERE	14:48	14:57	00:09	MAIN SUPPLY FAILURE
2063	14-Apr-24	BENGALURU	LINE	66	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMBERE	14:48	14:57	00:09	MAIN SUPPLY FAILURE
2064	14-Apr-24	BENGALURU	LINE	220	220KV TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	14:48	14:53	00:05	TRIPPED ON FAULT
2065	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	M GOLLAHALLI	00:00	00:30	00:30	TRIPPED ON FAULT
2066	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HONNIGANAHALLI	10:03	10:13	00:10	LINE CLEAR AVOIDED
2067	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSPALYA CIRLCE	10:50	11:00	00:10	LINE CLEAR AVOIDED
2068	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TYAMAGONDLU	03:30	03:40	00:10	TRIPPED ON FAULT
2069	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TK HALLI 220	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2070	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA I/A	16:30	16:35	00:05	LINE CLEAR AVOIDED
2071	14-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	08:50	08:58	00:08	LINE CLEAR AVOIDED
2072	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BTM 4TH PHASE	05:20	05:29	00:09	TRIPPED ON FAULT
2073	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TUBAGERE	11:30	12:10	00:40	LINE CLEAR AVOIDED
2074	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BUDIKOTE	15:20	15:45	00:25	TRIPPED ON FAULT
2075	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HONNIGANAHALLI	10:13	10:23	00:10	LINE CLEAR AVOIDED
2076	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TK HALLI 220	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2077	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YARANDANAHALLI 220	10:12	10:16	00:04	LINE CLEAR AVOIDED
2078	14-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YARANDANAHALLI 220	19:10	19:15	00:05	LINE CLEAR AVOIDED
2079	14-Apr-24	BENGALURU	TRANSFORMER	220	HV1	TK HALLI 220	14:48	14:53	00:05	MAIN SUPPLY FAILURE
2080	14-Apr-24	BENGALURU	TRANSFORMER	220	HV2	TK HALLI 220	14:48	14:55	00:07	MAIN SUPPLY FAILURE
2081	14-Apr-24	BENGALURU	TRANSFORMER	220	HV3	TK HALLI 220	14:48	14:56	00:08	MAIN SUPPLY FAILURE
2082	14-Apr-2024	GULBARGA	LINE	66	ITTAGI-CJ HALLI	CJ HALLI_66, HOSAHALLI_66, HUDEM_66	11:45	11:55	00:10	TRIPPED ON FAULT
2083	14-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	17:48(13.04.2024)	7:56(14.04.2024)	14:08	TRIPPED ON FAULT
2084	14-Apr-2024	GULBARGA	LINE	110	MALLAT-KAVITAL1	KAVITAL_110	01:30	01:42	00:12	TRIPPED ON FAULT
2085	14-Apr-2024	GULBARGA	LINE	110	MALLAT-KAVITAL2	KAVITAL_110	02:23	02:33	00:10	TRIPPED ON FAULT
2086	14-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	BANAVEKAL_66	10:20	13:40	03:20	LINE CLEAR AVOIDED
2087	14-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)			TRIPPED ON FAULT
2088	14-Apr-2024	GULBARGA	TRANSFORMER	110	LV2	RAICHUR_220	14:42	16:51	02:09	LINE CLEAR AVOIDED
2089	14-Apr-24	HASSAN	LINE	66	BAGUR-RAMAPUR	BAGUR_66	13:36	13:54	00:18	TRIPPED ON FAULT
2090	14-Apr-24	HASSAN	LINE	66	BAGUR-RAMAPUR	BAGUR_66	13:36	13:54	00:18	TRIPPED ON FAULT
2091	14-Apr-24	HASSAN	LINE	110	ARSK2-BNVARA	ARSIKERE_220	00:45	00:56	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2092	14-Apr-24	HASSAN	LINE	110	HULICA-HSNGD	HULICAL_110	16:22	16:36	00:14	TRIPPED ON FAULT
2093	14-Apr-24	HASSAN	LINE	110	LPH-LST4	gen_lph	19:17 (13.04.2024)			LINE CLEAR AVAILED
2094	14-Apr-24	HASSAN	LINE	110	MRSSHM-BADRAVATY1	MRSMSG_220	08:18	14:14	05:56	LINE CLEAR AVAILED
2095	14-Apr-24	HASSAN	LINE	110	MRSSHM-BADRAVATY2	MRSMSG_220	08:18	14:14	05:56	LINE CLEAR AVAILED
2096	14-Apr-24	HASSAN	LINE	110	SAGARA-LST4	SAGARA_110	11:40	18:45	07:05	LINE CLEAR AVAILED
2097	14-Apr-24	HASSAN	LINE	110	SAGARA-TAL	SAGARA_110	18:55	19:16	00:21	TRIPPED ON FAULT
2098	14-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMSG_220	19:17(13.04.2024)	11:10 (14.04.2024)	15:52 hrs	LINE CLEAR AVAILED
2099	14-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA1	gen_sharavathy	19:16(13.04.2024)	18:53(14.04.2024)	23:26 hrs	LINE CLEAR AVAILED
2100	14-Apr-24	HASSAN	LINE	220	TALAGU-SGS1	TALAGUPPA_400	19:16(13.04.2024)	18:53(14.04.2024)	23:26 hrs	LINE CLEAR AVAILED
2101	14-Apr-24	HASSAN	TRANSFORMER	66	HV1	KANDLI_66	08:00	08:09	00:09	TRIPPED ON FAULT
2102	14-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	10:26	10:37	00:11	MAIN SUPPLY FAILURE
2103	14-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_66	12:30	14:02	01:32	LINE CLEAR AVAILED
2104	14-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	10:26	10:37	00:11	MAIN SUPPLY FAILURE
2105	14-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	18:55	19:00	00:05	TRIPPED ON FAULT
2106	14-Apr-24	MYSORE	LINE	66	BEGUR 220-SARAGUR	ANTHARSANTHE_66 CHANDRAVADI_66 HDKOTE_66 HURA_66 SANTHESARAGUR_66 YERALLI HAND POST_66	12:44	12:48	00:04	TRIPPED ON FAULT
2107	14-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
2108	14-Apr-24	MYSORE	LINE	66	JAIPURA-HAMPAPURA(K)	HAMPAPURA(K)_66	12:43	12:57	00:14	TRIPPED ON FAULT
2109	14-Apr-24	MYSORE	LINE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, GOLLUR_66, SUTTUR_66	13:53	14:30	00:37	TRIPPED ON FAULT
2110	14-Apr-24	MYSORE	LINE	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66, GOLLUR_66, SUTTUR_66	23:35	23:41	00:05	TRIPPED ON FAULT
2111	14-Apr-24	MYSORE	LINE	66	KM DODDI-MANDYA	KIADBMANDYA_66, KOLKARANADODDI_66, TUMBEKERE_66	13:33	13:38	00:04	TRIPPED ON FAULT
2112	14-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2113	14-Apr-24	MYSORE	LINE	66	KUSHALANAGARA 220-MADIKERI	MADIKERI_66	13:51	13:58	00:07	TRIPPED ON FAULT
2114	14-Apr-24	MYSORE	LINE	66	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	13:51	14:00	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2115	14-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
2116	14-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	08:44	11:33	02:48	LINE CLEAR AVAILED
2117	14-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	14:26	21:59	07:33	LINE CLEAR AVAILED
2118	14-Apr-24	MYSORE	LINE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	13:50	13:59	00:09	TRIPPED ON FAULT
2119	14-Apr-24	MYSORE	LINE	66	THALAGAVADI-MANDYA	KIADBMANDYA_66, KOLKARANADODDI_66, TUMBEKERE_66	13:32	13:37	00:05	TRIPPED ON FAULT
2120	14-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48 (14/04/2024)			TRIPPED ON FAULT
2121	14-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:47:00 (13/4/2024)	7:53 (14/04/2024)	11:06 HRs	TRIPPED ON FAULT
2122	14-Apr-24	MYSORE	LINE	220	VAJMANGALA-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, K_HONNALGERE_66 TALAGAVADI_66 TUMBEKERE_66 YETHAMBADI_66	14:48	14:55	00:07	TRIPPED ON FAULT
2123	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	KIADBMANDYA_66	14:47	14:56	00:09	MAIN SUPPLY FAILURE
2124	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	KMDODDI_66	14:46	14:58	00:12	MAIN SUPPLY FAILURE
2125	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	KOLKARANADODDI_66	14:49	15:05	00:15	MAIN SUPPLY FAILURE
2126	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	SHIVALLY_66	09:06	09:50	00:44	LINE CLEAR AVAILED
2127	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	SRIRANGAPATNA_66	10:10	10:50	00:40	LINE CLEAR AVAILED
2128	14-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2129	14-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	05:39	05:46	00:07	TRIPPED ON FAULT
2130	14-Apr-24	MYSORE	TRANSFORMER	66	HV2	KIADBMANDYA_66	14:47	14:56	00:09	MAIN SUPPLY FAILURE
2131	14-Apr-24	MYSORE	TRANSFORMER	66	HV2	KMDODDI_66	14:46	14:58	00:12	MAIN SUPPLY FAILURE
2132	14-Apr-24	MYSORE	TRANSFORMER	66	HV2	KOLKARANADODDI_66	14:49	15:05	00:15	MAIN SUPPLY FAILURE
2133	14-Apr-24	MYSORE	TRANSFORMER	66	HV2	THANDYA_66	13:55	14:35	00:40	TRIPPED ON FAULT
2134	14-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	11:06	11:36	00:30	TRIPPED ON FAULT
2135	14-Apr-24	TUMKUR	LINE	66	BILCHODU-SOKKE	BILCHODU_66, PALLAGATTE_66, SOKKE_66	08:00	08:05	00:05	MAIN SUPPLY FAILURE
2136	14-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-CHITRADURGA 1,2 &4	CHITRADURGA_220	15:55	17:59	02:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2137	14-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-CHITRADURGA 3	CHITRADURGA_220	11:11 (13.4.24)	17:34 (14.4.24)	1 day 6:23 hrs	TRIPPED ON FAULT
2138	14-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66	15:30	17:40	02:10	LINE CLEAR AVAILED
2139	14-Apr-24	TUMKUR	LINE	66	HANAGAL- THALLAK_661&2	HANGAL_66, NAGASAMUDRA, RAMPURA	11:45	11:51	00:06	TRIPPED ON FAULT
2140	14-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-P R PURA	HARIAYABBE,P.D KOTE	08:00	15:00	07:00	LINE CLEAR AVAILED
2141	14-Apr-24	TUMKUR	LINE	66	HIRIYUR 220-THALLAK	KALAMARANAHALLI_66, THALLAK_66,RANGENA HALLI_66	08:00	15:00	07:00	LINE CLEAR AVAILED
2142	14-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	16:37	17:07	00:30	TRIPPED ON FAULT
2143	14-Apr-24	TUMKUR	LINE	66	PANDARAHALLI- CHITRADURGA 2	HOLALKERE_66, HIREGUNTANURU	15:30	15:36	00:06	TRIPPED ON FAULT
2144	14-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- RTPS	GUTTUR_400	5:27 (13.4.24)	14:45 (14.4.24)	1day 9:18 hrs	TRIPPED ON FAULT
2145	15-Apr-24	BAGALKOTE	LINE	110	ATHANI220- AIGALI	ATHANI_220	05:57	06:10	00:13	TRIPPED ON FAULT
2146	15-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2147	15-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
2148	15-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2149	15-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	04:29	11:41	07:12	TRIPPED ON FAULT
2150	15-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2151	15-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
2152	15-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2153	15-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MK HUBLI2	MK HUBLI_220	04:55	09:05	04:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2154	15-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAIED
2155	15-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- NAGNUR	MUGALKHOD_220	08:04	10:51	02:47	LINE CLEAR AVAIED
2156	15-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	04:55	04:56	00:01	LINE CLEAR AVAIED
2157	15-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	13:02	13:03	00:01	LINE CLEAR AVAIED
2158	15-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- SULTANPUR	MUGALKHOD_220	10:15	13:07	02:52	LINE CLEAR AVAIED
2159	15-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAIED
2160	15-Apr-24	BAGALKOTE	LINE	110	SADALAGA-VPPL	SADALAGA_110	09:20	17:45	08:25	LINE CLEAR AVAIED
2161	15-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAIED
2162	15-Apr-24	BAGALKOTE	LINE	220	AMBEWADI- PONDA1	AMBEWADI_220	07:49	12:07	04:18	TRIPPED ON FAULT
2163	15-Apr-24	BAGALKOTE	LINE	220	HAVERI- GUTTUR1	HAVERI_220	6:59 (14.04.2024)			LINE CLEAR AVAIED
2164	15-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI2	HUBLI_220	13:30	18:09	04:39	TRIPPED ON FAULT
2165	15-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAIED
2166	15-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	MUGALKHOD_220	09:56	11:36	01:40	LINE CLEAR AVAIED
2167	15-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	VAJRAMATTI_220	18:03	19:47	01:44	LINE CLEAR AVAIED
2168	15-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	CHIKKODI_220	10:38	13:35	02:57	LINE CLEAR AVAIED
2169	15-Apr-24	BENGALURU	LINE	66	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	17:13	17:16	00:03	LINE CLEAR AVAIED
2170	15-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2171	15-Apr-24	BENGALURU	LINE	66	66KV DG2 PUTTENAHALLI 220 - SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	13:59	14:01	00:02	LINE CLEAR AVAIED
2172	15-Apr-24	BENGALURU	LINE	66	66KV DG2 PUTTENAHALLI 220 - SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	17:34	17:44	00:10	TRIPPED ON FAULT
2173	15-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	15:35	15:57	00:22	TRIPPED ON FAULT
2174	15-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	06:32	06:42	00:10	TRIPPED ON FAULT
2175	15-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	16:54	17:16	00:22	MAIN SUPPLY FAILURE
2176	15-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	JADIGENAHALLI	16:54	17:16	00:22	MAIN SUPPLY FAILURE
2177	15-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	16:54	17:16	00:22	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2178	15-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	06:07	06:21	00:14	TRIPPED ON FAULT
2179	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	16:53	17:25	00:32	MAIN SUPPLY FAILURE
2180	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	17:04	17:22	00:18	MAIN SUPPLY FAILURE
2181	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	17:26	17:37	00:11	MAIN SUPPLY FAILURE
2182	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:53	17:26	00:33	MAIN SUPPLY FAILURE
2183	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:04	17:22	00:18	MAIN SUPPLY FAILURE
2184	15-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:26	17:36	00:10	MAIN SUPPLY FAILURE
2185	15-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
2186	15-Apr-24	BENGALURU	LINE	220	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 2	SARJAPURA 220	17:04	17:22	00:18	LINE CLEAR AVAILED
2187	15-Apr-24	BENGALURU	LINE	220	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 2	SARJAPURA 220	17:26	17:31	00:05	TRIPPED ON FAULT
2188	15-Apr-24	BENGALURU	LINE	400	220KV NELAMANGALA 400 - NITTUR	110KV GUBBI, 110KV BIDERE, 110KV KALLURU, 110KV KADABA, 110KV DODDGUNI, 110KV KG TEMPLE, 110KV UNGRA , 110KV SOMLAPURA, 110KV RAILWAYS.	17:51	18:20	00:29	TRIPPED ON FAULT
2189	15-Apr-24	BENGALURU	LINE	400	400KV NELAMANGALA 400 - DEVANAHALLI 400 GIS	NO STATION AFFECTED	13:28	17:46	04:18	TRIPPED ON FAULT
2190	15-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VIJAYANAGARA	11:45	13:16	01:31	LINE CLEAR AVAILED
2191	15-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HULLENAHALLI	08:25	09:05	00:40	LINE CLEAR AVAILED
2192	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KHB	06:29	06:40	00:11	TRIPPED ON FAULT
2193	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VIJAYANAGARA	11:45	13:16	01:31	LINE CLEAR AVAILED
2194	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ANNABEL(DLF)	00:12	00:20	00:08	TRIPPED ON FAULT
2195	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUNDAMGERE	17:50	18:20	00:30	LINE CLEAR AVAILED
2196	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUDIBANDE	15:15	16:15	01:00	LINE CLEAR AVAILED
2197	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	AVANI	14:00	14:20	00:20	LINE CLEAR AVAILED
2198	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SARJAPURA 220	16:25	17:33	01:08	LINE CLEAR AVAILED
2199	15-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SARJAPURA 220	17:04	17:22	00:18	MAIN SUPPLY FAILURE
2200	15-Apr-24	BENGALURU	TRANSFORMER	220	HV2	SARJAPURA 220	16:53	17:23	00:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2201	15-Apr-24	BENGALURU	TRANSFORMER	220	HV2	SARJAPURA 220	17:26	17:32	00:06	MAIN SUPPLY FAILURE
2202	15-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MALUR 220	16:54	17:16	00:22	TRIPPED ON FAULT
2203	15-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-TELAGI	TELAGI_66,KURBHAHALI_66,SHAMNUR SUGAR_IPP, GREEN INFR_IPP	11:00	11:25	00:25	LINE CLEAR AVAILED
2204	15-Apr-2024	GULBARGA	LINE	66	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBAJJIHALLI_66	19:40	19:45	00:05	TRIPPED ON FAULT
2205	15-Apr-2024	GULBARGA	LINE	110	ALIPUR-MUNIRABAD	KIADB_110,KUDITINI_110,AGARWAL_IPP,SHATAVAHANA_IPP,RBNS FACTORY, KAMALAPUR_110,TORANGALU_110,METRI_110, KURUGOD_110	12:46	13:59	01:13	LINE CLEAR AVAILED
2206	15-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-KPRL	LINGASUGUR_220	11:30	17:30	06:00	LINE CLEAR AVAILED
2207	15-Apr-2024	GULBARGA	LINE	110	RAICHUR-KURDICROSS	KURDICROSS_110	11:12	11:17	00:05	LINE CLEAR AVAILED
2208	15-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-YADGIR	YADGIR_110,KONKAL_110	04:33	04:41	00:08	TRIPPED ON FAULT
2209	15-Apr-2024	GULBARGA	LINE	110	WADI-YADGIR	WADI_110	01:05	01:09	00:04	LINE CLEAR AVAILED
2210	15-Apr-2024	GULBARGA	LINE	110	WADI-YADGIR	WADI_110	01:25	02:18	00:53	LINE CLEAR AVAILED
2211	15-Apr-2024	GULBARGA	LINE	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	17:38	22:20	04:42	LINE CLEAR AVAILED
2212	15-Apr-2024	GULBARGA	LINE	220	MALLAT-RTPS	MALLAT_220	08:34	09:13	00:39	TRIPPED ON FAULT
2213	15-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	17:51	21:10	03:19	TRIPPED ON FAULT
2214	15-Apr-2024	GULBARGA	LINE	220	SULEKAL-SINDHANOOR	SULEKAL_220	09:37	11:27	01:50	LINE CLEAR AVAILED
2215	15-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	BANAVEKAL_66	09:20	09:30	00:10	TRIPPED ON FAULT
2216	15-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)			TRIPPED ON FAULT
2217	15-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KURUGOD_110	07:55	08:05	00:10	TRIPPED ON FAULT
2218	15-Apr-24	HASSAN	LINE	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	18:25	19:15	00:50	LINE CLEAR AVAILED
2219	15-Apr-24	HASSAN	LINE	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	19:20	21:05	01:45	LINE CLEAR AVAILED
2220	15-Apr-24	HASSAN	LINE	66	ALDUR-JENUGADDE	ALDUR_66	18:25	19:45	01:20	LINE CLEAR AVAILED
2221	15-Apr-24	HASSAN	LINE	66	ALDUR-JENUGADDE	ALDUR_66	19:47	21:25	01:38	LINE CLEAR AVAILED
2222	15-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	gen_bhadra	12:25	12:32	00:07	TRIPPED ON FAULT
2223	15-Apr-24	HASSAN	LINE	66	CHIKKAMAGLUR	ALDUR_66	21:28 (15.4.2024)	13:05 (16.4.2024)		TRIPPED ON FAULT
2224	15-Apr-24	HASSAN	LINE	66	GORUR-HASSAN	GORUR_66	14:40	14:57	00:17	TRIPPED ON FAULT
2225	15-Apr-24	HASSAN	LINE	66	RAMNAT-BELVADI	RAMNATHPURA_66	22:00	22:10	00:10	TRIPPED ON FAULT
2226	15-Apr-24	HASSAN	LINE	66	SAKALE-IPCL1	SAKALESHPURA_66	10:05	13:46	03:41	LINE CLEAR AVAILED
2227	15-Apr-24	HASSAN	LINE	110	KADUR-NERELEKERE	KADUR_220	13:36	13:44	00:08	LINE CLEAR AVAILED
2228	15-Apr-24	HASSAN	LINE	110	KADUR-TNGL	KADUR_220	13:37	13:45	00:08	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2229	15-Apr-24	HASSAN	LINE	110	KADUR-YGTI	KADUR_220	13:36	13:44	00:08	LINE CLEAR AVAILED
2230	15-Apr-24	HASSAN	LINE	110	LPH-LST4	gen_lph	19:17 (13.04.2024)	10:29 (15.4.2024)	39:11 hrs	LINE CLEAR AVAILED
2231	15-Apr-24	HASSAN	LINE	110	SAGARA-ALKLA	SAGARA_110	20:05	20:45	00:40	MAIN SUPPLY FAILURE
2232	15-Apr-24	HASSAN	LINE	110	SAGARA-JST1	SAGARA_110	20:05 (15.04.2024)	12:00(16.04.2024)		TRIPPED ON FAULT
2233	15-Apr-24	HASSAN	LINE	110	SAGARA-JST2	SAGARA_110	20:05	20:55	00:50	MAIN SUPPLY FAILURE
2234	15-Apr-24	HASSAN	LINE	110	SAGARA-LST4	SAGARA_110	20:05	21:05	01:00	MAIN SUPPLY FAILURE
2235	15-Apr-24	HASSAN	LINE	110	SAGARA-SORABA	SAGARA_110	20:05	21:07	01:02	MAIN SUPPLY FAILURE
2236	15-Apr-24	HASSAN	LINE	110	SAGARA-SS2	SAGARA_110	20:05	21:04	00:59	MAIN SUPPLY FAILURE
2237	15-Apr-24	HASSAN	LINE	110	SAGARA-TAL	SAGARA_110	20:05	20:55	00:50	MAIN SUPPLY FAILURE
2238	15-Apr-24	HASSAN	LINE	220	MRSSHM-HSN4001	MRSMSG_220	13:58	15:59	02:01	TRIPPED ON FAULT
2239	15-Apr-24	HASSAN	LINE	220	TALAGU-SGS2	TALAGUPPA-400	10:41	12:01	01:20	LINE CLEAR AVAILED
2240	15-Apr-24	HASSAN	LINE	400	UPCL-HASSAN2	gen_upcl	13:01	19:51	06:50	TRIPPED ON FAULT
2241	15-Apr-24	HASSAN	TRANSFORMER	66	HV1	ALDUR_66	18:25 (15.4.2024)	16:35 (16.4.2024)		TRIPPED ON FAULT
2242	15-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_66	05:50	06:23	00:33	LINE CLEAR AVAILED
2243	15-Apr-24	HASSAN	TRANSFORMER	66	HV1	MALLIPATNA_66	01:26	01:44	00:18	TRIPPED ON FAULT
2244	15-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	22:02	22:10	00:08	MAIN SUPPLY FAILURE
2245	15-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMESHWARNAGARA_66	08:40	14:12	05:32	TRIPPED ON FAULT
2246	15-Apr-24	HASSAN	TRANSFORMER	66	HV2	ALDUR_66	19:10	21:10	02:00	LINE CLEAR AVAILED
2247	15-Apr-24	HASSAN	TRANSFORMER	66	HV2	HNPURA_66	05:50	06:23	00:33	LINE CLEAR AVAILED
2248	15-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	22:02	22:10	00:08	MAIN SUPPLY FAILURE
2249	15-Apr-24	HASSAN	TRANSFORMER	110	HV1	HALADY_110	11:24	11:36	00:12	LINE CLEAR AVAILED
2250	15-Apr-24	HASSAN	TRANSFORMER	110	HV1	KAVOOR_220	09:08	17:47	08:39	LINE CLEAR AVAILED
2251	15-Apr-24	HASSAN	TRANSFORMER	110	HV2	KARAYA_110	11:00	13:44	02:44	LINE CLEAR AVAILED
2252	15-Apr-24	HASSAN	TRANSFORMER	110	HV2	SORABA_110	08:41	09:11	00:30	TRIPPED ON FAULT
2253	15-Apr-24	HASSAN	TRANSFORMER	110	HV2	SORABA_110	10:06	10:39	00:33	TRIPPED ON FAULT
2254	15-Apr-24	MYSORE	LINE	66	220KV KUSHALNAGARA -MYSORE 1 MIRLE	MIRLE_66	04:33	04:46	00:13	TRIPPED ON FAULT
2255	15-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
2256	15-Apr-24	MYSORE	LINE	66	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	10:37	10:47	00:09	TRIPPED ON FAULT
2257	15-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2258	15-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2259	15-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36 (15/04/2024)			LINE CLEAR AVAILED
2260	15-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48 (14/04/2024)	7:04 (15/04/2024)	10:15	MAIN SUPPLY FAILURE
2261	15-Apr-24	MYSORE	TRANSFORMER	66	HV1	ANEGOLAL_66	10:40	13:30	02:50	LINE CLEAR AVAILED
2262	15-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2263	15-Apr-24	MYSORE	TRANSFORMER	66	HV2	CHANDAKAVADI_66	13:11	13:16	00:05	TRIPPED ON FAULT
2264	15-Apr-24	MYSORE	TRANSFORMER	66	HV2	CHUNCHUNKATTE_66	09:05	09:15	00:10	TRIPPED ON FAULT
2265	15-Apr-24	MYSORE	TRANSFORMER	66	HV2	DODDINADUVADI_66	12:10	12:29	00:19	TRIPPED ON FAULT
2266	15-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	21:13	21:19	00:06	TRIPPED ON FAULT
2267	15-Apr-24	MYSORE	TRANSFORMER	66	HV2	HDKOTE_66	13:12	13:25	00:12	TRIPPED ON FAULT
2268	15-Apr-24	MYSORE	TRANSFORMER	220	HV2	HUNSUR_220	17:14	17:38	00:24	LINE CLEAR AVAILED
2269	15-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHITRADURGA-2	CHITRADURGA_220	10:52	11:36	00:44	LINE CLEAR AVAILED
2270	15-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHITRADURGA-3	CHITRADURGA_220	11:55	12:25	00:30	LINE CLEAR AVAILED
2271	15-Apr-24	TUMKUR	LINE	66	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	12:28	12:42	00:14	TRIPPED ON FAULT
2272	15-Apr-24	TUMKUR	LINE	66	DYAVARANAHALLI- PR PURA	PR PURA_66	22:18	23:00	00:42	TRIPPED ON FAULT
2273	15-Apr-24	TUMKUR	LINE	66	KURUBARAHALLI- TELAGI	KURUBARAHALLI_66	11:00	11:25	00:25	MAIN SUPPLY FAILURE
2274	15-Apr-24	TUMKUR	LINE	66	SIRA66 - KALLAMBELLA	KALLAMBELLA_66	16:55	17:45	00:50	TRIPPED ON FAULT
2275	15-Apr-24	TUMKUR	LINE	66	SOKKE-JAGLUR	SOKKE_66	01:40	01:45	00:05	TRIPPED ON FAULT
2276	15-Apr-24	TUMKUR	LINE	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	17:45	17:51	00:06	LINE CLEAR AVAILED
2277	15-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI1	HONNALLI_220	13:54	14:13	00:19	TRIPPED ON FAULT
2278	15-Apr-24	TUMKUR	LINE	220	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	13:38	20:57	07:19	LINE CLEAR AVAILED
2279	15-Apr-24	TUMKUR	LINE	220	MADHUGIRI 220kV- HIRIYUR	MADHUGIRI_220	13:52	15:42	01:50	TRIPPED ON FAULT
2280	15-Apr-24	TUMKUR	LINE	220	NITTUR 220kV- NELAMANGALA	NITTUR_220, 110KV GUBBI, KALLURU, KADABA, K G TEMPLE, UNGRA, DODDAGUNI, SOMLAPURA, RAILWAY TRACTION	17:51	19:17	01:26	TRIPPED ON FAULT
2281	15-Apr-24	TUMKUR	TRANSFORMER	220	TR-2(HV SIDE)	KIADB_220	12:06	17:49	05:43	LINE CLEAR AVAILED
2282	16-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2283	16-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2284	16-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2285	16-Apr-24	BAGALKOTE	LINE	110	HALIYAL- ALNAVAR	HALIYAL_110	18:52	19:05	00:13	TRIPPED ON FAULT
2286	16-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2287	16-Apr-24	BAGALKOTE	LINE	110	KARWAR220-BINAGA	KARWAR_220	07:55	18:46	10:51	LINE CLEAR AVAILED
2288	16-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
2289	16-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2290	16-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2291	16-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2292	16-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2293	16-Apr-24	BAGALKOTE	LINE	220	HAVERI- GUTTUR1	HAVERI_220	6:59 (14.04.2024)	13:49 (16.04.2024)	54:50:00	LINE CLEAR AVAILED
2294	16-Apr-24	BAGALKOTE	LINE	220	KADRA - KARWAR1	KARWAR_220	11:20	15:18	03:58	LINE CLEAR AVAILED
2295	16-Apr-24	BAGALKOTE	LINE	220	KADRA - KARWAR2	KARWAR_220	15:31	18:04	02:33	LINE CLEAR AVAILED
2296	16-Apr-24	BAGALKOTE	LINE	220	KUDACHI- ATHANI	KUDACHI_220	19:50	20:25	00:35	TRIPPED ON FAULT
2297	16-Apr-24	BAGALKOTE	LINE	220	KUDACHI- CHIKKODI1	KUDACHI_220	19:50	20:15	00:25	TRIPPED ON FAULT
2298	16-Apr-24	BAGALKOTE	LINE	220	KUDACHI- CHIKKODI2	KUDACHI_220	19:50	20:20	00:30	TRIPPED ON FAULT
2299	16-Apr-24	BAGALKOTE	LINE	220	KUDACHI- MAHALINGAPUR	KUDACHI_220	19:50	20:30	00:40	TRIPPED ON FAULT
2300	16-Apr-24	BAGALKOTE	LINE	220	KUDACHI- SWR CHINCHALI	KUDACHI_220	19:50	20:30	00:40	TRIPPED ON FAULT
2301	16-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2302	16-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1&HV2(10MVA)	KUDACHI_220	19:50	20:17	00:27	TRIPPED ON FAULT
2303	16-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	RAIBAG_110	18:21 (16.04.2024)			TRIPPED ON FAULT
2304	16-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MUDHOL_110	18:38 (16.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2305	16-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	KUDACHI_220, MORAB_110, AINAPUR_110, YELPARAHATTI_110, KUDACHI_110, HARUGERI_110, UGARKHUD_110	19:50	20:17	00:27	TRIPPED ON FAULT
2306	16-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	KARWAR_220	12:51	18:33	05:42	LINE CLEAR AVAILED
2307	16-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	KUDACHI_220	19:50	20:17	00:27	TRIPPED ON FAULT
2308	16-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	KUDACHI_220	19:50	20:18	00:28	TRIPPED ON FAULT
2309	16-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	AVANI, MULBAGALU, ADITYA BIRLA SOLAR (IPP)	13:35	13:55	00:20	TRIPPED ON FAULT
2310	16-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI & BURDAGUNTE	18:36	19:04	00:28	TRIPPED ON FAULT
2311	16-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION EHT	13:04	14:57	01:53	LINE CLEAR AVAILED
2312	16-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - BIAL BEGUR 220	66KV PILLAGUMPA	07:28	07:50	00:22	TRIPPED ON FAULT
2313	16-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - BANASAWADI (ITI- HEBBAL-1)	BANASWADI HV2	13:40	14:15	00:35	LINE CLEAR AVAILED
2314	16-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - DRDO (EHT)	DRDO (EHT)	13:40	14:50	01:10	LINE CLEAR AVAILED
2315	16-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - POTTERY ROAD MUSS	POTTERY ROAD	13:40	14:28	00:48	LINE CLEAR AVAILED
2316	16-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	13:45	13:55	00:10	TRIPPED ON FAULT
2317	16-Apr-24	BENGALURU	LINE	66	66KV MALUR - LAKKUR	LAKKUR, DEVANGUNDI	14:41	14:55	00:14	MAIN SUPPLY FAILURE
2318	16-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	JADIGENAHALLI	14:41	14:55	00:14	MAIN SUPPLY FAILURE
2319	16-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - TEKAL - KGF 1	BUDIKOTE, THORALAKKI, TEKAL	14:41	14:55	00:14	MAIN SUPPLY FAILURE
2320	16-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI - SADALI	SADALI	11:35	11:48	00:13	LINE CLEAR AVAILED
2321	16-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	16:40	16:50	00:10	TRIPPED ON FAULT
2322	16-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADALI	SADALI	17:25	17:35	00:10	LINE CLEAR AVAILED
2323	16-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENIGADALE, CHELUR, CHAKAVELU	13:00	13:12	00:12	TRIPPED ON FAULT
2324	16-Apr-24	BENGALURU	LINE	66	66KV SOMENAHALLI - NALLIMARADANAHALLI	NALLIMARADAHALLI	15:50	16:05	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2325	16-Apr-24	BENGALURU	LINE	66	66KV T GOL1AHALLI 220 - THAYALUR	TAYALUR,M.N HALLI, N.G HULKUR	09:41	09:56	00:15	TRIPPED ON FAULT
2326	16-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHAKAVELU, CHELUR	11:30	11:35	00:05	LINE CLEAR AVAILED
2327	16-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHAKAVELU, CHELUR	14:35	14:40	00:05	LINE CLEAR AVAILED
2328	16-Apr-24	BENGALURU	LINE	220	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	14:40	15:24	00:44	TRIPPED ON FAULT
2329	16-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MANCHENAHALLI	03:30	03:45	00:15	TRIPPED ON FAULT
2330	16-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TAVAREKERE	14:11	14:14	00:03	LINE CLEAR AVAILED
2331	16-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TYAMAGONDLU	04:30	04:40	00:10	TRIPPED ON FAULT
2332	16-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TYAMAGONDLU	17:00	17:10	00:10	TRIPPED ON FAULT
2333	16-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA I/A	18:12	18:25	00:13	TRIPPED ON FAULT
2334	16-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KHODAYS 220	12:30	12:34	00:04	TRIPPED ON FAULT
2335	16-Apr-24	BENGALURU	TRANSFORMER	66	HV2	LAKSHMIPURA	00:05	00:55	00:50	LINE CLEAR AVAILED
2336	16-Apr-24	BENGALURU	TRANSFORMER	66	HV3	IGGALUR	01:08	01:14	00:06	TRIPPED ON FAULT
2337	16-Apr-24	BENGALURU	TRANSFORMER	220	HV1	MALUR 220	14:41	14:55	00:14	TRIPPED ON FAULT
2338	16-Apr-24	BENGALURU	TRANSFORMER	220	LV1	MALUR 220	14:41	14:55	00:14	TRIPPED ON FAULT
2339	16-Apr-2024	GULBARGA	LINE	66	ITTAGI-CJ HALLI	CJ HALLI_66, HOSAHALLI_66, HUDEM_66	17:45	19:35	01:50	LINE CLEAR AVAILED
2340	16-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI 2	HIREHADAGALI_66, SOVENHALLI_66	11:05	16:20	05:15	LINE CLEAR AVAILED
2341	16-Apr-2024	GULBARGA	LINE	66	KUDALGI-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66	07:10	19:25	12:15	LINE CLEAR AVAILED
2342	16-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-MOKA	MOKA_110,PDHALLI_110,SOMASAMUNDRA_110,BISIHALLI_110	06:11	07:16	01:05	LINE CLEAR AVAILED
2343	16-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-MOKA	MOKA_110,PDHALLI_110,SOMASAMUNDRA_110,BISIHALLI_110	18:50	20:10	01:20	LINE CLEAR AVAILED
2344	16-Apr-2024	GULBARGA	LINE	110	DEVAPUR-SHORAPUR	SHORAPUR_110	03:02	03:06	00:04	TRIPPED ON FAULT
2345	16-Apr-2024	GULBARGA	LINE	110	KALBURGI SOUTH-SOUTH UNIVERSITY1	GULBARGA UNIVERSITY_110, NANDOOR_110	06:20	06:50	00:30	TRIPPED ON FAULT
2346	16-Apr-2024	GULBARGA	LINE	110	KANAKAGIRI-NAVALI	NAVALI_110	22:45	23:15	00:30	TRIPPED ON FAULT
2347	16-Apr-2024	GULBARGA	LINE	110	KAPNOOR-WEST2	KALBURGI WEST_110	07:31	09:15	01:44	LINE CLEAR AVAILED
2348	16-Apr-2024	GULBARGA	LINE	110	KAPNOOR-WEST2	KALBURGI WEST_110	17:10	18:30	01:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2349	16-Apr-2024	GULBARGA	LINE	110	PDHALLI-BELLARY NORTH	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,JANAKI_IPP ,BASAI_IPP, MOURYA SALEEM SOLAR_IPP	06:10	20:12	14:02	LINE CLEAR AVAILED
2350	16-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-NIRLOOTI	NIRLOOTI_IPP	18:28	18:38	00:10	TRIPPED ON FAULT
2351	16-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SINDHANOOR 1& 2	SINDHANOOR_110	18:30	18:40	00:10	TRIPPED ON FAULT
2352	16-Apr-2024	GULBARGA	LINE	110	UNIVERSITY(NANDOOR)-SHAHBAD	NANDOOR_110	05:35	06:42	01:07	TRIPPED ON FAULT
2353	16-Apr-2024	GULBARGA	LINE	110	UNIVERSITY(NANDOOR)-SHAHBAD	NANDOOR_110	06:42	10:34	03:52	LINE CLEAR AVAILED
2354	16-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-BASAVAN BAGEWADI2	LINGASUGUR_220	17:22	18:55	01:33	LINE CLEAR AVAILED
2355	16-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GUGAL_110	12:15	12:25	00:10	TRIPPED ON FAULT
2356	16-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)			TRIPPED ON FAULT
2357	16-Apr-24	HASSAN	LINE	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	21:28 (15.4.2024)	13:05 (16.4.2024)	15:36 hrs	TRIPPED ON FAULT
2358	16-Apr-24	HASSAN	LINE	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	14:40	15:05	00:25	LINE CLEAR AVAILED
2359	16-Apr-24	HASSAN	LINE	66	ALDUR-JENUGADDE	ALDUR_66	08:50	09:20	00:30	LINE CLEAR AVAILED
2360	16-Apr-24	HASSAN	LINE	66	ALDUR-JENUGADDE	ALDUR_66	11:25	13:00	01:35	LINE CLEAR AVAILED
2361	16-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	20:26	20:32	00:06	TRIPPED ON FAULT
2362	16-Apr-24	HASSAN	LINE	66	HASSN22-SKPURA	HASSAN_220	10:13	10:30	00:17	TRIPPED ON FAULT
2363	16-Apr-24	HASSAN	LINE	66	KANDLI-SAKLESHPUR	KANDLI_66	10:13	10:33	00:20	TRIPPED ON FAULT
2364	16-Apr-24	HASSAN	LINE	66	SAKALE-HANBAL	SAKALESHPUR_66	09:05	09:15	00:10	TRIPPED ON FAULT
2365	16-Apr-24	HASSAN	LINE	66	SAKALE-HASSAN	SAKALESHPUR_66	10:13	10:35	00:22	TRIPPED ON FAULT
2366	16-Apr-24	HASSAN	LINE	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	08:15	09:11	00:56	LINE CLEAR AVAILED
2367	16-Apr-24	HASSAN	LINE	110	BAIKAM-KAVOOR	BAIKAMPADY_110	14:00	14:05	00:05	LINE CLEAR AVAILED
2368	16-Apr-24	HASSAN	LINE	110	BANTWA-SALATTUR	BANTWAL_110	09:46	13:24	03:38	LINE CLEAR AVAILED
2369	16-Apr-24	HASSAN	LINE	110	BLGMBA-Aft	BELAGUMBA_110	10:00	15:46	05:46	LINE CLEAR AVAILED
2370	16-Apr-24	HASSAN	LINE	110	BLGMBA-Aft	BELAGUMBA_110	10:00	15:46	05:46	LINE CLEAR AVAILED
2371	16-Apr-24	HASSAN	LINE	110	BLGMBA-ARSIKERE	BELAGUMBA_110	10:00	15:46	05:46	LINE CLEAR AVAILED
2372	16-Apr-24	HASSAN	LINE	110	BLGMBA-SOLAR	BELAGUMBA_110	10:00	12:30	02:30	LINE CLEAR AVAILED
2373	16-Apr-24	HASSAN	LINE	110	BRAHMAV-MANIPAL	BRAHMAVAA_110	11:29	11:31	00:02	LINE CLEAR AVAILED
2374	16-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	06:36	12:25	05:49	TRIPPED ON FAULT
2375	16-Apr-24	HASSAN	LINE	110	NITUR11-MANIPAL	NITTUR_110	11:32	15:27	03:55	LINE CLEAR AVAILED
2376	16-Apr-24	HASSAN	LINE	110	SAGARA-JST1	SAGARA_110	20:05 (15.04.2024)	12:00(16.04.2024)	15:54 hrs	TRIPPED ON FAULT
2377	16-Apr-24	HASSAN	TRANSFORMER	66	HV1	ALDUR_66	18:25 (15.4.2024)	16:35 (16.4.2024)	22:9 hrs	TRIPPED ON FAULT
2378	16-Apr-24	HASSAN	TRANSFORMER	110	HV1	MANIPAL_110	07:06	07:24	00:18	TRIPPED ON FAULT
2379	16-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2380	16-Apr-24	MYSORE	LINE	66	KADAKOLA-SARGUR2	DOORA_66 HULLAHALLI_66	08:01	08:06	00:05	TRIPPED ON FAULT
2381	16-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2382	16-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
2383	16-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-BHOGADHI	NO STATIONS EFFECTED	18:24	22:06	03:42	LINE CLEAR AVAILED
2384	16-Apr-24	MYSORE	LINE	66	PANDAVAPURA-CHINKURLI	NO STATIONS EFFECTED	16:02	18:57	02:55	LINE CLEAR AVAILED
2385	16-Apr-24	MYSORE	LINE	66	VAJMANG-MALIYUR	NO STATIONS EFFECTED	06:03	06:08	00:05	TRIPPED ON FAULT
2386	16-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	18:20:00 (16/4/2023)			LINE CLEAR AVAILED
2387	16-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:36 (15/04/2024)	7:10:52 (16/04/2024)	10:34	LINE CLEAR AVAILED
2388	16-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHANDRAWADI_66	15:50	15:55	00:05	TRIPPED ON FAULT
2389	16-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHUNCHUNKATTE_66	05:00	06:50	01:50	LINE CLEAR AVAILED
2390	16-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHUNCHUNKATTE_66	08:23	10:49	02:26	LINE CLEAR AVAILED
2391	16-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2392	16-Apr-24	MYSORE	TRANSFORMER	66	HV2	DKMAIDANA_66	12:12	13:02	00:49	TRIPPED ON FAULT
2393	16-Apr-24	MYSORE	TRANSFORMER	66	HV2	PANDAVAPURA_66	23:02	23:26	00:24	TRIPPED ON FAULT
2394	16-Apr-24	MYSORE	TRANSFORMER	66	HV2	POONAMPETE_66	01:12	01:29	00:16	TRIPPED ON FAULT
2395	16-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 1&2	CHITRAHALLI_66, H D PURA_66, PANDARAHALLI_66	12:28	12:38	00:10	LINE CLEAR AVAILED
2396	16-Apr-24	TUMKUR	LINE	66	H D PURA- PANDARAHALLI	H D PURA_66	09:27	09:37	00:10	MAIN SUPPLY FAILURE
2397	16-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	RANGENAHALLI_66, PR PUA_66	14:36	14:43	00:07	TRIPPED ON FAULT
2398	16-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV-CHALLAKERE	SANIKERE_66	13:40	13:46	00:06	TRIPPED ON FAULT
2399	16-Apr-24	TUMKUR	LINE	66	KEREBILCHI-BENKIKERE 220	KEREBILCHI_66	10:50	10:55	00:05	MAIN SUPPLY FAILURE
2400	16-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	11:51	13:34	01:43	LINE CLEAR AVAILED
2401	17-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2402	17-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
2403	17-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	20:15	22:00	01:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2404	17-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2405	17-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220-ANKALI	CHIKKODI_220	09:50	11:00	01:10	LINE CLEAR AVAILED
2406	17-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2407	17-Apr-24	BAGALKOTE	LINE	110	KANAGALA220- GOLD PLUS	KANAGALA_220	14:26	16:17	01:51	TRIPPED ON FAULT
2408	17-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)			LINE CLEAR AVAILED
2409	17-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2410	17-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2411	17-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2412	17-Apr-24	BAGALKOTE	LINE	110	SOUDATTI220-MMCL	SOUDATTI_220	16:42	21:14	04:32	TRIPPED ON FAULT
2413	17-Apr-24	BAGALKOTE	LINE	110	SOUDATTI220-MMCL	SOUDATTI_220	21:18	21:30	00:12	TRIPPED ON FAULT
2414	17-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2415	17-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220-MELLIGERI	VAJRAMATTI_220	12:31	12:37	00:06	LINE CLEAR AVAILED
2416	17-Apr-24	BAGALKOTE	LINE	220	HAVERI- GUTTUR1	HAVERI_220	6:59 (14.04.2024)			LINE CLEAR AVAILED
2417	17-Apr-24	BAGALKOTE	LINE	220	KANAGALA- AEQUS1	KANAGALA_220	16:24	17:21	00:57	TRIPPED ON FAULT
2418	17-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2419	17-Apr-24	BAGALKOTE	LINE	220	SOUDATTI-BIDNAL	SOUDATTI_220	16:51	20:55	04:04	TRIPPED ON FAULT
2420	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	RAIBAG_110	18:21 (16.04.2024)			LINE CLEAR AVAILED
2421	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	KHADAKALAT_110	17:30	17:40	00:10	TRIPPED ON FAULT
2422	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MUDHOL_110	18:38 (16.04.2024)			LINE CLEAR AVAILED
2423	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	HALIYAL_110	14:23	15:15	00:52	TRIPPED ON FAULT
2424	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	CHIKKODI_220	15:35	15:45	00:10	TRIPPED ON FAULT
2425	17-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV4(10MVA)	ANKALI_110	19:00	19:30	00:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2426	17-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	SOUDATTI_220	16:51 (17.04.2024)			TRIPPED ON FAULT
2427	17-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2428	17-Apr-24	BENGALURU	LINE	66	66KV BOMMEPALLI - YENNIGADALE	BOMMEPALLI	16:12	16:15	00:03	LINE CLEAR AVAILED
2429	17-Apr-24	BENGALURU	LINE	66	66KV BOMMEPALLI - YENNIGADALE	YENNIGADALE	16:16	16:17	00:01	LINE CLEAR AVAILED
2430	17-Apr-24	BENGALURU	LINE	66	66KV CB PURA I/A - NALLIMARADANAHALLI	NO STATION AFFECTED	10:52	12:14	01:22	LINE CLEAR AVAILED
2431	17-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR	17:15	17:33	00:18	TRIPPED ON FAULT
2432	17-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	15:46	15:53	00:07	TRIPPED ON FAULT
2433	17-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	00:25	00:37	00:12	TRIPPED ON FAULT
2434	17-Apr-24	BENGALURU	LINE	66	66KV D CROSS - DODDABELAVANGALA - THONDEBHAVI - ALIPURA	THONDEBHAVI	18:35	18:45	00:10	TRIPPED ON FAULT
2435	17-Apr-24	BENGALURU	LINE	66	66KV DG4_MANYATA 220 - BYATRAYANAPURA (L&T)	BYATRAYANAPURA	16:48	17:03	00:15	TRIPPED ON FAULT
2436	17-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)	AMAR JYOTHI, GOLF LINK	07:23	07:40	00:17	TRIPPED ON FAULT
2437	17-Apr-24	BENGALURU	LINE	66	66KV KEMPANAHALLI - AGALKOTE	AGALAKOTE	11:00	11:10	00:10	TRIPPED ON FAULT
2438	17-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	17:16	17:20	00:04	LINE CLEAR AVAILED
2439	17-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI	13:55	13:57	00:02	LINE CLEAR AVAILED
2440	17-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	NO STATION AFFECTED	14:05	14:20	00:15	TRIPPED ON FAULT
2441	17-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	NO STATION AFFECTED	14:20	16:05	01:45	LINE CLEAR AVAILED
2442	17-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	18:00	18:13	00:13	TRIPPED ON FAULT
2443	17-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
2444	17-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	NO STATION AFFECTED	09:29	09:57	00:28	LINE CLEAR AVAILED
2445	17-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	YENNIGADALE	13:55	13:56	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2446	17-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - KHODAYS 220	NO STATION AFFECTED	15:03	17:40	02:37	TRIPPED ON FAULT
2447	17-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - MYLASANDRA 2	NO STATION AFFECTED	15:03	17:40	02:37	TRIPPED ON FAULT
2448	17-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - TATHAGUNI 220	TATAGUNI BWSSB	16:20	16:45	00:25	TRIPPED ON FAULT
2449	17-Apr-24	BENGALURU	LINE	220	220KV TATHAGUNI 220 - VRUSHABAVATHI 220	NO STATION AFFECTED	16:20	16:45	00:25	TRIPPED ON FAULT
2450	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VIJAYANAGARA	17:43	17:49	00:06	LINE CLEAR AVAILED
2451	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VIJAYANAGARA	23:16	23:25	00:09	LINE CLEAR AVAILED
2452	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BUDIGERE	10:27	11:12	00:45	LINE CLEAR AVAILED
2453	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	JANGAMKOTE	08:30	08:46	00:16	TRIPPED ON FAULT
2454	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SADALI	14:00	14:10	00:10	LINE CLEAR AVAILED
2455	17-Apr-24	BENGALURU	TRANSFORMER	66	HV1	H GOLLAHALLI	18:00	18:40	00:40	TRIPPED ON FAULT
2456	17-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VIJAYANAGARA	17:43	17:49	00:06	LINE CLEAR AVAILED
2457	17-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VIJAYANAGARA	23:16	23:25	00:09	LINE CLEAR AVAILED
2458	17-Apr-24	BENGALURU	TRANSFORMER	66	HV2	CHIKKABALLAPURA I/A	12:42	13:14	00:32	LINE CLEAR AVAILED
2459	17-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HOSUR RAMAPURA	08:20	08:30	00:10	TRIPPED ON FAULT
2460	17-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KEMPANAHALLI	08:00	08:30	00:30	LINE CLEAR AVAILED
2461	17-Apr-2024	GULBARGA	LINE	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	18:00	19:04	01:04	LINE CLEAR AVAILED
2462	17-Apr-2024	GULBARGA	LINE	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	19:24	19:28	00:04	LINE CLEAR AVAILED
2463	17-Apr-2024	GULBARGA	LINE	110	KAMALAPUR-SANKLAPUR	KAMALAPUR_110	10:10	10:35	00:25	MAIN SUPPLY FAILURE
2464	17-Apr-2024	GULBARGA	LINE	110	KANAKAGIRI-NAVALI	NAVALI_110	04:15	04:25	00:10	TRIPPED ON FAULT
2465	17-Apr-2024	GULBARGA	LINE	110	MUNIRABAD-SANKLAPUR	SANKLAPUR_110	10:43	13:57	03:14	LINE CLEAR AVAILED
2466	17-Apr-2024	GULBARGA	LINE	110	SANTHAPUR-HALBARGA	SANTHAPUR_110	22:20	22:29	00:09	TRIPPED ON FAULT
2467	17-Apr-2024	GULBARGA	LINE	110	SOMASAMUNDRA-BELLARY NORTH	BELLARY NORTH_110,MOKA_110, BISIHALLI_110,PDHALLI_110	19:10	19:20	00:10	TRIPPED ON FAULT
2468	17-Apr-2024	GULBARGA	LINE	110	VAJJARBANDI-KUSHTAGI	VAJJARBANDI_110, KUKUNOOR_110, YELBURGA_110	10:10	12:28	02:18	LINE CLEAR AVAILED
2469	17-Apr-2024	GULBARGA	LINE	110	YADGIR-RAMASAMUDRA	YADGIR_110	05:35	05:45	00:10	TRIPPED ON FAULT
2470	17-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SHAHAPUR_220	11:37	14:35	02:58	LINE CLEAR AVAILED
2471	17-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GUGAL_110	12:45	12:55	00:10	TRIPPED ON FAULT
2472	17-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GUGAL_110	14:15	14:30	00:15	TRIPPED ON FAULT
2473	17-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)			TRIPPED ON FAULT
2474	17-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	KARATAGI_110	10:35	11:25	00:50	TRIPPED ON FAULT
2475	17-Apr-2024	GULBARGA	TRANSFORMER	220	HV1	MUNIRABAD_220	07:38	14:38	07:00	LINE CLEAR AVAILED
2476	17-Apr-24	HASSAN	LINE	110	ANANDA-LPH(LST-4)	ANANDAPURA_110	11:28	15:47	04:19	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2477	17-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	10:00	13:20	03:20	MAIN SUPPLY FAILURE
2478	17-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	16:25	16:31	00:06	LINE CLEAR AVAILED
2479	17-Apr-24	HASSAN	LINE	110	PUTTUR-PUTUR 2	PUTTUR_220	10:00	15:13	05:13	TRIPPED ON FAULT
2480	17-Apr-24	HASSAN	LINE	110	PUTTUR-SLTR	PUTTUR_220	12:40	15:11	02:31	LINE CLEAR AVAILED
2481	17-Apr-24	HASSAN	LINE	110	SAGARA-SS2	SAGARA_110	11:28	15:47	04:19	LINE CLEAR AVAILED
2482	17-Apr-24	HASSAN	LINE	110	SALATHU-NTMDNOR	SALATHUR_110	10:00	10:39	00:39	MAIN SUPPLY FAILURE
2483	17-Apr-24	HASSAN	LINE	110	SALATHU-NTMDNOR	SALATHUR_110	15:20	16:10	00:50	LINE CLEAR AVAILED
2484	17-Apr-24	HASSAN	LINE	220	SHRAVITY-TALAGUPPA 2	gen_sharavaty	15:08	15:46	00:38	LINE CLEAR AVAILED
2485	17-Apr-24	HASSAN	LINE	220	TALAGU-ST2	TALAGUPPA_400	15:08	15:46	00:38	LINE CLEAR AVAILED
2486	17-Apr-24	HASSAN	TRANSFORMER	66	HV1	CRPATNA_220	11:56	12:56	01:00	LINE CLEAR AVAILED
2487	17-Apr-24	HASSAN	TRANSFORMER	66	HV2	CHIKMANGLUR_66	12:05	12:18	00:13	TRIPPED ON FAULT
2488	17-Apr-24	HASSAN	TRANSFORMER	66	LV1	CRPATNA_220	11:56	12:56	01:00	LINE CLEAR AVAILED
2489	17-Apr-24	HASSAN	TRANSFORMER	110	HV1	KONAJE_110	10:40	13:27	02:47	LINE CLEAR AVAILED
2490	17-Apr-24	HASSAN	TRANSFORMER	110	HV1	VITTALA_110	13:08	16:00	02:52	LINE CLEAR AVAILED
2491	17-Apr-24	HASSAN	TRANSFORMER	110	HV2	VITTALA_110	10:30	13:07	02:37	LINE CLEAR AVAILED
2492	17-Apr-24	HASSAN	TRANSFORMER	110	HV3	KADUR_110	05:00	05:26	00:26	TRIPPED ON FAULT
2493	17-Apr-24	HASSAN	TRANSFORMER	110	HV4	BAIKAMPADY_110	03:00	03:16	00:16	TRIPPED ON FAULT
2494	17-Apr-24	HASSAN	TRANSFORMER	110	VITTAL-PUTR_SLTUR	VITTALA_110	10:00	10:40	00:40	MAIN SUPPLY FAILURE
2495	17-Apr-24	HASSAN	TRANSFORMER	110	VITTAL-PUTR_SLTUR	VITTALA_110	10:40	16:08	05:28	LINE CLEAR AVAILED
2496	17-Apr-24	MYSORE	LINE	66	BEGUR 220-GUNDLUPETE 2	NO STATIONS EFFECTED	16:15	16:22	00:07	TRIPPED ON FAULT
2497	17-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
2498	17-Apr-24	MYSORE	LINE	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	16:25	17:15	00:50	LINE CLEAR AVAILED
2499	17-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2500	17-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
2501	17-Apr-24	MYSORE	LINE	66	MYSORE SOUTH-GIS	NO STATIONS EFFECTED	16:07	22:07	05:59	LINE CLEAR AVAILED
2502	17-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:42 (17/04/2024)			LINE CLEAR AVAILED
2503	17-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	18:20:00 (16/4/2023)	7:09 (17/04/2024)	12:49 HRs	LINE CLEAR AVAILED
2504	17-Apr-24	MYSORE	TRANSFORMER	66	HV1	KOPPA_66	16:15	16:55	00:40	LINE CLEAR AVAILED
2505	17-Apr-24	MYSORE	TRANSFORMER	66	HV1	HAMPAPURA(K)_66	10:30	11:10	00:40	LINE CLEAR AVAILED
2506	17-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2507	17-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	06:29	06:44	00:15	TRIPPED ON FAULT
2508	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-PANDARAHALLI 2 LINE	HIREGUNTANUR_66, PANDARAHALLI_66	17:08	17:45	00:37	LINE CLEAR AVAILED
2509	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-PANDARAHALLI 2 LINE	HIREGUNTANUR_66, PANDARAHALLI_66	10:59	11:18	00:19	LINE CLEAR AVAILED
2510	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-CHITRADURGA 3	CHITRADURGA_66	15:18	18:08	02:50	LINE CLEAR AVAILED
2511	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV-CHITRADURGA 4	CHITRADURGA_66	10:45	13:49	03:04	LINE CLEAR AVAILED
2512	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV-PANDARAHALLI 1 LINE	PANDARAHALLI_66, HOLALKERE_66	00:11	00:34	00:23	TRIPPED ON FAULT
2513	17-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV-PANDARAHALLI 1 LINE	PANDARAHALLI_66, HOLALKERE_66	07:30	09:30	02:00	LINE CLEAR AVAILED
2514	17-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	08:25	17:55	09:30	LINE CLEAR AVAILED
2515	17-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	HARIYABBE_66,PDKOT E_66	08:25	17:55	09:30	LINE CLEAR AVAILED
2516	17-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	03:58	04:12	00:14	TRIPPED ON FAULT
2517	17-Apr-24	TUMKUR	LINE	66	J N KOTE_66-MALLAPPANAHALLI	AIMANGALA_66, MALLAPPANAHALLI_66	14:15	14:25	00:10	TRIPPED ON FAULT
2518	17-Apr-24	TUMKUR	LINE	66	KUKKAWADA-BASAVAPATNA_66	TYVANAGI_66,	11:48	11:58	00:10	TRIPPED ON FAULT
2519	17-Apr-24	TUMKUR	LINE	66	MADHURE_220- RAMAGIRI_66	RAMAGIRI_66	14:20	14:40	00:20	TRIPPED ON FAULT
2520	17-Apr-24	TUMKUR	LINE	66	NAGASAMUDRA- HANAGAL LINE-1	NAGASAMUDRA_66, RAMPURA_66	19:00	19:20	00:20	TRIPPED ON FAULT
2521	17-Apr-24	TUMKUR	LINE	66	RAMAGIRI_66-HOLALKERE_66	CHIKKAJAJUR_66	14:25	14:45	00:20	TRIPPED ON FAULT
2522	17-Apr-24	TUMKUR	LINE	66	THALLAK 220kV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	15:10	15:16	00:06	TRIPPED ON FAULT
2523	17-Apr-24	TUMKUR	LINE	220	MADHUGIRI 220kV-VASANTANARASAPURA 1	VASANTANARASAPURA LINE 1	00:13	00:50	00:37	TRIPPED ON FAULT
2524	17-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- BTPS LINE	GUTTUR_400	20:34		-	TRIPPED ON FAULT
2525	18-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV1	KANAGALA_220	22:10	23:09	00:59	TRIPPED ON FAULT
2526	18-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV1(55MVA)	SIRSI_220	18:55 (18.04.2024)			LINE CLEAR AVAILED
2527	18-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV2(55MVA)	SIRSI_220	19:03 (18.04.2024)			LINE CLEAR AVAILED
2528	18-Apr-24	BAGALKOTE	LINE	110	AEQUS220- HATTARAGI	AEQUS_220	17:21	17:34	00:13	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2529	18-Apr-24	BAGALKOTE	LINE	110	ATHANI220- HALIYAL	ATHANI_220	14:50	15:11	00:21	TRIPPED ON FAULT
2530	18-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2531	18-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)			LINE CLEAR AVAILED
2532	18-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F8-LOKAPUR	BAGALKOT_220	20:52	21:32	00:40	TRIPPED ON FAULT
2533	18-Apr-24	BAGALKOTE	LINE	110	BIDNAL220- ANNIGERI	BIDNAL_220	15:36	16:55	01:19	TRIPPED ON FAULT
2534	18-Apr-24	BAGALKOTE	LINE	110	BIDNAL220- NAVALGUND	BIDNAL_220	15:37	17:26	01:49	TRIPPED ON FAULT
2535	18-Apr-24	BAGALKOTE	LINE	110	BILAGI- KATRAKI (SHIRAGUPPI)	BILAGI_110	20:03	20:13	00:10	TRIPPED ON FAULT
2536	18-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2537	18-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- NANADI	CHIKKODI_220	22:03	22:40	00:37	TRIPPED ON FAULT
2538	18-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- RAIBAG2	CHIKKODI_220	21:42 (18.04.2024)			TRIPPED ON FAULT
2539	18-Apr-24	BAGALKOTE	LINE	110	GADAG220- BETAGERI(ROH)	GADAG_220	17:12	18:12	01:00	LINE CLEAR AVAILED
2540	18-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	20:21	20:52	00:31	TRIPPED ON FAULT
2541	18-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	19:32	20:34	01:02	TRIPPED ON FAULT
2542	18-Apr-24	BAGALKOTE	LINE	110	HALIYAL- KAVALWAD	HALIYAL_110	15:22	17:22	02:00	TRIPPED ON FAULT
2543	18-Apr-24	BAGALKOTE	LINE	110	HIREHAL- IDLE(BADAMI)	HIREHAL_110	6:05 (14.04.2024)	16:52 (18.04.2024)	106:47:00	LINE CLEAR AVAILED
2544	18-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2545	18-Apr-24	BAGALKOTE	LINE	110	JAMKHANDI- NAVALAGI	JAMKHANDI_110	20:45	21:00	00:15	TRIPPED ON FAULT
2546	18-Apr-24	BAGALKOTE	LINE	110	KANAGALA220- GOLD PLUS	KANAGALA_220	22:10 (18.04.2024)			TRIPPED ON FAULT
2547	18-Apr-24	BAGALKOTE	LINE	110	KAVALWADA- KIRUVATTI	KAVALWADA_110	15:22	17:22	02:00	TRIPPED ON FAULT
2548	18-Apr-24	BAGALKOTE	LINE	110	KIRUVATTI- UMMACHAGI	KIRUVATTI_110	17:42 (18.04.2024)			LINE CLEAR AVAILED
2549	18-Apr-24	BAGALKOTE	LINE	110	KUD DHARWAD- LAKMANAHALLI	KUD DHARWAD_110	16:47	18:05	01:18	TRIPPED ON FAULT
2550	18-Apr-24	BAGALKOTE	LINE	110	KUDACHI220- HARUGERI	KUDACHI_220	20:41	21:31	00:50	TRIPPED ON FAULT
2551	18-Apr-24	BAGALKOTE	LINE	110	KULCRS-KON Cbreaker	KULAGERI CROSS_110	17:25 (30.03.2024)	17:08 (18.04.2024)	455:43:00	LINE CLEAR AVAILED
2552	18-Apr-24	BAGALKOTE	LINE	110	LOKAPUR- BAGALKOT	LOKAPUR_110	20:52	21:35	00:43	TRIPPED ON FAULT
2553	18-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2554	18-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR(B)- BELGAUM SOLAR	MAMDADAPUR(B)_110	19:29	21:21	01:52	TRIPPED ON FAULT
2555	18-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2556	18-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- LN5(ITANAL3)	MUGALKHOD_220	20:47	21:20	00:33	TRIPPED ON FAULT
2557	18-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220-LN3(ITANAL1)	MUGALKHOD_220	20:54	21:18	00:24	LINE CLEAR AVAILED
2558	18-Apr-24	BAGALKOTE	LINE	110	NAGANUR-F2 (TIGADI)	NAGANUR_110	22:09 (18.04.2024)			TRIPPED ON FAULT
2559	18-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- KUD DHARWAD	NARENDRA_220	16:15	16:40	00:25	TRIPPED ON FAULT
2560	18-Apr-24	BAGALKOTE	LINE	110	NAVALAGI-F1 (JAMAKAHANDI)	NAVALAGI_110	20:46	21:00	00:14	TRIPPED ON FAULT
2561	18-Apr-24	BAGALKOTE	LINE	110	NAVALAGUND-BIDNAL	NAVALAGUND_110	15:37	17:26	01:49	TRIPPED ON FAULT
2562	18-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2563	18-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220- HONNATTI	RANEBENNUR_220	03:39	03:45	00:06	TRIPPED ON FAULT
2564	18-Apr-24	BAGALKOTE	LINE	110	RON-GAMESH IPP	GAMESH IPP_110 RON_110	10:20	16:39	06:19	LINE CLEAR AVAILED
2565	18-Apr-24	BAGALKOTE	LINE	110	SIRSI220- KAWALWADA	SIRSI_220	16:58	17:15	00:17	TRIPPED ON FAULT
2566	18-Apr-24	BAGALKOTE	LINE	110	SIRSI220- SIRSI1	SIRSI_220	18:48	19:35	00:47	LINE CLEAR AVAILED
2567	18-Apr-24	BAGALKOTE	LINE	110	SOUDATTI220- MMCL	SOUDATTI_220	18:30	18:50	00:20	TRIPPED ON FAULT
2568	18-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2569	18-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - VAJARAMATTI-2	BAGALKOT_220	17:40	19:02	01:22	TRIPPED ON FAULT
2570	18-Apr-24	BAGALKOTE	LINE	220	BIDNAL- NAGJHARI2	BIDNAL_220	15:47	16:54	01:07	LINE CLEAR AVAILED
2571	18-Apr-24	BAGALKOTE	LINE	220	CHIKKODI- AEQUS1(KANAGALA1)	CHIKKODI_220	22:06	22:47	00:41	TRIPPED ON FAULT
2572	18-Apr-24	BAGALKOTE	LINE	220	CHIKKODI- AEQUS2(KANAGALA2)	CHIKKODI_220	22:06	22:47	00:41	TRIPPED ON FAULT
2573	18-Apr-24	BAGALKOTE	LINE	220	DHONI- LINGAPUR1(HALAVARTHI2)	DHONI_400	16:03	17:43	01:40	TRIPPED ON FAULT
2574	18-Apr-24	BAGALKOTE	LINE	220	HAVERI- GUTTUR1	HAVERI_220	6:59 (14.04.2024)			LINE CLEAR AVAILED
2575	18-Apr-24	BAGALKOTE	LINE	220	HAVERI- SHIGGAON2	HAVERI_220	15:23	19:04	03:41	TRIPPED ON FAULT
2576	18-Apr-24	BAGALKOTE	LINE	220	HUBLI- NAGJHARI3	HUBLI_220	16:04 (18.04.2024)			TRIPPED ON FAULT
2577	18-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	15:58 (18.04.2024)			TRIPPED ON FAULT
2578	18-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI2	HUBLI_220	15:53 (18.04.2024)			TRIPPED ON FAULT
2579	18-Apr-24	BAGALKOTE	LINE	220	KANAGALA- AEQUS2	KANAGALA_220	23:48	23:52	00:04	TRIPPED ON FAULT
2580	18-Apr-24	BAGALKOTE	LINE	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	18:16 (18.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2581	18-Apr-24	BAGALKOTE	LINE	220	NARENDRA- HUBLI2	NARENDRA_220	11:19	11:46	00:27	TRIPPED ON FAULT
2582	18-Apr-24	BAGALKOTE	LINE	220	NARENDRA- SHIGGOAN1	NARENDRA_220	15:23	16:31	01:08	TRIPPED ON FAULT
2583	18-Apr-24	BAGALKOTE	LINE	220	SHIGGOAN- BIDNAL	SHIGGOAN_220	16:17	18:25	02:08	TRIPPED ON FAULT
2584	18-Apr-24	BAGALKOTE	LINE	220	SHIGGOAN- HAVERI2	SHIGGOAN_220	15:23	18:56	03:33	TRIPPED ON FAULT
2585	18-Apr-24	BAGALKOTE	LINE	220	SIRSI220- SHARAVATHY1	SIRSI_220	20:32 (18.04.2024)			LINE CLEAR AVAILED
2586	18-Apr-24	BAGALKOTE	LINE	220	SIRSI220- SHARAVATHY2	SIRSI_220	18:18 (18.04.2024)			TRIPPED ON FAULT
2587	18-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2588	18-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	17:40	18:28	00:48	TRIPPED ON FAULT
2589	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV ,HV1 (20MVA)	BILAGI_110	20:04	22:56	02:52	TRIPPED ON FAULT
2590	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV ,HV2 (10MVA)	BILAGI_110	20:13	21:10	00:57	TRIPPED ON FAULT
2591	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	MKHUBLI_110	20:42	21:23	00:41	TRIPPED ON FAULT
2592	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	RAIBAG_110	18:21 (16.04.2024)			LINE CLEAR AVAILED
2593	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MALGHAN(B)_110	19:18	19:23	00:05	TRIPPED ON FAULT
2594	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	HIDIKAL_110	21:10	22:45	01:35	TRIPPED ON FAULT
2595	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MUDHOL_110	18:38 (16.04.2024)	21:36 (18.04.2024)	50:58:00	LINE CLEAR AVAILED
2596	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	VODAGOAN_110	12:55	19:51	06:56	TRIPPED ON FAULT
2597	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(20MVA)	KALADAGI_110	17:43	18:05	00:22	TRIPPED ON FAULT
2598	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(20MVA)	KALADAGI_110	18:17	18:25	00:08	TRIPPED ON FAULT
2599	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(20MVA)	MAMDADAPUR(B)_110	23:01	23:10	00:09	TRIPPED ON FAULT
2600	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV3 (10MVA)	BIJAPUR_110	18:02	18:08	00:06	TRIPPED ON FAULT
2601	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV1 (20MVA)	TALIKOTI_110	18:16	18:38	00:22	TRIPPED ON FAULT
2602	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV2(20MVA)	HIREKERUR_110	17:14	17:57	00:43	TRIPPED ON FAULT
2603	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (10MVA)	SHIGGAON_110	15:15	15:32	00:17	TRIPPED ON FAULT
2604	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (10MVA)	SHIGGAON_110	17:08	17:18	00:10	TRIPPED ON FAULT
2605	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA)	SINDAGI_110	17:51	17:59	00:08	LINE CLEAR AVAILED
2606	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA)	GOKAK_110	02:03	02:15	00:12	TRIPPED ON FAULT
2607	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4 (20MVA)	VADAGAON_110	12:55	19:30	06:35	TRIPPED ON FAULT
2608	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV1 (20MVA)	CHIKKODI_110	21:12	21:16	00:04	TRIPPED ON FAULT
2609	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV2 (20MVA)	ATHANI_110	20:21	22:59	02:38	TRIPPED ON FAULT
2610	18-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3 (20MVA)	GHATAPRABHA_110	22:50 (18.04.2024)			TRIPPED ON FAULT
2611	18-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	KANAGALA_220	22:10	23:04	00:54	TRIPPED ON FAULT
2612	18-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	SOUDATTI_220	16:51 (17.04.2024)	12:04 (18.04.2024)	28:45:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2613	18-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2614	18-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDAGUNTE	12:18	12:21	00:03	LINE CLEAR AVAILED
2615	18-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	12:58	13:09	00:11	LINE CLEAR AVAILED
2616	18-Apr-24	BENGALURU	LINE	66	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	DASHAVARA, SANKALGERE, VANDARGUPPE, BEVOOR	15:15	15:25	00:10	TRIPPED ON FAULT
2617	18-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	22:25	23:16	00:51	TRIPPED ON FAULT
2618	18-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	15:01	15:06	00:05	LINE CLEAR AVAILED
2619	18-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	17:05	17:08	00:03	LINE CLEAR AVAILED
2620	18-Apr-24	BENGALURU	LINE	66	66KV KEMPANAHALLI - AGALKOTE	AGALAKOTE	12:50	13:00	00:10	LINE CLEAR AVAILED
2621	18-Apr-24	BENGALURU	LINE	66	66KV KOLAR - AVANI	NO STATION AFFECTED	05:50	06:18	00:28	TRIPPED ON FAULT
2622	18-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	09:37	10:31	00:54	TRIPPED ON FAULT
2623	18-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	10:31	12:00	01:29	LINE CLEAR AVAILED
2624	18-Apr-24	BENGALURU	LINE	66	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	18:35	18:55	00:20	LINE CLEAR AVAILED
2625	18-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	MALUR IND AREA	19:27	20:00	00:33	TRIPPED ON FAULT
2626	18-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	19:27	20:00	00:33	MAIN SUPPLY FAILURE
2627	18-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MASTHI	MAASTHI	19:27	19:59	00:32	MAIN SUPPLY FAILURE
2628	18-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	06:10	06:25	00:15	TRIPPED ON FAULT
2629	18-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	10:39	13:00	02:21	LINE CLEAR AVAILED
2630	18-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI	19:15	20:20	01:05	TRIPPED ON FAULT
2631	18-Apr-24	BENGALURU	LINE	66	66KV TALAGUNDA - VEMGAL	VEMGAL, KYALANUR	09:18	09:26	00:08	TRIPPED ON FAULT
2632	18-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	15:38	15:43	00:05	TRIPPED ON FAULT
2633	18-Apr-24	BENGALURU	LINE	66	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	15:45	16:29	00:44	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2634	18-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
2635	18-Apr-24	BENGALURU	LINE	220	220KV EPIP 220 - HSR LAYOUT 220	NO STATION AFFECTED	14:33	15:55	01:22	TRIPPED ON FAULT
2636	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	EPIP 220	15:08	16:31	01:23	TRIPPED ON FAULT
2637	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SAUDELA	12:44	12:48	00:04	LINE CLEAR AVOIDED
2638	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUNDAMGERE	08:01	08:06	00:05	TRIPPED ON FAULT
2639	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUNDANA	13:27	13:32	00:05	TRIPPED ON FAULT
2640	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KEMBODI	15:00	15:15	00:15	LINE CLEAR AVOIDED
2641	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NANGLI	19:15	20:20	01:05	LINE CLEAR AVOIDED
2642	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KGF	16:10	16:40	00:30	LINE CLEAR AVOIDED
2643	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUDEMARAMAHALLI	08:10	08:20	00:10	LINE CLEAR AVOIDED
2644	18-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSPALYA CIRCLE	09:20	10:10	00:50	TRIPPED ON FAULT
2645	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KEMBODI	15:15	15:17	00:02	LINE CLEAR AVOIDED
2646	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BUDIKOTE	12:55	13:20	00:25	TRIPPED ON FAULT
2647	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BUDIKOTE	14:40	15:00	00:20	TRIPPED ON FAULT
2648	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	06:20	06:45	00:25	LINE CLEAR AVOIDED
2649	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NELAMANGALA 66	13:04	13:14	00:10	TRIPPED ON FAULT
2650	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	CHANNAPATNA 220	12:00	12:11	00:11	TRIPPED ON FAULT
2651	18-Apr-24	BENGALURU	TRANSFORMER	66	HV2	CHANNAPATNA 220	15:48	15:53	00:05	TRIPPED ON FAULT
2652	18-Apr-24	BENGALURU	TRANSFORMER	66	HV3	DEVANAHALLI 66	13:35	13:45	00:10	TRIPPED ON FAULT
2653	18-Apr-24	BENGALURU	TRANSFORMER	220	HV2	MALUR 220	19:27	19:59	00:32	TRIPPED ON FAULT
2654	18-Apr-2024	GULBARGA	LINE	66	CHILAKANAHATTI-HANSI	CHILAKANAHATTI_66	13:45	13:55	00:10	TRIPPED ON FAULT
2655	18-Apr-2024	GULBARGA	LINE	66	HPHALLI-SUZLON1,2	HARAPANAHALLI_66	20:55	23:20	02:25	LINE CLEAR AVOIDED
2656	18-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	15:40	15:58	00:18	TRIPPED ON FAULT
2657	18-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66, TBCL	22:37	22:58	00:21	TRIPPED ON FAULT
2658	18-Apr-2024	GULBARGA	LINE	66	KUDALGI-KOTTUR	UJJINI_66, KOTTUR_66, SOKKE_66, PALLANGATTA_66, BELICHOD_66	14:15	14:50	00:35	TRIPPED ON FAULT
2659	18-Apr-2024	GULBARGA	LINE	66	KUDALGI-KUDALGI	KUDALGI_66, CHORNOOR_66	05:50	06:20	00:30	TRIPPED ON FAULT
2660	18-Apr-2024	GULBARGA	LINE	66	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_ HALLI_66	17:29	18:18	00:49	TRIPPED ON FAULT
2661	18-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66,UP ANAYAKANAHALLI_66,N IMBALGERE_66,SUZLO N_IPP	15:06	15:33	00:27	TRIPPED ON FAULT
2662	18-Apr-2024	GULBARGA	LINE	110	BISIHALLI-BELLARY NORTH	BISIHALLI_110,HALKUN DI_110	13:06	13:28	00:22	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2663	18-Apr-2024	GULBARGA	LINE	110	KAMALAPUR-SANKLAPUR	KAMALAPUR_110	16:30	16:50	00:20	MAIN SUPPLY FAILURE
2664	18-Apr-2024	GULBARGA	LINE	110	MALLAT-ALKOD	ALKOD_110	14:31	15:06	00:35	LINE CLEAR AVAILED
2665	18-Apr-2024	GULBARGA	LINE	110	MALLAT-BYAGWAT	BYGWAT_110	13:30	13:46	00:16	LINE CLEAR AVAILED
2666	18-Apr-2024	GULBARGA	LINE	110	MALLAT-KAVITAL1	KAVITAL_110	12:30	12:57	00:27	LINE CLEAR AVAILED
2667	18-Apr-2024	GULBARGA	LINE	110	MALLAT-KAVITAL2	KAVITAL_110	12:58	13:19	00:21	LINE CLEAR AVAILED
2668	18-Apr-2024	GULBARGA	LINE	110	MALLAT-KONDAPURAM	KONDAPURAM_110	16:12	16:23	00:11	LINE CLEAR AVAILED
2669	18-Apr-2024	GULBARGA	LINE	110	MALLAT-MADLAPUR	MADLAPUR_110	13:50	13:58	00:08	LINE CLEAR AVAILED
2670	18-Apr-2024	GULBARGA	LINE	110	MALLAT-SIRWAR	SIRWAR_110	14:21	14:30	00:09	LINE CLEAR AVAILED
2671	18-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	11:50	21:30	09:40	LINE CLEAR AVAILED
2672	18-Apr-2024	GULBARGA	LINE	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	17:56	21:09	03:13	LINE CLEAR AVAILED
2673	18-Apr-2024	GULBARGA	LINE	220	NEELAGUNDA-ITTAGGI	NEELAGUNDA_220	15:09	23:47	08:38	TRIPPED ON FAULT
2674	18-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	TELAGI_66	17:55	18:05	00:10	TRIPPED ON FAULT
2675	18-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HARAPANAHALLI_66	10:15	18:20	08:05	LINE CLEAR AVAILED
2676	18-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)			TRIPPED ON FAULT
2677	18-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	HANUMSAGAR_110	17:10	17:55	00:45	LINE CLEAR AVAILED
2678	18-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	00:28	00:34	00:06	TRIPPED ON FAULT
2679	18-Apr-2024	GULBARGA	TRANSFORMER	110	HV7	MUNIRABAD_220	17:41	17:46	00:05	TRIPPED ON FAULT
2680	18-Apr-2024	GULBARGA	TRANSFORMER	220	HV1	MALLAT_220	17:04	18:12	01:08	LINE CLEAR AVAILED
2681	18-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	MALLAT_220	18:18	18:47	00:29	LINE CLEAR AVAILED
2682	18-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	ITTAGI_220	15:08	15:23	00:15	TRIPPED ON FAULT
2683	18-Apr-24	HASSAN	LINE	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:25	17:30	02:05	TRIPPED ON FAULT
2684	18-Apr-24	HASSAN	LINE	66	SAKALE-IPCL2	SAKALESHPURA_66	12:24	15:27	03:03	LINE CLEAR AVAILED
2685	18-Apr-24	HASSAN	LINE	110	ALKOLA-SAGAR	ALKOLA_110	18:32	20:07	01:35	TRIPPED ON FAULT
2686	18-Apr-24	HASSAN	LINE	110	ANANDA-SAGAR	ANANDAPURA_110	18:35	19:35	01:00	TRIPPED ON FAULT
2687	18-Apr-24	HASSAN	LINE	110	ANANDA-SAGAR	ANANDAPURA_110	19:45	21:05	01:20	LINE CLEAR AVAILED
2688	18-Apr-24	HASSAN	LINE	110	BARANG-ANVATTI	BARANGI_110	18:05	19:30	01:25	MAIN SUPPLY FAILURE
2689	18-Apr-24	HASSAN	LINE	110	BRAHMAV-MANIPAL	BRAHMAVARA_110	13:50	15:30	01:40	LINE CLEAR AVAILED
2690	18-Apr-24	HASSAN	LINE	110	BRAHMAV-NITTUR	BRAHMAVARA_110	13:44	13:47	00:03	LINE CLEAR AVAILED
2691	18-Apr-24	HASSAN	LINE	110	KADUR-NERELEKERE	KADUR_110	14:20	14:30	00:10	LINE CLEAR AVAILED
2692	18-Apr-24	HASSAN	LINE	110	KADUR-TNGL	KADUR_110	14:20	14:28	00:08	LINE CLEAR AVAILED
2693	18-Apr-24	HASSAN	LINE	110	KADUR-YGTI	KADUR_110	14:20	14:29	00:09	LINE CLEAR AVAILED
2694	18-Apr-24	HASSAN	LINE	110	KMS110-MRS-ANDPR	KMSI_110	19:25	19:59	00:34	TRIPPED ON FAULT
2695	18-Apr-24	HASSAN	LINE	110	MRSSHM-SBT	MRSMG_220	16:00	17:54	01:54	TRIPPED ON FAULT
2696	18-Apr-24	HASSAN	LINE	110	SAGARA-ALKLA	SAGARA_110	18:35	20:10	01:35	TRIPPED ON FAULT
2697	18-Apr-24	HASSAN	LINE	110	SAGARA-SORABA	SAGARA_110	18:35	21:05	02:30	TRIPPED ON FAULT
2698	18-Apr-24	HASSAN	LINE	110	SAGARA-ULAVI	SAGARA_110	19:35	21:15	01:40	LINE CLEAR AVAILED
2699	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMG_220	13:59	16:02	02:03	TRIPPED ON FAULT
2700	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMG_220	15:28	16:02	00:34	LINE CLEAR AVAILED
2701	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY1	MRSMG_220	16:37	17:32	00:55	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2702	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY3	MRSMSG_220	16:55(18.04.2024)			TRIPPED ON FAULT
2703	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY3	MRSMSG_220	16:37	17:32	00:55	TRIPPED ON FAULT
2704	18-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY3	MRSMSG_220	14:50	14:54	00:04	LINE CLEAR AVAILED
2705	18-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA1	gen_sharavaty	13:59	16:32	02:33	TRIPPED ON FAULT
2706	18-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA1	gen_sharavaty	16:37	17:32	00:55	TRIPPED ON FAULT
2707	18-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA3	gen_sharavaty	16:55(18.04.2024)			TRIPPED ON FAULT
2708	18-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA3	gen_sharavaty	10:34	14:45	04:11	TRIPPED ON FAULT
2709	18-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA3	gen_sharavaty	14:50	14:54	00:04	TRIPPED ON FAULT
2710	18-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA1	gen_sharavaty	18:22 (18.04.2024)			TRIPPED ON FAULT
2711	18-Apr-24	HASSAN	LINE	220	TALAGU-SGS1	TALAGUPPA_400	18:22 (18.04.2024)			TRIPPED ON FAULT
2712	18-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	13:12	13:30	00:18	LINE CLEAR AVAILED
2713	18-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	15:20	15:25	00:05	LINE CLEAR AVAILED
2714	18-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	13:12	13:30	00:18	LINE CLEAR AVAILED
2715	18-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	15:20	15:25	00:05	LINE CLEAR AVAILED
2716	18-Apr-24	HASSAN	TRANSFORMER	110	HV1	CHANDRAGUTTI_10	18:03	19:12	01:09	LINE CLEAR AVAILED
2717	18-Apr-24	HASSAN	TRANSFORMER	110	HV1	NAVUNDA_110	11:05	11:17	00:12	TRIPPED ON FAULT
2718	18-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	17:10	18:20	01:10	TRIPPED ON FAULT
2719	18-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	18:35	18:40	00:05	TRIPPED ON FAULT
2720	18-Apr-24	HASSAN	TRANSFORMER	110	HV3	ANANDAPURA_110	19:45	20:05	00:20	TRIPPED ON FAULT
2721	18-Apr-24	MYSORE	LINE	66	CHAMALAPURA-ARAKERE-TUBINKERE	CHAMLAPURA_66 GAMANAHALLY_66	00:41	01:03	00:22	TRIPPED ON FAULT
2722	18-Apr-24	MYSORE	LINE	66	CHAMALAPURA-GAMANAHALLI	CHAMLAPURA_66 GAMANAHALLY_66	00:41	01:09	00:28	TRIPPED ON FAULT
2723	18-Apr-24	MYSORE	LINE	66	CHUNCHUNKATTE-BETTDAPURA-RAVANDUR	KITTUR_66 RAVANDUR_66	19:44	19:55	00:11	TRIPPED ON FAULT
2724	18-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	06:06	06:16	00:10	TRIPPED ON FAULT
2725	18-Apr-24	MYSORE	LINE	66	DR PETE -KUNTHUR	SANTHEMARAHALLI_66	15:23	15:30	00:06	TRIPPED ON FAULT
2726	18-Apr-24	MYSORE	LINE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:10	19:08	00:58	TRIPPED ON FAULT
2727	18-Apr-24	MYSORE	LINE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	23:02	23:16	00:13	TRIPPED ON FAULT
2728	18-Apr-24	MYSORE	LINE	66	HAMPAPURA(K)-JAIPURA	NO STATIONS EFFECTED	05:46	05:54	00:08	TRIPPED ON FAULT
2729	18-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2730	18-Apr-24	MYSORE	LINE	66	HEBBANI-SFC -3	NO STATIONS EFFECTED	16:23	17:23	01:00	TRIPPED ON FAULT
2731	18-Apr-24	MYSORE	LINE	66	HEBBANI-SFC -4	NO STATIONS EFFECTED	16:23	17:22	00:59	TRIPPED ON FAULT
2732	18-Apr-24	MYSORE	LINE	66	HEBBANI-SFC -5	NO STATIONS EFFECTED	16:23	17:17	00:54	TRIPPED ON FAULT
2733	18-Apr-24	MYSORE	LINE	66	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	17:21	17:34	00:13	TRIPPED ON FAULT
2734	18-Apr-24	MYSORE	LINE	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	22:49	00:00	01:11	TRIPPED ON FAULT
2735	18-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2736	18-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
2737	18-Apr-24	MYSORE	LINE	66	MADIKERI-VIRAJPETE	VIRAJPET_66	20:27	21:23	00:56	TRIPPED ON FAULT
2738	18-Apr-24	MYSORE	LINE	66	MYSORE SOUTH -GIS KALAMANDIR	NO STATIONS EFFECTED	16:07	22:10	06:03	LINE CLEAR AVAILED
2739	18-Apr-24	MYSORE	LINE	66	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	19:46	19:56	00:10	TRIPPED ON FAULT
2740	18-Apr-24	MYSORE	LINE	66	PERIYAPATNA-HANAGODU	PONNAMPET_66 SRIMANGALA_66	19:58	20:36	00:37	TRIPPED ON FAULT
2741	18-Apr-24	MYSORE	LINE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	20:27 (18/04/2024)			TRIPPED ON FAULT
2742	18-Apr-24	MYSORE	LINE	66	SFC SIVA-PGL	NO STATIONS EFFECTED	16:23	16:31	00:07	TRIPPED ON FAULT
2743	18-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	15:29	15:37	00:07	TRIPPED ON FAULT
2744	18-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	21:17 (18/04/2024)			TRIPPED ON FAULT
2745	18-Apr-24	MYSORE	LINE	66	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	17:57	18:18	00:20	TRIPPED ON FAULT
2746	18-Apr-24	MYSORE	LINE	66	TUBINAKERE-MANDYA 2	NO STATIONS EFFECTED	17:31	17:53	00:22	TRIPPED ON FAULT
2747	18-Apr-24	MYSORE	LINE	66	TUBINAKERE-PANDAVAPURA	BANANGADI_66 BELAGOLA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	17:54	18:15	00:21	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2748	18-Apr-24	MYSORE	LINE	66	TUBINAKERE-PANDAVAPURA	BANANGADI_66 BELAGOLA_66 DODDABYADARAHALLI_66 PANDAVAPURA_66	18:20	20:30	02:10	TRIPPED ON FAULT
2749	18-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:52 (18/04/2024)			LINE CLEAR AVAILED
2750	18-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:42 (17/04/2024)	6:45 (18/04/2024)	10:03 HRs	LINE CLEAR AVAILED
2751	18-Apr-24	MYSORE	TRANSFORMER	66	HV1	BOOKANAKERE_66	14:25	16:10	01:45	LINE CLEAR AVAILED
2752	18-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2753	18-Apr-24	MYSORE	TRANSFORMER	66	HV2	BOOKANAKERE_66	10:20	14:30	04:10	LINE CLEAR AVAILED
2754	18-Apr-24	MYSORE	TRANSFORMER	66	HV2	HAMPAPURA_66	11:04	11:14	00:10	TRIPPED ON FAULT
2755	18-Apr-24	MYSORE	TRANSFORMER	66	HV2	HAMPAPURA_66	17:05	17:12	00:07	TRIPPED ON FAULT
2756	18-Apr-24	MYSORE	TRANSFORMER	66	HV2	SANTHEMARAHALLI_66	20:50	21:22	00:32	LINE CLEAR AVAILED
2757	18-Apr-24	MYSORE	TRANSFORMER	220	HV3	HOOTAGALLY_220	22:54 (18/04/2024)			TRIPPED ON FAULT
2758	18-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66	05:37	05:47	00:10	TRIPPED ON FAULT
2759	18-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66, HULIYAR_66, NIDASALE_66	14:13	14:39	00:26	TRIPPED ON FAULT
2760	18-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	12:50	12:53	00:03	LINE CLEAR AVAILED
2761	18-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	07:09	09:49	02:40	LINE CLEAR AVAILED
2762	18-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	BILCHODU_66, PALLAGATTE_66	18:50	19:00	00:10	TRIPPED ON FAULT
2763	18-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	BILCHODU_66, PALLAGATTE_66	19:40	19:50	00:10	TRIPPED ON FAULT
2764	18-Apr-24	TUMKUR	LINE	66	BILCHODU-PALLAGATTE	BILCHODU_66, PALLAGATTE_66	20:15	20:25	00:10	TRIPPED ON FAULT
2765	18-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 1 LINE	PANDARAHALLI_66	01:28	01:33	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2766	18-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	16:08	16:38	00:30	TRIPPED ON FAULT
2767	18-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	15:05	15:10	00:05	TRIPPED ON FAULT
2768	18-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS-ANGODU	ANGODU_66, ATTIGERE_66	15:55	16:00	00:05	TRIPPED ON FAULT
2769	18-Apr-24	TUMKUR	LINE	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:25	17:32	05:07	LINE CLEAR AVAILED
2770	18-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	11:00	15:00	04:00	LINE CLEAR AVAILED
2771	18-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	HARIYABBE_66, PDKOTE_66	11:00	15:00	04:00	LINE CLEAR AVAILED
2772	18-Apr-24	TUMKUR	LINE	66	MADURE220-BAGUR	BAGUR_66	13:15	13:20	00:05	LINE CLEAR AVAILED
2773	18-Apr-24	TUMKUR	LINE	66	MADURE220-BAGUR	BAGUR_66	19:10	19:30	00:20	LINE CLEAR AVAILED
2774	18-Apr-24	TUMKUR	LINE	66	MADURE220-HALURAMESWARA-	HALURAMESWARA_66, MADADKERE_66	18:15	18:25	00:10	TRIPPED ON FAULT
2775	18-Apr-24	TUMKUR	LINE	66	MADURE220-HALURAMESWARA-	HALURAMESWARA_66, MADADKERE_66	13:40	13:45	00:05	LINE CLEAR AVAILED
2776	18-Apr-24	TUMKUR	LINE	66	MADURE220-HALURAMESWARA-	HALURAMESWARA_66, MADADKERE_66	19:10	19:30	00:20	LINE CLEAR AVAILED
2777	18-Apr-24	TUMKUR	LINE	66	MADURE220-HOSADURGE_66	HOSADURGA_66, NEERGUNDA_66	12:40	12:45	00:05	LINE CLEAR AVAILED
2778	18-Apr-24	TUMKUR	LINE	66	MADURE220-HOSADURGE_66	HOSADURGA_66, NEERGUNDA_66	19:10	19:30	00:20	LINE CLEAR AVAILED
2779	18-Apr-24	TUMKUR	LINE	66	MADURE220-RAMGIRI	RAMAGIRI_66	13:25	13:35	00:10	LINE CLEAR AVAILED
2780	18-Apr-24	TUMKUR	LINE	66	MADURE220-RAMGIRI	RAMAGIRI_66	19:10	19:30	00:20	LINE CLEAR AVAILED
2781	18-Apr-24	TUMKUR	LINE	66	MATHOD_66KV- HIRIYUR	HALURAMESWARA_66, MADADKERE_66, RAMGIRI_66, BAGUR_66, HOSADURGA_66, NEERGUNDA_66	18:15	18:25	00:10	TRIPPED ON FAULT
2782	18-Apr-24	TUMKUR	LINE	220	BENKIKERE-MADHURE LINE2	HOSADURGA_220	02:38	03:03	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2783	18-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI LINE 1	220KV HONNALLI, BENKIKERE, MADHURE, 66KV HONNALLI, KATTIGE, NYAMATHI,SAVALANGA ,CHILUR,BASAVAPATNA ,SASVEHALLI,KUNDUR, MALEBENNUR,DEVARA BELEKERE,BHANUVALLI,NANDIGUDI,EHT CARGILL	16:20	18:35	02:15	TRIPPED ON FAULT
2784	18-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI LINE 2	HALRAMESWARA,MADADKERE,RAMAGIRI,BAGUR,HOSADURGA,NEERGUNDA,BENKIKERE_66, MALLADIHALLI,DEVARAHALLI,SANTHEBENNUR, KERECHILCHI,NALLUR,LINGADAHALLI,CHANNAGIRI,GOPPENAHALLI,TAVAREKERE	16:15	18:30	02:15	TRIPPED ON FAULT
2785	18-Apr-24	TUMKUR	LINE	220	HONNALLI 220kv-DAVANAGERE SRS	HONNALLI_220	16:16	16:47	00:31	TRIPPED ON FAULT
2786	18-Apr-24	TUMKUR	LINE	400	GUTTUR 400kv- BTPS LINE	GUTTUR_400	20:34(17.04.24)	19:50(18.04.24)	23:16	TRIPPED ON FAULT
2787	18-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRADURGA_66	16:48	16:58	00:10	TRIPPED ON FAULT
2788	18-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HIRIYUR_66	15:15	15:43	00:28	TRIPPED ON FAULT
2789	18-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HONNALLI_66	15:42	16:02	00:20	LINE CLEAR AVAILED
2790	18-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	HONNALLI_66	16:16	16:46	00:30	LINE CLEAR AVAILED
2791	18-Apr-24	TUMKUR	TRANSFORMER	220	TR-1	MADHUEI_220	12:50	12:55	00:05	LINE CLEAR AVAILED
2792	18-Apr-24	TUMKUR	TRANSFORMER	220	TR-1 HV & LV SIDE	K B CROSS_220	18:01	18:14	00:13	TRIPPED ON FAULT
2793	18-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	MADHUEI_220	13:05	13:10	00:05	LINE CLEAR AVAILED
2794	18-Apr-24	TUMKUR	TRANSFORMER	220	TR-3	DAVANGERE_220	16:51	16:59	00:08	TRIPPED ON FAULT
2795	19-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV1(55MVA)	SIRSI_220	18:55 (18.04.2024)	13:07 (19.04.2024)	18:12:00	LINE CLEAR AVAILED
2796	19-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV2(55MVA)	SIRSI_220	19:03 (18.04.2024)	13:07 (19.04.2024)	18:04:00	LINE CLEAR AVAILED
2797	19-Apr-24	BAGALKOTE	LINE	110	ANMOD- SUPA2	ANMOD_110	12:10 (19.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2798	19-Apr-24	BAGALKOTE	LINE	110	ANMOD- SUPA2	ANMOD_110	12:10 (19.04.2024)			TRIPPED ON FAULT
2799	19-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2800	19-Apr-24	BAGALKOTE	LINE	110	BABLESHW-F2 CB (TIKOTA)	BABLESHWAR_110	18:54 (01.04.2024)	13:43 (19.04.2024)	426:49:00	LINE CLEAR AVAILED
2801	19-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
2802	19-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- RAIBAG2	CHIKKODI_220	21:42 (18.04.2024)	13:05 (19.04.2024)	15:23:00	TRIPPED ON FAULT
2803	19-Apr-24	BAGALKOTE	LINE	110	GADAG220- DAMBAL1 (SAMBAPUR ROAD)	GADAG_220	16:55	18:18	01:23	LINE CLEAR AVAILED
2804	19-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2805	19-Apr-24	BAGALKOTE	LINE	110	KAMBAGI- F1(MAMADAPUR)	KAMBAGI_110	17:49	18:58	01:09	LINE CLEAR AVAILED
2806	19-Apr-24	BAGALKOTE	LINE	110	KANAGALA220- GOLD PLUS	KANAGALA_220	22:10 (18.04.2024)	00:06 (19.04.2024)	1:56:00	TRIPPED ON FAULT
2807	19-Apr-24	BAGALKOTE	LINE	110	KARWAR220-KUMTA (KARWAR-ARGA)	KARWAR_220	01:38	01:55	00:17	TRIPPED ON FAULT
2808	19-Apr-24	BAGALKOTE	LINE	110	KARWAR220-KUMTA (KARWAR-ARGA)	KARWAR_220	09:18	09:30	00:12	TRIPPED ON FAULT
2809	19-Apr-24	BAGALKOTE	LINE	110	KIRUVATTI- UMMACHAGI	KIRUVATTI_110	17:42 (18.04.2024)			LINE CLEAR AVAILED
2810	19-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
2811	19-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
2812	19-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2813	19-Apr-24	BAGALKOTE	LINE	110	MAHALINGAPUR- BANAHATTI	MAHALINGAPUR_220	11:56	11:59	00:03	TRIPPED ON FAULT
2814	19-Apr-24	BAGALKOTE	LINE	110	MAHALINGAPUR- HIDIKAL	MAHALINGAPUR_220	15:50	15:55	00:05	TRIPPED ON FAULT
2815	19-Apr-24	BAGALKOTE	LINE	110	MAHALINGAPUR- TERDAL	MAHALINGAPUR_220	08:51	09:23	00:32	TRIPPED ON FAULT
2816	19-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI1	MAMADAPUR(B)_110	13:59	18:50	04:51	LINE CLEAR AVAILED
2817	19-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BAGEWADI2	MAMADAPUR(B)_110	13:34	18:50	05:16	LINE CLEAR AVAILED
2818	19-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BELGAUM SOLAR	MAMADAPUR(B)_110	13:59	18:51	04:52	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2819	19-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2820	19-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- HALLUR	MUGALKHOD_220	22:30	22:42	00:12	TRIPPED ON FAULT
2821	19-Apr-24	BAGALKOTE	LINE	110	NAGANUR-F2 (TIGADI)	NAGANUR_110	22:09 (18.04.2024)	10:23 (19.04.2024)	12:14:00	TRIPPED ON FAULT
2822	19-Apr-24	BAGALKOTE	LINE	110	NAGANUR-F2 (TIGADI)	NAGANUR_110	11:00	11:02	00:02	LINE CLEAR AVAILED
2823	19-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2824	19-Apr-24	BAGALKOTE	LINE	110	RONIHAL- F2(MAMADAPUR)	RONIHAL_110	13:40	18:35	04:55	LINE CLEAR AVAILED
2825	19-Apr-24	BAGALKOTE	LINE	110	SAMBAPUR ROAD- DAMBL	SAMBAPUR ROAD_110	11:53	18:40	06:47	LINE CLEAR AVAILED
2826	19-Apr-24	BAGALKOTE	LINE	110	SHIGGOAN220-LN4(SAVANUR)	SHIGGOAN_220	20:06	20:49	00:43	TRIPPED ON FAULT
2827	19-Apr-24	BAGALKOTE	LINE	110	SIRSI- HUBLI1(ESALE1)	SIRSI_110	13:01	13:13	00:12	LINE CLEAR AVAILED
2828	19-Apr-24	BAGALKOTE	LINE	110	SIRSI-KUMTA1	SIRSI_110	18:55 (18.04.2024)	13:16 (19.04.2024)	18:21	LINE CLEAR AVAILED
2829	19-Apr-24	BAGALKOTE	LINE	110	SIRSI-KUMTA2	SIRSI_110	18:55 (18.04.2024)	13:16 (19.04.2024)	18:21	LINE CLEAR AVAILED
2830	19-Apr-24	BAGALKOTE	LINE	110	TAKKALAKI- TIKOTA	TAKKALAKI_110	18:31	18:46	00:15	TRIPPED ON FAULT
2831	19-Apr-24	BAGALKOTE	LINE	110	THORVI- TIKOTA	BJCTY(THORVI)_110	18:31	18:43	00:12	LINE CLEAR AVAILED
2832	19-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2833	19-Apr-24	BAGALKOTE	LINE	220	BIDNAL-NAGJHARI2	BIDNAL_220	11:58	16:30	04:32	LINE CLEAR AVAILED
2834	19-Apr-24	BAGALKOTE	LINE	220	HAVERI- SHIGGOAN1	HAVERI_220	20:29	21:56	01:27	TRIPPED ON FAULT
2835	19-Apr-24	BAGALKOTE	LINE	220	HUBLI- NAGJHARI3	HUBLI_220	16:04 (18.04.2024)	16:36 (19.04.2024)	24:32:00	TRIPPED ON FAULT
2836	19-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	15:58 (18.04.2024)	16:26 (19.04.2024)	24:28:00	TRIPPED ON FAULT
2837	19-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI2	HUBLI_220	15:53 (18.04.2024)	16:30 (19.04.2024)	24:37:00	TRIPPED ON FAULT
2838	19-Apr-24	BAGALKOTE	LINE	220	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	18:16 (18.04.2024)	10:03 (19.04.2024)	15:47:00	LINE CLEAR AVAILED
2839	19-Apr-24	BAGALKOTE	LINE	220	RANEENNUR- BELLIGAVI	RANEENNUR_220	08:20	20:43	12:23	LINE CLEAR AVAILED
2840	19-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	08:10	16:26	08:16	LINE CLEAR AVAILED
2841	19-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI2	SIRSI_220	08:10	16:30	08:20	LINE CLEAR AVAILED
2842	19-Apr-24	BAGALKOTE	LINE	220	SIRSI- SHARAVATHY1	SIRSI_220	14:00	17:40	03:40	LINE CLEAR AVAILED
2843	19-Apr-24	BAGALKOTE	LINE	220	SIRSI220- SHARAVATHY1	SIRSI_220	20:32 (18.04.2024)	13:01 (19.04.2024)	16:29:00	LINE CLEAR AVAILED
2844	19-Apr-24	BAGALKOTE	LINE	220	SIRSI220- SHARAVATHY2	SIRSI_220	18:18 (18.04.2024)	13:01 (19.04.2024)	66:43:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2845	19-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2846	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	RAIBAG_110	18:21 (16.04.2024)	18:27 (19.04.2024)	72:06:00	LINE CLEAR AVAILED
2847	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	GADAG_110	23:57 (19.04.2024)			TRIPPED ON FAULT
2848	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	CHIKKODI_110	12:09	12:19	00:10	TRIPPED ON FAULT
2849	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	GADAG_110	23:57 (19.04.2024)		07:12	TRIPPED ON FAULT
2850	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(20MVA)	HIREKERUR_110	17:00	17:17	00:17	LINE CLEAR AVAILED
2851	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	RANEBENNUR_220	21:34	21:44	00:10	TRIPPED ON FAULT
2852	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	KAGAWAD_110	15:55	16:10	00:15	TRIPPED ON FAULT
2853	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3(20MVA)	RANEBENNUR_220	11:01	17:59	06:58	LINE CLEAR AVAILED
2854	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3(20MVA)	BIJAPUR CITY_110	08:21	08:24	00:03	TRIPPED ON FAULT
2855	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3(20MVA)	SHIGGOAN_110	20:46	20:53	00:07	TRIPPED ON FAULT
2856	19-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3 (20MVA)	GHATAPRABHA_110	22:50 (18.04.2024)	9:44 (19.04.2024)	10:54:00	TRIPPED ON FAULT
2857	19-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1&LV1	KUDACHI_220	10:01	18:49	08:48	LINE CLEAR AVAILED
2858	19-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2&LV2	MUGALKHOD_220	09:47	11:23	01:36	LINE CLEAR AVAILED
2859	19-Apr-24	BENGALURU	LINE	66	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	12:58	13:02	00:04	LINE CLEAR AVAILED
2860	19-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2861	19-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURHALLI	15:38	15:50	00:12	LINE CLEAR AVAILED
2862	19-Apr-24	BENGALURU	LINE	66	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, VANDARAGUPPE, DASHAVARA	17:25	17:44	00:19	TRIPPED ON FAULT
2863	19-Apr-24	BENGALURU	LINE	66	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	17:08	17:26	00:18	TRIPPED ON FAULT
2864	19-Apr-24	BENGALURU	LINE	66	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	17:26	17:52	00:26	TRIPPED ON FAULT
2865	19-Apr-24	BENGALURU	LINE	66	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	17:52	18:20	00:28	LINE CLEAR AVAILED
2866	19-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	15:14	15:19	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2867	19-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR	14:54	15:14	00:20	TRIPPED ON FAULT
2868	19-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR	17:05	17:20	00:15	TRIPPED ON FAULT
2869	19-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - TADIGOL CROSS	NANDIGANAHALLI	15:06	15:13	00:07	LINE CLEAR AVAILED
2870	19-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - HIREHALLI	HIREHALLI, HONNUDIKE	12:47	13:44	00:57	LINE CLEAR AVAILED
2871	19-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - HIREHALLI	HIREHALLI, HONNUDIKE	19:55	19:59	00:04	LINE CLEAR AVAILED
2872	19-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	12:47	13:05	00:18	LINE CLEAR AVAILED
2873	19-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	20:03	20:08	00:05	LINE CLEAR AVAILED
2874	19-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	14:47	16:33	01:46	TRIPPED ON FAULT
2875	19-Apr-24	BENGALURU	LINE	66	66KV DRDO - T D HALLI (MALLASANDRA)	MALLASANDRA	17:30	18:10	00:40	LINE CLEAR AVAILED
2876	19-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	GUNDAMGERE, SASALU	05:55	06:05	00:10	LINE CLEAR AVAILED
2877	19-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	GUNDAMGERE, SASALU	08:32	08:40	00:08	LINE CLEAR AVAILED
2878	19-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	06:12	06:24	00:12	TRIPPED ON FAULT
2879	19-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - ADUGODI	ADUGODI	12:50	13:05	00:15	TRIPPED ON FAULT
2880	19-Apr-24	BENGALURU	LINE	66	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI DIARY, DODDALAHALLI	10:33	10:41	00:08	TRIPPED ON FAULT
2881	19-Apr-24	BENGALURU	LINE	66	66KV KEMPANAHALLI - AGALKOTE	AGALKOTE	18:10	18:30	00:20	TRIPPED ON FAULT
2882	19-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	18:05	18:50	00:45	LINE CLEAR AVAILED
2883	19-Apr-24	BENGALURU	LINE	66	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI	11:40	12:10	00:30	LINE CLEAR AVAILED
2884	19-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSAPALYA CIRCLE, MAGADI 66	17:18	17:38	00:20	TRIPPED ON FAULT
2885	19-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - VG DODDI - TG HALLI	TG HALLI, TAVAREKERE, VG DODDI	17:44	18:08	00:24	TRIPPED ON FAULT
2886	19-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	14:00	18:17	04:17	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2887	19-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:10	18:25	00:15	TRIPPED ON FAULT
2888	19-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SADHALI	DIBBURAHALLI, SADALI	18:53	19:06	00:13	TRIPPED ON FAULT
2889	19-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA	07:01	08:03	01:02	LINE CLEAR AVAILED
2890	19-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA,	11:27	11:55	00:28	TRIPPED ON FAULT
2891	19-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	07:01	07:02	00:01	LINE CLEAR AVAILED
2892	19-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 2	GUNDAMGERE, SASLU, AIR(EHT)	11:27	11:55	00:28	TRIPPED ON FAULT
2893	19-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENIGADALE	21:58	22:00	00:02	LINE CLEAR AVAILED
2894	19-Apr-24	BENGALURU	LINE	66	66KV RAYALAPADU - ADDAGAL	ADDAGAL, RAYALPADU	18:20	18:55	00:35	LINE CLEAR AVAILED
2895	19-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - G KODIHALLI	G KODIHALLI	18:48	19:31	00:43	TRIPPED ON FAULT
2896	19-Apr-24	BENGALURU	LINE	66	66KV T D HALLI (MALLASANDRA) - DALASANUR	NO STATION AFFECTED	17:00	18:10	01:10	LINE CLEAR AVAILED
2897	19-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI	18:10	18:48	00:38	LINE CLEAR AVAILED
2898	19-Apr-24	BENGALURU	LINE	66	66KV TALAGUNDA - VEMGAL	VEMGAL, KYALANUR	09:23	09:32	00:09	TRIPPED ON FAULT
2899	19-Apr-24	BENGALURU	LINE	66	66KV VEMGAL - KYALANUR	KYALANUR	13:12	13:25	00:13	LINE CLEAR AVAILED
2900	19-Apr-24	BENGALURU	LINE	66	66KV VOKKALERI - KC VALLEY	KC VALLEY PUMP HOUSE	00:00	23:59	23:59	TRIPPED ON FAULT
2901	19-Apr-24	BENGALURU	LINE	220	220KV NELAMANGALA 400 - ANTHAHRASANAHALLI (B1)	NO STATION AFFECTED	16:13	17:32	01:19	TRIPPED ON FAULT
2902	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ANJANAPURA	11:38	11:45	00:07	LINE CLEAR AVAILED
2903	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MELUR	17:05	17:21	00:16	TRIPPED ON FAULT
2904	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUNDAMGERE	06:05	07:35	01:30	LINE CLEAR AVAILED
2905	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUNDAMGERE	07:35	08:45	01:10	LINE CLEAR AVAILED
2906	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GUNDAMGERE	17:30	18:00	00:30	LINE CLEAR AVAILED
2907	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ADDAGAL	17:00	17:40	00:40	LINE CLEAR AVAILED
2908	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DALASANUR	17:40	17:50	00:10	LINE CLEAR AVAILED
2909	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWNIPALLI	12:15	12:35	00:20	LINE CLEAR AVAILED
2910	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	LAKSHMIPURA	11:50	12:25	00:35	LINE CLEAR AVAILED
2911	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MALLANAYAKANAHALLI	11:40	11:42	00:02	LINE CLEAR AVAILED
2912	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MUDIYANUR	13:05	13:06	00:01	LINE CLEAR AVAILED
2913	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	RAYALPADU	13:20	13:35	00:15	LINE CLEAR AVAILED
2914	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SRINIVASAPURA 66	15:21	15:50	00:29	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2915	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TADIGOLU CROSS	13:45	14:05	00:20	LINE CLEAR AVAILED
2916	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	THAYALUR	13:00	13:53	00:53	LINE CLEAR AVAILED
2917	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VOKKALERI	17:25	17:30	00:05	LINE CLEAR AVAILED
2918	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HUKUNDA	07:07	07:12	00:05	TRIPPED ON FAULT
2919	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	11:10	11:25	00:15	LINE CLEAR AVAILED
2920	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	14:45	15:45	01:00	LINE CLEAR AVAILED
2921	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	17:14	17:40	00:26	TRIPPED ON FAULT
2922	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	17:42	18:00	00:18	LINE CLEAR AVAILED
2923	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DABUSPETE 220	12:47	13:05	00:18	LINE CLEAR AVAILED
2924	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DABUSPETE 220	20:03	20:08	00:05	LINE CLEAR AVAILED
2925	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSAPALYA CIRCLE	12:05	12:10	00:05	TRIPPED ON FAULT
2926	19-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KEMPANAHALLI	02:30	02:40	00:10	TRIPPED ON FAULT
2927	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BAGEPALLI	18:10	18:25	00:15	TRIPPED ON FAULT
2928	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ADDAGAL	16:30	16:55	00:25	LINE CLEAR AVAILED
2929	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DALASANUR	17:05	17:35	00:30	LINE CLEAR AVAILED
2930	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GOWNIPALLI	11:40	12:10	00:30	LINE CLEAR AVAILED
2931	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	LAKSHMIPURA	12:30	12:50	00:20	LINE CLEAR AVAILED
2932	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MALLANAYAKANAHALLI	10:40	10:42	00:02	LINE CLEAR AVAILED
2933	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MUDIYANUR	12:15	12:17	00:02	LINE CLEAR AVAILED
2934	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	RAYALPADU	13:40	13:50	00:10	LINE CLEAR AVAILED
2935	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	RAYALPADU	19:00	20:45	01:45	LINE CLEAR AVAILED
2936	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TADIGOLU CROSS	14:05	14:15	00:10	LINE CLEAR AVAILED
2937	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	THAYALUR	13:55	14:37	00:42	LINE CLEAR AVAILED
2938	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VOKKALERI	15:30	15:35	00:05	LINE CLEAR AVAILED
2939	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YELDUR	09:15	10:00	00:45	LINE CLEAR AVAILED
2940	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DABUSPETE 220	12:47	13:05	00:18	LINE CLEAR AVAILED
2941	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DABUSPETE 220	20:03	20:08	00:05	LINE CLEAR AVAILED
2942	19-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	18:00	18:05	00:05	TRIPPED ON FAULT
2943	19-Apr-24	BENGALURU	TRANSFORMER	220	HV2	CHINTAMANI 220(NO LOAD AFFECTED)	14:54	23:59	09:05	TRIPPED ON FAULT
2944	19-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	18:30(19.04.2024)	10:28:00		TRIPPED ON FAULT
2945	19-Apr-2024	GULBARGA	LINE	110	HALBARGA-KOLHAR	KOLHAR_110	22:47	23:03	00:16	TRIPPED ON FAULT
2946	19-Apr-2024	GULBARGA	LINE	110	HALWARTHY-HIRESINDHOGI	HIRSINDHOGI_110	00:57	01:27	00:30	TRIPPED ON FAULT
2947	19-Apr-2024	GULBARGA	LINE	220	HALWARTHY-MSPL2	HALWARTHY_220	09:40	09:42	00:02	LINE CLEAR AVAILED
2948	19-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SHAHAPUR_220	13:40	18:45	05:05	LINE CLEAR AVAILED
2949	19-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	TEKKALKOTE_110	15:20(14.04.2024)	12:10(19.04.2024)	116:50:00	TRIPPED ON FAULT
2950	19-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	SHAHAPUR_220	12:16	18:50	06:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2951	19-Apr-24	HASSAN	LINE	66	BANDISH-ADANI	BANDISHETTIHALLY_66	19:00	20:45	01:45	MAIN SUPPLY FAILURE
2952	19-Apr-24	HASSAN	LINE	66	BANDISH-ADANI	BANDISHETTIHALLY_66	23:10	23:35	00:25	MAIN SUPPLY FAILURE
2953	19-Apr-24	HASSAN	LINE	66	BELUR66-HASSAN	BELUR_66	05:00	06:40	01:40	LINE CLEAR AVAIED
2954	19-Apr-24	HASSAN	LINE	66	BELUR66-MUDIGERE	BELUR_66	05:00	06:40	01:40	LINE CLEAR AVAIED
2955	19-Apr-24	HASSAN	LINE	66	BHADRA-LINGADAHALLI	gen_bhadra	19:55	20:38	00:43	MAIN SUPPLY FAILURE
2956	19-Apr-24	HASSAN	LINE	66	BHADRA-SHMG 1	gen_bhadra	16:40	22:37	05:57	TRIPPED ON FAULT
2957	19-Apr-24	HASSAN	LINE	66	BHADRA-SHMG 2	gen_bhadra	16:40	22:35	05:55	TRIPPED ON FAULT
2958	19-Apr-24	HASSAN	LINE	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	19:00	22:40	03:40	MAIN SUPPLY FAILURE
2959	19-Apr-24	HASSAN	LINE	66	DODDAKA-HNPURA	DODDAKADNUR_66	19:00(19.04.2024)			TRIPPED ON FAULT
2960	19-Apr-24	HASSAN	LINE	66	GENDEHA-MUDIGERE	GENDEHALLY_66	15:45	19:00	03:15	TRIPPED ON FAULT
2961	19-Apr-24	HASSAN	LINE	66	HASSN22-BELUR	HASSAN_220	19:05	21:16	02:11	LINE CLEAR AVAIED
2962	19-Apr-24	HASSAN	LINE	66	HASSN22-UDDUR	HASSAN_220	18:41	18:59	00:18	TRIPPED ON FAULT
2963	19-Apr-24	HASSAN	LINE	66	HASSN22-UDDUR	HASSAN_220	19:05	21:14	02:09	LINE CLEAR AVAIED
2964	19-Apr-24	HASSAN	LINE	66	HASSN22-UDDURKOPLU	HASSAN_220	19:05	21:14	02:09	LINE CLEAR AVAIED
2965	19-Apr-24	HASSAN	LINE	66	HNPR2-HASS1	HNPURA_220	19:00	23:33	04:33	MAIN SUPPLY FAILURE
2966	19-Apr-24	HASSAN	LINE	66	HNPR2-HASS2	HNPURA_220	19:00	23:37	04:37	MAIN SUPPLY FAILURE
2967	19-Apr-24	HASSAN	LINE	66	HNPR2-HASS3	HNPURA_220	19:00	23:45	04:45	MAIN SUPPLY FAILURE
2968	19-Apr-24	HASSAN	LINE	66	HNPR2-HNPR1	HNPURA_220	19:00	23:35	04:35	MAIN SUPPLY FAILURE
2969	19-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR1	HNPURA_220	19:00	19:10	00:10	MAIN SUPPLY FAILURE
2970	19-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR1	HNPURA_220	23:05	23:10	00:05	LINE CLEAR AVAIED
2971	19-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR2	HNPURA_220	19:00	23:58	04:58	MAIN SUPPLY FAILURE
2972	19-Apr-24	HASSAN	LINE	66	HNPR2-RNPR1	HNPURA_220	19:00	22:42	03:42	MAIN SUPPLY FAILURE
2973	19-Apr-24	HASSAN	LINE	66	HNPR2-RNPR1	HNPURA_220	23:10	23:35	00:25	LINE CLEAR AVAIED
2974	19-Apr-24	HASSAN	LINE	66	HNPR2-RNPR2	HNPURA_220	19:00	22:47	03:47	MAIN SUPPLY FAILURE
2975	19-Apr-24	HASSAN	LINE	66	HNPR2-RNPR2	HNPURA_220	23:10	23:35	00:25	TRIPPED ON FAULT
2976	19-Apr-24	HASSAN	LINE	66	HNPR2-RNPR2	HNPURA_220	19:00	23:35	04:35	MAIN SUPPLY FAILURE
2977	19-Apr-24	HASSAN	LINE	66	HNPURA-HNPR2	HNPURA_66	19:05	23:14	04:09	MAIN SUPPLY FAILURE
2978	19-Apr-24	HASSAN	LINE	66	HNPURA-RAMNATHPURA	HNPURA_66	19:05	23:35	04:30	MAIN SUPPLY FAILURE
2979	19-Apr-24	HASSAN	LINE	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:48	16:10	00:22	TRIPPED ON FAULT
2980	19-Apr-24	HASSAN	LINE	66	MALALI-CRPATNA	MALALI_66	19:00	22:27	03:27	MAIN SUPPLY FAILURE
2981	19-Apr-24	HASSAN	LINE	66	MALALI-HASSAN	MALALI_66	19:00	22:27	03:27	MAIN SUPPLY FAILURE
2982	19-Apr-24	HASSAN	LINE	66	SAKALE-IPCL2	SAKALESHPURA_66	14:40	16:06	01:26	LINE CLEAR AVAIED
2983	19-Apr-24	HASSAN	LINE	66	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	19:00	22:25	03:25	MAIN SUPPLY FAILURE
2984	19-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALLI	TAVARECHETTANAHALLY_66	17:08	18:11	01:03	TRIPPED ON FAULT
2985	19-Apr-24	HASSAN	LINE	66	UDDURKO-HASSAN1	UDDURKOPLU_66	19:00	21:15	02:15	MAIN SUPPLY FAILURE
2986	19-Apr-24	HASSAN	LINE	66	UDDURKO-HASSAN2	UDDURKOPLU_66	19:00	21:15	02:15	MAIN SUPPLY FAILURE
2987	19-Apr-24	HASSAN	LINE	110	ARSK2-ARSKR	ARSIKERE_20	15:31	16:40	01:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2988	19-Apr-24	HASSAN	LINE	110	ARSK2-GERUMARA	ARSIKERE_20	15:31	16:40	01:09	TRIPPED ON FAULT
2989	19-Apr-24	HASSAN	LINE	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	17:00(19.04.2024)			TRIPPED ON FAULT
2990	19-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANKERE_110	17:50	18:15	00:25	TRIPPED ON FAULT
2991	19-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANKERE_110	22:11	22:43	00:32	TRIPPED ON FAULT
2992	19-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANKERE_110	17:50	18:15	00:25	TRIPPED ON FAULT
2993	19-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANKERE_110	22:11	22:43	00:32	TRIPPED ON FAULT
2994	19-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANKERE_110	17:50	18:15	00:25	TRIPPED ON FAULT
2995	19-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANKERE_110	22:11	22:43	00:32	TRIPPED ON FAULT
2996	19-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	17:50	18:15	00:25	TRIPPED ON FAULT
2997	19-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	22:11	22:43	00:32	TRIPPED ON FAULT
2998	19-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	17:50	18:15	00:25	TRIPPED ON FAULT
2999	19-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	22:11	22:43	00:32	TRIPPED ON FAULT
3000	19-Apr-24	HASSAN	LINE	110	MRSSHM-GAJNUR	MRSMG_220	16:59(19.04.2024)			TRIPPED ON FAULT
3001	19-Apr-24	HASSAN	LINE	110	MRSSHM-RLW CBreaker	MRSMG_220	17:16	17:46	00:30	TRIPPED ON FAULT
3002	19-Apr-24	HASSAN	LINE	110	MRSSHM-RLW CBreaker	MRSMG_220	17:50	20:35	02:45	TRIPPED ON FAULT
3003	19-Apr-24	HASSAN	LINE	110	MRSSHM-SBT	MRSMG_220	15:15(19.04.2024)			TRIPPED ON FAULT
3004	19-Apr-24	HASSAN	LINE	110	SAGARA-HONALI	SAGARA_110	10:50	14:55	04:05	LINE CLEAR AVAILED
3005	19-Apr-24	HASSAN	LINE	110	SHRLKP-BARANG	SHIRALKOPPA_220	19:27	21:05	01:38	LINE CLEAR AVAILED
3006	19-Apr-24	HASSAN	LINE	110	SHRLKP-BELIGAVE ANVATTI	SHIRALKOPPA_220	18:32	18:56	00:24	TRIPPED ON FAULT
3007	19-Apr-24	HASSAN	LINE	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:27	20:58	01:31	LINE CLEAR AVAILED
3008	19-Apr-24	HASSAN	LINE	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	19:27	20:57	01:30	LINE CLEAR AVAILED
3009	19-Apr-24	HASSAN	LINE	110	SHRLKP-SORAB	SHIRALKOPPA_220	19:27	21:12	01:45	LINE CLEAR AVAILED
3010	19-Apr-24	HASSAN	LINE	220	ARSK2-SHMG	ARSIKERE_20	15:31	20:54	05:23	TRIPPED ON FAULT
3011	19-Apr-24	HASSAN	LINE	220	CHKNGR-L2	CHKINAGARA_220	20:42 (19.04.2024)			TRIPPED ON FAULT
3012	19-Apr-24	HASSAN	LINE	220	GOPALAP-BASTIPURA	GOPALAPURA_220	19:00	22:45	03:45	TRIPPED ON FAULT
3013	19-Apr-24	HASSAN	LINE	220	GOPALAP-HNPUR21	GOPALAPURA_220	21:10(19.04.2024)			LINE CLEAR AVAILED
3014	19-Apr-24	HASSAN	LINE	220	GOPALAP-HNPUR22	GOPALAPURA_220	21:10	22:50	01:40	LINE CLEAR AVAILED
3015	19-Apr-24	HASSAN	LINE	220	GOPALAP-HSN400	GOPALAPURA_220	19:00(19.04.2024)			TRIPPED ON FAULT
3016	19-Apr-24	HASSAN	LINE	220	HBNHL-L1	HEBBANAHALLY_400	20:42	23:04	02:22	TRIPPED ON FAULT
3017	19-Apr-24	HASSAN	LINE	220	HNPR2-GPLPR1	HNPURA_220	19:00(19.04.2024)			TRIPPED ON FAULT
3018	19-Apr-24	HASSAN	LINE	220	HNPR2-GPLPR2	HNPURA_220	19:00	23:25	04:25	MAIN SUPPLY FAILURE
3019	19-Apr-24	HASSAN	LINE	220	MRSSHM-ARSIKERE	MRSMG_220	15:31	20:54	05:23	TRIPPED ON FAULT
3020	19-Apr-24	HASSAN	LINE	220	MRSSHM-DAVANGERE	MRSMG_220	12:19	12:45	00:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3021	19-Apr-24	HASSAN	LINE	220	MRSSHM-SHARAVATHY3	MRSMSG_220	16:55(18.04.2024)	8:50(19.04.2024)	16:55hrs	LINE CLEAR AVAILED
3022	19-Apr-24	HASSAN	LINE	220	MRSSHM-VARAH1	MRSMSG_220	17:06(19.04.2024)			TRIPPED ON FAULT
3023	19-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIMOGA3	gen_sharavaty	16:55(18.04.2024)	8:50(19.04.2024)	16:55hrs	LINE CLEAR AVAILED
3024	19-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIRALKOPPA	gen_sharavaty	19:27(19.04.024)			TRIPPED ON FAULT
3025	19-Apr-24	HASSAN	LINE	220	SHRAVTY-TALAGUPPA 2	gen_sharavaty	18:22 (18.04.2024)	13:21 (19.04.2024)	18:59hrs	LINE CLEAR AVAILED
3026	19-Apr-24	HASSAN	LINE	220	SHRLKP-RANIBNR	SHIRALKOPPA_220	18:38	20:48	02:10	TRIPPED ON FAULT
3027	19-Apr-24	HASSAN	LINE	220	SHRLKP-SGS	SHIRALKOPPA_220	19:27(19.04.2024)			TRIPPED ON FAULT
3028	19-Apr-24	HASSAN	LINE	220	TALAGU-SGS1	TALAGUPPA_400	18:22 (18.04.2024)	13:21 (19.04.2024)	18:59hrs	LINE CLEAR AVAILED
3029	19-Apr-24	HASSAN	LINE	220	TALAGU-SGS2	TALAGUPPA_400	10:34	14:04	03:30	LINE CLEAR AVAILED
3030	19-Apr-24	HASSAN	LINE	220	VARAH1-SHIMOGA1	gen_varahi	17:06(19.04.2024)			TRIPPED ON FAULT
3031	19-Apr-24	HASSAN	TRANSFORMER	66	HV1	HANGARAHALLY_66	15:10	15:46	00:36	MAIN SUPPLY FAILURE
3032	19-Apr-24	HASSAN	TRANSFORMER	66	HV1	MALLAPURA-66	18:50	19:05	00:15	MAIN SUPPLY FAILURE
3033	19-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	12:05	12:10	00:05	MAIN SUPPLY FAILURE
3034	19-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	19:00	22:47	03:47	MAIN SUPPLY FAILURE
3035	19-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	23:10	23:35	00:25	MAIN SUPPLY FAILURE
3036	19-Apr-24	HASSAN	TRANSFORMER	66	HV2	HOLEHONNR_66	18:40	20:50	02:10	TRIPPED ON FAULT
3037	19-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	12:05	12:10	00:05	MAIN SUPPLY FAILURE
3038	19-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	19:00	22:47	03:47	MAIN SUPPLY FAILURE
3039	19-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	23:10	23:35	00:25	MAIN SUPPLY FAILURE
3040	19-Apr-24	HASSAN	TRANSFORMER	66	HV2	SBELAGOLA_66	10:52	12:02	01:10	LINE CLEAR AVAILED
3041	19-Apr-24	HASSAN	TRANSFORMER	66	HV4	BALEHONNUR_66	15:10	16:43	01:33	TRIPPED ON FAULT
3042	19-Apr-24	HASSAN	TRANSFORMER	66	Lv1	HNPURA_220	19:00	23:30	04:30	MAIN SUPPLY FAILURE
3043	19-Apr-24	HASSAN	TRANSFORMER	66	Lv2	HNPURA_220	19:00	23:30	04:30	MAIN SUPPLY FAILURE
3044	19-Apr-24	HASSAN	TRANSFORMER	66	LV4	MRSMSG_220	11:30	15:23	03:53	LINE CLEAR AVAILED
3045	19-Apr-24	HASSAN	TRANSFORMER	110	HV3	BAIKAMPADY_110	13:27	13:32	00:05	TRIPPED ON FAULT
3046	19-Apr-24	HASSAN	TRANSFORMER	110	HV3	SHIRALKOPPA_110	18:40	21:05	02:25	TRIPPED ON FAULT
3047	19-Apr-24	HASSAN	TRANSFORMER	110	LV2	SHIRALKOPPA_220	19:27	20:58	01:31	LINE CLEAR AVAILED
3048	19-Apr-24	HASSAN	TRANSFORMER	220	HV1	HNPURA_220	19:00	23:30	04:30	MAIN SUPPLY FAILURE
3049	19-Apr-24	HASSAN	TRANSFORMER	220	HV2	GOPALAPURA_220	21:10(19.04.2024)			LINE CLEAR AVAILED
3050	19-Apr-24	HASSAN	TRANSFORMER	220	HV2	HNPURA_220	19:00	23:30	04:30	MAIN SUPPLY FAILURE
3051	19-Apr-24	HASSAN	TRANSFORMER	220	HV4	MRSMSG_220	11:30	15:17	03:47	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3052	19-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-KADKOLA	NO STATIONS EFFECTED	11:20	17:16	05:55	LINE CLEAR AVAILED
3053	19-Apr-24	MYSORE	LINE	66	FTS-HOTGALLY2	NO STATIONS EFFECTED	18:25:31	18:34	00:09	LINE CLEAR AVAILED
3054	19-Apr-24	MYSORE	LINE	66	GARUDANAUKKADA-PANDAVAPURA	NO STATIONS EFFECTED	00:00	14:12	14:12	LINE CLEAR AVAILED
3055	19-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
3056	19-Apr-24	MYSORE	LINE	66	HOTAGALLY-BOGADHI	BOGADHI_66 KALAMANDIR_66 MYSORESOUTH_66	09:27	09:29	00:02	LINE CLEAR AVAILED
3057	19-Apr-24	MYSORE	LINE	66	HOTAGALLY-BOGADHI	BOGADHI_66	11:46	17:08	05:22	LINE CLEAR AVAILED
3058	19-Apr-24	MYSORE	LINE	66	HUNSUR-KAMPLAPURA	PERIYAPATNA_66 PONNAMPETE_66 VIRAJPETE_66 KAMPLAPURA_66	19:06	19:24	00:18	TRIPPED ON FAULT
3059	19-Apr-24	MYSORE	LINE	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	09:48	11:10	01:22	LINE CLEAR AVAILED
3060	19-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3061	19-Apr-24	MYSORE	LINE	66	KRPETE-KIKKERI	KIKKERI_66	18:55:00 (19/04/2024)			TRIPPED ON FAULT
3062	19-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-BETTADAPURA	NO STATIONS EFFECTED	19:06	20:08	01:02	TRIPPED ON FAULT
3063	19-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MADIKERI 1	NO STATIONS EFFECTED	19:05:00 (19/04/2024)			TRIPPED ON FAULT
3064	19-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
3065	19-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-PERIPATNA-1	NO STATIONS EFFECTED	13:51	13:57	00:06	TRIPPED ON FAULT
3066	19-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-PERIPATNA-2	BYLUKUPPE_66	18:28	18:57	00:29	TRIPPED ON FAULT
3067	19-Apr-24	MYSORE	LINE	66	PERIAPATNA-KUSHALNAGARA2	PERIYAPATNA_66 PONNAMPETE_66 VIRAJPETE_66 KAMPLAPURA_66	19:07:55	19:24:50	00:16:55	TRIPPED ON FAULT
3068	19-Apr-24	MYSORE	LINE	66	PONNAMPETE-VIRAJPETE	VIRAJPET_66	20:27 (18/04/2024)	14:03:00 (19/04/2024)	17:36	TRIPPED ON FAULT
3069	19-Apr-24	MYSORE	LINE	66	SANTHEBACHALLI-HARIYALDAMMA	HARIYALDAMMA_66	20:34	21:34	01:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3070	19-Apr-24	MYSORE	LINE	66	SANTHEBACHALLI-HYUGONAHALLI 1	ADDIHALLI_66 HARIYALDAMMA_66 SANTEBACHALLI_66	18:30	18:49	00:19	TRIPPED ON FAULT
3071	19-Apr-24	MYSORE	LINE	66	SANTHEBACHALLI-HYUGONAHALLI 1	ADDIHALLI_66 HARIYALDAMMA_66 SANTEBACHALLI_66	20:34	20:51	00:17	TRIPPED ON FAULT
3072	19-Apr-24	MYSORE	LINE	66	SANTHEBACHALLI-HYUGONAHALLI 2	ADDIHALLI_66 HARIYALDAMMA_66 SANTEBACHALLI_66	18:30	18:49	00:19	TRIPPED ON FAULT
3073	19-Apr-24	MYSORE	LINE	66	SANTHEBACHALLI-HYUGONAHALLI 2	ADDIHALLI_66 HARIYALDAMMA_66 SANTEBACHALLI_66	20:34	20:51	00:17	TRIPPED ON FAULT
3074	19-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	21:17 (18/04/2024)			TRIPPED ON FAULT
3075	19-Apr-24	MYSORE	LINE	66	SUTTUR-SUTTUR WATER SUPPLY	NO STATIONS EFFECTED	16:50	17:07	00:17	TRIPPED ON FAULT
3076	19-Apr-24	MYSORE	LINE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66	06:40	14:33	07:53	LINE CLEAR AVAILED
3077	19-Apr-24	MYSORE	LINE	66	VAJMANGALA-KADKOLA1	AYRAHALLI_66 MARADIHUNDI_66	05:33	05:44	00:11	TRIPPED ON FAULT
3078	19-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:42:00 (19/04/2024)			LINE CLEAR AVAILED
3079	19-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:52 (18/04/2024)	7:25:00 (19/04/2024)	10:32	LINE CLEAR AVAILED
3080	19-Apr-24	MYSORE	LINE	220	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	19:00	21:27	02:27	TRIPPED ON FAULT
3081	19-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDGERE_66	19:00:00 (19/04/2024)			LINE CLEAR AVAILED
3082	19-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3083	19-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGOD_66	16:39	17:18	00:39	LINE CLEAR AVAILED
3084	19-Apr-24	MYSORE	TRANSFORMER	66	HV2	MEGHALAPURA_66	22:48	22:53	00:05	TRIPPED ON FAULT
3085	19-Apr-24	MYSORE	TRANSFORMER	66	HV2	HOSURGATE_66	09:30	09:35	00:05	TRIPPED ON FAULT
3086	19-Apr-24	MYSORE	TRANSFORMER	66	HV2	GUNDLUPETE_66	16:40	17:10	00:30	LINE CLEAR AVAILED
3087	19-Apr-24	MYSORE	TRANSFORMER	220	HV3	HOOTAGALLY_220	22:54 (18/04/2024)	0:30:00 (19/04/2024)	15:38	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3088	19-Apr-24	MYSORE	TRANSFORMER	220	KUSHALNAGARA-HV1	ALURSIDDAPURA_66 KANAGALU_66 CHIKKABOMMANAHLI_66 RUDRAPATNA_66 MIRLE_66 PERIYAPATNA_66 PONNAMPETE_66 MADIKERI_66 SRIMANGALA_66 VIRAJPETE_66 BYLUKUPPE_66 SUNTIKOPPA_66	19:06	19:48	00:42	TRIPPED ON FAULT
3089	19-Apr-24	MYSORE	TRANSFORMER	220	KUSHALNAGARA-HV1	NO STATIONS EFFECTED	22:06:00 (19/04/2024)			TRIPPED ON FAULT
3090	19-Apr-24	MYSORE	TRANSFORMER	220	KUSHALNAGARA-HV2	ALURSIDDAPURA_66 KANAGALU_66 CHIKKABOMMANAHLI_66 RUDRAPATNA_66 MIRLE_66 PERIYAPATNA_66 PONNAMPETE_66 MADIKERI_66 SRIMANGALA_66 VIRAJPETE_66 BYLUKUPPE_66 SUNTIKOPPA_66	19:06	19:48	00:42	TRIPPED ON FAULT
3091	19-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220- HEBBUR	HEBBUR_66, HONNENAHLI_66, THIMMASANDRA_66	16:51	17:52	01:01	TRIPPED ON FAULT
3092	19-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66,	17:17	17:38	00:21	TRIPPED ON FAULT
3093	19-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	16:32	17:01	00:29	TRIPPED ON FAULT
3094	19-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	00:00	00:10	00:10	TRIPPED ON FAULT
3095	19-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	04:54	05:04	00:10	TRIPPED ON FAULT
3096	19-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- PANDARAHALLI 2	HIREGUNTANUR_66, CHITRAHALLI_66, PANDARAHALLI_66, HD PURA_66	15:09	15:39	00:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3097	19-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 1	PANDARAHALLI_66, HOLALKERE_66	15:29	15:44	00:15	TRIPPED ON FAULT
3098	19-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRAHALLI_66,HD PURA_66	15:40	16:07	00:27	TRIPPED ON FAULT
3099	19-Apr-24	TUMKUR	LINE	66	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	15:40	16:10	00:30	MAIN SUPPLY FAILURE
3100	19-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR NEW_66	20:18	20:51	00:33	TRIPPED ON FAULT
3101	19-Apr-24	TUMKUR	LINE	66	DEVARAHALLI- SANTHEBENNUR	SANTHEBENNUR_66, KEREILCI_66	17:00	17:20	00:20	TRIPPED ON FAULT
3102	19-Apr-24	TUMKUR	LINE	66	HANAGAL- RAMPURA	NAGASAMUDRA_66. RAMPURA	10:15	10:23	00:08	TRIPPED ON FAULT
3103	19-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	08:00	16:00	08:00	LINE CLEAR AVAILED
3104	19-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	HARIYABBE_66,PDKOT E_66	08:00	16:00	08:00	LINE CLEAR AVAILED
3105	19-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- HOLAVINHALLI	HOLAVINAHALLI_66, KORATAGERE_66, BELADARA_66	09:01	09:18	00:16	TRIPPED ON FAULT
3106	19-Apr-24	TUMKUR	LINE	66	RAMAGIRI_66-HOSADURGA_66	RAMAGIRI_66, CHIKKAJAJURU_66	20:15	20:30	00:15	TRIPPED ON FAULT
3107	19-Apr-24	TUMKUR	LINE	66	RAMAGIRI-BAGUR LINE	RAMAGIRI_66, ENERCON_IPP_66	20:15	20:30	00:15	TRIPPED ON FAULT
3108	19-Apr-24	TUMKUR	LINE	66	SOKKE-BILCHODU	BILCHODU_66, PALLAGATTE_66	17:00	17:15	00:15	TRIPPED ON FAULT
3109	19-Apr-24	TUMKUR	LINE	66	SOKKE-BILCHODU	BILCHODU_66, PALLAGATTE_66	22:00	22:10	00:10	TRIPPED ON FAULT
3110	19-Apr-24	TUMKUR	LINE	220	BENKIKERE 220kV-HOSADURGA LINE 1 (MADHURE)	HOSADURGA_220	16:37	17:22	00:45	TRIPPED ON FAULT
3111	19-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	18:13	18:29	00:16	TRIPPED ON FAULT
3112	19-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI2	HONNALLI_220	20:20	20:45	00:25	LINE CLEAR AVAILED
3113	19-Apr-24	TUMKUR	LINE	220	GUTTUR 220KV- GUTTUR400KV LINE1	GUTTUR_66, HARIHARA HOSPET	18:13	19:07	00:54	TRIPPED ON FAULT
3114	19-Apr-24	TUMKUR	LINE	220	GUTTUR 220KV- GUTTUR400KV LINE2	GUTTUR_66, HARIHARA HOSPET	18:13	19:09	00:56	TRIPPED ON FAULT
3115	19-Apr-24	TUMKUR	LINE	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	18:13(19.04.24)		-	TRIPPED ON FAULT
3116	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRAHALI_66	10:15	10:20	00:05	TRIPPED ON FAULT
3117	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRAHALI_66	15:20	15:25	00:05	TRIPPED ON FAULT
3118	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	DAVANAGERE_66	20:20	20:42	00:22	LINE CLEAR AVAILED
3119	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	GARAG_66	00:03	00:08	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3120	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	GARAG_66	11:28	11:42	00:14	TRIPPED ON FAULT
3121	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	KOLALA_66	16:30		-	TRIPPED ON FAULT
3122	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	MATHOD_66	14:01	14:12	00:11	TRIPPED ON FAULT
3123	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	TAVAREKERE_66	06:03	06:08	00:05	TRIPPED ON FAULT
3124	19-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	RAMPURA_66	12:15	13:20	01:05	LINE CLEAR AVAILED
3125	19-Apr-24	TUMKUR	TRANSFORMER	220	HV-1	DAVANAGERE_220	20:20	20:42	00:22	LINE CLEAR AVAILED
3126	19-Apr-24	TUMKUR	TRANSFORMER	220	HV-2	DAVANAGERE_220	20:20	20:42	00:22	LINE CLEAR AVAILED
3127	19-Apr-24	TUMKUR	TRANSFORMER	220	HV-3	DAVANAGERE_220	20:20	20:42	00:22	LINE CLEAR AVAILED
3128	19-Apr-24	TUMKUR	TRANSFORMER	400	HV-2	GUTTUR_400KV	20:16	23:53	03:37	TRIPPED ON FAULT
3129	20-Apr-24	BAGALKOTE	LINE	110	220KV ATHANI-110KV ATHANI	ATHANI_220	05:00	06:12	01:12	TRIPPED ON FAULT
3130	20-Apr-24	BAGALKOTE	LINE	110	220KV ATHANI-AIGALI1	ATHANI_220	11:45	11:57	00:12	TRIPPED ON FAULT
3131	20-Apr-24	BAGALKOTE	LINE	110	220KV ATHANI-AIGALI2	ATHANI_220	11:45	11:57	00:12	TRIPPED ON FAULT
3132	20-Apr-24	BAGALKOTE	LINE	110	220KVBELAGAVI-HUDALI	BELAGAVI_220	10:12	17:06	06:54	LINE CLEAR AVAILED
3133	20-Apr-24	BAGALKOTE	LINE	110	220KVMUGALKHOD-HALLUR	MUGALKHOD_220	05:45	05:59	00:14	TRIPPED ON FAULT
3134	20-Apr-24	BAGALKOTE	LINE	110	220KVSIRSI-KAVALWADA	SIRSI_220	16:15	17:14	00:59	LINE CLEAR AVAILED
3135	20-Apr-24	BAGALKOTE	LINE	110	220KVSIRSI-UMACHAGI	SIRSI_220	16:15	17:14	00:59	LINE CLEAR AVAILED
3136	20-Apr-24	BAGALKOTE	LINE	110	22KVAMBEWADI-NK 2	AMBEWADI_220	16:23	16:26	00:03	LINE CLEAR AVAILED
3137	20-Apr-24	BAGALKOTE	LINE	110	22KVAMBEWADI-NK 2	AMBEWADI_220	17:00	17:02	00:02	LINE CLEAR AVAILED
3138	20-Apr-24	BAGALKOTE	LINE	110	ALBAL-SPRSCBreaker	ALBAL_110	12:02	12:12	00:10	TRIPPED ON FAULT
3139	20-Apr-24	BAGALKOTE	LINE	110	ANKALAGI-I/CLINEBELGAUM2 (HUDALI)	ANKALAGI_110	09:48	12:09	02:21	LINE CLEAR AVAILED
3140	20-Apr-24	BAGALKOTE	LINE	110	ANKOLA-KUMTA(L2)	STATION NOT AFFECTED ANKOLA_110	07:06	15:45	08:39	TRIPPED ON FAULT
3141	20-Apr-24	BAGALKOTE	LINE	110	ANMOD- SUPA2	ANMOD_110	12:10 (19.04.2024)	16:50 (20.04.2024)	28:40:00	TRIPPED ON FAULT
3142	20-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3143	20-Apr-24	BAGALKOTE	LINE	110	BANAHA-110KVO/GJAMAKAN (NAVALAGI)	NAVALAGI_110	12:42	13:32	00:50	LINE CLEAR AVAILED
3144	20-Apr-24	BAGALKOTE	LINE	110	BILAGI-KATARKI (GIRISAGAR)	BILAGI_110,GIRISAGAR_110	05:38	05:45	00:07	TRIPPED ON FAULT
3145	20-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
3146	20-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	STATION NOT AFFECTED DAMBAL_110	8:21 (20.04.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3147	20-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
3148	20-Apr-24	BAGALKOTE	LINE	110	HONNAVAR-MURUDESWAR	STATION NOT AFFECTED HONNAVAR_110	07:40	11:33	03:53	TRIPPED ON FAULT
3149	20-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3150	20-Apr-24	BAGALKOTE	LINE	110	HUDALI-ANKALAGI	HUDALI_110	09:49	17:15	07:26	LINE CLEAR AVAILED
3151	20-Apr-24	BAGALKOTE	LINE	110	HUDALI-BSPL IPP	BSPL IPP_110 HUDALI_110	09:51	17:21	07:30	LINE CLEAR AVAILED
3152	20-Apr-24	BAGALKOTE	LINE	110	HUDLI-BELAGAVI220	HUDALI_110	10:03	17:07	07:04	LINE CLEAR AVAILED
3153	20-Apr-24	BAGALKOTE	LINE	110	JAMAKHANDI-MLPURA (NAVALAGI)	JAMAKHANDI_110	13:02	15:09	02:07	LINE CLEAR AVAILED
3154	20-Apr-24	BAGALKOTE	LINE	110	KAVALWADA-NK 2	KAVALWAD_110	16:22	16:25	00:03	MAIN SUPPLY FAILURE
3155	20-Apr-24	BAGALKOTE	LINE	110	KAVALWADA-NK 2	KAVALWAD_110	16:59	17:02	00:03	MAIN SUPPLY FAILURE
3156	20-Apr-24	BAGALKOTE	LINE	110	KIRUVATTI- UMMACHAGI	STATION NOT AFFECTED KIRUVATTI_110	17:42 (18.04.2024)	11:45 (20.04.2024)	42:03:00	LINE CLEAR AVAILED
3157	20-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
3158	20-Apr-24	BAGALKOTE	LINE	110	KUMTA-HONNAVAR	KUMTA-110	07:14	11:26	04:12	TRIPPED ON FAULT
3159	20-Apr-24	BAGALKOTE	LINE	110	KUMTA-SIRSI1	KUMTA-110	16:32	17:43	01:11	LINE CLEAR AVAILED
3160	20-Apr-24	BAGALKOTE	LINE	110	LAXMESHWER-GADAG1	LAXMESHWER_110	09:00	10:03	01:03	TRIPPED ON FAULT
3161	20-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3162	20-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3163	20-Apr-24	BAGALKOTE	LINE	110	NAVALAGI-BANAHATTI	NAVALAGI_110	12:31	13:34	01:03	LINE CLEAR AVAILED
3164	20-Apr-24	BAGALKOTE	LINE	110	NAVALAGI-JAMAKHANDI	NAVALAGI_110	12:31	13:47	01:16	LINE CLEAR AVAILED
3165	20-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3166	20-Apr-24	BAGALKOTE	LINE	110	SIRSI-KUMTA2	SIRSI_110	06:22	06:45	00:23	TRIPPED ON FAULT
3167	20-Apr-24	BAGALKOTE	LINE	110	SIRSI-KUMTA2	SIRSI_110	06:46	17:39	10:53	TRIPPED ON FAULT
3168	20-Apr-24	BAGALKOTE	LINE	110	SIRSI-KUMTA2	SIRSI_110	17:40	19:32	01:52	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3169	20-Apr-24	BAGALKOTE	LINE	110	TODALBAGI-JAMAKHANDI SUGARS	JAMKAHANDI SUGARS_110 TODALBAGI_110	11:45	12:30	00:45	TRIPPED ON FAULT
3170	20-Apr-24	BAGALKOTE	LINE	110	UMMACHAGI-KIRVATTI	UMMACHAGI_110	11:00	19:50	08:50	LINE CLEAR AVAILED
3171	20-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3172	20-Apr-24	BAGALKOTE	LINE	110	YELLAMMANAWADI-F2 (SAVALAGI)	YELLAMMANAWADI_110	11:45	12:04	00:19	TRIPPED ON FAULT
3173	20-Apr-24	BAGALKOTE	LINE	220	NARENDRA-GHATAPRABHA2	GHATAPRABHA_220	07:40	08:09	00:29	TRIPPED ON FAULT
3174	20-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3175	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED ALNAVAR_110	21:40 (20.04.2024)			TRIPPED ON FAULT
3176	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	HUDALI_110	10:02	17:12	07:10	LINE CLEAR AVAILED
3177	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	MALAGHAN (B)_110	12:52	15:03	02:11	TRIPPED ON FAULT
3178	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	LAXMESHWER_110	13:27	13:30	00:03	LINE CLEAR AVAILED
3179	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	HALIYAL_110	06:50	06:55	00:05	TRIPPED ON FAULT
3180	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	HALIYAL_110	07:15	07:22	00:07	TRIPPED ON FAULT
3181	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	HALIYAL_110	12:30	00:00	11:30	TRIPPED ON FAULT
3182	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	RAIBAG_110	14:11	17:45	03:34	LINE CLEAR AVAILED
3183	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	MKHUBLI_110	07:12	08:11	00:59	TRIPPED ON FAULT
3184	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	STATION NOT AFFECTED GADAG_110	23:57 (19.04.2024)	00:21 (20.04.2024)	0:24:00	TRIPPED ON FAULT
3185	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10 MVA)	BAGALKOT_220	10:59	12:52	01:53	LINE CLEAR AVAILED
3186	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	HUDALI_110	10:02	17:09	07:07	LINE CLEAR AVAILED
3187	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	NAVANAGAR(BGK)_110	11:06	11:32	00:26	TRIPPED ON FAULT
3188	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	NAVANAGAR(BGK)_110	11:39	12:25	00:46	TRIPPED ON FAULT
3189	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	NAVANAGAR(BGK)_110	14:50	15:13	00:23	TRIPPED ON FAULT
3190	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MALAGHAN (S)_110	16:42	16:49	00:07	TRIPPED ON FAULT
3191	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	RON_110	07:15	08:40	01:25	TRIPPED ON FAULT
3192	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	LAXMESHWER_110	13:27	13:30	00:03	LINE CLEAR AVAILED
3193	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	NAVALAGI_110	10:01	14:42	04:41	LINE CLEAR AVAILED
3194	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	NAVALAGI_110	11:00	14:21	03:21	LINE CLEAR AVAILED
3195	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	AREMALLAPUR_110	11:23	11:59	00:36	LINE CLEAR AVAILED
3196	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	BILAGI_110	13:13	13:20	00:07	TRIPPED ON FAULT
3197	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	HEBBALLI_110	09:42	09:52	00:10	TRIPPED ON FAULT
3198	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(10MVA)	GADAG_110	00:53	00:57	00:04	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3199	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	AKSHYACOLONY _110	10:16	11:43	01:27	TRIPPED ON FAULT
3200	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (10MVA)	SHIGGAON_110	00:44	00:54	00:10	TRIPPED ON FAULT
3201	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA)	LAXMESHWER_110	13:27	13:30	00:03	LINE CLEAR AVAILED
3202	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4 (20MVA)	HIDIKAL_110	11:51	12:50	00:59	LINE CLEAR AVAILED
3203	20-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4 (20MVA)	HIDIKAL_110	13:51	14:42	00:51	LINE CLEAR AVAILED
3204	20-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1 & HV2	SIRSI_220	16:15	16:25	00:10	LINE CLEAR AVAILED
3205	20-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1 & HV2	SIRSI_220	17:04	17:14	00:10	LINE CLEAR AVAILED
3206	20-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1 & LV1 (100 MVA)	BIJAPUR_220	03:21	03:32	00:11	TRIPPED ON FAULT
3207	20-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2 & LV2 (100 MVA)	BIJAPUR_220	03:21	03:42	00:21	TRIPPED ON FAULT
3208	20-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3209	20-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	MULBAGAL	12:05	12:40	00:35	LINE CLEAR AVAILED
3210	20-Apr-24	BENGALURU	LINE	66	66KV BOMMEPALLI - YENNIGADALE	BOMMEPALLI	15:14	15:15	00:01	LINE CLEAR AVAILED
3211	20-Apr-24	BENGALURU	LINE	66	66KV BOMMEPALLI - YENNIGADALE	YENNIGADALE	15:17	15:20	00:03	LINE CLEAR AVAILED
3212	20-Apr-24	BENGALURU	LINE	66	66KV BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	15:57	16:02	00:05	LINE CLEAR AVAILED
3213	20-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA, KALYANI TECH PARK, ORACLE(EHT)	13:04	13:40	00:36	LINE CLEAR AVAILED
3214	20-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	14:33	14:38	00:05	LINE CLEAR AVAILED
3215	20-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	12:05	12:15	00:10	LINE CLEAR AVAILED
3216	20-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	02:40	03:00	00:20	TRIPPED ON FAULT
3217	20-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDHURASHWATHA, GUNDLU KOTTUR	09:43	10:01	00:18	TRIPPED ON FAULT
3218	20-Apr-24	BENGALURU	LINE	66	66KV HSR 220 - ADUGODI	ADUGODI	14:49	17:01	02:12	TRIPPED ON FAULT
3219	20-Apr-24	BENGALURU	LINE	66	66KV HULLENAHALLI - KUDURU	KUDUR, SRIGIRIPURA	16:39	17:05	00:26	TRIPPED ON FAULT
3220	20-Apr-24	BENGALURU	LINE	66	66KV ITI 220 - POTTERY ROAD MUSS	POTTERY ROAD	21:41	22:25	00:44	TRIPPED ON FAULT
3221	20-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	15:04	15:25	00:21	MAIN SUPPLY FAILURE
3222	20-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - FALSON CITY	PRESTIGE FALCON CITY	15:04	15:59	00:55	TRIPPED ON FAULT
3223	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - BANGARPET 2	BANGARPETE	16:24	16:38	00:14	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3224	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - KEMBODI	KEMBODI	08:00	09:05	01:05	LINE CLEAR AVAILED
3225	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA	TAMAKA	15:30	15:42	00:12	LINE CLEAR AVAILED
3226	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA	TAMAKA	07:10	08:00	00:50	LINE CLEAR AVAILED
3227	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA - DRDO	DRDO, MALLASANDRA	14:40	15:21	00:41	LINE CLEAR AVAILED
3228	20-Apr-24	BENGALURU	LINE	66	66KV KOLAR - VOKKALERI	VOKKALERI	17:08	17:22	00:14	LINE CLEAR AVAILED
3229	20-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	07:05	07:50	00:45	TRIPPED ON FAULT
3230	20-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	03:20	03:26	00:06	TRIPPED ON FAULT
3231	20-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	15:00	17:00	02:00	LINE CLEAR AVAILED
3232	20-Apr-24	BENGALURU	LINE	66	66KV NARASAPURA - KC VALLEY (EHT)	KC VALLEY	12:10	13:00	00:50	LINE CLEAR AVAILED
3233	20-Apr-24	BENGALURU	LINE	66	66KV NARASAPURA - WISTRON (EHT)	WISTRON	13:15	13:45	00:30	LINE CLEAR AVAILED
3234	20-Apr-24	BENGALURU	LINE	66	66KV NIMHANS 220 - JAYADEVA	JAYADEVA	12:41	12:47	00:06	LINE CLEAR AVAILED
3235	20-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	17:05	17:24	00:19	TRIPPED ON FAULT
3236	20-Apr-24	BENGALURU	LINE	66	66KV PATHPALYA - THIMMAMPALLI	THIMMAMPALLI	21:40	22:00	00:20	TRIPPED ON FAULT
3237	20-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	16:43	17:04	00:21	LINE CLEAR AVAILED
3238	20-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 1	JAYADEVA	15:06	15:20	00:14	MAIN SUPPLY FAILURE
3239	20-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 1	SARAKKI	12:01	12:10	00:09	LINE CLEAR AVAILED
3240	20-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 2	JAYADEVA	15:06	15:20	00:14	MAIN SUPPLY FAILURE
3241	20-Apr-24	BENGALURU	LINE	66	66KV SARAKKI - JAYADEVA 2	SARAKKI	12:01	12:10	00:09	LINE CLEAR AVAILED
3242	20-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:15	11:23	00:08	LINE CLEAR AVAILED
3243	20-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:15	11:25	00:10	LINE CLEAR AVAILED
3244	20-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:29	11:44	00:15	LINE CLEAR AVAILED
3245	20-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR	13:00	13:10	00:10	LINE CLEAR AVAILED
3246	20-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	15:04	15:48	00:44	MAIN SUPPLY FAILURE
3247	20-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	12:30	12:33	00:03	LINE CLEAR AVAILED
3248	20-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	11:48	11:59	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3249	20-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL TECH PARK	15:04	15:22	00:18	MAIN SUPPLY FAILURE
3250	20-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	15:04	15:21	00:17	MAIN SUPPLY FAILURE
3251	20-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	BYRAKUR	15:55	17:00	01:05	LINE CLEAR AVAIED
3252	20-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	09:15	09:24	00:09	MAIN SUPPLY FAILURE
3253	20-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	16:00	17:38	01:38	LINE CLEAR AVAIED
3254	20-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	16:13	17:38	01:25	LINE CLEAR AVAIED
3255	20-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	09:16	09:25	00:09	MAIN SUPPLY FAILURE
3256	20-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	09:16	09:25	00:09	MAIN SUPPLY FAILURE
3257	20-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	13:43	13:56	00:13	MAIN SUPPLY FAILURE
3258	20-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	MUDIYANUR	17:40	18:10	00:30	LINE CLEAR AVAIED
3259	20-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	02:40	23:59	21:19	TRIPPED ON FAULT
3260	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	13:06	13:19	00:13	LINE CLEAR AVAIED
3261	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	13:46	13:50	00:04	LINE CLEAR AVAIED
3262	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	13:06	13:19	00:13	LINE CLEAR AVAIED
3263	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	13:46	13:50	00:04	LINE CLEAR AVAIED
3264	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	13:06	13:19	00:13	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3265	20-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	13:46	13:50	00:04	LINE CLEAR AVAILED
3266	20-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	12:32	13:03	00:31	TRIPPED ON FAULT
3267	20-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - MYLASANDRA 2	KHODAYS 220, SUBRAMANYAPURA 220	15:04	15:25	00:21	TRIPPED ON FAULT
3268	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BANASAWADI	08:25	08:28	00:03	LINE CLEAR AVAILED
3269	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BANASAWADI	16:06	16:10	00:04	LINE CLEAR AVAILED
3270	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HEBBALA 220	15:30	15:49	00:19	TRIPPED ON FAULT
3271	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MAHALAKSHMI LAYOUT	11:05	11:55	00:50	LINE CLEAR AVAILED
3272	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VICTORIA HOSPITAL	22:04	22:06	00:02	LINE CLEAR AVAILED
3273	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BYRAKUR	15:10	16:10	01:00	LINE CLEAR AVAILED
3274	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NARASAPURA	16:10	16:15	00:05	LINE CLEAR AVAILED
3275	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SM MANGALA	11:45	11:55	00:10	LINE CLEAR AVAILED
3276	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	YELDUR	07:45	08:25	00:40	LINE CLEAR AVAILED
3277	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VR DODDI	06:21	06:31	00:10	TRIPPED ON FAULT
3278	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KEMPANAHALLI	09:07	09:25	00:18	TRIPPED ON FAULT
3279	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	11:15	11:24	00:09	LINE CLEAR AVAILED
3280	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	YARANDANAHALLI 220	11:34	11:37	00:03	LINE CLEAR AVAILED
3281	20-Apr-24	BENGALURU	TRANSFORMER	66	HV1	YARANDANAHALLI 220	15:10	15:17	00:07	TRIPPED ON FAULT
3282	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAHALAKSHMI LAYOUT	11:05	11:55	00:50	LINE CLEAR AVAILED
3283	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NRS 220	22:09	22:17	00:08	LINE CLEAR AVAILED
3284	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVARABISANAHALLI	14:50	15:00	00:10	TRIPPED ON FAULT
3285	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVANAHALLI 66	17:00	17:20	00:20	TRIPPED ON FAULT
3286	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DODDABELAVANGALA	19:43	19:53	00:10	TRIPPED ON FAULT
3287	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NARASAPURA	16:50	16:55	00:05	LINE CLEAR AVAILED
3288	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VOKKALERI	23:15	23:30	00:15	TRIPPED ON FAULT
3289	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BANGARPETE	16:40	17:00	00:20	LINE CLEAR AVAILED
3290	20-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HUKUNDA	09:33	09:38	00:05	TRIPPED ON FAULT
3291	20-Apr-24	BENGALURU	TRANSFORMER	66	HV3	BANASAWADI	08:25	08:28	00:03	LINE CLEAR AVAILED
3292	20-Apr-24	BENGALURU	TRANSFORMER	66	HV3	BANASAWADI	16:06	16:10	00:04	LINE CLEAR AVAILED
3293	20-Apr-24	BENGALURU	TRANSFORMER	220	HV1	KHODAYS 220	15:04	15:25	00:21	TRIPPED ON FAULT
3294	20-Apr-24	BENGALURU	TRANSFORMER	220	HV1	SUBRAMANYAPURA 220	15:04	15:20	00:16	MAIN SUPPLY FAILURE
3295	20-Apr-24	BENGALURU	TRANSFORMER	220	HV2	KHODAYS 220	15:04	15:25	00:21	TRIPPED ON FAULT
3296	20-Apr-24	BENGALURU	TRANSFORMER	220	HV2	SUBRAMANYAPURA 220	15:04	15:21	00:17	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3297	20-Apr-24	BENGALURU	TRANSFORMER	220	HV2	T GOLLAHALLI 220	09:16	09:25	00:09	TRIPPED ON FAULT
3298	20-Apr-24	BENGALURU	TRANSFORMER	220	HV3	SUBRAMANYAPURA 220	15:04	15:22	00:18	MAIN SUPPLY FAILURE
3299	20-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI1&2	HIREHADAGALI_66, SOVENHALLI_66	18:52	19:16	00:24	TRIPPED ON FAULT
3300	20-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66	06:35	07:02	00:27	TRIPPED ON FAULT
3301	20-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66,LIS EHT NITTUR_66	20:03	20:19	00:16	TRIPPED ON FAULT
3302	20-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	18:30(19.04.2024)	10:28:00 (20.04.2024)	15:58:00	TRIPPED ON FAULT
3303	20-Apr-2024	GULBARGA	LINE	110	ALIPUR-SOUTH	BELLARY SOUTH_110,	05:34	05:53	00:19	TRIPPED ON FAULT
3304	20-Apr-2024	GULBARGA	LINE	110	ALIPUR-SOUTH	BELLARY SOUTH_110	14:52	20:00	05:08	LINE CLEAR AVAILED
3305	20-Apr-2024	GULBARGA	LINE	110	BELLARY NORTH-ALIPUR	BELLARY NORTH_110,MOKA_110, PD_HALLI_110	13:32	14:09	00:37	LINE CLEAR AVAILED
3306	20-Apr-2024	GULBARGA	LINE	110	BISIHALLI-BELLARY NORTH	BISILAHALLI_110	20:25(20.04.2024)			LINE CLEAR AVAILED
3307	20-Apr-2024	GULBARGA	LINE	110	BISIHALLI-HALKUNDI	BISILAHALLI_110	20:08	20:27	00:19	LINE CLEAR AVAILED
3308	20-Apr-2024	GULBARGA	LINE	110	GABUR-RAICHUR	GABUR_110, GUGAL_110	23:04	23:09	00:05	TRIPPED ON FAULT
3309	20-Apr-2024	GULBARGA	LINE	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	11:03	11:04	00:01	TRIPPED ON FAULT
3310	20-Apr-2024	GULBARGA	LINE	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	14:20	14:35	00:15	TRIPPED ON FAULT
3311	20-Apr-2024	GULBARGA	LINE	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:00	19:35	01:35	TRIPPED ON FAULT
3312	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	13:29	15:57	02:28	LINE CLEAR AVAILED
3313	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MADIYAL	MADIYAL_110, CHOWDAPUR_110, AFZALPUR_110	13:36	15:57	02:21	LINE CLEAR AVAILED
3314	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	13:28	15:06	01:38	LINE CLEAR AVAILED
3315	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-NORTH	GULBARGA NORTH_110	13:46	15:19	01:33	TRIPPED ON FAULT
3316	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-NORTH	GULBARGA NORTH_110	15:25	16:22	00:57	LINE CLEAR AVAILED
3317	20-Apr-2024	GULBARGA	LINE	110	KAPNOOR-WEST	GULBARGA WEST_110	13:13	14:42	01:29	TRIPPED ON FAULT
3318	20-Apr-2024	GULBARGA	LINE	110	PDHALLI-BASAI STEELS	PD_HALLI_110	19:01	20:27	01:26	LOAD CURTAILMENT
3319	20-Apr-2024	GULBARGA	LINE	110	RAMASAMUDRA-YADGIR	YADGIR_110	00:47	00:58	00:11	TRIPPED ON FAULT
3320	20-Apr-2024	GULBARGA	LINE	110	RAMASAMUDRA-YADGIR	YADGIR_110	00:35	00:40	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3321	20-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSA GI_110,ASKI_110,NAGNOOR_110,UGAR SUGAR_IPP	20:18	20:26	00:08	TRIPPED ON FAULT
3322	20-Apr-2024	GULBARGA	LINE	110	SOMASAMUNDRA-ALIPUR	BELLARY NORTH_110,SOMASAMUNDRA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110,MOKA_110,SIRIGERICROSS_110	05:32	05:46	00:14	TRIPPED ON FAULT
3323	20-Apr-2024	GULBARGA	LINE	110	SOMASAMUNDRA-ALIPUR	BELLARY NORTH_110,SOMASAMUNDRA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110,MOKA_110,SIRIGERICROSS_110	17:03	17:25	00:22	TRIPPED ON FAULT
3324	20-Apr-2024	GULBARGA	LINE	110	SOMASAMUNDRA-ALIPUR	BELLARY NORTH_110,SOMASAMUNDRA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110,MOKA_110,SIRIGERICROSS_110	18:39	19:01	00:22	TRIPPED ON FAULT
3325	20-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HOSAHALLI_66	07:20	07:25	00:05	TRIPPED ON FAULT
3326	20-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	10:36	11:06	00:30	TRIPPED ON FAULT
3327	20-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	10:36	13:58	03:22	LINE CLEAR AVAILED
3328	20-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	17:19	17:33	00:14	TRIPPED ON FAULT
3329	20-Apr-2024	GULBARGA	TRANSFORMER	110	HV3	BELLARY NORTH_110	01:40	02:00	00:20	TRIPPED ON FAULT
3330	20-Apr-2024	GULBARGA	TRANSFORMER	220	HV2	KAPNOOR_220	13:13	13:32	00:19	TRIPPED ON FAULT
3331	20-Apr-24	HASSAN	LINE	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	08:12	10:09	01:57	MAIN SUPPLY FAILURE
3332	20-Apr-24	HASSAN	LINE	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	11:00	11:12	00:12	LINE CLEAR AVAILED
3333	20-Apr-24	HASSAN	LINE	66	DODDAKA-HNPURA	DODDAKADNUR_66	19:00(19.04.2024)	00:05(20.04.2024)		LINE CLEAR AVAILED
3334	20-Apr-24	HASSAN	LINE	66	GENDEHA-MUDIGERE	GENDEHALLI_66	17:05	17:10	00:05	LINE CLEAR AVAILED
3335	20-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	09:45	09:50	00:05	LINE CLEAR AVAILED
3336	20-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	12:48	12:51	00:03	LINE CLEAR AVAILED
3337	20-Apr-24	HASSAN	LINE	66	HASSN22-BELUR	HASSAN_220	08:12	12:52	04:40	LINE CLEAR AVAILED
3338	20-Apr-24	HASSAN	LINE	66	HASSN22-HN PURA	HASSAN_220	10:03	12:52	02:49	LINE CLEAR AVAILED
3339	20-Apr-24	HASSAN	LINE	66	HASSN22-HSN66	HASSAN_220	09:53	09:56	00:03	LINE CLEAR AVAILED
3340	20-Apr-24	HASSAN	LINE	66	HASSN22-HSN66	HASSAN_220	13:09	13:12	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3341	20-Apr-24	HASSAN	LINE	66	HASSN22-UDDURKOPLU	HASSAN_220	08:12	12:52	04:40	LINE CLEAR AVAILED
3342	20-Apr-24	HASSAN	LINE	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	09:45	09:50	00:05	MAIN SUPPLY FAILURE
3343	20-Apr-24	HASSAN	LINE	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	12:50	12:55	00:05	MAIN SUPPLY FAILURE
3344	20-Apr-24	HASSAN	LINE	66	MRSSHM-SBT	MRSMSG_220	15:15(19.04.2024)	10:47(20.04.2024)		LINE CLEAR AVAILED
3345	20-Apr-24	HASSAN	LINE	66	SAKALE-IPCL2	SAKALESH PURA_66	13:30	14:58	01:28	LINE CLEAR AVAILED
3346	20-Apr-24	HASSAN	LINE	66	SALAGAM-HIREMANGLUR	SALAGAME_66	10:30	11:05	00:35	MAIN SUPPLY FAILURE
3347	20-Apr-24	HASSAN	LINE	66	SALAGAM-HIREMANGLUR	SALAGAME_66	12:35	12:50	00:15	MAIN SUPPLY FAILURE
3348	20-Apr-24	HASSAN	LINE	66	SALAGAM-UDURKOPPLU	SALAGAME_66	10:30	11:05	00:35	MAIN SUPPLY FAILURE
3349	20-Apr-24	HASSAN	LINE	66	UDDURKO-HASSAN1	UDDURKOPPLU_66	08:30	12:46	04:16	LINE CLEAR AVAILED
3350	20-Apr-24	HASSAN	LINE	66	UDDURKO-HASSAN2	UDDURKOPPLU_66	08:30	12:46	04:16	MAIN SUPPLY FAILURE
3351	20-Apr-24	HASSAN	LINE	110	ANANDA-SHIMOGA	ANANDAPURA_110	06:33	07:00	00:27	TRIPPED ON FAULT
3352	20-Apr-24	HASSAN	LINE	110	BANTWA-SALATTUR	BANTWAL_110	04:59	06:07	01:08	TRIPPED ON FAULT
3353	20-Apr-24	HASSAN	LINE	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	17:00(19.04.2024)	8:52(20.4.2024)		LINE CLEAR AVAILED
3354	20-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR1	GURUVAYANKERE_110	03:51	06:11	02:20	TRIPPED ON FAULT
3355	20-Apr-24	HASSAN	LINE	110	GURUVA-KEMAR2	GURUVAYANKERE_110	03:51	06:11	02:20	TRIPPED ON FAULT
3356	20-Apr-24	HASSAN	LINE	110	GURUVA-SLVPWR	GURUVAYANKERE_110	03:51	06:11	02:20	TRIPPED ON FAULT
3357	20-Apr-24	HASSAN	LINE	110	HIRIYA-MADHUVANA	HIRIYADKA_110	04:54	06:04	01:10	TRIPPED ON FAULT
3358	20-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	04:09	04:12	00:03	TRIPPED ON FAULT
3359	20-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	12:10	12:14	00:04	TRIPPED ON FAULT
3360	20-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	12:23	12:40	00:17	TRIPPED ON FAULT
3361	20-Apr-24	HASSAN	LINE	110	KADUR-RAILWAY	KADUR_220	15:54	16:01	00:07	TRIPPED ON FAULT
3362	20-Apr-24	HASSAN	LINE	110	KAVOOR-BANTWAL	KAVOOR-220	06:45	07:13	00:28	TRIPPED ON FAULT
3363	20-Apr-24	HASSAN	LINE	110	KEMAR-BELMAN	KEMAR_220	04:54	05:52	00:58	TRIPPED ON FAULT
3364	20-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere1	KEMAR_220	03:51	06:11	02:20	TRIPPED ON FAULT
3365	20-Apr-24	HASSAN	LINE	110	KEMAR-Guruvykere2	KEMAR_220	03:51	06:11	02:20	TRIPPED ON FAULT
3366	20-Apr-24	HASSAN	LINE	110	KEMAR-Manipal1	KEMAR_220	05:00	05:51	00:51	TRIPPED ON FAULT
3367	20-Apr-24	HASSAN	LINE	110	KEMAR-Manipal2	KEMAR_220	05:00	05:51	00:51	TRIPPED ON FAULT
3368	20-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	09:37	09:49	00:12	LINE CLEAR AVAILED
3369	20-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	12:49	12:54	00:05	LINE CLEAR AVAILED
3370	20-Apr-24	HASSAN	LINE	110	MADHUV-KUNDAPURA	MADHUVANA_110	04:29	06:14	01:45	TRIPPED ON FAULT
3371	20-Apr-24	HASSAN	LINE	110	MANIPAL-KEMAR1	MANIPAL_110	05:02	05:51	00:49	MAIN SUPPLY FAILURE
3372	20-Apr-24	HASSAN	LINE	110	MRSSHM-GAJNUR	MRSMSG_220	16:59(19.04.2024)	8:44(20.04.2024)		LINE CLEAR AVAILED
3373	20-Apr-24	HASSAN	LINE	110	MRSSHM-SBT	MRSMSG_220	15:15(19.04.2024)	10:47(20.04.2024)		LINE CLEAR AVAILED
3374	20-Apr-24	HASSAN	LINE	110	SAGARA-ALKLA	SAGARA_110	12:15	12:35	00:20	LINE CLEAR AVAILED
3375	20-Apr-24	HASSAN	LINE	110	SALATHUR-BNTWAL	SALATHUR_110	09:41	12:40	02:59	LINE CLEAR AVAILED
3376	20-Apr-24	HASSAN	LINE	220	GOPALAP-HNPUR21	GOPALAPURA_220	21:10(19.04.2024)	16:55(20.04.2024)		LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3377	20-Apr-24	HASSAN	LINE	220	GOPALAP-HSN400	GOPALAPURA_220	19:00(19.04.2024)	14:55(20.04.2024)		LINE CLEAR AVAILED
3378	20-Apr-24	HASSAN	LINE	220	KEMAR-BASTIPR1	KEMAR_220	04:58	05:54	00:56	TRIPPED ON FAULT
3379	20-Apr-24	HASSAN	LINE	220	KEMAR-BASTIPR2	KEMAR_220	04:58	05:54	00:56	TRIPPED ON FAULT
3380	20-Apr-24	HASSAN	LINE	220	KEMAR-Varahi1	KEMAR_220	03:07	03:30	00:23	TRIPPED ON FAULT
3381	20-Apr-24	HASSAN	LINE	220	KEMAR-Varahi2	KEMAR_220	03:07	03:31	00:24	TRIPPED ON FAULT
3382	20-Apr-24	HASSAN	LINE	220	MRSSHM-VARAH1	MRSMSG_220	17:06(19.04.2024)	10:37(20.04.2024)		LINE CLEAR AVAILED
3383	20-Apr-24	HASSAN	LINE	220	MSEZ-KEMAR1	MSEZ_220	04:58	05:56	00:58	TRIPPED ON FAULT
3384	20-Apr-24	HASSAN	LINE	220	MSEZ-KEMAR2	MSEZ_220	04:58	05:57	00:59	TRIPPED ON FAULT
3385	20-Apr-24	HASSAN	LINE	220	SHRAVTY-SHIRALKOPPA	gen_sharavathy	19:27(19.04.2024)	13:00(20.04.2024)		LINE CLEAR AVAILED
3386	20-Apr-24	HASSAN	LINE	220	SHRLKP-SGS	SHIRALKOPPA_220	19:27(19.04.2024)	13:00(20.04.2024)		LINE CLEAR AVAILED
3387	20-Apr-24	HASSAN	LINE	220	VARAHI-KEMAR1	gen_varahi	03:07	03:32	00:25	TRIPPED ON FAULT
3388	20-Apr-24	HASSAN	LINE	220	VARAHI-KEMAR2	gen_varahi	03:07	03:32	00:25	TRIPPED ON FAULT
3389	20-Apr-24	HASSAN	LINE	220	VARAHI-SHIMOGA1	gen_varahi	17:06(19.04.2024)	10:39(20.04.2024)		LINE CLEAR AVAILED
3390	20-Apr-24	HASSAN	LINE	400	UPCL-KEMAR1	gen_upcl	11:32	12:34	01:02	LINE CLEAR AVAILED
3391	20-Apr-24	HASSAN	TRANSFORMER	66	HV1	BELUR_66	05:03	06:41	01:38	LINE CLEAR AVAILED
3392	20-Apr-24	HASSAN	TRANSFORMER	66	HV1	BELUR_66	06:42	09:20	02:38	LINE CLEAR AVAILED
3393	20-Apr-24	HASSAN	TRANSFORMER	66	LV2	HASSAN_220	10:03	12:39	02:36	LINE CLEAR AVAILED
3394	20-Apr-24	HASSAN	TRANSFORMER	110	HV1	BIRUR_110	15:30	15:56	00:26	LINE CLEAR AVAILED
3395	20-Apr-24	HASSAN	TRANSFORMER	110	HV1	HALADY_110	18:30	18:45	00:15	LINE CLEAR AVAILED
3396	20-Apr-24	HASSAN	TRANSFORMER	110	HV1	NERALEEKRE_110	13:10	14:00	00:50	LINE CLEAR AVAILED
3397	20-Apr-24	HASSAN	TRANSFORMER	110	HV1	VITTAL_110	02:54	03:01	00:07	TRIPPED ON FAULT
3398	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	BIRUR_110	15:30	15:56	00:26	LINE CLEAR AVAILED
3399	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	BRAHMAVARA_110	05:55	11:55	06:00	MAIN SUPPLY FAILURE
3400	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	ESSUR_110	16:00	16:31	00:31	LINE CLEAR AVAILED
3401	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	HALADY_110	19:43	22:22	02:39	LINE CLEAR AVAILED
3402	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	KADUR_220	02:26	03:46	01:20	TRIPPED ON FAULT
3403	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	MRSMSG_220	13:00	13:10	00:10	LINE CLEAR AVAILED
3404	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	NERALEEKRE_110	02:35	03:30	00:55	TRIPPED ON FAULT
3405	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	SAGARA_110	10:40	12:45	02:05	LINE CLEAR AVAILED
3406	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	SORABA_110	09:58	10:40	00:42	TRIPPED ON FAULT
3407	20-Apr-24	HASSAN	TRANSFORMER	110	HV2	SORABA_110	11:00	11:30	00:30	TRIPPED ON FAULT
3408	20-Apr-24	HASSAN	TRANSFORMER	110	HV3	KADUR_220	21:17	21:36	00:19	TRIPPED ON FAULT
3409	20-Apr-24	HASSAN	TRANSFORMER	110	HV3	MRSMSG_220	13:00	13:10	00:10	LINE CLEAR AVAILED
3410	20-Apr-24	HASSAN	TRANSFORMER	110	HV4	BAIKAMPADI_110	10:15	10:24	00:09	TRIPPED ON FAULT
3411	20-Apr-24	HASSAN	TRANSFORMER	110	HV4	MRSMSG_220	13:00	13:10	00:10	LINE CLEAR AVAILED
3412	20-Apr-24	HASSAN	TRANSFORMER	110	LV3	MRSMSG_220	09:58	15:03	05:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3413	20-Apr-24	HASSAN	TRANSFORMER	110	SAGARA-JST2	SAGARA_110	12:15	12:50	00:35	LINE CLEAR AVAILED
3414	20-Apr-24	HASSAN	TRANSFORMER	110	SAGARALST4	SAGARA_110	12:15	12:50	00:35	LINE CLEAR AVAILED
3415	20-Apr-24	HASSAN	TRANSFORMER	110	SAGARA-TAL	SAGARA_110	12:15	12:50	00:35	LINE CLEAR AVAILED
3416	20-Apr-24	HASSAN	TRANSFORMER	220	HV2	GOPALAPURA_220	21:10(19.04.2024)	17:02(20.04.2024)		LINE CLEAR AVAILED
3417	20-Apr-24	HASSAN	TRANSFORMER	220	HV2	HASSAN_220	10:04	12:38	02:34	LINE CLEAR AVAILED
3418	20-Apr-24	HASSAN	TRANSFORMER	220	HV3	MRSMSG_220	09:58	15:03	05:05	LINE CLEAR AVAILED
3419	20-Apr-24	HASSAN	TRANSFORMER	220	HV3	KADUR_220	02:26	02:43	00:17	TRIPPED ON FAULT
3420	20-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
3421	20-Apr-24	MYSORE	LINE	66	HONGANUR-YELANDUR	NO STATIONS EFFECTED	21:55	22:00	00:05	TRIPPED ON FAULT
3422	20-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3423	20-Apr-24	MYSORE	LINE	66	KRPETE-KIKKERI	KIKKERI_66	18:55:00 (19/04/2024)	6:38 (20/04/2024)	11:43 HRs	TRIPPED ON FAULT
3424	20-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MADIKERI 1	NO STATIONS EFFECTED	19:05:00 (19/04/2024)	11:44 (20/04/2024)	16:39 HRs	TRIPPED ON FAULT
3425	20-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
3426	20-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	14:21	15:56	01:35	LINE CLEAR AVAILED
3427	20-Apr-24	MYSORE	LINE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	21:17 (18/04/2024)	13:35 (20/04/2024)	40:18 HRs	TRIPPED ON FAULT
3428	20-Apr-24	MYSORE	LINE	66	VAJMANGALA -KADAKOLA 1	AYRAHALLI_66 MARADIHUNDI_66	18:43	18:46	00:03	TRIPPED ON FAULT
3429	20-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:42:00 (19/04/2024)	7:25 (20/04/2024)	10:42 HRs	LINE CLEAR AVAILED
3430	20-Apr-24	MYSORE	TRANSFORMER	66	HV1	MANDGERE_66	19:00:00 (19/04/2024)	0:00 (20/04/2024)	5:00 HRs	LINE CLEAR AVAILED
3431	20-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3432	20-Apr-24	MYSORE	TRANSFORMER	220	HV1	KUSHALNAGARA_220	22:06:00 (19/04/2024)	11:44 (20/04/2024)	13:38 HRs	TRIPPED ON FAULT
3433	20-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220- B.G.NAGARA_66	B.G.NAGARA_66	03:54	04:04	00:10	TRIPPED ON FAULT
3434	20-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	07:50	08:10	00:20	TRIPPED ON FAULT
3435	20-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	18:57	19:47	00:50	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3436	20-Apr-24	TUMKUR	LINE	66	BENKIKERE-220-MALLADIHALLI	MALLADIHALLI_66	06:00	06:07	00:07	TRIPPED ON FAULT
3437	20-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	10:43	12:54	02:11	LINE CLEAR AVAILED
3438	20-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- P.R. PURA	P.R. PURA	06:17	17:16	10:59	LINE CLEAR AVAILED
3439	20-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- TALLAK_66	TALLAK_66	06:17	17:16	10:59	LINE CLEAR AVAILED
3440	20-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV-HARIYABBE_66	HARIYABBE_66	06:17	18:05	11:48	LINE CLEAR AVAILED
3441	20-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	05:28	05:52	00:24	TRIPPED ON FAULT
3442	20-Apr-24	TUMKUR	LINE	66	TMTP-66KV -BRAHMASANDRALKINE-1	ANKASANDRA_66,BRAH MASANDRA_66,SUNVIK PLANT	07:11	07:23	00:12	TRIPPED ON FAULT
3443	20-Apr-24	TUMKUR	LINE	220	CHITRADURGA 220- GUTTUR 220	GUTTUR 220	11:56	15:55	03:59	LINE CLEAR AVAILED
3444	20-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	00:00	16:14	16:14	LINE CLEAR AVAILED
3445	20-Apr-24	TUMKUR	LINE	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	18:13(19.04.24)	16:14(20:04.20 24)	21:59	TRIPPED ON FAULT
3446	20-Apr-24	TUMKUR	LINE	400	GUTTUR 400kV- NARENDRA-2	NARENDRA -2 LINE	06:55	17:56	11:01	TRIPPED ON FAULT
3447	20-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV-400KV BTPS LINE	GUTTUR 400KV	08:20	10:12	01:52	LINE CLEAR AVAILED
3448	20-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV-400KV RTPS LINE	GUTTUR 400KV	01:00	12:18	11:18	TRIPPED ON FAULT
3449	20-Apr-24	TUMKUR	LINE	400	GUTUR_400-BEERANAHALLI-2	GUTUR_400	20:01(20.04.20 24)		-	TRIPPED ON FAULT
3450	20-Apr-24	TUMKUR	TRANSFORMER	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	05:28	05:52	00:24	TRIPPED ON FAULT
3451	20-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	KOLALA_66	16:30(19.04.20 24)	17:45(20.04.20 24)	1DAy 1:15 hrs	TRIPPED ON FAULT
3452	20-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRAHALLI_66	01:45	01:50	00:05	TRIPPED ON FAULT
3453	20-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	ANCHEPALYA_66	11:05	12:35	01:30	LINE CLEAR AVAILED
3454	20-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	CHITRAHALLI_66	15:35	15:40	00:05	TRIPPED ON FAULT
3455	20-Apr-24	TUMKUR	TRANSFORMER	220	TR-1&2 20 MVA	NITTUR_110KV	11:15	11:45	00:30	TRIPPED ON FAULT
3456	20-Apr-24	TUMKUR	TRANSFORMER	220	TR-1&2(HVSIDE)100 MVA	NITTUR_220KV	11:15	11:45	00:30	TRIPPED ON FAULT
3457	21-Apr-24	BAGALKOTE	LINE	110	220KVBELAGAVI-HUDALI	BELAGAVI_220	17:29	17:43	00:14	TRIPPED ON FAULT
3458	21-Apr-24	BAGALKOTE	LINE	110	220KVSHIGGAON-LN4 (SAVANUR)	SHIGGAON_220	14:27	17:55	03:28	LINE CLEAR AVAILED
3459	21-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3460	21-Apr-24	BAGALKOTE	LINE	110	BLG110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
3461	21-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	8:21:00 AM (20.04.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3462	21-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
3463	21-Apr-24	BAGALKOTE	LINE	110	HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3464	21-Apr-24	BAGALKOTE	LINE	110	ISMPR-F2 Cbreaker (HIDIKAL DAM)	ISLAMPUR_110,HIDIKAL DAM	17:30	18:08	00:38	TRIPPED ON FAULT
3465	21-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
3466	21-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3467	21-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3468	21-Apr-24	BAGALKOTE	LINE	110	NAVALGUND-NOKAR SOLAR	NOKAR SOLAR_110 NAVALGUND_110	19:25 (21.04.2024)			LINE CLEAR AVAILED
3469	21-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3470	21-Apr-24	BAGALKOTE	LINE	110	TALIKOTI-FPEL SOLAR	FPEL SOLAR_110 TALIKOTI_110	18:26	19:53	01:27	LINE CLEAR AVAILED
3471	21-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3472	21-Apr-24	BAGALKOTE	LINE	220	HUBLI-SIRSI1	HUBLI_220	12:24	15:58	03:34	TRIPPED ON FAULT
3473	21-Apr-24	BAGALKOTE	LINE	220	SIRSI-HUBLI1	SIRSI_220	12:24	15:58	03:34	TRIPPED ON FAULT
3474	21-Apr-24	BAGALKOTE	LINE	220	SIRSI-HUBLI1	SIRSI_220	12:24	15:58	03:34	TRIPPED ON FAULT
3475	21-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3476	21-Apr-24	BAGALKOTE	LINE	400	DHONI-GUTTUR	DHONI_400	09:58	18:18	08:20	LINE CLEAR AVAILED
3477	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	ALNAVAR_110	21:40 (20.04.2024)	13:50 (21.04.2024)	16:10	TRIPPED ON FAULT
3478	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MALAGHAN (S)_110	13:29	13:50	00:21	TRIPPED ON FAULT
3479	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MALAGHAN (S)_110	14:13	14:32	00:19	TRIPPED ON FAULT
3480	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	MALAGHAN (S)_110	19:44	20:00	00:16	TRIPPED ON FAULT
3481	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	TUMMINAKATTI_110	19:35	20:25	00:50	LINE CLEAR AVAILED
3482	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3 (20MVA)	MUNDARGI_110	14:48	17:39	02:51	TRIPPED ON FAULT
3483	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(10MVA)	GADAG_110	18:35	18:50	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3484	21-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV3 (20MVA)	BIJAPURCITY_110	23:54	23:58	00:04	TRIPPED ON FAULT
3485	21-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3486	21-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA, KALYANI TECH PARK, ORACLE(EHT)	13:13	13:22	00:09	MAIN SUPPLY FAILURE
3487	21-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA - HIMAT SINGH (EHT)	HIMAT SINGH(EHT)	05:52	06:36	00:44	TRIPPED ON FAULT
3488	21-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA - HIMAT SINGH (EHT)	HIMAT SINGH(EHT)	10:00	10:33	00:33	LINE CLEAR AVAILED
3489	21-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	07:30	08:45	01:15	LINE CLEAR AVAILED
3490	21-Apr-24	BENGALURU	LINE	66	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	07:46	08:34	00:48	LINE CLEAR AVAILED
3491	21-Apr-24	BENGALURU	LINE	66	66KV KIADB DODDABALLAPURA 220 - INDO MIM (EHT)	INDO MM(EHT)	08:35	09:08	00:33	LINE CLEAR AVAILED
3492	21-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NARASAPURA	10:05	10:23	00:18	LINE CLEAR AVAILED
3493	21-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	08:17	10:26	02:09	LINE CLEAR AVAILED
3494	21-Apr-24	BENGALURU	LINE	66	66KV KOLAR - TAMAKA - DRDO	DRDO, MALLASANDRA	05:46	05:58	00:12	TRIPPED ON FAULT
3495	21-Apr-24	BENGALURU	LINE	66	66KV LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	06:35	07:15	00:40	LINE CLEAR AVAILED
3496	21-Apr-24	BENGALURU	LINE	66	66KV NARASAPURA - HONDA LTD (EHT)	HONDA(EHT)	07:45	08:20	00:35	LINE CLEAR AVAILED
3497	21-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	06:06	06:10	00:04	LINE CLEAR AVAILED
3498	21-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	05:52	06:01	00:09	TRIPPED ON FAULT
3499	21-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 1	SRINIVASAPURA 66	08:20	09:20	01:00	LINE CLEAR AVAILED
3500	21-Apr-24	BENGALURU	LINE	66	66KV TAVAREKERE - KODIGEHALLI	TAVAREKERE	17:35	17:40	00:05	LINE CLEAR AVAILED
3501	21-Apr-24	BENGALURU	LINE	66	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	15:47	15:52	00:05	LINE CLEAR AVAILED
3502	21-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
3503	21-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	13:13	13:20	00:07	MAIN SUPPLY FAILURE
3504	21-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	13:13	13:20	00:07	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3505	21-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	13:13	13:20	00:07	MAIN SUPPLY FAILURE
3506	21-Apr-24	BENGALURU	LINE	220	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	EXORA 220, VIKAS TECH PARK 220	13:13	13:20	00:07	TRIPPED ON FAULT
3507	21-Apr-24	BENGALURU	LINE	220	220KV NELAMANGALA 400 - NITTUR	NITTUR 220	19:02	21:10	02:08	TRIPPED ON FAULT
3508	21-Apr-24	BENGALURU	LINE	400	NELAMANGALA 400 - GOOTY	NO STATION AFFECTED	11:26	12:18	00:52	TRIPPED ON FAULT
3509	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NANDI	15:05	15:30	00:25	LINE CLEAR AVAILED
3510	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	H GOLLAHALLI	21:05	21:25	00:20	TRIPPED ON FAULT
3511	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KOLAR 220	07:38	07:57	00:19	LINE CLEAR AVAILED
3512	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SRINIVASAPURA 66	14:00	14:25	00:25	LINE CLEAR AVAILED
3513	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSPALYA CIRCLE	06:13	06:23	00:10	TRIPPED ON FAULT
3514	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA	12:55	13:09	00:14	TRIPPED ON FAULT
3515	21-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HUSKUR	13:06	14:01	00:55	LINE CLEAR AVAILED
3516	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VICTORIA	00:42	00:45	00:03	LINE CLEAR AVAILED
3517	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	D PALYA	09:05	09:20	00:15	TRIPPED ON FAULT
3518	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KOLAR 220	07:57	08:14	00:17	LINE CLEAR AVAILED
3519	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SRINIVASAPURA 66	14:00	14:25	00:25	LINE CLEAR AVAILED
3520	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	10:19	10:24	00:05	TRIPPED ON FAULT
3521	21-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	11:34	11:39	00:05	TRIPPED ON FAULT
3522	21-Apr-24	BENGALURU	TRANSFORMER	66	HV3	YARANDANAHALLI 220	00:42	02:07	01:25	TRIPPED ON FAULT
3523	21-Apr-24	BENGALURU	TRANSFORMER	66	HV3	YARANDANAHALLI 220	15:10	15:35	00:25	LINE CLEAR AVAILED
3524	21-Apr-24	BENGALURU	TRANSFORMER	220	LV1	KIADB DB PURA 220	05:52	06:24	00:32	TRIPPED ON FAULT
3525	21-Apr-24	BENGALURU	TRANSFORMER	220	LV1	KIADB DB PURA 220	09:20	09:45	00:25	LINE CLEAR AVAILED
3526	21-Apr-24	BENGALURU	TRANSFORMER	220	LV1	KIADB DB PURA 220	21:55	22:17	00:22	TRIPPED ON FAULT
3527	21-Apr-2024	GULBARGA	LINE	66	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	12:17	12:33	00:16	LINE CLEAR AVAILED
3528	21-Apr-2024	GULBARGA	LINE	66	NEELAGUNDA-PUNABGHATA	PUNABGATTA_66, UCCHANGIDURGA_66	15:22	18:33	03:11	LINE CLEAR AVAILED
3529	21-Apr-2024	GULBARGA	LINE	66	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBAJ JIHALLI_66	12:10	12:20	00:10	TRIPPED ON FAULT
3530	21-Apr-2024	GULBARGA	LINE	110	BISIHALLI-BELLARY NORTH	BISILAHALLI_110	20:25(20.04.2024)			LINE CLEAR AVAILED
3531	21-Apr-2024	GULBARGA	LINE	110	BISIHALLI-BELLARY NORTH	BISILAHALLI_110	20:25(20.04.2024)	10:39(22.04.2024)	38:14:00	LINE CLEAR AVAILED
3532	21-Apr-2024	GULBARGA	LINE	110	HALWARTHY-HIRESINDHOGI	HIRESINDHOGI_110	01:25	01:52	00:27	TRIPPED ON FAULT
3533	21-Apr-2024	GULBARGA	LINE	110	JAWALGERA-WALABALLARY	JAWALGERA_110	01:06	01:19	00:13	TRIPPED ON FAULT
3534	21-Apr-2024	GULBARGA	LINE	110	SULEKAL-MALLAPUR	MALLAPUR_110,KAMPLI_110	08:40	18:58	10:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3535	21-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-BAGEWADI2	LINGASUGUR_220	11:56	13:23	01:27	TRIPPED ON FAULT
3536	21-Apr-2024	GULBARGA	LINE	220	RAMASAMUDRA-RTPS II	RAMASAMUDRA_220	21:26	21:49	00:23	TRIPPED ON FAULT
3537	21-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-RTPS2	SHAHAPUR_220	21:26	21:49	00:23	TRIPPED ON FAULT
3538	21-Apr-24	HASSAN	LINE	66	AREHALI-SAKLESPUR	AREHALLI_66	17:30	19:15	01:45	LINE CLEAR AVAILED
3539	21-Apr-24	HASSAN	LINE	66	CHIKABO-KUSHLNAGAR	CHIKABOMMENAHHLLI_66	09:15	10:50	01:35	MAIN SUPPLY FAILURE
3540	21-Apr-24	HASSAN	LINE	66	HANUBAL-SAKLESPUR	HANUBAL_66	17:30	19:12	01:42	LINE CLEAR AVAILED
3541	21-Apr-24	HASSAN	LINE	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:40	15:45	00:05	LINE CLEAR AVAILED
3542	21-Apr-24	HASSAN	LINE	66	SAKALE-HANBAL	SAKALESH PURA_66	17:30	19:12	01:42	LINE CLEAR AVAILED
3543	21-Apr-24	HASSAN	LINE	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI	06:26	06:35	00:09	TRIPPED ON FAULT
3544	21-Apr-24	HASSAN	TRANSFORMER	66	HV1	CHIKABOMMENAHHLLI_66	09:15	10:50	01:35	MAIN SUPPLY FAILURE
3545	21-Apr-24	HASSAN	TRANSFORMER	66	HV1	CHIKABOMMENAHHLLI_66	09:15	10:50	01:35	MAIN SUPPLY FAILURE
3546	21-Apr-24	HASSAN	TRANSFORMER	110	HV1	ESSUR_110	13:10	13:45	00:35	LINE CLEAR AVAILED
3547	21-Apr-24	HASSAN	TRANSFORMER	110	HV1	NAVUNDA_110	11:28	11:35	00:07	TRIPPED ON FAULT
3548	21-Apr-24	HASSAN	TRANSFORMER	110	HV1	NAVUNDA_110	12:45	12:53	00:08	TRIPPED ON FAULT
3549	21-Apr-24	HASSAN	TRANSFORMER	110	HV3	BAIKAMPADI_110	13:00	13:46	00:46	LINE CLEAR AVAILED
3550	21-Apr-24	HASSAN	TRANSFORMER	110	HV3	MANIPAL_110	11:48	12:51	01:03	TRIPPED ON FAULT
3551	21-Apr-24	HASSAN	TRANSFORMER	110	HV4	BAIKAMPADI_110	09:55	12:57	03:02	LINE CLEAR AVAILED
3552	21-Apr-24	MYSORE	LINE	66	D R PETE-KUNTHUR	SANTHEMARAHALLI_66	07:20	07:26	00:05	TRIPPED ON FAULT
3553	21-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	09:10	12:09	02:59	LINE CLEAR AVAILED
3554	21-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
3555	21-Apr-24	MYSORE	LINE	66	HEBBANI-VADKEPURA	KIRUGAVALU_66 MALIYURU_66 VADKEPURA_66	06:17	06:25	00:08	TRIPPED ON FAULT
3556	21-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	09:36	11:54	02:18	LINE CLEAR AVAILED
3557	21-Apr-24	MYSORE	LINE	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	09:41	12:03	02:22	LINE CLEAR AVAILED
3558	21-Apr-24	MYSORE	LINE	66	HOSUR GATE-HUNSUR-BANNIKUPPE	BANNIKUPPE_66, GVGUDI_66	11:40	11:55	00:15	TRIPPED ON FAULT
3559	21-Apr-24	MYSORE	LINE	66	HUNSUR 220-HUNSUR -2	BANNIKUPPE_66, GVGUDI_66, HUNSUR_66	11:41	11:48	00:07	TRIPPED ON FAULT
3560	21-Apr-24	MYSORE	LINE	66	HUNSUR-ELAWALA-GAVADGERE	NO STATIONS EFFECTED	11:40	11:50	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3561	21-Apr-24	MYSORE	LINE	66	HUNSUR-HUNSUR -1	BANNIKUPPE_66, GVGUDI_66, HUNSUR_66	11:40	11:50	00:10	TRIPPED ON FAULT
3562	21-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3563	21-Apr-24	MYSORE	LINE	66	KUSHALANAGARA 220- RAMANATHAPURA- 1	ALUR SIDDAPURA_66, KANAGAL_66	09:15	10:50	01:35	LINE CLEAR AVAILED
3564	21-Apr-24	MYSORE	LINE	66	KUSHALNAGARA- MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
3565	21-Apr-24	MYSORE	LINE	66	PANNYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	07:45	07:50	00:05	TRIPPED ON FAULT
3566	21-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:44 (21/04/2024)			LINE CLEAR AVAILED
3567	21-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3568	21-Apr-24	MYSORE	TRANSFORMER	66	HV2	HUNSUR_66	11:41	11:54	00:12	LINE CLEAR AVAILED
3569	21-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	7:28 (21/04/2024)			LINE CLEAR AVAILED
3570	21-Apr-24	MYSORE	TRANSFORMER	220	HV3	HOOTAGALLY_220	09:45	11:49	02:04	LINE CLEAR AVAILED
3571	21-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALI 220KV- TUMKUR	TUMKUR_66	10:34	10:46	00:12	LINE CLEAR AVAILED
3572	21-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- HIRIYUR LINE	J.N.KOTE,AIMANGALA, MALLAPPANAHALLI_66	12:09	12:18	00:09	TRIPPED ON FAULT
3573	21-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHALLAKERE_66	CHALLAKERE_66	23:14(21.04.20 24)	9:45(22.04.202 4)	10:31	TRIPPED ON FAULT
3574	21-Apr-24	TUMKUR	LINE	66	DEVARAHALLI_66- P.R.PURA_66	P.R. PURA	19:12	19:18	00:06	TRIPPED ON FAULT
3575	21-Apr-24	TUMKUR	LINE	66	DEVARAHALLI_66- P.R.PURA_66	P.R. PURA	19:18(21.04.20 24)		-	TRIPPED ON FAULT
3576	21-Apr-24	TUMKUR	LINE	66	ENERCON_66 LINE -HOLALKERE- STATION	HOLALKERE_66	13:00	13:39	00:39	TRIPPED ON FAULT
3577	21-Apr-24	TUMKUR	LINE	66	GUTTUR_220KV-HALASABALU_66	HALASABALU_66	01:22	01:33	00:11	TRIPPED ON FAULT
3578	21-Apr-24	TUMKUR	LINE	66	GUTTUR_220KV-HALASABALU_66	HALASABALU_66	05:35	05:46	00:11	TRIPPED ON FAULT
3579	21-Apr-24	TUMKUR	LINE	66	GUTUR_400-DONE_400	GUTUR_400	10:19	18:18	07:59	LINE CLEAR AVAILED
3580	21-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- TALLAK_66	TALLAK_66	19:34	19:45	00:11	TRIPPED ON FAULT
3581	21-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	10:10	10:20	02:11	TRIPPED ON FAULT
3582	21-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	10:24	10:55	00:31	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3583	21-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	08:43	09:00	00:17	TRIPPED ON FAULT
3584	21-Apr-24	TUMKUR	LINE	66	TR-1	GOPPENAHALLI_66	14:25	14:30	01:11	TRIPPED ON FAULT
3585	21-Apr-24	TUMKUR	LINE	110	NITTUR 220kV- KALLUR	KALLUR_110	02:54	03:15	00:21	TRIPPED ON FAULT
3586	21-Apr-24	TUMKUR	LINE	220	NITTUR_220KV-NELAMANGALALINE	NITTUR_220KV	19:10	21:14	02:04	TRIPPED ON FAULT
3587	21-Apr-24	TUMKUR	LINE	400	GUTUR_400-BEERANAHALLI-2	GUTUR_400	20:01(20.04.2024)	15:29(21.04.2024)	19:28	TRIPPED ON FAULT
3588	22-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV2 (100 MVA)	RANEBENNUR_220	17:30	18:38	01:08	LINE CLEAR AVAILED
3589	22-Apr-24	BAGALKOTE	LINE	110	220KV AHERI- MORATAGI	AHERI_220	15:45	17:10	01:25	TRIPPED ON FAULT
3590	22-Apr-24	BAGALKOTE	LINE	110	220KV BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	20:52 (22.04.2024)			TRIPPED ON FAULT
3591	22-Apr-24	BAGALKOTE	LINE	110	220KV GADAG-DAMBAL1 (SAMBAPUR)	GADAG_220 STATION AFFECTED SAMBAPUR_110	17:16	17:24	00:08	TRIPPED ON FAULT
3592	22-Apr-24	BAGALKOTE	LINE	110	220KV GADAG-DAMBAL2	GADAG_220 STATION AFFECTED DAMBAL_110, MUNDARGI_110, SHINGTALUR_110	17:16	17:23	00:07	TRIPPED ON FAULT
3593	22-Apr-24	BAGALKOTE	LINE	110	220KV RANEBENNUR-BYADGI	RANEBENNUR_220	10:38	18:50	08:12	LINE CLEAR AVAILED
3594	22-Apr-24	BAGALKOTE	LINE	110	220KV RANEBENNUR-HIREKERUR	RANEBENNUR_220	10:40	18:53	08:13	LINE CLEAR AVAILED
3595	22-Apr-24	BAGALKOTE	LINE	110	220KV RANEBENNUR-HONNATTI	RANEBENNUR_220	10:37	18:46	08:09	LINE CLEAR AVAILED
3596	22-Apr-24	BAGALKOTE	LINE	110	AMBEWADI-SUPA2	AMBEWADI_220	15:10	19:43	04:33	TRIPPED ON FAULT
3597	22-Apr-24	BAGALKOTE	LINE	110	ANMOD-GOA2	ANMOD_110	16:00	20:30	04:30	MAIN SUPPLY FAILURE
3598	22-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3599	22-Apr-24	BAGALKOTE	LINE	110	BABALESHWER- MAMDAPUR(TIKOTA)	BABALESHWER_110	16:20	16:37	00:17	LINE CLEAR AVAILED
3600	22-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
3601	22-Apr-24	BAGALKOTE	LINE	110	DAMBAL-EILS (L1) (ASE)	DAMBAL_110	17:30	17:37	00:07	LINE CLEAR AVAILED
3602	22-Apr-24	BAGALKOTE	LINE	110	DAMBAL-EILS(L1)	DAMBAL_110	17:30	17:38	00:08	LINE CLEAR AVAILED
3603	22-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON1(L3)	DAMBAL_110	17:30	17:48	00:18	LINE CLEAR AVAILED
3604	22-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	STATION NOT AFFECTED DAMBAL_110	8:21:00 AM (20.04.2024)	17:30 (22.04.2024)	57:09:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3605	22-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
3606	22-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
3607	22-Apr-24	BAGALKOTE	LINE	110	HIRMUL-F1 Cbreaker (MUDDEBIHAL)	HIREMURAL_110	05:01	05:28	00:27	LINE CLEAR AVAILED
3608	22-Apr-24	BAGALKOTE	LINE	110	INDI220KV- HIREBENUR	HIREBENUR_110	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3609	22-Apr-24	BAGALKOTE	LINE	110	INDI220KV- INDI	INDI_110	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3610	22-Apr-24	BAGALKOTE	LINE	110	INDI220KV- LACHYAN	LACHYAN_110	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3611	22-Apr-24	BAGALKOTE	LINE	110	INDI220KV- ZALAKI 1&2	ZALAKI_110	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3612	22-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
3613	22-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3614	22-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3615	22-Apr-24	BAGALKOTE	LINE	110	MUNDAR-VIJAYA SUGARS	MUNADARAGI_110	17:07	17:29	00:22	LINE CLEAR AVAILED
3616	22-Apr-24	BAGALKOTE	LINE	110	NARENDRA220-MRNGR2(UAS DHARWAD)	NARENDRA_220	11:40	17:10	05:30	LINE CLEAR AVAILED
3617	22-Apr-24	BAGALKOTE	LINE	110	NAVALGUND-NOKAR SOLAR	NOKAR SOLAR_110 NAVALGUND_110	19:25 (21.04.2024)	00:41 (22.04.2024)	05:16	LINE CLEAR AVAILED
3618	22-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3619	22-Apr-24	BAGALKOTE	LINE	110	SAMBAPUR-DAMBAL	SAMBAPUR_110	17:28	17:36	00:08	LINE CLEAR AVAILED
3620	22-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3621	22-Apr-24	BAGALKOTE	LINE	110	SULTANPUR-F2 (MUGALKHOD220)	SULTANPUR_110	10:46	11:09	00:23	LINE CLEAR AVAILED
3622	22-Apr-24	BAGALKOTE	LINE	110	UAS DHARWAD-F1(NARENDRA220)	UAS DHARWAD_110	12:05	17:10	05:05	LINE CLEAR AVAILED
3623	22-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3624	22-Apr-24	BAGALKOTE	LINE	220	AHERI-BIJAPUR1	AHERI_220	15:53	17:08	01:15	MAIN SUPPLY FAILURE
3625	22-Apr-24	BAGALKOTE	LINE	220	AHERI-BIJAPUR2	AHERI_220	15:19	15:48	00:29	TRIPPED ON FAULT
3626	22-Apr-24	BAGALKOTE	LINE	220	AHERI-BIJAPUR2	AHERI_220	15:53	17:08	01:15	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3627	22-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI1 (ADPH2)	STATION NOT AFFECTED BAGALKOT_220	17:16 (22.04.2024)			TRIPPED ON FAULT
3628	22-Apr-24	BAGALKOTE	LINE	220	BIJAPUR-AHERI2	BIJAPUR_220	15:07	15:47	00:40	TRIPPED ON FAULT
3629	22-Apr-24	BAGALKOTE	LINE	220	BIJAPUR-GMNAVR1&2(NANDIHAL SW)	BIJAPUR_220, BIJAPUR CITY_110, JUMNAL_110, KIADB BIJAPUR_110, BHUTNAL_110, THORVI_110, TIKOTA_110, HONWAD_110, TAKKALKI_110	15:52	17:38	01:46	TRIPPED ON FAULT
3630	22-Apr-24	BAGALKOTE	LINE	220	BIJAPUR-GMNAVR1&2(NANDIHAL SW)	BIJAPUR_220, BIJAPUR CITY_110, JUMNAL_110, KIADB BIJAPUR_110, BHUTNAL_110, THORVI_110, TIKOTA_110, HONWAD_110, TAKKALKI_110	15:52	17:07	01:15	TRIPPED ON FAULT
3631	22-Apr-24	BAGALKOTE	LINE	220	BIJAPUR-VAISHALI1	BIJAPUR_220	15:53	19:46	03:53	TRIPPED ON FAULT
3632	22-Apr-24	BAGALKOTE	LINE	220	BIJAPUR-VAISHALI2	BIJAPUR_220	15:53	19:39	03:46	TRIPPED ON FAULT
3633	22-Apr-24	BAGALKOTE	LINE	220	CHIKKODI-MUGALKHOD2	CHIKKODI_220	10:43	12:31	01:48	LINE CLEAR AVAILED
3634	22-Apr-24	BAGALKOTE	LINE	220	HAVERI-GUTTUR2	HAVERI_220	01:15	12:37	11:22	LINE CLEAR AVAILED
3635	22-Apr-24	BAGALKOTE	LINE	220	HUBLI-SIRSI1	HUBLI_220	13:36	16:19	02:43	LINE CLEAR AVAILED
3636	22-Apr-24	BAGALKOTE	LINE	220	HUBLI-SIRSI2	HUBLI_220	13:36	17:46	04:10	LINE CLEAR AVAILED
3637	22-Apr-24	BAGALKOTE	LINE	220	INDI-BIJAPUR1	INDI_220	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3638	22-Apr-24	BAGALKOTE	LINE	220	INDI-BIJAPUR1	INDI_220	15:50	17:08	01:18	MAIN SUPPLY FAILURE
3639	22-Apr-24	BAGALKOTE	LINE	220	KARWAR-KADRA1	KARWAR_220	12:57	18:04	05:07	LINE CLEAR AVAILED
3640	22-Apr-24	BAGALKOTE	LINE	220	KUDACHI-MAHALINGAPUR2	KUDACHI_220	12:34	13:44	01:10	LINE CLEAR AVAILED
3641	22-Apr-24	BAGALKOTE	LINE	220	MUGALKHOD-CHIKKODI 2	MUGALKHOD_220	10:43	12:31	01:48	LINE CLEAR AVAILED
3642	22-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR-BALLIGAVI	RANEBENNUR_220	11:12	13:35	02:23	LINE CLEAR AVAILED
3643	22-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3644	22-Apr-24	BAGALKOTE	TRANSFORMER	66	66/11,HV1 (12.5MVA)	HARIHAR HOSPET_66	10:59	11:04	00:05	LINE CLEAR AVAILED
3645	22-Apr-24	BAGALKOTE	TRANSFORMER	66	66/11,HV4 (12.5MVA)	HARIHAR HOSPET_66	10:59	11:04	00:05	LINE CLEAR AVAILED
3646	22-Apr-24	BAGALKOTE	TRANSFORMER	66	66/11,HVV2 (12.5 MVA)	HARIHAR HOSPET_66	10:59	11:04	00:05	LINE CLEAR AVAILED
3647	22-Apr-24	BAGALKOTE	TRANSFORMER	66	66/11KV,HV3 (8MVA	HARIHAR HOSPET_66	10:59	11:04	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3648	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11,HV1 (20MVA)	MALGHAN(S)_110	13:34	13:45	00:11	TRIPPED ON FAULT
3649	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	RANNABELAGALI_110	13:13	14:26	01:13	LINE CLEAR AVAILED
3650	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10 MVA)	TALIKOTI_110	14:41	14:51	00:10	TRIPPED ON FAULT
3651	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	ATHARGA_110	11:20	18:44	07:24	LINE CLEAR AVAILED
3652	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (HV4 /10MVA)	HANGAL_110	16:06	16:07	00:01	TRIPPED ON FAULT
3653	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (20MVA)	MALGHAN(S)_110	09:35	10:00	00:25	TRIPPED ON FAULT
3654	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (20MVA)	MALGHAN(S)_110	11:45	11:55	00:10	TRIPPED ON FAULT
3655	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA)	MUNAVALLI_110	12:30	17:55	05:25	TRIPPED ON FAULT
3656	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV4 (20MVA)	ZALKI_110	09:45	15:27	05:42	TRIPPED ON FAULT
3657	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV2 (20MVA)	MUNAVALLI_110	12:29	17:24	04:55	TRIPPED ON FAULT
3658	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV2 (20MVA)	MUNAVALLI_110	17:39	17:55	00:16	LINE CLEAR AVAILED
3659	22-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV2 (HV2/20MVA)	HANGAL_110	15:55	16:07	00:12	TRIPPED ON FAULT
3660	22-Apr-24	BENGALURU	LINE	66	66KV A STATION 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	08:04	08:08	00:04	LINE CLEAR AVAILED
3661	22-Apr-24	BENGALURU	LINE	66	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGUR	04:58	05:07	00:09	TRIPPED ON FAULT
3662	22-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3663	22-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	14:15	14:20	00:05	LINE CLEAR AVAILED
3664	22-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	17:54	18:20	00:26	TRIPPED ON FAULT
3665	22-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	08:06	08:32	00:26	TRIPPED ON FAULT
3666	22-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	08:33	08:38	00:05	TRIPPED ON FAULT
3667	22-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	08:38	09:52	01:14	LINE CLEAR AVAILED
3668	22-Apr-24	BENGALURU	LINE	66	66KV KGF - KAMASAMUDRA	KAMASAMUDRA	15:25	17:55	02:30	LINE CLEAR AVAILED
3669	22-Apr-24	BENGALURU	LINE	66	66KV KOLAR - KEMBODI	KEMBODI	17:19	17:42	00:23	LINE CLEAR AVAILED
3670	22-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSPALYA CIRLCE, MAGADI	08:44	10:58	02:14	TRIPPED ON FAULT
3671	22-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSPALYA CIRLCE, MAGADI	10:58	11:44	00:46	LINE CLEAR AVAILED
3672	22-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSPALYA CIRLCE, MAGADI	11:53	12:19	00:26	TRIPPED ON FAULT
3673	22-Apr-24	BENGALURU	LINE	66	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSPALYA CIRLCE, MAGADI	12:19	12:59	00:40	LINE CLEAR AVAILED
3674	22-Apr-24	BENGALURU	LINE	66	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	15:35	15:39	00:04	LINE CLEAR AVAILED
3675	22-Apr-24	BENGALURU	LINE	66	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	09:06	09:09	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3676	22-Apr-24	BENGALURU	LINE	66	66KV RAYALAPADU - ADDAGAL	GOWNIPALLI, RAYALPADU, ADDAGAL	17:15	18:21	01:06	LINE CLEAR AVAILED
3677	22-Apr-24	BENGALURU	LINE	66	66KV SAHAKARANAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	14:15	14:25	00:10	TRIPPED ON FAULT
3678	22-Apr-24	BENGALURU	LINE	66	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	17:35	17:57	00:22	MAIN SUPPLY FAILURE
3679	22-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI, GOWNIPALLI, RAYALPADU	17:10	17:55	00:45	LINE CLEAR AVAILED
3680	22-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	15:42	15:51	00:09	TRIPPED ON FAULT
3681	22-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - THAYALUR	THAYALUR, MALLANAYAKANAHALLI, NG HULKUR	17:29	17:40	00:11	TRIPPED ON FAULT
3682	22-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
3683	22-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	14:24	14:30	00:06	LINE CLEAR AVAILED
3684	22-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	14:24	14:30	00:06	LINE CLEAR AVAILED
3685	22-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	14:25	14:30	00:05	LINE CLEAR AVAILED
3686	22-Apr-24	BENGALURU	LINE	220	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	11:08	11:29	00:21	TRIPPED ON FAULT
3687	22-Apr-24	BENGALURU	LINE	220	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	11:32	13:57	02:25	TRIPPED ON FAULT
3688	22-Apr-24	BENGALURU	LINE	220	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 2	SARJAPURA 220	17:35	17:55	00:20	LINE CLEAR AVAILED
3689	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KADUBISANAHALLI	12:30	12:55	00:25	TRIPPED ON FAULT
3690	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DEVARABISANAHALLI	16:00	18:40	02:40	TRIPPED ON FAULT
3691	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	AERO SPACE PARK 220	12:14	15:12	02:58	LINE CLEAR AVAILED
3692	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	NANDAGUDI	06:30	06:42	00:12	TRIPPED ON FAULT
3693	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SRINIVASAPURA 66	17:15	17:20	00:05	LINE CLEAR AVAILED
3694	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	CHATRA	16:13	16:20	00:07	TRIPPED ON FAULT
3695	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HONNIGANAHALLI	04:58	05:07	00:09	TRIPPED ON FAULT
3696	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BV HALLI	11:28	12:12	00:44	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3697	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA I/A	08:42	08:50	00:08	TRIPPED ON FAULT
3698	22-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SARJAPURA 220	17:35	17:56	00:21	MAIN SUPPLY FAILURE
3699	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TELECOM LAYOUT	05:21	05:53	00:32	TRIPPED ON FAULT
3700	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVARABISANAHALLI	13:03	13:08	00:05	TRIPPED ON FAULT
3701	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVARABISANAHALLI	16:00	18:45	02:45	TRIPPED ON FAULT
3702	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	IRAGAMPALLI	11:58	12:15	00:17	TRIPPED ON FAULT
3703	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	JANGAMKOTE	14:57	15:16	00:19	LINE CLEAR AVAILED
3704	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BAGEPALLI	13:00	13:05	00:05	LINE CLEAR AVAILED
3705	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	D PALYA	13:00	13:05	00:05	LINE CLEAR AVAILED
3706	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VOKKLERI	14:45	14:50	00:05	LINE CLEAR AVAILED
3707	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	10:10	14:15	04:05	LINE CLEAR AVAILED
3708	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YEDUMADU	11:35	12:30	00:55	TRIPPED ON FAULT
3709	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BEVOOR	09:09	09:25	00:16	TRIPPED ON FAULT
3710	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BEVOOR	13:44	13:49	00:05	TRIPPED ON FAULT
3711	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BOMMASANDRA I/A	17:16	17:41	00:25	LINE CLEAR AVAILED
3712	22-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SARJAPURA 220	17:35	17:56	00:21	MAIN SUPPLY FAILURE
3713	22-Apr-24	BENGALURU	TRANSFORMER	220	HV1	SARJAPURA 220	11:08	17:58	06:50	TRIPPED ON FAULT
3714	22-Apr-24	BENGALURU	TRANSFORMER	220	HV2	SARJAPURA 220	17:35	17:56	00:21	LINE CLEAR AVAILED
3715	22-Apr-2024	GULBARGA	LINE	66	ITTAGI-HB HALLI	H B HALLI_66	17:21	18:15	00:54	TRIPPED ON FAULT
3716	22-Apr-2024	GULBARGA	LINE	66	KUDALGI-KOGALI	KOGALI_66	18:00	21:25	03:25	TRIPPED ON FAULT
3717	22-Apr-2024	GULBARGA	LINE	66	KUDALGI-KUDALGI	KUDALGI_66, CHORNOOR_66	16:45	17:40	00:55	TRIPPED ON FAULT
3718	22-Apr-2024	GULBARGA	LINE	110	ALIPUR-NORTH	BELLARY NORTH_110,SOMASAM UNDRA_110,PD_HALLI_ 110,BISIHALLI_110,HALK UNDI_110,MOKA_110,SI RIGERICROSS_110	04:47	04:59	00:12	TRIPPED ON FAULT
3719	22-Apr-2024	GULBARGA	LINE	110	ALIPUR-TORANGALU	KIADB_110,KUDITINI_11 0,AGARWAL_IPP,SHATA VAHANA_IPP,RBNS FACTORY, KAMALAPUR_110,TORA NGALU_110,METRI_110, KURUGOD_110	05:39	05:57	00:18	TRIPPED ON FAULT
3720	22-Apr-2024	GULBARGA	LINE	110	BISIHALLI-BELLARY NORTH	BISILAHALLI_110	20:25(20.04.20 24)	10:39(22.04.20 24)	38:14:00	LINE CLEAR AVAILED
3721	22-Apr-2024	GULBARGA	LINE	110	HUMNABAD-HALIKHED	HALIKHED_110	17:58	00:00	06:02	TRIPPED ON FAULT
3722	22-Apr-2024	GULBARGA	LINE	110	KEMBHAVI-ASKI	ASKI_110,TALIKOT_110	21:45	21:55	00:10	TRIPPED ON FAULT
3723	22-Apr-2024	GULBARGA	LINE	110	KEMBHAVI-HUNASAGI	HUNASAGI_110	20:15	20:25	00:10	TRIPPED ON FAULT
3724	22-Apr-2024	GULBARGA	LINE	110	KUSHTAGI-VAJJARBANDI	VAJJARBANDI_110	16:40	17:15	00:35	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3725	22-Apr-2024	GULBARGA	LINE	110	KUSHTAGI-VAJJARBANDI	VAJJARBANDI_110	17:15	23:25	06:10	LINE CLEAR AVAILED
3726	22-Apr-2024	GULBARGA	LINE	110	MALLAT-BYAGWAT	BYAGWAT_110	17:55	18:01	00:06	TRIPPED ON FAULT
3727	22-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-SULEKAL	SULEKAL_220	13:03	13:27	00:24	TRIPPED ON FAULT
3728	22-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-RTPS2	LINGASUGUR_220	18:05	19:31	01:26	TRIPPED ON FAULT
3729	22-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	HALVAGALU_66	03:50	04:00	00:10	TRIPPED ON FAULT
3730	22-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	HALVAGALU_66	19:50	19:55	00:05	TRIPPED ON FAULT
3731	22-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	HALVAGALU_66	22:15	22:20	00:05	TRIPPED ON FAULT
3732	22-Apr-24	HASSAN	LINE	66	BELUR66-MUDIGERE	BELUR_66	15:20	15:54	00:34	MAIN SUPPLY FAILURE
3733	22-Apr-24	HASSAN	LINE	66	GENDEHA-MUDIGERE	GENDEHALLI_66	15:25	15:54	00:29	MAIN SUPPLY FAILURE
3734	22-Apr-24	HASSAN	LINE	66	HASSN22-ARAKALGUD	HASSAN_220	04:04	04:14	00:10	TRIPPED ON FAULT
3735	22-Apr-24	HASSAN	LINE	66	HASSN22-UDDURKOPLU	HASSAN_220	13:14	13:55	00:41	TRIPPED ON FAULT
3736	22-Apr-24	HASSAN	LINE	66	HNPR2-HASS1	HNPURA_220	14:10	14:15	00:05	TRIPPED ON FAULT
3737	22-Apr-24	HASSAN	LINE	66	HNPR2-HASS3	HNPURA_220	14:10	14:15	00:05	TRIPPED ON FAULT
3738	22-Apr-24	HASSAN	LINE	66	HNPR2-MYSOR1	HNPURA_220	14:10	14:15	00:05	TRIPPED ON FAULT
3739	22-Apr-24	HASSAN	LINE	66	HNPR2-RNPR1	HNPURA_220	14:10	14:15	00:05	TRIPPED ON FAULT
3740	22-Apr-24	HASSAN	LINE	66	MALALI-CRPATNA	MALALI_66	05:40	05:51	00:11	TRIPPED ON FAULT
3741	22-Apr-24	HASSAN	LINE	66	MALLIPA-ARAKALGUD	MALLIPATNA_66	04:05	04:15	00:10	MAIN SUPPLY FAILURE
3742	22-Apr-24	HASSAN	LINE	66	SAKALE-HANBAL	SAKALESHPURA_66	13:15	13:40	00:25	MAIN SUPPLY FAILURE
3743	22-Apr-24	HASSAN	LINE	66	SAKALE-HANBAL	SAKALESHPURA_66	15:00	15:10	00:10	TRIPPED ON FAULT
3744	22-Apr-24	HASSAN	LINE	66	UDDURKO-NITTUR	UDDURKOPPLU_66	13:19	17:20	04:01	TRIPPED ON FAULT
3745	22-Apr-24	HASSAN	LINE	110	BRAHMAV-NITTUR	BRAHMAVARA_110	12:50	12:55	00:05	TRIPPED ON FAULT
3746	22-Apr-24	HASSAN	LINE	110	KADUR-RAILWY	KADUR_220	04:23	04:36	00:13	TRIPPED ON FAULT
3747	22-Apr-24	HASSAN	LINE	110	KONAJE-MANJESWARG	KONAJE_110	19:08	19:31	00:23	TRIPPED ON FAULT
3748	22-Apr-24	HASSAN	LINE	220	MRSSHM-CHMLR	MRSMSG_220	13:14	13:55	00:41	TRIPPED ON FAULT
3749	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	ARAKALGUD_66	11:15	11:55	00:40	LINE CLEAR AVAILED
3750	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	ARAKALGUD_66	14:22	15:34	01:12	LINE CLEAR AVAILED
3751	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	HANGARAHALLI_66	14:05	14:15	00:10	MAIN SUPPLY FAILURE
3752	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	HNPURA_220	14:04	14:10	00:06	TRIPPED ON FAULT
3753	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	RAMNATHPURA_66	14:04	14:14	00:10	MAIN SUPPLY FAILURE
3754	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	SALAGAME_66	09:59	16:43	06:44	LINE CLEAR AVAILED
3755	22-Apr-24	HASSAN	TRANSFORMER	66	HV1	SINGAPURA_66	21:16	22:20	01:04	TRIPPED ON FAULT
3756	22-Apr-24	HASSAN	TRANSFORMER	66	HV2	RAMNATHPURA_66	14:04	14:14	00:10	MAIN SUPPLY FAILURE
3757	22-Apr-24	HASSAN	TRANSFORMER	66	LV1	HASSAN_220	13:14	13:42	00:28	TRIPPED ON FAULT
3758	22-Apr-24	HASSAN	TRANSFORMER	110	HV1	BAIKAMPADI_110	10:50	13:11	02:21	LINE CLEAR AVAILED
3759	22-Apr-24	HASSAN	TRANSFORMER	110	HV2	SORABA_110	11:45	17:00	05:15	LINE CLEAR AVAILED
3760	22-Apr-24	HASSAN	TRANSFORMER	220	HV1	HASSN-220	13:14	13:42	00:28	TRIPPED ON FAULT
3761	22-Apr-24	HASSAN	TRANSFORMER	220	HV1	SHIRALKOPPA_220	11:18	17:07	05:49	LINE CLEAR AVAILED
3762	22-Apr-24	MYSORE	LINE	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	11:55	14:04	02:08	LINE CLEAR AVAILED
3763	22-Apr-24	MYSORE	LINE	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	12:00	13:58	01:58	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3764	22-Apr-24	MYSORE	LINE	66	HAMPAPURA-SARGUR	YEREHALLIHANDPOST_66,HDKOTE_66,ANTHAR SANTHE_66	02:29	02:39	00:10	TRIPPED ON FAULT
3765	22-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)			LINE CLEAR AVAILED
3766	22-Apr-24	MYSORE	LINE	66	HOOTAGALLI-BEML	HEBBAL-INDUSTRIAL_66	12:26	13:02	00:36	TRIPPED ON FAULT
3767	22-Apr-24	MYSORE	LINE	66	JYOTHINAGARA-DK MAIDANA	NO STATIONS EFFECTED	12:05	13:47	01:42	LINE CLEAR AVAILED
3768	22-Apr-24	MYSORE	LINE	66	JYOTHINAGARA-VAJMANGALA 2	NO STATIONS EFFECTED	16:10	16:48	00:38	LINE CLEAR AVAILED
3769	22-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3770	22-Apr-24	MYSORE	LINE	66	KOLLEGALA-PARINAMIPURA	PARINAMIPURA_66CHANDALLI_66THALAKADU_66BGPURA_66	14:12	14:18	00:06	TRIPPED ON FAULT
3771	22-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
3772	22-Apr-24	MYSORE	LINE	66	MADIKERI-KUSHANAGARA	NO STATIONS EFFECTED	09:26	19:00	09:33	LINE CLEAR AVAILED
3773	22-Apr-24	MYSORE	LINE	66	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	14:41 (22/04/2024)			TRIPPED ON FAULT
3774	22-Apr-24	MYSORE	LINE	66	TALAKADU-CHANDALLI	BGPURA_66	14:12	14:25	00:13	TRIPPED ON FAULT
3775	22-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:44 (21/04/2024)	7:00 (22/04/2024)	10:15 HRs	LINE CLEAR AVAILED
3776	22-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:45 (22/04/2024)			LINE CLEAR AVAILED
3777	22-Apr-24	MYSORE	TRANSFORMER	66	HV1	MADHUVANAHALLI_220	11:22	11:30	00:08	LINE CLEAR AVAILED
3778	22-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3779	22-Apr-24	MYSORE	TRANSFORMER	66	HV2	HULLAHALLI_66	10:45	10:50	00:05	TRIPPED ON FAULT
3780	22-Apr-24	MYSORE	TRANSFORMER	66	HV2	JYOTHINAGARA_66	12:47	13:43	00:56	LINE CLEAR AVAILED
3781	22-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	7:28 (21/04/2024)			LINE CLEAR AVAILED
3782	22-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220- ANCHEPALYA 1	ANCHEPALYA_66, BHAKTHARAHALLI_66,	10:30	10:55	00:25	LINE CLEAR AVAILED
3783	22-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV-HONNENAHALLI_66	HONNENAHALLI_66	12:50	13:05	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3784	22-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:11	16:24	00:13	TRIPPED ON FAULT
3785	22-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHALLAKERE_66	CHALLAKERE_66	23:14(21.04.2024)	9:45(22.04.2024)	10:31	TRIPPED ON FAULT
3786	22-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 1	PANDARAHALLI_66, HOLALKERE_66	13:41	14:44	01:03	LINE CLEAR AVAILED
3787	22-Apr-24	TUMKUR	LINE	66	DEVARAHALLI_66- P.R.PURA_66	P.R. PURA	19:18(21.04.2024)	13:35(22.04.2024)	18:17	TRIPPED ON FAULT
3788	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	19:13	20:44	01:31	TRIPPED ON FAULT
3789	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	10:48	18:10	07:22	LINE CLEAR AVAILED
3790	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	18:20	18:28	00:08	LINE CLEAR AVAILED
3791	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NALLUR_66	NALLUR_66, BASAVAPATNA, TYVANAGI	10:48	18:30	07:42	LINE CLEAR AVAILED
3792	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NALLUR_66	NALLUR_66, BASAVAPATNA, TYVANAGI	06:21	06:31	00:10	TRIPPED ON FAULT
3793	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NALLUR_66	NALLUR_66, BASAVAPATNA, TYVANAGI	21:23	21:36	00:13	TRIPPED ON FAULT
3794	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66,SAVALAN GA,CHILUR_66	05:51	06:03	00:12	TRIPPED ON FAULT
3795	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66,SAVALAN GA,CHILUR_66	19:13	20:44	01:31	TRIPPED ON FAULT
3796	22-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	10:48	18:29	07:41	LINE CLEAR AVAILED
3797	22-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	19:10	20:43	01:33	TRIPPED ON FAULT
3798	22-Apr-24	TUMKUR	LINE	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66,	16:11	16:23	00:12	MAIN SUPPLY FAILURE
3799	22-Apr-24	TUMKUR	LINE	66	NAYAKANAHATTI_66- HIREMALLANAHOLE_66	HIREMALLANAHOLE_66	15:45	19:00	03:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3800	22-Apr-24	TUMKUR	LINE	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66,KUTTIGAHALLI, WATERHOUSE	10:25	11:30	01:05	LINE CLEAR AVAILED
3801	22-Apr-24	TUMKUR	LINE	66	TR-1	HONNENAHALLI_66,	12:25	13:05	00:40	LINE CLEAR AVAILED
3802	22-Apr-24	TUMKUR	LINE	66	TR-1&TR-2	HONNALLI_220KV	10:48	10:52	00:04	LINE CLEAR AVAILED
3803	22-Apr-24	TUMKUR	LINE	220	HIREMALLANAHOLE 2-KUDLIGI-2	HIREMALLANAHOLE 2	16:48	18:01	01:13	TRIPPED ON FAULT
3804	22-Apr-24	TUMKUR	LINE	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	01:03	12:37	11:34	LINE CLEAR AVAILED
3805	22-Apr-24	TUMKUR	LINE	220	HIREMALLANAHOLE -THALLAK-2 220kV-	HIREMALLANAHOLE 2	16:24	19:12	02:48	TRIPPED ON FAULT
3806	22-Apr-24	TUMKUR	LINE	220	TR-1(HV SIDE) 100MVA	MADHUGIRI_220KV	16:01(22.04.2024)		-	TRIPPED ON FAULT
3807	22-Apr-24	TUMKUR	LINE	220	TR-1(HV SIDE) 100MVA	HONNALLI_220KV	10:48	18:50	08:02	LINE CLEAR AVAILED
3808	23-Apr-24	BAGALKOTE	LINE	110	220KV BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	20:52 (22.04.2024)	8:12 (23.04.2024)	10:20:00	TRIPPED ON FAULT
3809	23-Apr-24	BAGALKOTE	LINE	110	AEQUS220-DADDI	AEQUS_220	17:04	17:16	00:12	TRIPPED ON FAULT
3810	23-Apr-24	BAGALKOTE	LINE	110	AEQUS220-DADDI	AEQUS_220	18:05	23:12	05:07	LINE CLEAR AVAILED
3811	23-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3812	23-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F9-KATARAKI(NEERABUDIHAL)	BAGALKOT_220	03:56	04:17	00:21	TRIPPED ON FAULT
3813	23-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F9-KATARAKI(NEERABUDIHAL)	BAGALKOT_220	19:27	19:38	00:11	TRIPPED ON FAULT
3814	23-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
3815	23-Apr-24	BAGALKOTE	LINE	110	CHIKKODI-DKSSK COGEN	CHIKKODI_220	14:59	17:10	02:11	LINE CLEAR AVAILED
3816	23-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON1(L3)	DAMBAL_110	15:48	18:08	02:20	LINE CLEAR AVAILED
3817	23-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	11:28 (23.04.2024)			LINE CLEAR AVAILED
3818	23-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
3819	23-Apr-24	BAGALKOTE	LINE	110	DVGON-F1CBreaker (AFZALAPUR)	DEVANGOAN_110	10:35	11:24	00:49	LINE CLEAR AVAILED
3820	23-Apr-24	BAGALKOTE	LINE	110	GADAG220- DAMBAL	GADAG_220	17:06	17:23	00:17	TRIPPED ON FAULT
3821	23-Apr-24	BAGALKOTE	LINE	110	GADAG220- SAMBAPUR ROAD	GADAG_220	17:06	17:25	00:19	TRIPPED ON FAULT
3822	23-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3823	23-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
3824	23-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3825	23-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3826	23-Apr-24	BAGALKOTE	LINE	110	MRUTHYUNJAY NAGAR-NARENDRA	MRUTHYUNJAY NAGAR_110	13:14	13:29	00:15	LINE CLEAR AVAILED
3827	23-Apr-24	BAGALKOTE	LINE	110	MRUTHYUNJAY NAGAR-NARENDRA	MRUTHYUNJAY NAGAR_110	17:03	19:02	01:59	LINE CLEAR AVAILED
3828	23-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3829	23-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3830	23-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3831	23-Apr-24	BAGALKOTE	LINE	220	AMBEWADI- PONDA1	AMBEWADI_220	13:00	14:04	01:04	TRIPPED ON FAULT
3832	23-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI1 (ADPH2)	STATION NOT AFFECTED BAGALKOT_220	17:16 (22.04.2024)	15:00 (23.04.2024)	21:44:00	TRIPPED ON FAULT
3833	23-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - ALAMATTI-2 (ALAMATTI-1)	BAGALKOT_220	13:25	15:32	02:07	LINE CLEAR AVAILED
3834	23-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	14:46 (23.04.2024)			TRIPPED ON FAULT
3835	23-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	11:36	13:29	01:53	LINE CLEAR AVAILED
3836	23-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
3837	23-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3838	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	ALNAVAR_110	15:13	18:00	02:47	LINE CLEAR AVAILED
3839	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	BEDI_110	16:15	17:30	01:15	LINE CLEAR AVAILED
3840	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	NAVANAGAR(B)_110	10:45	10:52	00:07	TRIPPED ON FAULT
3841	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	YELPARATTI_110	18:00	18:15	00:15	LINE CLEAR AVAILED
3842	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	UCHAGAON_110	13:13	14:20	01:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3843	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	HEBBALLI_110	16:03	16:18	00:15	LINE CLEAR AVAILED
3844	23-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	ITANAL_110	08:15	18:26	10:11	LINE CLEAR AVAILED
3845	23-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	SOUDATTI_220	15:50	16:05	00:15	LINE CLEAR AVAILED
3846	23-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	RANEENNUR_220	16:39	18:26	01:47	LINE CLEAR AVAILED
3847	23-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3848	23-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDAGUNTE	18:41	18:47	00:06	TRIPPED ON FAULT
3849	23-Apr-24	BENGALURU	LINE	66	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	16:27	16:31	00:04	LINE CLEAR AVAILED
3850	23-Apr-24	BENGALURU	LINE	66	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	12:00	12:05	00:05	LINE CLEAR AVAILED
3851	23-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	13:00	13:30	00:30	LINE CLEAR AVAILED
3852	23-Apr-24	BENGALURU	LINE	66	66KV HOODY 220 - ITI (POTTERYROAD)	HOSKOTE 66	08:49	09:15	00:26	TRIPPED ON FAULT
3853	23-Apr-24	BENGALURU	LINE	66	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST	15:55	15:58	00:03	LINE CLEAR AVAILED
3854	23-Apr-24	BENGALURU	LINE	66	66KV NRS 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	06:48	06:52	00:04	LINE CLEAR AVAILED
3855	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	GUNDAMGERE, SASALU, AIR(EHT)	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3856	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3857	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - D CROSS 2	DODDABELAVANGALA	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3858	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHARD	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3859	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA, DEVANAHALLI 66	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3860	23-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	16:06	16:13	00:07	MAIN SUPPLY FAILURE
3861	23-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - ISKCON	ISKON	15:04	15:15	00:11	TRIPPED ON FAULT
3862	23-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST	22:22	22:28	00:06	LINE CLEAR AVAILED
3863	23-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	18:00	18:30	00:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3864	23-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
3865	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	16:28	16:35	00:07	MAIN SUPPLY FAILURE
3866	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	16:38	16:42	00:04	LINE CLEAR AVAILED
3867	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	16:28	16:35	00:07	MAIN SUPPLY FAILURE
3868	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	16:38	16:42	00:04	LINE CLEAR AVAILED
3869	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	16:28	16:35	00:07	MAIN SUPPLY FAILURE
3870	23-Apr-24	BENGALURU	LINE	66	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	16:38	16:42	00:04	LINE CLEAR AVAILED
3871	23-Apr-24	BENGALURU	LINE	220	220KV NRS DB PURA 220 - BIAL BEGUR 220	NRS DB PURA 220	16:05	16:13	00:08	TRIPPED ON FAULT
3872	23-Apr-24	BENGALURU	LINE	220	EXORA 220 - SOMANAHALLI 220	NO STATION AFFECTED	16:26	23:59	07:33	TRIPPED ON FAULT
3873	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DEVARABISANAHALLI	12:25	14:15	01:50	LINE CLEAR AVAILED
3874	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	11:18	11:31	00:13	TRIPPED ON FAULT
3875	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MALLASANDRA	14:25	14:30	00:05	LINE CLEAR AVAILED
3876	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	RAYALPADU	15:10	15:25	00:15	LINE CLEAR AVAILED
3877	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SOMAYAJANAHALLI	03:08	03:50	00:42	TRIPPED ON FAULT
3878	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	SRINIVASAPURA 66	12:35	13:05	00:30	LINE CLEAR AVAILED
3879	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ANDERSONPETE	12:00	12:02	00:02	LINE CLEAR AVAILED
3880	23-Apr-24	BENGALURU	TRANSFORMER	66	HV1	BOMMASANDRA I/A	11:59	12:10	00:11	LINE CLEAR AVAILED
3881	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ANJANAPURA	12:13	12:18	00:05	LINE CLEAR AVAILED
3882	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	IRAGAMPALLI	06:35	06:45	00:10	LINE CLEAR AVAILED
3883	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	YENNIGADALE	11:50	12:10	00:20	LINE CLEAR AVAILED
3884	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	D PALYA	11:05	11:06	00:01	LINE CLEAR AVAILED
3885	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	RAYALPADU	15:50	16:00	00:10	LINE CLEAR AVAILED
3886	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	VOKKALERI	14:15	14:20	00:05	LINE CLEAR AVAILED
3887	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ANDERSONPETE	12:35	12:37	00:02	LINE CLEAR AVAILED
3888	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BIDADI 220	11:01	12:58	01:57	LINE CLEAR AVAILED
3889	23-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	14:12	14:17	00:05	TRIPPED ON FAULT
3890	23-Apr-24	BENGALURU	TRANSFORMER	66	HV3	KIADB DB PURA 220	06:58	07:20	00:22	TRIPPED ON FAULT
3891	23-Apr-24	BENGALURU	TRANSFORMER	66	HV3	KIADB DB PURA 220	07:20	10:24	03:04	LINE CLEAR AVAILED
3892	23-Apr-2024	GULBARGA	LINE	110	KAPNOOR-GULBARGA NORTH 2	GULBARGA NORTH_110	10:35	12:07	01:32	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3893	23-Apr-2024	GULBARGA	LINE	110	KUSHTAGI-HANUMASAGAR	GAJENDRAGAD_110,HI REGONAGAR_110,HAN UMANAL_110	05:44	06:02	00:18	TRIPPED ON FAULT
3894	23-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-KPRL	LINGASUGUR_220	05:17	07:05	01:48	TRIPPED ON FAULT
3895	23-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-MARALIHALLA	MARALIHALLA_110, MUKUNDA_110	01:30	01:40	00:10	TRIPPED ON FAULT
3896	23-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-MARALIHALLA	MARALIHALLA_110, MUKUNDA_110, KARATAGI_110, S R NAGAR_110	08:58	12:35	03:37	LINE CLEAR AVAILED
3897	23-Apr-2024	GULBARGA	LINE	110	SINDHANOOR-SR NAGAR	KARATAGI_110	09:00	12:50	03:50	LINE CLEAR AVAILED
3898	23-Apr-2024	GULBARGA	LINE	220	KAPNOOR-HUMNABAD2	KAPNOOR_220	13:17	14:43	01:26	LINE CLEAR AVAILED
3899	23-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-RTPS2	LINGASUGUR_220	05:29	07:27	01:58	TRIPPED ON FAULT
3900	23-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	16:38(22.04.2024)	7:09(23.04.2024)	14:31 HRS	LINE CLEAR AVAILED
3901	23-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	ALIPUR_220	09:21	09:32	00:11	TRIPPED ON FAULT
3902	23-Apr-2024	GULBARGA	TRANSFORMER	110	HV2	ALIPUR_220	15:28	15:35	00:07	TRIPPED ON FAULT
3903	23-Apr-2024	GULBARGA	TRANSFORMER	110	HV7	MUNIRABAD_220	12:26	12:31	00:05	TRIPPED ON FAULT
3904	23-Apr-24	MYSORE	LINE	66	HANAGOD-PONNAMPETE	NO STATIONS EFFECTED	07:30	15:46	08:16	TRIPPED ON FAULT
3905	23-Apr-24	MYSORE	LINE	66	HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	18:53 (04/04/2024)	7:30 (23/04/2024)	444:37 HRs	LINE CLEAR AVAILED
3906	23-Apr-24	MYSORE	LINE	66	HOOTGALLY-BANNIMANTAPA 2	NO STATIONS EFFECTED	09:50	14:45	04:55	LINE CLEAR AVAILED
3907	23-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3908	23-Apr-24	MYSORE	LINE	66	KRPETE-KIKKERI	KIKKERI_66	18:55:00 (19/04/2024)			TRIPPED ON FAULT
3909	23-Apr-24	MYSORE	LINE	66	KUSHALNAGARA- MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
3910	23-Apr-24	MYSORE	LINE	66	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	14:41 (22/04/2024)	15:44 (23/04/2024)	25:03 HRs	TRIPPED ON FAULT
3911	23-Apr-24	MYSORE	LINE	66	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	05:54	06:05	00:11	TRIPPED ON FAULT
3912	23-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:40:00 (23/4/2024)			LINE CLEAR AVAILED
3913	23-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:45 (22/04/2024)	7:05:00 (23/4/2024)	10:19 HRs	LINE CLEAR AVAILED
3914	23-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3915	23-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	7:28 (21/04/2024)			LINE CLEAR AVAILED
3916	23-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220- B.G.NAGARA_66	B.G.NAGARA_66	02:27	02:36	00:09	TRIPPED ON FAULT
3917	23-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220- B.G.NAGARA_66	B.G.NAGARA_66	05:42	05:51	00:09	TRIPPED ON FAULT
3918	23-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	09:15	09:26	00:11	TRIPPED ON FAULT
3919	23-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66, DEVARAHALLI,SANTHE BENNUR, KEREBILACHI_66	04:00	04:12	00:12	TRIPPED ON FAULT
3920	23-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66,LINGADAHA LLI_66	09:53	10:04	00:11	LINE CLEAR AVAILED
3921	23-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- MAYAKONDA_66	MAYAKONDA_66,SASAL UHALLA_66	18:02	18:32	00:30	LINE CLEAR AVAILED
3922	23-Apr-24	TUMKUR	LINE	66	DYAVARANAHALLI_66- P.R.PURA_66	P.R. PURA	19:06	19:11	00:05	TRIPPED ON FAULT
3923	23-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	P R PURA_66	06:55	18:48	11:53	LINE CLEAR AVAILED
3924	23-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-THALLAK_66	THALLAK_66	06:55	18:48	11:53	LINE CLEAR AVAILED
3925	23-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	22:18	22:28	00:10	TRIPPED ON FAULT
3926	23-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	23:18	23:32	00:14	TRIPPED ON FAULT
3927	23-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBEN NUR_66 ,DEVARABELKERE_66	23:53(23.04.20 24)	00:03(24.04.20 24)	00:10	TRIPPED ON FAULT
3928	23-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66,SAVALAN GA,CHILUR_66	11:30	11:37	00:07	LINE CLEAR AVAILED
3929	23-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- NYAMATHI_66	NYAMATHI_66,SAVALAN GA,CHILUR_66	16:09	16:16	00:07	LINE CLEAR AVAILED
3930	23-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	11:30	11:37	00:07	LINE CLEAR AVAILED
3931	23-Apr-24	TUMKUR	LINE	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	16:09	16:16	00:07	LINE CLEAR AVAILED
3932	23-Apr-24	TUMKUR	LINE	66	HOSADURGA_220-66O/G HOSADURGA	HOSADURGA_66,NEER GUNDA	04:55	05:10	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3933	23-Apr-24	TUMKUR	LINE	66	KB CROSS 220kV- TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	13:35	14:15	00:40	LINE CLEAR AVAILED
3934	23-Apr-24	TUMKUR	LINE	66	KUKKAWADA _66- BASAVAPATNA_66	BASAVAPATNA_66,THY AVANAGI_66	13:25	13:35	00:10	TRIPPED ON FAULT
3935	23-Apr-24	TUMKUR	LINE	66	NAYAKANAHATTI_66- HIREMALLANAHOLE_66	HIREMALLANAHOLE_66	14:05	17:30	03:25	LINE CLEAR AVAILED
3936	23-Apr-24	TUMKUR	LINE	66	PATTNAYAKANAHALLI-C B KERE(L2)	CB KERE_66, PD KOTE_66, HARIYABBE_66	12:20	12:35	00:15	TRIPPED ON FAULT
3937	23-Apr-24	TUMKUR	LINE	66	SHYGALE_66-KEREBILACHI LINE	SHGALE_66	13:10	13:20	00:10	TRIPPED ON FAULT
3938	23-Apr-24	TUMKUR	LINE	110	NITTUR_110-KALLUR_110	KALLUR_110	01:45	02:02	00:17	TRIPPED ON FAULT
3939	23-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI_220KV LINE-2	HONNALLI_220	11:10	13:19	02:09	LINE CLEAR AVAILED
3940	23-Apr-24	TUMKUR	LINE	220	HOSADURGA_220-NEELAGUNDAI/C LINE	HOSADURGA_220	04:55	05:10	00:15	MAIN SUPPLY FAILURE
3941	23-Apr-24	TUMKUR	LINE	220	TR-1(HV SIDE) 100MVA	MADHUGIRI_220KV	16:01(22.04.2024)	18:04(23.04.2024)	1DAY,2HR,03 MIN	TRIPPED ON FAULT
3942	24-Apr-24	BAGALKOTE	LINE	110	AEQUS220-SANKESHWAR	AEQUS_220	15:47	16:15	00:28	TRIPPED ON FAULT
3943	24-Apr-24	BAGALKOTE	LINE	110	ALBAL-ALAGUR	ALBAL_110 ALAGUR_110	18:16	18:20	00:04	LINE CLEAR AVAILED
3944	24-Apr-24	BAGALKOTE	LINE	110	ALBAL-RAY SOLAR	RAY SOLAR_110 ALBAL_110	18:16	18:20	00:04	LINE CLEAR AVAILED
3945	24-Apr-24	BAGALKOTE	LINE	110	ALBAL-SPRS (SAIPRIYA SUGARS)	SAIPRIYA SUGARS_110 ALBAL_110	18:16	18:20	00:04	LINE CLEAR AVAILED
3946	24-Apr-24	BAGALKOTE	LINE	110	ALBAL-YELLAMMANAWADI 1&2	ALBAL_110	18:03	18:18	00:15	TRIPPED ON FAULT
3947	24-Apr-24	BAGALKOTE	LINE	110	ATHANI220- AIGALI1&2	ATHANI_220	18:03	18:11	00:08	TRIPPED ON FAULT
3948	24-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3949	24-Apr-24	BAGALKOTE	LINE	110	BABALESHWER- MAMDAPUR(TIKOTA)	BABALESHWER_110	10:25	10:45	00:20	LINE CLEAR AVAILED
3950	24-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	16:33	19:21	02:48	LINE CLEAR AVAILED
3951	24-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
3952	24-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220- BHOJ	CHIKKODI_220	17:05	17:55	00:50	TRIPPED ON FAULT
3953	24-Apr-24	BAGALKOTE	LINE	110	CHIKKODI220-RAIBAG1	CHIKKODI_220	08:25	11:50	03:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3954	24-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	11:28 (23.04.2024)	17:28 (24.04.2024)	30:00:00	LINE CLEAR AVAILED
3955	24-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
3956	24-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
3957	24-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	22:53	23:01	00:08	TRIPPED ON FAULT
3958	24-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
3959	24-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
3960	24-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3961	24-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3962	24-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	12:43	14:50	02:07	LINE CLEAR AVAILED
3963	24-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3964	24-Apr-24	BAGALKOTE	LINE	110	RAIBAG-CHIKKODI1	STATION NOT AFFECTED RAIBAG_110	08:25	11:50	03:25	LINE CLEAR AVAILED
3965	24-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3966	24-Apr-24	BAGALKOTE	LINE	110	TAKLI-TIK Cbreaker	TIKOTA_110	18:37	18:50	00:13	TRIPPED ON FAULT
3967	24-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3968	24-Apr-24	BAGALKOTE	LINE	110	YLWD-F2 Cbreaker(SAVALAGI)	YELLAMANWADI_110,S AVALAGI_110	18:02	18:22	00:20	TRIPPED ON FAULT
3969	24-Apr-24	BAGALKOTE	LINE	110	YLWD-F2 Cbreaker(SAVALAGI)	STATION NOT AFFECTED YELLAMANWADI_110	18:29	18:45	00:16	LINE CLEAR AVAILED
3970	24-Apr-24	BAGALKOTE	LINE	220	BAGEWADI- ATRIA1&2	BAGEWADI_220	10:16	12:11	01:55	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3971	24-Apr-24	BAGALKOTE	LINE	220	BAGEWADI- FORTUNE FIVE 1&2	BAGEWADI_220	10:16	12:11	01:55	TRIPPED ON FAULT
3972	24-Apr-24	BAGALKOTE	LINE	220	BAGEWADI- RBRK	BAGEWADI_220	10:16	12:11	01:55	TRIPPED ON FAULT
3973	24-Apr-24	BAGALKOTE	LINE	220	BAGEWADI-ADPH1&2	BAGEWADI_220	10:16	12:11	01:55	TRIPPED ON FAULT
3974	24-Apr-24	BAGALKOTE	LINE	220	BAGEWADI-LINGASUR1&2	BAGEWADI_220	10:16	12:11	01:55	TRIPPED ON FAULT
3975	24-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	14:46 (23.04.2024)	15:22 (24.04.2024)	24:36:00	TRIPPED ON FAULT
3976	24-Apr-24	BAGALKOTE	LINE	220	KUDACHI- MAHALINGPUR	KUDACHI_220	12:34	13:44	01:10	LINE CLEAR AVAILED
3977	24-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	09:36	13:05	03:29	TRIPPED ON FAULT
3978	24-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	13:12 (24.04.2024)			TRIPPED ON FAULT
3979	24-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
3980	24-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3981	24-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI- ENERCON SOLAR	VAJRAMATTI_220	02:51	12:53	10:02	TRIPPED ON FAULT
3982	24-Apr-24	BAGALKOTE	LINE	400	DHONI- GUDDADAHALLI	DHONI_400	07:41	23:00	15:19	LINE CLEAR AVAILED
3983	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11,HV3 (10MVA)	RAIBAG_110	16:30	17:08	00:38	LINE CLEAR AVAILED
3984	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	BIDI_110	17:06	18:20	01:14	LINE CLEAR AVAILED
3985	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	CHIKKODI_220	17:24	19:13	01:49	LINE CLEAR AVAILED
3986	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(20MVA)	RAIBAG_110	12:59	13:09	00:10	TRIPPED ON FAULT
3987	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	HATTARGI_110	16:31	16:51	00:20	TRIPPED ON FAULT
3988	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	HATTARGI_110	16:58	17:14	00:16	TRIPPED ON FAULT
3989	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
3990	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	HALIYAL_110	14:27	14:39	00:12	TRIPPED ON FAULT
3991	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	HALIYAL_110	10:05	15:13	05:08	TRIPPED ON FAULT
3992	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3(10MVA)	RAIBAG_110	16:30	17:08	00:38	LINE CLEAR AVAILED
3993	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(10MVA)	ZALKI_110	12:38	13:26	00:48	LINE CLEAR AVAILED
3994	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(10MVA)	ZALKI_110	14:30	14:35	00:05	TRIPPED ON FAULT
3995	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33,HV2 (10MVA)	MATTIHAL_110	08:55	08:57	00:02	TRIPPED ON FAULT
3996	24-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV1& HV2 (10MVA)	MURDESHWAR_110	10:13	11:21	01:08	LINE CLEAR AVAILED
3997	24-Apr-24	BENGALURU	LINE	66	66KV AGALAKOTE - MATHIKERE	AGALAKOTE	13:47	13:53	00:06	LINE CLEAR AVAILED
3998	24-Apr-24	BENGALURU	LINE	66	66KV AVANI - ADITHYA BIRLA SOLAR LTD. (IPP)	M/S ADITHYA BIRLA SOLAR LTD. (IPP)	14:25	14:35	00:10	LINE CLEAR AVAILED
3999	24-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - TALAGAWARA	66/11KV TALAGAWARA, Y.HUNASENAHALLI & CHEEMANGALA	18:15	18:49	00:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4000	24-Apr-24	BENGALURU	LINE	66	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI	16:45	17:38	00:53	LINE CLEAR AVAILED
4001	24-Apr-24	BENGALURU	LINE	66	66KV KEMPANAHALLI - AGALKOTE	AGALAKOTE	12:47	12:50	00:03	LINE CLEAR AVAILED
4002	24-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - BYADARAHALLI	BYADARAHALLI, SRIGANDAKAVLU, KODIGEHALLI(NEL)	13:10	14:40	01:30	LINE CLEAR AVAILED
4003	24-Apr-24	BENGALURU	LINE	66	66KV SRS PEENYA 220 - MEI L/O	MEI LAYOUT	10:27	10:30	00:03	LINE CLEAR AVAILED
4004	24-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKON	15:20	15:27	00:07	LINE CLEAR AVAILED
4005	24-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGALI, BYRAKUR	10:34	10:44	00:10	TRIPPED ON FAULT
4006	24-Apr-24	BENGALURU	LINE	66	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGALI, BYRAKUR	10:44	13:27	02:43	TRIPPED ON FAULT
4007	24-Apr-24	BENGALURU	LINE	66	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI(NEL)	14:47	14:52	00:05	LINE CLEAR AVAILED
4008	24-Apr-24	BENGALURU	TRANSFORMER	66	HV1	M GOLLAHALLI	17:25	17:50	00:25	LINE CLEAR AVAILED
4009	24-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KAMASAMUDRA	13:06	19:20	06:14	TRIPPED ON FAULT
4010	24-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DABUSPET 220	09:38	09:48	00:10	TRIPPED ON FAULT
4011	24-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAHALAXMI LAYOUT	22:38	22:44	00:06	LINE CLEAR AVAILED
4012	24-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NANDINI LAYOUT	05:51	05:55	00:04	LINE CLEAR AVAILED
4013	24-Apr-24	BENGALURU	TRANSFORMER	66	HV2	AGALAKOTE	11:20	12:10	00:50	LINE CLEAR AVAILED
4014	24-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DABUSPET 220	09:38	09:49	00:11	TRIPPED ON FAULT
4015	24-Apr-2024	GULBARGA	LINE	110	ALIPUR-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110,BISIHALLI_110	12:38	18:24	05:46	LINE CLEAR AVAILED
4016	24-Apr-2024	GULBARGA	LINE	110	BISIHALLI-NORTH	BISIHALLI_110,HALAKUNDI_110	22:26	23:16	00:50	LINE CLEAR AVAILED
4017	24-Apr-2024	GULBARGA	LINE	110	ITTAGI-HIREHADAGALI	HIREHADAGALI_66	12:15	13:30	01:15	LINE CLEAR AVAILED
4018	24-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-HATTI	HATTI_110	11:47	12:53	01:06	LINE CLEAR AVAILED
4019	24-Apr-2024	GULBARGA	LINE	110	LINGASUGUR-MARALIHALLA	MUKUNDA_110	17:49	17:59	00:10	TRIPPED ON FAULT
4020	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-ALIPUR	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,BASAI_IPP,J ANAKI STEELS_IPP	16:48	17:08	00:20	TRIPPED ON FAULT
4021	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-ALIPUR	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,BASAI_IPP,J ANAKI STEELS_IPP	17:28	17:56	00:28	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4022	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-ALIPUR	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,BASAI_IPP,J ANAKI STEELS_IPP	22:32	22:42	00:10	TRIPPED ON FAULT
4023	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-ALIPUR	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,BASAI_IPP,J ANAKI STEELS_IPP	22:55	23:06	00:11	LINE CLEAR AVAILED
4024	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-ALIPUR	PD_HALLI_110,CLEAN MAX_IPP,CLEAN SOLAR_IPP,BASAI_IPP,J ANAKI STEELS_IPP	23:06	23:22	00:16	TRIPPED ON FAULT
4025	24-Apr-2024	GULBARGA	LINE	110	PDHALLI-BASAI STEELS	PD_HALLI_110	17:56	18:24	00:28	LINE CLEAR AVAILED
4026	24-Apr-2024	GULBARGA	LINE	110	SEDAM-CHINCHOLI-1	TALIKOT_110	09:20	11:30	02:10	LINE CLEAR AVAILED
4027	24-Apr-2024	GULBARGA	LINE	110	SEDAM-KURKUNTA	KURKUNTA_110	10:45	12:05	01:20	LINE CLEAR AVAILED
4028	24-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-SULEKAL	SULEKAL_220	12:24	12:52	00:28	TRIPPED ON FAULT
4029	24-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-SULEKAL	SULEKAL_220	13:54	14:30	00:36	TRIPPED ON FAULT
4030	24-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-BAGEWADI2	LINGASUGUR_220	10:35	12:12	01:37	LINE CLEAR AVAILED
4031	24-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	13:12	16:07	02:55	LINE CLEAR AVAILED
4032	24-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	13:25	16:05	02:40	LINE CLEAR AVAILED
4033	24-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	19:12	19:13	00:01	TRIPPED ON FAULT
4034	24-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HARAPANAHALLI_66	20:35	20:40	00:05	TRIPPED ON FAULT
4035	24-Apr-2024	GULBARGA	TRANSFORMER	110	HV3	KURUGOD_110	17:27	17:32	00:05	TRIPPED ON FAULT
4036	24-Apr-2024	GULBARGA	TRANSFORMER	110	HV7	MUNIRABAD_220	08:17	08:26	00:09	TRIPPED ON FAULT
4037	24-Apr-24	MYSORE	LINE	66	K R PETE 220- MAHADESHWARAPURA	G MALLIGERE_66 JAKKANAHALLY_66 MADESWARAPURA_66	03:52	04:00	00:08	TRIPPED ON FAULT
4038	24-Apr-24	MYSORE	LINE	66	KABBALLI-CLEAN SOLAR	NO STATIONS EFFECTED	09:00	09:10	00:10	TRIPPED ON FAULT
4039	24-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4040	24-Apr-24	MYSORE	LINE	66	KUSHALNAGARA- MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4041	24-Apr-24	MYSORE	LINE	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	12:15	12:40	00:25	LINE CLEAR AVAILED
4042	24-Apr-24	MYSORE	LINE	66	LOKKANAHALLI-PG PALYA	PGPALYA_66	12:40	12:45	00:05	TRIPPED ON FAULT
4043	24-Apr-24	MYSORE	LINE	66	PANNYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	03:50	04:00	00:10	TRIPPED ON FAULT
4044	24-Apr-24	MYSORE	LINE	66	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66	21:17	21:24	00:07	TRIPPED ON FAULT
4045	24-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:41 (24/04/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4046	24-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:40:00 (23/04/2024)	7:17 (24/04/2024)	10:37 HRs	LINE CLEAR AVAILED
4047	24-Apr-24	MYSORE	TRANSFORMER	66	HV1	ADDIHALLI_66	05:00	05:05	00:05	LINE CLEAR AVAILED
4048	24-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4049	24-Apr-24	MYSORE	TRANSFORMER	66	HV2	HONNALLY_MYS_66	13:45	13:50	00:05	TRIPPED ON FAULT
4050	24-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4051	24-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	7:28 (21/04/2024)	14:38 (24/04/2024)	79:10 HRs	LINE CLEAR AVAILED
4052	24-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66,SANT HEBENNUR,KEREBILAC HI_66	08:55	09:00	00:05	TRIPPED ON FAULT
4053	24-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- HIRIYUR	SANEKERE_66, CHALKERE_66, IMANGALA_66	07:28	08:19	00:51	LINE CLEAR AVAILED
4054	24-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	03:36	03:46	00:10	TRIPPED ON FAULT
4055	24-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHALLAKERE_66	CHALLAKERE_66	07:42	08:42	01:00	LINE CLEAR AVAILED
4056	24-Apr-24	TUMKUR	LINE	66	CHITRADURGA 220kV- CHALLAKERE_66	CHALLAKERE_66	08:30	09:15	00:45	LINE CLEAR AVAILED
4057	24-Apr-24	TUMKUR	LINE	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66, HOLALKERE_66	15:48	17:17	01:29	LINE CLEAR AVAILED
4058	24-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-P R PURA	P R PURA_66	12:30	18:50	06:20	LINE CLEAR AVAILED
4059	24-Apr-24	TUMKUR	LINE	66	HIRIYUR220kV-THALLAK_66	THALLAK_66	12:30	18:50	06:20	LINE CLEAR AVAILED
4060	24-Apr-24	TUMKUR	LINE	66	HONNALLI 220kV- KUNDUR66	KUNDUR_66,MALEBEN NUR_66 ,DEVARABELKERE_66	23:53(23.04.20 24)	00:03(24.04.20 24)	00:10	TRIPPED ON FAULT
4061	24-Apr-24	TUMKUR	LINE	66	HOSADURGA_220-66O/G HOSADURGA	HOSADURGA_66,NEER GUNDA	03:20	03:40	00:20	TRIPPED ON FAULT
4062	24-Apr-24	TUMKUR	LINE	66	HOSADURGA_220-BAGUR LINE	BAGUR_66	06:15	06:40	00:25	TRIPPED ON FAULT
4063	24-Apr-24	TUMKUR	LINE	66	MADANAYAKANAHALLI- TURUVANUR	MADANAYAKANAHALLI_66,	07:20	08:20	00:12	MAIN SUPPLY FAILURE
4064	24-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	09:40	09:48	00:08	TRIPPED ON FAULT
4065	24-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	10:38	10:45	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4066	24-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	10:48	12:34	01:46	TRIPPED ON FAULT
4067	24-Apr-24	TUMKUR	LINE	66	MATHOD-GARAGA_66 ,PANCHANAHALLI	GARAGA_66- PANCHANAHALLI_66	14:45	16:00	01:15	TRIPPED ON FAULT
4068	24-Apr-24	TUMKUR	LINE	66	RAMAGIRI-I/C LINE BAGURU	RAMAGIRI_66,CHIKJAJUR_66	03:20	03:45	00:25	TRIPPED ON FAULT
4069	24-Apr-24	TUMKUR	LINE	66	RAMAGIRI-I/C LINE HOSADURGA_66	RAMAGIRI_66,CHIKJAJUR_66	03:20	03:45	00:25	TRIPPED ON FAULT
4070	24-Apr-24	TUMKUR	LINE	66	RAMPURA66-NAGASAMUDRA	NAGASAMUDRA_66	06:48	07:35	00:47	LINE CLEAR AVAILED
4071	24-Apr-24	TUMKUR	LINE	66	RAMPURA66-NAGASAMUDRA	NAGASAMUDRA_66	17:30	17:45	00:15	LINE CLEAR AVAILED
4072	24-Apr-24	TUMKUR	LINE	66	TR-1	ANTHRASANAHALLI_220	16:45	20:09	03:24	LINE CLEAR AVAILED
4073	24-Apr-24	TUMKUR	LINE	66	TR-1	CHITRAHALLI_66	14:15	14:20	00:05	TRIPPED ON FAULT
4074	24-Apr-24	TUMKUR	LINE	66	TR-1	LINGADAHALLI_66	07:15	07:50	00:35	LINE CLEAR AVAILED
4075	24-Apr-24	TUMKUR	LINE	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	12:33	13:13	00:40	TRIPPED ON FAULT
4076	24-Apr-24	TUMKUR	LINE	220	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	11:50	19:35	07:45	TRIPPED ON FAULT
4077	24-Apr-24	TUMKUR	LINE	400	GUTTUR 400KV- KAIGA 400KV -2	GUTUR_400	10:28	18:19	07:51	LINE CLEAR AVAILED
4078	25-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4079	25-Apr-24	BAGALKOTE	LINE	110	BANAHATTI- JAMAKHANDI(NAVALAGI)	BANAHATTI_110	10:28	10:39	00:11	TRIPPED ON FAULT
4080	25-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
4081	25-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
4082	25-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KV/ICMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4083	25-Apr-24	BAGALKOTE	LINE	110	GARAG- F1(NARENDRA)	GARAG_110	19:41	21:01	01:20	LINE CLEAR AVAILED
4084	25-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	20:14	20:31	00:17	TRIPPED ON FAULT
4085	25-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	07:31	11:26	03:55	LINE CLEAR AVAILED
4086	25-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	13:10	13:12	00:02	LINE CLEAR AVAILED
4087	25-Apr-24	BAGALKOTE	LINE	110	GOPANAKOPPA- MRUTHYUNJAY NAGAR2	GOPANAKOPPA_110	19:10	19:29	00:19	TRIPPED ON FAULT
4088	25-Apr-24	BAGALKOTE	LINE	110	HAVERI220- BYADAGI	HAVERI_220	13:37	17:48	04:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4089	25-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4090	25-Apr-24	BAGALKOTE	LINE	110	KUD DHARWAD- NARENDRA	KUD DHARWAD_110	19:05	19:57	00:52	LINE CLEAR AVAILED
4091	25-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
4092	25-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4093	25-Apr-24	BAGALKOTE	LINE	110	MALGHAN-BASAVASUG	MALGHAN(B)_110	20:24	20:28	00:04	TRIPPED ON FAULT
4094	25-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4095	25-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	07:32	07:34	00:02	LINE CLEAR AVAILED
4096	25-Apr-24	BAGALKOTE	LINE	110	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	13:02	13:05	00:03	LINE CLEAR AVAILED
4097	25-Apr-24	BAGALKOTE	LINE	110	MUKARTHA-SPV (KODANGAL)	MUKARTIHAL_110	13:32	13:51	00:19	TRIPPED ON FAULT
4098	25-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- KUD DHARWAD	NARENDRA_220	19:03	19:56	00:53	TRIPPED ON FAULT
4099	25-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- MRUTHYUNJAY NAGAR	NARENDRA_220	19:03 (25.04.2024)			TRIPPED ON FAULT
4100	25-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- SHEDBAL	NARENDRA_220	19:03	20:59	01:56	TRIPPED ON FAULT
4101	25-Apr-24	BAGALKOTE	LINE	110	NARENDRA220-BELUR1&2	NARENDRA_220	19:03	19:53	00:50	TRIPPED ON FAULT
4102	25-Apr-24	BAGALKOTE	LINE	110	NVLGI-F2 Cbreaker (BANAHATTI)	BANAHATTI_110	10:30	10:42	00:12	TRIPPED ON FAULT
4103	25-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- GHATAPRABHA	PG HUNSHYAL_110	07:39	13:16	05:37	LINE CLEAR AVAILED
4104	25-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALGI(MUGALKHOD)	PG HUNSHYAL_110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4105	25-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)	7:39 (25.04.2024)	5199:17:00	LINE CLEAR AVAILED
4106	25-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4107	25-Apr-24	BAGALKOTE	LINE	110	RANEENNUR- GUTTAL	RANEENNUR_220	12:10	13:37	01:27	LINE CLEAR AVAILED
4108	25-Apr-24	BAGALKOTE	LINE	110	RANEENNUR- HIREKERUR	RANEENNUR_220	12:10	13:37	01:27	LINE CLEAR AVAILED
4109	25-Apr-24	BAGALKOTE	LINE	110	RANEENNUR- RATTIHALLI (TUMMINKATTI)	RANEENNUR_220	11:53	13:40	01:47	LINE CLEAR AVAILED
4110	25-Apr-24	BAGALKOTE	LINE	110	RANEENNUR-BYADAGI(HONNATTI)	RANEENNUR_220	12:10	13:38	01:28	LINE CLEAR AVAILED
4111	25-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	21:20 (23.04.2024)	11:50 (25.04.2024)	38:30:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4112	25-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4113	25-Apr-24	BAGALKOTE	LINE	110	SHIGON-RMKP Cbreaake (MUNDGOD)	MUNDGOD_110	16:11	16:57	00:46	TRIPPED ON FAULT
4114	25-Apr-24	BAGALKOTE	LINE	110	SHIGON-SVNR Cbreaake (GANJIKATTI)	GANJIKATTI_110	16:11	16:20	00:09	TRIPPED ON FAULT
4115	25-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4116	25-Apr-24	BAGALKOTE	LINE	110	TADASINAKOPPA- GAMANAGATTI	TADASINAKOPPA_110	6:54 (28.03.2024)	20:03 (25.04.2024)	685:09:00	LINE CLEAR AVAILED
4117	25-Apr-24	BAGALKOTE	LINE	110	TADASINAKOPPA- GAMANAGATTI	TADASINAKOPPA_110	6:54 (28.03.2024)	20:03 (25.04.2024)	685:09:00	LINE CLEAR AVAILED
4118	25-Apr-24	BAGALKOTE	LINE	110	TADASINAKOPPA- NARENDRA	TADASINAKOPPA_110	19:03	20:03	01:00	LINE CLEAR AVAILED
4119	25-Apr-24	BAGALKOTE	LINE	110	TADASINAKOPPA- NARENDRA	TADASINAKOPPA_110	19:03	20:03	01:00	LINE CLEAR AVAILED
4120	25-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4121	25-Apr-24	BAGALKOTE	LINE	220	HUBLI- NARENDRA1	HUBLI_220	12:59	21:42	08:43	TRIPPED ON FAULT
4122	25-Apr-24	BAGALKOTE	LINE	220	NARENDRA- HUBLI1	NARENDRA_220	12:59	21:42	08:43	TRIPPED ON FAULT
4123	25-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	13:12 (24.04.2024)	15:42 (25.04.2024)	26:30:00	TRIPPED ON FAULT
4124	25-Apr-24	BAGALKOTE	LINE	220	RANEBENNUR- GUTTUR	RANEBENNUR_220	12:18	13:36	01:18	LINE CLEAR AVAILED
4125	25-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
4126	25-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4127	25-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	21:04	22:03	00:59	TRIPPED ON FAULT
4128	25-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	22:14	22:40	00:26	TRIPPED ON FAULT
4129	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4130	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1 (10MVA)	TALIKOTI_110	20:14	20:20	00:06	TRIPPED ON FAULT
4131	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV1(10MVA)	HALKI_110	12:18	12:25	00:07	LINE CLEAR AVAILED
4132	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (20MVA)	MALGHAN(S)_110	16:10	18:20	02:10	LINE CLEAR AVAILED
4133	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(20MVA)	UCHAGOAN_110	12:50	16:15	03:25	LINE CLEAR AVAILED
4134	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(10MVA)	KANABARGI LAYOUT_110	15:24	16:07	00:43	LINE CLEAR AVAILED
4135	25-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2(20MVA)	HATTARAGI_110	11:53	13:09	01:16	TRIPPED ON FAULT
4136	25-Apr-24	BAGALKOTE	TRANSFORMER	110	220/110KV, HV2&LV2	HUBLI_220	11:57	13:20	01:23	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4137	25-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	NARENDRA_220	19:03	19:28	00:25	TRIPPED ON FAULT
4138	25-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	NARENDRA_220	19:03	19:28	00:25	TRIPPED ON FAULT
4139	25-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	NARENDRA_220	19:03	19:28	00:25	TRIPPED ON FAULT
4140	25-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4141	25-Apr-24	BENGALURU	LINE	66	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	06:08	06:30	00:22	TRIPPED ON FAULT
4142	25-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - BIAL BEGUR 220	PILLAGUMPA	09:13	09:45	00:32	TRIPPED ON FAULT
4143	25-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	09:06	09:09	00:03	LINE CLEAR AVAILED
4144	25-Apr-24	BENGALURU	LINE	66	66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1	NO STATION AFFECTED	16:35	17:00	00:25	TRIPPED ON FAULT
4145	25-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	21:35	21:46	00:11	TRIPPED ON FAULT
4146	25-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	21:35	21:46	00:11	TRIPPED ON FAULT
4147	25-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	16:47	16:57	00:10	TRIPPED ON FAULT
4148	25-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - SANJEEVANADODDI	NO STATION AFFECTED	16:55	19:11	02:16	TRIPPED ON FAULT
4149	25-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	05:30	05:45	00:15	TRIPPED ON FAULT
4150	25-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL TECH(EHT)	06:18	06:26	00:08	TRIPPED ON FAULT
4151	25-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4152	25-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DALASANUR	10:00	10:15	00:15	TRIPPED ON FAULT
4153	25-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DALASANUR	10:55	11:05	00:10	TRIPPED ON FAULT
4154	25-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KAMASAMUDRA	12:05	12:10	00:05	TRIPPED ON FAULT
4155	25-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NANGLI	20:55	21:10	00:15	LINE CLEAR AVAILED
4156	25-Apr-2024	GULBARGA	LINE	110	ALIPUR-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110,BISIHALLI_110	14:31	15:00	00:29	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4157	25-Apr-2024	GULBARGA	LINE	110	ALIPUR-NORTH	BELLARY NORTH_110,SOMASAMUNDRA_110,PD_HALLI_110,MOKA_110	00:01	02:27	02:26	LINE CLEAR AVAILED
4158	25-Apr-2024	GULBARGA	LINE	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	07:03	07:21	00:18	LINE CLEAR AVAILED
4159	25-Apr-2024	GULBARGA	LINE	110	SANKLAPUR-TORANGALU	TORANGALU_110	09:35	13:55	04:20	LINE CLEAR AVAILED
4160	25-Apr-2024	GULBARGA	LINE	110	SEDAM-CHINCHOLI-2	CHINCHOLI_110	07:50	10:10	02:20	LINE CLEAR AVAILED
4161	25-Apr-2024	GULBARGA	LINE	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	21:57	22:07	00:10	TRIPPED ON FAULT
4162	25-Apr-2024	GULBARGA	LINE	110	SINDHANOOR- SR NAGAR	SR NAGAR_110, KARATAGI_110	13:05	13:15	00:10	TRIPPED ON FAULT
4163	25-Apr-2024	GULBARGA	LINE	220	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	11:10	14:09	02:59	LINE CLEAR AVAILED
4164	25-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	NEELAGUNDA_220	16:05	17:30	01:25	LINE CLEAR AVAILED
4165	25-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SOMASAMUNDRA_110	19:32	20:32	01:00	LINE CLEAR AVAILED
4166	25-Apr-24	MYSORE	LINE	66	GAVADAGERE-ELAVALA-HUNSUR	ELAVALA_66	13:05	13:13	00:08	TRIPPED ON FAULT
4167	25-Apr-24	MYSORE	LINE	66	HUNSUR 220-HANGOD	HANAGUD_66	13:03	13:12	00:09	TRIPPED ON FAULT
4168	25-Apr-24	MYSORE	LINE	66	HUNSUR 220-HOSURGATE	HOSURGATE_66	13:03	13:12	00:09	TRIPPED ON FAULT
4169	25-Apr-24	MYSORE	LINE	66	HUNSUR 220-HUNSUR 1	HUNSUR_66 BANNIKUPPE_66 GVGUDI_66	13:03	13:12	00:09	TRIPPED ON FAULT
4170	25-Apr-24	MYSORE	LINE	66	HUNSUR 220-HUNSUR 2	HUNSUR_66 BANNIKUPPE_66 GVGUDI_66	13:03	13:12	00:09	TRIPPED ON FAULT
4171	25-Apr-24	MYSORE	LINE	66	HUNSUR 220-KAMPALAPURA	NO STATIONS EFFECTED	13:03	13:12	00:09	TRIPPED ON FAULT
4172	25-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4173	25-Apr-24	MYSORE	LINE	66	KOPPA-NSL SUGAR	NO STATIONS EFFECTED	08:26:00	08:44:00	00:18:00	TRIPPED ON FAULT
4174	25-Apr-24	MYSORE	LINE	66	KUNTHUR-DR PETE	NO STATIONS EFFECTED	05:55	06:00	00:05	TRIPPED ON FAULT
4175	25-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4176	25-Apr-24	MYSORE	LINE	66	MANDAKALLI-RK NAGARA	NO STATIONS EFFECTED	06:13	06:18	00:05	TRIPPED ON FAULT
4177	25-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:41 (24/04/2024)	7:47:00 (25/04/2024)	11:06	LINE CLEAR AVAILED
4178	25-Apr-24	MYSORE	TRANSFORMER	66	HV1	BYLUKUPPE_66	12:25	12:30	00:05	TRIPPED ON FAULT
4179	25-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHIKKAMANDYA_66	12:40	13:10	00:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4180	25-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4181	25-Apr-24	MYSORE	TRANSFORMER	66	HV2	BESAGARALLY_66	05:00	09:50	04:50	TRIPPED ON FAULT
4182	25-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4183	25-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	14:20	14:30	00:10	TRIPPED ON FAULT
4184	25-Apr-24	TUMKUR	LINE	66	KADAJJI_66-DAVANGERE_220	KADAJJI_66	14:20	14:30	00:10	TRIPPED ON FAULT
4185	25-Apr-24	TUMKUR	LINE	66	NAGASAMUDRA- RAMPUR	RAMPURA_66	19:30	19:40	00:10	TRIPPED ON FAULT
4186	25-Apr-24	TUMKUR	LINE	66	SOKKE-JAGLUR	SOKKE_66	15:55	16:00	00:05	LINE CLEAR AVAILED
4187	25-Apr-24	TUMKUR	LINE	220	CHITRADURGA 220- GUTTUR 220	GUTTUR 220	11:15	12:55	01:40	LINE CLEAR AVAILED
4188	25-Apr-24	TUMKUR	LINE	220	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:41	17:29	01:48	LINE CLEAR AVAILED
4189	25-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HONNENAHALLI_66	11:15	12:25	01:10	LINE CLEAR AVAILED
4190	26-Apr-24	BAGALKOTE	LINE	110	ATHANI220- AIGALI	ATHANI_220	21:45	21:56	00:11	TRIPPED ON FAULT
4191	26-Apr-24	BAGALKOTE	LINE	110	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)	13:25 (26.04.2024)	1722:29:00	LINE CLEAR AVAILED
4192	26-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)			LINE CLEAR AVAILED
4193	26-Apr-24	BAGALKOTE	LINE	110	BELGAUM220- VADAGOAN	BELGAUM_220	15:22	15:46	00:24	TRIPPED ON FAULT
4194	26-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
4195	26-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KV/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4196	26-Apr-24	BAGALKOTE	LINE	110	DEVARGENNUR-F1 (BELLUBBI)	DEVARGENNUR_110	18:21	18:34	00:13	TRIPPED ON FAULT
4197	26-Apr-24	BAGALKOTE	LINE	110	DEVARGENNUR-F2 (SHIRBUR)	DEVARGENNUR_110	18:21	18:34	00:13	TRIPPED ON FAULT
4198	26-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4199	26-Apr-24	BAGALKOTE	LINE	110	HUBLI220- KALGHATAGI	HUBLI_220	17:40	18:30	00:50	TRIPPED ON FAULT
4200	26-Apr-24	BAGALKOTE	LINE	110	HUBLI220-TARIHAL-2	HUBLI_220	17:39	18:49	01:10	TRIPPED ON FAULT
4201	26-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4202	26-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4203	26-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4204	26-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- MRUTHYUNJAY NAGAR	NARENDRA_220	19:03 (25.04.2024)			TRIPPED ON FAULT
4205	26-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALGI(MUGALKHOD)	PG HUNSHYAL_110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4206	26-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4207	26-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220- BYADAGI	RANEBENNUR_220	9:21 (25.04.2024)	12:13 (26.04.2024)	26:52:00	TRIPPED ON FAULT
4208	26-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4209	26-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4210	26-Apr-24	BAGALKOTE	LINE	110	TARIHA-SRS HUBLI-2	TARIHAL_110	17:39	18:51	01:12	TRIPPED ON FAULT
4211	26-Apr-24	BAGALKOTE	LINE	110	VADAGO-BELGAUM	STATION NOT AFFECTED VADAGOAN_110	15:43	15:47	00:04	LINE CLEAR AVAILED
4212	26-Apr-24	BAGALKOTE	LINE	110	VADAGO-MACHE	STATION NOT AFFECTED VADAGOAN_110	15:22	15:56	00:34	TRIPPED ON FAULT
4213	26-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4214	26-Apr-24	BAGALKOTE	LINE	110	YLWD-F1CBreaker(AIGALI)	YELLAMANAWADI_110, AIGALI_110	21:46	21:55	00:09	TRIPPED ON FAULT
4215	26-Apr-24	BAGALKOTE	LINE	220	CHIKKODI220- KOLAH PURA (TALANDAGE)	CHIKKODI_220	12:25	16:57	04:32	LINE CLEAR AVAILED
4216	26-Apr-24	BAGALKOTE	LINE	220	HUBLI- SIRSI1	HUBLI_220	13:58	18:41	04:43	TRIPPED ON FAULT
4217	26-Apr-24	BAGALKOTE	LINE	220	KANAGALA- AEQUS	KANAGALA_220	14:09	14:11	00:02	LINE CLEAR AVAILED
4218	26-Apr-24	BAGALKOTE	LINE	220	NARENDRA- HUBLI1	NARENDRA_220	14:08	14:22	00:14	TRIPPED ON FAULT
4219	26-Apr-24	BAGALKOTE	LINE	220	NARENDRA- HUBLI2	NARENDRA_220	14:08	17:57	03:49	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4220	26-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
4221	26-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAIED
4222	26-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-BAGALKOT LINE 1	VAJRAMATTI_220	18:05	18:13	00:08	LINE CLEAR AVAIED
4223	26-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	16:33	19:47	03:14	TRIPPED ON FAULT
4224	26-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-MAHALINGPUR 1 &2	VAJRAMATTI_220	18:04	18:06	00:02	LINE CLEAR AVAIED
4225	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	HALKI_110	08:06	12:53	04:47	LINE CLEAR AVAIED
4226	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(20MVA)	NAVALAGI_110	6:51	7:45	00:54	LINE CLEAR AVAIED
4227	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	KUD DHARWAD_110	15:25	19:41	04:16	TRIPPED ON FAULT
4228	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4229	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MAMADAPUR(B)_110	15:38	16:07	00:29	LINE CLEAR AVAIED
4230	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	19:31	19:35	00:04	TRIPPED ON FAULT
4231	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	22:15	22:19	00:04	TRIPPED ON FAULT
4232	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	19:56	19:58	00:02	TRIPPED ON FAULT
4233	26-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA-1)	TODALBAGI_110	17:33	18:18	00:45	LINE CLEAR AVAIED
4234	26-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4235	26-Apr-24	BENGALURU	LINE	66	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:03	05:26	00:23	TRIPPED ON FAULT
4236	26-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	09:43	10:06	00:23	TRIPPED ON FAULT
4237	26-Apr-24	BENGALURU	LINE	66	66KV KODIHALLI - BIJJALLI - HUNASENAHALLI	BIJJAHALLI, HUNSENAHALLI	10:00	10:10	00:10	TRIPPED ON FAULT
4238	26-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	11:22	11:30	00:08	TRIPPED ON FAULT
4239	26-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	08:18	08:24	00:06	TRIPPED ON FAULT
4240	26-Apr-24	BENGALURU	LINE	66	66KV MITTEMARI 220 - SADHALI	SADALI, DIBBURAHALLI	05:43	05:51	00:08	TRIPPED ON FAULT
4241	26-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	06:24	06:29	00:05	TRIPPED ON FAULT
4242	26-Apr-24	BENGALURU	LINE	66	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	06:30	06:39	00:09	TRIPPED ON FAULT
4243	26-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4244	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	02:02	02:07	00:05	TRIPPED ON FAULT
4245	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	03:24	03:29	00:05	TRIPPED ON FAULT
4246	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GOWRIBIDANUR 220	07:49	07:59	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4247	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	ADDAGAL	00:55	01:35	00:40	TRIPPED ON FAULT
4248	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KEMBODI	14:45	15:15	00:30	LINE CLEAR AVAILED
4249	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MAASTHI	08:05	10:00	01:55	TRIPPED ON FAULT
4250	26-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HOSPALYA CIRCLE	11:59	12:24	00:25	TRIPPED ON FAULT
4251	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KADUBISANAHALLI	03:54	04:10	00:16	TRIPPED ON FAULT
4252	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	AUSTIN TOWN	13:08	13:16	00:08	TRIPPED ON FAULT
4253	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BRIGADE MEADOWS	13:54	14:03	00:09	TRIPPED ON FAULT
4254	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GANJIGUNTE	09:50	10:00	00:10	TRIPPED ON FAULT
4255	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GANJIGUNTE	10:55	11:15	00:20	LINE CLEAR AVAILED
4256	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	CHIKKABALLAPURA I/A	12:27	12:34	00:07	TRIPPED ON FAULT
4257	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BAGEPALLI	22:00	22:15	00:15	TRIPPED ON FAULT
4258	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	MAASTHI	12:30	12:47	00:17	TRIPPED ON FAULT
4259	26-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DASHAVARA	13:35	13:40	00:05	TRIPPED ON FAULT
4260	26-Apr-2024	GULBARGA	LINE	66	MUNIRABAD-TBHES	TBHES_66	23:26(26.04.2024)			TRIPPED ON FAULT
4261	26-Apr-2024	GULBARGA	LINE	66	TELAGI-YAGUNTA	OBJ HALLI_66	15:15	15:20	00:05	TRIPPED ON FAULT
4262	26-Apr-2024	GULBARGA	LINE	110	BHALKI-HUMNABAD	BHALKI_110	19:45	20:25	00:40	TRIPPED ON FAULT
4263	26-Apr-2024	GULBARGA	LINE	110	SHAHBAD-NALWAR	NALWAR_110	05:50	05:54	00:04	TRIPPED ON FAULT
4264	26-Apr-2024	GULBARGA	LINE	110	SHAHBAD-WADI	WADI_110	20:37	20:57	00:20	LINE CLEAR AVAILED
4265	26-Apr-2024	GULBARGA	LINE	110	SULEKAL-SORABHASOLAR_IPP	SULEKAL_220	18:15	19:11	00:56	TRIPPED ON FAULT
4266	26-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	BANAVEKAL_66	11:05	14:05	03:00	LINE CLEAR AVAILED
4267	26-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	HOSAHALLI_66	16:10	16:15	00:05	TRIPPED ON FAULT
4268	26-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	HARVI_66	08:15	09:05	00:50	LINE CLEAR AVAILED
4269	26-Apr-2024	GULBARGA	TRANSFORMER	66	HV2	TELAGI_66	16:15	16:30	00:15	TRIPPED ON FAULT
4270	26-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	SOMASAMUDRA_110	17:30	19:17	01:47	LINE CLEAR AVAILED
4271	26-Apr-2024	GULBARGA	TRANSFORMER	110	HV4	ALIPUR_220	10:50	10:56	00:06	TRIPPED ON FAULT
4272	26-Apr-2024	GULBARGA	TRANSFORMER	110	HV4	ALIPUR_220	11:03	11:13	00:10	TRIPPED ON FAULT
4273	26-Apr-24	MYSORE	LINE	66	CRNAGAR-CHANDAKAWADI	CHANDAKAVADI_66	06:23	06:29	00:06	TRIPPED ON FAULT
4274	26-Apr-24	MYSORE	LINE	66	HANNUR-AMP SOLAR	NO STATIONS	00:00	00:45	00:45	LINE CLEAR AVAILED
4275	26-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS	17:07			LINE CLEAR AVAILED
4276	26-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4277	26-Apr-24	MYSORE	LINE	66	NAGAMANGALA 220-BG NAGARA	BG NAGARA_66 VADERALLI_66KADABALLI_66 ADICHUNCHANGIRI_66	10:51	10:55	00:04	TRIPPED ON FAULT
4278	26-Apr-24	MYSORE	LINE	66	NAGAMANGALA 220-NAGAMANGALA 2	NO STATIONS EFFECTED	13:31:00	13:35:00	00:04:00	TRIPPED ON FAULT
4279	26-Apr-24	MYSORE	LINE	66	SATHEGALA-KOLLEGALA	KOLLEGALA-66	22:33	22:39	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4280	26-Apr-24	MYSORE	LINE	66	SUTTUR-ALAMBUR LIFT IRRIGATION	NO STATIONS EFFECTED	03:44	10:10	06:26	TRIPPED ON FAULT
4281	26-Apr-24	MYSORE	LINE	66	THALAKADU-ADANI SOLAR	NO STATIONS EFFECTED	06:33	06:40	00:07	TRIPPED ON FAULT
4282	26-Apr-24	MYSORE	LINE	66	VAJMANGALA-KADAKOLA1	AYRAHALLI_66 MARADIHUNDI_66	10:16	10:18	00:02	TRIPPED ON FAULT
4283	26-Apr-24	MYSORE	LINE	66	VAJMANGALA-MEGHALAPURA	MEGHALAPURA_66	01:19	01:24	00:05	TRIPPED ON FAULT
4284	26-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	6:30:00 (26/04/2024)			LINE CLEAR AVAILED
4285	26-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4286	26-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4287	26-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	05:40	05:52	00:12	TRIPPED ON FAULT
4288	26-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	02:12	02:19	00:07	TRIPPED ON FAULT
4289	26-Apr-24	TUMKUR	LINE	66	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	22:05	22:10	00:05	LINE CLEAR AVAILED
4290	26-Apr-24	TUMKUR	LINE	66	BRAHMASANDRA- SUNVIK SOLARLINE	SUNVIK PLANT	18:55	19:17	00:22	TRIPPED ON FAULT
4291	26-Apr-24	TUMKUR	LINE	66	HIRIYUR 220KV- MATHOD1	MATHOD_66, HINDASGHATTA_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	18:00(26.04.24)		-	TRIPPED ON FAULT
4292	26-Apr-24	TUMKUR	LINE	66	HONNALLI 220kv- NALLUR_66	BASAVAPATNA_66	04:03	07:30	03:27	TRIPPED ON FAULT
4293	26-Apr-24	TUMKUR	TRANSFORMER	220	TR-1	HONNALLI_220	04:13	04:44	00:31	TRIPPED ON FAULT
4294	26-Apr-24	TUMKUR	TRANSFORMER	220	TR1&TR3	HIRIYUR_220	18:00	18:20	00:20	TRIPPED ON FAULT
4295	27-Apr-24	BAGALKOTE	LINE	110	BELGAUM110-KANBARGI	STATION NOT AFFECTED BELGAUM_110	11:47 (24.03.2024)	19:49 (27.04.2024)	80:02:00	LINE CLEAR AVAILED
4296	27-Apr-24	BAGALKOTE	LINE	110	BIDNAL220- ANNIGERI	BIDNAL_220	14:10	20:59	06:49	LINE CLEAR AVAILED
4297	27-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
4298	27-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4299	27-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	07:25	08:55	01:30	LINE CLEAR AVAILED
4300	27-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	04:45	04:59	00:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4301	27-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4302	27-Apr-24	BAGALKOTE	LINE	110	JAMAKHANDI-PRABHU SUGARS	STATION NOT AFFECTED JAMAKHANDI_110	16:11 (27.04.2024)			LINE CLEAR AVAILED
4303	27-Apr-24	BAGALKOTE	LINE	110	KANABARGI-BELGAUM110	KANABARGI_110	19:49	19:50	00:01	LINE CLEAR AVAILED
4304	27-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
4305	27-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4306	27-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4307	27-Apr-24	BAGALKOTE	LINE	110	MRUTHYUNJAY- NARENRA2(UAS2)	MRUTHYUNJAY NAGAR_110	7:26 (27.04.2024)			LINE CLEAR AVAILED
4308	27-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- MRUTHYUNJAY NAGAR	NARENDRA_220	19:03 (25.04.2024)			TRIPPED ON FAULT
4309	27-Apr-24	BAGALKOTE	LINE	110	NAVALAGI- F1(JAMKHANDI)	NAVALAGI_110	8:51	16:06	07:15	LINE CLEAR AVAILED
4310	27-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALGI(MUGALKHOD)	PG HUNSHYAL_110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4311	27-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4312	27-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4313	27-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4314	27-Apr-24	BAGALKOTE	LINE	110	UTTUR-F1 JAMB CB(MUDHOL)	STATION NOT AFFECTED UTTUR_110	17:20 (07.03.2024)	7:32 (27.04.2024)	1214:12:00	LINE CLEAR AVAILED
4315	27-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4316	27-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MELLIGERI	VAJRAMATTI_220	09:04	10:01	00:57	LINE CLEAR AVAILED
4317	27-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_220	09:04	09:27	00:23	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4318	27-Apr-24	BAGALKOTE	LINE	110	YLWD-F3CBreaker(ALBAL-1	YELLAMANAWADI_110, ALBAL_110	13:29	14:22	00:53	TRIPPED ON FAULT
4319	27-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - VAJARAMATTI1	BAGALKOT_220	21:20	21:51	00:31	LINE CLEAR AVAILED
4320	27-Apr-24	BAGALKOTE	LINE	220	BIDNAL- NAGJHARI2	BIDNAL_220	13:02	18:25	05:23	TRIPPED ON FAULT
4321	27-Apr-24	BAGALKOTE	LINE	220	HUBLI-NARENDRA-2	HUBLI_220	14:08	17:57	03:49	TRIPPED ON FAULT
4322	27-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
4323	27-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4324	27-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	20:34	21:34	01:00	LINE CLEAR AVAILED
4325	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	ANKALAGI_110	03:29	09:14	05:45	LINE CLEAR AVAILED
4326	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	ANKALAGI_110	17:55	18:00	00:05	LINE CLEAR AVAILED
4327	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (10MVA)	GADAG_110	09:15	10:10	00:55	LINE CLEAR AVAILED
4328	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1(10MVA)	LAXMESHWAR_110	8:34	13:23	04:49	LINE CLEAR AVAILED
4329	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	ANKALAGI_110	03:29	09:15	05:46	LINE CLEAR AVAILED
4330	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	ANKALAGI_110	17:55	18:00	00:05	LINE CLEAR AVAILED
4331	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4332	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MANTUR(G)_110	20:05	20:10	00:05	TRIPPED ON FAULT
4333	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	16:33	16:35	00:02	TRIPPED ON FAULT
4334	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	20:13	20:16	00:03	TRIPPED ON FAULT
4335	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MUKARTIHAL_110	1:06	1:11	00:05	TRIPPED ON FAULT
4336	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MUKARTIHAL_110	10:38	10:55	00:17	TRIPPED ON FAULT
4337	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MUKARTIHAL_110	11:17	11:30	00:13	TRIPPED ON FAULT
4338	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	20:28	20:37	00:09	TRIPPED ON FAULT
4339	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3(20MVA)	LAXMESHWAR_110	14:59	18:23	03:24	LINE CLEAR AVAILED
4340	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV4 (20MVA)	KULIGOD_110	17:34	19:11	01:37	LINE CLEAR AVAILED
4341	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV1 (20MVA)	KADANAKOPPA_110	08:59	11:54	02:55	LINE CLEAR AVAILED
4342	27-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3 (20MVA)	ZALKI_110	15:25	16:25	01:00	TRIPPED ON FAULT
4343	27-Apr-24	BENGALURU	LINE	66	66KV A STATION 220 - VICTORIA	VICTORIA	14:45	16:34	01:49	LINE CLEAR AVAILED
4344	27-Apr-24	BENGALURU	LINE	66	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGURU	11:54	12:00	00:06	TRIPPED ON FAULT
4345	27-Apr-24	BENGALURU	LINE	66	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGURU	14:30	14:35	00:05	TRIPPED ON FAULT
4346	27-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4347	27-Apr-24	BENGALURU	LINE	66	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	14:26	15:24	00:58	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4348	27-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	11:45	11:57	00:12	TRIPPED ON FAULT
4349	27-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	13:31	13:42	00:11	TRIPPED ON FAULT
4350	27-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	NANDAGUDI	12:20	12:25	00:05	LOAD CURTAILMENT
4351	27-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	14:30	14:40	00:10	LINE CLEAR AVAILED
4352	27-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	KADUBISANAHALLI, CESSNA(EHT)	09:04	09:31	00:27	TRIPPED ON FAULT
4353	27-Apr-24	BENGALURU	LINE	66	66KV JIGANI LINK ROAD - JIGANI OLD STATION	NO STATION AFFECTED	07:18	07:54	00:36	TRIPPED ON FAULT
4354	27-Apr-24	BENGALURU	LINE	66	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	12:07	12:12	00:05	LINE CLEAR AVAILED
4355	27-Apr-24	BENGALURU	LINE	66	66KV MALUR 220 - MASTHI	MASTHI	11:05	11:23	00:18	TRIPPED ON FAULT
4356	27-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURHALLI	17:35	17:40	00:05	LINE CLEAR AVAILED
4357	27-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4358	27-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	VIDURASHWATHA	05:40	05:45	00:05	TRIPPED ON FAULT
4359	27-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	VIDURASHWATHA, GUNDLU KOTTUR	17:30	17:40	00:10	TRIPPED ON FAULT
4360	27-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	BOMMASANDRA I/A	06:23	07:02	00:39	TRIPPED ON FAULT
4361	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	VICTORIA	14:45	16:34	01:49	TRIPPED ON FAULT
4362	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MUDIYANUR	09:35	10:00	00:25	TRIPPED ON FAULT
4363	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MUDIYANUR	10:00	11:50	01:50	LINE CLEAR AVAILED
4364	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KYASAMBALLI	10:20	10:35	00:15	TRIPPED ON FAULT
4365	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MASTHI	21:15	21:20	00:05	TRIPPED ON FAULT
4366	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUDUR	13:47	14:17	00:30	TRIPPED ON FAULT
4367	27-Apr-24	BENGALURU	TRANSFORMER	66	HV1	TAVAREKERE	09:47	10:25	00:38	LINE CLEAR AVAILED
4368	27-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TUBAGERE	03:20	03:22	00:02	TRIPPED ON FAULT
4369	27-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BOMMASANDRA I/A	06:23	10:43	04:20	TRIPPED ON FAULT
4370	27-Apr-24	BENGALURU	TRANSFORMER	66	HV2	BOMMASANDRA I/A	11:48	11:58	00:10	LINE CLEAR AVAILED
4371	27-Apr-24	BENGALURU	TRANSFORMER	66	HV3	CHIKKABALLAPURA I/A	10:38	11:40	01:02	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4372	27-Apr-2024	GULBARGA	LINE	66	MUNIRABAD-TBHES	TBHES_66	23:26(26.04.2024)	07:21(27.04.2024)	07:55HRS	TRIPPED ON FAULT
4373	27-Apr-2024	GULBARGA	LINE	110	ALIPUR-SOUTH	SOUTH_110	09:00	18:00	09:00	TRIPPED ON FAULT
4374	27-Apr-2024	GULBARGA	LINE	110	BELLARY SOUTH-HALKUNDI	HALKUNDI_110,BISIHALLI_110	17:15	17:30	00:15	MAIN SUPPLY FAILURE
4375	27-Apr-2024	GULBARGA	LINE	110	HALBARGA-KAMATHANA	KAMTHANA_110	05:21	05:32	00:11	TRIPPED ON FAULT
4376	27-Apr-2024	GULBARGA	LINE	110	MADIYAL-KAPNOOR	MADIYAL_110	16:07	16:14	00:07	TRIPPED ON FAULT
4377	27-Apr-2024	GULBARGA	LINE	110	SOMASAMUDRA-NORTH	NORTH_110, MOKA_110, PD HALLI_110, BISILHALLI_110	17:15	17:30	00:15	TRIPPED ON FAULT
4378	27-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	16:05	18:37	02:32	TRIPPED ON FAULT
4379	27-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HOSAHALLI_66	13:15	13:20	00:05	TRIPPED ON FAULT
4380	27-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HALAVAGALU_66	11:40	11:45	00:05	LINE CLEAR AVAILED
4381	27-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	GUGAL_110	16:20	17:55	01:35	TRIPPED ON FAULT
4382	27-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4383	27-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4384	27-Apr-24	MYSORE	LINE	66	SR PATNA-G UKKADA	SRIRANGAPATNA_66	05:55	06:15	00:20	TRIPPED ON FAULT
4385	27-Apr-24	MYSORE	LINE	66	YELANDURU-CR NAGARA	NO STATIONS EFFECTED	8:05 (27/4/2024)			LINE CLEAR AVAILED
4386	27-Apr-24	MYSORE	LINE	66	YELANDURU-MAMBALLI	NO STATIONS EFFECTED	05:21	05:27	00:06	TRIPPED ON FAULT
4387	27-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48 (27/4/2024)			LINE CLEAR AVAILED
4388	27-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	6:30:00 (26/04/2024)	6:44 (27/4/2024)	10:01	LINE CLEAR AVAILED
4389	27-Apr-24	MYSORE	TRANSFORMER	66	HV1	HALGUR_66	11:53	11:58	00:05	MAIN SUPPLY FAILURE
4390	27-Apr-24	MYSORE	TRANSFORMER	66	HV1	HALGUR_66	14:28	14:33	00:05	MAIN SUPPLY FAILURE
4391	27-Apr-24	MYSORE	TRANSFORMER	66	HV1	PANDAVAPURA_66	02:05	02:16	00:11	TRIPPED ON FAULT
4392	27-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4393	27-Apr-24	MYSORE	TRANSFORMER	66	HV2	HALGUR_66	11:53	11:58	00:05	MAIN SUPPLY FAILURE
4394	27-Apr-24	MYSORE	TRANSFORMER	66	HV2	HALGUR_66	14:28	14:33	00:05	MAIN SUPPLY FAILURE
4395	27-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4396	27-Apr-24	TUMKUR	LINE	66	DYAVARANAHALLI- PR PURA	PR PURA_66	03:57	04:15	00:18	TRIPPED ON FAULT
4397	27-Apr-24	TUMKUR	LINE	66	GARAGA- PANCHLI	PANCHANAHALLI_66	18:15	18:20	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4398	27-Apr-24	TUMKUR	LINE	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	20:55	21:05	00:10	TRIPPED ON FAULT
4399	27-Apr-24	TUMKUR	LINE	220	HIRIYUR 220KV- MATHOD1	MATHOD_66, HINDASGHATTA_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	18:00(26.4.24)	17:45(27.4.24)	23:45	TRIPPED ON FAULT
4400	28-Apr-24	BAGALKOTE	LINE	110	BAGALKOT220-BAGALKOT-2	BAGALKOT_220	15:39	15:50	00:11	TRIPPED ON FAULT
4401	28-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
4402	28-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4403	28-Apr-24	BAGALKOTE	LINE	110	HAVERI220- BYADAGI	HAVERI_220	18:22 (28.04.2024)			LINE CLEAR AVAILED
4404	28-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4405	28-Apr-24	BAGALKOTE	LINE	110	JAMAKHANDI-PRABHU SUGARS	STATION NOT AFFECTED JAMAKHANDI_110	16:11 (27.04.2024)	9:40 (28.04.2024)	17:29	LINE CLEAR AVAILED
4406	28-Apr-24	BAGALKOTE	LINE	110	JAMAKHANDI-PRABHU SUGARS	STATION NOT AFFECTED JAMAKHANDI_110	16:11 (27.04.2024)	09:40 (28.04.2024)	17:29	LINE CLEAR AVAILED
4407	28-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
4408	28-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4409	28-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BELGAUM SOLAR	MAMADAPUR(B)_110	20:01 (28.04.2024)			LINE CLEAR AVAILED
4410	28-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4411	28-Apr-24	BAGALKOTE	LINE	110	MRUTHYUNJAY- NARENRA2(UAS2)	MRUTHYUNJAY NAGAR_110	7:26 (27.04.2024)			LINE CLEAR AVAILED
4412	28-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- MRUTHYUNJAY NAGAR	NARENDRA_220	19:03 (25.04.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4413	28-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL-MUDALGI(MUGALKHOD)	PG HUNSHYAL_110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4414	28-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4415	28-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220-BYADAGI(GUTTAL)	RANEBENNUR_220	11:52	13:14	01:22	LINE CLEAR AVAILED
4416	28-Apr-24	BAGALKOTE	LINE	110	RANEBENNUR220- HIREKERUR	RANEBENNUR_220	13:20	18:31	05:11	LINE CLEAR AVAILED
4417	28-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4418	28-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4419	28-Apr-24	BAGALKOTE	LINE	110	UTTUR-F1 JAMB CB(MUDHOL)	MUDHOL_110,STATION NOT AFFECTED UTTUR_110,	04:33	04:42	00:09	TRIPPED ON FAULT
4420	28-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4421	28-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
4422	28-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4423	28-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI- MAHALINGAPUR1	VAJRAMATTI_220	12:15	17:49	05:34	TRIPPED ON FAULT
4424	28-Apr-24	BAGALKOTE	LINE	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	14:14	17:50	03:36	LINE CLEAR AVAILED
4425	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	HIREKERUR_110	10:34	19:04	08:30	LINE CLEAR AVAILED
4426	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	YELPHARATTI_110	21:54	22:54	01:00	LINE CLEAR AVAILED
4427	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	HIREKERUR_110	10:32	19:14	08:42	LINE CLEAR AVAILED
4428	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4429	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	NAVANAGAR(B)_110	22:22	22:27	00:05	TRIPPED ON FAULT
4430	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	1:18	1:23	00:05	TRIPPED ON FAULT
4431	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	7:52	7:56	00:04	TRIPPED ON FAULT
4432	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	8:48	9:18	00:30	TRIPPED ON FAULT
4433	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV2 (20MVA)	HANAGAL_110	17:13	17:29	00:16	TRIPPED ON FAULT
4434	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV2 (20MVA)	HANAGAL_110	18:20	18:26	00:06	TRIPPED ON FAULT
4435	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3 (20MVA)	HIREKERUR_110	10:31	18:33	08:02	LINE CLEAR AVAILED
4436	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3 (20MVA)	ZALKI_110	15:20	16:03	00:43	TRIPPED ON FAULT
4437	28-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV4 (20MVA)	ZALKI_110	21:35	21:43	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4438	28-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	14:37	14:47	00:10	TRIPPED ON FAULT
4439	28-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	15:35	15:45	00:10	TRIPPED ON FAULT
4440	28-Apr-24	BENGALURU	LINE	66	66KV ANEKAL - ATTIBELE	ATTIBELE	16:42	17:35	00:53	LINE CLEAR AVAILED
4441	28-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4442	28-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	11:55	12:13	00:18	TRIPPED ON FAULT
4443	28-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	12:38	14:01	01:23	TRIPPED ON FAULT
4444	28-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	14:39	16:00	01:21	TRIPPED ON FAULT
4445	28-Apr-24	BENGALURU	LINE	66	66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)	K&C VALLEY	18:40	19:07	00:27	TRIPPED ON FAULT
4446	28-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	06:47	07:05	00:18	TRIPPED ON FAULT
4447	28-Apr-24	BENGALURU	LINE	66	66KV SOMANAHALLI 220 - ISKCON	ISKON	11:45	12:00	00:15	LINE CLEAR AVAILED
4448	28-Apr-24	BENGALURU	LINE	66	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKON	15:17	15:24	00:07	LINE CLEAR AVAILED
4449	28-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4450	28-Apr-24	BENGALURU	LINE	220	220KV MANYATA 220 - ITI 220	NO STATION AFFECTED	13:54	16:08	02:14	TRIPPED ON FAULT
4451	28-Apr-24	BENGALURU	LINE	220	220KV PUTTENAHALLI 220 - SAHAKARNAGAR 1	NO STATION AFFECTED	13:53	14:26	00:33	TRIPPED ON FAULT
4452	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GANJIGUTE	15:20	15:25	00:05	TRIPPED ON FAULT
4453	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	GANJIGUTE	16:05	16:10	00:05	TRIPPED ON FAULT
4454	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	M GOLLAHALLI	09:12	09:35	00:23	TRIPPED ON FAULT
4455	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUDUR	14:37	15:30	00:53	TRIPPED ON FAULT
4456	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUDUR	15:34	15:46	00:12	TRIPPED ON FAULT
4457	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUDUR	16:27	16:45	00:18	TRIPPED ON FAULT
4458	28-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KUDUR	18:15	18:20	00:05	TRIPPED ON FAULT
4459	28-Apr-24	BENGALURU	TRANSFORMER	66	HV2	DEVANAHALLI 66	16:30	16:35	00:05	TRIPPED ON FAULT
4460	28-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TEKAL	12:30	17:00	04:30	TRIPPED ON FAULT
4461	28-Apr-24	BENGALURU	TRANSFORMER	66	HV2	GUDEMARANAHALLI	12:35	13:25	00:50	LINE CLEAR AVAILED
4462	28-Apr-24	BENGALURU	TRANSFORMER	66	HV2	SHIVANAHALLI	20:35	21:05	00:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4463	28-Apr-2024	GULBARGA	LINE	66	NEELGUNDA-HARAPPANAHALLI	HARAPPANAHALLI_66, SUZALON_IPP	05:43	05:48	00:05	TRIPPED ON FAULT
4464	28-Apr-2024	GULBARGA	LINE	110	GABUR-RAICHUR	GABUR_110, GUGAL_110	05:33	05:39	00:06	TRIPPED ON FAULT
4465	28-Apr-2024	GULBARGA	LINE	110	HALBARGA-KAMTHANA	KAMTHANA_110	05:21	05:32	00:11	TRIPPED ON FAULT
4466	28-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	11:30	12:02	00:32	TRIPPED ON FAULT
4467	28-Apr-24	MYSORE	LINE	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66	03:02	03:08	00:06	TRIPPED ON FAULT
4468	28-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4469	28-Apr-24	MYSORE	LINE	66	KOPPA -BESAGARAHALLI	BESAGARAHALLI_66DUNANAHALLI_66	12:38	12:44	00:06	TRIPPED ON FAULT
4470	28-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4471	28-Apr-24	MYSORE	LINE	66	PANYADAHUNDI-KARYA	HEMMARGALA_66KARYA_66	06:13	06:19	00:06	TRIPPED ON FAULT
4472	28-Apr-24	MYSORE	LINE	66	TUBINKERE-GUKKADE	SRIRANGAPATNA_66GARUDANAUKADDA_66	20:11	21:22	01:10	TRIPPED ON FAULT
4473	28-Apr-24	MYSORE	LINE	66	TUBINKERE-PANDAVAPURA	BANANGADI_66BELAGOLA_66DODDABYADARAHALLI_66PANDAVAPURA_66	20:12	20:37	00:25	TRIPPED ON FAULT
4474	28-Apr-24	MYSORE	LINE	66	YELANDURU-CR NAGARA	NO STATIONS EFFECTED	8:05 (27/4/2024)			LINE CLEAR AVAILED
4475	28-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:47 (28/04/2024)			LINE CLEAR AVAILED
4476	28-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48 (27/4/2024)	7:03 (28/04/2024)	10:15	LINE CLEAR AVAILED
4477	28-Apr-24	MYSORE	TRANSFORMER	66	HV1	ELAVALA_66	16:52	17:03	00:11	TRIPPED ON FAULT
4478	28-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4479	28-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4480	28-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV-ANCHEPALYA 2	HULLENAHALLI_66, KUNDUR_66, SRIGIRIPURA_66	14:36	14:46	00:10	TRIPPED ON FAULT
4481	28-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV-ANCHEPALYA 2	HULLENAHALLI_66, KUNDUR_66, SRIGIRIPURA_66	15:34	15:44	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4482	28-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	00:11	00:21	00:10	TRIPPED ON FAULT
4483	28-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	12:10	12:15	00:05	TRIPPED ON FAULT
4484	28-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	12:20	12:25	00:05	TRIPPED ON FAULT
4485	28-Apr-24	TUMKUR	LINE	66	KUKKAWADA-BASAVAPATNA_66	TYVANAGI_66,	17:00	17:05	00:05	TRIPPED ON FAULT
4486	28-Apr-24	TUMKUR	LINE	66	MADHURE_220- HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	18:55	19:15	00:20	TRIPPED ON FAULT
4487	28-Apr-24	TUMKUR	LINE	66	MATHOD_66-GARAGA PANCHANAHALLI LINE	GARAGA PANCHANAHALLI_66	18:50	19:10	00:20	TRIPPED ON FAULT
4488	29-Apr-24	BAGALKOTE	LINE	110	220KUDUCHI-YELPHARATTI	YELPHARATTI_110	12:20	13:05	00:45	LINE CLEAR AVAILED
4489	29-Apr-24	BAGALKOTE	LINE	110	BAGEWADI- LINGSUR2	BAGEWADI_220	13:02	13:30	06:59	TRIPPED ON FAULT
4490	29-Apr-24	BAGALKOTE	LINE	110	BELAGAVI(NEHRUNAGAR)- KANABARGI	BELAGAVI(NEHARUNAGAR)_110	17:24	19:50	02:26	LINE CLEAR AVAILED
4491	29-Apr-24	BAGALKOTE	LINE	110	DADDI- HONAGA	DADDI_110	16:10	19:27	05:59	TRIPPED ON FAULT
4492	29-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED
4493	29-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4494	29-Apr-24	BAGALKOTE	LINE	110	HAVERI220- BYADAGI	HAVERI_220	18:22 (28.04.2024)			LINE CLEAR AVAILED
4495	29-Apr-24	BAGALKOTE	LINE	110	HIDAKALDAM-AEQUS220	HIDAKALDAM_110	09:17	09:40	00:23	TRIPPED ON FAULT
4496	29-Apr-24	BAGALKOTE	LINE	110	HIDAKALDAM-ANKALAGI	HIDAKALDAM_110	09:20	09:27	00:07	LINE CLEAR AVAILED
4497	29-Apr-24	BAGALKOTE	LINE	110	HIDAKALDAM-GHATAPRABHA(G)	GHATAPRABHA(G)_110 HIDAKALDAM_110	09:30	09:39	00:09	LINE CLEAR AVAILED
4498	29-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4499	29-Apr-24	BAGALKOTE	LINE	110	KUD DHARWAD- LAKMANAHALLI	KUD DHARWAD_110	13:45	19:02	05:17	LINE CLEAR AVAILED
4500	29-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
4501	29-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4502	29-Apr-24	BAGALKOTE	LINE	110	MAMADAPUR- BELGAUM SOLAR	MAMADAPUR(B)_ 110	20:01 (28.04.2024)	5:17 (29.04.2024)	9:16:00	LINE CLEAR AVAILED
4503	29-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_ 220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4504	29-Apr-24	BAGALKOTE	LINE	110	MRUTHYUNJAY- NARENRA2(UAS2)	MRUTHYUNJAY NAGAR_ 110	7:26 (27.04.2024)	19:35 (29.04.2024)	60:09:00	LINE CLEAR AVAILED
4505	29-Apr-24	BAGALKOTE	LINE	110	NARENDRA220- MRUTHYUNJAY NAGAR	NARENDRA_ 220	19:03 (25.04.2024)	18:58 (29.04.2024)	95:55:00	TRIPPED ON FAULT
4506	29-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALGI(MUGALKHOD)	PG HUNSHYAL_ 110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4507	29-Apr-24	BAGALKOTE	LINE	110	RAIBAG-CHIKKODI2	STATION NOT AFFECTED RAIBAG_ 110	08:14	13:13	04:59	LINE CLEAR AVAILED
4508	29-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_ 110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4509	29-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_ 110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4510	29-Apr-24	BAGALKOTE	LINE	110	SIRSI-JOG2	STATION NOT AFFECTED SIRSI_ 110	18:35	18:47	00:12	LINE CLEAR AVAILED
4511	29-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_ 220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4512	29-Apr-24	BAGALKOTE	LINE	110	SUVARNAS-MACHE O/G	MACHE_ 110	09:46	10:18	00:32	TRIPPED ON FAULT
4513	29-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_ 220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4514	29-Apr-24	BAGALKOTE	LINE	220	HUBLI- NARENDRA1	HUBLI_ 220	11:13	17:16	06:03	LINE CLEAR AVAILED
4515	29-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1	SIRSI_ 220	16:22 (23.04.2024)			TRIPPED ON FAULT
4516	29-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_ 220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4517	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	ANKALAGI_ 110	06:00	06:24	00:24	TRIPPED ON FAULT
4518	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	KALADAGI_ 110	13:19	13:38	00:19	TRIPPED ON FAULT
4519	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV1 (20MVA)	YELPHARATTI_ 110	12:20	13:05	00:45	LINE CLEAR AVAILED
4520	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (10MVA)	SANKESHWAR_ 110	16:46	16:50	00:04	LINE CLEAR AVAILED
4521	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	PH COMPOUND_ 110	00:18	11:00	10:42	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4522	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2 (20MVA)	BJCTY (THORVI_110)	14:37	14:42	00:05	TRIPPED ON FAULT
4523	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4524	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	MALGHAN(B)_110	10:10	10:14	00:04	TRIPPED ON FAULT
4525	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	KALGHATAGI_110	10:03	10:19	00:16	TRIPPED ON FAULT
4526	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	08:54	09:08	00:14	TRIPPED ON FAULT
4527	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV4(10MVA)	BAGALKOT_220	15:29	16:31	01:02	TRIPPED ON FAULT
4528	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	YELPHARATTI_110	12:20	12:40	00:20	LINE CLEAR AVAILED
4529	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV,HV2 (10MVA)	TUMMINAKATTE_110	16:07	16:50	00:43	LINE CLEAR AVAILED
4530	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33/,HV3 (20MVA)	YELPHARATTI_110	12:20	13:05	00:45	LINE CLEAR AVAILED
4531	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3(10MVA)	ZALKI_110	11:30	12:00	00:30	TRIPPED ON FAULT
4532	29-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV, HV3(10MVA)	ZALKI_110	13:11	14:00	00:49	TRIPPED ON FAULT
4533	29-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	KUDACHI_220	10:00	17:17	07:17	LINE CLEAR AVAILED
4534	29-Apr-24	BENGALURU	LINE	66	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	12:41	13:01	00:20	TRIPPED ON FAULT
4535	29-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4536	29-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR	08:23	08:37	00:14	TRIPPED ON FAULT
4537	29-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 1	NARASAPURA, HONDA, WISTRON, K&C VALLEY	12:07	12:15	00:08	TRIPPED ON FAULT
4538	29-Apr-24	BENGALURU	LINE	66	66KV KOLAR - NARSAPURA 2	NARASAPURA, HONDA, WISTRON, K&C VALLEY	12:07	12:17	00:10	TRIPPED ON FAULT
4539	29-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	YELDUR, DALASANUR	18:53	19:08	00:15	TRIPPED ON FAULT
4540	29-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	09:23	09:33	00:10	TRIPPED ON FAULT
4541	29-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	09:23	09:40	00:17	TRIPPED ON FAULT
4542	29-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4543	29-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	17:00	17:10	00:10	LINE CLEAR AVAILED
4544	29-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	18:05	18:10	00:05	LINE CLEAR AVAILED
4545	29-Apr-24	BENGALURU	LINE	66	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	22:30	22:40	00:10	TRIPPED ON FAULT
4546	29-Apr-24	BENGALURU	LINE	66	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	NO STATION AFFECTED	15:25	16:15	00:50	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4547	29-Apr-24	BENGALURU	LINE	220	220KV SOMANAHALLI 220 - MYLASANDRA 1	NO STATION AFFECTED	12:25	14:25	02:00	TRIPPED ON FAULT
4548	29-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HAROBEL	14:00	14:05	00:05	LINE CLEAR AVOIDED
4549	29-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HUKUNDA	16:50	16:55	00:05	LINE CLEAR AVOIDED
4550	29-Apr-24	BENGALURU	TRANSFORMER	66	HV1	MARALAWADI	11:25	13:45	02:20	LINE CLEAR AVOIDED
4551	29-Apr-24	BENGALURU	TRANSFORMER	66	HV1	KODIGEHALLI (NELAMANGALA)	15:15	17:38	02:23	TRIPPED ON FAULT
4552	29-Apr-24	BENGALURU	TRANSFORMER	66	HV1	HUSKUR	04:00	04:25	00:25	TRIPPED ON FAULT
4553	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TUBAGERE	18:12	18:20	00:08	TRIPPED ON FAULT
4554	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	ADDAGAL	17:10	17:20	00:10	LINE CLEAR AVOIDED
4555	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	NANGLI	18:05	18:10	00:05	LINE CLEAR AVOIDED
4556	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TAMAKA	13:30	14:30	01:00	LINE CLEAR AVOIDED
4557	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HAROBEL	14:35	14:40	00:05	LINE CLEAR AVOIDED
4558	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	HUKUNDA	16:10	16:15	00:05	LINE CLEAR AVOIDED
4559	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	T BEGUR	14:10	14:20	00:10	TRIPPED ON FAULT
4560	29-Apr-24	BENGALURU	TRANSFORMER	66	HV2	T BEGUR	14:33	14:53	00:20	TRIPPED ON FAULT
4561	29-Apr-2024	GULBARGA	LINE	66	HOSAHALLI-CJ HALLI	HOSAHALLI_66, HUDEM_66	13:30	13:45	00:15	TRIPPED ON FAULT
4562	29-Apr-2024	GULBARGA	LINE	110	KUSHTAGI-KBJNL	KUSHTAGI_220	19:25	00:00	04:35	LINE CLEAR AVOIDED
4563	29-Apr-2024	GULBARGA	LINE	110	SANTHAPUR-AURAD	AURAD_110	08:40	11:35	02:55	LINE CLEAR AVOIDED
4564	29-Apr-2024	GULBARGA	LINE	220	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	13:03	13:46	00:43	TRIPPED ON FAULT
4565	29-Apr-2024	GULBARGA	LINE	220	MALLAT-LINGASUGUR	LINGASUGUR_220	13:00	13:37	00:37	TRIPPED ON FAULT
4566	29-Apr-2024	GULBARGA	LINE	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	13:03	13:47	00:44	TRIPPED ON FAULT
4567	29-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	12:08	14:10	02:02	LINE CLEAR AVOIDED
4568	29-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	HOSAHALLI_66	07:10	07:15	00:05	TRIPPED ON FAULT
4569	29-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	NEELAGUNDA_220	07:55	08:35	00:40	LINE CLEAR AVOIDED
4570	29-Apr-2024	GULBARGA	TRANSFORMER	66	HV1	NEELAGUNDA_220	15:25	15:40	00:15	LINE CLEAR AVOIDED
4571	29-Apr-24	MYSORE	LINE	66	BANNIMANTAPA -FTS2	NO STATIONS EFFECTED	07:48	08:01	00:13	TRIPPED ON FAULT
4572	29-Apr-24	MYSORE	LINE	66	CHIKKMANDYA-HAMPAPURA	NO STATIONS EFFECTED	10:15	13:15	03:00	LINE CLEAR AVOIDED
4573	29-Apr-24	MYSORE	LINE	66	CHUNCHUKATTE-BETTADAPURA 2	KITTUR_66 RAVANDUR_66	09:54	10:05	00:11	TRIPPED ON FAULT
4574	29-Apr-24	MYSORE	LINE	66	CR NAGARA-CHANDAKAWADI	CHANDAKAWADI_66	13:34	13:50	00:16	TRIPPED ON FAULT
4575	29-Apr-24	MYSORE	LINE	66	CR NAGARA-DR PETE 1	NO STATIONS EFFECTED	13:34	13:50	00:16	TRIPPED ON FAULT
4576	29-Apr-24	MYSORE	LINE	66	CR NAGARA-HONGANUR	HONGANUR_66	13:34	13:50	00:16	TRIPPED ON FAULT
4577	29-Apr-24	MYSORE	LINE	66	CR NAGARA-KOLLEGALA	MUGUR_66 JANNUR_66 THAYUR_66 TNARSIPURA_66	13:34	13:50	00:16	TRIPPED ON FAULT
4578	29-Apr-24	MYSORE	LINE	66	HUNSU2 220-HANGUD	HANAGUD_66	13:19:00	13:26:00	00:07:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4579	29-Apr-24	MYSORE	LINE	66	HUNSU2 220-HOSURGATE	HOSURGATE_66	13:19	13:26	00:07	TRIPPED ON FAULT
4580	29-Apr-24	MYSORE	LINE	66	HUNSU2 220-HUNSUR 1	HUNSUR_66 BANNIKUPPE_66 GVGUDI_66	13:19	13:26	00:07	TRIPPED ON FAULT
4581	29-Apr-24	MYSORE	LINE	66	HUNSU2 220-HUNSUR 2	HUNSUR_66 BANNIKUPPE_66 GVGUDI_66	13:19	13:26	00:07	TRIPPED ON FAULT
4582	29-Apr-24	MYSORE	LINE	66	HUNSU2 220-KAMPLAPURA	NO STATIONS EFFECTED	13:19	13:26	00:07	TRIPPED ON FAULT
4583	29-Apr-24	MYSORE	LINE	66	HUNSUR-ELVALA	YELAWALA_66	13:20	13:28	00:08	TRIPPED ON FAULT
4584	29-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4585	29-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4586	29-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-KOLLEGALA	KOLLEGALA_66 PARINAMIPURA_66	13:33	13:45	00:12	TRIPPED ON FAULT
4587	29-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-LOKKANAHALLI	PGPALYA_66 LOKKANAHALLI_66	13:33	13:45	00:12	TRIPPED ON FAULT
4588	29-Apr-24	MYSORE	LINE	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELAMDUR_66	13:33	13:45	00:12	TRIPPED ON FAULT
4589	29-Apr-24	MYSORE	LINE	66	YELANDURU-CR NAGARA	NO STATIONS EFFECTED	8:05 (27/4/2024)			LINE CLEAR AVAILED
4590	29-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:29:00 (29/4/2024)			LINE CLEAR AVAILED
4591	29-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:47 (28/04/2024)	7:03:00 (29/04/2024)	10:16	LINE CLEAR AVAILED
4592	29-Apr-24	MYSORE	TRANSFORMER	66	HV1	CHIKKMANDYA_66	16:45	18:10	01:25	LINE CLEAR AVAILED
4593	29-Apr-24	MYSORE	TRANSFORMER	66	HV1	HALAGURU_66	14:35	14:38	00:03	LINE CLEAR AVAILED
4594	29-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4595	29-Apr-24	MYSORE	TRANSFORMER	66	HV2	GUNDLUPETE_66	12:20	12:25	00:05	TRIPPED ON FAULT
4596	29-Apr-24	MYSORE	TRANSFORMER	66	HV2	HALAGURU_66	14:30	14:50	00:20	LINE CLEAR AVAILED
4597	29-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4598	29-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	21:20	21:32	00:12	LINE CLEAR AVAILED
4599	29-Apr-24	TUMKUR	LINE	66	ANCHEPALYA 220kV- ANCHEPALYA2	HULLENAHALLI_66, KUNDUR_66, SRIGIRIPURA_66	12:42	13:01	00:18	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4600	29-Apr-24	TUMKUR	LINE	66	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	01:41	01:50	00:09	MAIN SUPPLY FAILURE
4601	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:12	09:15	00:03	TRIPPED ON FAULT
4602	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:26	09:42	00:16	TRIPPED ON FAULT
4603	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	15:43	15:48	00:05	TRIPPED ON FAULT
4604	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	15:51	16:00	00:09	TRIPPED ON FAULT
4605	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	10:35	10:41	00:06	TRIPPED ON FAULT
4606	29-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	10:43	10:57	00:14	TRIPPED ON FAULT
4607	29-Apr-24	TUMKUR	LINE	66	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	11:24	11:54	00:30	LINE CLEAR AVAILED
4608	29-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, ATTIGERE_66	10:10	10:21	00:11	TRIPPED ON FAULT
4609	29-Apr-24	TUMKUR	LINE	66	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	11:24	11:54	00:30	LINE CLEAR AVAILED
4610	29-Apr-24	TUMKUR	LINE	66	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	21:30	21:43	00:13	TRIPPED ON FAULT
4611	29-Apr-24	TUMKUR	LINE	110	HONNAVALLI 110-KADUR220(ARASEKERE)	HONNAVALLI_110	13:20	13:50	00:30	LINE CLEAR AVAILED
4612	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	BUKKAPATNA_66	10:00	10:05	00:05	TRIPPED ON FAULT
4613	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HIRIYUR_66	09:52	09:54	00:02	TRIPPED ON FAULT
4614	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HOLALKERE_66	17:20	17:30	00:10	TRIPPED ON FAULT
4615	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	KUNIGAL_66	11:45	12:40	00:55	LINE CLEAR AVAILED
4616	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	10:55	11:00	00:05	TRIPPED ON FAULT
4617	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	12:10	12:15	00:05	TRIPPED ON FAULT
4618	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	17:35	17:40	00:05	TRIPPED ON FAULT
4619	29-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	SASALUHALLA_66	10:13	10:23	00:10	TRIPPED ON FAULT
4620	30-Apr-24	BAGALKOTE	LINE	110	220/110KV, LV2	ATHANI_220	10:33	11:28	00:55	LINE CLEAR AVAILED
4621	30-Apr-24	BAGALKOTE	LINE	110	ATHANI220- GHATANATTI	ATHANI_220	00:24	00:31	00:07	TRIPPED ON FAULT
4622	30-Apr-24	BAGALKOTE	LINE	110	ATHANI220- HALIYAL	ATHANI_220	15:09	15:14	00:05	LINE CLEAR AVAILED
4623	30-Apr-24	BAGALKOTE	LINE	110	DAMBAL-SUZLON2(L2)	DAMBAL_110	17:30 (24.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4624	30-Apr-24	BAGALKOTE	LINE	110	DAVALESH-110KVI/CMAHALIN	STATION NOT AFFECTED DAVALESHWAR_110	17:26 (22.04.2024)			LINE CLEAR AVAILED
4625	30-Apr-24	BAGALKOTE	LINE	110	GAJENDRAGAD- RON1	GAJENDRAGAD_110	5:35 (30.04.2024)			LINE CLEAR AVAILED
4626	30-Apr-24	BAGALKOTE	LINE	110	GAJENDRAGAD- RON2	GAJENDRAGAD_110	00:01 (01.02.2024)	5:43 (30.04.2024)	2165:42:00	LINE CLEAR AVAILED
4627	30-Apr-24	BAGALKOTE	LINE	110	GHATAPRABHA220-KABBUR	GHATAPRABHA_220	07:22	07:36	00:14	TRIPPED ON FAULT
4628	30-Apr-24	BAGALKOTE	LINE	110	HAVERI220- BYADAGI	HAVERI_220	18:22 (28.04.2024)			LINE CLEAR AVAILED
4629	30-Apr-24	BAGALKOTE	LINE	110	HAVERI220- TILUVALLI(HANGAL)	HAVERI_220	18:16	18:30	00:14	TRIPPED ON FAULT
4630	30-Apr-24	BAGALKOTE	LINE	110	HIDIKDAM-ANKALGI (ISLAMPUR)	STATION NOT AFFECTED HIDIKAL DAM_110	17:39 (20.04.2024)			LINE CLEAR AVAILED
4631	30-Apr-24	BAGALKOTE	LINE	110	KUDACHI220- AINAPUR(YALPARATTI)	KUDACHI_220	12:25	13:07	00:42	LINE CLEAR AVAILED
4632	30-Apr-24	BAGALKOTE	LINE	110	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
4633	30-Apr-24	BAGALKOTE	LINE	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4634	30-Apr-24	BAGALKOTE	LINE	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4635	30-Apr-24	BAGALKOTE	LINE	110	MUDDEBIHAL- KNM SOLAR(HIREMURAL)	MUDDEBIHAL_110	14:25	14:39	00:14	TRIPPED ON FAULT
4636	30-Apr-24	BAGALKOTE	LINE	110	PG HUNSHYAL- MUDALGI(MUGALKHOD)	PG HUNSHYAL_110	13:16 (25.04.2024)			LINE CLEAR AVAILED
4637	30-Apr-24	BAGALKOTE	LINE	110	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
4638	30-Apr-24	BAGALKOTE	LINE	110	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4639	30-Apr-24	BAGALKOTE	LINE	110	RON-GAJENDRAGAD1	STATION NOT AFFECTED RON_110	05:29	07:39	02:10	TRIPPED ON FAULT
4640	30-Apr-24	BAGALKOTE	LINE	110	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4641	30-Apr-24	BAGALKOTE	LINE	110	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4642	30-Apr-24	BAGALKOTE	LINE	110	YLWD-F3 Cbreaker (ALBAL 1)	YELLAMANAWADI _110	13:19	14:48	01:29	TRIPPED ON FAULT
4643	30-Apr-24	BAGALKOTE	LINE	220	ATHANI- MAHALINGAPUR	ATHANI_220	11:30	11:44	00:14	TRIPPED ON FAULT
4644	30-Apr-24	BAGALKOTE	LINE	220	BAGALKOT - KOPPAL LIS	BAGALKOT_220	19:53	20:07	00:14	TRIPPED ON FAULT
4645	30-Apr-24	BAGALKOTE	LINE	220	MAHALINGAPUR- ATHANI	MAHALINGAPUR_220	11:14	11:45	00:31	TRIPPED ON FAULT
4646	30-Apr-24	BAGALKOTE	LINE	220	SIRSI- HUBLI1&2	SIRSI_220	16:22 (23.04.2024)			TRIPPED ON FAULT
4647	30-Apr-24	BAGALKOTE	LINE	220	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4648	30-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(10MVA)	SINGATALUR_110	10:20 (22.04.2024)			TRIPPED ON FAULT
4649	30-Apr-24	BAGALKOTE	TRANSFORMER	110	110/11KV, HV2(20MVA)	HATTARAGI_110	03:12	13:11	09:59	TRIPPED ON FAULT
4650	30-Apr-24	BAGALKOTE	TRANSFORMER	110	110/33KV,HV3 (10MVA)	ZALKI_110	13:03	16:23	03:20	TRIPPED ON FAULT
4651	30-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV1	KUDACHI_220	18:20	18:41	00:21	TRIPPED ON FAULT
4652	30-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV2	KUDACHI_220	18:20	18:41	00:21	TRIPPED ON FAULT
4653	30-Apr-24	BAGALKOTE	TRANSFORMER	220	220/110KV, HV3	KUDACHI_220	18:20	18:42	00:22	TRIPPED ON FAULT
4654	30-Apr-24	BENGALURU	LINE	66	66KV ANEKAL - ATTIBELE	ATTIBELE(TR1)	15:24	15:46	00:22	LINE CLEAR AVAILED
4655	30-Apr-24	BENGALURU	LINE	66	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4656	30-Apr-24	BENGALURU	LINE	66	66KV AVANI - MULABAGAL	MULBAGAL	06:00	06:18	00:18	TRIPPED ON FAULT
4657	30-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDAGUNTE	13:25	13:30	00:05	TRIPPED ON FAULT
4658	30-Apr-24	BENGALURU	LINE	66	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	PALLICHERLU, GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	13:25	13:29	00:04	MAIN SUPPLY FAILURE
4659	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - 66KV CHINTAMANI	CHINTAMANI 66, SM MANGALA	12:31	13:57	01:26	MAIN SUPPLY FAILURE
4660	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - GANJIGUNTE 1	PALLICHERLU, GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	12:31	13:03	00:32	MAIN SUPPLY FAILURE
4661	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - GANJIGUNTE 1	PALLICHERLU, GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	16:20	16:27	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4662	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - GANJIGUNTE 2	PALLICHERLU, GANJIGUNTE, DIBBURAHALLI, BURUDAGUNTE	12:31	13:03	00:32	MAIN SUPPLY FAILURE
4663	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - IRGAMPALLY	IRAGAMPALLI, M GOLLAHALLI	12:31	13:22	00:51	MAIN SUPPLY FAILURE
4664	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGANAHALLI	12:31	14:03	01:32	MAIN SUPPLY FAILURE
4665	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR	12:31	14:01	01:30	MAIN SUPPLY FAILURE
4666	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	12:31	13:21	00:50	MAIN SUPPLY FAILURE
4667	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION	12:31	13:35	01:04	MAIN SUPPLY FAILURE
4668	30-Apr-24	BENGALURU	LINE	66	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION	13:55	13:58	00:03	LINE CLEAR AVAILED
4669	30-Apr-24	BENGALURU	LINE	66	66KV CHINTMANI 220 - RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI, YENIGADALE	12:31	13:35	01:04	MAIN SUPPLY FAILURE
4670	30-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - HIREHALLI	HIREHALLI, HONNUDIKE	00:15	00:29	00:14	LINE CLEAR AVAILED
4671	30-Apr-24	BENGALURU	LINE	66	66KV DABASPETE 220 - HIREHALLI	HIREHALLI, HONNUDIKE	12:03	12:19	00:16	LINE CLEAR AVAILED
4672	30-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	13:02	13:13	00:11	TRIPPED ON FAULT
4673	30-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	14:06	16:33	02:27	TRIPPED ON FAULT
4674	30-Apr-24	BENGALURU	LINE	66	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE	15:44	18:09	02:25	TRIPPED ON FAULT
4675	30-Apr-24	BENGALURU	LINE	66	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	05:10	05:21	00:11	TRIPPED ON FAULT
4676	30-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)	AMAR JYOTHI, GOLF LINK	22:47	23:15	00:28	TRIPPED ON FAULT
4677	30-Apr-24	BENGALURU	LINE	66	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	KADUBISANAHALLI, CESSNA(EHT)	18:12	19:00	00:48	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4678	30-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	15:18	15:25	00:07	LINE CLEAR AVAILED
4679	30-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLI - BURUDAGUNTE	IRAGAMPALLI, M GOLLAHALLI M GOLLAHALLI, IRGAMPALLI	13:27	13:33	00:06	LINE CLEAR AVAILED
4680	30-Apr-24	BENGALURU	LINE	66	66KV IRGAMPALLY - M GOLLAHALLY		14:08	14:15	00:07	LINE CLEAR AVAILED
4681	30-Apr-24	BENGALURU	LINE	66	66KV KYASAMBALLI - DODDAKARI	DODDAKARI	08:55	19:55	11:00	LINE CLEAR AVAILED
4682	30-Apr-24	BENGALURU	LINE	66	66KV LAKKUR - DEVANAGUNDHI	LAKKUR, DEVANAGUNDHI	02:50	03:10	00:20	TRIPPED ON FAULT
4683	30-Apr-24	BENGALURU	LINE	66	66KV LAKKUR - DEVANAGUNDHI	LAKKUR, DEVANAGUNDHI	09:25	09:50	00:25	TRIPPED ON FAULT
4684	30-Apr-24	BENGALURU	LINE	66	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLI	16:21	16:42	00:21	TRIPPED ON FAULT
4685	30-Apr-24	BENGALURU	LINE	66	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	SM MANGALA	13:55	14:09	00:14	LINE CLEAR AVAILED
4686	30-Apr-24	BENGALURU	LINE	66	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANUKUNTE	13:09	13:23	00:14	TRIPPED ON FAULT
4687	30-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, RAGHUTTAHALLI	14:01	14:05	00:04	LINE CLEAR AVAILED
4688	30-Apr-24	BENGALURU	LINE	66	66KV RAGHUTTAHALLI - BOMMEPALLI	K RAGHUTTAHALLI, BOMMEPALLI, YENIGADALE	13:58	14:05	00:07	LINE CLEAR AVAILED
4689	30-Apr-24	BENGALURU	LINE	66	66KV SIDDALAGHATTA - MELUR	SIDDALAGHATTA, MELUR	14:19	14:22	00:03	LINE CLEAR AVAILED
4690	30-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - G KODIHALLI	G KODIHALLI	12:31	14:07	01:36	MAIN SUPPLY FAILURE
4691	30-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	12:31	14:03	01:32	MAIN SUPPLY FAILURE
4692	30-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 1	SRINIVASAPURA 66	12:31	13:55	01:24	MAIN SUPPLY FAILURE
4693	30-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	12:31	14:01	01:30	MAIN SUPPLY FAILURE
4694	30-Apr-24	BENGALURU	LINE	66	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	YELDUR, DALASANUR	12:31	14:05	01:34	MAIN SUPPLY FAILURE
4695	30-Apr-24	BENGALURU	LINE	66	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	06:01	06:12	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4696	30-Apr-24	BENGALURU	LINE	66	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	00:00	23:59	23:59	TRIPPED ON FAULT
4697	30-Apr-24	BENGALURU	LINE	66	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	YENNIGADALE	14:10	14:14	00:04	LINE CLEAR AVAILED
4698	30-Apr-24	BENGALURU	LINE	220	220KV PGCIL KOLAR 400 - CHINTAMANI 1	CHINTAMANI 220	12:31	13:48	01:17	TRIPPED ON FAULT
4699	30-Apr-24	BENGALURU	LINE	220	220KV PGCIL KOLAR 400 - CHINTAMANI 2	NO STATION AFFECTED	12:21	14:52	02:31	TRIPPED ON FAULT
4700	30-Apr-24	BENGALURU	TRANSFORMER	66	HV1	DEVANAGUNDHI	10:06	12:06	02:00	TRIPPED ON FAULT
4701	30-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KADUBISANAHALLI	18:33	19:01	00:28	TRIPPED ON FAULT
4702	30-Apr-24	BENGALURU	TRANSFORMER	66	HV2	KUNDANA	12:40	14:00	01:20	LINE CLEAR AVAILED
4703	30-Apr-24	BENGALURU	TRANSFORMER	66	HV2	TUBAGERE	23:20	23:53	00:33	LINE CLEAR AVAILED
4704	30-Apr-24	BENGALURU	TRANSFORMER	66	HV2	THAYALUR	17:00	17:25	00:25	LINE CLEAR AVAILED
4705	30-Apr-24	BENGALURU	TRANSFORMER	66	HV2	AGALAKOTE	11:15	11:45	00:30	LINE CLEAR AVAILED
4706	30-Apr-2024	GULBARGA	LINE	110	BYAGWAT-MALLAT	WALKAMDINI_110, BYAGWAT_110	01:18	01:38	00:20	TRIPPED ON FAULT
4707	30-Apr-2024	GULBARGA	LINE	110	HALWARTHY-KOPPAL2	KOPPAL_110	17:21	17:43	00:22	LINE CLEAR AVAILED
4708	30-Apr-2024	GULBARGA	LINE	110	KUSHTAGI-KBJNL	KUSHTAGI_220	00:00	13:15	13:15	LINE CLEAR AVAILED
4709	30-Apr-2024	GULBARGA	LINE	110	PDHALLI-JANAKI_IPP	PDHALLI_110	09:55	18:05	08:10	LINE CLEAR AVAILED
4710	30-Apr-2024	GULBARGA	LINE	110	RAICHUR-SHAHAPUR2	GABUR_110, GUGAL_110	16:39	17:00	00:21	TRIPPED ON FAULT
4711	30-Apr-2024	GULBARGA	LINE	110	SIRIGERICROSS-SIRIGUPPA	SIRIGUPPA_110	16:52	17:12	00:20	LINE CLEAR AVAILED
4712	30-Apr-2024	GULBARGA	LINE	110	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,DHADE SUGUR_110,TEKKALCO TE_110,SIRIGERICROSS_110	12:31	12:51	00:20	MAIN SUPPLY FAILURE
4713	30-Apr-2024	GULBARGA	LINE	110	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,DHADE SUGUR_110,TEKKALCO TE_110,SIRIGERICROSS_110	13:10	13:55	00:45	MAIN SUPPLY FAILURE
4714	30-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-SULEKAL	SINDHANOOR_220	12:30	12:50	00:20	TRIPPED ON FAULT
4715	30-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-SULEKAL	SINDHANOOR_220	13:10	14:25	01:15	TRIPPED ON FAULT
4716	30-Apr-2024	GULBARGA	LINE	220	SINDHANOOR-SULEKAL	SINDHANOOR_220	14:25	17:43	03:18	LINE CLEAR AVAILED
4717	30-Apr-2024	GULBARGA	TRANSFORMER	110	HV1	HANUMSAGAR_110	07:50	08:20	00:30	LINE CLEAR AVAILED
4718	30-Apr-2024	GULBARGA	TRANSFORMER	220	HV1	LINGASUGUR_220	00:00	11:19	11:19	LINE CLEAR AVAILED
4719	30-Apr-24	MYSORE	LINE	66	220KV BEGUR-SARGUR	NO STATIONS EFFECTED	09:34	09:43	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4720	30-Apr-24	MYSORE	LINE	66	JAYAPURA-KADAKOLA	JAIPUR_66HAMPAPURA (K)_66YEREHALLIHAND POST_66,HDKOTE_66,ANTHARSANTHE_66SANTHESARAGUR_66CHANDRAVADI_66HURA_66	10:03	10:09	00:06	TRIPPED ON FAULT
4721	30-Apr-24	MYSORE	LINE	66	KADAKOLA-SARGUR1	JAIPUR_66HAMPAPURA (K)_66YEREHALLIHAND POST_66,HDKOTE_66,ANTHARSANTHE_66SANTHESARAGUR_66CHANDRAVADI_66HURA_66	09:39	09:48	00:09	TRIPPED ON FAULT
4722	30-Apr-24	MYSORE	LINE	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4723	30-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-MUTTINAMULLUSOGE LIFT IRRIGATION	NO STATIONS EFFECTED	1:54 (26/03/2024)			TRIPPED ON FAULT
4724	30-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-PERIYAPATNA-1	NO STATIONS EFFECTED	18:29	19:05	00:35	TRIPPED ON FAULT
4725	30-Apr-24	MYSORE	LINE	66	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	13:12	13:19	00:07	TRIPPED ON FAULT
4726	30-Apr-24	MYSORE	LINE	66	PERIYAPATNA-BYLUKUPPE	BYLUKUPPE_66PERIYAPATNA_66	18:26	19:08	00:42	TRIPPED ON FAULT
4727	30-Apr-24	MYSORE	LINE	66	PONNAMPETE-HANGODU	NO STATIONS EFFECTED	18:29	19:20	00:51	TRIPPED ON FAULT
4728	30-Apr-24	MYSORE	LINE	66	PONNAMPETE-VIRAJPET	NO STATIONS EFFECTED	11:48	13:28	01:39	LINE CLEAR AVAILED
4729	30-Apr-24	MYSORE	LINE	66	SANTHE SARGUR-BEGUR	NO STATIONS EFFECTED	09:48:00	10:08:00	00:20:00	TRIPPED ON FAULT
4730	30-Apr-24	MYSORE	LINE	66	YELANDURU-CR NAGARA	NO STATIONS EFFECTED	8:05 (27/4/2024)			LINE CLEAR AVAILED
4731	30-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:40 (30/04/2024)			LINE CLEAR AVAILED
4732	30-Apr-24	MYSORE	LINE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:29:00 (29/4/2024)	7:33 (30/04/2024)	10:45	LINE CLEAR AVAILED
4733	30-Apr-24	MYSORE	TRANSFORMER	66	HV1	HANAGODU_66	12:59	13:04	00:05	TRIPPED ON FAULT
4734	30-Apr-24	MYSORE	TRANSFORMER	66	HV1	PERIYAPATNA_66	18:26 (30/04/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	TRF/ LINE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4735	30-Apr-24	MYSORE	TRANSFORMER	66	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4736	30-Apr-24	MYSORE	TRANSFORMER	66	HV2	HANAGODU_66	19:00	20:54	01:54	LINE CLEAR AVAILED
4737	30-Apr-24	MYSORE	TRANSFORMER	66	HV2	PERIYAPATNA_66	12:06	12:49	00:43	LINE CLEAR AVAILED
4738	30-Apr-24	MYSORE	TRANSFORMER	66	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4739	30-Apr-24	TUMKUR	LINE	66	MADHUGIRI_66-MADHUGIRI 220kV	MADHUGIRI_66, BADAVANAHALLI_66	14:57	15:08	00:11	TRIPPED ON FAULT
4740	30-Apr-24	TUMKUR	LINE	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	10:33	12:37	02:03	LINE CLEAR AVAILED
4741	30-Apr-24	TUMKUR	LINE	66	BENKIKERE 220kV-NALLUR	NALLUR_66	18:01	18:09	00:08	TRIPPED ON FAULT
4742	30-Apr-24	TUMKUR	LINE	66	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	11:40	11:51	00:11	TRIPPED ON FAULT
4743	30-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- MADHUGIRI_66	MADHUGIRI_66, BADAVANAHALLI_66	13:15	13:22	00:07	TRIPPED ON FAULT
4744	30-Apr-24	TUMKUR	LINE	66	MADHUGIRI 220kV- MADHUGIRI_66	MADHUGIRI_66, BADAVANAHALLI_66	13:40	14:34	00:54	LINE CLEAR AVAILED
4745	30-Apr-24	TUMKUR	LINE	66	MADHUGIRI 66kV- BADAVANAHALLI_66	BADAVANAHALLI_66	14:57	15:08	00:11	TRIPPED ON FAULT
4746	30-Apr-24	TUMKUR	LINE	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	15:25	15:40	00:15	TRIPPED ON FAULT
4747	30-Apr-24	TUMKUR	LINE	66	PAVAGADA220-MADHUGIRI	MADHUGIRI_220	13:08	13:15	00:06	TRIPPED ON FAULT
4748	30-Apr-24	TUMKUR	LINE	220	DAVANGERE SRS- HONNALI LINE 2	HONNALLI_220	07:12	07:27	00:14	TRIPPED ON FAULT
4749	30-Apr-24	TUMKUR	LINE	220	HONNALLI 220kV-DAVANAGERE SRS LINE 1	HONNALLI_220	13:28	13:48	00:20	TRIPPED ON FAULT
4750	30-Apr-24	TUMKUR	LINE	220	HONNALLI 220kV-DAVANAGERE SRS LINE 2	HONNALLI_220	13:28	13:48	00:20	TRIPPED ON FAULT
4751	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	CHITRADURGA_66	07:17	07:22	00:05	TRIPPED ON FAULT
4752	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	HANGAL_66	17:31	18:00	00:29	LINE CLEAR AVAILED
4753	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	LINGADAHALLI_66	20:42	20:48	00:06	TRIPPED ON FAULT
4754	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-1	MALLAPPANAHALLI_66	02:05	02:16	00:10	TRIPPED ON FAULT
4755	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	HONNUDIKE_66	00:00	13:25	13:25	TRIPPED ON FAULT
4756	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MADADKRE_66	17:40	17:46	00:06	TRIPPED ON FAULT
4757	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	10:25	12:15	01:50	TRIPPED ON FAULT
4758	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	14:05	14:20	00:15	TRIPPED ON FAULT
4759	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	15:10	15:25	00:15	TRIPPED ON FAULT
4760	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-2	MELLEKATTE_66	23:45	23:50	00:05	TRIPPED ON FAULT
4761	30-Apr-24	TUMKUR	TRANSFORMER	66	TR-3	HOLALKERE_66	17:09	17:15	00:06	TRIPPED ON FAULT
4762	30-Apr-24	TUMKUR	TRANSFORMER	220	TR-2	HIRIYUR_220	21:00	21:20	00:20	TRIPPED ON FAULT