

400/220/110/66 kV TRANSMISSION OUTAGES FOR THE MONTH OF FEBRUARY-2024

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	PG HUNSHYAL_110	12:50 (31.01.2024)	20:04 (01.02.2024)	31:14:00	TRIPPED ON FAULT
2	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	ALBAL_110	10:26	12:13	01:47	LINE CLEAR AVAILED
3	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALADAGI_110	14:37	15:38	01:01	LINE CLEAR AVAILED
4	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	SINDAGI_110	10:52	13:53	03:01	LINE CLEAR AVAILED
5	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	HIREKERUR_110	12:22	13:15	00:53	LINE CLEAR AVAILED
6	01-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	UGARKHUD_110	13:26	14:58	01:32	TRIPPED ON FAULT
7	01-Feb-24	BAGALKOTE	110	LINE	ANKOLA- KUMTA(L2)	ANKOLA_110	09:09	19:24	10:15	LINE CLEAR AVAILED
8	01-Feb-24	BAGALKOTE	110	LINE	ANNIGERI- GADAG	ANNIGERI_110	11:25	14:40	03:15	LINE CLEAR AVAILED
9	01-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
10	01-Feb-24	BAGALKOTE	110	LINE	GADAGROAD- BIDNAL (GOPPANAKOPPA)	GADAG ROAD_110	21:16 (28.01.2024)	17:20 (01.02.2024)	92:04:00	LINE CLEAR AVAILED
11	01-Feb-24	BAGALKOTE	110	LINE	GADG ROAD- GOPPANAKOPPA	STATION NOT AFFECTED GADAG ROAD_110	10:02	17:20	07:18	TRIPPED ON FAULT
12	01-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA220- SURYODAYA SOLAR	GHATAPRABHA_220	00:45	00:48	00:03	LINE CLEAR AVAILED
13	01-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- GADAG ROAD	GOPPANAKOPPA_110	12:48	17:25	04:37	LINE CLEAR AVAILED
14	01-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- GADAG ROAD	STATION NOT AFFECTED GOPPANAKOPPA_110	21:45 (28.01.2024)	12:39 (01.02.2024)	86:45:00	LINE CLEAR AVAILED
15	01-Feb-24	BAGALKOTE	110	LINE	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
16	01-Feb-24	BAGALKOTE	110	LINE	KUMATA- SIRSI1(RAILWAY)	KUMATA_110	12:25	14:34	02:09	LINE CLEAR AVAILED
17	01-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
18	01-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
19	01-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD-RAIBAG2	STATION NOT AFFECTED MUGALKHOD_220	13:47	14:33	00:46	TRIPPED ON FAULT
20	01-Feb-24	BAGALKOTE	110	LINE	MUNDARGI- VIJAYANAGAR SUGARS	MUNDARGI_110	06:50	06:59	00:09	TRIPPED ON FAULT
21	01-Feb-24	BAGALKOTE	110	LINE	NARENDRA-TADASINAKOPPA	STATION NOT AFFECTED NARENDRA_220	11:13	13:45	02:32	LINE CLEAR AVAILED
22	01-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
23	01-Feb-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
24	01-Feb-24	BAGALKOTE	220	LINE	BIDNAL- HUBLI3(HUBLI2)	BIDNAL_220	10:05	18:36	08:31	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
25	01-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
26	01-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
27	01-Feb-24	BAGALKOTE	220	LINE	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	10:05	18:36	08:31	LINE CLEAR AVAILED
28	01-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
29	01-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
30	01-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
31	01-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
32	01-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE, SHIVANAHALLI DAIRY	08:51	09:01	00:10	TRIPPED ON FAULT
33	01-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	NO STATION AFFECTED	06:27	08:34	02:07	TRIPPED ON FAULT
34	01-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	11:26	11:55	00:29	LINE CLEAR AVAILED
35	01-Feb-24	BENGALURU	66	LINE	66KV HANUMANTHANAGARA - YEDAMADU	HANUMANTHANAGARA	16:25	16:35	00:10	MAIN SUPPLY FAILURE
36	01-Feb-24	BENGALURU	66	LINE	66KV ISRO - SARAKKI 1	NO STATION AFFECTED	06:42	07:41	00:59	TRIPPED ON FAULT
37	01-Feb-24	BENGALURU	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	DOMMASANDRA	15:33	15:40	00:07	LINE CLEAR AVAILED
38	01-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	HANUMANTHANAGARA	17:35	17:40	00:05	LINE CLEAR AVAILED
39	01-Feb-24	BENGALURU	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	14:10	14:45	00:35	LINE CLEAR AVAILED
40	01-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	DEVANGONDHI, LAKKUR	17:57	18:43	00:46	MAIN SUPPLY FAILURE
41	01-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	17:21	18:21	01:00	MAIN SUPPLY FAILURE
42	01-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	17:57	18:43	00:46	TRIPPED ON FAULT
43	01-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	11:33	11:36	00:03	LINE CLEAR AVAILED
44	01-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	14:00	14:02	00:02	LINE CLEAR AVAILED
45	01-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:30	14:51	00:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
46	01-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	YEDUMADU	16:25	16:48	00:23	TRIPPED ON FAULT
47	01-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB(EHT)	12:08	12:18	00:10	TRIPPED ON FAULT
48	01-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB(EHT)	12:20	12:25	00:05	TRIPPED ON FAULT
49	01-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	VIJAYAPURA, JANGAMKOTE	10:31	10:37	00:06	LINE CLEAR AVAILED
50	01-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	VIJAYAPURA, JANGAMKOTE	17:38	17:41	00:03	LINE CLEAR AVAILED
51	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BYADRAHALLI	09:47	10:00	00:13	LINE CLEAR AVAILED
52	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	CHAKAVELU	10:45	11:05	00:20	LINE CLEAR AVAILED
53	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	10:24	10:29	00:05	TRIPPED ON FAULT
54	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VR DODDI	12:55	13:45	00:50	LINE CLEAR AVAILED
55	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	03:23	06:00	02:37	TRIPPED ON FAULT
56	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BV HALLI	01:28	01:33	00:05	TRIPPED ON FAULT
57	01-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KADUGODI	22:50	23:25	00:35	TRIPPED ON FAULT
58	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	K&C VALLEY	16:45	17:00	00:15	LINE CLEAR AVAILED
59	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	RMZ	13:28	13:32	00:04	LINE CLEAR AVAILED
60	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	17:32	17:36	00:04	LINE CLEAR AVAILED
61	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TUBAGERE	15:34	16:08	00:34	LINE CLEAR AVAILED
62	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TALAGUNDA	12:50	13:25	00:35	TRIPPED ON FAULT
63	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TAMAKA	13:00	13:45	00:45	LINE CLEAR AVAILED
64	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	THAYALUR	12:30	12:55	00:25	LINE CLEAR AVAILED
65	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VR DODDI	14:05	14:45	00:40	LINE CLEAR AVAILED
66	01-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DASHAVARA	07:10	08:25	01:15	TRIPPED ON FAULT
67	01-Feb-24	BENGALURU	66	TRANSFORMER	HV3	KGF	03:45	04:20	00:35	TRIPPED ON FAULT
68	01-Feb-24	BENGALURU	66	TRANSFORMER	HV3	KGF	07:30	08:40	01:10	TRIPPED ON FAULT
69	01-Feb-24	BENGALURU	220	LINE	LV1	MALUR 220	17:57	18:21	00:24	TRIPPED ON FAULT
70	1-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	11:55	12:00	00:05	TRIPPED ON FAULT
71	1-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	SOVENHALLI_66, TBPCL_IPP	05:37	05:47	00:10	TRIPPED ON FAULT
72	1-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	GUGAL_110	12:35	12:55	00:20	TRIPPED ON FAULT
73	1-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	NALWAR_110	14:20	14:35	00:15	TRIPPED ON FAULT
74	1-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SOMASAMUNDRA_110	03:44	04:23	00:39	TRIPPED ON FAULT
75	1-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	02:15	02:25	00:10	TRIPPED ON FAULT
76	1-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	10:50	11:00	00:10	TRIPPED ON FAULT
77	1-Feb-2024	GULBARGA	110	LINE	SOMASAMUNDRA-ALIPUR	SOMASAMUNDRA_110	03:44	03:55	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
78	1-Feb-2024	GULBARGA	110	LINE	VENKATAGIRI-MUNIRABAD	VENKATAGIRI_110	18:58	19:08	00:10	MAIN SUPPLY FAILURE
79	01-Feb-24	HASSAN	66	LINE	HASSN22-CHIKAMAGLUR2	HASSAN_220	02:52	03:14	00:22	TRIPPED ON FAULT
80	01-Feb-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	02:52	03:14	00:22	TRIPPED ON FAULT
81	01-Feb-24	HASSAN	66	LINE	UDDURKO-NITTTUR1	UDDURKOPPLU_66	02:25	16:40	14:15	TRIPPED ON FAULT
82	01-Feb-24	HASSAN	66	LINE	UDDURKO-NITTTUR1	UDDURKOPPLU_66	16:45	18:50	02:05	LINE CLEAR AVAILED
83	01-Feb-24	HASSAN	66	LINE	UDDURKO-NITTUR2	UDDURKOPPLU_66	02:50	03:50	01:00	TRIPPED ON FAULT
84	01-Feb-24	HASSAN	66	LINE	UDDURKO-UDDUR	UDDURKOPPLU_66	02:50	03:20	00:30	TRIPPED ON FAULT
85	01-Feb-24	HASSAN	110	LINE	KADUR-AJAMPURA	KADUR_220	03:54	04:05	00:11	TRIPPED ON FAULT
86	01-Feb-24	HASSAN	220	TRANSFORMER	HV4	MRSMSG_220	08:37	08:38	00:01	LINE CLEAR AVAILED
87	1-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
88	1-Feb-24	MYSORE	66	LINE	HANNUR-ECOREN SOLAR	NO STATIONS EFFECTED	15:34	15:36	00:02	LINE CLEAR AVAILED
89	1-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
90	1-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
91	1-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
92	1-Feb-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	11:26	12:23	00:57	LINE CLEAR AVAILED
93	1-Feb-24	MYSORE	66	TRANSFORMER	HV1	KADKOTHANAHALLI_66	14:25	16:20	01:55	LINE CLEAR AVAILED
94	1-Feb-24	MYSORE	66	TRANSFORMER	HV1	KADKOTHANAHALLI_66	16:35	17:00	00:25	LINE CLEAR AVAILED
95	1-Feb-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	18:50	19:15	00:25	LINE CLEAR AVAILED
96	1-Feb-24	MYSORE	66	TRANSFORMER	HV2	MALLAVALLI_66	16:06	16:43	00:37	LINE CLEAR AVAILED
97	1-Feb-24	MYSORE	66	TRANSFORMER	HV2	NAGAMANGALA_66	12:58	16:26	03:27	LINE CLEAR AVAILED
98	1-Feb-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	23:18:00 (1/02/2024)			LINE CLEAR AVAILED
99	1-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
100	1-Feb-24	MYSORE	66	LINE	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66	03:37	03:47	00:10	TRIPPED ON FAULT
101	1-Feb-24	MYSORE	66	LINE	MANDYA-KK HALLI	KADKOTHANAHALLI_66	16:25	16:36	00:10	TRIPPED ON FAULT
102	1-Feb-24	MYSORE	66	LINE	TALAGAWADI-MADDUR	MADDUR_66 KIADB SOMANAHALLI_66	07:18	07:25	00:07	TRIPPED ON FAULT
103	1-Feb-24	MYSORE	66	LINE	VAJMANGALA-KADKOLA 1	AYRALLI_66 MARADIHUNDI_66	03:43	03:48	00:05	TRIPPED ON FAULT
104	1-Feb-24	MYSORE	220	LINE	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	05:29	11:23	05:54	TRIPPED ON FAULT
105	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220KV-HIRIYUR	SANEKERE_66, CHALKERE_66, IMANGALA_66	06:17	06:37	00:20	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
106	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	06:17	06:55	00:38	LOAD CURTAILMENT
107	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	07:26	08:44	01:18	LOAD CURTAILMENT
108	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:12	10:20	00:08	TRIPPED ON FAULT
109	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	12:40	12:46	00:06	TRIPPED ON FAULT
110	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	06:23	06:55	00:32	LOAD CURTAILMENT
111	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHITRAHALLI_66	07:26	08:47	01:21	LOAD CURTAILMENT
112	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	06:17	06:36	00:19	LOAD CURTAILMENT
113	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	07:25	07:28	00:03	LOAD CURTAILMENT
114	1-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	08:22	08:29	00:07	TRIPPED ON FAULT
115	1-Feb-24	TUMKUR	66	LINE	CHITRAHALLI-CHITRADURGA_220 OLD MUSS	CHITRAHALLI_66	07:22	08:48	01:26	MAIN SUPPLY FAILURE
116	1-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:20	12:30	00:10	TRIPPED ON FAULT
117	1-Feb-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI1	HOLALKERE_66	06:20	06:55	00:35	LOAD CURTAILMENT
118	1-Feb-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	PANDRAHALLI_66	07:25	08:45	01:20	LOAD CURTAILMENT
119	1-Feb-24	TUMKUR	66	LINE	JAGALURU_66-BIDARAKERE_66	JAGALURU_66, SOKKE_66	06:20	06:50	00:30	MAIN SUPPLY FAILURE
120	1-Feb-24	TUMKUR	66	LINE	JAGALURU_66-BIDARAKERE_66	JAGALURU_66, SOKKE_66	08:20	08:30	00:10	MAIN SUPPLY FAILURE
121	1-Feb-24	TUMKUR	66	LINE	JAGALURU_66-BIDARAKERE_66	JAGALURU_66, SOKKE_66	07:25	07:30	00:05	MAIN SUPPLY FAILURE
122	1-Feb-24	TUMKUR	66	LINE	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	08:50	08:55	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
123	1-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
124	1-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRAHALLI_66	02:00	02:05	00:05	TRIPPED ON FAULT
125	1-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRAHALLI_66	02:10	02:15	00:05	TRIPPED ON FAULT
126	1-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KIADB V N PURA_220	14:20	18:14	03:54	TRIPPED ON FAULT
127	1-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	GOPPENAHALLI-66	15:05	15:15	00:10	TRIPPED ON FAULT
128	1-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	PATPATTNAYAKANAHALLI_66	17:40	18:02	00:22	LINE CLEAR AVAILED
129	1-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-TURUVEKERE110	TURUVEKERE_110,TANDAGA_110, NONAVINAKERE_110,GUNGURMALE_110	11:12	15:38	04:26	LINE CLEAR AVAILED
130	1-Feb-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220kV-SHIMOGA	ANTHRASANAHALLI_220	07:00	08:04	01:04	TRIPPED ON FAULT
131	1-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
132	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	PG HUNSHYAL_110	11:50	18:57	07:07	LINE CLEAR AVAILED
133	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TALIKOT_110	21:33	21:34	00:01	LINE CLEAR AVAILED
134	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	BILAGI_110	17:15	17:25	00:10	TRIPPED ON FAULT
135	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	HUDALI_110	10:35	14:10	03:35	LINE CLEAR AVAILED
136	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	VAJRAMATTI_110	13:03	13:18	00:15	LINE CLEAR AVAILED
137	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	HANAGAL_110	12:01	12:09	00:08	TRIPPED ON FAULT
138	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(10MVA)	SHIGGOAN_110	01:32	01:36	00:04	TRIPPED ON FAULT
139	02-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	HANAGAL_110	12:01	12:09	00:08	TRIPPED ON FAULT
140	02-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
141	02-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GHATAPRABHA2	STATION NOT AFFECTED GHATAPRABHA_220	10:45	16:40	05:55	LINE CLEAR AVAILED
142	02-Feb-24	BAGALKOTE	110	LINE	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
143	02-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
144	02-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
145	02-Feb-24	BAGALKOTE	110	LINE	NARENDRA220-MRUTHYUNJAY NAGAR2 (UAS DHARWAD)	STATION NOT AFFECTED NARENDRA_220	12:22	17:22	05:00	LINE CLEAR AVAILED
146	02-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
147	02-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	HIREKERUR_110 STATION NOT AFFECTED RANEBENNUR_220	07:20	07:25	00:05	TRIPPED ON FAULT
148	02-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	HIREKERUR_110 STATION NOT AFFECTED RANEBENNUR_220	07:32	08:35	01:03	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
149	02-Feb-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
150	02-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	09:08	16:06	06:58	LINE CLEAR AVAILED
151	02-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	STATION NOT AFFECTED HUBLI_220	10:10	13:52	03:42	LINE CLEAR AVAILED
152	02-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:10	16:20	06:10	LINE CLEAR AVAILED
153	02-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
154	02-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
155	02-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
156	02-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
157	02-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
158	02-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
159	02-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURALLI	07:26	07:32	00:06	LINE CLEAR AVAILED
160	02-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	08:29	08:36	00:07	LINE CLEAR AVAILED
161	02-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLY	IRAGAMPALLI, M GOLAHALLI, BURUDAGUNTE	17:39	17:43	00:04	LINE CLEAR AVAILED
162	02-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDLAGHATTA, MELUR, JANGAMAKOTE, VIJAYAPURA	15:38	15:43	00:05	LINE CLEAR AVAILED
163	02-Feb-24	BENGALURU	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	PURVANKARA PALM BEACH, HENNUR CROSS	16:45	16:57	00:12	TRIPPED ON FAULT
164	02-Feb-24	BENGALURU	66	LINE	66KV DIBBURHALLI - SADLI - SOMENAHALLI - PERESANDRA	DIBBURALLI	17:24	17:30	00:06	LINE CLEAR AVAILED
165	02-Feb-24	BENGALURU	66	LINE	66KV DIBBURHALLI - SADLI - SOMENAHALLI - PERESANDRA	PERESANDRA	11:30	11:40	00:10	TRIPPED ON FAULT
166	02-Feb-24	BENGALURU	66	LINE	66KV GOKULA - RMV	RMV	13:35	13:50	00:15	LINE CLEAR AVAILED
167	02-Feb-24	BENGALURU	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	21:20	23:59	02:39	TRIPPED ON FAULT
168	02-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	KGF, BEML(EHT), KAMASAMUDRA	23:58	23:59	00:01	LINE CLEAR AVAILED
169	02-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	JANGAMKOTE, VIJAYPURA	10:05	10:11	00:06	LINE CLEAR AVAILED
170	02-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - ANDERSONPET	ANDERSONPETE	19:17	23:59	04:42	LINE CLEAR AVAILED
171	02-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KGF 1	NO STATION AFFECTED	16:45	17:08	00:23	TRIPPED ON FAULT
172	02-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KGF 1	NO STATION AFFECTED	17:08	23:59	06:51	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
173	02-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KGF 2	KGF, BEML(EHT), KAMASAMUDRA	19:20	19:35	00:15	LINE CLEAR AVAILED
174	02-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KYASAMBALLY	KYASAMBALLI, DODDAKARI	19:17	23:59	04:42	LINE CLEAR AVAILED
175	02-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYPURA	16:27	16:33	00:06	LINE CLEAR AVAILED
176	02-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GANJIGUNTE	12:30	12:35	00:05	LINE CLEAR AVAILED
177	02-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	21:45	21:55	00:10	TRIPPED ON FAULT
178	02-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	22:20	22:25	00:05	TRIPPED ON FAULT
179	02-Feb-24	BENGALURU	66	TRANSFORMER	HV2	GANJIGUNTE	12:30	12:35	00:05	LINE CLEAR AVAILED
180	02-Feb-24	BENGALURU	66	TRANSFORMER	HV2	GUDIBANDE	15:05	16:00	00:55	TRIPPED ON FAULT
181	02-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIDURASHWATHA	18:15	18:25	00:10	TRIPPED ON FAULT
182	02-Feb-24	BENGALURU	66	TRANSFORMER	HV3	YARANDANAHALLI 220	06:35	06:50	00:15	LINE CLEAR AVAILED
183	2-Feb-2024	GULBARGA	66	LINE	TBHALLI-ITTAGGI	TAMBRAHALLI_66,HAMPASAGAR_66,MORAGERE_66	05:45	09:45	04:00	TRIPPED ON FAULT
184	2-Feb-2024	GULBARGA	110	LINE	HUMNABAD-RAJESHWAR	RAJESHWAR_110SASTHAPUR_110	17:25(2.02.2024)			LINE CLEAR AVAILED
185	2-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	BELLARY NORTH_110	07:47	07:53	00:06	TRIPPED ON FAULT
186	2-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	BELLARY NORTH_110	07:58	08:03	00:05	TRIPPED ON FAULT
187	2-Feb-2024	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	ECOREN SOLAR_IPP,NAVALI_110	01:10	01:25	00:15	TRIPPED ON FAULT
188	2-Feb-2024	GULBARGA	110	LINE	KURUGOD-SUZLON	KURUGOD_110	11:30	11:35	00:05	TRIPPED ON FAULT
189	2-Feb-2024	GULBARGA	110	LINE	LV1	ITTAGI_220	05:44	05:48	00:04	TRIPPED ON FAULT
190	2-Feb-2024	GULBARGA	110	LINE	MUNIRABAD-DONIMALAI(VYSANKERE1)	JSW PUMP HOUSE_IPP,STAR METALLIC_IPP	14:48	14:59	00:11	TRIPPED ON FAULT
191	2-Feb-2024	GULBARGA	110	LINE	RAICHUR-SINDHANOOR1	SIRWAR_110	18:43	18:50	00:07	TRIPPED ON FAULT
192	2-Feb-2024	GULBARGA	110	LINE	SOMASAMUNDRA-BELLARY NORTH	PD_HALLI_110,SOMASAMUNDRA_110,MOKA_110	11:34	11:40	00:06	TRIPPED ON FAULT
193	02-Feb-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	12:04	13:22	01:18	LINE CLEAR AVAILED
194	02-Feb-24	HASSAN	66	LINE	BALEHN-CHKM	BALEHONNUR_66	11:10	11:53	00:43	LINE CLEAR AVAILED
195	02-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	13:15	18:15	05:00	LINE CLEAR AVAILED
196	02-Feb-24	HASSAN	66	TRANSFORMER	HV1	HALEBEDU_66	11:00	11:05	00:05	LINE CLEAR AVAILED
197	02-Feb-24	HASSAN	66	TRANSFORMER	HV2	ARAKALGUD_66	14:30	14:40	00:10	LINE CLEAR AVAILED
198	02-Feb-24	HASSAN	110	TRANSFORMER	HV1	KAVOOR_220	10:24	17:29	07:05	LINE CLEAR AVAILED
199	02-Feb-24	HASSAN	110	TRANSFORMER	HV2	MANIPAL_110	07:43	07:51	00:08	TRIPPED ON FAULT
200	02-Feb-24	HASSAN	110	LINE	LV3	MRSMSG_220	15:23	19:49	04:26	LINE CLEAR AVAILED
201	02-Feb-24	HASSAN	110	LINE	MSEZ-GSS3	MSEZ_220	10:20	13:51	03:31	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
202	02-Feb-24	HASSAN	220	TRANSFORMER	HV3	MRSMSG_220	15:23	19:49	04:26	LINE CLEAR AVAILED
203	2-Feb-24	MYSORE	66	LINE	BEGUR 220-GUNDLUPETE 2	NO STATIONS EFFECTED	07:24	07:34	00:10	LINE CLEAR AVAILED
204	2-Feb-24	MYSORE	66	LINE	GUNDALPETE-BEGUR	NO STATIONS EFFECTED	07:22	07:33	00:10	LINE CLEAR AVAILED
205	2-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
206	2-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
207	2-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
208	2-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
209	2-Feb-24	MYSORE	66	TRANSFORMER	HV1	BANNANGADI_66	09:00	13:30	04:30	LINE CLEAR AVAILED
210	2-Feb-24	MYSORE	66	TRANSFORMER	HV1	MADIKERI_66	11:07	14:55	03:48	LINE CLEAR AVAILED
211	2-Feb-24	MYSORE	66	TRANSFORMER	HV1	MUGUR_66	07:22	07:29	00:07	TRIPPED ON FAULT
212	2-Feb-24	MYSORE	66	TRANSFORMER	HV1	SINDHUVALLI_66	16:08	16:42	00:34	LINE CLEAR AVAILED
213	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	KIRUGAVALU_66	13:01	13:04	00:03	LINE CLEAR AVAILED
214	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	14:55	17:04	02:09	LINE CLEAR AVAILED
215	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	POONAMPETE_66	23:51	00:30	00:39	LINE CLEAR AVAILED
216	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	GUNDLUPETE_66	08:00	09:42	01:42	LINE CLEAR AVAILED
217	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	HOSURGATE_66	12:50	13:25	00:35	LINE CLEAR AVAILED
218	2-Feb-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	23:18:00 (1/02/2024)	0:38:00 (2/02/2024)	01:20	LINE CLEAR AVAILED
219	2-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
220	2-Feb-24	MYSORE	66	LINE	JAKKANALLI-NAGMANGLA	G MALLIGERE_66	05:55	06:05	00:09	TRIPPED ON FAULT
221	2-Feb-24	MYSORE	66	LINE	K R PETE 220-MADESHWARAPURA	NO STATIONS EFFECTED	10:01:00 (2/02/2024)			LINE CLEAR AVAILED
222	2-Feb-24	MYSORE	66	LINE	KK DODDI -MADDUR	MADDUR_66	07:16	07:26	00:10	TRIPPED ON FAULT
223	2-Feb-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	KOLLEGALA_66	19:36	20:05	00:29	TRIPPED ON FAULT
224	2-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTUR	NO STATIONS EFFECTED	07:22	08:11	00:48	LINE CLEAR AVAILED
225	2-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	02:11	02:16	00:04	TRIPPED ON FAULT
226	2-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	02:16	02:25	00:09	TRIPPED ON FAULT
227	2-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	00:45	09:26	08:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
228	2-Feb-24	MYSORE	66	LINE	PARINAMIPURA-KOLLEGALA	NO STATIONS EFFECTED	19:36	20:12	00:36	TRIPPED ON FAULT
229	2-Feb-24	MYSORE	66	LINE	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	06:21	06:28	00:07	TRIPPED ON FAULT
230	2-Feb-24	MYSORE	220	LINE	KUSHALNAGARA-HUNSUR 1	NO STATIONS EFFECTED	03:43	06:12	02:29	TRIPPED ON FAULT
231	2-Feb-24	MYSORE	220	LINE	KUSHALNAGARA-HUNSUR 1	NO STATIONS EFFECTED	06:35	07:02	00:27	TRIPPED ON FAULT
232	2-Feb-24	TUMKUR	66	LINE	ANKASANDRA-BRAHMASANDRA-SIRA	ANKASANDRA_66	00:46	01:06	00:20	TRIPPED ON FAULT
233	2-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66	07:10	08:01	00:51	LOAD CURTAILMENT
234	2-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	14:42	14:48	00:06	TRIPPED ON FAULT
235	2-Feb-24	TUMKUR	66	LINE	CHITRAHALLI_66-HOLALKERE TAPING LINE	CHITRAHALLI_66	06:28	08:38	02:10	LINE CLEAR AVAILED
236	2-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	13:40	13:56	00:16	TRIPPED ON FAULT
237	2-Feb-24	TUMKUR	66	LINE	HIEMALLANHOLE_66 NAYAKANAHATTI66-	HIEMALLANHOLE_66	10:35	11:05	00:30	LINE CLEAR AVAILED
238	2-Feb-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	PANDRAHALLI_66	06:30	06:55	00:25	MAIN SUPPLY FAILURE
239	2-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-NYAMATHI_66	NYAMATHI_66	08:35	08:45	00:10	TRIPPED ON FAULT
240	2-Feb-24	TUMKUR	66	LINE	HONNALLI220- KUNDUR66	KUNDUR_66	10:36	10:45	00:09	TRIPPED ON FAULT
241	2-Feb-24	TUMKUR	66	LINE	MELEKOTE-BADDIHALLI_66	MELEKOTE_66	15:07	15:14	00:07	LINE CLEAR AVAILED
242	2-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
243	2-Feb-24	TUMKUR	66	LINE	RAMAGIRI_66 HOLALKERE-1	RAMAGIRI_66	06:45	07:20	00:35	TRIPPED ON FAULT
244	2-Feb-24	TUMKUR	66	LINE	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	13:40	14:00	00:20	MAIN SUPPLY FAILURE
245	2-Feb-24	TUMKUR	66	LINE	SIRA66 - KALLAMBELLA	KALLAMBELLA_66(ALTERNATIVE)	01:10	01:45	00:35	TRIPPED ON FAULT
246	2-Feb-24	TUMKUR	66	LINE	SIRIGERE_66-CHITRADURGA_66	SIRIGERE_66	06:27	08:00	01:33	MAIN SUPPLY FAILURE
247	2-Feb-24	TUMKUR	66	LINE	THALLAK 220kV-NAYAKANHATTI	NAYAKANHATTI_66, HIEMALLANAHOLE_66	10:29	11:06	00:37	LINE CLEAR AVAILED
248	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	ANCHEPALYA_66	13:15	13:30	00:15	LINE CLEAR AVAILED
249	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BADAVANAHALLI_66	14:15	14:25	00:10	LINE CLEAR AVAILED
250	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRAHALLI_66	12:51	12:55	00:04	TRIPPED ON FAULT
251	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-1L(V SIDE)	THALLAKK_220	12:07	18:04	05:57	LINE CLEAR AVAILED
252	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-1L(V SIDE)	MADHUGIRI_220	11:46	12:00	00:14	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
253	2-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NAYAKANAHATTI_ 66-	16:25	16:50	00:25	LINE CLEAR AVAILED
254	2-Feb-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	07:42	07:53	00:11	LINE CLEAR AVAILED
255	2-Feb-24	TUMKUR	110	LINE	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	06:13	06:25	00:12	TRIPPED ON FAULT
256	2-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
257	2-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	THALLAKK_220	12:07	18:04	05:57	LINE CLEAR AVAILED
258	2-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:09	18:20	08:11	LINE CLEAR AVAILED
259	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1	KUDACHI_220	05:40	05:50	00:10	TRIPPED ON FAULT
260	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SAMBAPUR ROAD	10:20	15:25	05:05	LINE CLEAR AVAILED
261	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (10MVA)	PG HUNSHYAL_110	09:25	12:19	02:54	LINE CLEAR AVAILED
262	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	MUDHOL_110	10:30	14:34	04:04	LINE CLEAR AVAILED
263	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	STATION NOT AFFECTED UCHAGAON_110	10:55	13:00	02:05	LINE CLEAR AVAILED
264	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	HUDALI_110	09:31	18:00	08:29	LINE CLEAR AVAILED
265	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA-HV1)	KALADAGI_110	12:13	14:29	02:16	LINE CLEAR AVAILED
266	03-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	BIJAPUR CITY_110	09:18	09:32	00:14	LINE CLEAR AVAILED
267	03-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
268	03-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI	ATHARGA_110	07:12	07:54	00:42	LINE CLEAR AVAILED
269	03-Feb-24	BAGALKOTE	110	LINE	CHIKKODI- BHOJ	STATION NOT AFFECTED CHIKKODI_220	11:43	12:52	01:09	LINE CLEAR AVAILED
270	03-Feb-24	BAGALKOTE	110	LINE	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
271	03-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
272	03-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
273	03-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
274	03-Feb-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)	19:14 (04.02.2024)	777:37 hrs	LINE CLEAR AVAILED
275	03-Feb-24	BAGALKOTE	110	LINE	UTTUR-F1JAMB (MUDHOL)	STATION NOT AFFECTED UTTUR_110	10:32	14:27	03:55	LINE CLEAR AVAILED
276	03-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
277	03-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:27 (25.01.2024)	17:57 (03.02.2024)	223:30:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRANSFORM ER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
278	03-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENRA1	STATION NOT AFFECTED HUBLI_220	11:40	15:28	03:48	LINE CLEAR AVAILED
279	03-Feb-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	12:18	15:55	03:37	LINE CLEAR AVAILED
280	03-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
281	03-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
282	03-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
283	03-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
284	03-Feb-24	BENGALURU	66	LINE	66KV BOMMASANDRA I/A - SYNGENE INTERNATIONAL LTD EHT	SYNGENE	12:42	18:04	05:22	LINE CLEAR AVAILED
285	03-Feb-24	BENGALURU	66	LINE	66KV BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE, SAUDELA	12:40	12:44	00:04	LINE CLEAR AVAILED
286	03-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	08:15	10:15	02:00	LINE CLEAR AVAILED
287	03-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGHMANE TECH PARK, GTRE	09:11	09:30	00:19	TRIPPED ON FAULT
288	03-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	KADUBISANAHALLI	10:50	11:02	00:12	LINE CLEAR AVAILED
289	03-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - FALSON CITY	PRESTIGE FALCON CITY	11:04	12:22	01:18	LINE CLEAR AVAILED
290	03-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	12:45	12:51	00:06	LINE CLEAR AVAILED
291	03-Feb-24	BENGALURU	66	LINE	66KV KHODAYS GLASS FACTORY 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA	10:58	11:03	00:05	LINE CLEAR AVAILED
292	03-Feb-24	BENGALURU	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	00:00	00:43	00:43	LINE CLEAR AVAILED
293	03-Feb-24	BENGALURU	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	00:00	00:43	00:43	TRIPPED ON FAULT
294	03-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	KGF, BEML(EHT), KAMASAMUDRA	00:00	00:08	00:08	LINE CLEAR AVAILED
295	03-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	SOUTH CITY	10:45	10:50	00:05	LINE CLEAR AVAILED
296	03-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - ANDERSONPET	ANDERSONPETE	00:00	00:08	00:08	LINE CLEAR AVAILED
297	03-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KGF 1	NO STATION AFFECTED	00:00	00:08	00:08	TRIPPED ON FAULT
298	03-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - KYASAMBALLY	KYASAMBALLI, DODDAKARI	00:00	00:08	00:08	LINE CLEAR AVAILED
299	03-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	10:22	10:27	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
300	03-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	17:32	17:35	00:03	LINE CLEAR AVAILED
301	03-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	14:05	14:10	00:05	LINE CLEAR AVAILED
302	03-Feb-24	BENGALURU	66	TRANSFORMER	HV1	EXORA 66	08:55	09:05	00:10	LINE CLEAR AVAILED
303	03-Feb-24	BENGALURU	66	TRANSFORMER	HV1	EXORA 66	11:42	11:45	00:03	LINE CLEAR AVAILED
304	03-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	13:30	13:35	00:05	LINE CLEAR AVAILED
305	03-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	11:05	11:08	00:03	LINE CLEAR AVAILED
306	03-Feb-24	BENGALURU	66	TRANSFORMER	HV2	PALLICHERLU	10:36	10:50	00:14	TRIPPED ON FAULT
307	03-Feb-24	BENGALURU	66	TRANSFORMER	HV2	RANGANADODDI	16:15	16:30	00:15	LINE CLEAR AVAILED
308	3-Feb-2024	GULBARGA	66	LINE	HARAPANAHALLI-ITTAGGI	HARAPANAHALLI_66	11:10	11:40	00:30	LINE CLEAR AVAILED
309	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	09:20	09:30	00:10	TRIPPED ON FAULT
310	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	12:05	12:15	00:10	TRIPPED ON FAULT
311	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	NEELAGUNDA_220	12:30	12:40	00:10	TRIPPED ON FAULT
312	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	CHOORNUR_66	07:25	07:30	00:05	TRIPPED ON FAULT
313	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	CHOORNUR_66	08:00	08:10	00:10	TRIPPED ON FAULT
314	3-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	CHOORNUR_66	11:10	11:15	00:05	TRIPPED ON FAULT
315	3-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:08	19:24	00:16	TRIPPED ON FAULT
316	3-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66, GIRIYAPUR_66	19:08	19:40	00:32	TRIPPED ON FAULT
317	3-Feb-2024	GULBARGA	110	LINE	CHINCHOLI-SEDAM-1	CHINCHOLI_110	20:47	21:30	00:43	TRIPPED ON FAULT
318	3-Feb-2024	GULBARGA	110	LINE	CHINCHOLI-SEDAM-2	CHINCHOLI_110	20:47	22:28	01:41	TRIPPED ON FAULT
319	3-Feb-2024	GULBARGA	110	LINE	HANWAL-MARALIHALLA	YERADONA_110, BENNUR_110	13:50	14:00	00:10	TRIPPED ON FAULT
320	3-Feb-2024	GULBARGA	110	LINE	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	17:25(2.02.2024)			LINE CLEAR AVAILED
321	3-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SHAHAPUR_220	16:42	16:57	00:15	TRIPPED ON FAULT
322	3-Feb-2024	GULBARGA	110	LINE	KADECHUR-KHANAPUR	SAIDAPUR_110	00:54	01:12	00:18	TRIPPED ON FAULT
323	3-Feb-2024	GULBARGA	110	LINE	KADECHUR-KHANAPUR	SAIDAPUR_110	05:45	05:55	00:10	TRIPPED ON FAULT
324	3-Feb-2024	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	03:30	03:45	00:15	TRIPPED ON FAULT
325	3-Feb-2024	GULBARGA	110	LINE	KBJNL	KBJNL	17:35	17:40	00:05	LINE CLEAR AVAILED
326	3-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, TEKKALKOTE_110, SIRAGUPPA_110	13:33	13:43	00:10	TRIPPED ON FAULT
327	3-Feb-2024	GULBARGA	110	LINE	YELBURGA-VAJJARBANDI	YALBURGA_110, KUKNOOR_110	17:05	17:33	00:28	TRIPPED ON FAULT
328	3-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	06:55	08:25	01:30	LINE CLEAR AVAILED
329	3-Feb-2024	GULBARGA	220	LINE	KAPNOOR-FIROZABAD	KAPNOOR_220	11:45	14:15	02:30	LINE CLEAR AVAILED
330	03-Feb-24	HASSAN	66	LINE	BAGUR-UDAYAPUR	BAGUR_66	07:55	21:50	13:55	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
331	03-Feb-24	HASSAN	66	LINE	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	12:30	17:26	04:56	LINE CLEAR AVAILED
332	03-Feb-24	HASSAN	66	LINE	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	09:30	12:30	03:00	LINE CLEAR AVAILED
333	03-Feb-24	HASSAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	07:00	20:47	13:47	LINE CLEAR AVAILED
334	03-Feb-24	HASSAN	66	LINE	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	07:00	20:35	13:35	LINE CLEAR AVAILED
335	03-Feb-24	HASSAN	66	TRANSFORMER	HV1	BAGUR_66	07:00	21:57	14:57	MAIN SUPPLY FAILURE
336	03-Feb-24	HASSAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	11:50	18:50	07:00	LINE CLEAR AVAILED
337	03-Feb-24	HASSAN	66	TRANSFORMER	HV1	UDAYAPURA_66	07:00	21:52	14:52	MAIN SUPPLY FAILURE
338	03-Feb-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	07:00	21:57	14:57	MAIN SUPPLY FAILURE
339	03-Feb-24	HASSAN	66	TRANSFORMER	HV2	HIREMANGLUR_66	21:40	22:40	01:00	LINE CLEAR AVAILED
340	03-Feb-24	HASSAN	66	TRANSFORMER	HV2	UDAYAPURA_66	07:00	21:52	14:52	MAIN SUPPLY FAILURE
341	03-Feb-24	HASSAN	66	LINE	UDAYAP-BAGUR	UDAYAPURA_66	07:00	21:45	14:45	MAIN SUPPLY FAILURE
342	03-Feb-24	HASSAN	66	LINE	UDAYAP-CRP	UDAYAPURA_66	07:00	21:45	14:45	MAIN SUPPLY FAILURE
343	03-Feb-24	HASSAN	66	LINE	UDAYAP-SATHENAHALLI	UDAYAPURA_66	07:00	21:52	14:52	MAIN SUPPLY FAILURE
344	03-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	10:05	14:29	04:24	LINE CLEAR AVAILED
345	03-Feb-24	HASSAN	110	TRANSFORMER	HV2	HIRIYADKA_110	12:08	16:02	03:54	LINE CLEAR AVAILED
346	03-Feb-24	HASSAN	110	LINE	LV3	MRSMSG_220	14:33	19:57	05:24	LINE CLEAR AVAILED
347	03-Feb-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	10:18	14:02	03:44	LINE CLEAR AVAILED
348	03-Feb-24	HASSAN	220	TRANSFORMER	HV3	MRSMSG_220	14:33	19:57	05:24	LINE CLEAR AVAILED
349	03-Feb-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMSG_220	09:07	18:09	09:02	LINE CLEAR AVAILED
350	3-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47			LINE CLEAR AVAILED
351	3-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
352	3-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
353	3-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
354	3-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
355	3-Feb-24	MYSORE	66	TRANSFORMER	HV1	BANANGADI_66	14:00	14:10	00:10	LINE CLEAR AVAILED
356	3-Feb-24	MYSORE	66	TRANSFORMER	HV1	BANANGADI_66	16:45	17:50	01:05	LINE CLEAR AVAILED
357	3-Feb-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORNGUDU_66	14:24	16:05	01:41	LINE CLEAR AVAILED
358	3-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	09:28	09:39	00:11	MAIN SUPPLY FAILURE
359	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	06:24	08:14	01:50	LINE CLEAR AVAILED
360	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	12:03	14:10	02:07	LINE CLEAR AVAILED
361	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	14:15	14:20	00:05	TRIPPED ON FAULT
362	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	13:25	13:38	00:13	LINE CLEAR AVAILED
363	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	09:28	09:40	00:11	MAIN SUPPLY FAILURE
364	3-Feb-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	15:31	16:00	00:29	LINE CLEAR AVAILED
365	3-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
366	3-Feb-24	MYSORE	66	LINE	K R PETE 220-MADESHWARAPURA	NO STATIONS EFFECTED	10:01:00 (2/02/2024)	16:00 (03/02/2024)	29:59:00	LINE CLEAR AVAILED
367	3-Feb-24	MYSORE	66	LINE	KIRUGAVALU-MALIYUR	BANNUR_66 MALIYURU_66	12:30	12:39	00:08	TRIPPED ON FAULT
368	3-Feb-24	MYSORE	66	LINE	KIRUGAVALU-MALIYUR	BANNUR_66 MALIYURU_66	12:42	13:02	00:20	TRIPPED ON FAULT
369	3-Feb-24	MYSORE	66	LINE	KIRUGAVALU-MALIYUR	BANNUR_66 MALIYURU_66	21:05	21:22	00:16	TRIPPED ON FAULT
370	3-Feb-24	MYSORE	220	TRANSFORMER	HV1	SHIVASAMUDRA_220	09:25	09:35	00:10	TRIPPED ON FAULT
371	3-Feb-24	MYSORE	220	TRANSFORMER	HV2	SHIVASAMUDRA_220	09:24	10:52	01:28	LINE CLEAR AVAILED
372	3-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE_66	13:06	13:10	00:04	TRIPPED ON FAULT
373	3-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	09:59	10:09	00:10	TRIPPED ON FAULT
374	3-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	PAVAGADA_66	17:15	18:34	01:19	LINE CLEAR AVAILED
375	3-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)& HV2(TR2)	MADHUGIRI_66	01:30	02:00	00:30	LINE CLEAR AVAILED
376	3-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	MADHUGIRI_66	08:45	09:00	00:15	LINE CLEAR AVAILED
377	3-Feb-24	TUMKUR	66	LINE	LV1(TR1)	THALLAK_220	16:32	19:29	02:57	LINE CLEAR AVAILED
378	3-Feb-24	TUMKUR	66	LINE	LV2(TR2)	THALLAK_220	19:32	21:29	01:57	LINE CLEAR AVAILED
379	3-Feb-24	TUMKUR	66	LINE	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	14:45	15:50	01:05	LINE CLEAR AVAILED
380	3-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
381	3-Feb-24	TUMKUR	110	TRANSFORMER	HV2(TR2)	NITTUR_110	06:02	06:18	00:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
382	3-Feb-24	TUMKUR	110	TRANSFORMER	HV2(TR2)	NITTUR_110	14:10	15:50	01:40	LINE CLEAR AVAILED
383	3-Feb-24	TUMKUR	110	TRANSFORMER	HV2(TR2)	NITTUR_110	12:45	14:02	01:17	LINE CLEAR AVAILED
384	3-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	THALLAK_220	16:33	19:26	02:53	LINE CLEAR AVAILED
385	3-Feb-24	TUMKUR	220	TRANSFORMER	HV2(TR2)	THALLAK_220	19:33	21:20	01:47	LINE CLEAR AVAILED
386	3-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
387	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MUDALAGI_110	04:55	04:58	00:03	TRIPPED ON FAULT
388	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NIPPANI_110	13:31	16:08	02:37	LINE CLEAR AVAILED
389	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	NIPPANI_110	13:31	16:08	02:37	LINE CLEAR AVAILED
390	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA-HV3)	KULIGOD_110	05:25	08:36	03:11	TRIPPED ON FAULT
391	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	HANAGAL_110	08:04	08:09	00:05	TRIPPED ON FAULT
392	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	NIPPANI_110	13:31	16:08	02:37	LINE CLEAR AVAILED
393	04-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	HANAGAL_110	08:00	08:09	00:09	TRIPPED ON FAULT
394	04-Feb-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA2(2)	ANKOLA_110	17:27	17:31	00:04	LINE CLEAR AVAILED
395	04-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
396	04-Feb-24	BAGALKOTE	110	LINE	BELGAUM220-HUKKERI(UCHAGOAN)	STATION NOT AFFECTED BELGAUM_220	12:20 (04.02.2024)			LINE CLEAR AVAILED
397	04-Feb-24	BAGALKOTE	110	LINE	BELGAUM220- NEHRU NAGAR	STATION NOT AFFECTED BELGAUM_220	13:50	16:31	02:41	LINE CLEAR AVAILED
398	04-Feb-24	BAGALKOTE	110	LINE	BELGAUM220- VADAGOAN	STATION NOT AFFECTED BELGAUM_220	16:53	17:03	00:10	LINE CLEAR AVAILED
399	04-Feb-24	BAGALKOTE	110	LINE	BELGAUM-MACHE(BELGAUM220)	BELGAUM_110	13:49	16:33	02:44	LINE CLEAR AVAILED
400	04-Feb-24	BAGALKOTE	110	LINE	BIDNAL220- GADAG ROAD	BIDNAL_220	07:30	12:23	04:53	LINE CLEAR AVAILED
401	04-Feb-24	BAGALKOTE	110	LINE	GADG ROAD-BIDNAL	GADG ROAD_110	01:38	12:40	11:02	LINE CLEAR AVAILED
402	04-Feb-24	BAGALKOTE	110	LINE	GOPANAKOPPAGADAG ROAD	GOPANAKOPPA_110	7:07 (04.02.2024)			LINE CLEAR AVAILED
403	04-Feb-24	BAGALKOTE	110	LINE	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
404	04-Feb-24	BAGALKOTE	110	LINE	KUDACHI220-TERDAL(MORAB)	STATION NOT AFFECTED KUDACHI_220	00:59	01:35	00:36	TRIPPED ON FAULT
405	04-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	17:37 (04.02.2024)			LINE CLEAR AVAILED
406	04-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI2	KUMTA_110	17:37 (04.02.2024)			LINE CLEAR AVAILED
407	04-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
408	04-Feb-24	BAGALKOTE	110	LINE	MK HUBLI220- BAILHONGAL	STATION NOT AFFECTED MK HUBLI_220	10:02	17:13	07:11	LINE CLEAR AVAILED
409	04-Feb-24	BAGALKOTE	110	LINE	MK HUBLI- NARENDRA(KITTUR)	MK HUBLI_110	15:18	18:41	03:23	LINE CLEAR AVAILED
410	04-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
411	04-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
412	04-Feb-24	BAGALKOTE	110	LINE	SIRSI-(KUMTA1)	SIRSI_110	17:50	23:19	05:29	LINE CLEAR AVAILED
413	04-Feb-24	BAGALKOTE	110	LINE	SIRSI-HUBLI1(SIRS220)(1)	SIRSI_110	17:05	23:19	06:14	TRIPPED ON FAULT
414	04-Feb-24	BAGALKOTE	110	LINE	SIRSI- KAVALWADA(SIRS220(2)	SIRSI_110	19:14	23:21	04:07	LINE CLEAR AVAILED
415	04-Feb-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	17:50	23:24	05:34	LINE CLEAR AVAILED
416	04-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	SIRSI_220	17:05 (04.02.2024)			TRIPPED ON FAULT
417	04-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED SOUDATTI_220	12:27	15:05	02:38	LINE CLEAR AVAILED
418	04-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1&LV1	STATION NOT AFFECTED KUDACHI_220	12:32	22:16	09:44	LINE CLEAR AVAILED
419	04-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV1	SIRSI_220	17:05 (04.02.2024)			TRIPPED ON FAULT
420	04-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
421	04-Feb-24	BAGALKOTE	220	LINE	NARENDRA- SHIGGOAN	NARENDRA_220	12:18	15:55	03:37	LINE CLEAR AVAILED
422	04-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
423	04-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
424	04-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
425	04-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	A STATION 66	10:11	14:55	04:44	LINE CLEAR AVAILED
426	04-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A2)	A STATION 66	10:11	14:43	04:32	LINE CLEAR AVAILED
427	04-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
428	04-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	08:45	09:04	00:19	TRIPPED ON FAULT
429	04-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:00	17:24	07:24	LINE CLEAR AVAILED
430	04-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE, SHIVANAHALLI DAIRY	11:26	11:35	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
431	04-Feb-24	BENGALURU	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	13:30	13:34	00:04	LINE CLEAR AVAILED
432	04-Feb-24	BENGALURU	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	13:01	14:25	01:24	TRIPPED ON FAULT
433	04-Feb-24	BENGALURU	66	LINE	66KV GOKULA - MATHIKERE	MATHIKERE	13:01	13:23	00:22	TRIPPED ON FAULT
434	04-Feb-24	BENGALURU	66	LINE	66KV GOKULA - MATHIKERE	MATHIKERE	16:58	18:48	01:50	LINE CLEAR AVAILED
435	04-Feb-24	BENGALURU	66	LINE	66KV GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	16:52	17:00	00:08	LINE CLEAR AVAILED
436	04-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	16:48	16:50	00:02	LINE CLEAR AVAILED
437	04-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - RMV	RMV, TATA INSTITUTE (EHT)	18:55	18:59	00:04	LINE CLEAR AVAILED
438	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	10:32	10:40	00:08	LINE CLEAR AVAILED
439	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	13:32	13:58	00:26	TRIPPED ON FAULT
440	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	19:02	19:05	00:03	LINE CLEAR AVAILED
441	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI 66	16:32	16:40	00:08	LINE CLEAR AVAILED
442	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI 66	21:07	21:13	00:06	LINE CLEAR AVAILED
443	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD	15:31	15:34	00:03	LINE CLEAR AVAILED
444	04-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD	21:17	21:20	00:03	LINE CLEAR AVAILED
445	04-Feb-24	BENGALURU	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	TG HALLI	12:23	12:40	00:17	LINE CLEAR AVAILED
446	04-Feb-24	BENGALURU	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	VG DODDI	12:23	13:46	01:23	LINE CLEAR AVAILED
447	04-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	10:00	17:20	07:20	LINE CLEAR AVAILED
448	04-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA	08:37	08:59	00:22	TRIPPED ON FAULT
449	04-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA	10:17	10:24	00:07	LINE CLEAR AVAILED
450	04-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI	19:45	19:50	00:05	TRIPPED ON FAULT
451	04-Feb-24	BENGALURU	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TG HALLI	13:45	13:50	00:05	LINE CLEAR AVAILED
452	04-Feb-24	BENGALURU	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	13:50	13:55	00:05	LINE CLEAR AVAILED
453	04-Feb-24	BENGALURU	66	LINE	66KV VEMGAL - KYALANUR	KYALANUR	05:37	05:57	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
454	04-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	10:34	10:39	00:05	LINE CLEAR AVAILED
455	04-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	16:39	16:41	00:02	LINE CLEAR AVAILED
456	04-Feb-24	BENGALURU	66	LINE	HAL 220 - HAL(EHT)	HAL(EHT)	11:14	11:34	00:20	TRIPPED ON FAULT
457	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ABBIGERE	10:40	10:42	00:02	LINE CLEAR AVAILED
458	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HAL 220	03:14	03:39	00:25	TRIPPED ON FAULT
459	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BG ROAD	09:57	10:08	00:11	TRIPPED ON FAULT
460	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KIADB HARDWARE PARK 220	12:31	13:23	00:52	LINE CLEAR AVAILED
461	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	M GOLLAHALLI	08:05	08:10	00:05	LINE CLEAR AVAILED
462	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MUDIYANUR	02:10	02:40	00:30	TRIPPED ON FAULT
463	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	JIGANI 220	10:43	10:50	00:07	LINE CLEAR AVAILED
464	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	JIGANI 220	16:35	16:40	00:05	LINE CLEAR AVAILED
465	04-Feb-24	BENGALURU	66	TRANSFORMER	HV1	JIGANI 220	18:58	19:01	00:03	LINE CLEAR AVAILED
466	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	ABBIGERE	11:55	12:57	01:02	LINE CLEAR AVAILED
467	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SUGUTUR	11:30	11:35	00:05	TRIPPED ON FAULT
468	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TAYALUR	13:45	14:10	00:25	LINE CLEAR AVAILED
469	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	ATTIBELE	10:50	10:55	00:05	LINE CLEAR AVAILED
470	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BOMMASANDRA I/A	12:47	13:11	00:24	LINE CLEAR AVAILED
471	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	JIGANI 220	10:43	10:50	00:07	LINE CLEAR AVAILED
472	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	JIGANI 220	16:35	16:40	00:05	LINE CLEAR AVAILED
473	04-Feb-24	BENGALURU	66	TRANSFORMER	HV2	JIGANI 220	18:58	19:01	00:03	LINE CLEAR AVAILED
474	04-Feb-24	BENGALURU	66	TRANSFORMER	HV4	A STATION 66	10:10	14:54	04:44	LINE CLEAR AVAILED
475	04-Feb-24	BENGALURU	220	LINE	220KV MYLASANDRA - JIGANI	JIGANI 220	16:36	16:40	00:04	LINE CLEAR AVAILED
476	04-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NO STATION AFFECTED	10:15	17:52	07:37	LINE CLEAR AVAILED
477	04-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 2	NO STATION AFFECTED	10:15	17:17	07:02	LINE CLEAR AVAILED
478	04-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - MYLASANDRA 2	NO STATION AFFECTED	15:35	20:01	04:26	TRIPPED ON FAULT
479	04-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - MYLASANDRA 2	NO STATION AFFECTED	15:35	20:01	04:26	TRIPPED ON FAULT
480	4-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	HALVAGALU_66	17:45	17:50	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
481	4-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-TELAGI	TELAGI_66,KURBHAHALLI_66,OBBIJJIHALLI_66,SHAMNUR SUGAR_IPP, GREEN INFR_IPP	08:00	08:15	00:15	TRIPPED ON FAULT
482	4-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-TELAGI	TELAGI_66,KURBHAHALLI_66,OBBIJJIHALLI_66,SHAMNUR SUGAR_IPP, GREEN INFR_IPP	08:25	08:35	00:10	TRIPPED ON FAULT
483	4-Feb-2024	GULBARGA	66	LINE	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBIJJIHALLI_66	08:25	10:30	02:05	LINE CLEAR AVAILED
484	4-Feb-2024	GULBARGA	110	LINE	CHINCHOLI-SEDAM-1	CHINCHOLI_110	20:47	21:30	00:43	TRIPPED ON FAULT
485	4-Feb-2024	GULBARGA	110	LINE	CHINCHOLI-SEDAM-2	CHINCHOLI_110	20:47	22:28	01:41	TRIPPED ON FAULT
486	4-Feb-2024	GULBARGA	110	LINE	HANGAL-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66	11:05	11:20	01:32	TRIPPED ON FAULT
487	4-Feb-2024	GULBARGA	110	LINE	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	17:25(2.02.2024)			LINE CLEAR AVAILED
488	4-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	10:20	14:20	00:32	LINE CLEAR AVAILED
489	04-Feb-24	HASSAN	66	TRANSFORMER	HV1	HIREMANGLUR_66	13:47	14:25	00:38	LINE CLEAR AVAILED
490	04-Feb-24	HASSAN	66	TRANSFORMER	HV2	HIREMANGLUR_66	10:00	16:35	06:35	LINE CLEAR AVAILED
491	04-Feb-24	HASSAN	110	LINE	KADUR-RAILWAY	KADUR_220	03:29	03:36	00:07	TRIPPED ON FAULT
492	04-Feb-24	HASSAN	110	LINE	KEMAR-Manipal2	KEMAR_220	10:07	12:25	02:18	LINE CLEAR AVAILED
493	4-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47			LINE CLEAR AVAILED
494	4-Feb-24	MYSORE	66	LINE	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	08:07	11:58	03:51	LINE CLEAR AVAILED
495	4-Feb-24	MYSORE	66	LINE	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	07:47	08:05	00:17	LINE CLEAR AVAILED
496	4-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
497	4-Feb-24	MYSORE	66	LINE	HANNUR-AJJIPURA	COWDALLI_66BANDALLI_66AJJIPURA_66RAMAPURA_MYS_66MARTAHALLI_66	09:04	09:11	00:07	TRIPPED ON FAULT
498	4-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
499	4-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
500	4-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
501	4-Feb-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	12:42	12:58	00:16	TRIPPED ON FAULT
502	4-Feb-24	MYSORE	66	TRANSFORMER	HV2	COWDALLI_66	11:18	11:31	00:12	TRIPPED ON FAULT
503	4-Feb-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	18:15	18:45	00:30	LINE CLEAR AVAILED
504	4-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
505	4-Feb-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	10:04	11:37	01:33	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
506	4-Feb-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	KOLLEGALA_66	10:04	11:37	01:32	LINE CLEAR AVAILED
507	4-Feb-24	MYSORE	66	LINE	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66DMG_HALLI_66	17:47	17:59	00:11	TRIPPED ON FAULT
508	4-Feb-24	MYSORE	66	LINE	PONNAMPETE-PERİYAPATNA	PONNAMPETE_66	05:05	05:25	00:20	TRIPPED ON FAULT
509	4-Feb-24	MYSORE	66	LINE	VIRAJPETE-PONNAMPETE	SRIMANGALA_66	05:05	05:20	00:15	TRIPPED ON FAULT
510	4-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV- DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	03:08	03:13	00:05	TRIPPED ON FAULT
511	4-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV- DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	10:46	10:51	00:05	TRIPPED ON FAULT
512	4-Feb-24	TUMKUR	66	LINE	DEVARAHALLI-KEREBILCH	DEVARAHALLI_66	03:08	03:13	00:05	MAIN SUPPLY FAILURE
513	4-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-BEVINAHALLI	CHANGAVARA_66, BEVINAHALLI_66, 110KV DASUDI	06:35	06:50	00:15	TRIPPED ON FAULT
514	4-Feb-24	TUMKUR	66	LINE	PAVAGADA- (GOWRIBIDANUR)VENKATAP URA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
515	4-Feb-24	TUMKUR	220	LINE	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	08:00	08:15	00:15	MAIN SUPPLY FAILURE
516	4-Feb-24	TUMKUR	220	LINE	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	08:23	08:43	00:20	MAIN SUPPLY FAILURE
517	4-Feb-24	TUMKUR	220	LINE	NITTUR 220kV- NELAMANGALA	NITTUR_220	10:28	18:28	08:00	LINE CLEAR AVAILED
518	4-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
519	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	BENAKATTI_110	17:26	18:20	00:54	LINE CLEAR AVAILED
520	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ARGA_110	02:00	04:42	02:42	TRIPPED ON FAULT
521	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	HANAGAL_110	10:03	10:15	00:12	TRIPPED ON FAULT
522	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	HANAGAL_110	10:03	10:15	00:12	TRIPPED ON FAULT
523	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA-HV1)	LOKAPUR_220	15:09	15:17	00:08	TRIPPED ON FAULT
524	05-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA-HV2)	GADAG_110	10:27	11:10	00:43	LINE CLEAR AVAILED
525	05-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2	STATION NOT AFFECTED HUBLI_220	10:15	16:56	06:41	LINE CLEAR AVAILED
526	05-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1(LV2)	SIRSI_220	09:59	10:19	00:20	TRIPPED ON FAULT
527	05-Feb-24	BAGALKOTE	110	LINE	ALBAL-HUBLI	ALBAL_110	21:53	21:59	00:06	LINE CLEAR AVAILED
528	05-Feb-24	BAGALKOTE	110	LINE	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	06:56	07:10	00:14	LINE CLEAR AVAILED
529	05-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
530	05-Feb-24	BAGALKOTE	110	LINE	ATHARGA-RAILWAY LINE	ATHARGA_110	03:50	04:00	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRANSFORM ER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
531	05-Feb-24	BAGALKOTE	110	LINE	BAGALKOT220- RAMDURGA	STATION NOT AFFECTED BAGALKOT_220	13:28	18:50	05:22	LINE CLEAR AVAILED
532	05-Feb-24	BAGALKOTE	110	LINE	BAGALKOT220-BAGALKOT1	STATION NOT AFFECTED BAGALKOT_220	13:30	18:50	05:20	LINE CLEAR AVAILED
533	05-Feb-24	BAGALKOTE	110	LINE	BAGALKOT220-F4- NAVANAGAR-2	STATION NOT AFFECTED BAGALKOT_220	13:17	18:40	05:23	LINE CLEAR AVAILED
534	05-Feb-24	BAGALKOTE	110	LINE	BELGAUM220- HUKKERI(UCHAGOAN)	STATION NOT AFFECTED BELGAUM_220	12:20 (04.02.2024)	13:09 (05.02.2024)	24:49:00	LINE CLEAR AVAILED
535	05-Feb-24	BAGALKOTE	110	LINE	BELGAUM220- HUKKERI(UCHAGOAN)	STATION NOT AFFECTED BELGAUM_220	17:35	17:59	00:24	TRIPPED ON FAULT
536	05-Feb-24	BAGALKOTE	110	LINE	BELLATTI-AB SOLAR	BELLATTI_110	19:11 (05.02.2024)			LINE CLEAR AVAILED
537	05-Feb-24	BAGALKOTE	110	LINE	DADDI-F2(HONAGA)	DADDI_110	03:28	06:35	03:07	TRIPPED ON FAULT
538	05-Feb-24	BAGALKOTE	110	LINE	DEVANAGOAN- F1(GATTARAGA)	DEVANAGOAN_110	18:17	19:20	01:03	LINE CLEAR AVAILED
539	05-Feb-24	BAGALKOTE	110	LINE	GOPANAKOPPA-GADAG ROAD	STATION NOT AFFECTED GOPANAKOPPA_110	7:07 (04.02.2024)	16:56 (05.02.2024)	33:49:00	LINE CLEAR AVAILED
540	05-Feb-24	BAGALKOTE	110	LINE	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)	16:09 (05.02.2024)	4972:00 hrs	LINE CLEAR AVAILED
541	05-Feb-24	BAGALKOTE	110	LINE	KARWAR220- SOLARIS(BINAGA)	STATION NOT AFFECTED KARWAR_220	08:55	11:05	02:10	LINE CLEAR AVAILED
542	05-Feb-24	BAGALKOTE	110	LINE	KARWAR220-ARGA(KUMATA)	STATION NOT AFFECTED KARWAR_220	01:34	01:44	00:10	TRIPPED ON FAULT
543	05-Feb-24	BAGALKOTE	110	LINE	KARWAR220-ARGA(KUMATA)	STATION NOT AFFECTED KARWAR_220	02:19	10:54	08:35	LINE CLEAR AVAILED
544	05-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	17:37 (04.02.2024)	2:32 (05.02.2024)	8:46:00	LINE CLEAR AVAILED
545	05-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI2	KUMTA_110	17:37 (04.02.2024)	2:27 (05.02.2024)	8:50:00	LINE CLEAR AVAILED
546	05-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
547	05-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
548	05-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN12 (PG HUNSHYAL)	STATION NOT AFFECTED MUGALKHOD_220	09:49	12:16	02:27	LINE CLEAR AVAILED
549	05-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
550	05-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
551	05-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA1	STATION NOT AFFECTED SOUDATTI_220	06:03	12:35	06:32	TRIPPED ON FAULT
552	05-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA2	STATION NOT AFFECTED SOUDATTI_220	12:39	14:02	01:23	LINE CLEAR AVAILED
553	05-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
554	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	17:05 (04.02.2024)	13:55 (05.02.2024)	20:50:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
555	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED ATHANI_220	08:48	12:40	03:52	LINE CLEAR AVAILED
556	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1(HV2)	SIRSI_220	10:00	10:19	00:19	TRIPPED ON FAULT
557	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	STATION NOT AFFECTED HUBLI_220	10:15	16:56	06:41	LINE CLEAR AVAILED
558	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV1	SIRSI_220	17:05 (04.02.2024)	13:59 (05.02.2024)	20:54:00	TRIPPED ON FAULT
559	05-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV1	STATION NOT AFFECTED ATHANI_220	08:57	13:15	04:18	LINE CLEAR AVAILED
560	05-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
561	05-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
562	05-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
563	05-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
564	05-Feb-24	BAGALKOTE	220	LINE	VAJRAMATTI- ENERCON	STATION NOT AFFECTED VAJRAMATTI_220	22:33	22:45	00:12	LINE CLEAR AVAILED
565	05-Feb-24	BENGALURU	66	LINE	66kV A STATION 220 - C STATION	C STATION	05:40	05:44	00:04	LINE CLEAR AVAILED
566	05-Feb-24	BENGALURU	66	LINE	66kV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
567	05-Feb-24	BENGALURU	66	LINE	66kV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	18:41	18:49	00:08	TRIPPED ON FAULT
568	05-Feb-24	BENGALURU	66	LINE	66kV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	MINOR IRRIGATION, DIVYASHREE TECH PARK, KACHAMARANAHALLI, SHOBHA DREAMS 66, PRESTIGE LAKESIDE HABITAT	23:48	23:59	00:11	TRIPPED ON FAULT
569	05-Feb-24	BENGALURU	66	LINE	66kV IGGALURU - CNL (EHT)	CNL(EHT)	13:06	15:30	02:24	LINE CLEAR AVAILED
570	05-Feb-24	BENGALURU	66	LINE	66kV K & C VALLEY - NAL	NAL(EHT)	15:03	16:32	01:29	TRIPPED ON FAULT
571	05-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	GODUR, MARALAWADI	13:05	13:10	00:05	TRIPPED ON FAULT
572	05-Feb-24	BENGALURU	66	LINE	66kV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP)	K&C VALLEY	15:03	16:00	00:57	TRIPPED ON FAULT
573	05-Feb-24	BENGALURU	66	LINE	66kV KUDURU - SRIGIRIPURA	SRIGIRIPURA	15:07	15:33	00:26	TRIPPED ON FAULT
574	05-Feb-24	BENGALURU	66	LINE	66kV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	MAGADI 66, HOSAPALYA	10:30	10:51	00:21	TRIPPED ON FAULT
575	05-Feb-24	BENGALURU	66	LINE	66kV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	03:08	03:33	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
576	05-Feb-24	BENGALURU	66	LINE	66kV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	03:59	04:43	00:44	TRIPPED ON FAULT
577	05-Feb-24	BENGALURU	66	LINE	66kV MITTEMARI - BAGEPALLI 2	BAGEPALLI	08:35	08:41	00:06	TRIPPED ON FAULT
578	05-Feb-24	BENGALURU	66	LINE	66kV NRS 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	13:40	13:44	00:04	LINE CLEAR AVAILED
579	05-Feb-24	BENGALURU	66	LINE	66kV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	18:12	18:24	00:12	TRIPPED ON FAULT
580	05-Feb-24	BENGALURU	66	LINE	66kV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	18:12	18:25	00:13	TRIPPED ON FAULT
581	05-Feb-24	BENGALURU	66	LINE	66kV SK STEEL - KOLALA	NO STATION AFFECTED	10:15	10:59	00:44	TRIPPED ON FAULT
582	05-Feb-24	BENGALURU	66	LINE	66kV SOMANAHALLI - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	06:11	06:23	00:12	LINE CLEAR AVAILED
583	05-Feb-24	BENGALURU	66	LINE	66kV T GOLLAHALLI - AVANI	AVANI, MULBAGAL	15:36	16:29	00:53	LINE CLEAR AVAILED
584	05-Feb-24	BENGALURU	66	LINE	66kV TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, MADDUR, KIADB SOMANAHALLI	01:41	01:51	00:10	TRIPPED ON FAULT
585	05-Feb-24	BENGALURU	66	LINE	66kV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	10:20	10:25	00:05	LINE CLEAR AVAILED
586	05-Feb-24	BENGALURU	66	LINE	66kV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	18:07	18:10	00:03	LINE CLEAR AVAILED
587	05-Feb-24	BENGALURU	66	LINE	66kV YARANDANAHALLI - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON, BOMMASANDRA I/A, SYNGENE(EHT)	14:35	14:46	00:11	MAIN SUPPLY FAILURE
588	05-Feb-24	BENGALURU	66	LINE	66kV YARANDANAHALLI - JIGANI	NO STATION AFFECTED	09:00	09:16	00:16	TRIPPED ON FAULT
589	05-Feb-24	BENGALURU	66	LINE	66kV YARANDANAHALLI - JIGANI	NO STATION AFFECTED	14:35	14:46	00:11	TRIPPED ON FAULT
590	05-Feb-24	BENGALURU	66	LINE	66kV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	14:35	14:46	00:11	MAIN SUPPLY FAILURE
591	05-Feb-24	BENGALURU	66	LINE	66kV YARDANAHALLI 220 - CHANDAPURA	CHANDAPURA	14:35	14:46	00:11	MAIN SUPPLY FAILURE
592	05-Feb-24	BENGALURU	66	LINE	66kV YELAHANKA 220 - RAJANUKUNTE	RAJANUKUNTE	18:29	18:42	00:13	TRIPPED ON FAULT
593	05-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SHOBHA APARTMENT	11:00	11:40	00:40	LINE CLEAR AVAILED
594	05-Feb-24	BENGALURU	66	TRANSFORMER	HV1	M GOLLAHALLI	17:05	17:10	00:05	TRIPPED ON FAULT
595	05-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SOMENAHALLI	18:00	18:10	00:10	TRIPPED ON FAULT
596	05-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GUDEMARNAHALLI	16:30	18:00	01:30	TRIPPED ON FAULT
597	05-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BRIGADE MEADOWS	11:47	11:53	00:06	TRIPPED ON FAULT
598	05-Feb-24	BENGALURU	66	TRANSFORMER	HV2	CHINTAMANI 66	13:57	14:13	00:16	TRIPPED ON FAULT
599	05-Feb-24	BENGALURU	66	TRANSFORMER	HV2	GUDEMARNAHALLI	16:30	18:00	01:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
600	05-Feb-24	BENGALURU	66	TRANSFORMER	HV2	IGGALUR	10:10	10:30	00:20	LINE CLEAR AVAILED
601	05-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MAASTHI	12:25	13:25	01:00	LINE CLEAR AVAILED
602	05-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	13:06	15:30	02:24	LINE CLEAR AVAILED
603	05-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	16:40	16:49	00:09	TRIPPED ON FAULT
604	05-Feb-24	BENGALURU	66	TRANSFORMER	HV3	YARANDANAHALLI 220	14:35	14:46	00:11	MAIN SUPPLY FAILURE
605	05-Feb-24	BENGALURU	220	TRANSFORMER	HV1	YARANDANAHALLI 220	14:35	14:46	00:11	TRIPPED ON FAULT
606	5-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	02:11	02:57	00:16	TRIPPED ON FAULT
607	5-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66, GIRIYAPUR_66	02:11	02:22	00:32	TRIPPED ON FAULT
608	5-Feb-2024	GULBARGA	66	LINE	KUDALGI-KOTTUR	UJJANI_66	22:35	22:45	02:32	TRIPPED ON FAULT
609	5-Feb-2024	GULBARGA	66	LINE	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBIJJIHALLI_66	10:00	10:10	00:10	LINE CLEAR AVAILED
610	5-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SHREERAMNAGAR_110	16:40	16:50	01:32	TRIPPED ON FAULT
611	5-Feb-2024	GULBARGA	110	LINE	KADECHUR-KHANAPUR	SAIDAPUR_110	22:31	22:48	00:17	TRIPPED ON FAULT
612	5-Feb-2024	GULBARGA	110	LINE	SANTAPUR-JANAWADA	JANAWADA_110	06:40	06:55	00:15	TRIPPED ON FAULT
613	5-Feb-2024	GULBARGA	110	LINE	SEDAM-CHINCHOLI-2	CHINCHOLI-2	19:32	20:14	00:42	LINE CLEAR AVAILED
614	05-Feb-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	10:55	12:35	01:40	LINE CLEAR AVAILED
615	05-Feb-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	16:59	17:11	00:12	LINE CLEAR AVAILED
616	05-Feb-24	HASSAN	66	LINE	MATTA NAV-DIDGTHL	MATTANAVAILE_66	14:15	15:22	01:07	LINE CLEAR AVAILED
617	05-Feb-24	HASSAN	66	LINE	TAVAREC-DVG2	TAVARECHATNAHALLI_66	10:45	10:50	00:05	TRIPPED ON FAULT
618	05-Feb-24	HASSAN	66	LINE	TAVAREC-DVG2	TAVARECHATNAHALLI_66	17:40	18:10	00:30	TRIPPED ON FAULT
619	05-Feb-24	HASSAN	110	LINE	ANAVATI-BARNGI	ANAVATTI_110	16:30	17:25	00:55	LINE CLEAR AVAILED
620	05-Feb-24	HASSAN	110	TRANSFORMER	HV2	KARKLA_110	08:40	08:47	00:07	TRIPPED ON FAULT
621	05-Feb-24	HASSAN	110	LINE	MRSSHM-TRKER	MRS MG_220	15:12	18:30	03:18	TRIPPED ON FAULT
622	05-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	16:04	17:27	01:23	LINE CLEAR AVAILED
623	05-Feb-24	HASSAN	220	LINE	MRSSHM-CHIKLMNGLUR	MRS MG_220	09:09	18:13	09:04	LOAD CURTAILMENT
624	5-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
625	5-Feb-24	MYSORE	66	LINE	BEGUR 220-HARVEY	HARVEY_66	18:50	18:55	00:05	TRIPPED ON FAULT
626	5-Feb-24	MYSORE	66	LINE	BGPURA	HV2	18:30	19:23	00:52	LINE CLEAR AVAILED
627	5-Feb-24	MYSORE	66	LINE	GUNDLUPETE-HANGLA	HANGLA_66 BHARGI_66	06:36	06:42	00:05	TRIPPED ON FAULT
628	5-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
629	5-Feb-24	MYSORE	66	LINE	HAMPAPURA-SANTESARGUR	YERALLI HAND POST_66 ANTHARSANTHE_66, HDKOTE_66	18:36	18:47	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
630	5-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
631	5-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
632	5-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
633	5-Feb-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_220	10:55	16:10	05:15	LINE CLEAR AVAILED
634	5-Feb-24	MYSORE	66	TRANSFORMER	HV2	NAGAMANGALA_220	16:22	18:26	02:04	LINE CLEAR AVAILED
635	5-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
636	5-Feb-24	MYSORE	66	LINE	K HONALAGERE-IGLOOR	NO STATIONS EFFECTED	13:30	15:23	01:53	LINE CLEAR AVAILED
637	5-Feb-24	MYSORE	66	LINE	KMDODDI-MANDYA	NO STATIONS EFFECTED	02:04	02:07	00:02	LINE CLEAR AVAILED
638	5-Feb-24	MYSORE	66	LINE	KMDODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66	01:40	01:58	00:17	TRIPPED ON FAULT
639	5-Feb-24	MYSORE	66	LINE	KMDODDI-TK HALLI	NO STATIONS EFFECTED	02:07	09:42	07:35	LINE CLEAR AVAILED
640	5-Feb-24	MYSORE	66	LINE	KUSHALNAGARA 220-MIRLE-KR NAGARA(M1)	MIRLE_66	19:24	19:31	00:06	TRIPPED ON FAULT
641	5-Feb-24	MYSORE	66	LINE	KUSHALNAGARA 220-RAMANTHAPURA1	KANAGAL_66 RUDRAPATNA_66 ALUR SIDDAPURA_66	07:02	07:15	00:13	TRIPPED ON FAULT
642	5-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI 220-KOLLEGALA	NO STATIONS EFFECTED	15:12	15:43	00:31	LINE CLEAR AVAILED
643	5-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66, SOKKE, PALLAGHATTE,	22:35:00	22:45:00	00:10	TRIPPED ON FAULT
644	5-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-(LINGADAHALLI) NALLUR_66	NALLURU_66,BASAVAPATNA, THYAVANIGE	12:58	13:14	00:15	TRIPPED ON FAULT
645	5-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	BADAVANAHALLI_66	16:30	17:28	00:58	LINE CLEAR AVAILED
646	5-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	BILCHODE_66	18:37	18:51	00:13	TRIPPED ON FAULT
647	5-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHANNAGIRI_66	12:18	12:22	00:03	TRIPPED ON FAULT
648	5-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HARIYABBE_66	13:10	13:12	00:02	TRIPPED ON FAULT
649	5-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	RANAGANATHAPURA_66	18:19	18:47	00:28	LINE CLEAR AVAILED
650	5-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	BILCHODE_66	22:38	22:46	00:07	TRIPPED ON FAULT
651	5-Feb-24	TUMKUR	66	LINE	NAGALAMADIKE- RNS INFRA SOLAR_IPP_66	RNS INFRA SOLAR_IPP_66	06:28	06:40	00:11	TRIPPED ON FAULT
652	5-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
653	5-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	15:48	16:01	00:13	TRIPPED ON FAULT
654	5-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV-BEERANAHALLI1	BEERANAHALLI1	11:18	19:11	07:53	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRANSFORM ER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
655	5-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
656	06-Feb-24	BAGALKOTE	110	LINE	UDAKERI-NOKAR SOLAR	NOKAR SOLAR_110 STATION NOT AFFECTED UDAKERI_110	19:15	23:15	04:00	LINE CLEAR AVAILED
657	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED UKKALI_110	14:25	15:20	00:55	LINE CLEAR AVAILED
658	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KANABARGI LAYOUT_110	12:15	12:50	00:35	LINE CLEAR AVAILED
659	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BIJAPUR CITY_110	08:41	09:20	00:39	LINE CLEAR AVAILED
660	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	10:46	11:23	00:37	TRIPPED ON FAULT
661	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	NAVALAGI_110	10:46	11:23	00:37	TRIPPED ON FAULT
662	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BIJAPUR CITY_110	09:03	09:25	00:22	LINE CLEAR AVAILED
663	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MACHE_110	07:18	07:19	00:01	LINE CLEAR AVAILED
664	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MACHE_110	08:10	08:20	00:10	LINE CLEAR AVAILED
665	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	RATTIHALLI_110	09:30	09:35	00:05	TRIPPED ON FAULT
666	06-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA-HV1)	KUDCHI_110	09:39	16:12	06:33	LINE CLEAR AVAILED
667	06-Feb-24	BAGALKOTE	110	LINE	ALBAL-HUBLI	ALBAL_110	23:00	23:59	00:59	LINE CLEAR AVAILED
668	06-Feb-24	BAGALKOTE	110	LINE	AMBEWADI- SUPA1	AMBEWDI_220	10:31	13:44	03:13	LINE CLEAR AVAILED
669	06-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
670	06-Feb-24	BAGALKOTE	110	LINE	BELLATTI-AB SOLAR	BELLATTI_110	19:11 (05.02.2024)	0:25 (06.02.2024)	05:14	LINE CLEAR AVAILED
671	06-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
672	06-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
673	06-Feb-24	BAGALKOTE	110	LINE	MAHALINGAPUR- BANAHATTI	MAHALINGAPUR_220, BANAHATTI_110	10:46	11:18	00:32	LINE CLEAR AVAILED
674	06-Feb-24	BAGALKOTE	110	LINE	MAHALINGAPUR- TERDAL	MAHALINGAPUR_220, TERDAL_110	10:46	11:18	00:32	LINE CLEAR AVAILED
675	06-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
676	06-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
677	06-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
678	06-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- HONNATTI	RANEBENNUR_220	07:20	07:45	00:25	LINE CLEAR AVAILED
679	06-Feb-24	BAGALKOTE	110	LINE	TAKKALAKI-TIKOTA	TAKKALAKI_110	10:44	10:53	00:09	TRIPPED ON FAULT
680	06-Feb-24	BAGALKOTE	110	LINE	THORVI-TIKKOTA	THORVI_110	10:45	10:54	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
681	06-Feb-24	BAGALKOTE	110	LINE	TODALBAGI-JAMAKHANDI SUGARS	JAMAKHANDI SUGARS_110 STATION NOT AFFECTED TODALBAGI_110	23:54	23:59	00:05	TRIPPED ON FAULT
682	06-Feb-24	BAGALKOTE	110	LINE	TUMMINAKATTI-F2 (RATTIHALLI)	RATTIHALLI_110 STATION NOT AFFECTED TUMMINAKATTI_110	00:54	01:08	00:14	TRIPPED ON FAULT
683	06-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
684	06-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1&LV1	MAHALINGAPUR_220, RANNABELAGALI_110, BANAHAATTI_110, TERDAL_110, DHAVALESHWAR_110	10:46	11:05	00:19	TRIPPED ON FAULT
685	06-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	ATHANI_220	10:38	12:18	01:40	LINE CLEAR AVAILED
686	06-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	HAVERI_220	19:39	20:26	00:47	LINE CLEAR AVAILED
687	06-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	MAHALINGAPUR_220, RANNABELAGALI_110, BANAHAATTI_110, TERDAL_110, DHAVALESHWAR_110	10:46	11:05	00:19	TRIPPED ON FAULT
688	06-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV2	ATHANI_220	10:38	12:18	01:40	LINE CLEAR AVAILED
689	06-Feb-24	BAGALKOTE	220	LINE	BIDNAL- HUBLI1	BIDNAL_220	10:38	16:30	05:52	LINE CLEAR AVAILED
690	06-Feb-24	BAGALKOTE	220	LINE	BIDNAL- HUBLI3(HUBLI2)	BIDNAL_220	13:14	15:23	02:09	TRIPPED ON FAULT
691	06-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
692	06-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-MUGALKHOD2	GHATAPRABHA_220	09:47	11:54	02:07	LINE CLEAR AVAILED
693	06-Feb-24	BAGALKOTE	220	LINE	HUBLI- BIDNAL1	HUBLI_220	10:38	16:30	05:52	LINE CLEAR AVAILED
694	06-Feb-24	BAGALKOTE	220	LINE	HUBLI- BIDNAL2	HUBLI_220	13:14	15:22	02:08	TRIPPED ON FAULT
695	06-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD-GHATAPRABHA2	MUGALKHOD_220	09:45	11:55	02:10	LINE CLEAR AVAILED
696	06-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
697	06-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
698	06-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
699	06-Feb-24	BENGALURU	66	LINE	66kV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
700	06-Feb-24	BENGALURU	66	LINE	66KV DABASPET - SK STEEL	JINDAL, SK STEEL(EHT)	17:38	18:17	00:39	TRIPPED ON FAULT
701	06-Feb-24	BENGALURU	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR, PURVANKARA PALM BEACH	07:40	09:18	01:38	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
702	06-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL(EHT)	06:39	06:56	00:17	TRIPPED ON FAULT
703	06-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL(EHT)	07:40	09:21	01:41	TRIPPED ON FAULT
704	06-Feb-24	BENGALURU	66	LINE	66kv DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	MINOR IRRIGATION, DIVYASHREE TECH PARK, KACHAMARANAHALLI, SHOBHA DREAMS 66, PRESTIGE LAKESIDE HABITAT	00:00	00:31	00:31	TRIPPED ON FAULT
705	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA	KONDASAPURA	07:40	08:00	00:20	TRIPPED ON FAULT
706	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA	KONDASAPURA	07:40	08:00	00:20	TRIPPED ON FAULT
707	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BIAL BEGUR 220	PILLAGUMPA	07:40	08:43	01:03	TRIPPED ON FAULT
708	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BIAL BEGUR 220	NO STATION AFFECTED	07:40	09:21	01:41	TRIPPED ON FAULT
709	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	07:40	08:19	00:39	TRIPPED ON FAULT
710	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	07:11	07:25	00:14	TRIPPED ON FAULT
711	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	07:40	09:21	01:41	TRIPPED ON FAULT
712	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	07:27	09:21	01:54	TRIPPED ON FAULT
713	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	07:40	09:21	01:41	TRIPPED ON FAULT
714	06-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE	07:40	08:19	00:39	TRIPPED ON FAULT
715	06-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	07:13	08:00	00:47	LOAD CURTAILMENT
716	06-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - BRIGADE METROPIS	BRIGADE METROPOLIS	16:45	16:55	00:10	LINE CLEAR AVAILED
717	06-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	HANUMANTHNAGARA	15:25	15:35	00:10	MAIN SUPPLY FAILURE
718	06-Feb-24	BENGALURU	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	13:31	13:41	00:10	TRIPPED ON FAULT
719	06-Feb-24	BENGALURU	66	LINE	66KV KUDUMULAKUNTE - THERIYUR	TERIYUR	07:15	08:00	00:45	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
720	06-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	12:54	13:54	01:00	TRIPPED ON FAULT
721	06-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	03:52	08:08	04:16	TRIPPED ON FAULT
722	06-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	08:08	09:46	01:38	TRIPPED ON FAULT
723	06-Feb-24	BENGALURU	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	14:10	14:20	00:10	TRIPPED ON FAULT
724	06-Feb-24	BENGALURU	66	LINE	66KV RBI - ELITA PROMENEDE	ELITA PROMENEDE	15:26	16:10	00:44	MAIN SUPPLY FAILURE
725	06-Feb-24	BENGALURU	66	LINE	66KV SIDDALAGHATTA - MELUR	JANGAMKOTE, VIJAYAPURA	17:59	18:02	00:03	LINE CLEAR AVAILED
726	06-Feb-24	BENGALURU	66	LINE	66KV SK STEEL - KOLALA	JINDAL, SK STEEL(EHT)	17:38	18:17	00:39	TRIPPED ON FAULT
727	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	15:25	16:01	00:36	MAIN SUPPLY FAILURE
728	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	15:26	16:48	01:22	MAIN SUPPLY FAILURE
729	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - ISKCON	ISKCON	15:25	15:42	00:17	MAIN SUPPLY FAILURE
730	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - KAGGALIPURA (BRIGADE MEADOWS)	BRIGADE MEADOWS, SHOBHA FOREST	15:25	16:06	00:41	MAIN SUPPLY FAILURE
731	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - RBI - SOUTH CITY (JIGANI 1)	RBI	15:25	16:09	00:44	MAIN SUPPLY FAILURE
732	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - RBI - SOUTH CITY (JIGANI 1)	SOUTH CITY	15:25	16:09	00:44	MAIN SUPPLY FAILURE
733	06-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI - YEDAMADU	YEDUMADU	15:25	16:15	00:50	MAIN SUPPLY FAILURE
734	06-Feb-24	BENGALURU	66	LINE	66KV SRIGANDA KAVAL - BYADARAHALLI	SRIGANDA KAVALU	12:24	13:39	01:15	TRIPPED ON FAULT
735	06-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	BYADRAHALLI, KODIGEHALI	12:12	12:22	00:10	TRIPPED ON FAULT
736	06-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA - PB NAGAR	PADMANABHANAGARA	18:08	18:13	00:05	LINE CLEAR AVAILED
737	06-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	17:40	17:45	00:05	LINE CLEAR AVAILED
738	06-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE, VIJAYAPURA	10:43	10:51	00:08	LINE CLEAR AVAILED
739	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	16:30	16:34	00:04	LINE CLEAR AVAILED
740	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIJAYANAGARA	22:10	22:16	00:06	LINE CLEAR AVAILED
741	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NANDINI LAYOUT	11:00	11:02	00:02	LINE CLEAR AVAILED
742	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KONDASAPURA	16:26	16:30	00:04	LINE CLEAR AVAILED
743	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DIBBURAHALLI	09:24	09:44	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
744	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	THONDEBHAVI	13:15	13:25	00:10	TRIPPED ON FAULT
745	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GUDEMARANAHALLI	12:30	14:00	01:30	LINE CLEAR AVAILED
746	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	IGGALUR	10:05	10:10	00:05	LINE CLEAR AVAILED
747	06-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DOMMASANDRA	11:25	11:30	00:05	LINE CLEAR AVAILED
748	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	PRESTIGE FALCON CITY	11:15	13:10	01:55	LINE CLEAR AVAILED
749	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KONDASAPURA	16:26	16:30	00:04	LINE CLEAR AVAILED
750	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	YENIGADALE	16:20	16:25	00:05	LINE CLEAR AVAILED
751	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VOKKALERI	08:15	08:20	00:05	TRIPPED ON FAULT
752	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KANAKAPURA 66	03:25	03:50	00:25	TRIPPED ON FAULT
753	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DOMMASANDRA	14:22	14:30	00:08	TRIPPED ON FAULT
754	06-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DOMMASANDRA	14:30	16:55	02:25	LINE CLEAR AVAILED
755	06-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - BIDADI 1	SOMANAHALLI 220	15:25	16:01	00:36	TRIPPED ON FAULT
756	06-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - BIDADI 2	SOMANAHALLI 220	15:25	16:01	00:36	TRIPPED ON FAULT
757	06-Feb-24	BENGALURU	220	TRANSFORMER	HV1	EKARAJAPURA 220	07:40	08:05	00:25	TRIPPED ON FAULT
758	06-Feb-24	BENGALURU	220	TRANSFORMER	HV2	EKARAJAPURA 220	07:40	08:05	00:25	TRIPPED ON FAULT
759	06-Feb-24	BENGALURU	220	TRANSFORMER	HV2	GOWRIBIDANUR 220	18:25	18:46	00:21	TRIPPED ON FAULT
760	06-Feb-24	BENGALURU	400	LINE	400KV NELAMANGALA 400 - HIRIYUR 1	NO STATION AFFECTED	13:26	16:12	02:46	TRIPPED ON FAULT
761	06-Feb-24	BENGALURU	400	LINE	400KV NELAMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	13:26	16:13	02:47	TRIPPED ON FAULT
762	6-Feb-2024	GULBARGA	66	LINE	HIREHADAGALI-GIRIYAPUR	GIRIYAPURA_66	06:30	06:35	00:05	TRIPPED ON FAULT
763	6-Feb-2024	GULBARGA	66	TRANSFORMER	HV1 & HV2	UJJANI_66	09:25	19:15	09:50	LINE CLEAR AVAILED
764	6-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	TAMBRAHALLI_66	21:00	21:05	00:05	TRIPPED ON FAULT
765	6-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	HALVAGALU_66	16:20	17:15	00:55	LINE CLEAR AVAILED
766	6-Feb-2024	GULBARGA	66	LINE	KUDALGI-BANAVEKAL	BANAVEKAL_66	06:30	06:45	00:15	TRIPPED ON FAULT
767	6-Feb-2024	GULBARGA	110	LINE	CHICKSUGUR-RAICHUR	SHAKTINAGAR_110	06:20	06:45	00:25	MAIN SUPPLY FAILURE
768	6-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	00:43	00:50	00:07	MAIN SUPPLY FAILURE
769	6-Feb-2024	GULBARGA	110	LINE	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	17:25(2.02.2024)			LINE CLEAR AVAILED
770	6-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	YADGIR_110	09:40	09:50	00:10	TRIPPED ON FAULT
771	6-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	BISIHALLI_110	13:36	13:48	00:12	LINE CLEAR AVAILED
772	6-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	KURUGOD_110	13:22	13:27	00:05	TRIPPED ON FAULT
773	6-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	HALWARTHY_220	15:22	15:27	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
774	6-Feb-2024	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	14:25	17:10	02:45	LINE CLEAR AVAILED
775	6-Feb-2024	GULBARGA	110	LINE	KUSHTAGI-KANAKAGIRI	GANADAL_110	11:00	11:10	00:10	MAIN SUPPLY FAILURE
776	6-Feb-2024	GULBARGA	110	LINE	LINGASUGUR-L.GAMESHA_IPP	LINGASUGUR_220	15:50	17:27	01:37	LINE CLEAR AVAILED
777	6-Feb-2024	GULBARGA	110	LINE	MADIYAL-CHOWDAPUR	CHOWDAPUR_110,SAGANOOOR_110	11:40	11:55	00:15	MAIN SUPPLY FAILURE
778	6-Feb-2024	GULBARGA	110	LINE	MALLAT-ALKOD	ALKOD_110, GALAG_110	05:45	05:55	00:10	TRIPPED ON FAULT
779	6-Feb-2024	GULBARGA	110	LINE	SAIDAPUR-KADECHUR	KADECHUR_110	08:30	13:20	04:50	LINE CLEAR AVAILED
780	6-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	07:15	09:15	02:00	LINE CLEAR AVAILED
781	6-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-WALABALLARY	WALABALLARY_110	10:03	13:25	03:22	LINE CLEAR AVAILED
782	6-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	KUSHTAGI_220	10:11	16:28	06:17	LINE CLEAR AVAILED
783	6-Feb-2024	GULBARGA	220	LINE	ITTAGI-HARAKANALU	ITTAGI_220	09:45	19:15	09:30	LINE CLEAR AVAILED
784	6-Feb-2024	GULBARGA	220	LINE	LINGAPUR-BMM ISPAT	LINGAPUR_220	14:04	15:29	01:25	TRIPPED ON FAULT
785	06-Feb-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	10:32	16:52	06:20	LINE CLEAR AVAILED
786	06-Feb-24	HASSAN	66	TRANSFORMER	HV2	MNJUNATHPURA_66	12:30	16:12	03:42	LINE CLEAR AVAILED
787	06-Feb-24	HASSAN	66	LINE	YESLUR-SNVRSNT	YESLUR_66	10:49	16:48	05:59	LINE CLEAR AVAILED
788	06-Feb-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADY_110	10:02	12:20	02:18	LINE CLEAR AVAILED
789	06-Feb-24	HASSAN	110	TRANSFORMER	HV1	BELAGUMBA_110	11:15	12:15	01:00	LINE CLEAR AVAILED
790	06-Feb-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADY_110	14:29(06.02.2024)			LINE CLEAR AVAILED
791	06-Feb-24	HASSAN	110	TRANSFORMER	HV4	BANTWAL_110	10:24	13:41	03:17	LINE CLEAR AVAILED
792	06-Feb-24	HASSAN	110	TRANSFORMER	HV4	BANTWAL_110	16:47	16:55	00:08	LINE CLEAR AVAILED
793	06-Feb-24	HASSAN	110	TRANSFORMER	HV4	KAVOOR_220	11:31	15:34	04:03	LINE CLEAR AVAILED
794	06-Feb-24	HASSAN	110	TRANSFORMER	HV5	BAIKAMPADY_110	12:21	14:24	02:03	LINE CLEAR AVAILED
795	06-Feb-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY4	MRSMSG_220	14:07	16:21	02:14	TRIPPED ON FAULT
796	06-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	16:57	21:32	04:35	TRIPPED ON FAULT
797	06-Feb-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA4	sharavathy_gen	13:59	16:23	02:24	TRIPPED ON FAULT
798	06-Feb-24	HASSAN	220	LINE	SHRAVITY-SIRISI 1	sharavathy_gen	10:06	15:14	05:08	LINE CLEAR AVAILED
799	06-Feb-24	HASSAN	220	LINE	SHRAVITY-SIRISI 2	sharavathy_gen	10:07	15:14	05:07	LINE CLEAR AVAILED
800	06-Feb-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	varahi_gen	16:57	21:32	04:35	TRIPPED ON FAULT
801	06-Feb-24	HASSAN	400	LINE	HBNHL-UPCL1	HEBBANAHALLI_400KV	13:34	16:16	02:42	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
802	06-Feb-24	HASSAN	400	LINE	UPCL-HEBBANAHALLI1	upcl_gen	13:34	16:21	02:47	TRIPPED ON FAULT
803	6-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
804	6-Feb-24	MYSORE	66	LINE	COWDALLI-MARTHALLI	MARTAHALLI_66RAMAPURA_MYS_66	10:25	16:43	06:18	LINE CLEAR AVAILED
805	6-Feb-24	MYSORE	66	LINE	CR NAGARA-HONGANUR	YELANDUR_66HONGANUR_66	23:58 (6/02/2024)			TRIPPED ON FAULT
806	6-Feb-24	MYSORE	66	LINE	DK MAIDANA-VAJAMANGALA	NO STATIONS EFFECTED	08:43	10:08	01:25	LINE CLEAR AVAILED
807	6-Feb-24	MYSORE	66	LINE	GUNDLUPETE-BEGUR 2	NO STATIONS EFFECTED	07:21	07:30	00:08	LINE CLEAR AVAILED
808	6-Feb-24	MYSORE	66	LINE	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	07:21	07:30	00:08	LINE CLEAR AVAILED
809	6-Feb-24	MYSORE	66	TRANSFORMER	GUNDLUPETE-HV1	GUNDLUPETE_66	07:21	07:30	00:08	LINE CLEAR AVAILED
810	6-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
811	6-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
812	6-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
813	6-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	BOGADHI_66	10:10	18:12	08:02	LINE CLEAR AVAILED
814	6-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
815	6-Feb-24	MYSORE	66	LINE	HUNSUR 220-HANAGUD	HANAGODU_66	10:21	18:40	08:19	LINE CLEAR AVAILED
816	6-Feb-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR 1	NO STATIONS EFFECTED	15:36	17:37	02:01	LINE CLEAR AVAILED
817	6-Feb-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR 2	HUNSUR_66	15:38	17:38	02:00	LINE CLEAR AVAILED
818	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	ADDIHALLI_66	10:38	11:05	00:26	TRIPPED ON FAULT
819	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	FTS_66	06:26	08:20	01:53	TRIPPED ON FAULT
820	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	GUNDLUPETE_66	07:21	07:30	00:08	LINE CLEAR AVAILED
821	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	02:02	02:10	00:07	TRIPPED ON FAULT
822	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	HUNSUR_66	10:01	17:45	07:43	LINE CLEAR AVAILED
823	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	MUGUR_66	07:21	07:27	00:05	LINE CLEAR AVAILED
824	6-Feb-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	13:00	18:35	05:35	LINE CLEAR AVAILED
825	6-Feb-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	10:01	17:45	07:43	LINE CLEAR AVAILED
826	6-Feb-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	17:15	17:45	00:30	LINE CLEAR AVAILED
827	6-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
828	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	15:39	15:55	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
829	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	15:56	16:13	00:17	LINE CLEAR AVAILED
830	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	16:33	16:57	00:24	LINE CLEAR AVAILED
831	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	08:00	10:13	02:13	LINE CLEAR AVAILED
832	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	16:38	17:02	00:23	LINE CLEAR AVAILED
833	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-LOKKANAHALLI	NO STATIONS EFFECTED	16:01	16:23	00:21	LINE CLEAR AVAILED
834	6-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	16:09	16:28	00:19	LINE CLEAR AVAILED
835	6-Feb-24	MYSORE	66	LINE	NAGAMANGALA-TUBINKERE	NAGAMANGALA_66	17:20	18:34	01:13	LINE CLEAR AVAILED
836	6-Feb-24	MYSORE	220	LINE	MADHUVANAHALLI-HEBBANI 1	NO STATIONS EFFECTED	12:37	13:41	01:03	LINE CLEAR AVAILED
837	6-Feb-24	MYSORE	220	LINE	TUBINKERE 220-BASTIPURA	NO STATIONS EFFECTED	14:45	18:59	04:14	LINE CLEAR AVAILED
838	6-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	07:08	08:00	00:51	LOAD CURTAILMENT
839	6-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	07:08	08:00	00:51	LOAD CURTAILMENT
840	6-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kv-MALLADIHALLI	MALLADIHALLI_66	09:45	09:55	00:10	LINE CLEAR AVAILED
841	6-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	09:25	09:40	00:15	LINE CLEAR AVAILED
842	6-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66	23:18	23:24	00:06	TRIPPED ON FAULT
843	6-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kv-CHITRADURGA 4	CHITRADURGA_220	11:40	12:01	00:21	LINE CLEAR AVAILED
844	6-Feb-24	TUMKUR	66	LINE	DASUDI-HIRIYUR	HIRIYUR_220	17:00	17:12	00:12	MAIN SUPPLY FAILURE
845	6-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:22	14:45	00:23	LINE CLEAR AVAILED
846	6-Feb-24	TUMKUR	66	LINE	DEVARABELEKERE-KUNDUR	DEVARABELEKERE_66	15:40	15:50	00:10	MAIN SUPPLY FAILURE
847	6-Feb-24	TUMKUR	66	LINE	HIRIYUR220kv-BEVINAHALLI	DASUDI_66, BEVINAHALLI_66, CHANGAVARA_66	17:00	17:12	00:12	TRIPPED ON FAULT
848	6-Feb-24	TUMKUR	66	LINE	HONNALLI 220kv- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:39	15:49	00:09	TRIPPED ON FAULT
849	6-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	DEVARABELKERE_66	14:10	17:30	03:20	LINE CLEAR AVAILED
850	6-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HOLALKERE_66	09:45	10:25	00:40	LINE CLEAR AVAILED
851	6-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	MYLANAHALLI_66	06:10	06:25	00:15	TRIPPED ON FAULT
852	6-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	NAGALAMADIKE_66	15:40	16:50	01:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
853	6-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	DEVARABELKERE_66	09:05	14:20	05:15	LINE CLEAR AVAILED
854	6-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HOLALKERE_66	18:05	18:37	00:31	LINE CLEAR AVAILED
855	6-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	KADAJJII_66	16:34	16:42	00:07	TRIPPED ON FAULT
856	6-Feb-24	TUMKUR	66	TRANSFORMER	HV3(TR3)	HOLALKERE_66	17:45	17:50	00:05	TRIPPED ON FAULT
857	6-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
858	6-Feb-24	TUMKUR	66	LINE	SHYAGALE- KERECHILCHI	SHYAGALE_66, KERECHILCHI_66, TYAVANAGI_66, SANTEBENNUR_66, BASAVAPATNA_66	18:15	18:30	00:15	TRIPPED ON FAULT
859	6-Feb-24	TUMKUR	66	LINE	SOKKE-PALLAGATTE	SOKKE-66kV Pallagatte-66kV	09:25	09:40	00:15	LINE CLEAR AVAILED
860	6-Feb-24	TUMKUR	220	LINE	ANCHEPALYA 220kV-NEGAMANGALA 1	ANCHEPALYA_220	16:19	19:03	02:44	LINE CLEAR AVAILED
861	6-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
862	6-Feb-24	TUMKUR	400	LINE	GUTTUR 400kV- NARENDRA-	NARENDRA - LINE	08:09	19:15	11:06	LINE CLEAR AVAILED
863	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED AREMALLAPUR_110	10:45	16:00	05:15	LINE CLEAR AVAILED
864	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED ATHARGA_110	12:47	13:10	00:23	LINE CLEAR AVAILED
865	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED ATHARGA_110	11:20	12:25	01:05	LINE CLEAR AVAILED
866	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	STATION NOT AFFECTED RANEBENNUR_220	11:10	18:10	07:00	LINE CLEAR AVAILED
867	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HIREKERUR_110	10:15	19:06	08:51	LINE CLEAR AVAILED
868	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	11:42	16:54	05:12	LINE CLEAR AVAILED
869	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	15:25	16:54	01:29	LINE CLEAR AVAILED
870	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KALAGATAGI_110	14:30	19:40	05:10	LINE CLEAR AVAILED
871	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	PH COMPOUND_110	10:00	17:45	07:45	LINE CLEAR AVAILED
872	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TOLAMATTI_110	17:28	18:32	01:04	LINE CLEAR AVAILED
873	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TUMMINAKATTI_110	10:15	19:08	08:53	LINE CLEAR AVAILED
874	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UKKALI_110	17:13	17:54	00:41	LINE CLEAR AVAILED
875	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	VAJRAMATTI_110	11:28	21:05	09:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
876	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	HIREKERUR_110	10:15	19:44	09:29	LINE CLEAR AVAILED
877	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KALAGATAGI_110	10:48	17:32	06:44	LINE CLEAR AVAILED
878	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	SANKESHWAR_110	10:05	10:16	00:11	LINE CLEAR AVAILED
879	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TUMMINAKATTI_110	10:15	19:08	08:53	LINE CLEAR AVAILED
880	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	VAJRAMATTI_110	11:28	22:00	10:32	LINE CLEAR AVAILED
881	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	HIREKERUR_110	10:15	19:00	08:45	LINE CLEAR AVAILED
882	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3,HV4(20MVA)	STATION NOT AFFECTED RANEENNUR_220	10:18	18:01	07:43	LINE CLEAR AVAILED
883	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	PH COMPOUND_110	10:00	17:45	07:45	LINE CLEAR AVAILED
884	07-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	TUMMINAKATTI_110	10:15	19:10	08:55	LINE CLEAR AVAILED
885	07-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3 (100MVA)	STATION NOT AFFECTED BIJAPUR_220	14:34	15:00	00:26	TRIPPED ON FAULT
886	07-Feb-24	BAGALKOTE	110	LINE	ATHANI220- GHATNATTI	STATION NOT AFFECTED ATHANI_220	20:40	20:50	00:10	TRIPPED ON FAULT
887	07-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
888	07-Feb-24	BAGALKOTE	110	LINE	BELUR-NARENDRA220-1	STATION NOT AFFECTED BELUR_110	11:26	19:03	07:37	LINE CLEAR AVAILED
889	07-Feb-24	BAGALKOTE	110	LINE	BIDNAL220-PH COMPOUND	STATION NOT AFFECTED BIDNAL_220	10:12	17:15	07:03	LINE CLEAR AVAILED
890	07-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
891	07-Feb-24	BAGALKOTE	110	LINE	HAVERI220-HAVERI	HAVERI_110 STATION NOT AFFECTED HAVERI_220	09:54	16:30	06:36	LINE CLEAR AVAILED
892	07-Feb-24	BAGALKOTE	110	LINE	HAVERI220-TILUVALLI	TILUVALLI_110 STATION NOT AFFECTED HAVERI_220	08:17	08:30	00:13	LINE CLEAR AVAILED
893	07-Feb-24	BAGALKOTE	110	LINE	HAVERI220-TILUVALLI	TILUVALLI_110 STATION NOT AFFECTED HAVERI_220	08:52	09:53	01:01	LINE CLEAR AVAILED
894	07-Feb-24	BAGALKOTE	110	LINE	HOSAHONNATTI-F1(RANEENNUR)	HOSAHONNATTI_110	10:30	17:25	06:55	LINE CLEAR AVAILED
895	07-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUND	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
896	07-Feb-24	BAGALKOTE	110	LINE	KALAGATAGI-ASPL	KALAGATAGI_110	16:30	17:25	00:55	LINE CLEAR AVAILED
897	07-Feb-24	BAGALKOTE	110	LINE	KALAGATAGI-HUBLI	KALAGATAGI_110	16:30	17:25	00:55	LINE CLEAR AVAILED
898	07-Feb-24	BAGALKOTE	110	LINE	KALAGATAGI-TABAKADA HONNALLI	KALAGATAGI_110	16:30	17:25	00:55	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
899	07-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
900	07-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
901	07-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- KULIGOD	STATION NOT AFFECTED MUGALKHOD_220	11:15	12:32	01:17	LINE CLEAR AVAILED
902	07-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- NAGNUR	STATION NOT AFFECTED MUGALKHOD_220	09:36	11:09	01:33	LINE CLEAR AVAILED
903	07-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
904	07-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
905	07-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-BIDNAL	PH COMPOUND_110	10:05	17:58	07:53	LINE CLEAR AVAILED
906	07-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
907	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- BYADAGI	STATION NOT AFFECTED RANEBENNUR_220	11:10	20:03	08:53	LINE CLEAR AVAILED
908	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	10:27	22:13	11:46	LINE CLEAR AVAILED
909	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- HONNATTI	STATION NOT AFFECTED RANEBENNUR_220	10:27	12:16	01:49	LINE CLEAR AVAILED
910	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- RATTIHALLI (TUMMINAKATTE)	STATION NOT AFFECTED RANEBENNUR_220	19:39	19:47	00:08	LINE CLEAR AVAILED
911	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- TUMMINAKATTE	STATION NOT AFFECTED RANEBENNUR_220	10:22	19:00	08:38	LINE CLEAR AVAILED
912	07-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	11:10	12:15	01:05	LINE CLEAR AVAILED
913	07-Feb-24	BAGALKOTE	110	LINE	TUMMINAKATTI- F1(RANEBENNUR)	TUMMINAKATTI_110	10:18	19:03	08:45	LINE CLEAR AVAILED
914	07-Feb-24	BAGALKOTE	110	LINE	TUMMINAKATTI- F2(RATTIHALLI)	TUMMINAKATTI_110	10:18	19:04	08:46	LINE CLEAR AVAILED
915	07-Feb-24	BAGALKOTE	110	LINE	UKKALI-F2(BAGEWADI)	UKKALI_110	17:14	17:54	00:40	LINE CLEAR AVAILED
916	07-Feb-24	BAGALKOTE	110	LINE	UTTUR-MUDHOL	UTTUR_110	00:22	00:27	00:05	TRIPPED ON FAULT
917	07-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
918	07-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- VAJRAMATTI	STATION NOT AFFECTED VAJRAMATTI_220	15:42	20:36	04:54	LINE CLEAR AVAILED
919	07-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED RANEBENNUR_220	10:35	19:54	09:19	LINE CLEAR AVAILED
920	07-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	STATION NOT AFFECTED RANEBENNUR_220	10:35	19:47	09:12	LINE CLEAR AVAILED
921	07-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3 (100MVA)	STATION NOT AFFECTED BIJAPUR_220	14:34	14:59	00:25	TRIPPED ON FAULT
922	07-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	13:03	13:14	00:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRANSFORM ER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
923	07-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
924	07-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-VAISHALI2	STATION NOT AFFECTED BIJAPUR_220	14:34	15:00	00:26	TRIPPED ON FAULT
925	07-Feb-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR2	STATION NOT AFFECTED HAVERI_220	10:53	21:51	10:58	LINE CLEAR AVAILED
926	07-Feb-24	BAGALKOTE	220	LINE	HUBLI- SIRSI1	STATION NOT AFFECTED HUBLI_220	12:16	17:58	05:42	LINE CLEAR AVAILED
927	07-Feb-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	12:28	16:11	03:43	LINE CLEAR AVAILED
928	07-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- BELLIGAVI	STATION NOT AFFECTED RANEBENNUR_220	10:36	19:33	08:57	LINE CLEAR AVAILED
929	07-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	STATION NOT AFFECTED RANEBENNUR_220	10:36	21:55	11:19	LINE CLEAR AVAILED
930	07-Feb-24	BAGALKOTE	220	LINE	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	12:10	18:04	05:54	LINE CLEAR AVAILED
931	07-Feb-24	BAGALKOTE	220	LINE	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	12:10	18:04	05:54	LINE CLEAR AVAILED
932	07-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)	12:10 (07.02.2024)	286:22:00	LINE CLEAR AVAILED
933	07-Feb-24	BAGALKOTE	220	LINE	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	13:48 (26.01.2024)	12:10 (07.02.2024)	286:22:00	LINE CLEAR AVAILED
934	07-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:04 (07.02.2024)			LINE CLEAR AVAILED
935	07-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:04 (07.02.2024)			LINE CLEAR AVAILED
936	07-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
937	07-Feb-24	BENGALURU	66	LINE	66kV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
938	07-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	07:33	07:40	00:07	LINE CLEAR AVAILED
939	07-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	VANDARGUPPE, SANKALGERE, SHIVANAHALLI DAIRY, DASHAVARA, BEVOOR, ADANI SOLAR, CNNL(EHT)	13:19	14:30	01:11	MAIN SUPPLY FAILURE
940	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	11:22	11:35	00:13	LINE CLEAR AVAILED
941	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	16:26	16:34	00:08	LINE CLEAR AVAILED
942	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGANAHALLI	11:22	11:35	00:13	LINE CLEAR AVAILED
943	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGANAHALLI	16:26	16:34	00:08	LINE CLEAR AVAILED
944	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNASENAHALLI, CHEEMANGALA	11:22	11:35	00:13	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
945	07-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNASENAHALLI, CHEEMANGALA	16:26	16:34	00:08	LINE CLEAR AVAILED
946	07-Feb-24	BENGALURU	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	NO STATION AFFECTED	07:28	09:45	02:17	TRIPPED ON FAULT
947	07-Feb-24	BENGALURU	66	LINE	66KV DIBBURHALLI - SADLI - SOMENAHALLI - PERESANDRA	DIBBURAHALLI	18:11	18:17	00:06	LINE CLEAR AVAILED
948	07-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH-2 SEC 2, HUSKUR, TATA POWER SOLAR(EHT), BIOCON(EHT), TECH MAHINDRA(EHT)	21:40	22:22	00:42	TRIPPED ON FAULT
949	07-Feb-24	BENGALURU	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	15:35	15:40	00:05	LINE CLEAR AVAILED
950	07-Feb-24	BENGALURU	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI, JALAMANGALA, MELEHALLI, KUTAGALU, CHIKKAGANGANAWADI, MATHIKERE, URAGAHALLI	13:19	14:47	01:28	MAIN SUPPLY FAILURE
951	07-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	07:52	07:56	00:04	LINE CLEAR AVAILED
952	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - SRINIVASAPURA 66 1	SRINIVASAPURA 66	13:13	14:06	00:53	MAIN SUPPLY FAILURE
953	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - SRINIVASAPURA 66 1	SRINIVASAPURA 66	18:55	19:04	00:09	LINE CLEAR AVAILED
954	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	13:13	14:08	00:55	MAIN SUPPLY FAILURE
955	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	18:57	19:05	00:08	LINE CLEAR AVAILED
956	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR, YELDUR	13:13	14:06	00:53	MAIN SUPPLY FAILURE
957	07-Feb-24	BENGALURU	66	LINE	66kV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR, YELDUR	18:56	19:06	00:10	LINE CLEAR AVAILED
958	07-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA - SARAKKI 2	NO STATION AFFECTED	11:31	14:25	02:54	TRIPPED ON FAULT
959	07-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	VIJAYAPURA, JANGAMKOTE	10:35	10:40	00:05	LINE CLEAR AVAILED
960	07-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	VIJAYAPURA, JANGAMKOTE	17:50	17:55	00:05	LINE CLEAR AVAILED
961	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HAL 220	12:31	12:35	00:04	LINE CLEAR AVAILED
962	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KORAMANGALA 220	15:52	15:55	00:03	LINE CLEAR AVAILED
963	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BURUDAGUNTE	10:24	11:24	01:00	LINE CLEAR AVAILED
964	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	M GOLLAHALLI	16:10	16:15	00:05	LINE CLEAR AVAILED
965	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YENIGADALE	08:00	08:01	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
966	07-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SRINIVASAPURA 220	13:13	14:30	01:17	MAIN SUPPLY FAILURE
967	07-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KORAMANGALA 220	17:13	17:17	00:04	LINE CLEAR AVAILED
968	07-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	12:10	12:12	00:02	LINE CLEAR AVAILED
969	07-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TUBAGERE	09:56	09:58	00:02	TRIPPED ON FAULT
970	07-Feb-24	BENGALURU	66	TRANSFORMER	HV3	DEVANAHALLI 66	16:55	17:00	00:05	TRIPPED ON FAULT
971	07-Feb-24	BENGALURU	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	CHANNAPATNA 220	13:21	14:34	01:13	TRIPPED ON FAULT
972	07-Feb-24	BENGALURU	220	LINE	220KV CHINTAMANI - SRINIVASPURA 1	SRINIVASAPURA 220	13:13	14:06	00:53	MAIN SUPPLY FAILURE
973	07-Feb-24	BENGALURU	220	LINE	220KV KOTHIPURA 220 - BIDADI 1	KOTHIPURA 220, CHANNAPATNA 220	13:19	14:14	00:55	TRIPPED ON FAULT
974	07-Feb-24	BENGALURU	220	LINE	220KV KOTHIPURA 220 - BIDADI 2	KOTHIPURA 220, CHANNAPATNA 220	13:19	14:14	00:55	TRIPPED ON FAULT
975	07-Feb-24	BENGALURU	220	LINE	220KV PGCIL KOLAR - CHINTAMANI 1	SRINIVASAPURA 220	13:14	14:06	00:52	TRIPPED ON FAULT
976	07-Feb-24	BENGALURU	400	LINE	400KV KOLAR 400 - MYLASANDRA	NO STATION AFFECTED	17:19	20:03	02:44	TRIPPED ON FAULT
977	7-Feb-2024	GULBARGA	66	LINE	CHILKANHATTI-MUNIRABAD	CHILKANHATTI_66	21:03	21:23	00:20	LINE CLEAR AVAILED
978	7-Feb-2024	GULBARGA	66	LINE	HANASI-KUDALGI	HANASI_66, CHILAKANAHATTI_66	18:45	21:20	02:35	LINE CLEAR AVAILED
979	7-Feb-2024	GULBARGA	66	TRANSFORMER	HV1&HV2	UJJANI_66	09:35	09:55	00:20	MAIN SUPPLY FAILURE
980	7-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	TELAGI_66	11:35	11:40	00:05	TRIPPED ON FAULT
981	7-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	TELAGI_66	13:20	13:25	00:05	TRIPPED ON FAULT
982	7-Feb-2024	GULBARGA	66	LINE	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBIJJIHALLI_66	18:25	18:35	00:10	TRIPPED ON FAULT
983	7-Feb-2024	GULBARGA	110	LINE	ALIPUR-BELLARY NORTH	BELLARY NORTH_110,MOKA_110,SOMASAMUNDRA_110,PD_HALLI_110,BISIHALLI_110	08:20	18:25	10:05	LINE CLEAR AVAILED
984	7-Feb-2024	GULBARGA	110	LINE	BELLARY SOUTH-HALKUNDI	HALKUNDI_110	05:45	06:14	00:29	TRIPPED ON FAULT
985	7-Feb-2024	GULBARGA	110	LINE	HUMNABAD-RAJESHWAR	RAJESHWAR_110,SASTHAPUR_110	17:25(2.02.2024)	19:00(7.02.2024)	228:25:00	LINE CLEAR AVAILED
986	7-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KURUGOD_110	09:45	11:05	01:20	TRIPPED ON FAULT
987	7-Feb-2024	GULBARGA	110	TRANSFORMER	HV1,HV2	MUNIRABAD_220	13:46	13:55	00:09	TRIPPED ON FAULT
988	7-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	ALIPUR_220	03:00	06:50	03:50	LINE CLEAR AVAILED
989	7-Feb-2024	GULBARGA	110	TRANSFORMER	HV7	MUNIRABAD_220	13:46	13:57	00:11	LINE CLEAR AVAILED
990	7-Feb-2024	GULBARGA	110	LINE	KAPNOOR-KALBURGI WEST	KALBURGI WEST_110	11:50	16:05	04:15	LINE CLEAR AVAILED
991	7-Feb-2024	GULBARGA	110	LINE	KHANAPUR-SANATHI	KHANAPUR_110	05:25	05:35	00:10	TRIPPED ON FAULT
992	7-Feb-2024	GULBARGA	110	LINE	MADIYAL-CHOWDAPUR	CHOWDAPUR_110, SAGNOOR_110	23:53	23:57	00:04	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
993	7-Feb-2024	GULBARGA	110	LINE	PDHALLI-ALIPUR	PD_HALLI_110,JANAKI STEELS_IPP,BASAI_IPP,CLN SLR_IPP,CLN MAX_IPP	05:46	05:56	00:10	TRIPPED ON FAULT
994	7-Feb-2024	GULBARGA	220	TRANSFORMER	HV2	KUSHTAGI_220	10:10	17:36	07:26	LINE CLEAR AVAILED
995	7-Feb-2024	GULBARGA	220	LINE	ITTAGI-HARAKANALU	ITTAGI_220	09:39	15:35	05:56	LINE CLEAR AVAILED
996	7-Feb-2024	GULBARGA	220	LINE	NEELAGUNDA-GUTTUR	GUTTUR_220	11:06	21:48	10:42	LINE CLEAR AVAILED
997	07-Feb-24	HASSAN	66	LINE	AREHALI-SAKLESPUR	AREHALLI_220	10:11	17:31	07:20	LINE CLEAR AVAILED
998	07-Feb-24	HASSAN	66	LINE	BALLUPE-KANDLI	BALLUPETE_66	10:03	17:01	06:58	MAIN SUPPLY FAILURE
999	07-Feb-24	HASSAN	66	LINE	CHANNAR-MALALI	CHANNARAYAPATNA_66	19:15	19:35	00:20	TRIPPED ON FAULT
1000	07-Feb-24	HASSAN	66	LINE	HANUBAL-SAKLESPUR	HANUBALU_66	10:12	17:26	07:14	MAIN SUPPLY FAILURE
1001	07-Feb-24	HASSAN	66	LINE	HASSN22-SKPURA1	HASSAN_220	10:37	13:00	02:23	LINE CLEAR AVAILED
1002	07-Feb-24	HASSAN	66	LINE	HASSN22-SKPURA2	HASSAN_220	10:03	14:37	04:34	LINE CLEAR AVAILED
1003	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	AREHALLI_220	10:11	17:31	07:20	LINE CLEAR AVAILED
1004	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	BALLUPETE_66	10:03	17:01	06:58	MAIN SUPPLY FAILURE
1005	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	HANUBALU_66	10:12	17:26	07:14	MAIN SUPPLY FAILURE
1006	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	KANDLI_66	10:08	13:00	02:52	LINE CLEAR AVAILED
1007	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	10:05	17:00	06:55	MAIN SUPPLY FAILURE
1008	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	10:10	17:25	07:15	LINE CLEAR AVAILED
1009	07-Feb-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	19:28	19:41	00:13	TRIPPED ON FAULT
1010	07-Feb-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	12:08	12:20	00:12	LINE CLEAR AVAILED
1011	07-Feb-24	HASSAN	66	TRANSFORMER	HV2	KANDLI_66	10:08	13:00	02:52	LINE CLEAR AVAILED
1012	07-Feb-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	10:10	17:25	07:15	LINE CLEAR AVAILED
1013	07-Feb-24	HASSAN	66	LINE	KANDLI-HASSAN	KANDLI_66	10:10	13:00	02:50	LINE CLEAR AVAILED
1014	07-Feb-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	10:05	17:07	07:02	LINE CLEAR AVAILED
1015	07-Feb-24	HASSAN	66	LINE	MRSSHM-DVG1	MRSMSG_220	14:41	14:55	00:14	TRIPPED ON FAULT
1016	07-Feb-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	10:35	17:24	06:49	LINE CLEAR AVAILED
1017	07-Feb-24	HASSAN	66	LINE	SAKALE-HASSAN	SAKALESHPURA_66	10:15	17:25	07:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1018	07-Feb-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	10:10	17:25	07:15	LINE CLEAR AVAILED
1019	07-Feb-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	10:10	18:00	07:50	LINE CLEAR AVAILED
1020	07-Feb-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	10:10	17:45	07:35	LINE CLEAR AVAILED
1021	07-Feb-24	HASSAN	66	LINE	TAVAREC-HONALI	TAVARECHETTANAHALLY_66	23:15	23:20	00:05	TRIPPED ON FAULT
1022	07-Feb-24	HASSAN	66	LINE	TAVAREC-HONALI	TAVARECHETTANAHALLY_66	14:40	14:55	00:15	MAIN SUPPLY FAILURE
1023	07-Feb-24	HASSAN	110	LINE	ARSK2-ARSKR	ARASIKERE_220	14:43	14:51	00:08	TRIPPED ON FAULT
1024	07-Feb-24	HASSAN	110	LINE	ARSK2-BANVARA	ARASIKERE_220	14:43	14:51	00:08	TRIPPED ON FAULT
1025	07-Feb-24	HASSAN	110	TRANSFORMER	HV1	MSEZ_220	10:16	13:19	03:03	LINE CLEAR AVAILED
1026	07-Feb-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADY_110	14:29(06.02.2024)	16:50(7.02.2024)		LINE CLEAR AVAILED
1027	07-Feb-24	HASSAN	110	TRANSFORMER	HV2	MSEZ_220	10:04	13:26	03:22	LINE CLEAR AVAILED
1028	07-Feb-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	10:15	14:02	03:47	LINE CLEAR AVAILED
1029	07-Feb-24	HASSAN	110	LINE	KADUR-YGTI	KADUR_220	18:03	18:29	00:26	LINE CLEAR AVAILED
1030	07-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	10:51	10:57	00:06	LINE CLEAR AVAILED
1031	07-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	12:29	12:35	00:06	LINE CLEAR AVAILED
1032	07-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	12:47	12:59	00:12	TRIPPED ON FAULT
1033	07-Feb-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:51	11:07	00:16	LINE CLEAR AVAILED
1034	07-Feb-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	12:13	12:31	00:18	LINE CLEAR AVAILED
1035	07-Feb-24	HASSAN	110	LINE	PUTTUR-MADAV	PUTTUR_220	11:06	12:00	00:54	LINE CLEAR AVAILED
1036	07-Feb-24	HASSAN	110	LINE	PUTTUR-SULIA	PUTTUR_220	11:07	12:00	00:53	LINE CLEAR AVAILED
1037	07-Feb-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	12:12	12:15	00:03	LINE CLEAR AVAILED
1038	07-Feb-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	10:57	11:07	00:10	MAIN SUPPLY FAILURE
1039	07-Feb-24	HASSAN	110	LINE	SALATHU-SLTR VTLA	SALATHUR_110	10:57	11:07	00:10	MAIN SUPPLY FAILURE
1040	07-Feb-24	HASSAN	110	LINE	SALATHU-SLTR VTLA	SALATHUR_110	11:07	11:13	00:06	LINE CLEAR AVAILED
1041	07-Feb-24	HASSAN	110	LINE	SALATHU-SLTR VTLA	SALATHUR_110	12:12	12:15	00:03	LINE CLEAR AVAILED
1042	07-Feb-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	03:56	04:31	00:35	TRIPPED ON FAULT
1043	07-Feb-24	HASSAN	220	LINE	MRSSHM-HONNALLI	MRSMSG_220	13:38	18:18	04:40	TRIPPED ON FAULT
1044	07-Feb-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	11:00	11:58	00:58	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1045	7-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1046	7-Feb-24	MYSORE	66	LINE	CR NAGARA-HONGANUR	YELANDUR_66HONGANUR_66	23:58 (6/02/2024)	0:07:00 (7.02.2024)	00:09	TRIPPED ON FAULT
1047	7-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	12:48:09	15:05:05	02:16:56	LINE CLEAR AVAILED
1048	7-Feb-24	MYSORE	66	LINE	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	09:34:44	12:48:05	03:13:21	LINE CLEAR AVAILED
1049	7-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1050	7-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1051	7-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1052	7-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1053	7-Feb-24	MYSORE	66	TRANSFORMER	HV1	DUNDANAHALLI_66	09:45:00	15:57:25	06:12:25	LINE CLEAR AVAILED
1054	7-Feb-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	09:50:00	10:05:00	00:15:00	LINE CLEAR AVAILED
1055	7-Feb-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	18:05:00	18:20:00	00:15:00	LINE CLEAR AVAILED
1056	7-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
1057	7-Feb-24	MYSORE	66	LINE	KIRUGAVALU-VADKEPURA	KIRUGAVALU_66 VADKEPURA_66	10:08:43	18:07:00	07:58:17	LINE CLEAR AVAILED
1058	7-Feb-24	MYSORE	66	LINE	KR PETE-BUKANKERE	BOOKANAKERE_66 CHINAKURALI_66GANJIGERE_66 PANDAVAPURA_66	09:53:00	10:04:19	00:11:19	TRIPPED ON FAULT
1059	7-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220- NAGAMANGALA 1	NO STATIONS EFFECTED	11:25:00	16:50:00	05:25:00	LINE CLEAR AVAILED
1060	7-Feb-24	MYSORE	66	LINE	NAGAMANGALA-TUBINKERE	NAGAMANGALA_66	10:42:25	17:10:00	06:27:35	LINE CLEAR AVAILED
1061	7-Feb-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	13:20:00	14:35:00	01:15:00	TRIPPED ON FAULT
1062	7-Feb-24	MYSORE	220	LINE	TUBINKERE-KOTHIPURA	NO STATIONS EFFECTED	13:20:00	14:40:00	01:20:00	TRIPPED ON FAULT
1063	7-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV- BENKIKERE	BENKIKERE_66	10:23	17:17	06:54	LINE CLEAR AVAILED
1064	7-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, BIDARKERE_66, JAGALUR_66,	23:18	23:25	00:07	TRIPPED ON FAULT
1065	7-Feb-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66	09:48	18:28	08:40	LINE CLEAR AVAILED
1066	7-Feb-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARAEKERE_66	04:37	04:47	00:10	TRIPPED ON FAULT
1067	7-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	09:00	09:05	00:05	LINE CLEAR AVAILED
1068	7-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	09:48	18:00	08:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1069	7-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-(LINGADAHALLI) NALLUR_66	NALLURU_66,	09:48	18:01	08:13	LINE CLEAR AVAILED
1070	7-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	BENKIKERE_66	10:20	17:15	06:55	LINE CLEAR AVAILED
1071	7-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	19:55	20:00	00:04	TRIPPED ON FAULT
1072	7-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	22:15	22:20	00:05	TRIPPED ON FAULT
1073	7-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	22:21	22:25	00:04	TRIPPED ON FAULT
1074	7-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HONNALLI_66	09:50	09:54	00:04	LINE CLEAR AVAILED
1075	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	BENKIKERE_66	10:20	18:05	07:45	LINE CLEAR AVAILED
1076	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GOPPENAHALLI_66	18:00	18:05	00:05	TRIPPED ON FAULT
1077	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GOPPENAHALLI_66	18:20	18:25	00:05	TRIPPED ON FAULT
1078	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GOPPENAHALLI_66	18:55	19:00	00:05	TRIPPED ON FAULT
1079	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GOPPENAHALLI_66	20:20	20:25	00:05	TRIPPED ON FAULT
1080	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GUTTUR_66	16:30	17:25	00:55	TRIPPED ON FAULT
1081	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HANGAL_66	16:21	17:22	01:01	LINE CLEAR AVAILED
1082	7-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HONNALLI_66	09:50	18:10	08:20	LINE CLEAR AVAILED
1083	7-Feb-24	TUMKUR	66	LINE	MADHURE_220- BAGUR_66	BAGURU_66	05:40	06:10	00:30	TRIPPED ON FAULT
1084	7-Feb-24	TUMKUR	66	LINE	MADHURE_220- HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	22:05	22:15	00:10	TRIPPED ON FAULT
1085	7-Feb-24	TUMKUR	66	LINE	MADHURE_220- HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	22:15	22:50	00:35	TRIPPED ON FAULT
1086	7-Feb-24	TUMKUR	66	LINE	OBAJJIHALLI-TELAGI LINE	OBAJJIHALLI_66	18:25	18:38	00:13	TRIPPED ON FAULT
1087	7-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1088	7-Feb-24	TUMKUR	66	LINE	SIRA66 - KALLAMBELLA	KALLAMBELLA_66	07:00	07:10	00:10	TRIPPED ON FAULT
1089	7-Feb-24	TUMKUR	110	TRANSFORMER	HV1(TR1)	NITTUR_110	02:27	15:14	12:47	TRIPPED ON FAULT
1090	7-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	12:07	15:44	03:36	LINE CLEAR AVAILED
1091	7-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- DAVANAGERE 3	DAVANGERE_SRS_220	12:07	15:44	03:37	LINE CLEAR AVAILED
1092	7-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	10:57	21:50	10:53	LINE CLEAR AVAILED
1093	7-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	10:52	21:50	10:58	LINE CLEAR AVAILED
1094	7-Feb-24	TUMKUR	220	LINE	GUTTUR 400kV- NARENDRA-2	NARENDRA -2 LINE	10:45	21:55	11:09	LINE CLEAR AVAILED
1095	7-Feb-24	TUMKUR	220	LINE	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:06	21:46	10:40	LINE CLEAR AVAILED
1096	7-Feb-24	TUMKUR	220	LINE	HONNALLI 220kV- SHIMOGA 220kV	MRSMSG_220	13:38	18:18	04:40	TRIPPED ON FAULT
1097	7-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	HONNALLI_220	09:53	17:56	08:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1098	7-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1099	7-Feb-24	TUMKUR	400	LINE	JAGALUR 400kV-BPS1(BALLARI400kV)	JAGALUR 400kV	11:33	18:06	06:33	LINE CLEAR AVAILED
1100	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BELLATTI_110	17:16	17:55	00:39	LINE CLEAR AVAILED
1101	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	HALKI_110	08:14	08:16	00:02	LINE CLEAR AVAILED
1102	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	NAVALGUND_110	11:21	13:12	01:51	LINE CLEAR AVAILED
1103	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TUMMINKATTI_110	06:55	12:02	05:07	TRIPPED ON FAULT
1104	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	UKKALI_110	11:50	13:53	02:03	LINE CLEAR AVAILED
1105	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KANAGALA_220	11:12	16:40	05:28	LINE CLEAR AVAILED
1106	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	HUDLI_110	11:25	11:31	00:06	LINE CLEAR AVAILED
1107	08-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	RATTIHALLI_110	12:28	12:33	00:05	TRIPPED ON FAULT
1108	08-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1109	08-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
1110	08-Feb-24	BAGALKOTE	110	LINE	GARAG-F2(TURAKARSHEEGEHALLI)	GARAG_110	09:44	17:45	08:01	LINE CLEAR AVAILED
1111	08-Feb-24	BAGALKOTE	110	LINE	HAVERI220-HANGAL(TILUVALLI)	STATION NOT AFFECTED HAVERI_220	16:47	17:18	00:31	LINE CLEAR AVAILED
1112	08-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1113	08-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1114	08-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1115	08-Feb-24	BAGALKOTE	110	LINE	NARENDRA220- SHEDBAL	STATION NOT AFFECTED NARENDRA_220	10:15	17:30	07:15	LINE CLEAR AVAILED
1116	08-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1117	08-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1118	08-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
1119	08-Feb-24	BAGALKOTE	110	LINE	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	18:45	19:08	00:23	TRIPPED ON FAULT
1120	08-Feb-24	BAGALKOTE	110	LINE	RON- HIREHAL	STATION NOT AFFECTED RON_110	10:25 (08.02.2024)			LINE CLEAR AVAILED
1121	08-Feb-24	BAGALKOTE	110	LINE	UKKALI- F2(BAGEWADI220)	UKKALI_110	11:51	13:52	02:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1122	08-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1123	08-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	STATION NOT AFFECTED AEQUS_220	10:32	15:10	04:38	LINE CLEAR AVAILED
1124	08-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	STATION NOT AFFECTED AEQUS_220	15:32	18:25	02:53	LINE CLEAR AVAILED
1125	08-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1126	08-Feb-24	BAGALKOTE	220	LINE	CHIKKODI- KUDACHI1	STATION NOT AFFECTED CHIKKODI_220	10:37	11:57	01:03	LINE CLEAR AVAILED
1127	08-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGHOLKOD1	STATION NOT AFFECTED GHATAPRABHA_220	13:09	21:00	07:51	LINE CLEAR AVAILED
1128	08-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGHOLKOD2	STATION NOT AFFECTED GHATAPRABHA_220	18:39	20:58	02:19	LINE CLEAR AVAILED
1129	08-Feb-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:23	16:08	05:45	LINE CLEAR AVAILED
1130	08-Feb-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	10:28	16:08	05:40	LINE CLEAR AVAILED
1131	08-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	13:12	21:02	07:50	LINE CLEAR AVAILED
1132	08-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA2	STATION NOT AFFECTED MUGALKHOD_220	18:42	21:01	02:19	LINE CLEAR AVAILED
1133	08-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- BELLIGAVI	STATION NOT AFFECTED RANEBENNUR_220	14:17	16:30	02:13	LINE CLEAR AVAILED
1134	08-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	23:30 (08.02.2024)			TRIPPED ON FAULT
1135	08-Feb-24	BAGALKOTE	220	LINE	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	10:19	16:22	06:03	LINE CLEAR AVAILED
1136	08-Feb-24	BAGALKOTE	220	LINE	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	10:20	16:22	06:02	LINE CLEAR AVAILED
1137	08-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:04 (07.02.2024)	10:19 (08.02.2024)	16:15	LINE CLEAR AVAILED
1138	08-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1139	08-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:04 (07.02.2024)	10:20 (08.02.2024)	16:15	LINE CLEAR AVAILED
1140	08-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1141	08-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1142	08-Feb-24	BAGALKOTE	220	LINE	VAJRAMATTI-ENERGON SOLAR	STATION NOT AFFECTED VAJRAMATTI_220	16:32	17:02	00:30	LINE CLEAR AVAILED
1143	08-Feb-24	BENGALURU	66	LINE	66kV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1144	08-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	12:49	12:54	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1145	08-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC2, HUSKUR, TATA POWER SOLAR(EHT), BIOCON(EHT), TECH MAHINDARA(EHT)	05:50	06:25	00:35	TRIPPED ON FAULT
1146	08-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC2, HUSKUR	07:46	07:58	00:12	LINE CLEAR AVAILED
1147	08-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC2, HUSKUR	12:25	12:50	00:25	LINE CLEAR AVAILED
1148	08-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC2, HUSKUR	14:12	14:20	00:08	LINE CLEAR AVAILED
1149	08-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC2, HUSKUR, TATA POWER SOLAR(EHT), BIOCON(EHT), TECH MAHINDARA(EHT)	08:13	08:45	00:32	TRIPPED ON FAULT
1150	08-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	19:15	19:18	00:03	LINE CLEAR AVAILED
1151	08-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD	13:45	14:24	00:39	LINE CLEAR AVAILED
1152	08-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MAASTHI	06:35	06:45	00:10	TRIPPED ON FAULT
1153	08-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KONDASAPURA	12:41	12:46	00:05	LINE CLEAR AVAILED
1154	08-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	23:00	23:10	00:10	TRIPPED ON FAULT
1155	08-Feb-24	BENGALURU	66	TRANSFORMER	HV1	LAKKUR	13:35	13:40	00:05	LINE CLEAR AVAILED
1156	08-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIDADI 220	22:02	22:10	00:08	TRIPPED ON FAULT
1157	08-Feb-24	BENGALURU	66	TRANSFORMER	HV1	JIGANI 66	13:41	13:51	00:10	LINE CLEAR AVAILED
1158	08-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KONDASAPURA	12:41	12:46	00:05	LINE CLEAR AVAILED
1159	08-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BANGARPETE	12:45	12:55	00:10	LINE CLEAR AVAILED
1160	08-Feb-24	BENGALURU	66	TRANSFORMER	HV2	LAKKUR	11:45	11:50	00:05	LINE CLEAR AVAILED
1161	08-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KODIGEHALLI	15:58	16:56	00:58	TRIPPED ON FAULT
1162	08-Feb-24	BENGALURU	66	TRANSFORMER	HV2	JIGANI 66	13:41	13:51	00:10	LINE CLEAR AVAILED
1163	8-Feb-2024	GULBARGA	66	TRANSFORMER	HV1 & HV2	UJJANI_66	09:10	09:50	00:40	MAIN SUPPLY FAILURE
1164	8-Feb-2024	GULBARGA	66	LINE	KUDALAGI-KOTTUR	UJJANI_66	09:10	09:35	00:25	TRIPPED ON FAULT
1165	8-Feb-2024	GULBARGA	66	LINE	KUDALAGI-KOTTUR	UJJANI_66	09:40	10:05	00:25	TRIPPED ON FAULT
1166	8-Feb-2024	GULBARGA	110	LINE	AFZALPUR-KARAJAGI	KARAJAGI_110, CHOWDAPUR_110, SAGNOOR_110	01:07	01:15	00:08	MAIN SUPPLY FAILURE
1167	8-Feb-2024	GULBARGA	110	LINE	AFZALPUR-SHAHABAD	AFZALPUR_110	12:30	12:33	00:03	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1168	8-Feb-2024	GULBARGA	110	LINE	HALBARGA-HALIKHED,HALBARGA	HALIKHED_110,HALBARGA_220	21:09(09.02.2024)			LINE CLEAR AVAILED
1169	8-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	GINIGERA_110	07:35	08:45	01:10	LINE CLEAR AVAILED
1170	8-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	ALIPUR_220	11:12	13:55	02:43	LINE CLEAR AVAILED
1171	8-Feb-2024	GULBARGA	110	LINE	KADECHUR-SAIDAPUR	KADECHUR_110	08:40	12:55	04:15	LINE CLEAR AVAILED
1172	8-Feb-2024	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	08:35	13:00	04:25	LINE CLEAR AVAILED
1173	8-Feb-2024	GULBARGA	110	LINE	LINGASUGUR-GURUGUNTA	GURGUNTA_110	06:50	07:03	00:13	TRIPPED ON FAULT
1174	8-Feb-2024	GULBARGA	110	LINE	MADIYAL-AFZALPUR	AFZALPUR_110	12:30	12:33	00:03	TRIPPED ON FAULT
1175	8-Feb-2024	GULBARGA	110	LINE	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVI AMARESHWAR_110	17:13	17:26	00:13	TRIPPED ON FAULT
1176	8-Feb-2024	GULBARGA	110	LINE	METRI-ALIPUR	METRI_110	08:50	19:35	10:45	LINE CLEAR AVAILED
1177	8-Feb-2024	GULBARGA	110	LINE	TORANGALU-ALIPUR	TORANGALU_110	08:45	08:50	00:05	LINE CLEAR AVAILED
1178	8-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	HALBARGA_220	10:55	13:45	02:50	LINE CLEAR AVAILED
1179	8-Feb-2024	GULBARGA	220	TRANSFORMER	HV2	HALBARGA_220	13:55	16:47	02:52	LINE CLEAR AVAILED
1180	8-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	02:42	02:58	00:16	TRIPPED ON FAULT
1181	08-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	08:20	08:25	00:05	TRIPPED ON FAULT
1182	08-Feb-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	14:35	18:10	03:35	LINE CLEAR AVAILED
1183	08-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALI_66	05:54	05:58	00:04	TRIPPED ON FAULT
1184	08-Feb-24	HASSAN	110	LINE	HGGUNJ-HALADY	HEGGUNJE_220	09:23	10:01	00:38	MAIN SUPPLY FAILURE
1185	08-Feb-24	HASSAN	110	LINE	HGGUNJ-HALADY	HEGGUNJE_220	17:04	17:31	00:27	MAIN SUPPLY FAILURE
1186	08-Feb-24	HASSAN	110	LINE	HGGUNJ-HIRIYADKA	HEGGUNJE_220	09:23	09:52	00:29	MAIN SUPPLY FAILURE
1187	08-Feb-24	HASSAN	110	LINE	HGGUNJ-HIRIYADKA	HEGGUNJE_220	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1188	08-Feb-24	HASSAN	110	LINE	HIRIYA-HGUNJE	HIRIYADKA_110	09:22	09:50	00:28	MAIN SUPPLY FAILURE
1189	08-Feb-24	HASSAN	110	LINE	HIRIYA-HGUNJE	HIRIYADKA_110	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1190	08-Feb-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	09:22	09:50	00:28	MAIN SUPPLY FAILURE
1191	08-Feb-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1192	08-Feb-24	HASSAN	110	LINE	HOSNGD-HGNJE	HOSANGADI_110	09:23	10:01	00:38	MAIN SUPPLY FAILURE
1193	08-Feb-24	HASSAN	110	LINE	HOSNGD-SHIMOGA	HOSANGADI_110	09:23	10:25	01:02	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1194	08-Feb-24	HASSAN	110	LINE	HULICA-HSNGD	HULICAL_110	09:25	10:25	01:00	MAIN SUPPLY FAILURE
1195	08-Feb-24	HASSAN	110	LINE	HULICA-HSNGD	HULICAL_110	17:05	18:10	01:05	MAIN SUPPLY FAILURE
1196	08-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	09:22	09:50	00:28	MAIN SUPPLY FAILURE
1197	08-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1198	08-Feb-24	HASSAN	110	TRANSFORMER	HV1	HULICAL_110	09:25	10:25	01:00	MAIN SUPPLY FAILURE
1199	08-Feb-24	HASSAN	110	TRANSFORMER	HV1	HULICAL_110	17:05	18:10	01:05	MAIN SUPPLY FAILURE
1200	08-Feb-24	HASSAN	110	TRANSFORMER	HV1	MANIPAL_110	10:02	16:40	06:38	LINE CLEAR AVAILED
1201	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	ESSUR_110	12:00	14:01	02:01	LINE CLEAR AVAILED
1202	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	ARASIKERE_220	12:34	13:58	01:24	LINE CLEAR AVAILED
1203	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	HIRIYADKA_110	09:22	09:50	00:28	MAIN SUPPLY FAILURE
1204	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	HIRIYADKA_110	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1205	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	HULICAL_110	09:25	10:25	01:00	MAIN SUPPLY FAILURE
1206	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	HULICAL_110	17:05	18:10	01:05	MAIN SUPPLY FAILURE
1207	08-Feb-24	HASSAN	110	TRANSFORMER	HV2	MANIPAL_110	10:02	16:40	06:38	LINE CLEAR AVAILED
1208	08-Feb-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	09:22	09:50	00:28	MAIN SUPPLY FAILURE
1209	08-Feb-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	17:04	17:26	00:22	MAIN SUPPLY FAILURE
1210	08-Feb-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	10:02	16:40	06:38	LINE CLEAR AVAILED
1211	08-Feb-24	HASSAN	110	LINE	KEMAR-Manipal2	KEMAR_220	10:02	16:40	06:38	LINE CLEAR AVAILED
1212	08-Feb-24	HASSAN	110	LINE	LV1	SHIRALKOPPA_220	16:18	18:52	02:34	LINE CLEAR AVAILED
1213	08-Feb-24	HASSAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	10:02	16:40	06:38	LINE CLEAR AVAILED
1214	08-Feb-24	HASSAN	110	LINE	MANIPAL-KEMAR1	MANIPAL_110	10:05	16:40	06:35	LINE CLEAR AVAILED
1215	08-Feb-24	HASSAN	110	LINE	MANIPAL-KEMAR2	MANIPAL_110	10:05	16:40	06:35	LINE CLEAR AVAILED
1216	08-Feb-24	HASSAN	220	TRANSFORMER	HV1	HEGGUNJE_220	09:23	10:00	00:37	TRIPPED ON FAULT
1217	08-Feb-24	HASSAN	220	TRANSFORMER	HV1	HEGGUNJE_220	17:04	17:30	00:26	TRIPPED ON FAULT
1218	08-Feb-24	HASSAN	220	TRANSFORMER	HV1	SHIRALKOPPA_220	16:18	18:52	02:34	LINE CLEAR AVAILED
1219	08-Feb-24	HASSAN	220	TRANSFORMER	HV2	HEGGUNJE_220	09:23	10:00	00:37	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1220	08-Feb-24	HASSAN	220	TRANSFORMER	HV2	HEGGUNJE_220	17:04	17:30	00:26	TRIPPED ON FAULT
1221	8-Feb-24	MYSORE	66	LINE	AJJIPURA-COWDALLI	COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	14:45	16:50	02:05	LINE CLEAR AVAILED
1222	8-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1223	8-Feb-24	MYSORE	66	LINE	CHUNCHUNKATTE- RAVANDURU	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66	10:15	16:36	06:21	LINE CLEAR AVAILED
1224	8-Feb-24	MYSORE	66	LINE	COWDALLI-MARTALLI	MARTAHALLI_66 RAMAPURA_MYS_66	09:59	20:45	10:45	LINE CLEAR AVAILED
1225	8-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	09:57	16:21	06:23	LINE CLEAR AVAILED
1226	8-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	17:37			LINE CLEAR AVAILED
1227	8-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1228	8-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1229	8-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1230	8-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1231	8-Feb-24	MYSORE	66	LINE	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	22:35	22:45	00:10	TRIPPED ON FAULT
1232	8-Feb-24	MYSORE	66	LINE	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	22:35	22:45	00:10	TRIPPED ON FAULT
1233	8-Feb-24	MYSORE	66	TRANSFORMER	HV1	AJJIPURA_66	10:55	16:00	05:05	LINE CLEAR AVAILED
1234	8-Feb-24	MYSORE	66	TRANSFORMER	HV1	COWDALLI_66	10:00	16:50	06:50	LINE CLEAR AVAILED
1235	8-Feb-24	MYSORE	66	TRANSFORMER	HV1	KRPET_220	13:40	16:05	02:25	LINE CLEAR AVAILED
1236	8-Feb-24	MYSORE	66	TRANSFORMER	HV1	PGPALYA_66	12:00	13:50	01:50	LINE CLEAR AVAILED
1237	8-Feb-24	MYSORE	66	TRANSFORMER	HV1	RAVANDUR_66	10:03	17:30	07:27	LINE CLEAR AVAILED
1238	8-Feb-24	MYSORE	66	TRANSFORMER	HV2	COWDALLI_66	10:00	16:50	06:50	LINE CLEAR AVAILED
1239	8-Feb-24	MYSORE	66	TRANSFORMER	HV2	KRPET_220	10:10	13:35	03:25	LINE CLEAR AVAILED
1240	8-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	09:59	19:35	09:35	LINE CLEAR AVAILED
1241	8-Feb-24	MYSORE	66	TRANSFORMER	HV2	RAVANDUR_66	10:03	17:30	07:27	LINE CLEAR AVAILED
1242	8-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
1243	8-Feb-24	MYSORE	66	LINE	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	18:36	18:43	00:07	TRIPPED ON FAULT
1244	8-Feb-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	NO STATIONS EFFECTED	12:00	12:48	00:47	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1245	8-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 1	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	14:33	16:02	01:28	LINE CLEAR AVAILED
1246	8-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	14:33	16:02	01:28	LINE CLEAR AVAILED
1247	8-Feb-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	10:03	17:32	07:29	LINE CLEAR AVAILED
1248	8-Feb-24	MYSORE	66	LINE	RAVANDURU-KITTUR	KITTUR_66	10:03	17:30	07:27	LINE CLEAR AVAILED
1249	8-Feb-24	MYSORE	66	LINE	SATHEGALA-BPCL	NO STATIONS EFFECTED	10:55	11:18	00:23	LINE CLEAR AVAILED
1250	8-Feb-24	MYSORE	220	TRANSFORMER	HV2	KRPET_220	17:05	18:44	01:39	LINE CLEAR AVAILED
1251	8-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, NANDHIHALLI_66, HAGALVADI_66	20:04	20:40	00:36	TRIPPED ON FAULT
1252	8-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV- DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	06:07	06:15	00:07	TRIPPED ON FAULT
1253	8-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:51	12:03	00:12	LINE CLEAR AVAILED
1254	8-Feb-24	TUMKUR	66	LINE	GUTTUR220-DITTUR LINE	DITTUR_66 , KNNL HALASABALU_66	06:25	06:43	00:18	TRIPPED ON FAULT
1255	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	02:30	02:35	00:05	TRIPPED ON FAULT
1256	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	02:50	02:55	00:05	TRIPPED ON FAULT
1257	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	04:40	04:45	00:05	TRIPPED ON FAULT
1258	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	12:30	16:45	04:15	LINE CLEAR AVAILED
1259	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HOLALKERE_66	14:20	15:00	00:40	LINE CLEAR AVAILED
1260	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	SAVLANGA_66	10:46	15:42	04:56	LINE CLEAR AVAILED
1261	8-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	TAVAREKERE_66	15:04	15:15	00:10	TRIPPED ON FAULT
1262	8-Feb-24	TUMKUR	66	LINE	MADHURE_220- HALURAMESWARA_66 LINE 1	HALURAMESWARA_66, MADADKERE_66	00:45	01:05	00:20	TRIPPED ON FAULT
1263	8-Feb-24	TUMKUR	66	LINE	PAVAGADA- (GOWRIBIDANUR)VENKATAP URA	VENKATAPURA_66(GOWRIBIDANU R_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1264	8-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- RANEBENNUR220	RANEBENNUR_220	23:30(8.2.240)			TRIPPED ON FAULT
1265	8-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1266	8-Feb-24	TUMKUR	400	LINE	GUTTUR 400kV- NARENDRA-2	NARENDRA -2 LINE	08:19	19:30	11:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1267	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED BELLATTI_110	11:10	13:26	02:16	LINE CLEAR AVAILED
1268	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED SULTANPUR_110	12:15	12:54	00:39	LINE CLEAR AVAILED
1269	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (10MVA)	STATION NOT AFFECTED GAJENDRAGAD_110	13:50	14:06	00:16	LINE CLEAR AVAILED
1270	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	YADWAD_110	17:25	17:47	00:22	LINE CLEAR AVAILED
1271	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UCHAGOAN_110	17:12	18:00	00:48	LINE CLEAR AVAILED
1272	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TOLAMATTI_110	09:40	10:48	01:08	LINE CLEAR AVAILED
1273	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED KIRUVATTI_110	13:30	15:28	01:58	LINE CLEAR AVAILED
1274	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED KIRUVATTI_110	16:40	18:25	01:45	LINE CLEAR AVAILED
1275	09-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED GOPANAKOPPA_110	12:50	12:56	00:06	LINE CLEAR AVAILED
1276	09-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	KUDACHI_220	17:42	18:22	00:40	LINE CLEAR AVAILED
1277	09-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1278	09-Feb-24	BAGALKOTE	110	LINE	BELUR-NARENDRA1	STATION NOT AFFECTED BELUR_110	15:16	15:54	00:38	LINE CLEAR AVAILED
1279	09-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
1280	09-Feb-24	BAGALKOTE	110	LINE	HAVERI220-HANGAL(TILUVALLI)	HAVERI_220	07:06	07:31	00:25	LINE CLEAR AVAILED
1281	09-Feb-24	BAGALKOTE	110	LINE	HIREBEVANUR-INDI (ROODAGI)	STATION NOT AFFECTED ROODAGI_110	05:37	05:42	00:05	TRIPPED ON FAULT
1282	09-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1283	09-Feb-24	BAGALKOTE	110	LINE	LAXMESHWAR-SHIRAHATTI	STATION NOT AFFECTED LAXMESHWAR_110	15:10	17:16	02:06	LINE CLEAR AVAILED
1284	09-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1285	09-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1286	09-Feb-24	BAGALKOTE	110	LINE	NARENDRA220- BELUR1	NARENDRA_220	15:16	15:44	00:28	LINE CLEAR AVAILED
1287	09-Feb-24	BAGALKOTE	110	LINE	NARENDRA220- BELUR2	NARENDRA_220	09:05	15:15	06:10	LINE CLEAR AVAILED
1288	09-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1289	09-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1290	09-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1291	09-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220-RATTIHALLI (TUMMINKATTI)	RANEBENNUR_220	12:59	14:38	01:39	LINE CLEAR AVAILED
1292	09-Feb-24	BAGALKOTE	110	LINE	RON- HIREHAL	STATION NOT AFFECTED RON_110	10:25 (08.02.2024)	14:15 (09.02.2024)	27:50:00	LINE CLEAR AVAILED
1293	09-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1294	09-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KUDACHI_220	17:42	18:18	00:36	LINE CLEAR AVAILED
1295	09-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KUDACHI_220	18:24	19:25	01:01	LINE CLEAR AVAILED
1296	09-Feb-24	BAGALKOTE	220	LINE	ATHANI- KUDACHI	ATHANI_220	15:27	20:42	05:15	LINE CLEAR AVAILED
1297	09-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1298	09-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	10:47	13:19	02:32	LINE CLEAR AVAILED
1299	09-Feb-24	BAGALKOTE	220	LINE	INDI- SAVALASANGA	INDI_220	18:41	18:54	00:13	TRIPPED ON FAULT
1300	09-Feb-24	BAGALKOTE	220	LINE	KUDACHI- MAHALINGAPUR	KUDACHI_220	15:45	20:39	04:54	LINE CLEAR AVAILED
1301	09-Feb-24	BAGALKOTE	220	LINE	KUDACHI-ATHANI	KUDACHI_220	15:27	20:42	05:15	LINE CLEAR AVAILED
1302	09-Feb-24	BAGALKOTE	220	LINE	KUDACHI-CHIKKODI1(RVNL)	KUDACHI_220	16:00	20:38	04:38	LINE CLEAR AVAILED
1303	09-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	23:30 (08.02.2024)	9:39 (09.02.2024)	10:09	TRIPPED ON FAULT
1304	09-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	12:57	14:34	01:37	LINE CLEAR AVAILED
1305	09-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1306	09-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1307	09-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1308	09-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	AREHALLI	16:43	16:47	00:04	LINE CLEAR AVAILED
1309	09-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1310	09-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, VANDARAGUPPE, SHIVANAHALLI, ADANI SOLAR IPP, KANVA(EHT)	06:30	06:43	00:13	TRIPPED ON FAULT
1311	09-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	TADIGOL CROSS	08:00	10:53	02:53	LINE CLEAR AVAILED
1312	09-Feb-24	BENGALURU	66	LINE	66KV D PALYA - GUDIBANDE - MANDIKAL	GUDIBANDE, MANDIKAL	10:30	10:40	00:10	LINE CLEAR AVAILED
1313	09-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	06:30	23:59	17:29	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1314	09-Feb-24	BENGALURU	66	LINE	66KV DIBBURHALLI - SADLI - SOMENAHALLI - PERESANDRA	PERESANDRA	13:25	13:35	00:10	TRIPPED ON FAULT
1315	09-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGEHALLI	22:10	22:20	00:10	TRIPPED ON FAULT
1316	09-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	22:20	23:03	00:43	TRIPPED ON FAULT
1317	09-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	BAGMANE WTC	12:04	12:09	00:05	LINE CLEAR AVAILED
1318	09-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	BAGMANE WTC	19:25	19:30	00:05	LINE CLEAR AVAILED
1319	09-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	22:03	22:09	00:06	LINE CLEAR AVAILED
1320	09-Feb-24	BENGALURU	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	11:00	14:57	03:57	LINE CLEAR AVAILED
1321	09-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	18:13	18:23	00:10	MAIN SUPPLY FAILURE
1322	09-Feb-24	BENGALURU	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA	22:57	23:01	00:04	TRIPPED ON FAULT
1323	09-Feb-24	BENGALURU	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI	18:15	18:32	00:17	MAIN SUPPLY FAILURE
1324	09-Feb-24	BENGALURU	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	18:15	18:27	00:12	MAIN SUPPLY FAILURE
1325	09-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - IISC	IISc	20:32	23:20	02:48	TRIPPED ON FAULT
1326	09-Feb-24	BENGALURU	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASWADI	18:01	18:15	00:14	TRIPPED ON FAULT
1327	09-Feb-24	BENGALURU	66	LINE	66KV SARAKKI - JAYADEVA 1 & 2	SARAKKI	22:35	22:40	00:05	LINE CLEAR AVAILED
1328	09-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL, GOWNIPALLI, RAYALPADU, SOLAR(IPP)	08:00	10:53	02:53	LINE CLEAR AVAILED
1329	09-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	10:35	10:40	00:05	LINE CLEAR AVAILED
1330	09-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIJAYANAGARA	22:03	22:09	00:06	LINE CLEAR AVAILED
1331	09-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NANDINI LAYOUT	12:14	12:16	00:02	LINE CLEAR AVAILED
1332	09-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NAGANATHPURA 220	09:53	10:05	00:12	LINE CLEAR AVAILED
1333	09-Feb-24	BENGALURU	66	TRANSFORMER	HV1	CHANDRAPPA CIRCLE	14:45	14:50	00:05	TRIPPED ON FAULT
1334	09-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HULLENAHALLI	12:40	12:45	00:05	TRIPPED ON FAULT
1335	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIJAYANAGARA	22:03	22:09	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1336	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	NAGANATHPURA 220	11:23	11:26	00:03	LINE CLEAR AVAILED
1337	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	NAGANATHPURA 220	17:18	17:28	00:10	LINE CLEAR AVAILED
1338	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	D CROSS	14:41	14:46	00:05	TRIPPED ON FAULT
1339	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MANCHENAHALLI	15:40	15:45	00:05	TRIPPED ON FAULT
1340	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MANCHENAHALLI	15:50	16:40	00:50	TRIPPED ON FAULT
1341	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KOLAR 220	11:55	11:58	00:03	LINE CLEAR AVAILED
1342	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VOKKALERI	10:30	10:35	00:05	TRIPPED ON FAULT
1343	09-Feb-24	BENGALURU	66	TRANSFORMER	HV2	LAKKUR	12:00	13:05	01:05	LINE CLEAR AVAILED
1344	09-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAWADI, MADDUR, KIADB SOMANAHALLI	12:42	12:47	00:05	TRIPPED ON FAULT
1345	09-Feb-24	BENGALURU	220	LINE	220KV CHINTAMANI - SRINIVASPURA 2	NO STATION AFFECTED	09:30	10:43	01:13	TRIPPED ON FAULT
1346	09-Feb-24	BENGALURU	220	TRANSFORMER	HV1	NIMHANS 220	18:15	18:29	00:14	TRIPPED ON FAULT
1347	09-Feb-24	BENGALURU	220	TRANSFORMER	HV1	NIMHANS 220	18:40	21:52	03:12	LINE CLEAR AVAILED
1348	09-Feb-24	BENGALURU	220	TRANSFORMER	HV2	NIMHANS 220	18:15	18:29	00:14	TRIPPED ON FAULT
1349	09-Feb-24	BENGALURU	220	TRANSFORMER	HV2	NIMHANS 220	18:40	21:52	03:12	LINE CLEAR AVAILED
1350	09-Feb-24	BENGALURU	220	TRANSFORMER	HV2	SRINIVASAPURA 220	09:30	10:55	01:25	LINE CLEAR AVAILED
1351	9-Feb-2024	GULBARGA	110	LINE	GANADAL-NAVALI	NAVALI_110	22:10	22:35	00:25	TRIPPED ON FAULT
1352	9-Feb-2024	GULBARGA	110	LINE	GANAGAVATI-SULEKAL	GANGAVATHI_110	03:25	03:36	00:11	TRIPPED ON FAULT
1353	9-Feb-2024	GULBARGA	110	LINE	HATTIGUDUR-RAICHUR-2	HATTIGUDUR_220	09:45	11:22	01:37	LINE CLEAR AVAILED
1354	9-Feb-2024	GULBARGA	110	LINE	HATTIGUDUR-SHAHPUR-2	HATTIGUDUR_220	06:22	09:30	03:08	LOAD CURTAILMENT
1355	9-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	VENKATGIRI_110	03:25	03:35	00:10	MAIN SUPPLY FAILURE
1356	9-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	SOMASAMUDRA_110	17:00	17:15	00:15	TRIPPED ON FAULT
1357	9-Feb-2024	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	22:15	22:35	00:20	TRIPPED ON FAULT
1358	9-Feb-2024	GULBARGA	110	LINE	MALLAT-SIRWAR	SIRWAR_110	01:49	01:59	00:10	TRIPPED ON FAULT
1359	09-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	23:00	23:27	00:27	TRIPPED ON FAULT
1360	09-Feb-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	13:11	14:35	01:24	LINE CLEAR AVAILED
1361	09-Feb-24	HASSAN	110	LINE	BLGMBA-AFT	BELAGMBA_110	06:10	06:20	00:10	MAIN SUPPLY FAILURE
1362	9-Feb-24	MYSORE	66	LINE	BANNIMANTAPA-FTS 2	FTS_66DEVANOORMYS_66RAJEE VNAGARA_66	07:11	13:32	06:21	TRIPPED ON FAULT
1363	9-Feb-24	MYSORE	66	LINE	BANNIMANTAPA-FTS1	NO STATIONS EFFECTED	07:25	16:59	09:34	LINE CLEAR AVAILED
1364	9-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1365	9-Feb-24	MYSORE	66	LINE	BANNUR-VAJMANGALA	NO STATIONS EFFECTED	07:59	17:30	09:30	LINE CLEAR AVAILED
1366	9-Feb-24	MYSORE	66	LINE	CHIKAMANDYA-HAMPAPURA	HAMPAPURA_66	11:50	14:20	02:29	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1367	9-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	17:37	7:25 (9/02/2024)	13:47	LINE CLEAR AVAILED
1368	9-Feb-24	MYSORE	66	LINE	FTS-JYOTHINAGAR	FTS_66	12:10	13:35	01:25	LINE CLEAR AVAILED
1369	9-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1370	9-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1371	9-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1372	9-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1373	9-Feb-24	MYSORE	66	LINE	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	01:55	02:00	00:05	TRIPPED ON FAULT
1374	9-Feb-24	MYSORE	66	LINE	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	02:57	03:11	00:14	TRIPPED ON FAULT
1375	9-Feb-24	MYSORE	66	LINE	HUNSUR-THAMDALLY 1	NO STATIONS EFFECTED	01:55	02:00	00:05	TRIPPED ON FAULT
1376	9-Feb-24	MYSORE	66	LINE	HUNSUR-THAMDALLY 1	NO STATIONS EFFECTED	02:57	03:11	00:14	TRIPPED ON FAULT
1377	9-Feb-24	MYSORE	66	TRANSFORMER	HV1	CHANDAKAWADI_66	11:35	12:00	00:25	LINE CLEAR AVAILED
1378	9-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	10:01	18:20	08:18	LINE CLEAR AVAILED
1379	9-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	19:06	19:13	00:07	LINE CLEAR AVAILED
1380	9-Feb-24	MYSORE	66	TRANSFORMER	HV2	KRPETE_66	11:24	12:36	01:11	LINE CLEAR AVAILED
1381	9-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)			LINE CLEAR AVAILED
1382	9-Feb-24	MYSORE	66	LINE	KMDODD-MANDYA	KOLKARANADODDI_66	12:33	15:08	02:34	LINE CLEAR AVAILED
1383	9-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	06:41	06:46	00:05	TRIPPED ON FAULT
1384	9-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	13:05	17:00	03:55	LINE CLEAR AVAILED
1385	9-Feb-24	MYSORE	66	TRANSFORMER	TALAGAWADI-HV1	THALAGAWADI_66 SOMANAHALLI_66 MADDUR_66	12:40	12:45	00:05	LINE CLEAR AVAILED
1386	9-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	16:14	16:25	00:11	TRIPPED ON FAULT
1387	9-Feb-24	MYSORE	220	LINE	CRNAGAR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	15:18	18:15	02:56	LINE CLEAR AVAILED
1388	9-Feb-24	MYSORE	220	TRANSFORMER	HV1	MADHUVANAHALLI_220	13:41	14:25	00:44	LINE CLEAR AVAILED
1389	9-Feb-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 220	NO STATIONS EFFECTED	16:20	16:36	00:16	TRIPPED ON FAULT
1390	9-Feb-24	TUMKUR	66	LINE	CHITRADURGA 66kV-PANDARAHALLI 1	PANDARAHALLI_66	10:13	10:26	00:13	TRIPPED ON FAULT
1391	9-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	12:04	14:37	02:33	LINE CLEAR AVAILED
1392	9-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-(LINGADAHALLI) NALLUR_66	NALLURU_66,	05:47	05:57	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1393	9-Feb-24	TUMKUR	66	LINE	NYAMATHI-HONNALLI-220	NYAMATHI_66	11:40	15:45	04:05	TRIPPED ON FAULT
1394	9-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1395	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHANNAGIRI_66	12:20	12:25	00:05	TRIPPED ON FAULT
1396	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	PATANAYAKANAHALLI_66	15:40	15:50	00:10	TRIPPED ON FAULT
1397	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	TMTP	15:22	18:38	03:16	TRIPPED ON FAULT
1398	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHANNAGIRI_66	04:25	04:35	00:10	TRIPPED ON FAULT
1399	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	GOPPENAHALLI-66	00:05	00:10	00:05	TRIPPED ON FAULT
1400	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	GOPPENAHALLI-66	18:50	18:55	00:05	TRIPPED ON FAULT
1401	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	15:25	18:30	03:05	TRIPPED ON FAULT
1402	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	15:30	15:40	00:10	TRIPPED ON FAULT
1403	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	08:25	08:30	00:05	TRIPPED ON FAULT
1404	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	18:45	18:50	00:05	TRIPPED ON FAULT
1405	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	PATANAYAKANAHALLI_66	16:10	16:50	00:40	TRIPPED ON FAULT
1406	9-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	TMTP	15:45	15:50	00:05	TRIPPED ON FAULT
1407	9-Feb-24	TUMKUR	220	LINE	ANCHEPALYA 220kV-NELMANGALA 1(NAGAMANGALA 1)	ANCHEPALYA_220	16:19	16:35	00:20	TRIPPED ON FAULT
1408	9-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	14:52	20:18	05:26	LINE CLEAR AVAILED
1409	9-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV-RANEBENNUR220	RANEBENNUR_220	11:30:40 PM (8.2.2024)	14:34(09.02.2024)	1 DAY 3HRS 4MIN	TRIPPED ON FAULT
1410	9-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1411	9-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1412	9-Feb-24	TUMKUR	400	LINE	GUTTUR 400kV- NARENDRA-2	GUTUR_400	08:11	19:04	00:10	LINE CLEAR AVAILED
1413	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED GOPANAKOPPA_110	18:41	23:23	04:42	TRIPPED ON FAULT
1414	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	STATION NOT AFFECTED SADALAGA_110	05:06	18:29	13:23	LINE CLEAR AVAILED
1415	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TUMMINKATTE_110	10:30	10:52	00:22	LINE CLEAR AVAILED
1416	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (10MVA)	STATION NOT AFFECTED NAGANUR_110	13:25	13:48	00:23	LINE CLEAR AVAILED
1417	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	STATION NOT AFFECTED MUDHOL_110	15:06	15:12	00:06	TRIPPED ON FAULT
1418	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HANAGAL_110	10:11	10:20	00:09	TRIPPED ON FAULT
1419	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HANAGAL_110	18:17	18:28	00:11	TRIPPED ON FAULT
1420	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HANAGAL_110	19:57	20:00	00:03	TRIPPED ON FAULT
1421	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HUNAGUND_110	18:37	18:44	00:07	TRIPPED ON FAULT
1422	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED RATTIHALLI_110	00:07	00:13	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1423	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED RATTIHALLI_110	00:33	00:50	00:17	TRIPPED ON FAULT
1424	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED HANAGAL_110	10:11	10:20	00:09	TRIPPED ON FAULT
1425	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED HANAGAL_110	18:17	18:28	00:11	TRIPPED ON FAULT
1426	10-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED HANAGAL_110	19:57	20:00	00:03	TRIPPED ON FAULT
1427	10-Feb-24	BAGALKOTE	110	LINE	AEQUS220-DADDI	STATION NOT AFFECTED AEQUS_110	10:51	11:03	00:12	TRIPPED ON FAULT
1428	10-Feb-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA(L2)	STATION NOT AFFECTED ANKOLA_110	18:37 (10.02.2024)			TRIPPED ON FAULT
1429	10-Feb-24	BAGALKOTE	110	LINE	ANNIGERI-GADAG	STATION NOT AFFECTED ANNIGERI_110	09:00	09:11	00:11	LINE CLEAR AVAILED
1430	10-Feb-24	BAGALKOTE	110	LINE	ATHANI220- GHATANATTI	ATHANI_220	20:35	20:46	00:11	TRIPPED ON FAULT
1431	10-Feb-24	BAGALKOTE	110	LINE	ATHANI220- GHATANATTI	ATHANI_220	23:28	23:36	00:08	TRIPPED ON FAULT
1432	10-Feb-24	BAGALKOTE	110	LINE	ATHANI220- KARIMASUTI	ATHANI_220	11:11	13:34	02:23	LINE CLEAR AVAILED
1433	10-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1434	10-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- NIPPANI(KHADAKALAT)	CHIKKODI_220	4:13	4:25	00:12	TRIPPED ON FAULT
1435	10-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
1436	10-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	02:25	02:34	00:09	TRIPPED ON FAULT
1437	10-Feb-24	BAGALKOTE	110	LINE	HAVERI220- HANGAL(TILUVALLI)	HAVERI_220	15:21	15:41	00:20	LINE CLEAR AVAILED
1438	10-Feb-24	BAGALKOTE	110	LINE	HAVERI220- TILUVALLI(HANGAL)	HAVERI_220	6:57	7:14	00:17	TRIPPED ON FAULT
1439	10-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1440	10-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1441	10-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1442	10-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1443	10-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1444	10-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
1445	10-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	5:42	5:50	00:08	TRIPPED ON FAULT
1446	10-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	5:55	8:48	02:53	TRIPPED ON FAULT
1447	10-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1448	10-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1449	10-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	23:30 (08.02.2024)	9:39 (09.02.2024)	10:09	TRIPPED ON FAULT
1450	10-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1451	10-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1452	10-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1453	10-Feb-24	BAGALKOTE	220	LINE	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	20:19 (10.02.2024)			LINE CLEAR AVAILED
1454	10-Feb-24	BAGALKOTE	400	LINE	DONI-GUTTUR	STATION NOT AFFECTED DONI_400	9:58	15:54	05:56	LINE CLEAR AVAILED
1455	10-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - C STATION	C STATION	13:06	13:09	00:03	LINE CLEAR AVAILED
1456	10-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1457	10-Feb-24	BENGALURU	66	LINE	66KV BTM 4TH PHASE - SOUTH CITY	SAUDELA, ANNABEL(DLF)	12:04	13:43	01:39	LINE CLEAR AVAILED
1458	10-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	06:28	06:50	00:22	TRIPPED ON FAULT
1459	10-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 2	NO STATION AFFECTED	06:28	06:38	00:10	TRIPPED ON FAULT
1460	10-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1461	10-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	NO STATION AFFECTED	12:20	14:45	02:25	TRIPPED ON FAULT
1462	10-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	08:50	12:44	03:54	LINE CLEAR AVAILED
1463	10-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	13:38	13:48	00:10	TRIPPED ON FAULT
1464	10-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - AMARJYOTHI 1 - LEELAVENTURE (TAP)	AMARJYOTHI(HV1)	13:40	13:42	00:02	LINE CLEAR AVAILED
1465	10-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGMANE TECH PARK	07:43	07:45	00:02	LINE CLEAR AVAILED
1466	10-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - ISRO EHT	ISRO(EHT)	09:10	12:32	03:22	LINE CLEAR AVAILED
1467	10-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	09:59	10:03	00:04	LINE CLEAR AVAILED
1468	10-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	09:59	10:03	00:04	LINE CLEAR AVAILED
1469	10-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - IISC	IISc	06:45	06:55	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1470	10-Feb-24	BENGALURU	66	LINE	66KV ITI 220 - POTTERY ROAD MUSS	POTTERY ROAD	13:03	14:10	01:07	TRIPPED ON FAULT
1471	10-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	18:37	18:47	00:10	TRIPPED ON FAULT
1472	10-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	08:37	08:53	00:16	LINE CLEAR AVAILED
1473	10-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	20:55	20:57	00:02	LINE CLEAR AVAILED
1474	10-Feb-24	BENGALURU	66	LINE	66KV RBI - ELITA PROMENADE	ELITA PROMENENDE	22:30	22:33	00:03	LINE CLEAR AVAILED
1475	10-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI	22:36	22:39	00:03	LINE CLEAR AVAILED
1476	10-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL, GOWNIPALLI, RAYALPADU, SOLAR(IPP)	09:15	09:20	00:05	LINE CLEAR AVAILED
1477	10-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	BYADRAHALLI, KODIGEHALI, SRIGANDA KAVALU	22:58	23:05	00:07	LINE CLEAR AVAILED
1478	10-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	06:50	06:54	00:04	LINE CLEAR AVAILED
1479	10-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HAL 220	08:04	08:08	00:04	LINE CLEAR AVAILED
1480	10-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KONDASAPURA	09:33	09:36	00:03	LINE CLEAR AVAILED
1481	10-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KENGERI SATELLITE TOWN	12:02	12:06	00:04	LINE CLEAR AVAILED
1482	10-Feb-24	BENGALURU	66	TRANSFORMER	HV2	NANDINI LAYOUT	10:22	10:24	00:02	LINE CLEAR AVAILED
1483	10-Feb-24	BENGALURU	220	LINE	220kV HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	10:02	10:25	00:23	TRIPPED ON FAULT
1484	10-Feb-24	BENGALURU	220	LINE	220kV HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	10:02	11:42	01:40	TRIPPED ON FAULT
1485	10-Feb-2024	GULBARGA	110	LINE	AFZALPUR-CHOWDAPUR	AFZALPUR_110	13:56	14:10	00:14	TRIPPED ON FAULT
1486	10-Feb-2024	GULBARGA	110	LINE	AFZALPUR-CHOWDAPUR	AFZALPUR_110	14:16	14:21	00:05	MAIN SUPPLY FAILURE
1487	10-Feb-2024	GULBARGA	110	LINE	AFZALPUR-CHOWDAPUR	AFZALPUR_110	14:54	14:59	00:05	MAIN SUPPLY FAILURE
1488	10-Feb-2024	GULBARGA	110	LINE	KAPANOOR-MAHAGOAN	MAHAGOAN_110	10:12	13:53	03:41	LINE CLEAR AVAILED
1489	10-Feb-2024	GULBARGA	110	LINE	MALLAT-MADALAPUR	MADALAPUR_110	02:26	02:32	00:06	TRIPPED ON FAULT
1490	10-Feb-24	HASSAN	66	TRANSFORMER	HV1	ALDUR_66	21:45	22:01	00:16	TRIPPED ON FAULT
1491	10-Feb-24	HASSAN	110	TRANSFORMER	HV2	KARKLA_110	09:19	09:26	00:07	TRIPPED ON FAULT
1492	10-Feb-24	HASSAN	110	LINE	JOG110-MGHE	JOG110	16:20	17:10	00:50	TRIPPED ON FAULT
1493	10-Feb-24	HASSAN	110	LINE	JOG-JLT3	JOG	16:19	17:35	01:16	TRIPPED ON FAULT
1494	10-Feb-24	HASSAN	110	LINE	LPH-MGHE 1	lpg_gen	16:19	16:55	00:36	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1495	10-Feb-24	HASSAN	110	LINE	SHIRAL-SHKARPURA	SHIRALKOPA_110	15:59	17:20	01:21	LINE CLEAR AVAILED
1496	10-Feb-24	HASSAN	220	LINE	HASSAN4-SHIMOGA1	HASSAN_400	14:02	15:21	01:19	TRIPPED ON FAULT
1497	10-Feb-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMSG_220	14:02	15:21	01:19	TRIPPED ON FAULT
1498	10-Feb-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	14:02	15:21	01:19	TRIPPED ON FAULT
1499	10-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1500	10-Feb-24	MYSORE	66	LINE	COWDALLI-MARTHALLI	RAMAPURA_66MARATHALLI_66	10:17	13:00	02:42	LINE CLEAR AVAILED
1501	10-Feb-24	MYSORE	66	LINE	COWDALLI-MARTHALLI	RAMAPURA_66MARATHALLI_66	17:10	18:00	00:50	LINE CLEAR AVAILED
1502	10-Feb-24	MYSORE	66	LINE	CRNAGAR-DR PETE 1	NO STATIONS EFFECTED	09:00	18:01	09:01	LINE CLEAR AVAILED
1503	10-Feb-24	MYSORE	66	LINE	CRNAGAR-DR PETE 2	NO STATIONS EFFECTED	09:00	18:01	09:01	LINE CLEAR AVAILED
1504	10-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1505	10-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1506	10-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1507	10-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1508	10-Feb-24	MYSORE	66	TRANSFORMER	HV1	BGNAGARA_66	10:18	17:53	07:34	LINE CLEAR AVAILED
1509	10-Feb-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	16:40	16:50	00:10	TRIPPED ON FAULT
1510	10-Feb-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_220	10:10	13:42	03:32	LINE CLEAR AVAILED
1511	10-Feb-24	MYSORE	66	TRANSFORMER	HV1	TUBINKERE_66	09:33	12:10	02:37	LINE CLEAR AVAILED
1512	10-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBANI_66	19:17	21:58	02:41	TRIPPED ON FAULT
1513	10-Feb-24	MYSORE	66	TRANSFORMER	HV2	BETTADAPURA_66	19:57	20:29	00:32	TRIPPED ON FAULT
1514	10-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGNAGARA_66	10:18	17:51	07:32	LINE CLEAR AVAILED
1515	10-Feb-24	MYSORE	66	TRANSFORMER	HV2	TUBINKERE_66	09:33	15:19	05:46	LINE CLEAR AVAILED
1516	10-Feb-24	MYSORE	66	TRANSFORMER	HV3	KUSHALNAGARA_66	15:50	15:55	00:05	TRIPPED ON FAULT
1517	10-Feb-24	MYSORE	66	TRANSFORMER	HV3	TUBINKERE_66	09:33	12:10	02:37	LINE CLEAR AVAILED
1518	10-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:30 (31/01/2024)	7:38:00 (10/2/2024)	228:07:04	LINE CLEAR AVAILED
1519	10-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	15:13 (10/02/2024)			LINE CLEAR AVAILED
1520	10-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	06:14	06:19	00:05	TRIPPED ON FAULT
1521	10-Feb-24	MYSORE	66	LINE	MANDYA-KK HALLI	NO STATIONS EFFECTED	10:11	14:30	04:18	LINE CLEAR AVAILED
1522	10-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	14:23	17:00	02:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1523	10-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-BG NAGARA	BGNAGARA_66ADICHUNCHANAGIRI_66VADERALLI_66KADABALLY_66	16:21	17:43	01:22	LINE CLEAR AVAILED
1524	10-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-HARADANAHLI	HARADANAHLI(JAK)_66	10:53	12:27	01:34	LINE CLEAR AVAILED
1525	10-Feb-24	MYSORE	220	TRANSFORMER	HV1	NAGAMANGALA _220	10:04	12:33	02:29	LINE CLEAR AVAILED
1526	10-Feb-24	MYSORE	220	TRANSFORMER	HV2	NAGAMANGALA _220	12:35	15:05	02:30	LINE CLEAR AVAILED
1527	10-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	04:25	04:55	00:30	MAIN SUPPLY FAILURE
1528	10-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	04:56	05:30	00:34	MAIN SUPPLY FAILURE
1529	10-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV- KUNDUR66	KUNDUR,_66,MALEBENNUR_66,DEVARABELKERE_66	13:58	14:08	00:10	TRIPPED ON FAULT
1530	10-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1531	10-Feb-24	TUMKUR	66	LINE	SOKKE-UJJINI_66	SOKKE_66	04:25	04:55	00:30	MAIN SUPPLY FAILURE
1532	10-Feb-24	TUMKUR	66	LINE	SOKKE-UJJINI_66	SOKKE_66	04:55	05:30	00:35	MAIN SUPPLY FAILURE
1533	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRAHALLI_66	06:30	06:35	00:05	TRIPPED ON FAULT
1534	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHANNAGIRI_66	13:00	13:10	00:10	TRIPPED ON FAULT
1535	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MYLANAHALLI_66	13:55	14:05	00:10	TRIPPED ON FAULT
1536	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	03:00	04:30	01:30	TRIPPED ON FAULT
1537	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	04:40	04:50	00:10	TRIPPED ON FAULT
1538	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	05:10	05:15	00:05	TRIPPED ON FAULT
1539	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	11:50	13:45	01:55	TRIPPED ON FAULT
1540	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	15:40	15:55	00:15	TRIPPED ON FAULT
1541	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	19:25	23:15	03:50	TRIPPED ON FAULT
1542	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	RANGANATHPURA_66	10:00	15:05	05:05	LINE CLEAR AVAILED
1543	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	GOPPENAHALLI-66	21:10	21:14	00:04	TRIPPED ON FAULT
1544	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KUKKAWADA_66,	11:27	11:34	00:07	TRIPPED ON FAULT
1545	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	08:40	08:45	00:05	TRIPPED ON FAULT
1546	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	18:00	18:05	00:05	TRIPPED ON FAULT
1547	10-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	RANGANATHPURA_66	14:45	17:35	02:50	LINE CLEAR AVAILED
1548	10-Feb-24	TUMKUR	220	LINE	CHITRADURGA 220- GUTTUR 220	GUTTUR 220	16:59	19:06	02:07	TRIPPED ON FAULT
1549	10-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	04:38(10.02.2024)			TRIPPED ON FAULT
1550	10-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	16:05	19:42	03:37	LINE CLEAR AVAILED
1551	10-Feb-24	TUMKUR	400	LINE	GUTTUR_400-DONI LINE(ZINDAL)	GUTTUR_400	09:58	15:44	05:46	LINE CLEAR AVAILED
1552	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED KANABAGARGI_110	09:15	17:05	07:50	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1553	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KANABAGARGI_110	09:15	16:52	07:37	LINE CLEAR AVAILED
1554	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	STATION NOT AFFECTED KANABAGARGI_110	09:30	16:42	07:12	LINE CLEAR AVAILED
1555	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	STATION NOT AFFECTED RATTIHALLI_110	17:55	18:01	00:06	TRIPPED ON FAULT
1556	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	STATION NOT AFFECTED KANABAGARGI_110	09:30	16:59	07:29	LINE CLEAR AVAILED
1557	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HANAGAL_110	17:05	17:13	00:08	TRIPPED ON FAULT
1558	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED HANAGAL_110	17:05	17:13	00:08	TRIPPED ON FAULT
1559	11-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4(20MVA)	ZALKI_110	21:31	21:55	00:24	TRIPPED ON FAULT
1560	11-Feb-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA(L2)	STATION NOT AFFECTED ANKOLA_110	18:37 (10.02.2024)	11:16 (11.02.2024)	16:39	TRIPPED ON FAULT
1561	11-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1562	11-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)			LINE CLEAR AVAILED
1563	11-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA220- PG HUNSHYAL	STATION NOT AFFECTED GHATAPRABHA_220	06:33	06:40	00:07	TRIPPED ON FAULT
1564	11-Feb-24	BAGALKOTE	110	LINE	HALIYAL-ALNAVAR	STATION NOT AFFECTED HALIYAL_110	10:53	15:02	04:09	LINE CLEAR AVAILED
1565	11-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1566	11-Feb-24	BAGALKOTE	110	LINE	HUNAGUND- B.BAGWDI(KUDALASANGUM)	STATION NOT AFFECTED HUNAGUND_110	14:57	16:24	01:27	LINE CLEAR AVAILED
1567	11-Feb-24	BAGALKOTE	110	LINE	INDI220- LACHYAN	STATION NOT AFFECTED INDI_220	08:25	08:35	00:10	TRIPPED ON FAULT
1568	11-Feb-24	BAGALKOTE	110	LINE	KANABARGI-BELAGAVI220I/C	STATION NOT AFFECTED KANABAGARGI_110	09:36	16:59	07:23	LINE CLEAR AVAILED
1569	11-Feb-24	BAGALKOTE	110	LINE	KUDALASANGAM-HUNAGUND	STATION NOT AFFECTED KUDALASANGAM_110	15:05	16:29	01:24	LINE CLEAR AVAILED
1570	11-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1571	11-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1572	11-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1573	11-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1574	11-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
1575	11-Feb-24	BAGALKOTE	110	LINE	SHIGGAON- RMNKP(MURGOD)	STATION NOT AFFECTED SHIGGAON_110	17:30	18:02	00:32	LINE CLEAR AVAILED
1576	11-Feb-24	BAGALKOTE	110	LINE	SUARNASOUDHA-MACHE	STATION NOT AFFECTED SUARNASOUDHA_110	17:40	20:28	02:48	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1577	11-Feb-24	BAGALKOTE	110	LINE	UDYAMBAG- MACHE	UDYAMBAG_110	10:25	16:54	06:29	LINE CLEAR AVAILED
1578	11-Feb-24	BAGALKOTE	110	LINE	VADAGOAN- BELGAUM220	VADAGOAN_110	16:19	20:44	04:25	LINE CLEAR AVAILED
1579	11-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1580	11-Feb-24	BAGALKOTE	220	LINE	AMBEWADI-NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	06:38	10:55	04:17	TRIPPED ON FAULT
1581	11-Feb-24	BAGALKOTE	220	LINE	BELGAUM220- KANABARGI	STATION NOT AFFECTED BELGAUM_220	10:08	15:47	05:39	LINE CLEAR AVAILED
1582	11-Feb-24	BAGALKOTE	220	LINE	BELGAUM220- VADAGOAN	STATION NOT AFFECTED BELGAUM_220	16:11	20:43	04:32	TRIPPED ON FAULT
1583	11-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1584	11-Feb-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	STATION NOT AFFECTED HUBLI_220	15:43	16:04	00:21	TRIPPED ON FAULT
1585	11-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1586	11-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1587	11-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1588	11-Feb-24	BAGALKOTE	220	LINE	VAJRAMATTI-ENERGON SOLAR	VAJRAMATTI_220	20:19 (10.02.2024)	2:54 (11.02.2024)	06:35	LINE CLEAR AVAILED
1589	11-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	AREHALLI	14:24	14:27	00:03	LINE CLEAR AVAILED
1590	11-Feb-24	BENGALURU	66	LINE	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	05:38	05:42	00:04	LINE CLEAR AVAILED
1591	11-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1592	11-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACAL(EHT)	06:20	06:25	00:05	MAIN SUPPLY FAILURE
1593	11-Feb-24	BENGALURU	66	LINE	66KV DABUSPET - HIREHALLI	HIREHALLI, HONNUDIKE	05:34	05:54	00:20	TRIPPED ON FAULT
1594	11-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNL (EHT)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1595	11-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGMANE TECH PARK	06:23	06:28	00:05	LINE CLEAR AVAILED
1596	11-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	KADUBISANAHALLI, ISRO	03:56	04:40	00:44	TRIPPED ON FAULT
1597	11-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	NO STATION AFFECTED	23:39	23:59	00:20	TRIPPED ON FAULT
1598	11-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	06:05	06:13	00:08	LINE CLEAR AVAILED
1599	11-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	12:57	13:02	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1600	11-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	12:51	12:58	00:07	LINE CLEAR AVAILED
1601	11-Feb-24	BENGALURU	66	LINE	66KV KHODAYS GLASS FACTORY 220 - ELITA PROMONEDE	ELITA PROMENENDE	15:48	15:52	00:04	LINE CLEAR AVAILED
1602	11-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	17:14	17:19	00:05	MAIN SUPPLY FAILURE
1603	11-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSAKOTE -1)	JADIGENAHALLI	17:14	17:19	00:05	MAIN SUPPLY FAILURE
1604	11-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	17:14	17:19	00:05	MAIN SUPPLY FAILURE
1605	11-Feb-24	BENGALURU	66	LINE	66KV RBI - ELITA PROMENADE	RBI	15:28	15:32	00:04	LINE CLEAR AVAILED
1606	11-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	06:20	06:25	00:05	LINE CLEAR AVAILED
1607	11-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	06:20	06:51	00:31	LINE CLEAR AVAILED
1608	11-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	10:18	10:28	00:10	LINE CLEAR AVAILED
1609	11-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	10:28	10:31	00:03	LINE CLEAR AVAILED
1610	11-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	SOUTH CITY	10:38	10:44	00:06	LINE CLEAR AVAILED
1611	11-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	10:34	10:37	00:03	LINE CLEAR AVAILED
1612	11-Feb-24	BENGALURU	66	LINE	66KV TAVAREKERE - KODIGEHALI	KODIGEHALI	00:10	00:14	00:04	LINE CLEAR AVAILED
1613	11-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH VILLAGE	06:20	06:26	00:06	MAIN SUPPLY FAILURE
1614	11-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH VILLAGE	06:20	06:26	00:06	MAIN SUPPLY FAILURE
1615	11-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	06:20	06:26	00:06	MAIN SUPPLY FAILURE
1616	11-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VRISHABHAVATHI 220	11:12	12:57	01:45	LINE CLEAR AVAILED
1617	11-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NANDINI LAYOUT	16:15	16:17	00:02	LINE CLEAR AVAILED
1618	11-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DIBBURAHALLI	14:57	15:08	00:11	TRIPPED ON FAULT
1619	11-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	06:20	06:32	00:12	LINE CLEAR AVAILED
1620	11-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIJAYANAGARA	11:48	11:57	00:09	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1621	11-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VRISHABHAVATHI 220	11:12	12:58	01:46	LINE CLEAR AVAILED
1622	11-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VRISHABHAVATHI 220	13:12	13:15	00:03	LINE CLEAR AVAILED
1623	11-Feb-24	BENGALURU	66	TRANSFORMER	HV2	HONNIGANAHALLI	17:35	17:45	00:10	TRIPPED ON FAULT
1624	11-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	06:20	06:32	00:12	LINE CLEAR AVAILED
1625	11-Feb-24	BENGALURU	220	LINE	220KV HOODY 220 - MALUR 220	NO STATION AFFECTED	07:01	15:01	08:00	LINE CLEAR AVAILED
1626	11-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 1	EXORA 220, VIKAS TECH PARK 220	06:20	06:25	00:05	MAIN SUPPLY FAILURE
1627	11-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 1	NO STATION AFFECTED	16:52	23:59	07:07	TRIPPED ON FAULT
1628	11-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 2	SARJAPURA 220	06:20	06:31	00:11	LINE CLEAR AVAILED
1629	11-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 2	NO STATION AFFECTED	16:53	23:59	07:06	TRIPPED ON FAULT
1630	11-Feb-24	BENGALURU	220	LINE	220KV MYLASANDRA - YARANDANAHALLI 1	NO STATION AFFECTED	13:43	14:56	01:13	TRIPPED ON FAULT
1631	11-Feb-24	BENGALURU	220	TRANSFORMER	HV1	MALUR 220	17:14	17:19	00:05	TRIPPED ON FAULT
1632	11-Feb-2024	GULBARGA	66	LINE	BADALADUKU-KOTTUR	UJJANI_66,NIMBALAGERE	04:30	05:30	01:00	TRIPPED ON FAULT
1633	11-Feb-2024	GULBARGA	66	LINE	BANVEKAL-SLR_IPP	BANVEKAL_66	04:28	04:48	00:20	MAIN SUPPLY FAILURE
1634	11-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI	SOVENHALLI_66	11:13	11:24	00:11	TRIPPED ON FAULT
1635	11-Feb-2024	GULBARGA	66	LINE	POONAMGHATTA-NEELGUNADA	POONABHAGATTA_66	06:34	06:44	00:10	TRIPPED ON FAULT
1636	11-Feb-2024	GULBARGA	110	LINE	MALLAPURA-KEREHALLI	KEREHALLI_110	21:06	21:14	21:06	TRIPPED ON FAULT
1637	11-Feb-24	HASSAN	66	LINE	BALLUPE-SKLPR	BALLUPETE_66	22:24	22:59	00:35	MAIN SUPPLY FAILURE
1638	11-Feb-24	HASSAN	66	LINE	HASSN22-SKPURA1	HASSAN_220	22:25	22:56	00:31	TRIPPED ON FAULT
1639	11-Feb-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	12:08	12:18	00:10	TRIPPED ON FAULT
1640	11-Feb-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:21	10:56	00:35	TRIPPED ON FAULT
1641	11-Feb-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	18:54	19:02	00:08	TRIPPED ON FAULT
1642	11-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1643	11-Feb-24	MYSORE	66	LINE	BEGUR -B MATTEKERE	B MATKERE_66	04:05	04:10	00:05	TRIPPED ON FAULT
1644	11-Feb-24	MYSORE	66	LINE	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	09:19	10:14	00:55	LINE CLEAR AVAILED
1645	11-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1646	11-Feb-24	MYSORE	66	LINE	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	06:38	06:45	00:07	TRIPPED ON FAULT
1647	11-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1648	11-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1649	11-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1650	11-Feb-24	MYSORE	66	LINE	HOSURGATE-BANNIKUPPE	BANNIKUPPE_66	16:05	16:15	00:10	TRIPPED ON FAULT
1651	11-Feb-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	14:27	14:57	00:29	TRIPPED ON FAULT
1652	11-Feb-24	MYSORE	66	TRANSFORMER	HV2	BETTADHAPURA_66	11:36	14:00	02:23	LINE CLEAR AVAILED
1653	11-Feb-24	MYSORE	66	TRANSFORMER	HV2	VAJAMANGALA_220	07:40	07:45	00:05	TRIPPED ON FAULT
1654	11-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	14:25	16:01	01:36	LINE CLEAR AVAILED
1655	11-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	15:13 (10/02/2024)	7:13 (11/02/2024)	16:00	LINE CLEAR AVAILED
1656	11-Feb-24	MYSORE	66	TRANSFORMER	SFCSIVA-HV5	NO STATIONS EFFECTED	18:38 (11/02/2024)			LINE CLEAR AVAILED
1657	11-Feb-24	MYSORE	220	LINE	HEBBANI -TK HALLI 1	NO STATIONS EFFECTED	07:00	17:37	10:37	LINE CLEAR AVAILED
1658	11-Feb-24	MYSORE	220	LINE	HEBBANI -TK HALLI 2	NO STATIONS EFFECTED	07:00	17:37	10:37	LINE CLEAR AVAILED
1659	11-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66,ADICHUCHANAGIRI_66, B G NAGARA_66	21:57	27:07:00	05:10	TRIPPED ON FAULT
1660	11-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	02:29	02:56	00:27	TRIPPED ON FAULT
1661	11-Feb-24	TUMKUR	66	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:34	14:05	03:31	LINE CLEAR AVAILED
1662	11-Feb-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66	22:59	23:12	00:13	TRIPPED ON FAULT
1663	11-Feb-24	TUMKUR	66	LINE	HANAGAL- GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	07:14	07:28	00:14	TRIPPED ON FAULT
1664	11-Feb-24	TUMKUR	66	LINE	HANGAL66-RAMPURA	RAMAPURA_66	06:55	07:08	00:13	TRIPPED ON FAULT
1665	11-Feb-24	TUMKUR	66	LINE	HANGAL66-THALLAK 1	HANGAL_66	06:45	07:07	00:22	TRIPPED ON FAULT
1666	11-Feb-24	TUMKUR	66	LINE	HANGAL66-THALLAK 1	HANGAL_66	07:13	07:16	00:03	TRIPPED ON FAULT
1667	11-Feb-24	TUMKUR	66	LINE	HANGAL66-THALLAK 2	HANGAL_66	06:45	07:15	00:30	TRIPPED ON FAULT
1668	11-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:45	14:34	02:49	LINE CLEAR AVAILED
1669	11-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	10:38	10:48	00:10	TRIPPED ON FAULT
1670	11-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- SIRA 2	GULIGENAHALLI_66,	03:12	03:16	00:04	TRIPPED ON FAULT
1671	11-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- SIRA 2	GULIGENAHALLI_66,	04:40	07:19	02:39	LINE CLEAR AVAILED
1672	11-Feb-24	TUMKUR	66	LINE	NYAMATHI-HONNALLI-220	NYAMATHI_66	10:40	10:50	00:10	MAIN SUPPLY FAILURE
1673	11-Feb-24	TUMKUR	66	LINE	PAVAGADA- (GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1674	11-Feb-24	TUMKUR	66	LINE	THALLAK 220kV - BGKERE 2	BGKERE_66	06:48	07:14	00:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1675	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHANNAGIRI_66	12:25	12:35	00:10	TRIPPED ON FAULT
1676	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADADKERE_66	10:30(11.02.2024)			LINE CLEAR AVAILED
1677	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	NAGALAMADIKE_66	11:40	15:50	04:10	TRIPPED ON FAULT
1678	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-1&2	MADADKERE_66	10:30	12:05	01:35	LINE CLEAR AVAILED
1679	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHANNAGIRI_66	05:50	05:55	00:05	TRIPPED ON FAULT
1680	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHANNAGIRI_66	10:22	10:30	00:08	TRIPPED ON FAULT
1681	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHANNAGIRI_66	19:50	19:57	00:07	TRIPPED ON FAULT
1682	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KUKKAWADA_66,	23:20	23:26	00:06	TRIPPED ON FAULT
1683	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	13:10	13:15	00:05	TRIPPED ON FAULT
1684	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	14:20	14:25	00:05	TRIPPED ON FAULT
1685	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	22:00	22:05	00:05	TRIPPED ON FAULT
1686	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	08:45	08:50	00:05	TRIPPED ON FAULT
1687	11-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NYAMATHI_66	18:05	18:10	00:05	TRIPPED ON FAULT
1688	11-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	02:31	03:01	00:30	TRIPPED ON FAULT
1689	11-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1690	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED TOLAMATTI_110	10:14	10:46	00:32	LINE CLEAR AVAILED
1691	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED VAJJRAMATTI_110	12:02	13:10	01:08	LINE CLEAR AVAILED
1692	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED NAVALAGI_110	23:34 (12.02.2024)			TRIPPED ON FAULT
1693	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED ZALKI_110	11:50	11:54	00:04	LINE CLEAR AVAILED
1694	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	NAREGAL_110	17:15	21:50	04:35	LINE CLEAR AVAILED
1695	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KALADAGI_110	21:20	22:57	01:37	TRIPPED ON FAULT
1696	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KALAGHATAGI_110	11:15	14:48	03:33	LINE CLEAR AVAILED
1697	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	NAVALGUND_110	11:43	13:00	01:17	LINE CLEAR AVAILED
1698	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GOKAK_110	18:14	18:27	00:13	LINE CLEAR AVAILED
1699	12-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	KUDACHI_110	08:17	08:30	00:13	LINE CLEAR AVAILED
1700	12-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1701	12-Feb-24	BAGALKOTE	110	LINE	BETAGERI- GADAG220	BETAGERI_110	04:46	05:08	00:22	TRIPPED ON FAULT
1702	12-Feb-24	BAGALKOTE	110	LINE	DEVANGOAN-GATTARAGA	DEVANGOAN_110	13:35 (06.02.2024)	16:18 (12.02.2024)	146:43:00	LINE CLEAR AVAILED
1703	12-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1704	12-Feb-24	BAGALKOTE	110	LINE	INDI220- ATHARGA	INDI_220	06:25	06:40	00:15	TRIPPED ON FAULT
1705	12-Feb-24	BAGALKOTE	110	LINE	INDI220- ATHARGA	INDI_220	22:38	22:48	00:10	TRIPPED ON FAULT
1706	12-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1707	12-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR(B)- BELGAUM SUGARS	MAMADAPUR(B)_110	13:33	13:50	00:17	LINE CLEAR AVAILED
1708	12-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1709	12-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- HALLUR	MUGALKHOD_220	10:14	15:23	05:09	LINE CLEAR AVAILED
1710	12-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	07:23	07:47	00:24	TRIPPED ON FAULT
1711	12-Feb-24	BAGALKOTE	110	LINE	MUNDAGOD- SHIGGOAN	MUDAGOD_110	3:54 (11.02.2024)	14:15 (12.02.2024)	10:21	TRIPPED ON FAULT
1712	12-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1713	12-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1714	12-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
1715	12-Feb-24	BAGALKOTE	110	LINE	SADALAGA- VPPL COGEN	VPPL COGEN_110 STATION NOT AFFECTED SADALAGA_110	11:22	14:57	03:35	LINE CLEAR AVAILED
1716	12-Feb-24	BAGALKOTE	110	LINE	SHIGGAON- RMKP(MUNDAGOD)	STATION NOT AFFECTED SHIGGAON_110	12:20	14:12	01:52	LINE CLEAR AVAILED
1717	12-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA1	SOUDATTI_220	18:37 (10.02.2024)	10:12 (12.02.2024)	39:35:00	TRIPPED ON FAULT
1718	12-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA1	SOUDATTI_220	10:17	10:22	00:05	LINE CLEAR AVAILED
1719	12-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1720	12-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1721	12-Feb-24	BAGALKOTE	220	LINE	CHIKKODI- KUDACHI1	CHIKKODI_220	17:27	19:25	01:58	LINE CLEAR AVAILED
1722	12-Feb-24	BAGALKOTE	220	LINE	CHIKKODI- KUDACHI2	CHIKKODI_220	10:59	19:25	08:26	LINE CLEAR AVAILED
1723	12-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	11:05	13:44	02:39	LINE CLEAR AVAILED
1724	12-Feb-24	BAGALKOTE	220	LINE	KUDACHI- CHIKKODI1	KUDACHI_220	17:26	19:25	01:59	LINE CLEAR AVAILED
1725	12-Feb-24	BAGALKOTE	220	LINE	KUDACHI- CHIKKODI2	KUDACHI_220	11:00	19:25	08:25	LINE CLEAR AVAILED
1726	12-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1727	12-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1728	12-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1729	12-Feb-24	BENGALURU	66	LINE	66kV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1730	12-Feb-24	BENGALURU	66	LINE	66KV BOMMEPALLI - YENIGADALE	YENIGADALE	11:20	11:30	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1731	12-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACAL(EHT)	03:36	03:40	00:04	LINE CLEAR AVAILED
1732	12-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	15:43	15:50	00:07	TRIPPED ON FAULT
1733	12-Feb-24	BENGALURU	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	06:54	07:02	00:08	TRIPPED ON FAULT
1734	12-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1735	12-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1736	12-Feb-24	BENGALURU	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	DOMMASANDRA	18:50	18:55	00:05	LINE CLEAR AVAILED
1737	12-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	10:30	10:42	00:12	TRIPPED ON FAULT
1738	12-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSAKOTE -1)	JADIGENAHALLI	10:30	10:42	00:12	TRIPPED ON FAULT
1739	12-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	10:30	10:42	00:12	TRIPPED ON FAULT
1740	12-Feb-24	BENGALURU	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI CROSS	13:10	13:15	00:05	LINE CLEAR AVAILED
1741	12-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE(HV2)	09:56	11:00	01:04	MAIN SUPPLY FAILURE
1742	12-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	09:56	11:25	01:29	MAIN SUPPLY FAILURE
1743	12-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	09:55	10:15	00:20	MAIN SUPPLY FAILURE
1744	12-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	04:32	04:46	00:14	LINE CLEAR AVAILED
1745	12-Feb-24	BENGALURU	66	LINE	66KV TALAGUNDA - VEMGAL	VEMGAL, KYALANUR	13:00	13:10	00:10	TRIPPED ON FAULT
1746	12-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH VILLAGE	03:36	03:40	00:04	LINE CLEAR AVAILED
1747	12-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH VILLAGE	03:36	03:40	00:04	LINE CLEAR AVAILED
1748	12-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	03:24	03:30	00:06	LINE CLEAR AVAILED
1749	12-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	13:28	13:35	00:07	LINE CLEAR AVAILED
1750	12-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	14:25	14:32	00:07	LINE CLEAR AVAILED
1751	12-Feb-24	BENGALURU	66	LINE	66KV YENIGADALE - SOMANATHAPURA - CHELUR	YENIGADALE, BOMMEPALLI CROSS	11:36	12:01	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1752	12-Feb-24	BENGALURU	66	LINE	66KV YENIGADALE - SOMANATHAPURA - CHELUR	YENIGADALE	13:16	13:18	00:02	LINE CLEAR AVAILED
1753	12-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	09:56	11:25	01:29	MAIN SUPPLY FAILURE
1754	12-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	04:32	04:45	00:13	LINE CLEAR AVAILED
1755	12-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	13:28	13:36	00:08	LINE CLEAR AVAILED
1756	12-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	14:26	14:32	00:06	LINE CLEAR AVAILED
1757	12-Feb-24	BENGALURU	66	TRANSFORMER	HV2	WIDIA	12:10	12:13	00:03	LINE CLEAR AVAILED
1758	12-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DODDABELAVANGALA	11:40	12:25	00:45	LINE CLEAR AVAILED
1759	12-Feb-24	BENGALURU	66	TRANSFORMER	HV2	ATTIBELE	06:05	06:15	00:10	LINE CLEAR AVAILED
1760	12-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	09:56	11:57	02:01	MAIN SUPPLY FAILURE
1761	12-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	04:10	04:18	00:08	LINE CLEAR AVAILED
1762	12-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 1	NO STATION AFFECTED	00:00	03:40	03:40	TRIPPED ON FAULT
1763	12-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 2	NO STATION AFFECTED	00:00	03:09	03:09	TRIPPED ON FAULT
1764	12-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 2	SARJAPURA 220	09:56	11:57	02:01	TRIPPED ON FAULT
1765	12-Feb-24	BENGALURU	220	TRANSFORMER	HV1	MALUR 220	10:30	10:40	00:10	TRIPPED ON FAULT
1766	12-Feb-24	BENGALURU	400	LINE	400KV NELAMANGALA 400 - TALAGUPPA	NO STATION AFFECTED	14:02	17:21	03:19	TRIPPED ON FAULT
1767	12-Feb-2024	GULBARGA	66	LINE	HIREHADAGALLI-GIRIYAPURA	GIRIYAPURA_66,TBPCL_IPP	01:00	01:10	00:10	TRIPPED ON FAULT
1768	12-Feb-2024	GULBARGA	66	LINE	HIREHADAGALLI-GIRIYAPURA	GIRIYAPURA_66,TBPCL_IPP	20:28	20:38	00:10	TRIPPED ON FAULT
1769	12-Feb-2024	GULBARGA	66	TRANSFORMER	HV6	MUNIRABAD_220	10:08	11:26	01:18	LINE CLEAR AVAILED
1770	12-Feb-2024	GULBARGA	66	LINE	MUNIRABAD-CHILKANHATTI(MSD LINE)	CHILKANHATTI_66	08:37	11:37	03:00	LINE CLEAR AVAILED
1771	12-Feb-2024	GULBARGA	66	LINE	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_HALLI_66	06:06	06:14	00:08	TRIPPED ON FAULT
1772	12-Feb-2024	GULBARGA	66	LINE	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_HALLI_66	06:16	11:36	05:20	LINE CLEAR AVAILED
1773	12-Feb-2024	GULBARGA	110	LINE	GABUR-DEODURGA	GABUR_110, GUGAL_110	15:00	15:05	00:05	TRIPPED ON FAULT
1774	12-Feb-2024	GULBARGA	110	LINE	HUMNABAD-HALIKHED	HALIKHED_110	15:40	17:50	02:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1775	12-Feb-2024	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	10:20	17:40	07:20	LINE CLEAR AVAILED
1776	12-Feb-2024	GULBARGA	110	LINE	MUNIRABAD-MALLAPURA	KEREHALLI_110,MALLAPURA_110	23:45	23:50	00:05	TRIPPED ON FAULT
1777	12-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNSAGI_66,ASKI_110,UGAR SUGAR_IPP	06:06	06:18	00:12	TRIPPED ON FAULT
1778	12-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	20:55	21:15	00:20	TRIPPED ON FAULT
1779	12-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	20:55	21:15	00:20	TRIPPED ON FAULT
1780	12-Feb-2024	GULBARGA	110	LINE	TEKKALKOTE-SHAHISOLAR	TEKKALKOTE_110	18:50	22:30	03:40	LINE CLEAR AVAILED
1781	12-Feb-24	HASSAN	66	TRANSFORMER	HV1	DODDAHALLI_66	12:05	12:20	00:15	LINE CLEAR AVAILED
1782	12-Feb-24	HASSAN	66	TRANSFORMER	HV2	DODDAHALLI_66	14:10	14:19	00:09	LINE CLEAR AVAILED
1783	12-Feb-24	HASSAN	110	LINE	HGUNJE-HIRIYAD	HEGGUNJE_220	13:40	13:52	00:12	TRIPPED ON FAULT
1784	12-Feb-24	HASSAN	110	LINE	HIRIYA-KEMAR	HIRIYADKA_110	13:40	13:56	00:16	MAIN SUPPLY FAILURE
1785	12-Feb-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADI_110	10:11	13:00	02:49	LINE CLEAR AVAILED
1786	12-Feb-24	HASSAN	110	TRANSFORMER	HV2	BHADRAVATHY_110	18:13	22:00	03:47	LINE CLEAR AVAILED
1787	12-Feb-24	HASSAN	110	TRANSFORMER	HV3	BAIKAMPADI_110	13:05	13:58	00:53	LINE CLEAR AVAILED
1788	12-Feb-24	HASSAN	110	LINE	KAVOOR-MCFLine	KAVOOR_220	10:00	12:50	02:50	LINE CLEAR AVAILED
1789	12-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
1790	12-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1791	12-Feb-24	MYSORE	66	LINE	HAMPAPURA-SARGUR	HDKOTE_66 ANATARSANTE_66 YERAHALLIHANDPOST_66	06:20	06:30	00:10	TRIPPED ON FAULT
1792	12-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1793	12-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1794	12-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
1795	12-Feb-24	MYSORE	66	TRANSFORMER	HV1	CHANDALLI_66	11:40	12:55	01:15	LINE CLEAR AVAILED
1796	12-Feb-24	MYSORE	66	TRANSFORMER	HV1	YERAHALLIHANDPOST_66	13:05	13:10	00:05	TRIPPED ON FAULT
1797	12-Feb-24	MYSORE	66	TRANSFORMER	HV2	KMDODDI_66	11:10	14:55	03:44	LINE CLEAR AVAILED
1798	12-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
1799	12-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:38 (11/02/2024)	9:17:00 (12/02/2024)	14:38:55	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1800	12-Feb-24	MYSORE	66	LINE	KHONALAGERE-IGLOOR	NO STATIONS EFFECTED	14:30	14:39	00:08	LINE CLEAR AVAILED
1801	12-Feb-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	SATHEGALA_66	10:05	17:42	07:37	LINE CLEAR AVAILED
1802	12-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	01:02	18:16	17:13	LINE CLEAR AVAILED
1803	12-Feb-24	MYSORE	66	LINE	TALAKADU-CHANADALLI	NO STATIONS EFFECTED	19:03	19:13	00:10	TRIPPED ON FAULT
1804	12-Feb-24	MYSORE	66	LINE	TUBINKERE-MANDYA2	MANDYA_66KIADBMANDYA_66CHIKKA_MANDYA_66TUMBEKERE_66	15:53	15:59	00:06	TRIPPED ON FAULT
1805	12-Feb-24	MYSORE	66	LINE	TUBINKERE-MANDYA4	MANDYA_66KIADBMANDYA_66CHIKKA_MANDYA_66TUMBEKERE_66	15:53	15:59	00:06	TRIPPED ON FAULT
1806	12-Feb-24	MYSORE	66	LINE	VAJMANGALA-DEVNUR(MYS)	DEVNUR(MYS)_66	10:55	11:00	00:05	TRIPPED ON FAULT
1807	12-Feb-24	MYSORE	220	TRANSFORMER	HV2	TUBINKERE_66	13:03	13:30	00:27	LINE CLEAR AVAILED
1808	12-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	13:37	13:39	00:02	TRIPPED ON FAULT
1809	12-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:01	15:20	00:19	TRIPPED ON FAULT
1810	12-Feb-24	TUMKUR	66	LINE	Davangere SRS _ Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	17:36	17:45	00:09	TRIPPED ON FAULT
1811	12-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:28	10:36	00:08	LINE CLEAR AVAILED
1812	12-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:40	10:41	00:01	TRIPPED ON FAULT
1813	12-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	17:20	17:54	00:34	LINE CLEAR AVAILED
1814	12-Feb-24	TUMKUR	66	LINE	HIRIYUR 220kv- SUZLON 2	SUZLON1_IPP_66	17:25	17:51	00:26	LINE CLEAR AVAILED
1815	12-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:57	18:00	07:03	LINE CLEAR AVAILED
1816	12-Feb-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	19:53	20:06	00:13	TRIPPED ON FAULT
1817	12-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	13:12	13:48	00:35	TRIPPED ON FAULT
1818	12-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	PATTANAYAKANAHALLI_66	08:10	08:15	00:04	TRIPPED ON FAULT
1819	12-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	SIRA_66	16:15	16:20	00:05	TRIPPED ON FAULT
1820	12-Feb-24	TUMKUR	66	LINE	NAYAKANAHATTI66-THALLAKK	NAYAKANHATTI_66, HIREMALLANAHOLE_66	11:15	11:40	00:25	LINE CLEAR AVAILED
1821	12-Feb-24	TUMKUR	66	LINE	NAYAKANAHATTI66-THALLAKK	NAYAKANHATTI_66, HIREMALLANAHOLE_66	15:10	15:35	00:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1822	12-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1823	12-Feb-24	TUMKUR	66	LINE	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	08:40	11:10	02:30	LINE CLEAR AVAILED
1824	12-Feb-24	TUMKUR	66	LINE	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	12:15	15:34	03:19	LINE CLEAR AVAILED
1825	12-Feb-24	TUMKUR	66	LINE	SANIKERE- CHALLAKERE	SANIKERE_66	10:55	10:57	00:02	LINE CLEAR AVAILED
1826	12-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADADKERE_66	10:30(11.02.2024)			LINE CLEAR AVAILED
1827	12-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	06:02	06:22	00:20	TRIPPED ON FAULT
1828	12-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	13:38	13:44	00:06	TRIPPED ON FAULT
1829	12-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1830	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED NIDAGUNDI_110	14:01	17:50	03:49	LINE CLEAR AVAILED
1831	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED UKKALI_110	09:07	09:18	00:11	TRIPPED ON FAULT
1832	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED NAVALAGI_110	23:34 (12.02.2024)	10:36 (13.02.2024)	11:02	TRIPPED ON FAULT
1833	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KALADAGI_110	10:30	12:38	02:08	LINE CLEAR AVAILED
1834	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MUDALAGI_110	12:10 (13.02.2024)			TRIPPED ON FAULT
1835	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	11:15 (13.02.2024)			LINE CLEAR AVAILED
1836	13-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	BISNAL_110	19:01	19:12	00:11	TRIPPED ON FAULT
1837	13-Feb-24	BAGALKOTE	110	LINE	ATHANI220- KSSKN	ATHANI_220	12:52	13:50	00:58	LINE CLEAR AVAILED
1838	13-Feb-24	BAGALKOTE	110	LINE	ATHANI220-SATTI(GHATANATTI)	ATHANI_220	11:13	13:37	02:24	LINE CLEAR AVAILED
1839	13-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
1840	13-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
1841	13-Feb-24	BAGALKOTE	110	LINE	INDI220- ATHARGA	INDI_220	00:18	00:28	00:10	TRIPPED ON FAULT
1842	13-Feb-24	BAGALKOTE	110	LINE	INDI220- ATHARGA	INDI_220	04:25	04:35	00:10	TRIPPED ON FAULT
1843	13-Feb-24	BAGALKOTE	110	LINE	INDI220- ATHARGA	INDI_220	05:55	06:05	00:10	TRIPPED ON FAULT
1844	13-Feb-24	BAGALKOTE	110	LINE	KULIGOD- GAMESHA	KULIGOD_110	11:00	17:24	06:24	LINE CLEAR AVAILED
1845	13-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1846	13-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1847	13-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- KULIGOD	MUGALKHOD_220	11:05	16:50	05:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1848	13-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
1849	13-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1850	13-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
1851	13-Feb-24	BAGALKOTE	110	LINE	TADASINAKOPPA-NARENDRA	TADASINAKOPPA_110	10:32	17:35	07:03	LINE CLEAR AVAILED
1852	13-Feb-24	BAGALKOTE	110	LINE	TALIKOTI-FPEL SOLAR	FPEL SOLAR_110 STATION NOT AFFECTED TALIKOTI_110	19:11	22:22	03:11	LINE CLEAR AVAILED
1853	13-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1854	13-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1855	13-Feb-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI3	HUBLI_220	10:40	17:28	06:48	LINE CLEAR AVAILED
1856	13-Feb-24	BAGALKOTE	220	LINE	KUDACHI- MAHALINGAPUR	KUDACHI_220	12:34	17:31	04:57	LINE CLEAR AVAILED
1857	13-Feb-24	BAGALKOTE	220	LINE	NARENDRA- SHIGGOAN	NARENDRA_220	11:45	13:32	01:47	LINE CLEAR AVAILED
1858	13-Feb-24	BAGALKOTE	220	LINE	SHIGGOAN-NARENDRA	SHIGGOAN_220	11:45	13:32	01:47	LINE CLEAR AVAILED
1859	13-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1860	13-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
1861	13-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1862	13-Feb-24	BENGALURU	66	LINE	220KV MYLASANDRA - YARANDANAHALLI 1	NO STATION AFFECTED	19:31	20:28	00:57	TRIPPED ON FAULT
1863	13-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1864	13-Feb-24	BENGALURU	66	LINE	66KV BAGEPALLI - GULUR	NO STATION AFFECTED	00:12	00:30	00:18	TRIPPED ON FAULT
1865	13-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	13:05	13:38	00:33	LINE CLEAR AVAILED
1866	13-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1867	13-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	12:06	12:55	00:49	TRIPPED ON FAULT
1868	13-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1869	13-Feb-24	BENGALURU	66	LINE	66KV MARALAVADI - GODUR	GODURU	18:49	18:59	00:10	TRIPPED ON FAULT
1870	13-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	12:28	12:50	00:22	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1871	13-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:28	13:15	00:47	MAIN SUPPLY FAILURE
1872	13-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:28	12:55	00:27	MAIN SUPPLY FAILURE
1873	13-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	GLOBAL(EHT)	10:38	11:47	01:09	LINE CLEAR AVAILED
1874	13-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO(HV1)	10:09	10:12	00:03	LINE CLEAR AVAILED
1875	13-Feb-24	BENGALURU	66	LINE	66KV T GOLAHALLI - MULBAGAL - BYRAKUR - NANGLI	BYRAKUR	10:22	10:43	00:21	TRIPPED ON FAULT
1876	13-Feb-24	BENGALURU	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	08:35	08:50	00:15	TRIPPED ON FAULT
1877	13-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON(EHT)	06:29	06:44	00:15	TRIPPED ON FAULT
1878	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	11:02	11:06	00:04	LINE CLEAR AVAILED
1879	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIJAYANAGARA	22:06	22:12	00:06	LINE CLEAR AVAILED
1880	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	RMZ	12:21	12:24	00:03	LINE CLEAR AVAILED
1881	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIAL BEGUR 220	12:32	12:38	00:06	LINE CLEAR AVAILED
1882	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MANCHENAHALLI	10:15	10:20	00:05	TRIPPED ON FAULT
1883	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ANDERSONPETE	16:10	16:20	00:10	LINE CLEAR AVAILED
1884	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HANUMANTHNAGARA	10:28	10:50	00:22	TRIPPED ON FAULT
1885	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	AGALAKOTE	14:30	14:55	00:25	LINE CLEAR AVAILED
1886	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	T BEGUR	13:00	15:15	02:15	TRIPPED ON FAULT
1887	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TG HALLI	08:50	09:35	00:45	LINE CLEAR AVAILED
1888	13-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	12:28	12:49	00:21	MAIN SUPPLY FAILURE
1889	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIJAYANAGARA	22:06	22:12	00:06	LINE CLEAR AVAILED
1890	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	RMZ	13:25	13:28	00:03	LINE CLEAR AVAILED
1891	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	ANDERSONPETE	14:05	14:10	00:05	LINE CLEAR AVAILED
1892	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	HANUMANTHNAGARA	10:28	10:50	00:22	TRIPPED ON FAULT
1893	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KODIHALLI	23:40	23:50	00:10	TRIPPED ON FAULT
1894	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	AGALAKOTE	15:25	15:55	00:30	LINE CLEAR AVAILED
1895	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TYAMAGONDLU	10:50	11:00	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1896	13-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	12:28	12:50	00:22	MAIN SUPPLY FAILURE
1897	13-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VTP 220 - EXORA 220 2	SARJAPURA 220	12:28	12:50	00:22	TRIPPED ON FAULT
1898	13-Feb-24	BENGALURU	400	LINE	NELAMANGALA 400kV - GOOTY 400kV	NO STATION AFFECTED	13:54	15:29	01:35	TRIPPED ON FAULT
1899	13-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	HALVAGALU_66	08:30	08:50	00:20	LINE CLEAR AVAILED
1900	13-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	HALVAGALU_66	12:50	15:45	02:55	LINE CLEAR AVAILED
1901	13-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-TELAGI	TELAGI_66,KURBHAHALLI_66,SHAMNUR SUGAR_IPP, GREEN INFR_IPP	13:05	13:10	00:05	TRIPPED ON FAULT
1902	13-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	11:15	11:20	00:05	TRIPPED ON FAULT
1903	13-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	11:23	11:29	00:06	MAIN SUPPLY FAILURE
1904	13-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	11:33	11:44	00:11	MAIN SUPPLY FAILURE
1905	13-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	12:11	12:23	00:12	MAIN SUPPLY FAILURE
1906	13-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	BISIHALLI_110	19:56	20:04	00:08	TRIPPED ON FAULT
1907	13-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	16:30	16:35	00:05	TRIPPED ON FAULT
1908	13-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	17:15	17:20	00:05	TRIPPED ON FAULT
1909	13-Feb-2024	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	15:37	17:17	01:40	LINE CLEAR AVAILED
1910	13-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR2(JEWARGI)	JEWARGI_110	01:08	01:18	00:10	TRIPPED ON FAULT
1911	13-Feb-2024	GULBARGA	110	LINE	YERADONA-MARALIHALLA	YERADONA_110,HANAWAL_110	21:43	22:00	00:17	MAIN SUPPLY FAILURE
1912	13-Feb-2024	GULBARGA	220	LINE	HALWARTHY-LINGAPUR	LINGAPUR_220	09:30	13:16	03:46	LINE CLEAR AVAILED
1913	13-Feb-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	12:00	13:22	01:22	LINE CLEAR AVAILED
1914	13-Feb-24	HASSAN	66	TRANSFORMER	HV1	MALLAPURA_66	14:30	15:20	00:50	TRIPPED ON FAULT
1915	13-Feb-24	HASSAN	66	LINE	MRSSHM-DVG2	MRSMSG_220	15:57	16:13	00:16	TRIPPED ON FAULT
1916	13-Feb-24	HASSAN	66	LINE	UDAYAP-BAGUR	UDAYAPURA_66	02:10	02:25	00:15	TRIPPED ON FAULT
1917	13-Feb-24	HASSAN	110	LINE	ARSK2-BANAVARA	ARSIKERE_220	15:59	16:16	00:17	TRIPPED ON FAULT
1918	13-Feb-24	HASSAN	110	LINE	ARSK2-GANDASI	ARSIKERE_220	12:52	15:35	02:43	TRIPPED ON FAULT
1919	13-Feb-24	HASSAN	110	LINE	ARSK2-GERUMARA	ARSIKERE_220	12:52	13:16	00:24	TRIPPED ON FAULT
1920	13-Feb-24	HASSAN	110	LINE	HALADY1-HEGGUNJE	HALADY_110	11:15	16:40	05:25	LINE CLEAR AVAILED
1921	13-Feb-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	11:00	15:13	04:13	LINE CLEAR AVAILED
1922	13-Feb-24	HASSAN	110	LINE	HGUNJE-HALADY	HEGGUNJE_220	11:15	16:40	05:25	LINE CLEAR AVAILED
1923	13-Feb-24	HASSAN	110	LINE	HGUNJE-HIRIYADKA	HEGGUNJE_220	13:04	13:42	00:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1924	13-Feb-24	HASSAN	110	LINE	HIRIYA-HEGGUNJE	HIRIYADKA_110	12:54	13:41	00:47	LINE CLEAR AVAILED
1925	13-Feb-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	11:00	14:40	03:40	LINE CLEAR AVAILED
1926	13-Feb-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	14:40	15:13	00:33	LINE CLEAR AVAILED
1927	13-Feb-24	HASSAN	110	LINE	HOSNGD-HULIKAL	HOSANGADI_110	16:41	17:29	00:48	LINE CLEAR AVAILED
1928	13-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG1	HOSANGADI_110	10:36	15:18	04:42	LINE CLEAR AVAILED
1929	13-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG2	HOSANGADI_110	10:36	15:18	04:42	LINE CLEAR AVAILED
1930	13-Feb-24	HASSAN	110	TRANSFORMER	HV1	HEGGUNJE_220	10:15	12:51	02:36	LINE CLEAR AVAILED
1931	13-Feb-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	11:15	15:13	03:58	LINE CLEAR AVAILED
1932	13-Feb-24	HASSAN	110	TRANSFORMER	HV1	HOSANGADI_110	13:50	15:02	01:12	LINE CLEAR AVAILED
1933	13-Feb-24	HASSAN	110	TRANSFORMER	HV1	KARAYA_110	10:45	13:14	02:29	LINE CLEAR AVAILED
1934	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADI_110	10:14	16:52	06:38	LINE CLEAR AVAILED
1935	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	BHADRAVATHI_110	11:01	13:30	02:29	LINE CLEAR AVAILED
1936	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	ESSUR_110	16:42	17:07	00:25	TRIPPED ON FAULT
1937	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	HALADY_110	11:16	16:43	05:27	LINE CLEAR AVAILED
1938	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	HOSANGADI_110	16:04	18:03	01:59	LINE CLEAR AVAILED
1939	13-Feb-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	10:18	13:00	02:42	LINE CLEAR AVAILED
1940	13-Feb-24	HASSAN	110	TRANSFORMER	HV4	BANTWAL_110	15:53	15:56	00:03	LINE CLEAR AVAILED
1941	13-Feb-24	HASSAN	110	LINE	KAVOOR-KONAJE	KAVOOR_220	10:10	14:52	04:42	LINE CLEAR AVAILED
1942	13-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	18:55	19:02	00:07	TRIPPED ON FAULT
1943	13-Feb-24	HASSAN	110	LINE	LV3	MRSMSG_220	10:48	17:03	06:15	LINE CLEAR AVAILED
1944	13-Feb-24	HASSAN	220	TRANSFORMER	HV1	HEGGUNJE_220	11:04	15:02	03:58	LINE CLEAR AVAILED
1945	13-Feb-24	HASSAN	220	TRANSFORMER	HV3	MRSMSG_220	10:48	17:03	06:15	LINE CLEAR AVAILED
1946	13-Feb-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA 2	gen_sharavathy	11:12	13:51	02:39	LINE CLEAR AVAILED
1947	13-Feb-24	HASSAN	220	LINE	TALAGU-STRP1	TALAGUPPA-400	11:08	13:51	02:43	LINE CLEAR AVAILED
1948	13-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1949	13-Feb-24	MYSORE	66	LINE	CR NAGARA-HONGANURU	HONAGANURU_66 MAMBALLI_66 YELANDUR_66	06:39	06:44	00:05	TRIPPED ON FAULT
1950	13-Feb-24	MYSORE	66	LINE	HALAGURU-HONGANAHALLI	HALAGUR_66	09:04	16:52	07:47	LINE CLEAR AVAILED
1951	13-Feb-24	MYSORE	66	LINE	HALAGURU-TK HALLI	NO STATIONS EFFECTED	09:04	18:10	09:05	LINE CLEAR AVAILED
1952	13-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
1953	13-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
1954	13-Feb-24	MYSORE	66	LINE	HEBBANI-BG PURA-CHIDRAVALLI	BGPURA_66 CHIDRAVALLI_66 THUMBLA_66 VYASRAJPURA_66	04:45	05:06	00:21	TRIPPED ON FAULT
1955	13-Feb-24	MYSORE	66	LINE	HEBBANI-VADKEPURA	KIRUGAVALU_66 MALIYURU_66 VADKEPURA_66	01:22	01:28	00:06	TRIPPED ON FAULT
1956	13-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
1957	13-Feb-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)	13:26 (13/02/2024)	414:51 HRs	LINE CLEAR AVAILED
1958	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	CHANDAKAVADI_66	09:55	10:55	01:00	LINE CLEAR AVAILED
1959	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	09:04	16:52	07:47	LINE CLEAR AVAILED
1960	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	JAKKANAHALLY_66	13:14	13:15	00:01	LINE CLEAR AVAILED
1961	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	10:04	10:41	00:36	LINE CLEAR AVAILED
1962	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	16:45	17:15	00:29	LINE CLEAR AVAILED
1963	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	03:50	03:55	00:05	TRIPPED ON FAULT
1964	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	04:02	04:07	00:05	TRIPPED ON FAULT
1965	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	VIRAJPET_66	19:24	19:30	00:06	TRIPPED ON FAULT
1966	13-Feb-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	10:03	16:00	05:56	LINE CLEAR AVAILED
1967	13-Feb-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	09:04	18:00	08:55	LINE CLEAR AVAILED
1968	13-Feb-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	11:00	12:07	01:07	LINE CLEAR AVAILED
1969	13-Feb-24	MYSORE	66	TRANSFORMER	HV2	JAKKANAHALLY_66	13:07	13:08	00:01	LINE CLEAR AVAILED
1970	13-Feb-24	MYSORE	66	TRANSFORMER	HV2	YETHAMBADI_66	10:03	16:00	05:56	LINE CLEAR AVAILED
1971	13-Feb-24	MYSORE	66	TRANSFORMER	HV3	KUSHALANAGARA_66	13:09	13:26	00:17	LINE CLEAR AVAILED
1972	13-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
1973	13-Feb-24	MYSORE	66	LINE	KIRUGAVLU-MALIYUR	MALIYURU_66	10:15	17:34	07:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1974	13-Feb-24	MYSORE	66	LINE	KOPPA-KASALAGERE	KESLAGERE_66	10:20	16:07	05:47	LINE CLEAR AVAILED
1975	13-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	06:54	07:07	00:13	TRIPPED ON FAULT
1976	13-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	19:19	21:51	02:32	LINE CLEAR AVAILED
1977	13-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	BESAGARAHALLI_66, DUNDANAHALLI_66, KOPPA_66	11:01	11:07	00:06	TRIPPED ON FAULT
1978	13-Feb-24	MYSORE	66	LINE	SFC SIVA-10 MW	NO STATIONS EFFECTED	01:23	06:10	04:47	TRIPPED ON FAULT
1979	13-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	01:23	01:28	00:05	TRIPPED ON FAULT
1980	13-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	04:45	04:56	00:11	TRIPPED ON FAULT
1981	13-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	08:45	18:18	09:33	LINE CLEAR AVAILED
1982	13-Feb-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	08:45	18:18	09:33	LINE CLEAR AVAILED
1983	13-Feb-24	MYSORE	66	LINE	TUBINAKERE-G UKKADA	GARUDANAUKADDA_66	11:42	13:22	01:40	LINE CLEAR AVAILED
1984	13-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:53			LINE CLEAR AVAILED
1985	13-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASANDRA_66,HONNENAHALLI_66	09:04	09:10	00:06	LINE CLEAR AVAILED
1986	13-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 66kV-THIMMASANDRA	THIMMASANDRA_66,BHAKTHARAHALLI_66	09:10	09:25	00:15	LINE CLEAR AVAILED
1987	13-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	09:03	09:27	00:24	TRIPPED ON FAULT
1988	13-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	06:27	06:32	00:05	TRIPPED ON FAULT
1989	13-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	00:29	00:48	00:19	TRIPPED ON FAULT
1990	13-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	03:05	03:11	00:06	TRIPPED ON FAULT
1991	13-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	00:11	00:21	00:10	TRIPPED ON FAULT
1992	13-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	06:05	06:12	00:07	TRIPPED ON FAULT
1993	13-Feb-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	15:16	15:32	00:16	TRIPPED ON FAULT
1994	13-Feb-24	TUMKUR	66	LINE	HOSADURGA220-HALURAMESHWARA66	HALURAMESHWARA_66	00:05	00:20	00:15	TRIPPED ON FAULT
1995	13-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1996	13-Feb-24	TUMKUR	66	LINE	THALLAK 220kV- P R PURA	PR PURA_66	06:33	06:44	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1997	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADADKERE_66	10:30(11.02.2024)			LINE CLEAR AVAILED
1998	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HANGAL_66	17:56	18:03	00:07	LINE CLEAR AVAILED
1999	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MYLANAHALLI_66	10:15	10:30	00:15	TRIPPED ON FAULT
2000	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MYLANAHALLI_66	10:45	11:45	01:00	TRIPPED ON FAULT
2001	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	12:05	12:15	00:10	TRIPPED ON FAULT
2002	13-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MELEKOTE_66	16:00	16:10	00:10	TRIPPED ON FAULT
2003	13-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2004	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	SIRSI_220	16:04	17:45	01:41	LINE CLEAR AVAILED
2005	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MUDALAGI_110	12:10 (13.02.2024)	16:43 (14.02.2024)	28:33:00	TRIPPED ON FAULT
2006	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KALADAGI_110	16:11	16:20	00:09	LINE CLEAR AVAILED
2007	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KULIGOD_110	12:02	15:20	03:18	LINE CLEAR AVAILED
2008	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MALGHAN(S)_110	12:19	13:48	01:29	LINE CLEAR AVAILED
2009	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	NAVALAGI_110	10:01	11:20	01:19	LINE CLEAR AVAILED
2010	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	SIRSI_110	14:21	17:08	02:47	LINE CLEAR AVAILED
2011	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MURDESHWAR_110	14:58	15:10	00:12	LINE CLEAR AVAILED
2012	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	11:15 (13.02.2024)	12:08 (14.02.2024)	24:53:00	LINE CLEAR AVAILED
2013	14-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	HANGAL_110	21:10	21:20	00:10	TRIPPED ON FAULT
2014	14-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
2015	14-Feb-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2016	14-Feb-24	BAGALKOTE	110	LINE	BAGEWADI220- DEVAR HIPPARAGI	STATION NOT AFFECTED BAGEWADI_220	11:15	14:02	02:47	TRIPPED ON FAULT
2017	14-Feb-24	BAGALKOTE	110	LINE	BIDNAL220- PH COMPOUND	BIDNAL_220	14:55	15:52	00:57	LINE CLEAR AVAILED
2018	14-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2019	14-Feb-24	BAGALKOTE	110	LINE	KULIGOD- GAMESHA	STATION NOT AFFECTED KULIGOD_110	12:02	12:10	00:08	LINE CLEAR AVAILED
2020	14-Feb-24	BAGALKOTE	110	LINE	KUMATA- SIRSI1	STATION NOT AFFECTED KUMATA_110	10:14	15:57	05:43	LINE CLEAR AVAILED
2021	14-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2022	14-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2023	14-Feb-24	BAGALKOTE	110	LINE	MURDESHWAR- HONNAVAR (RAILWAY LINE)	MURDESHWAR_110	14:47	16:02	01:15	LINE CLEAR AVAILED
2024	14-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
2025	14-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2026	14-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2027	14-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- RATTIHALLI (TUMMINKATTE)	STATION NOT AFFECTED RANEBENNUR_220	12:15	12:19	00:04	LINE CLEAR AVAILED
2028	14-Feb-24	BAGALKOTE	110	LINE	RON- GAJENDRAGAD2	RON_110	00:26	07:32	07:06	TRIPPED ON FAULT
2029	14-Feb-24	BAGALKOTE	110	LINE	SIRSI- KAVALWADA(SIRSI220)	SIRSI_110	10:05	14:21	04:16	LINE CLEAR AVAILED
2030	14-Feb-24	BAGALKOTE	110	LINE	SIRSI- KUMTA2	SIRSI_110	10:05	14:21	04:16	LINE CLEAR AVAILED
2031	14-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2032	14-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1&HV2	SIRSI_220	18:15	18:18	00:03	TRIPPED ON FAULT
2033	14-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- RBRK	STATION NOT AFFECTED BAGEWADI_220	07:37	07:52	00:15	TRIPPED ON FAULT
2034	14-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2035	14-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGALKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	06:45	18:35	11:50	LINE CLEAR AVAILED
2036	14-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGALKHOD2	STATION NOT AFFECTED GHATAPRABHA_220	06:56	18:45	11:49	LINE CLEAR AVAILED
2037	14-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	06:46	18:36	11:50	LINE CLEAR AVAILED
2038	14-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA2	STATION NOT AFFECTED MUGALKHOD_220	06:57	18:45	11:48	LINE CLEAR AVAILED
2039	14-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	STATION NOT AFFECTED RANEBENNUR_220	12:18	13:46	01:28	LINE CLEAR AVAILED
2040	14-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2041	14-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2042	14-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2043	14-Feb-24	BENGALURU	66	LINE	66KV ARMY WELFARE HOUSING ORGANISATION - KONDASAPURA (SAFAL)	ARMY WELFARE ORGANISATION	14:20	14:25	00:05	MAIN SUPPLY FAILURE
2044	14-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2045	14-Feb-24	BENGALURU	66	LINE	66KV BAGEPALLI - GULUR	NO STATION AFFECTED	00:12	00:30	00:18	TRIPPED ON FAULT
2046	14-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	16:45	17:00	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2047	14-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION SUBSTATION	08:15	08:24	00:09	TRIPPED ON FAULT
2048	14-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	17:02	17:11	00:09	LINE CLEAR AVAILED
2049	14-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2050	14-Feb-24	BENGALURU	66	LINE	66KV EPIP 220 - KADUGODI	KADUGODI	13:10	14:10	01:00	LINE CLEAR AVAILED
2051	14-Feb-24	BENGALURU	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	ARMY WELFARE ORGANISATION	13:12	13:17	00:05	MAIN SUPPLY FAILURE
2052	14-Feb-24	BENGALURU	66	LINE	66KV KUDURU - SRIGIRIPURA	SRIGIRIPURA	06:39	06:54	00:15	TRIPPED ON FAULT
2053	14-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR	17:09	17:39	00:30	LINE CLEAR AVAILED
2054	14-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	19:10	19:15	00:05	LINE CLEAR AVAILED
2055	14-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	17:31	17:36	00:05	LINE CLEAR AVAILED
2056	14-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	09:29	09:41	00:12	TRIPPED ON FAULT
2057	14-Feb-24	BENGALURU	66	LINE	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	SM MANGALA	17:08	17:11	00:03	LINE CLEAR AVAILED
2058	14-Feb-24	BENGALURU	66	LINE	66KV SK STEEL - KOLALA	NO STATION AFFECTED	03:08	07:24	04:16	TRIPPED ON FAULT
2059	14-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP	17:45	17:50	00:05	LINE CLEAR AVAILED
2060	14-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 1	SRINIVASAPURA	17:38	17:42	00:04	LINE CLEAR AVAILED
2061	14-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	17:22	17:26	00:04	LINE CLEAR AVAILED
2062	14-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	YELDUR, DALASANR	17:33	17:37	00:04	LINE CLEAR AVAILED
2063	14-Feb-24	BENGALURU	66	LINE	66kv SRS PEENYA 220 - BRINDAVANA	NANDINI LAYOUT, MAHALAKSHMI LAYOUT	14:38	15:10	00:32	TRIPPED ON FAULT
2064	14-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	14:38	15:13	00:35	MAIN SUPPLY FAILURE
2065	14-Feb-24	BENGALURU	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	13:10	13:30	00:20	TRIPPED ON FAULT
2066	14-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MATHIKERE	13:00	13:45	00:45	LINE CLEAR AVAILED
2067	14-Feb-24	BENGALURU	66	TRANSFORMER	HV1	AKKURMOLE	12:15	18:55	06:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2068	14-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ATTIBELE	14:10	14:25	00:15	LINE CLEAR AVAILED
2069	14-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KACHAMARANAHALLI	13:30	13:32	00:02	LINE CLEAR AVAILED
2070	14-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DEVARABISANAHALLI	02:18	02:30	00:12	TRIPPED ON FAULT
2071	14-Feb-24	BENGALURU	66	TRANSFORMER	HV2	THAYALUR	14:35	14:55	00:20	LINE CLEAR AVAILED
2072	14-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	06:46	06:52	00:06	TRIPPED ON FAULT
2073	14-Feb-24	BENGALURU	220	LINE	220KV MYLASANDRA - YARANDANAHALLI 1	NO STATION AFFECTED	09:52	10:17	00:25	TRIPPED ON FAULT
2074	14-Feb-2024	GULBARGA	66	LINE	HANGAL-GUDEKOTE LINE	CJ HALLI_66,HOSAHALLI_66	11:08	11:21	00:13	TRIPPED ON FAULT
2075	14-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	BENAVEKAL_66	16:00	16:05	00:05	TRIPPED ON FAULT
2076	14-Feb-2024	GULBARGA	66	LINE	KUDLIGI-KOGLI	KOGLI_66	12:15	12:20	00:05	LINE CLEAR AVAILED
2077	14-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HARVI_66,HALVAGALU_66,LIS(KNN L-EHT)_66	02:51	03:01	00:10	TRIPPED ON FAULT
2078	14-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HARVI_66,HALVAGALU_66,LIS(KNN L-EHT)_66	07:30	09:00	01:30	LINE CLEAR AVAILED
2079	14-Feb-2024	GULBARGA	110	LINE	ALIPUR-BELLARY NORTH	BELLARY NORTH_110,MOKA_110,BISIHALLI_110,PD_HALLI_110,SOMASAMUNDRA_110, HALKUNDI_110	19:21	19:41	00:20	TRIPPED ON FAULT
2080	14-Feb-2024	GULBARGA	110	LINE	BELLARY NORTH -PDHALLI	MOKA_110,BISIHALLI_110,PD_HALLI_110,SOMASAMUNDRA_110	06:05	06:20	00:15	TRIPPED ON FAULT
2081	14-Feb-2024	GULBARGA	110	LINE	BYGAWATH-WALKAMDINNI	WALKAMDINNI_110	10:00	14:00	04:00	LINE CLEAR AVAILED
2082	14-Feb-2024	GULBARGA	110	LINE	HALBARGA-CHIDRI	CHIDRI_110	15:35	16:48	01:13	LINE CLEAR AVAILED
2083	14-Feb-2024	GULBARGA	110	LINE	HALBARGA-KAMTHANA	KAMTHANA_110	12:05	13:25	01:20	LINE CLEAR AVAILED
2084	14-Feb-2024	GULBARGA	110	LINE	HALWARTHY-GINIGERA	GINIGERA_110	08:47	20:07	11:20	LINE CLEAR AVAILED
2085	14-Feb-2024	GULBARGA	110	LINE	HALWARTHY-HAREKRISHNA	HAREKRISHNA_IPP	08:43	20:24	11:41	LINE CLEAR AVAILED
2086	14-Feb-2024	GULBARGA	110	LINE	HALWARTHY-KOPPAL1&2	KOPPAL_110	15:16	15:33	00:17	TRIPPED ON FAULT
2087	14-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	DONIMALAI_110	09:00	13:45	04:45	LINE CLEAR AVAILED
2088	14-Feb-2024	GULBARGA	110	TRANSFORMER	HV1&2	WALKAMDINNI_110	09:00	14:00	05:00	LINE CLEAR AVAILED
2089	14-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KALBURGI NORTH_110	11:02	14:47	03:45	LINE CLEAR AVAILED
2090	14-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	WALKAMDINNI_110	10:00	14:15	04:15	LINE CLEAR AVAILED
2091	14-Feb-2024	GULBARGA	110	LINE	KADECHUR-SAIDAPUR	KADECHUR_110	16:45	18:40	01:55	LINE CLEAR AVAILED
2092	14-Feb-2024	GULBARGA	110	LINE	KALBURGI WEST-KALBURGI SOUTH	KALBURGI SOUTH_110	10:50	12:52	02:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2093	14-Feb-2024	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	13:23	13:57	00:34	LINE CLEAR AVAILED
2094	14-Feb-2024	GULBARGA	110	LINE	KAPNOOR-KALBURGI NORTH	KALBURGI NORTH_110	11:22	13:20	01:58	LINE CLEAR AVAILED
2095	14-Feb-2024	GULBARGA	110	LINE	KAPNOOR-MAHAGOAN	MAHAGOAN_110	13:42	16:35	02:53	LINE CLEAR AVAILED
2096	14-Feb-2024	GULBARGA	110	LINE	MALLAT-SIRWAR	SIRWAR_110	19:16	19:21	00:05	TRIPPED ON FAULT
2097	14-Feb-2024	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	17:10	17:20	00:10	MAIN SUPPLY FAILURE
2098	14-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	08:45	13:55	05:10	LINE CLEAR AVAILED
2099	14-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	08:45	17:45	09:00	LINE CLEAR AVAILED
2100	14-Feb-2024	GULBARGA	220	LINE	SULEKAL-KUSHTAGI	KUSHTAGI_220	10:55	16:32	05:37	LINE CLEAR AVAILED
2101	14-Feb-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:11	12:57	01:46	LINE CLEAR AVAILED
2102	14-Feb-24	HASSAN	66	TRANSFORMER	HV1	BALLUPETE_66	13:11	13:36	00:25	LINE CLEAR AVAILED
2103	14-Feb-24	HASSAN	66	TRANSFORMER	HV1	BALLUPETE_66	13:51	14:40	00:49	LINE CLEAR AVAILED
2104	14-Feb-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	18:11	18:26	00:15	TRIPPED ON FAULT
2105	14-Feb-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESH PURA_66	13:40	13:52	00:12	TRIPPED ON FAULT
2106	14-Feb-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	11:15	13:42	02:27	LINE CLEAR AVAILED
2107	14-Feb-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	06:54	07:11	00:17	TRIPPED ON FAULT
2108	14-Feb-24	HASSAN	110	TRANSFORMER	HV1	VITTALA_110	11:20	12:55	01:35	LINE CLEAR AVAILED
2109	14-Feb-24	HASSAN	110	TRANSFORMER	HV2	VITTALA_110	11:20	13:43	02:23	LINE CLEAR AVAILED
2110	14-Feb-24	HASSAN	110	LINE	JOG110-MGHE	JOG_110	10:20	15:30	05:10	LINE CLEAR AVAILED
2111	14-Feb-24	HASSAN	110	LINE	LPH-JLT4	gen_lph	10:28	15:45	05:17	LINE CLEAR AVAILED
2112	14-Feb-24	HASSAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	11:20	12:55	01:35	LINE CLEAR AVAILED
2113	14-Feb-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	12:57	13:02	00:05	LINE CLEAR AVAILED
2114	14-Feb-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	11:20	12:55	01:35	LINE CLEAR AVAILED
2115	14-Feb-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTALA_110	11:20	12:55	01:35	LINE CLEAR AVAILED
2116	14-Feb-24	HASSAN	110	LINE	VITTAL-PUTR_VITTLA	VITTALA_110	11:20	12:55	01:35	LINE CLEAR AVAILED
2117	14-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
2118	14-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2119	14-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
2120	14-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
2121	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	HULLAHALLI_66	09:15	12:29	03:14	TRIPPED ON FAULT
2122	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	HULLAHALLI_66	12:31	13:14	00:42	LINE CLEAR AVAILED
2123	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	NO STATIONS EFFECTED	13:16	13:22	00:06	LINE CLEAR AVAILED
2124	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	HULLAHALLI_66	13:24	13:38	00:14	LINE CLEAR AVAILED
2125	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-CHANDRAWADI	HULLAHALLI_66	14:20	14:38	00:17	LINE CLEAR AVAILED
2126	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-DOORA	NO STATIONS EFFECTED	13:24	14:55	01:31	LINE CLEAR AVAILED
2127	14-Feb-24	MYSORE	66	LINE	HULLAHALLI-DOORA	NO STATIONS EFFECTED	18:14	19:24	01:10	TRIPPED ON FAULT
2128	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	17:24	17:26	00:02	LINE CLEAR AVAILED
2129	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	17:31	17:32	00:01	LINE CLEAR AVAILED
2130	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	12:02	12:15	00:12	TRIPPED ON FAULT
2131	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	09:45	09:55	00:10	TRIPPED ON FAULT
2132	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	17:45	18:30	00:45	LINE CLEAR AVAILED
2133	14-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	07:24	07:29	00:05	TRIPPED ON FAULT
2134	14-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	11:24	12:10	00:45	LINE CLEAR AVAILED
2135	14-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	05:02	05:50	00:48	TRIPPED ON FAULT
2136	14-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	07:55	08:07	00:12	TRIPPED ON FAULT
2137	14-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
2138	14-Feb-24	MYSORE	66	LINE	KADAKOLA-DOORA	DOORA_66HULLAHALLI_66HURA_66CHANDRAVADI_66	22:02	22:11	00:08	TRIPPED ON FAULT
2139	14-Feb-24	MYSORE	66	LINE	KOTTANUR-HANNUR	NO STATIONS EFFECTED	02:00	02:05	00:05	TRIPPED ON FAULT
2140	14-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	12:58	13:38	00:40	LINE CLEAR AVAILED
2141	14-Feb-24	MYSORE	66	LINE	MYSORE-GIS	NO STATIONS EFFECTED	01:02	08:17	07:14	LINE CLEAR AVAILED
2142	14-Feb-24	MYSORE	66	LINE	MYSORE-GIS	NO STATIONS EFFECTED	17:30	22:11	04:41	LINE CLEAR AVAILED
2143	14-Feb-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	06:30	09:35	03:05	LINE CLEAR AVAILED
2144	14-Feb-24	MYSORE	66	LINE	SFCSIVA-PPCL	NO STATIONS EFFECTED	06:30	11:52	05:22	LINE CLEAR AVAILED
2145	14-Feb-24	MYSORE	66	LINE	TUBINKERE-ARAKERE	TARIPURA_66 GAMANAHALLY_66 ARAKERE_66BSEEHALLI_66	10:37	13:15	02:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2146	14-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	05:10	05:24	00:14	TRIPPED ON FAULT
2147	14-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	20:35	20:40	00:05	TRIPPED ON FAULT
2148	14-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	21:35 (14/2/2024)			TRIPPED ON FAULT
2149	14-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:53 (13/02/2024)	1:08 (14/02/2024)	3:15 HRs	LINE CLEAR AVAILED
2150	14-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:10 (14/2/2024)			LINE CLEAR AVAILED
2151	14-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	18:20	18:30	00:10	TRIPPED ON FAULT
2152	14-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	11:12	11:25	00:13	TRIPPED ON FAULT
2153	14-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	11:45	12:02	00:17	TRIPPED ON FAULT
2154	14-Feb-24	TUMKUR	66	LINE	HANAGAL-GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	11:08	11:18	00:10	LINE CLEAR AVAILED
2155	14-Feb-24	TUMKUR	66	LINE	HANGAL66-RAMPURA	RAMAPURA_66	11:08	11:18	00:10	LINE CLEAR AVAILED
2156	14-Feb-24	TUMKUR	66	LINE	HANGAL66-THALLAK 1	HANGAL_66	11:08	11:18	00:10	TRIPPED ON FAULT
2157	14-Feb-24	TUMKUR	66	LINE	HANGAL66-THALLAK 2	HANGAL_66	11:08	11:18	00:10	TRIPPED ON FAULT
2158	14-Feb-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	01:30	01:40	00:10	TRIPPED ON FAULT
2159	14-Feb-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	21:48	21:58	00:10	TRIPPED ON FAULT
2160	14-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	17:47	17:51	00:04	TRIPPED ON FAULT
2161	14-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	17:47	17:57	00:10	TRIPPED ON FAULT
2162	14-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2163	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADADKERE_66	10:30(11.02.2024)	16:15 (14.02.2024)	3DAYS ,5HR, 45MIN	LINE CLEAR AVAILED
2164	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HIRIYUR_220	16:06	16:21	00:15	LINE CLEAR AVAILED
2165	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HANGAL_66	00:16	00:20	00:04	TRIPPED ON FAULT
2166	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	HANGAL_66	00:05	00:10	00:05	TRIPPED ON FAULT
2167	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	P.D. KOTE_66	00:05	00:10	00:05	TRIPPED ON FAULT
2168	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	02:55	03:00	00:05	TRIPPED ON FAULT
2169	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	22:40	22:50	00:10	TRIPPED ON FAULT
2170	14-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MADADKERE_66	09:35	22:50	13:15	TRIPPED ON FAULT
2171	14-Feb-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220kV-SHIMOGA	ANTHRASANAHALLI_220	12:29	13:54	01:25	TRIPPED ON FAULT
2172	14-Feb-24	TUMKUR	220	LINE	GUTUR_400-RANEBENNUR	GUTUR_400	12:24	13:45	01:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2173	14-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)	14:34 (14.02.2024)	43 DAYS,5HR,16MIN.	LINE CLEAR AVAILED
2174	15-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MALGHAN(S)_110	16:01	17:26	01:25	LINE CLEAR AVAILED
2175	15-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	KUDACHI_220	12:17	16:42	04:25	LINE CLEAR AVAILED
2176	15-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	ATHANI_220	13:29	13:48	00:19	TRIPPED ON FAULT
2177	15-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
2178	15-Feb-24	BAGALKOTE	110	LINE	ATHANI220-KSSKN	ATHANI_220	15:54	17:15	01:21	TRIPPED ON FAULT
2179	15-Feb-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2180	15-Feb-24	BAGALKOTE	110	LINE	GADAG ROAD- GOPPANAKOPPA	GADAG ROAD_110	14:05	14:21	00:16	LINE CLEAR AVAILED
2181	15-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-GADAG ROAD	GOPPANAKOPPA_110	14:13	14:17	00:04	LINE CLEAR AVAILED
2182	15-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- MRUTHYUNJAYANAGAR	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
2183	15-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2184	15-Feb-24	BAGALKOTE	110	LINE	HUDALI-ANKALAGI	HUDALI_110	08:22	11:44	03:22	TRIPPED ON FAULT
2185	15-Feb-24	BAGALKOTE	110	LINE	ISLAMPUR- F2(HIDIKAL DAM)	ISLAMPUR_110	14:33	15:53	01:20	LINE CLEAR AVAILED
2186	15-Feb-24	BAGALKOTE	110	LINE	KUDACHI220- SHIRAGUPPI	KUDACHI_220	09:15	09:50	00:35	TRIPPED ON FAULT
2187	15-Feb-24	BAGALKOTE	110	LINE	KUDACHI220- UGSRKHUD	KUDACHI_220	09:15	09:32	00:17	TRIPPED ON FAULT
2188	15-Feb-24	BAGALKOTE	110	LINE	KUDUCHI220-KUDUCHI110	KUDUCHI_220	09:15	09:30	00:15	TRIPPED ON FAULT
2189	15-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2190	15-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR- BABLESHWAR	MAMADAPUR(B)_110	03:10	03:27	00:17	LINE CLEAR AVAILED
2191	15-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR- SHIRABUR	MAMADAPUR(B)_110	03:10	03:27	00:17	LINE CLEAR AVAILED
2192	15-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR- TODALBAGI	MAMADAPUR(B)_110	03:10	03:22	00:12	LINE CLEAR AVAILED
2193	15-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR- TODALBAGI	MAMADAPUR(B)_110	04:10	04:30	00:20	TRIPPED ON FAULT
2194	15-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2195	15-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR- L2(GOPPANAKOPPA2)	MRUTHYUNJAYANAGAR_110	17:30 (01.02.2024)	14:52 (15.02.2024)	333:22:00	LINE CLEAR AVAILED
2196	15-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR- NARENDRA1	MRUTHYUNJAYANAGAR_110	14:21	18:48	04:27	LINE CLEAR AVAILED
2197	15-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR- NARENDRA2	MRUTHYUNJAYANAGAR_110	12:04	12:40	00:36	LINE CLEAR AVAILED
2198	15-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR- NARENDRA2	MRUTHYUNJAYANAGAR_110	15:00	18:10	03:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2199	15-Feb-24	BAGALKOTE	110	LINE	MUNDARAGI- VIJAYANAGAR SUGARS	MUNDARAGI_110	18:44	18:55	00:11	TRIPPED ON FAULT
2200	15-Feb-24	BAGALKOTE	110	LINE	NARENDRA220-MRUTHYUNJAY NAGAR	NARENDRA_220	14:57	18:47	03:50	LINE CLEAR AVAILED
2201	15-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)			LINE CLEAR AVAILED
2202	15-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2203	15-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2204	15-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- SOUDATTI1	SOUDATTI_220	11:06	12:42	01:36	LINE CLEAR AVAILED
2205	15-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- SOUDATTI2	SOUDATTI_220	12:59	15:17	02:18	LINE CLEAR AVAILED
2206	15-Feb-24	BAGALKOTE	110	LINE	UAS- F2(MRUTHYUNJAY NAGAR)	UAS DHARWAD_110	12:03	12:46	00:43	TRIPPED ON FAULT
2207	15-Feb-24	BAGALKOTE	110	LINE	UAS- F2(MRUTHYUNJAY NAGAR)	UAS DHARWAD_110	15:09	18:45	03:36	LINE CLEAR AVAILED
2208	15-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2209	15-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KUDACHI_220	12:17	16:40	04:23	LINE CLEAR AVAILED
2210	15-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	ATHANI_220	12:11	14:28	02:17	LINE CLEAR AVAILED
2211	15-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	KUDACHI_220, KUDACHI_110	09:15	09:30	00:15	TRIPPED ON FAULT
2212	15-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3&LV3	ATHANI_220, SATTI_110, ATHANI_110, BALEGERI_110, KARIMASUTI LIS_110, HALIYAL_110, KSSKN_110	13:29	13:49	00:20	TRIPPED ON FAULT
2213	15-Feb-24	BAGALKOTE	220	LINE	ATHANI- KUDACHI	ATHANI_220	13:29	14:41	01:12	TRIPPED ON FAULT
2214	15-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2215	15-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	HUBLI_220	11:05	14:34	03:29	LINE CLEAR AVAILED
2216	15-Feb-24	BAGALKOTE	220	LINE	KUDACHI- ATHANI	KUDACHI_220	13:28	14:15	00:47	TRIPPED ON FAULT
2217	15-Feb-24	BAGALKOTE	220	LINE	NARENDRA- HUBLI1	NARENDRA_220	11:05	14:34	03:29	LINE CLEAR AVAILED
2218	15-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2219	15-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2220	15-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2221	15-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	BANASHANKARI	21:47	21:51	00:04	LINE CLEAR AVAILED
2222	15-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2223	15-Feb-24	BENGALURU	66	LINE	66KV DASHAVARA - CNNL (EHT)	NO STATION AFFECTED	00:00	16:30	16:30	TRIPPED ON FAULT
2224	15-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL	07:10	08:34	01:24	TRIPPED ON FAULT
2225	15-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	NO STATION AFFECTED	04:10	07:15	03:05	TRIPPED ON FAULT
2226	15-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - BHORUKA GRAPHITE INDIA	GRAPHITE INDIA	15:16	15:19	00:03	LINE CLEAR AVAILED
2227	15-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	14:10	14:15	00:05	LINE CLEAR AVAILED
2228	15-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	15:00	15:25	00:25	LINE CLEAR AVAILED
2229	15-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	17:25	17:45	00:20	LINE CLEAR AVAILED
2230	15-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	12:00	12:30	00:30	LINE CLEAR AVAILED
2231	15-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	17:20	17:25	00:05	LINE CLEAR AVAILED
2232	15-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	15:09	15:19	00:10	TRIPPED ON FAULT
2233	15-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	15:09	15:29	00:20	TRIPPED ON FAULT
2234	15-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI	14:01	14:33	00:32	TRIPPED ON FAULT
2235	15-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - IISC	IISc	22:32	22:37	00:05	LINE CLEAR AVAILED
2236	15-Feb-24	BENGALURU	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	04:54	05:10	00:16	TRIPPED ON FAULT
2237	15-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	13:53	13:56	00:03	LINE CLEAR AVAILED
2238	15-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	GLOBAL(EHT)	12:08	13:22	01:14	LINE CLEAR AVAILED
2239	15-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	13:56	14:03	00:07	LINE CLEAR AVAILED
2240	15-Feb-24	BENGALURU	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA	11:29	11:33	00:04	LINE CLEAR AVAILED
2241	15-Feb-24	BENGALURU	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	12:50	12:53	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2242	15-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - RR NAGAR	RR NAGAR	21:43	21:46	00:03	LINE CLEAR AVAILED
2243	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	REMCO	14:49	14:51	00:02	LINE CLEAR AVAILED
2244	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOODY 220	15:22	15:31	00:09	LINE CLEAR AVAILED
2245	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KHODAYS 220	12:58	13:04	00:06	LINE CLEAR AVAILED
2246	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	APPAREL PARK	15:50	16:00	00:10	TRIPPED ON FAULT
2247	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VEMGAL	14:55	15:05	00:10	TRIPPED ON FAULT
2248	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BUDIKOTE	15:20	15:50	00:30	LINE CLEAR AVAILED
2249	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HULLENAHALLI	14:30	14:50	00:20	LINE CLEAR AVAILED
2250	15-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TK HALLI 220	12:08	12:24	00:16	TRIPPED ON FAULT
2251	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	NRS 220	12:23	13:06	00:43	LINE CLEAR AVAILED
2252	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	HOODY 220	15:39	16:29	00:50	LINE CLEAR AVAILED
2253	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KHODAYS 220	12:58	13:04	00:06	LINE CLEAR AVAILED
2254	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	G KODIHALLI	17:31	17:43	00:12	LINE CLEAR AVAILED
2255	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	HULLENAHALLI	12:30	12:52	00:22	LINE CLEAR AVAILED
2256	15-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KUMBARANAHALLI	11:33	12:35	01:02	TRIPPED ON FAULT
2257	15-Feb-24	BENGALURU	66	TRANSFORMER	HV3	EMBASSY TECH PARK	13:42	13:45	00:03	LINE CLEAR AVAILED
2258	15-Feb-24	BENGALURU	66	TRANSFORMER	HV3	DEVANAHALLI 66	21:20	22:05	00:45	TRIPPED ON FAULT
2259	15-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	07:15	07:20	00:05	TRIPPED ON FAULT
2260	15-Feb-24	BENGALURU	220	LINE	220KV BIDADI PGCIL 400 - KUMBALAGODU GIS	NO STATION AFFECTED	11:52	00:24(16/02/2024)	12:32HRS	TRIPPED ON FAULT
2261	15-Feb-24	BENGALURU	220	TRANSFORMER	HV2	BIDADI 220	11:48	15:33	03:45	TRIPPED ON FAULT
2262	15-Feb-2024	GULBARGA	110	LINE	ALIPUR-BELLARY NORTH	BELLARY NORTH_110,MOKA_110,BISIHALLI_110,PD_HALLI_110,SOMASAMUNDRA_110, HALKUNDI_110	08:56	17:40	08:44	LINE CLEAR AVAILED
2263	15-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	FARTHABAD_110	11:40	15:30	03:50	LINE CLEAR AVAILED
2264	15-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	ALIPUR_220	11:20	18:07	06:47	LINE CLEAR AVAILED
2265	15-Feb-2024	GULBARGA	110	LINE	KIADB KUDITINI-TORANGALU	KUDITINI_110,METRI_110,TORANGALU_110	14:17	14:37	00:20	TRIPPED ON FAULT
2266	15-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-NAGNOOR	NAGNOOR_110,KEMBHAVI_110	06:06	06:18	00:12	TRIPPED ON FAULT
2267	15-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	21:02	21:12	00:10	TRIPPED ON FAULT
2268	15-Feb-2024	GULBARGA	220	LINE	HALWARTHY-LINGAPUR	LINGAPUR_220	13:31	14:24	00:53	TRIPPED ON FAULT
2269	15-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-KUSHTAGI	KUSHTAGI_220	12:50	16:28	03:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2270	15-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	NAGABENAL_220	17:02	19:03	02:01	LINE CLEAR AVAILED
2271	15-Feb-2024	GULBARGA	220	LINE	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	08:45	12:23	03:38	LINE CLEAR AVAILED
2272	15-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	16:20	16:40	00:20	LINE CLEAR AVAILED
2273	15-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	16:45	17:25	00:40	LINE CLEAR AVAILED
2274	15-Feb-24	HASSAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:54	12:15	00:21	LINE CLEAR AVAILED
2275	15-Feb-24	HASSAN	66	LINE	HNPR2-CRPTN	HNPURA_220	12:19	12:24	00:05	TRIPPED ON FAULT
2276	15-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	22:00	22:09	00:09	TRIPPED ON FAULT
2277	15-Feb-24	HASSAN	66	TRANSFORMER	HV3	BALEHONNUR_66	10:58	12:03	01:05	LINE CLEAR AVAILED
2278	15-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	07:15	07:30	00:15	TRIPPED ON FAULT
2279	15-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	09:05	09:10	00:05	LINE CLEAR AVAILED
2280	15-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	09:50	20:05	10:15	TRIPPED ON FAULT
2281	15-Feb-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	08:05	08:17	00:12	TRIPPED ON FAULT
2282	15-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	9:26(14.2.2024)			LINE CLEAR AVAILED
2283	15-Feb-24	HASSAN	110	TRANSFORMER	HV1	BANTWAL_110	10:35	12:59	02:24	LINE CLEAR AVAILED
2284	15-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	9:26(14.2.2024)	16:33(15.02.2024)		LINE CLEAR AVAILED
2285	15-Feb-24	HASSAN	110	TRANSFORMER	HV2	HOSANGADI_110	11:30	13:30	02:00	LINE CLEAR AVAILED
2286	15-Feb-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	12:21	13:07	00:46	TRIPPED ON FAULT
2287	15-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	09:54	14:40	04:46	LINE CLEAR AVAILED
2288	15-Feb-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	11:42	14:30	02:48	LINE CLEAR AVAILED
2289	15-Feb-24	HASSAN	110	LINE	LPH	JOG_110	09:55	16:22	06:27	LINE CLEAR AVAILED
2290	15-Feb-24	HASSAN	110	LINE	LPH-MGHE 1	gen_lph	10:22	16:22	06:00	LINE CLEAR AVAILED
2291	15-Feb-24	HASSAN	110	LINE	MRSSHM-MPM	MRSMSG_220	09:10	13:01	03:51	LINE CLEAR AVAILED
2292	15-Feb-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_66	10:18	10:45	00:27	LINE CLEAR AVAILED
2293	15-Feb-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_66	11:31	13:03	01:32	LINE CLEAR AVAILED
2294	15-Feb-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	10:54	15:25	04:31	LINE CLEAR AVAILED
2295	15-Feb-24	HASSAN	220	LINE	KEMAR-Varahi3	KEMAR_220	12:05	12:56	00:51	LINE CLEAR AVAILED
2296	15-Feb-24	HASSAN	220	LINE	KEMAR-Varahi3	KEMAR_220	14:16	14:40	00:24	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2297	15-Feb-24	HASSAN	220	LINE	VARAHI-KEMAR2	gen_varahi	10:54	15:25	04:31	LINE CLEAR AVAILED
2298	15-Feb-24	MYSORE	66	LINE	ARAYALLI-VAJMANGALA-KADAKOLA 1	AYRALLI_66	07:50	18:15	10:25	LINE CLEAR AVAILED
2299	15-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
2300	15-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	BEGUR_66 B MATKERE_66	12:50	12:53	00:03	TRIPPED ON FAULT
2301	15-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 2	BEGUR_66 B MATKERE_66	12:50	12:53	00:03	TRIPPED ON FAULT
2302	15-Feb-24	MYSORE	66	LINE	BEGUR 220-HARVEY	HARVEY_66	12:50	12:53	00:03	TRIPPED ON FAULT
2303	15-Feb-24	MYSORE	66	LINE	BEGUR 220-SANTHE SARGURU	CHANDRAVADI_66 HURA_66 SANTHESARAGUR_66	12:50	12:53	00:03	TRIPPED ON FAULT
2304	15-Feb-24	MYSORE	66	LINE	BEGUR 220-SINDHUVALLI	SINDHUVALLI_66	12:50	12:53	00:03	TRIPPED ON FAULT
2305	15-Feb-24	MYSORE	66	LINE	CR NAGARA-HONNALLI	ATTIGULIPURA_66 ARKALVADI_66 HONNALLY_MYS_66	09:54	10:01	00:07	TRIPPED ON FAULT
2306	15-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
2307	15-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
2308	15-Feb-24	MYSORE	66	LINE	HD KOTE-TARAKA-ANTHRASANTHE	ANTHARSANTHE_66	10:40	17:00	06:20	LINE CLEAR AVAILED
2309	15-Feb-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 CHANDALLI_66 PARINAMIPURA_66 THUMBLA_66 THALAKADU_66 VYASRAJPURA_66	09:15	09:34	00:19	TRIPPED ON FAULT
2310	15-Feb-24	MYSORE	66	LINE	HEBBANI-SATHEGALA	KOLLEGALA_66 SATHEGALA_66	09:23	09:40	00:17	TRIPPED ON FAULT
2311	15-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
2312	15-Feb-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	10:40	18:38	07:58	LINE CLEAR AVAILED
2313	15-Feb-24	MYSORE	66	TRANSFORMER	HV1	KADAKOLA_220	10:44	12:30	01:45	LINE CLEAR AVAILED
2314	15-Feb-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	13:40	13:45	00:05	TRIPPED ON FAULT
2315	15-Feb-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	08:00	08:15	00:15	LINE CLEAR AVAILED
2316	15-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2317	15-Feb-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	10:40	18:38	07:58	LINE CLEAR AVAILED
2318	15-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	12:01	13:05	01:03	LINE CLEAR AVAILED
2319	15-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	19:46	19:52	00:06	TRIPPED ON FAULT
2320	15-Feb-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	10:00	14:25	04:25	LINE CLEAR AVAILED
2321	15-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2322	15-Feb-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA(K)	ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 YERALLI HAND POST_66	10:45	13:39	02:54	LINE CLEAR AVAILED
2323	15-Feb-24	MYSORE	66	LINE	KADAKOLA-DOORA	CHANDRAVADI, DOORA, HURA & HULLALLI STATIONS INTERRUPTED.	12:50	13:03	00:12	TRIPPED ON FAULT
2324	15-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220- HARANGI	NO STATIONS EFFECTED	12:12	12:27	00:14	TRIPPED ON FAULT
2325	15-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	08:52	17:09	08:16	LINE CLEAR AVAILED
2326	15-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	21:13 (15/02/2024)			LINE CLEAR AVAILED
2327	15-Feb-24	MYSORE	66	LINE	PERIYAPATNA-PONNAMPETE	PONNAMPET_66 SRIMANGALA_66 VIRAJPET_66	18:50	21:14	02:23	LINE CLEAR AVAILED
2328	15-Feb-24	MYSORE	66	LINE	PONNAMPETE-PERIYAPATNA	PONNAMPET_66 SRIMANGALA_66 VIRAJPET_66	19:11	21:14	02:03	LINE CLEAR AVAILED
2329	15-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	06:40	08:58	02:18	LINE CLEAR AVAILED
2330	15-Feb-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	06:40	08:58	02:18	LINE CLEAR AVAILED
2331	15-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	21:35 (14/2/2024)			TRIPPED ON FAULT
2332	15-Feb-24	MYSORE	66	LINE	VIRAJPETE-MADIKERI	PONNAMPET_66 SRIMANGALA_66 VIRAJPET_66	18:50	19:52	01:02	TRIPPED ON FAULT
2333	15-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:10 (14/2/2024)	7:07 (15/02/2024)	9:56 HRs	LINE CLEAR AVAILED
2334	15-Feb-24	MYSORE	220	LINE	NAGAMANGALA 220- ANCHEPALYA-1	NO STATIONS EFFECTED	10:05	11:50	01:45	LINE CLEAR AVAILED
2335	15-Feb-24	MYSORE	220	LINE	NAGAMANGALA 220- ANCHEPALYA-2	NO STATIONS EFFECTED	11:52	13:18	01:26	LINE CLEAR AVAILED
2336	15-Feb-24	TUMKUR	66	LINE	DASUDI_66--HIRIYUR 220KV	DASUDI_66	10:55	11:20	00:25	MAIN SUPPLY FAILURE
2337	15-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- ANGODU 66	ANGODU_66	09:15	09:25	00:10	TRIPPED ON FAULT
2338	15-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE66	MELLEKATTE_66, SOKKE_66	09:08	09:35	00:27	LINE CLEAR AVAILED
2339	15-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE66	MELLEKATTE_66, SOKKE_66	22:02	22:16	00:14	LINE CLEAR AVAILED
2340	15-Feb-24	TUMKUR	66	LINE	HEBBUR-ANCHEPALYA	HEBBUR_66,THIMMASANDRA_66,B HAKTHARAHALLI_66,HONNENAHALLI_66	18:20	19:20	01:00	TRIPPED ON FAULT
2341	15-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:00	11:23	00:23	MAIN SUPPLY FAILURE
2342	15-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- SIRA(HIRIYUR)	HIRIYUR_66	11:00	11:21	00:21	MAIN SUPPLY FAILURE
2343	15-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:00	11:18	00:18	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2344	15-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66,PDKOTE_66	02:50	03:02	00:12	TRIPPED ON FAULT
2345	15-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66,PDKOTE_66	11:00	11:18	00:18	MAIN SUPPLY FAILURE
2346	15-Feb-24	TUMKUR	66	LINE	HOSAKERE- MIDIGESHI	ID HALLI_66,HOSKERE_66, MIDIGESHI_66	12:03	12:12	00:09	TRIPPED ON FAULT
2347	15-Feb-24	TUMKUR	66	TRANSFORMER	HV-1	HIRIYUR_220	10:55	11:20	00:25	TRIPPED ON FAULT
2348	15-Feb-24	TUMKUR	66	TRANSFORMER	HV-3	HIRIYUR_220	10:55	11:20	00:25	TRIPPED ON FAULT
2349	15-Feb-24	TUMKUR	66	LINE	MATHOD- PANCHANAHALLI	PANCHANAHALLI,GARAGA_66	12:34	12:38	00:04	LINE CLEAR AVAILED
2350	15-Feb-24	TUMKUR	66	LINE	MATHOD-HIRIYUR_220KV-LINE-1&2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	10:55	11:53	00:58	MAIN SUPPLY FAILURE
2351	15-Feb-24	TUMKUR	66	LINE	MATHOD-HIRIYUR_220KV-LINE-1&2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	11:35	11:53	00:18	LINE CLEAR AVAILED
2352	15-Feb-24	TUMKUR	66	LINE	MATHOD-HIRIYUR_220KV-LINE-1&2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	12:22	12:30	00:08	LINE CLEAR AVAILED
2353	15-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2354	15-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	TMTP_66	17:00	18:12	01:12	LINE CLEAR AVAILED
2355	15-Feb-24	TUMKUR	66	TRANSFORMER	TR-1&TR-2	TMTP_66	13:10	15:16	02:06	LINE CLEAR AVAILED
2356	15-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KADAJJII_66	15:42	15:46	00:04	TRIPPED ON FAULT
2357	15-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	SASALUHALLA_66	00:00	02:05	02:05	LINE CLEAR AVAILED
2358	15-Feb-24	TUMKUR	220	LINE	ANCHEPALYA 220kV-NELMANGALA 1(NAGAMANGALA 1)	ANCHEPALYA_220	10:05	11:49	01:44	LINE CLEAR AVAILED
2359	15-Feb-24	TUMKUR	220	LINE	ANCHEPALYA 220kV-NELMANGALA 1(NAGAMANGALA 2)	ANCHEPALYA_220	11:52	13:17	01:25	LINE CLEAR AVAILED
2360	15-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:53	19:15	08:22	LINE CLEAR AVAILED
2361	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UAS_110	10:00	17:10	07:10	LINE CLEAR AVAILED
2362	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MUKARTHIHAL_110	11:20	13:20	02:00	LINE CLEAR AVAILED
2363	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA-HV2)	MUDDEBIHAL_110	14:51	15:52	01:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2364	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA-HV2)	HANAGAL_110	08:10	18:10	10:00	TRIPPED ON FAULT
2365	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	UAS_110	10:00	17:10	07:10	LINE CLEAR AVAILED
2366	16-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	VAJRAMATTI_110	17:25	18:24	00:59	LINE CLEAR AVAILED
2367	16-Feb-24	BAGALKOTE	110	LINE	ANKALI-SHIVASHAKTI CO GEG	ANKALI_110	07:15	07:30	00:15	TRIPPED ON FAULT
2368	16-Feb-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)	20:08 (16.02.2024)	10:03	LINE CLEAR AVAILED
2369	16-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2370	16-Feb-24	BAGALKOTE	110	LINE	CHIKKODI- RAIBAG 1 & 2	CHIKKODI_220	10:06	17:46	07:40	LINE CLEAR AVAILED
2371	16-Feb-24	BAGALKOTE	110	LINE	DAMBAL-GADAG1(MUNDARAGI2)	DAMBAL_110	10:30 (14.02.2024)	12:21 (16.02.2024)	49:51:00	LINE CLEAR AVAILED
2372	16-Feb-24	BAGALKOTE	110	LINE	GADAG-BETAGERI(ROD)	GADAG_220	10:29	10:49	00:20	LINE CLEAR AVAILED
2373	16-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
2374	16-Feb-24	BAGALKOTE	110	LINE	HIREHAL-ROD	HIREHAL_110	08:40	10:58	02:18	LINE CLEAR AVAILED
2375	16-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUND	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2376	16-Feb-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	13:09	17:53	04:44	LINE CLEAR AVAILED
2377	16-Feb-24	BAGALKOTE	110	LINE	KONNUR-NAVALGUND	KONNUR_110	11:10	18:40	07:30	LINE CLEAR AVAILED
2378	16-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2379	16-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2380	16-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR-NARENDRA1	MRUTHYUNJAYANAGAR_110	10:35	13:28	02:53	LINE CLEAR AVAILED
2381	16-Feb-24	BAGALKOTE	110	LINE	MRUTHYUNJAYANAGAR-NARENDRA2(UAS)	MRUTHYUNJAYANAGAR_110	10:00	17:55	07:55	LINE CLEAR AVAILED
2382	16-Feb-24	BAGALKOTE	110	LINE	MUNDARAGI-DAMBAL2	MUNDARAGI_110	10:30 (15.02.2024)	11:21 (16.02.2024)	24:51:00	LINE CLEAR AVAILED
2383	16-Feb-24	BAGALKOTE	110	LINE	MUNDARAGI-VIJAYA SUGARS	MUNDARAGI_110	18:45	18:55	00:10	TRIPPED ON FAULT
2384	16-Feb-24	BAGALKOTE	110	LINE	NARAGAL-ROD	NARAGAL_110	10:16	11:18	01:02	LINE CLEAR AVAILED
2385	16-Feb-24	BAGALKOTE	110	LINE	NARENDRA-M R NAGAR	NARENDRA_220	10:39	13:22	02:43	LINE CLEAR AVAILED
2386	16-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	16:29 (05.02.2024)	11:19 (16.02.2024)	258:50:00	LINE CLEAR AVAILED
2387	16-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2388	16-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2389	16-Feb-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	10:18	10:50	00:32	LINE CLEAR AVAILED
2390	16-Feb-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	10:18	10:50	00:32	LINE CLEAR AVAILED
2391	16-Feb-24	BAGALKOTE	110	LINE	SHIGGOAN220-MUNDAGOD	MUNDAGOD_110	05:09	07:41	02:32	TRIPPED ON FAULT
2392	16-Feb-24	BAGALKOTE	110	LINE	TAKKALAKI-THORVI(KIADB)	TAKKALAKI_110	19:53	20:13	00:20	TRIPPED ON FAULT
2393	16-Feb-24	BAGALKOTE	110	LINE	TAKKALAKI-TIKOTA	TAKKALAKI_110	20:12	20:13	00:01	LINE CLEAR AVAILED
2394	16-Feb-24	BAGALKOTE	110	LINE	THORVI-BHUTNAL	THORVI_110	20:11	20:12	00:01	LINE CLEAR AVAILED
2395	16-Feb-24	BAGALKOTE	110	LINE	THORVI-TIKOTA	THORVI_110	20:10	20:14	00:04	LINE CLEAR AVAILED
2396	16-Feb-24	BAGALKOTE	110	LINE	UAS-F1(NARENDRA)	UAS_110	10:09	10:43	00:34	LINE CLEAR AVAILED
2397	16-Feb-24	BAGALKOTE	110	LINE	UAS-F2(MR NAGAR)	UAS_110	10:09	10:43	00:34	LINE CLEAR AVAILED
2398	16-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2399	16-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	KUDUCHI_220	12:22	14:46	02:24	LINE CLEAR AVAILED
2400	16-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV1	KUDUCHI_220	12:25	14:49	02:24	LINE CLEAR AVAILED
2401	16-Feb-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI_220	15:13	17:01	01:48	LINE CLEAR AVAILED
2402	16-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2403	16-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-KIADB1	BIJAPUR_220	19:52	20:07	00:15	TRIPPED ON FAULT
2404	16-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-KIADB1	BIJAPUR_220	19:52	20:07	00:15	TRIPPED ON FAULT
2405	16-Feb-24	BAGALKOTE	220	LINE	HUBLI-NARENDRA 1	HUBLI_220	11:41	19:48	08:07	LINE CLEAR AVAILED
2406	16-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2407	16-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2408	16-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2409	16-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	NO STATION AFFECTED	11:58	13:35	01:37	TRIPPED ON FAULT
2410	16-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	BANASHANKARI	05:07	05:12	00:05	LINE CLEAR AVAILED
2411	16-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2412	16-Feb-24	BENGALURU	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	HEJJALA, DODDERI, CHANDRAPPA CIRCLE	11:12	11:21	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2413	16-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, VANDARGUPPE, SANKALGERE, SHIVANAHALLI	08:48	08:57	00:09	TRIPPED ON FAULT
2414	16-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, VANDARGUPPE, SANKALGERE, SHIVANAHALLI	18:08	18:16	00:08	TRIPPED ON FAULT
2415	16-Feb-24	BENGALURU	66	LINE	66KV CHELUR - CHAKAVELU	CHELUR, CHAKAVELU	17:05	17:10	00:05	MAIN SUPPLY FAILURE
2416	16-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	16:32	16:35	00:03	LINE CLEAR AVAILED
2417	16-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGANAHALLI	16:35	18:30	01:55	LINE CLEAR AVAILED
2418	16-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	17:05	17:10	00:05	LINE CLEAR AVAILED
2419	16-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - IISC	IISc	13:43	13:48	00:05	LINE CLEAR AVAILED
2420	16-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	22:12	22:17	00:05	LINE CLEAR AVAILED
2421	16-Feb-24	BENGALURU	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	05:25	06:25	01:00	TRIPPED ON FAULT
2422	16-Feb-24	BENGALURU	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	MATHIKERE, KEMPANAHALLI, URAGAHALLI, CHIKKAGANGANAWADI, KOOTAGAL, JALAMANGALA, MELEHALLI	21:00	21:15	00:15	TRIPPED ON FAULT
2423	16-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	00:03	01:08	01:05	MAIN SUPPLY FAILURE
2424	16-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPET	12:05	12:10	00:05	LINE CLEAR AVAILED
2425	16-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA	17:15	18:25	01:10	LINE CLEAR AVAILED
2426	16-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - BRIGADE GATEWAY (GIS)	BRIGADE GATEWAY	00:03	00:37	00:34	MAIN SUPPLY FAILURE
2427	16-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	00:05	01:36	01:31	MAIN SUPPLY FAILURE
2428	16-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	00:03	00:52	00:49	MAIN SUPPLY FAILURE
2429	16-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	00:03	01:55	01:52	MAIN SUPPLY FAILURE
2430	16-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	16:36	20:53	04:17	TRIPPED ON FAULT
2431	16-Feb-24	BENGALURU	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	00:05	00:21	00:16	MAIN SUPPLY FAILURE
2432	16-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - REMCO GIS	REMCO(HV2)	00:05	00:25	00:20	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2433	16-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - SIR. MV LAYOUT	SIR MV LAYOUT	00:05	01:38	01:33	MAIN SUPPLY FAILURE
2434	16-Feb-24	BENGALURU	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	18:25	18:30	00:05	MAIN SUPPLY FAILURE
2435	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIJAYANAGARA	00:01	01:18	01:17	MAIN SUPPLY FAILURE
2436	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VRISHABHAVATHI 220	00:05	01:22	01:17	MAIN SUPPLY FAILURE
2437	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DIVYASHREE TECH PARK	11:30	11:35	00:05	LINE CLEAR AVAILED
2438	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 220	13:09	13:14	00:05	TRIPPED ON FAULT
2439	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 220	15:12	15:16	00:04	TRIPPED ON FAULT
2440	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	IRAGAMPALLI	17:50	18:10	00:20	LINE CLEAR AVAILED
2441	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GUNDAMGERE	22:10	22:15	00:05	TRIPPED ON FAULT
2442	16-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DALASANUR	17:45	18:10	00:25	LINE CLEAR AVAILED
2443	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIJAYANAGARA	00:01	00:44	00:43	MAIN SUPPLY FAILURE
2444	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VRISHABHAVATHI 220	00:05	01:22	01:17	MAIN SUPPLY FAILURE
2445	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	IRAGAMPALLI	15:50	17:50	02:00	LINE CLEAR AVAILED
2446	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KUNDANA	12:45	12:55	00:10	TRIPPED ON FAULT
2447	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SM MANGALA	07:40	07:45	00:05	LINE CLEAR AVAILED
2448	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SM MANGALA	17:00	17:05	00:05	LINE CLEAR AVAILED
2449	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TAMAKA	13:05	13:35	00:30	LINE CLEAR AVAILED
2450	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MALUR I/A	16:20	16:52	00:32	LINE CLEAR AVAILED
2451	16-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DASHAVARA	15:30	16:10	00:40	LINE CLEAR AVAILED
2452	16-Feb-24	BENGALURU	66	TRANSFORMER	HV3	YARANDANAHALLI 220	12:36	17:23	04:47	TRIPPED ON FAULT
2453	16-Feb-24	BENGALURU	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 1	BANGARPET RAILWAY TRACTION	10:11	10:55	00:44	TRIPPED ON FAULT
2454	16-Feb-24	BENGALURU	220	LINE	220KV KUMBALAGODU 220 - VRUSHBHAVATHI 220	KUMBALAGODU 220	00:03	01:08	01:05	MAIN SUPPLY FAILURE
2455	16-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - TATHAGUNI 220	TATHAGUNI 220, VRISHABHAVATHI 220, KUMBALAGODU 220	00:05	00:27	00:22	TRIPPED ON FAULT
2456	16-Feb-24	BENGALURU	220	LINE	220kV SRS PEENYA 220 - NRS 220	NRS 220	00:03	00:31	00:28	TRIPPED ON FAULT
2457	16-Feb-24	BENGALURU	220	TRANSFORMER	HV1	VRISHABHAVATHI 220	00:05	01:17	01:12	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2458	16-Feb-24	BENGALURU	220	TRANSFORMER	HV2	VRISHABHAVATHI 220	00:05	01:17	01:12	MAIN SUPPLY FAILURE
2459	16-Feb-2024	GULBARGA	66	LINE	BENNEHALLI-KOTTUR	KOTTUR_66	11:05	13:00	01:55	LINE CLEAR AVAILED
2460	16-Feb-2024	GULBARGA	66	LINE	HANGAL-GUDDEKOTE	C J HALLI_66, HOSAHALLI_66	11:45	12:05	00:20	TRIPPED ON FAULT
2461	16-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	CJ HALLI_66	12:10	13:20	01:10	LINE CLEAR AVAILED
2462	16-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66,LIS(KNNL)_66	02:05	02:10	00:05	TRIPPED ON FAULT
2463	16-Feb-2024	GULBARGA	110	LINE	BYAGWAT-MALLAT	BYAGWAT_110, VALKAMDINI_110	19:57	20:05	00:08	TRIPPED ON FAULT
2464	16-Feb-2024	GULBARGA	110	LINE	GUTTLA-MYLAR	MYLAR_110	12:35	14:35	02:00	LINE CLEAR AVAILED
2465	16-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	GANGAVATI_110	04:35	09:55	05:20	LINE CLEAR AVAILED
2466	16-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	09:07	09:22	00:15	LINE CLEAR AVAILED
2467	16-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	YADGIR_110	12:35	12:40	00:05	TRIPPED ON FAULT
2468	16-Feb-2024	GULBARGA	110	LINE	KAPNOOR-MADIYAL	MADIYAL_110	04:04	04:18	00:14	TRIPPED ON FAULT
2469	16-Feb-2024	GULBARGA	110	LINE	KARAJAGI-AFZALPUR	KARAJAGI_110	08:48	09:00	00:12	TRIPPED ON FAULT
2470	16-Feb-2024	GULBARGA	110	LINE	MUNIRABAD-KAMALAPUR	KAMALAPUR_110,TORANGALU_110,METRI_110	09:00	19:00	10:00	LINE CLEAR AVAILED
2471	16-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	07:55	12:50	04:55	LINE CLEAR AVAILED
2472	16-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	ALIPUR_220	14:31	18:08	03:37	LINE CLEAR AVAILED
2473	16-Feb-2024	GULBARGA	220	TRANSFORMER	HV2	ALIPUR_220	10:01	13:53	03:52	LINE CLEAR AVAILED
2474	16-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-MALLAT	MALLAT_220	16:20	19:10	02:50	LINE CLEAR AVAILED
2475	16-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS1	RTPS_400	07:16	11:10	03:54	LINE CLEAR AVAILED
2476	16-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS2	RTPS_400	11:42	14:39	02:57	LINE CLEAR AVAILED
2477	16-Feb-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	14:23	15:25	01:02	TRIPPED ON FAULT
2478	16-Feb-24	HASSAN	66	TRANSFORMER	BALEHN-HV3	BALEHONNUR_66	06:27	07:01	00:34	TRIPPED ON FAULT
2479	16-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	bhadra_gen	12:10	12:36	00:26	LINE CLEAR AVAILED
2480	16-Feb-24	HASSAN	66	LINE	HASSAN220-ARAKALGUD1	HASSAN_220	11:10	11:21	00:11	TRIPPED ON FAULT
2481	16-Feb-24	HASSAN	66	LINE	HASSAN220-ARAKALGUD2	HASSAN_220	11:02	11:49	00:47	TRIPPED ON FAULT
2482	16-Feb-24	HASSAN	66	TRANSFORMER	HV2	UDAYAPURA_66	00:40	00:45	00:05	TRIPPED ON FAULT
2483	16-Feb-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	06:21	08:42	02:21	LINE CLEAR AVAILED
2484	16-Feb-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	08:51	08:58	00:07	TRIPPED ON FAULT
2485	16-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	08:46	08:48	00:02	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2486	16-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	09:01	09:20	00:19	MAIN SUPPLY FAILURE
2487	16-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	15:05	15:15	00:10	LINE CLEAR AVAILED
2488	16-Feb-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANAKERE_110	09:19	12:23	03:04	LINE CLEAR AVAILED
2489	16-Feb-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	11:44	12:46	01:02	LINE CLEAR AVAILED
2490	16-Feb-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	11:44	12:46	01:02	LINE CLEAR AVAILED
2491	16-Feb-24	HASSAN	110	TRANSFORMER	HV1	MSEZ_220	10:10	13:40	03:30	LINE CLEAR AVAILED
2492	16-Feb-24	HASSAN	110	TRANSFORMER	HV2	HOSANGADI_110	10:03	19:26	09:23	LINE CLEAR AVAILED
2493	16-Feb-24	HASSAN	110	LINE	KADUR-BANVR	KADUR_220	18:02	18:14	00:12	TRIPPED ON FAULT
2494	16-Feb-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	09:04	12:23	03:19	TRIPPED ON FAULT
2495	16-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	17:24	17:50	00:26	TRIPPED ON FAULT
2496	16-Feb-24	HASSAN	110	LINE	LPH-LST4	lph_gen	12:14	18:17	06:03	LINE CLEAR AVAILED
2497	16-Feb-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	09:39	09:51	00:12	TRIPPED ON FAULT
2498	16-Feb-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	10:46	11:44	00:58	TRIPPED ON FAULT
2499	16-Feb-24	HASSAN	220	LINE	MRSSHM-DAVANGERE	MRSMSG_220	12:23	14:14	01:51	TRIPPED ON FAULT
2500	16-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
2501	16-Feb-24	MYSORE	66	LINE	BEGUR-B MATGERE	BMATTEKERE_66	07:16	07:30	00:14	TRIPPED ON FAULT
2502	16-Feb-24	MYSORE	66	LINE	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	01:22	01:27	00:05	TRIPPED ON FAULT
2503	16-Feb-24	MYSORE	66	LINE	CHIKKAMANDYA-HAMPAPURA	HAMPAPURA_66	01:28	08:00	06:32	TRIPPED ON FAULT
2504	16-Feb-24	MYSORE	66	LINE	DOORA-HULLALI 2	HULLAHALLI_66	18:29	19:02	00:32	TRIPPED ON FAULT
2505	16-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
2506	16-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
2507	16-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
2508	16-Feb-24	MYSORE	66	LINE	HOOTGALLY-BOGADHI	NO STATIONS EFFECTED	13:54	14:22	00:28	LINE CLEAR AVAILED
2509	16-Feb-24	MYSORE	66	LINE	HULLALLI-CHANDRAWADI	HULLAHALLI_66	18:29	19:02	00:32	TRIPPED ON FAULT
2510	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	08:05	16:38	08:33	LINE CLEAR AVAILED
2511	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	16:50	17:43	00:53	LINE CLEAR AVAILED
2512	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	KHB_66	17:09	17:16	00:06	LINE CLEAR AVAILED
2513	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	07:46	07:50	00:03	TRIPPED ON FAULT
2514	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	ANEGOLA_66	14:45	14:50	00:05	TRIPPED ON FAULT
2515	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA(K)_66	16:40	16:55	00:15	TRIPPED ON FAULT
2516	16-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2517	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	07:58	08:05	00:07	TRIPPED ON FAULT
2518	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	08:05	16:38	08:33	LINE CLEAR AVAILED
2519	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	16:42	16:45	00:03	LINE CLEAR AVAILED
2520	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	16:47	16:50	00:03	LINE CLEAR AVAILED
2521	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	16:50	17:43	00:53	LINE CLEAR AVAILED
2522	16-Feb-24	MYSORE	66	TRANSFORMER	HV2	ANEGOLA_66	14:20	17:45	03:25	LINE CLEAR AVAILED
2523	16-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
2524	16-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 1	NO STATIONS EFFECTED	10:23	15:51	05:28	LINE CLEAR AVAILED
2525	16-Feb-24	MYSORE	66	LINE	KUSHALANAGARA-RAMANTHAPURA1	RUDRAPATNA_66 CHIKKABOMMANAHALLI_66 ALURSIDDAPURA_66 KANAGALU_66	10:10	18:58	08:48	LINE CLEAR AVAILED
2526	16-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	06:19	06:24	00:04	LINE CLEAR AVAILED
2527	16-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	17:01	21:09	04:08	LINE CLEAR AVAILED
2528	16-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	14:22	17:01	02:38	LINE CLEAR AVAILED
2529	16-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	21:13 (15/02/2024)	13:54 (16/2/2024)	16:40 HRs	LINE CLEAR AVAILED
2530	16-Feb-24	MYSORE	66	LINE	PANDAVAPURA-CHINNAKURLI	NO STATIONS EFFECTED	06:49	06:58	00:09	TRIPPED ON FAULT
2531	16-Feb-24	MYSORE	66	LINE	SFC SHIVA-PGL	NO STATIONS EFFECTED	06:35	08:05	01:30	LINE CLEAR AVAILED
2532	16-Feb-24	MYSORE	66	LINE	SFC SHIVA-PPCL	NO STATIONS EFFECTED	06:35	08:05	01:30	LINE CLEAR AVAILED
2533	16-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	11:40	12:25	00:45	LINE CLEAR AVAILED
2534	16-Feb-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	21:35 (14/2/2024)	12:25:00 (16/2/2024)	38:50:00	TRIPPED ON FAULT
2535	16-Feb-24	TUMKUR	66	LINE	Davangere SRS _ Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	01:30	01:40	00:10	TRIPPED ON FAULT
2536	16-Feb-24	TUMKUR	66	LINE	Davangere SRS _ Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	03:47	03:57	00:10	TRIPPED ON FAULT
2537	16-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	16:08	16:11	00:03	LINE CLEAR AVAILED
2538	16-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	19:34	19:37	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2539	16-Feb-24	TUMKUR	66	LINE	HANAGAL-GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	11:45	12:02	00:17	LINE CLEAR AVAILED
2540	16-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	03:00	03:35	00:35	TRIPPED ON FAULT
2541	16-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2542	16-Feb-24	TUMKUR	66	LINE	RAMAGIRI_66-BAGURU	RAMAGIRI_66	03:05	03:25	00:20	TRIPPED ON FAULT
2543	16-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHANNAGIRI_66	23:55	24:00:00	00:05	TRIPPED ON FAULT
2544	16-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BILCHODU_66	07:44	07:51	00:07	TRIPPED ON FAULT
2545	16-Feb-24	TUMKUR	66	TRANSFORMER	TR-2(LV SIDE)	DAVANGERE_SRS_220	16:23	19:10	02:47	LINE CLEAR AVAILED
2546	16-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)	14:34 (14.02.2024)	43 DAYS,5HR,16MIN.	LINE CLEAR AVAILED
2547	16-Feb-24	TUMKUR	220	TRANSFORMER	TR-2(HV SIDE)	DAVANGERE_SRS_220	16:23	19:03	02:40	LINE CLEAR AVAILED
2548	17-Feb-24	BAGALKOTE	110	LINE	BAGALKOT-F6-KERUR	BAGALKOT_220	09:16	09:39	0:23	TRIPPED ON FAULT
2549	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	RON_110	10:00	18:03	8:03	LINE CLEAR AVAILED
2550	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KUD DAHRWAD_110	10:00	16:28	6:28	LINE CLEAR AVAILED
2551	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED ZALKI_110	17:12	18:26	1:14	LINE CLEAR AVAILED
2552	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED BJCTY (THORVI)_110	16:05	16:10	0:05	LINE CLEAR AVAILED
2553	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED BJCTY (THORVI)_110	15:00	15:05	0:05	TRIPPED ON FAULT
2554	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ALBAL_110	11:48	13:30	1:42	LINE CLEAR AVAILED
2555	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	RON_110	10:00	18:03	8:03	LINE CLEAR AVAILED
2556	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KUD DAHRWAD_110	10:00	16:29	6:29	LINE CLEAR AVAILED
2557	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	RON_110	10:00	18:03	8:03	LINE CLEAR AVAILED
2558	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	BIJAPUR_220	10:00	10:27	0:27	LINE CLEAR AVAILED
2559	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	AHERI_220	10:24	16:42	6:18	LINE CLEAR AVAILED
2560	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BIJAPUR_220	10:00	10:27	0:27	LINE CLEAR AVAILED
2561	17-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED HIDAKAL_110	18:45	18:59	0:14	LINE CLEAR AVAILED
2562	17-Feb-24	BAGALKOTE	110	LINE	AHERI-DEVARAHIPPARAGI (SH-BB)	AHERI_220	10:24	16:43	6:19	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2563	17-Feb-24	BAGALKOTE	110	LINE	AHERI-LN3(SINDAGI)	AHERI_220	10:31	16:43	6:12	LINE CLEAR AVAILED
2564	17-Feb-24	BAGALKOTE	110	LINE	AHERI-LN4(CHANDAKAWATE)	AHERI_220	10:30	16:45	6:15	LINE CLEAR AVAILED
2565	17-Feb-24	BAGALKOTE	110	LINE	AHERI-LN5(ALMEL2)	AHERI_220	10:30	16:43	6:13	LINE CLEAR AVAILED
2566	17-Feb-24	BAGALKOTE	110	LINE	AHERI-LN7(ALMEL1)	AHERI_220	10:29	16:43	6:14	LINE CLEAR AVAILED
2567	17-Feb-24	BAGALKOTE	110	LINE	AHERI-MALAGHAN	AHERI_220	10:24	16:43	6:19	LINE CLEAR AVAILED
2568	17-Feb-24	BAGALKOTE	110	LINE	AHERI-MORATAGI	AHERI_220	10:24	16:43	6:19	LINE CLEAR AVAILED
2569	17-Feb-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA-2	AMBEWADI_220	10:23	14:09	3:46	LINE CLEAR AVAILED
2570	17-Feb-24	BAGALKOTE	110	LINE	ATHANI-BALIGERI	ATHANI_220	20:53	21:12	0:19	TRIPPED ON FAULT
2571	17-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2572	17-Feb-24	BAGALKOTE	110	LINE	GADAG-BETAGERI)RON	GADAG_220	11:10	17:45	6:35	LINE CLEAR AVAILED
2573	17-Feb-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	18:40 (17.02.2024)			LINE CLEAR AVAILED
2574	17-Feb-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON1	STATION NOT AFFECTED GAJENDRAGAD_110	10:45	18:40	7:55	LINE CLEAR AVAILED
2575	17-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
2576	17-Feb-24	BAGALKOTE	110	LINE	HAVERI-KNNL	HAVERI_220	11:17	19:11	7:54	LINE CLEAR AVAILED
2577	17-Feb-24	BAGALKOTE	110	LINE	HAVERI-TILUVALI	HAVERI_220	10:02	19:21	9:19	LINE CLEAR AVAILED
2578	17-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2579	17-Feb-24	BAGALKOTE	110	LINE	HUBLI-RAMANKOPPA	HUBLI_220	10:55	17:12	6:17	LINE CLEAR AVAILED
2580	17-Feb-24	BAGALKOTE	110	LINE	INDI220-HIREBENUR	INDI_220	10:15	17:11	6:56	LINE CLEAR AVAILED
2581	17-Feb-24	BAGALKOTE	110	LINE	INDI220-INDI	INDI_220	10:15	17:00	6:45	LINE CLEAR AVAILED
2582	17-Feb-24	BAGALKOTE	110	LINE	INDI220-LACHYAN	INDI_220	10:15	17:07	6:52	LINE CLEAR AVAILED
2583	17-Feb-24	BAGALKOTE	110	LINE	INDI220-SAVALSANG	INDI_220	10:15	16:50	6:35	LINE CLEAR AVAILED
2584	17-Feb-24	BAGALKOTE	110	LINE	INDI220-ZALAKI1	INDI_220	10:15	17:05	6:50	LINE CLEAR AVAILED
2585	17-Feb-24	BAGALKOTE	110	LINE	INDI220-ZALAKI2	INDI_220	10:15	17:05	6:50	LINE CLEAR AVAILED
2586	17-Feb-24	BAGALKOTE	110	LINE	KUD DHARWAD-LAKAMANAHALLI	KUD DAHRWAD_110	10:12	16:34	6:22	LINE CLEAR AVAILED
2587	17-Feb-24	BAGALKOTE	110	LINE	KUD DHARWAD-NARENDRA	KUD DAHRWAD_110	10:17	16:38	6:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2588	17-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	21:39	21:55	0:16	LINE CLEAR AVAILED
2589	17-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2590	17-Feb-24	BAGALKOTE	110	LINE	MAMDAPUR(B)- BABALESHWER	MAMDAPUR(B)_110 BABALESHWER_110	11:26	11:27	0:01	LINE CLEAR AVAILED
2591	17-Feb-24	BAGALKOTE	110	LINE	MAMDAPUR(B)-SHIRBUR	MAMDAPUR(B)_110 SHIRBUR_110	11:26	11:31	0:05	LINE CLEAR AVAILED
2592	17-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2593	17-Feb-24	BAGALKOTE	110	LINE	NAREGAL-RON	STATION NOT AFFECTED NAREGAL_110	10:22	18:02	7:40	LINE CLEAR AVAILED
2594	17-Feb-24	BAGALKOTE	110	LINE	NARENDRA-KUD1	NARENDRA_220	10:19	20:34	10:15	LINE CLEAR AVAILED
2595	17-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2596	17-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2597	17-Feb-24	BAGALKOTE	110	LINE	RAMANAKOPPA-SAVNUR (HUBLI220)	RAMANAKOPPA_110	10:35	18:33	7:58	LINE CLEAR AVAILED
2598	17-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- TUMMINAKATTI	RANEBENNUR_220	09:32	12:56	3:24	TRIPPED ON FAULT
2599	17-Feb-24	BAGALKOTE	110	LINE	RON-BELAVANKI	RON_110	10:35	17:50	7:15	LINE CLEAR AVAILED
2600	17-Feb-24	BAGALKOTE	110	LINE	RON-GADAG	RON_110	11:10	17:50	6:40	LINE CLEAR AVAILED
2601	17-Feb-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD 1&2	RON_110	10:55	18:39	7:44	LINE CLEAR AVAILED
2602	17-Feb-24	BAGALKOTE	110	LINE	RON-GAMESH IPP	RON_110 GAMESH IPP_110	10:48	18:25	7:37	LINE CLEAR AVAILED
2603	17-Feb-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	10:30	18:26	7:56	LINE CLEAR AVAILED
2604	17-Feb-24	BAGALKOTE	110	LINE	RONIHAL-F2 (MAMADAPUR)	STATION NOT AFFECTED RONIHAL_110	11:19	11:30	0:11	TRIPPED ON FAULT
2605	17-Feb-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	10:30	18:25	7:55	LINE CLEAR AVAILED
2606	17-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2607	17-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1,LV1	BIJAPUR_220	10:00	17:13	7:13	LINE CLEAR AVAILED
2608	17-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1,LV1	AHERI_220	10:59	16:41	5:42	LINE CLEAR AVAILED
2609	17-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	BIJAPUR_220	10:00	16:25	6:25	LINE CLEAR AVAILED
2610	17-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	AHERI_220	10:59	16:41	5:42	LINE CLEAR AVAILED
2611	17-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	BIJAPUR_220	10:00	16:25	6:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2612	17-Feb-24	BAGALKOTE	220	LINE	AHERI-F1(BIJAPUR 1)	AHERI_220	10:28	16:41	6:13	LINE CLEAR AVAILED
2613	17-Feb-24	BAGALKOTE	220	LINE	AHERI-F2(BIJAPUR 2)	AHERI_220	10:28	16:41	6:13	LINE CLEAR AVAILED
2614	17-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)			LINE CLEAR AVAILED
2615	17-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2616	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-AHERI1	BIJAPUR_220	11:17	16:29	5:12	LINE CLEAR AVAILED
2617	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-AHERI2	BIJAPUR_220	11:17	16:40	5:23	LINE CLEAR AVAILED
2618	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-GM NAVAR1	BIJAPUR_220	10:47	14:15	3:28	LINE CLEAR AVAILED
2619	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-GM NAVAR2	BIJAPUR_220	10:47	14:15	3:28	LINE CLEAR AVAILED
2620	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-INDI1	BIJAPUR_220	11:48	16:50	5:02	LINE CLEAR AVAILED
2621	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-INDI2	BIJAPUR_220	11:48	16:50	5:02	LINE CLEAR AVAILED
2622	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-VAISHALI1	BIJAPUR_220	10:23	14:15	3:52	LINE CLEAR AVAILED
2623	17-Feb-24	BAGALKOTE	220	LINE	BIJAPUR-VAISHALI2	BIJAPUR_220	10:23	14:15	3:52	LINE CLEAR AVAILED
2624	17-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	11:01 (17.02.2024)			LINE CLEAR AVAILED
2625	17-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	11:01 (17.02.2024)			LINE CLEAR AVAILED
2626	17-Feb-24	BAGALKOTE	220	LINE	HUBLI-NARENDRA 1	HUBLI_220	10:19	20:33	10:14	LINE CLEAR AVAILED
2627	17-Feb-24	BAGALKOTE	220	LINE	INDI220--BIJAPUR LINE1	INDI_220	10:15	16:50	6:35	LINE CLEAR AVAILED
2628	17-Feb-24	BAGALKOTE	220	LINE	INDI220-BIJAPUR LINE2	INDI_220	10:15	16:50	6:35	LINE CLEAR AVAILED
2629	17-Feb-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI1	NARENDRA_220	10:57	16:20	5:23	LINE CLEAR AVAILED
2630	17-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2631	17-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2632	17-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2633	17-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2634	17-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	12:10	12:15	00:05	LINE CLEAR AVAILED
2635	17-Feb-24	BENGALURU	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	HEJJALA, DODDERI, CHANDRAPPA CIRCLE	09:25	09:30	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2636	17-Feb-24	BENGALURU	66	LINE	66KV BOMMEPALLI - YENNIGADALE	BOMMEPALLI CROSS	14:08	14:15	00:07	LINE CLEAR AVAILED
2637	17-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	07:46	07:52	00:06	LINE CLEAR AVAILED
2638	17-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	EXORA 66, KALYANI TECH PARK	07:06	07:11	00:05	MAIN SUPPLY FAILURE
2639	17-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	08:00	08:05	00:05	LINE CLEAR AVAILED
2640	17-Feb-24	BENGALURU	66	LINE	66KV DEVARABISANAHALLI - SHOBHA JASMINE	SHOBHA APARTMENT	04:37	04:42	00:05	LINE CLEAR AVAILED
2641	17-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	09:50	09:55	00:05	LINE CLEAR AVAILED
2642	17-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	GODUR, MARALAWADI	18:11	18:16	00:05	TRIPPED ON FAULT
2643	17-Feb-24	BENGALURU	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	08:40	08:45	00:05	LINE CLEAR AVAILED
2644	17-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	21:20	21:25	00:05	LINE CLEAR AVAILED
2645	17-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	SOMENAHALLI, NALLIMARADANAHALLI	13:00	13:45	00:45	TRIPPED ON FAULT
2646	17-Feb-24	BENGALURU	66	LINE	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLI	18:00	18:06	00:06	LINE CLEAR AVAILED
2647	17-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	06:40	06:56	00:16	TRIPPED ON FAULT
2648	17-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	07:24	09:54	02:30	TRIPPED ON FAULT
2649	17-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI, BRIGADE ORCHIDS, KUNDANA	06:40	06:56	00:16	TRIPPED ON FAULT
2650	17-Feb-24	BENGALURU	66	LINE	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	SM MANGALA	18:15	18:20	00:05	LINE CLEAR AVAILED
2651	17-Feb-24	BENGALURU	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI CROSS, YENNIGADALE	08:04	08:05	00:01	LINE CLEAR AVAILED
2652	17-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	14:36	15:16	00:40	MAIN SUPPLY FAILURE
2653	17-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	14:36	15:19	00:43	MAIN SUPPLY FAILURE
2654	17-Feb-24	BENGALURU	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR, YELDUR	08:30	08:35	00:05	LINE CLEAR AVAILED
2655	17-Feb-24	BENGALURU	66	LINE	66KV T D HALLI (MALLASANDRA) - DALASANUR	DALASANUR, YELDUR	17:53	18:03	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2656	17-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	CESSNA 66, EXORA 66, KALYANI TECH PARK, KADUBISANAHALLI, CESSNA(EHT), ORACLE(EHT)	06:22	06:49	00:27	MAIN SUPPLY FAILURE
2657	17-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	06:22	07:03	00:41	MAIN SUPPLY FAILURE
2658	17-Feb-24	BENGALURU	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	YENNIGADALE	14:37	14:39	00:02	LINE CLEAR AVAILED
2659	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	15:10	15:13	00:03	LINE CLEAR AVAILED
2660	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	AUSTIN TOWN	11:22	11:24	00:02	LINE CLEAR AVAILED
2661	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DEVANGUNDHI	14:27	14:52	00:25	LINE CLEAR AVAILED
2662	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MULBAGAL	10:55	11:39	00:44	LINE CLEAR AVAILED
2663	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NANGLI	17:20	17:30	00:10	TRIPPED ON FAULT
2664	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SM MANGALA	07:10	07:20	00:10	LINE CLEAR AVAILED
2665	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SM MANGALA	15:05	15:10	00:05	LINE CLEAR AVAILED
2666	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	14:36	14:50	00:14	MAIN SUPPLY FAILURE
2667	17-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	15:09	15:15	00:06	LINE CLEAR AVAILED
2668	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DIVYASHREE TECH PARK	15:15	15:50	00:35	LINE CLEAR AVAILED
2669	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	AUSTIN TOWN	15:50	15:52	00:02	LINE CLEAR AVAILED
2670	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VOLVO	16:05	16:10	00:05	LINE CLEAR AVAILED
2671	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	CHELUR	09:55	10:05	00:10	TRIPPED ON FAULT
2672	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	CHELUR	13:10	13:20	00:10	TRIPPED ON FAULT
2673	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BEVOOR	09:09	09:23	00:14	TRIPPED ON FAULT
2674	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	14:36	14:50	00:14	MAIN SUPPLY FAILURE
2675	17-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	15:09	15:15	00:06	LINE CLEAR AVAILED
2676	17-Feb-24	BENGALURU	66	TRANSFORMER	HV3	AUSTIN TOWN	13:35	13:38	00:03	LINE CLEAR AVAILED
2677	17-Feb-24	BENGALURU	220	LINE	220KV HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	06:22	06:50	00:28	TRIPPED ON FAULT
2678	17-Feb-24	BENGALURU	220	LINE	220KV HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	06:22	07:02	00:40	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2679	17-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 2	SARJAPURA 220	14:36	14:49	00:13	MAIN SUPPLY FAILURE
2680	17-Feb-24	BENGALURU	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	NO STATION AFFECTED	14:27	17:34	03:07	LINE CLEAR AVAILED
2681	17-Feb-24	BENGALURU	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 2	NO STATION AFFECTED	09:56	13:32	03:36	LINE CLEAR AVAILED
2682	17-Feb-24	BENGALURU	220	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	06:22	07:15	00:53	MAIN SUPPLY FAILURE
2683	17-Feb-24	BENGALURU	220	TRANSFORMER	HV1	SARJAPURA 220	14:36	15:14	00:38	MAIN SUPPLY FAILURE
2684	17-Feb-24	BENGALURU	220	TRANSFORMER	HV2	SARJAPURA 220	14:36	15:14	00:38	MAIN SUPPLY FAILURE
2685	17-Feb-24	BENGALURU	400	LINE	400KV NELAMANGALA 400 - HASSAN	NO STATION AFFECTED	15:21	16:32	01:11	TRIPPED ON FAULT
2686	17-Feb-24	BENGALURU	400	LINE	400KV SINGANAYAKANAHALLI PGCIL 400 - NELAMANGALA 400	NO STATION AFFECTED	14:23	00:04(18/02/2024)	09:41	TRIPPED ON FAULT
2687	17-Feb-2024	GULBARGA	66	LINE	HANASI-CHILKANHATTI	CHILKANAHATTI_66	09:05	17:05	08:00	LINE CLEAR AVAILED
2688	17-Feb-2024	GULBARGA	66	LINE	HANGAL-GUDDEKAOTE	CJ HALLI_66, HOSAHALLI_66	11:00	11:10	00:10	LINE CLEAR AVAILED
2689	17-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1&2	MAGALA_66, GIRIYAPUR_66, SOVENHALLI_66	17:40	18:15	00:35	LINE CLEAR AVAILED
2690	17-Feb-2024	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALKI_110	14:20	14:25	00:05	TRIPPED ON FAULT
2691	17-Feb-2024	GULBARGA	110	LINE	HALBARGA-SANTHAPUR	SANTHAPUR_110	14:20	14:25	00:05	TRIPPED ON FAULT
2692	17-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KALBURGI NORTH_110	11:00	14:00	03:00	LINE CLEAR AVAILED
2693	17-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	04:20	05:20	01:00	TRIPPED ON FAULT
2694	17-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	KURUGOD_110	09:47	09:54	00:07	TRIPPED ON FAULT
2695	17-Feb-2024	GULBARGA	110	LINE	LINGASUGUR-MUDGAL	MUDAGAL_110	16:35	18:22	01:47	LINE CLEAR AVAILED
2696	17-Feb-2024	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	11:50	11:57	00:07	TRIPPED ON FAULT
2697	17-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	01:35	01:45	00:10	TRIPPED ON FAULT
2698	17-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	ITTAGI_220	11:25	15:35	04:10	LINE CLEAR AVAILED
2699	17-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-BASAVAN BAGEVADI	LINGASUGUR_220	07:14	09:15	02:01	LINE CLEAR AVAILED
2700	17-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	09:47	12:50	03:03	LINE CLEAR AVAILED
2701	17-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	09:47	12:50	03:03	LINE CLEAR AVAILED
2702	17-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-RTPS1	SHAHAPUR_220	12:52	18:53	06:01	LINE CLEAR AVAILED
2703	17-Feb-2024	GULBARGA	220	LINE	SULEKAL-KUSHTAGI	KUSHTAGI_220	19:52	00:00	04:08	TRIPPED ON FAULT
2704	17-Feb-24	HASSAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_110	13:01	13:13	00:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2705	17-Feb-24	HASSAN	66	LINE	HAGARE-HASSAN	HAGARE_66	00:14	00:22	00:08	LINE CLEAR AVAILED
2706	17-Feb-24	HASSAN	66	LINE	HAGARE-HASSAN	HAGARE_66	07:00	07:30	00:30	LINE CLEAR AVAILED
2707	17-Feb-24	HASSAN	66	TRANSFORMER	HV1	KANDLI_66	09:15	09:25	00:10	TRIPPED ON FAULT
2708	17-Feb-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	09:50	09:55	00:05	LINE CLEAR AVAILED
2709	17-Feb-24	HASSAN	110	TRANSFORMER	HV3	SHIRALKOPPA_110	15:30	17:00	01:30	LINE CLEAR AVAILED
2710	17-Feb-24	HASSAN	110	LINE	KAVOOR-BANTWAL	KAVOOR_220	10:01	10:13	00:12	TRIPPED ON FAULT
2711	17-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	18:23	18:46	00:23	TRIPPED ON FAULT
2712	17-Feb-24	HASSAN	110	LINE	SAGARA-HONNALLI	SAGARA_110	19:45	20:30	00:45	LINE CLEAR AVAILED
2713	17-Feb-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	15:24	15:34	00:10	LINE CLEAR AVAILED
2714	17-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
2715	17-Feb-24	MYSORE	66	LINE	BEGUR 220-SARGUR	CHANDRAVADI_66HURA_66SANTH ESARAGUR_66HDKOTE_66ANTHA RSANTHE_66HAMPAPURA_66B MATKERE_66YEREHALLIHANDPO ST_66	10:58	11:04	00:06	TRIPPED ON FAULT
2716	17-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
2717	17-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
2718	17-Feb-24	MYSORE	66	LINE	HEBBANI-MEGALAPURA	CHANDALLI_66THALAKADU_66BG PURA_66THUMBLA_66CHIDRAVAL LI_66VYASRAJPURA_66	08:26	08:38	00:12	TRIPPED ON FAULT
2719	17-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
2720	17-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAP 1	NO STATIONS EFFECTED	18:08	18:19	00:11	LINE CLEAR AVAILED
2721	17-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAP 2	NO STATIONS EFFECTED	18:08	18:15	00:07	LINE CLEAR AVAILED
2722	17-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	16:11	17:52	01:41	LINE CLEAR AVAILED
2723	17-Feb-24	MYSORE	66	LINE	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	18:25	18:29	00:03	LINE CLEAR AVAILED
2724	17-Feb-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	17:45	17:54	00:09	TRIPPED ON FAULT
2725	17-Feb-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	07:00	07:10	00:10	TRIPPED ON FAULT
2726	17-Feb-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	11:10	11:30	00:20	TRIPPED ON FAULT
2727	17-Feb-24	MYSORE	66	TRANSFORMER	HV1	HUNSUR_220	10:32	10:44	00:12	TRIPPED ON FAULT
2728	17-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2729	17-Feb-24	MYSORE	66	TRANSFORMER	HV2	BILIKERE_66	10:54	11:18	00:23	LINE CLEAR AVAILED
2730	17-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2731	17-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA	AYRALLI_66MARADIHUNDI_66	08:01	18:20	10:19	LINE CLEAR AVAILED
2732	17-Feb-24	MYSORE	66	LINE	KHB STATION-BILIKERE	NO STATIONS EFFECTED	09:28	10:16	00:47	LINE CLEAR AVAILED
2733	17-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	02:13	02:18	00:05	TRIPPED ON FAULT
2734	17-Feb-24	MYSORE	66	LINE	MYSORE-GIS	NO STATIONS EFFECTED	17:52	21:06	03:13	LINE CLEAR AVAILED
2735	17-Feb-24	MYSORE	66	LINE	PERIYAPATNA-HANGODU	NO STATIONS EFFECTED	11:40	12:41	01:01	LINE CLEAR AVAILED
2736	17-Feb-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	KOLLEGALA_66PARINAMIPURA_66 SATHEGALA_66	08:20	08:40	00:20	TRIPPED ON FAULT
2737	17-Feb-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	08:20	08:26	00:05	TRIPPED ON FAULT
2738	17-Feb-24	MYSORE	66	LINE	SFCSIVA-PPCL	NO STATIONS EFFECTED	08:30	16:23	07:53	LINE CLEAR AVAILED
2739	17-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:09 (17/02/2024)			LINE CLEAR AVAILED
2740	17-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV- DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:07	09:09	00:02	TRIPPED ON FAULT
2741	17-Feb-24	TUMKUR	66	LINE	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	14:30	15:15	00:45	MAIN SUPPLY FAILURE
2742	17-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- BARAMAGIRI	BARAMAGIRI_66	14:30	15:15	00:45	MAIN SUPPLY FAILURE
2743	17-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD1	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	14:30	15:12	00:42	LINE CLEAR AVAILED
2744	17-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	14:30	15:07	00:37	LINE CLEAR AVAILED
2745	17-Feb-24	TUMKUR	66	LINE	HONNUDIKE_66-HIREHALLI	HONNUDIKE_66	12:05	12:10	00:05	LINE CLEAR AVAILED
2746	17-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHITRAHALLI_66	12:50	12:55	00:04	TRIPPED ON FAULT
2747	17-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HONNALLI_66	11:56	12:04	00:07	LINE CLEAR AVAILED
2748	17-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HONNUDIKE_66	11:45	12:25	00:40	LINE CLEAR AVAILED
2749	17-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	KUKKAWADA_66	13:57	15:55	01:58	LINE CLEAR AVAILED
2750	17-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	CHANNAGIRI_66	07:30	07:35	00:05	TRIPPED ON FAULT
2751	17-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	CHANNAGIRI_66	07:35	07:40	00:05	TRIPPED ON FAULT
2752	17-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	CHANNAGIRI_66	09:00	09:05	00:05	TRIPPED ON FAULT
2753	17-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HONNALLI_66	11:56	12:03	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2754	17-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HONNUDIKE_66	11:30	12:05	00:35	LINE CLEAR AVAILED
2755	17-Feb-24	TUMKUR	66	TRANSFORMER	HV3(TR3)	HONNALLI_66	11:56	12:03	00:07	LINE CLEAR AVAILED
2756	17-Feb-24	TUMKUR	66	LINE	LV1(TR1)	PAVAGADA_220	10:20	10:40	00:20	TRIPPED ON FAULT
2757	17-Feb-24	TUMKUR	66	LINE	LV2(TR2)	PAVAGADA_220	10:20	10:40	00:20	TRIPPED ON FAULT
2758	17-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2759	17-Feb-24	TUMKUR	110	LINE	K G TEMPLE-UNGRDLI	KGTEMPLE_110	09:46	13:19	03:33	LINE CLEAR AVAILED
2760	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED ZALKI_110	2:28	2:48	0:20	TRIPPED ON FAULT
2761	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED KALADAGI_110	13:03	13:24	0:21	LINE CLEAR AVAILED
2762	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED HUNAGUND_110	17:00	17:36	0:36	LINE CLEAR AVAILED
2763	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BELAGAVI(NEHRUNAGAR)_110	9:15	13:34	4:19	LINE CLEAR AVAILED
2764	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	STATION NOT AFFECTED YARAGATTI_110	14:32	15:37	1:05	TRIPPED ON FAULT
2765	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	UCHAGAON_110	10:05	17:32	7:27	LINE CLEAR AVAILED
2766	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	BELAGAVI(NEHRUNAGAR)_110	9:15	13:35	4:20	LINE CLEAR AVAILED
2767	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED RATTIHALLI_110	22:05	22:11	0:06	TRIPPED ON FAULT
2768	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED RATTIHALLI_110	16:00	16:05	0:05	TRIPPED ON FAULT
2769	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED RATTIHALLI_110	22:45	22:50	0:05	TRIPPED ON FAULT
2770	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	BELAGAVI(NEHRUNAGAR)_110	10:45	13:35	2:50	LINE CLEAR AVAILED
2771	18-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	BELAGAVI(NEHRUNAGAR)_110	10:45	13:34	2:49	LINE CLEAR AVAILED
2772	18-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	06:42	07:24	0:42	TRIPPED ON FAULT
2773	18-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	7:26 (18.02.2024)			LINE CLEAR AVAILED
2774	18-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2775	18-Feb-24	BAGALKOTE	110	LINE	BELAGAVI-NEHRU NAGAR	BELAGAVI_220	11:01	13:22	2:21	LINE CLEAR AVAILED
2776	18-Feb-24	BAGALKOTE	110	LINE	BELAGAVI-UCHAGAON	BELAGAVI_220	10:11	14:02	3:51	LINE CLEAR AVAILED
2777	18-Feb-24	BAGALKOTE	110	LINE	BELGAVI(NEHRUNAGAR)-MACHE(KANABARGI)	BELAGAVI(NEHRUNAGAR)_110	10:58	13:33	2:35	LINE CLEAR AVAILED
2778	18-Feb-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	18:40 (17.02.2024)	8:34 (18.02.2024)	757:54:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2779	18-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA-MUDALAGI(MANTUR(GHP))	GHATAPRABHA_220	14:05	18:16	4:11	LINE CLEAR AVAILED
2780	18-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
2781	18-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2782	18-Feb-24	BAGALKOTE	110	LINE	KANABARGI-NEHARUNAGAR(BELGAVI)	KANABARGI_110	9:36	16:00	6:24	LINE CLEAR AVAILED
2783	18-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2784	18-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2785	18-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2786	18-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2787	18-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR-RATTIHALLI(HIREKERUR)	RANEBENNUR_220	14:00	14:07	0:07	TRIPPED ON FAULT
2788	18-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220-UDAKERI	SOUDATTI_220	15:47	16:03	0:16	TRIPPED ON FAULT
2789	18-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220-YARAGATTI	YARAGATTI_110	14:32	15:36	1:04	TRIPPED ON FAULT
2790	18-Feb-24	BAGALKOTE	110	LINE	UDYAMBAG-UCHAGAON	STATION NOT AFFECTED UDYAMBAG_110	10:08	14:20	4:12	LINE CLEAR AVAILED
2791	18-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2792	18-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)			LINE CLEAR AVAILED
2793	18-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2794	18-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	11:01 (17.02.2024)			LINE CLEAR AVAILED
2795	18-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	11:01 (17.02.2024)			LINE CLEAR AVAILED
2796	18-Feb-24	BAGALKOTE	220	LINE	HUBLI-NARENDRA 1	HUBLI_220	10:04	18:26	8:22	LINE CLEAR AVAILED
2797	18-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2798	18-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2799	18-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2800	18-Feb-24	BENGALURU	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	PLATINUM CITY	17:46	17:49	00:03	LINE CLEAR AVAILED
2801	18-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2802	18-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	66/25KV RAILWAY TRACTION SUBSTATION	17:33	17:45	00:12	TRIPPED ON FAULT
2803	18-Feb-24	BENGALURU	66	LINE	66KV DG2 PUTTENAHALLI 220 - SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	18:28	18:46	00:18	TRIPPED ON FAULT
2804	18-Feb-24	BENGALURU	66	LINE	66KV DG2 PUTTENAHALLI 220 - SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	18:46	18:55	00:09	TRIPPED ON FAULT
2805	18-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	22:40	23:05	00:25	TRIPPED ON FAULT
2806	18-Feb-24	BENGALURU	66	LINE	66KV GUNDLU KOTHUR - BAGEPALLI	NO STATION AFFECTED	18:30	18:40	00:10	TRIPPED ON FAULT
2807	18-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	NO STATION AFFECTED	15:12	18:58	03:46	LINE CLEAR AVAILED
2808	18-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - ISRO EHT	ISRO(EHT)	15:48	18:48	03:00	LINE CLEAR AVAILED
2809	18-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - IISC	IISc	23:20	23:28	00:08	LINE CLEAR AVAILED
2810	18-Feb-24	BENGALURU	66	LINE	66KV KODIHALLI - BIJJALLI - HUNASENAHALLI	BIJJAHALI, HUNASENAHALLI	15:35	15:55	00:20	TRIPPED ON FAULT
2811	18-Feb-24	BENGALURU	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	18:28	18:35	00:07	TRIPPED ON FAULT
2812	18-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	DODDERI, CHANDRAPPA CIRCLE	20:40	20:52	00:12	LINE CLEAR AVAILED
2813	18-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	05:09	05:14	00:05	LINE CLEAR AVAILED
2814	18-Feb-24	BENGALURU	66	LINE	66KV NRS 220 - IISC	IISc	04:30	04:35	00:05	LINE CLEAR AVAILED
2815	18-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - PLATINUM CITY DG-4	PLATINUM CITY	09:40	17:20	07:40	LINE CLEAR AVAILED
2816	18-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	NO STATION AFFECTED	09:16	12:10	02:54	TRIPPED ON FAULT
2817	18-Feb-24	BENGALURU	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	VIDHURASHWATHA, GUNDLU KOTTUR	18:30	18:40	00:10	TRIPPED ON FAULT
2818	18-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	23:04	23:12	00:08	LINE CLEAR AVAILED
2819	18-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA I/A, SYNGENE(EHT)	16:01	17:05	01:04	LINE CLEAR AVAILED
2820	18-Feb-24	BENGALURU	66	LINE	HAL 220 - HAL(EHT)	HAL(EHT)	10:08	12:38	02:30	LINE CLEAR AVAILED
2821	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HENNUR CROSS	10:08	10:18	00:10	TRIPPED ON FAULT
2822	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 220	07:50	07:58	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2823	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MAASTHI	18:00	18:55	00:55	LINE CLEAR AVAILED
2824	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MARALAWADI	17:35	17:47	00:12	TRIPPED ON FAULT
2825	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DABUSPETE 220	09:33	09:46	00:13	TRIPPED ON FAULT
2826	18-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BV HALLI	11:00	12:15	01:15	LINE CLEAR AVAILED
2827	18-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DABUSPETE 220	12:37	12:50	00:13	LINE CLEAR AVAILED
2828	18-Feb-24	BENGALURU	220	TRANSFORMER	HV1	GOWRIBIDANUR 220	18:31	19:17	00:46	TRIPPED ON FAULT
2829	18-Feb-24	BENGALURU	400	LINE	400KV NELAMANGALA 400 - TALAGUPPA	NO STATION AFFECTED	13:54	19:49	05:55	TRIPPED ON FAULT
2830	18-Feb-2024	GULBARGA	66	LINE	HANGAL-GUDDEKOTE	C J HALLI_66, HOSAHALLI_66	12:50	13:05	00:15	LINE CLEAR AVAILED
2831	18-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	BANAVEKAL_66	08:28	08:38	00:10	TRIPPED ON FAULT
2832	18-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	TAMBRAHALLI_66	06:50	07:10	00:20	TRIPPED ON FAULT
2833	18-Feb-2024	GULBARGA	66	LINE	KUDALAGI-HANASI	HANASI_66, CHILAKANAHATTI_66	19:20	19:35	00:15	TRIPPED ON FAULT
2834	18-Feb-2024	GULBARGA	110	LINE	KIADB KUDITINI-ALIPUR	KIADB KUDITINI_110,KUDITINI_110,KURUGOD_110,TORANGALU_110	13:48	13:58	00:10	TRIPPED ON FAULT
2835	18-Feb-2024	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	08:30	14:05	05:35	LINE CLEAR AVAILED
2836	18-Feb-2024	GULBARGA	110	LINE	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,TEKKALKOTE_110,SIRIGERICROSS_110,NSL SUGAR_IPP	20:45	21:08	00:23	TRIPPED ON FAULT
2837	18-Feb-2024	GULBARGA	110	LINE	YELBURGA-VAJJARBANDI	YELBURGA_110, KUKUNOR_110	08:49	09:30	00:41	TRIPPED ON FAULT
2838	18-Feb-2024	GULBARGA	220	LINE	SULEKAL-KUSHTAGI	KUSHTAGI_220	00:00	11:09	11:09	TRIPPED ON FAULT
2839	18-Feb-24	HASSAN	66	LINE	BASAVAG-DUDDA	BASAVAGHATTA_66	11:25	12:28	01:03	LINE CLEAR AVAILED
2840	18-Feb-24	HASSAN	66	LINE	DUDDA-BASAVAGHATTA	DUDDA_66	11:27	12:27	01:00	LINE CLEAR AVAILED
2841	18-Feb-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	16:23	17:25	01:02	LINE CLEAR AVAILED
2842	18-Feb-24	HASSAN	66	TRANSFORMER	HV1	HANUBAL_110	14:59	16:05	01:06	TRIPPED ON FAULT
2843	18-Feb-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	11:05	11:27	00:22	LINE CLEAR AVAILED
2844	18-Feb-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	12:02	13:26	01:24	LINE CLEAR AVAILED
2845	18-Feb-24	HASSAN	66	TRANSFORMER	HV1	SHANTHIGRAMA_66	07:34	07:57	00:23	TRIPPED ON FAULT
2846	18-Feb-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	13:21	13:26	00:05	LINE CLEAR AVAILED
2847	18-Feb-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	13:21	13:23	00:02	LINE CLEAR AVAILED
2848	18-Feb-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	13:21	13:23	00:02	LINE CLEAR AVAILED
2849	18-Feb-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	12:41	12:53	00:12	TRIPPED ON FAULT
2850	18-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG1	HOSANGADI_110	13:48	14:22	00:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2851	18-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG2	HOSANGADI_110	13:48	14:22	00:34	LINE CLEAR AVAILED
2852	18-Feb-24	HASSAN	110	TRANSFORMER	HV3	BAIKAMPADI_110	09:04	11:33	02:29	LINE CLEAR AVAILED
2853	18-Feb-24	HASSAN	110	TRANSFORMER	HV4	BAIKAMPADI_110	11:35	13:55	02:20	LINE CLEAR AVAILED
2854	18-Feb-24	HASSAN	110	LINE	MRSSHM-MPM	MRSMSG_220	08:57	19:41	10:44	LINE CLEAR AVAILED
2855	18-Feb-24	HASSAN	110	LINE	PUTTUR-PUTUR 1	PUTTUR_220	11:52	12:04	00:12	LINE CLEAR AVAILED
2856	18-Feb-24	HASSAN	110	LINE	PUTTUR-PUTUR 1	PUTTUR_220	15:32	15:43	00:11	LINE CLEAR AVAILED
2857	18-Feb-24	HASSAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	11:52	12:03	00:11	LINE CLEAR AVAILED
2858	18-Feb-24	HASSAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	15:32	15:43	00:11	LINE CLEAR AVAILED
2859	18-Feb-24	HASSAN	220	LINE	ARSK2-HSN	ARSIKERE_220	16:00	16:46	00:46	LINE CLEAR AVAILED
2860	18-Feb-24	HASSAN	220	LINE	GERSOPA-TALGUPA1	gen_gersoppa	12:20	12:47	00:27	LINE CLEAR AVAILED
2861	18-Feb-24	HASSAN	220	LINE	GERSOPA-TALGUPA2	gen_gersoppa	12:20	12:47	00:27	LINE CLEAR AVAILED
2862	18-Feb-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	11:52	12:02	00:10	LINE CLEAR AVAILED
2863	18-Feb-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	15:33	15:41	00:08	LINE CLEAR AVAILED
2864	18-Feb-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	11:54	12:02	00:08	LINE CLEAR AVAILED
2865	18-Feb-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	15:33	15:41	00:08	LINE CLEAR AVAILED
2866	18-Feb-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	12:05	15:19	03:14	LINE CLEAR AVAILED
2867	18-Feb-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	12:24	12:46	00:22	LINE CLEAR AVAILED
2868	18-Feb-24	HASSAN	220	LINE	PUTTUR-KEMAR1	PUTTUR_220	11:54	12:02	00:08	LINE CLEAR AVAILED
2869	18-Feb-24	HASSAN	220	LINE	PUTTUR-KEMAR1	PUTTUR_220	15:33	15:41	00:08	LINE CLEAR AVAILED
2870	18-Feb-24	HASSAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	13:53	19:49	05:56	TRIPPED ON FAULT
2871	18-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
2872	18-Feb-24	MYSORE	66	LINE	BEGUR 220-SARAGURU	ANTHARSANTHE_66 CHANDRAVADI_66 DOORA_66 HDKOTE_66 HURA_66 HULLAHALLI_66 SANTHESARAGUR_66 YERALLI HAND POST 66	09:09	09:16	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2873	18-Feb-24	MYSORE	66	LINE	BEGUR 220-SARAGURU	ANTHARSANTHE_66 CHANDRAVADI_66 DOORA_66 HDKOTE_66 HURA_66 HULLAHALLI_66 SANTHESARAGUR_66 YERALLI HAND POST_66	09:41	09:45	00:04	TRIPPED ON FAULT
2874	18-Feb-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBE_60	21:02			TRIPPED ON FAULT
2875	18-Feb-24	MYSORE	66	LINE	DODDINDHUVADI-KOTHANUR	NO STATIONS EFFECTED	15:20	16:40	01:20	LINE CLEAR AVAILED
2876	18-Feb-24	MYSORE	66	LINE	DODDINDHUVADI-MADHUVANAHALLI	DODDINADUVADI_66	14:05	16:50	02:45	LINE CLEAR AVAILED
2877	18-Feb-24	MYSORE	66	LINE	HAMPAPURA(K)-SARAGURU	NO STATIONS EFFECTED	09:40	09:45	00:04	LINE CLEAR AVAILED
2878	18-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
2879	18-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
2880	18-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
2881	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	BYLUKUPPE_66	13:47	13:57	00:10	TRIPPED ON FAULT
2882	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	CRNAGAR_220	20:58	21:52	00:54	LINE CLEAR AVAILED
2883	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	DODDINADUVADI_66	10:35	17:00	06:25	LINE CLEAR AVAILED
2884	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	LOKKANAHALLI_66	10:00	15:00	05:00	LINE CLEAR AVAILED
2885	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	13:03	13:49	00:46	LINE CLEAR AVAILED
2886	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	16:33	16:40	00:07	MAIN SUPPLY FAILURE
2887	18-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2888	18-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	13:05	13:30	00:25	LINE CLEAR AVAILED
2889	18-Feb-24	MYSORE	66	TRANSFORMER	HV2	DODDINADUVADI_66	10:35	17:00	06:25	LINE CLEAR AVAILED
2890	18-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADHUVANAHALLI_220	11:15	13:02	01:47	LINE CLEAR AVAILED
2891	18-Feb-24	MYSORE	66	TRANSFORMER	HV2	MALAVALLI_66	16:33	16:40	00:07	MAIN SUPPLY FAILURE
2892	18-Feb-24	MYSORE	66	TRANSFORMER	HV2	ANEGOLAL_66	18:05			LINE CLEAR AVAILED
2893	18-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
2894	18-Feb-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA(K)	HAMPAPURA(K)_66	09:08	09:17	00:08	TRIPPED ON FAULT
2895	18-Feb-24	MYSORE	66	LINE	KADAKOLA-DOORA	CHANDRAVADI_66 DOORA_66 HURA_66 HULLAHALLI_66	12:32	12:43	00:10	TRIPPED ON FAULT
2896	18-Feb-24	MYSORE	66	LINE	KRISHNAPURA-ANEGOLA	ANEGOLAL_66	18:05	18:30	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2897	18-Feb-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	15:00	15:05	00:05	TRIPPED ON FAULT
2898	18-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	13:25	14:55	01:30	LINE CLEAR AVAILED
2899	18-Feb-24	MYSORE	66	LINE	MUGUR-CR NAGARA	NO STATIONS EFFECTED	21:19			LINE CLEAR AVAILED
2900	18-Feb-24	MYSORE	66	LINE	SFC SIVA-10 MW	NO STATIONS EFFECTED	16:35	16:45	00:10	TRIPPED ON FAULT
2901	18-Feb-24	MYSORE	66	LINE	SFC SIVA-5 MW	NO STATIONS EFFECTED	16:35	16:42	00:07	TRIPPED ON FAULT
2902	18-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	16:33	16:40	00:06	TRIPPED ON FAULT
2903	18-Feb-24	MYSORE	66	LINE	YELANDURU-HONGANURU	NO STATIONS EFFECTED	21:35	21:55	00:19	LINE CLEAR AVAILED
2904	18-Feb-24	MYSORE	220	TRANSFORMER	HV1	CRNAGAR_220	20:58			TRIPPED ON FAULT
2905	18-Feb-24	MYSORE	220	TRANSFORMER	HV2	CRNAGAR_220	20:58	22:08	01:10	LINE CLEAR AVAILED
2906	18-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:09 (17/02/2024)	1:07 (18/02/2024)		LINE CLEAR AVAILED
2907	18-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220kV-URDIGERE	URDIGERE_66, KOLALA_66	11:14	12:30	01:16	TRIPPED ON FAULT
2908	18-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	21:25	21:35	00:10	TRIPPED ON FAULT
2909	18-Feb-24	TUMKUR	66	LINE	CHANNAGIRI-LINGDHLI	CHANNAGIRI_66	09:40	10:20	00:40	MAIN SUPPLY FAILURE
2910	18-Feb-24	TUMKUR	66	LINE	CHIKKAJAJUR-HOLALKERE-1	CHIKKAJAJUR_66	09:45	10:20	00:35	LINE CLEAR AVAILED
2911	18-Feb-24	TUMKUR	66	LINE	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	12:53	12:59	00:06	TRIPPED ON FAULT
2912	18-Feb-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66	09:32	10:13	00:41	LINE CLEAR AVAILED
2913	18-Feb-24	TUMKUR	66	LINE	HONNALLI 220k-BENKIKERE-1	BENKIKERE_220	09:32	10:14	00:42	LINE CLEAR AVAILED
2914	18-Feb-24	TUMKUR	66	LINE	HONNALLI 220k-BENKIKERE-2	BENKIKERE_220	09:32	10:14	00:42	LINE CLEAR AVAILED
2915	18-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	09:32	10:13	00:41	LINE CLEAR AVAILED
2916	18-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV-(LINGADAHALLI) NALLUR_66	NALLURU_66,	09:32	10:13	00:41	LINE CLEAR AVAILED
2917	18-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	KALMARANAHALLI_66	(17.2.24)17:43:40 PM			LINE CLEAR AVAILED
2918	18-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	STATIONS NOT INTERRUPTED	09:32	10:11	00:39	LINE CLEAR AVAILED
2919	18-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	KADAJII_66	15:00	15:03	00:03	TRIPPED ON FAULT
2920	18-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	THALLAK_66	15:55	18:40	02:45	LINE CLEAR AVAILED
2921	18-Feb-24	TUMKUR	66	LINE	KEREBILCHI-HONNALLI	KEREBILCHI_66	09:10	09:20	00:10	MAIN SUPPLY FAILURE
2922	18-Feb-24	TUMKUR	66	LINE	KEREBILCHI-HONNALLI	KEREBILCHI_66	10:40	11:20	00:40	MAIN SUPPLY FAILURE
2923	18-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-BADAVANAHALLI	MADHUGIRI_66, BADAVANAHALLI_66	01:35	01:45	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2924	18-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	01:35	01:45	00:10	TRIPPED ON FAULT
2925	18-Feb-24	TUMKUR	66	LINE	MADHURE_220- RAMAGIRI_66	RAMAGIRI_66, CHIKKAJAJUR_66	10:20	10:35	00:15	TRIPPED ON FAULT
2926	18-Feb-24	TUMKUR	66	LINE	NAGALAMADIKE-MADHUGIRI	NAGALMADIKE_66	10:15	10:20	00:05	TRIPPED ON FAULT
2927	18-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2928	18-Feb-24	TUMKUR	66	LINE	RAMAGIRI-BAGUR LINE	RAMAGIRI_66, ENERCON_IPP_66	10:22	10:40	00:18	TRIPPED ON FAULT
2929	18-Feb-24	TUMKUR	66	LINE	SOKKE-UJJINI	SOKKE_66	21:25	21:35	00:10	TRIPPED ON FAULT
2930	18-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- HONNALI1	HONNALLI_220	09:45	10:10	00:25	LINE CLEAR AVAILED
2931	18-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- HONNALI2	HONNALLI_220	09:45	10:10	00:25	LINE CLEAR AVAILED
2932	18-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	THALLAK_220	15:55	18:39	02:44	LINE CLEAR AVAILED
2933	19-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	16:38	16:52	00:14	TRIPPED ON FAULT
2934	19-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	16:59	17:39	00:40	TRIPPED ON FAULT
2935	19-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YADWAD_110	19:40	20:30	00:50	TRIPPED ON FAULT
2936	19-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2	ATHANI_220	15:20	16:30	01:10	LINE CLEAR AVAILED
2937	19-Feb-24	BAGALKOTE	110	LINE	AMBEWADI- SUPA-2	AMBEWADI_220	11:15	14:21	03:06	LINE CLEAR AVAILED
2938	19-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	7:26 (18.02.2024)			LINE CLEAR AVAILED
2939	19-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
2940	19-Feb-24	BAGALKOTE	110	LINE	BELLATTI-AB SOLAR	AB SOLAR_110 STATION NOT AFFECTED BELLATTI_110	19:22	22:29	03:07	LINE CLEAR AVAILED
2941	19-Feb-24	BAGALKOTE	110	LINE	BYADAGI-RAILWAY	RAILWAY_110 STATION NOT AFFECTED ATHARGA_110	00:55	01:16	00:21	TRIPPED ON FAULT
2942	19-Feb-24	BAGALKOTE	110	LINE	BYADAGI-RAILWAY	RAILWAY_110 STATION NOT AFFECTED ATHARGA_110	01:46	01:54	00:08	TRIPPED ON FAULT
2943	19-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
2944	19-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
2945	19-Feb-24	BAGALKOTE	110	LINE	ITNAL-RAIBAG2(MUGALKHOD1)	STATION NOT AFFECTED ITNAL_110	01:37	01:42	00:05	TRIPPED ON FAULT
2946	19-Feb-24	BAGALKOTE	110	LINE	KUDACHI220- SHIRAGUPPI	KUDACHI_220	04:00	08:25	04:25	TRIPPED ON FAULT
2947	19-Feb-24	BAGALKOTE	110	LINE	KULIGOD-GAMESH WIND	GAMESH WIND_110 STATION NOT AFFECTED KULIGOD_110	09:53	17:01	07:08	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2948	19-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2949	19-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2950	19-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- HIDIKAL	MUGALKHOD_220	11:22	12:52	01:30	LINE CLEAR AVAILED
2951	19-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- ITANAL1	MUGALKHOD_220	01:28	01:42	00:14	TRIPPED ON FAULT
2952	19-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2953	19-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
2954	19-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR220- HIREKERUR	RANEBENNUR_220	07:01	08:38	01:37	TRIPPED ON FAULT
2955	19-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA2	SOUDATTI_220	11:25	14:20	02:55	LINE CLEAR AVAILED
2956	19-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2957	19-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	ATHANI_220	16:17	16:30	00:13	LINE CLEAR AVAILED
2958	19-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	KUDACHI_220	04:00	04:38	00:38	TRIPPED ON FAULT
2959	19-Feb-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA2	AMBEWADI_220	14:27	15:28	01:01	LINE CLEAR AVAILED
2960	19-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)			LINE CLEAR AVAILED
2961	19-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2962	19-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	11:01 (17.02.2024)	22:28 (19.02.2024)	11:27	LINE CLEAR AVAILED
2963	19-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	11:01 (17.02.2024)	22:34 (19.02.2024)	11:33	LINE CLEAR AVAILED
2964	19-Feb-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI2	HUBLI_220	11:10	17:11	06:01	LINE CLEAR AVAILED
2965	19-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	HUBLI_220	10:22	22:07	11:45	LINE CLEAR AVAILED
2966	19-Feb-24	BAGALKOTE	220	LINE	KUDACHI- ATHANI	KUDACHI_220	03:30	04:42	01:12	TRIPPED ON FAULT
2967	19-Feb-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	SHIGGOAN_220	13:02	13:17	00:15	TRIPPED ON FAULT
2968	19-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2969	19-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
2970	19-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2971	19-Feb-24	BENGALURU	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	PLATINUM CITY	07:21	07:24	00:03	LINE CLEAR AVAILED
2972	19-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2973	19-Feb-24	BENGALURU	66	LINE	66KV BIDADI 220 - HEJJALA 2	HEJJALA	07:40	07:45	00:05	LINE CLEAR AVAILED
2974	19-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - RAMAPURA	RAMAPURA	03:04	03:30	00:26	TRIPPED ON FAULT
2975	19-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	GUNDLU KOTTUR, VIDURASHWATHA	17:15	17:35	00:20	LINE CLEAR AVAILED
2976	19-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - ITI (POTTERYROAD)	HOSKOTE 66	18:50	19:10	00:20	TRIPPED ON FAULT
2977	19-Feb-24	BENGALURU	66	LINE	66KV KIADB DB PURA - HIMAT SINGH (EHT)	HIMAT SINGH(EHT)	18:00	18:42	00:42	MAIN SUPPLY FAILURE
2978	19-Feb-24	BENGALURU	66	LINE	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	18:00	18:42	00:42	MAIN SUPPLY FAILURE
2979	19-Feb-24	BENGALURU	66	LINE	66KV KIADB DODDABALLAPURA 220 - INDO MIM (EHT)	INDO MM(EHT)	18:00	18:42	00:42	MAIN SUPPLY FAILURE
2980	19-Feb-24	BENGALURU	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	13:52	13:58	00:06	LINE CLEAR AVAILED
2981	19-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	08:24	08:26	00:02	LINE CLEAR AVAILED
2982	19-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	RR NAGAR	06:13	06:18	00:05	LINE CLEAR AVAILED
2983	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GANJIGUNTE	06:17	06:23	00:06	TRIPPED ON FAULT
2984	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GANJIGUNTE	07:45	07:50	00:05	TRIPPED ON FAULT
2985	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GUNDAMGERE	18:13	18:20	00:07	TRIPPED ON FAULT
2986	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	15:43	15:58	00:15	TRIPPED ON FAULT
2987	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BANGARPET	16:35	17:00	00:25	LINE CLEAR AVAILED
2988	19-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MAASTHI	17:30	19:05	01:35	LINE CLEAR AVAILED
2989	19-Feb-24	BENGALURU	66	TRANSFORMER	HV2	CHELUR	10:30	10:40	00:10	TRIPPED ON FAULT
2990	19-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 1	NO STATION AFFECTED	06:37	06:55	00:18	TRIPPED ON FAULT
2991	19-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, MADDUR, KIADB SOMANAHALLI, TALAGAWADI	06:41	06:59	00:18	TRIPPED ON FAULT
2992	19-Feb-24	BENGALURU	220	LINE	220KV GOWRIBIDANUR 220 - KIADB DODDABALLAPURA	KIADB DB PURA 220	18:02	18:40	00:38	TRIPPED ON FAULT
2993	19-Feb-24	BENGALURU	220	LINE	220KV PGCIL KOLAR 400 - T GOLAHALLI 1	NO STATION AFFECTED	21:58	2:30(20.02.2024)	04:32	TRIPPED ON FAULT
2994	19-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66,LIS(KNNL)_66	05:31	05:45	00:14	TRIPPED ON FAULT
2995	19-Feb-2024	GULBARGA	66	LINE	TELAGI-YARAGUNTA	YARAGUNTA_66,OBBIJJIHALLI_66	11:45	11:55	00:10	TRIPPED ON FAULT
2996	19-Feb-2024	GULBARGA	110	LINE	BETAGERA-TALAKAL	BETAGERA_110	05:55	06:15	00:20	TRIPPED ON FAULT
2997	19-Feb-2024	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110	02:45	02:50	00:05	TRIPPED ON FAULT
2998	19-Feb-2024	GULBARGA	110	LINE	GANGAVATI-MUNIRABAD	GANGAVATI_110,VENKATAGIRI_110	14:47	15:04	00:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2999	19-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KUDITINI_110	13:50	14:00	00:10	TRIPPED ON FAULT
3000	19-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	22:44	23:11	00:27	TRIPPED ON FAULT
3001	19-Feb-2024	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GABUR_110, GUGAL_110	11:44	11:49	00:05	TRIPPED ON FAULT
3002	19-Feb-2024	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GABUR_110, GUGAL_110	12:25	12:30	00:05	TRIPPED ON FAULT
3003	19-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR2(JEWARGI)	JEWARGI_110	03:06	03:11	00:05	TRIPPED ON FAULT
3004	19-Feb-2024	GULBARGA	110	LINE	SIRIGUPPA-NSL SUGAR_IPP	SIRIGUPPA_110	13:15	16:57	03:42	LINE CLEAR AVAILED
3005	19-Feb-2024	GULBARGA	220	TRANSFORMER	HV2	HALWARTHY_220	10:50	13:02	02:12	LINE CLEAR AVAILED
3006	19-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-RTPS2	SHAHAPUR_220	11:25	18:23	06:58	LINE CLEAR AVAILED
3007	19-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	12:01	13:19	01:18	LINE CLEAR AVAILED
3008	19-Feb-24	HASSAN	66	LINE	DODDAKA-KRNAGARA	DODDAKADNUR_66	10:23	12:16	01:53	LINE CLEAR AVAILED
3009	19-Feb-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPURA_220	10:23	12:22	01:59	LINE CLEAR AVAILED
3010	19-Feb-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	04:05	04:15	00:10	TRIPPED ON FAULT
3011	19-Feb-24	HASSAN	66	TRANSFORMER	HV1 CB	NAGARTHI_110	10:23	13:25	03:02	LINE CLEAR AVAILED
3012	19-Feb-24	HASSAN	66	TRANSFORMER	HV2	HNPURA_66	15:55	17:15	01:20	TRIPPED ON FAULT
3013	19-Feb-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	11:35	12:02	00:27	LINE CLEAR AVAILED
3014	19-Feb-24	HASSAN	66	LINE	NGRTHI-L1 CB	NAGARTHI_110	10:28	13:31	03:03	LINE CLEAR AVAILED
3015	19-Feb-24	HASSAN	66	LINE	NGRTHI-L2 CB	NAGARTHI_110	09:53	18:19	08:26	LINE CLEAR AVAILED
3016	19-Feb-24	HASSAN	110	LINE	BAIKAM-KAVOOR1	BAIKAMPADI_110	10:15	12:27	02:12	LINE CLEAR AVAILED
3017	19-Feb-24	HASSAN	110	LINE	BAIKAM-KAVOOR1	BAIKAMPADI_110	11:41	16:16	04:35	LINE CLEAR AVAILED
3018	19-Feb-24	HASSAN	110	LINE	KADUR-RAILWAY	KADUR_220	03:18	03:27	00:09	TRIPPED ON FAULT
3019	19-Feb-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKALA_110	10:25	11:06	00:41	LINE CLEAR AVAILED
3020	19-Feb-24	HASSAN	110	LINE	KEMAR-Manipal2	KEMAR_220	06:45	07:03	00:18	TRIPPED ON FAULT
3021	19-Feb-24	HASSAN	220	LINE	KAVOOR-TK1	KAVOOR_220	10:00	13:45	03:45	LINE CLEAR AVAILED
3022	19-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED
3023	19-Feb-24	MYSORE	66	LINE	BG PURA-CHANDALLI	NO STATIONS EFFECTED	08:33	13:31	04:58	LINE CLEAR AVAILED
3024	19-Feb-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBE_60	21:02 (18/02/2024)			TRIPPED ON FAULT
3025	19-Feb-24	MYSORE	66	LINE	GUNDLUPETE-CR NAGARA	TERAKANAMBE_60	12:13	13:28	01:14	LINE CLEAR AVAILED
3026	19-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3027	19-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
3028	19-Feb-24	MYSORE	66	LINE	HEBBANI-MEGALAPURA	CHANDALLI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66THU MBLA_66 MUGUR_66 JANNUR_66 TNARASIPURA_66THAYURU_66GA RGESHWARI_66	12:51	13:03	00:12	TRIPPED ON FAULT
3029	19-Feb-24	MYSORE	66	LINE	HEBBANI-VADKEPURA	KIRUGAVALU_66VADKEPURA_66M ALIYURU_66	06:19	06:35	00:16	TRIPPED ON FAULT
3030	19-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
3031	19-Feb-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	10:10	10:41	00:31	LINE CLEAR AVAILED
3032	19-Feb-24	MYSORE	66	TRANSFORMER	HV1	SUNTIKOPPA_66	12:05	13:10	01:05	LINE CLEAR AVAILED
3033	19-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3034	19-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADDUR_66	13:30	14:00	00:29	LINE CLEAR AVAILED
3035	19-Feb-24	MYSORE	66	TRANSFORMER	HV2	ANEGOLAL_66	18:05 (18/02/2024)	14:40 (19/02/2024)	20:35 HRs	LINE CLEAR AVAILED
3036	19-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
3037	19-Feb-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	16:40	16:50	00:10	TRIPPED ON FAULT
3038	19-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJMANGALA	AYRALLI_66	07:47	18:20	10:33	LINE CLEAR AVAILED
3039	19-Feb-24	MYSORE	66	LINE	KM DODDI-KK DODDI	SOMANAHALLI_66 KMDODDI_66 KKDODDI_66MADDUR_66	06:39	06:51	00:12	TRIPPED ON FAULT
3040	19-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	19:03 (19/02/2024)			LINE CLEAR AVAILED
3041	19-Feb-24	MYSORE	66	LINE	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	16:38	16:42	00:04	TRIPPED ON FAULT
3042	19-Feb-24	MYSORE	66	LINE	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	16:45	16:53	00:08	TRIPPED ON FAULT
3043	19-Feb-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	KOLLEGALA_66	16:38	16:42	00:04	TRIPPED ON FAULT
3044	19-Feb-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	KOLLEGALA_66	16:45	16:53	00:08	TRIPPED ON FAULT
3045	19-Feb-24	MYSORE	66	LINE	MANDGERE-NAGARATI	MANDAGERE_66	09:30	18:30	09:00	LINE CLEAR AVAILED
3046	19-Feb-24	MYSORE	66	LINE	MUGUR-CR NAGARA	NO STATIONS EFFECTED	21:19 (18/02/2024)	13:00 (19/02/2024)	15:40 HRs	LINE CLEAR AVAILED
3047	19-Feb-24	MYSORE	66	LINE	SARGUR -BEGUR	NO STATIONS EFFECTED	07:11	07:21	00:10	TRIPPED ON FAULT
3048	19-Feb-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	06:18	06:22	00:03	TRIPPED ON FAULT
3049	19-Feb-24	MYSORE	220	TRANSFORMER	HV1	CRNAGAR_220	20:58 (18/02/2024)	12:02 (19/02/2024)	15:40 HRs	TRIPPED ON FAULT
3050	19-Feb-24	MYSORE	220	LINE	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	11:22	13:02	01:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3051	19-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	09:01	17:11	08:09	LINE CLEAR AVAILED
3052	19-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:12 (19/02/2024)			LINE CLEAR AVAILED
3053	19-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:13	18:02	03:48	TRIPPED ON FAULT
3054	19-Feb-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGERE_66	16:32	16:42	00:10	TRIPPED ON FAULT
3055	19-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-BEVINAHALLI	DASUDI_66, CHANGAVARA_66BEVINAHALLI_66	00:23	00:38	00:15	TRIPPED ON FAULT
3056	19-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	KALMARANAHALLI_66	(17.2.24) 17:43:40 PM	(19.2.24) 12:20 PM	1D:19HR:23M	LINE CLEAR AVAILED
3057	19-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	PDKOTE_66	03:07	03:10	00:02	TRIPPED ON FAULT
3058	19-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	PDKOTE_66	03:13	03:15	00:02	TRIPPED ON FAULT
3059	19-Feb-24	TUMKUR	66	LINE	LV1(TR1)	THALLAK_66	13:08	17:45	04:36	LINE CLEAR AVAILED
3060	19-Feb-24	TUMKUR	66	LINE	LV1(TR1)	THALLAK_66	17:15	19:13	01:58	LINE CLEAR AVAILED
3061	19-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-MEDIGESHI	MEDIGESHI_66	18:50	19:11	00:20	TRIPPED ON FAULT
3062	19-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3063	19-Feb-24	TUMKUR	66	LINE	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	14:43	14:49	00:06	TRIPPED ON FAULT
3064	19-Feb-24	TUMKUR	66	LINE	SHYAGALE- KEREBILCHI	WATER WORKS	08:55	09:20	00:24	TRIPPED ON FAULT
3065	19-Feb-24	TUMKUR	110	LINE	CHIKKANAYAKANAHALLI-HULIYAR	SHETTYKERE_110, THIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	15:02	15:26	00:23	TRIPPED ON FAULT
3066	19-Feb-24	TUMKUR	110	TRANSFORMER	HV2(TR2)	KG TEMPLE_110	23:25	23:50	00:25	TRIPPED ON FAULT
3067	19-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETTYKERE_110	14:34	14:47	00:13	TRIPPED ON FAULT
3068	19-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-HANDANKERE_110	HANDANKERE_110, HULIYAR_110	14:34	14:57	00:23	TRIPPED ON FAULT
3069	19-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV-THIMMANAHALLI_110	KATHRIKEHAL_110, THIMMANAHALLI_110	14:34	14:54	00:20	TRIPPED ON FAULT
3070	19-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	THALLAK_220	17:16	19:11	01:55	LINE CLEAR AVAILED
3071	19-Feb-24	TUMKUR	400	LINE	GUTTUR 400-DONI_400(GUDDABAHALLI)	GUDDABAHALLI_400	14:04	16:57	02:53	TRIPPED ON FAULT
3072	19-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV-BEERANAHALLI2	BEERANAHALLI2	13:49	17:25	03:36	TRIPPED ON FAULT
3073	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KANABARGI_110	11:16	12:20	01:04	LINE CLEAR AVAILED
3074	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RANNABELAGALI_110	10:12	10:23	00:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3075	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RANNABELAGALI_110	10:24	10:25	00:01	LINE CLEAR AVAILED
3076	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	15:05	15:25	00:20	LINE CLEAR AVAILED
3077	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	13:11	13:26	00:15	TRIPPED ON FAULT
3078	20-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TAKKALAKI_110	14:25	14:35	00:10	TRIPPED ON FAULT
3079	20-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	7:26 (18.02.2024)			LINE CLEAR AVAILED
3080	20-Feb-24	BAGALKOTE	110	LINE	ATHANI-GHATANATTI	ATHANI_220	06:58	07:17	00:19	TRIPPED ON FAULT
3081	20-Feb-24	BAGALKOTE	110	LINE	ATHANI-HALIYAL	ATHANI_220	10:26	15:02	04:36	LINE CLEAR AVAILED
3082	20-Feb-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3083	20-Feb-24	BAGALKOTE	110	LINE	BIDNAL220- PH COMPOUND	BIDNAL_220	09:57	11:15	01:18	LINE CLEAR AVAILED
3084	20-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
3085	20-Feb-24	BAGALKOTE	110	LINE	HIREHAL-IDLE (BADAMI)	STATION NOT AFFECTED HIREHAL_110	17:27	18:33	01:06	LINE CLEAR AVAILED
3086	20-Feb-24	BAGALKOTE	110	LINE	HIREHAL-MYFAR SOLAR	MYFAR SOLAR_110 STATION NOT AFFECTED HIREHAL_110	17:27	18:33	01:06	LINE CLEAR AVAILED
3087	20-Feb-24	BAGALKOTE	110	LINE	HIREHAL-RON	STATION NOT AFFECTED HIREHAL_110	17:27	18:33	01:06	LINE CLEAR AVAILED
3088	20-Feb-24	BAGALKOTE	110	LINE	HIREMASALI-F2 (ATHARGA)	STATION NOT AFFECTED HIREMASALI_110	19:46 (20.02.2024)			LINE CLEAR AVAILED
3089	20-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
3090	20-Feb-24	BAGALKOTE	110	LINE	LAKSHMESHWER-SHIRHATTI	SHIRHATTI_110 STATION NOT AFFECTED LAKSHMESHWER_110	06:44	07:23	00:39	TRIPPED ON FAULT
3091	20-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3092	20-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3093	20-Feb-24	BAGALKOTE	110	LINE	MUGHAKOD-ITNAL-1	MUGHAKOD(KABBUR)_220	10:04	14:11	04:07	LINE CLEAR AVAILED
3094	20-Feb-24	BAGALKOTE	110	LINE	MUGHAKOD-ITNAL-2	MUGHAKOD(KABBUR)_220	10:05	13:50	03:45	LINE CLEAR AVAILED
3095	20-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3096	20-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
3097	20-Feb-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	12:14	17:22	05:08	LINE CLEAR AVAILED
3098	20-Feb-24	BAGALKOTE	110	LINE	SHIGGOAN-AVANTI	SHIGGOAN_110	19:00	19:25	00:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3099	20-Feb-24	BAGALKOTE	110	LINE	SHIGGOAN-RAMANAKOPPA(GANJIGATTI)	SHIGGOAN_110	04:15	12:14	07:59	TRIPPED ON FAULT
3100	20-Feb-24	BAGALKOTE	110	LINE	SHIGGOAN-SAVANUR(MUNDAGOD)	SHIGGOAN_110	04:15	04:35	00:20	TRIPPED ON FAULT
3101	20-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3102	20-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1,LV1	KUDUCHI_220	16:04	16:53	00:49	LINE CLEAR AVAILED
3103	20-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2&LV2	ATHANI_220	9:50 (20.02.2024)			LINE CLEAR AVAILED
3104	20-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	SHIGGAON_220	15:27	15:45	00:18	LINE CLEAR AVAILED
3105	20-Feb-24	BAGALKOTE	220	LINE	ATHANI-KUDUCHI	ATHANI_220	10:41	11:12	00:31	TRIPPED ON FAULT
3106	20-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)			LINE CLEAR AVAILED
3107	20-Feb-24	BAGALKOTE	220	LINE	BIDNAL- NARENDRA	BIDNAL_220	12:27	14:47	02:20	LINE CLEAR AVAILED
3108	20-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3109	20-Feb-24	BAGALKOTE	220	LINE	KUDUCH-ATHANI	KUDUCHI_220	10:40	11:12	00:32	TRIPPED ON FAULT
3110	20-Feb-24	BAGALKOTE	220	LINE	MUGHAKOD-GHATAPRABHA 1	MUGHAKOD(KABBUR)_220	16:55	20:11	03:16	LINE CLEAR AVAILED
3111	20-Feb-24	BAGALKOTE	220	LINE	NARENDRA- BIDNAL	NARENDRA_220	12:27	14:48	02:21	LINE CLEAR AVAILED
3112	20-Feb-24	BAGALKOTE	220	LINE	SHIGGAON - BIDNAL	SHIGGAON_220	17:21	17:23	00:02	TRIPPED ON FAULT
3113	20-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3114	20-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3115	20-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3116	20-Feb-24	BENGALURU	66	LINE	220KV HOODY 220 - BIAL BEGUR 220	HOODY 220	11:47	12:20	00:33	MAIN SUPPLY FAILURE
3117	20-Feb-24	BENGALURU	66	LINE	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGURU	16:22	16:57	00:35	TRIPPED ON FAULT
3118	20-Feb-24	BENGALURU	66	LINE	66KV AERO SPACE 220 - BOEING (EHT)	BOEING(EHT)	11:47	12:16	00:29	MAIN SUPPLY FAILURE
3119	20-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3120	20-Feb-24	BENGALURU	66	LINE	66KV BAGEPALLI - GULUR	NO STATION AFFECTED	06:35	07:10	00:35	TRIPPED ON FAULT
3121	20-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - 66 KV ITC AIRPORT ROAD (EHT)	ITC AIRPORT(EHT)	11:47	12:28	00:41	MAIN SUPPLY FAILURE
3122	20-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - BIAL 1 (EHT)	BIAL(EHT)	11:47	12:11	00:24	MAIN SUPPLY FAILURE
3123	20-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - BIAL 2 (EHT)	BIAL(EHT)	11:47	12:11	00:24	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3124	20-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	11:47	12:28	00:41	MAIN SUPPLY FAILURE
3125	20-Feb-24	BENGALURU	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGAR	VIDYANAGARA	11:47	12:28	00:41	MAIN SUPPLY FAILURE
3126	20-Feb-24	BENGALURU	66	LINE	66KV BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	10:54	11:07	00:13	LINE CLEAR AVAILED
3127	20-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	12:29	12:32	00:03	LINE CLEAR AVAILED
3128	20-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	14:56	15:01	00:05	LINE CLEAR AVAILED
3129	20-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	11:47	12:16	00:29	MAIN SUPPLY FAILURE
3130	20-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	14:21	14:31	00:10	MAIN SUPPLY FAILURE
3131	20-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, SHIVANAHALLI, CNNL(EHT), VANDARGUPPE	18:39	18:53	00:14	TRIPPED ON FAULT
3132	20-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDLAGHATTA, MELUR	06:25	06:47	00:22	TRIPPED ON FAULT
3133	20-Feb-24	BENGALURU	66	LINE	66KV DCROSS - AIR EHT - RAJANKUNTE	AIR(EHT)	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3134	20-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	11:47	12:31	00:44	MAIN SUPPLY FAILURE
3135	20-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	07:40	07:45	00:05	LINE CLEAR AVAILED
3136	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA	KONDASAPURA	11:47	12:20	00:33	MAIN SUPPLY FAILURE
3137	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	10:52	10:56	00:04	LINE CLEAR AVAILED
3138	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	12:00	12:37	00:37	LINE CLEAR AVAILED
3139	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	11:47	12:37	00:50	MAIN SUPPLY FAILURE
3140	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	NANDAGUDI, VOLVO	11:47	12:20	00:33	MAIN SUPPLY FAILURE
3141	20-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE	11:47	12:21	00:34	MAIN SUPPLY FAILURE
3142	20-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	07:05	07:10	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3143	20-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	17:00	17:05	00:05	LINE CLEAR AVAILED
3144	20-Feb-24	BENGALURU	66	LINE	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	11:48	11:52	00:04	LINE CLEAR AVAILED
3145	20-Feb-24	BENGALURU	66	LINE	66KV HULLENAHALLI - KUDURU	KUDUR, SRIGIRIPURA	06:37	06:53	00:16	TRIPPED ON FAULT
3146	20-Feb-24	BENGALURU	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	12:43	12:49	00:06	LINE CLEAR AVAILED
3147	20-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	07:38	08:09	00:31	MAIN SUPPLY FAILURE
3148	20-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - FALCON CITY	PRESTIGE FALCON CITY	07:38	11:06	03:28	MAIN SUPPLY FAILURE
3149	20-Feb-24	BENGALURU	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE	15:15	15:35	00:20	LINE CLEAR AVAILED
3150	20-Feb-24	BENGALURU	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	06:30	06:50	00:20	TRIPPED ON FAULT
3151	20-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	16:37	18:03	01:26	LINE CLEAR AVAILED
3152	20-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	14:02	14:17	00:15	TRIPPED ON FAULT
3153	20-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	06:36	06:50	00:14	TRIPPED ON FAULT
3154	20-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASALU	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3155	20-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3156	20-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHIDS	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3157	20-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3158	20-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3159	20-Feb-24	BENGALURU	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	12:15	12:40	00:25	TRIPPED ON FAULT
3160	20-Feb-24	BENGALURU	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	14:15	15:25	01:10	TRIPPED ON FAULT
3161	20-Feb-24	BENGALURU	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	15:40	15:45	00:05	LINE CLEAR AVAILED
3162	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	07:38	08:04	00:26	MAIN SUPPLY FAILURE
3163	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	07:38	08:15	00:37	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3164	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	07:38	08:11	00:33	MAIN SUPPLY FAILURE
3165	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	07:38	08:10	00:32	MAIN SUPPLY FAILURE
3166	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL(EHT)	07:38	08:15	00:37	MAIN SUPPLY FAILURE
3167	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	07:38	08:10	00:32	MAIN SUPPLY FAILURE
3168	20-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	SUBRAMANYAPURA 66	11:02	11:07	00:05	LINE CLEAR AVAILED
3169	20-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	11:47	12:25	00:38	MAIN SUPPLY FAILURE
3170	20-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	14:22	14:54	00:32	MAIN SUPPLY FAILURE
3171	20-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	11:47	12:25	00:38	MAIN SUPPLY FAILURE
3172	20-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	14:22	14:54	00:32	MAIN SUPPLY FAILURE
3173	20-Feb-24	BENGALURU	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	08:02	08:08	00:06	TRIPPED ON FAULT
3174	20-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	06:25	06:48	00:23	TRIPPED ON FAULT
3175	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ATTUR YELAHANKA	14:09	14:11	00:02	LINE CLEAR AVAILED
3176	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIAL BEGUR 220	11:47	12:20	00:33	MAIN SUPPLY FAILURE
3177	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 66	08:35	08:45	00:10	TRIPPED ON FAULT
3178	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 66	08:45	09:15	00:30	LINE CLEAR AVAILED
3179	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 66	12:30	12:55	00:25	LINE CLEAR AVAILED
3180	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSKOTE 66	16:05	16:55	00:50	LINE CLEAR AVAILED
3181	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HONNIGANAHALLI	16:22	17:25	01:03	TRIPPED ON FAULT
3182	20-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HONNIGANAHALLI	20:45	21:10	00:25	LINE CLEAR AVAILED
3183	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BAGHMANE TECH PARK	04:25	07:20	02:55	TRIPPED ON FAULT
3184	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BAGHMANE TECH PARK	18:18	18:30	00:12	LINE CLEAR AVAILED
3185	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BRIGADE MEADOWS	12:04	12:11	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3186	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BIAL BEGUR 220	11:47	12:20	00:33	MAIN SUPPLY FAILURE
3187	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	APPAREL PARK	14:53	15:23	00:30	TRIPPED ON FAULT
3188	20-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VANDARAGUPPE	13:13	13:35	00:22	TRIPPED ON FAULT
3189	20-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 1	NO STATION AFFECTED	07:54	09:39	01:45	TRIPPED ON FAULT
3190	20-Feb-24	BENGALURU	220	LINE	220KV DEVANAHALLI 400 GIS KIADB DEVANAHALLI HP 1	KIADB DEVANAHALLI HARDWARE PARK 220	11:47	12:11	00:24	TRIPPED ON FAULT
3191	20-Feb-24	BENGALURU	220	LINE	220KV DEVANAHALLI 400 GIS KIADB DEVANAHALLI HP 2	KIADB DEVANAHALLI HARDWARE PARK 220	11:47	12:11	00:24	TRIPPED ON FAULT
3192	20-Feb-24	BENGALURU	220	LINE	220KV HOODY 220 - MALUR 220	VIKAS TECH PARK 220, EXORA 220	11:47	12:24	00:37	MAIN SUPPLY FAILURE
3193	20-Feb-24	BENGALURU	220	LINE	220KV KIADB DEVANAHALLI HP 220 - AERO SPACE 220	AERO SAPCE 220	11:47	12:16	00:29	MAIN SUPPLY FAILURE
3194	20-Feb-24	BENGALURU	220	LINE	220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 1	BIAL BEGUR 220	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3195	20-Feb-24	BENGALURU	220	LINE	220KV KIADB DEVANAHALLI HP 220 - EKARAJ PURA 1	EKARAJ PURA 220	11:47	12:15	00:28	MAIN SUPPLY FAILURE
3196	20-Feb-24	BENGALURU	220	LINE	220KV KIADB DEVANAHALLI HP 220 - EKARAJ PURA 2	EKARAJ PURA 220	11:47	12:15	00:28	MAIN SUPPLY FAILURE
3197	20-Feb-24	BENGALURU	220	LINE	220KV KOLAR 220 - MALUR 3	NO STATION AFFECTED	12:55	13:33	00:38	TRIPPED ON FAULT
3198	20-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	EXORA 220	11:47	11:53	00:06	MAIN SUPPLY FAILURE
3199	20-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	EXORA 220, VIKAS TECH PARK	14:21	14:31	00:10	MAIN SUPPLY FAILURE
3200	20-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	VIKAS TECH PARK 220, EXORA 220	14:22	14:54	00:32	TRIPPED ON FAULT
3201	20-Feb-24	BENGALURU	220	LINE	220KV NRS DB PURA 220 - BIAL BEGUR 220	NRS DB PURA 220	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3202	20-Feb-24	BENGALURU	220	LINE	220KV SOMANAHALLI 220 - KHODAYS 220	KHODAYS 220, SUBRAMANYAPURA 220	07:38	07:45	00:07	TRIPPED ON FAULT
3203	20-Feb-24	BENGALURU	220	TRANSFORMER	HV1	SUBRAMANYAPURA 220	07:38	07:53	00:15	MAIN SUPPLY FAILURE
3204	20-Feb-24	BENGALURU	220	TRANSFORMER	HV1	NRS DB PURA 220	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3205	20-Feb-24	BENGALURU	220	TRANSFORMER	HV2	SUBRAMANYAPURA 220	07:38	07:57	00:19	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3206	20-Feb-24	BENGALURU	220	TRANSFORMER	HV2	NRS DB PURA 220	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3207	20-Feb-24	BENGALURU	220	TRANSFORMER	HV2	CHANNAPATNA 220	09:31	10:03	00:32	TRIPPED ON FAULT
3208	20-Feb-24	BENGALURU	220	TRANSFORMER	HV2	CHANNAPATNA 220	10:04	10:21	00:17	TRIPPED ON FAULT
3209	20-Feb-24	BENGALURU	220	TRANSFORMER	HV2	CHANNAPATNA 220	10:49	10:51	00:02	TRIPPED ON FAULT
3210	20-Feb-24	BENGALURU	220	TRANSFORMER	HV3	SUBRAMANYAPURA 220	07:38	07:58	00:20	MAIN SUPPLY FAILURE
3211	20-Feb-24	BENGALURU	220	TRANSFORMER	HV3	NRS DB PURA 220	11:47	12:09	00:22	MAIN SUPPLY FAILURE
3212	20-Feb-2024	GULBARGA	110	LINE	BYGWAT-YADRAMI	YADRAMI_110	16:15	17:38	01:23	LINE CLEAR AVAILED
3213	20-Feb-2024	GULBARGA	110	LINE	HALWARTHY-KOPPAL 1& 2	KOPPAL_110	13:39	15:03	01:24	LINE CLEAR AVAILED
3214	20-Feb-2024	GULBARGA	110	LINE	HALWARTHY-TALAKAL	TALAKAL_110, BETAGERA_110	13:39	15:05	01:26	LINE CLEAR AVAILED
3215	20-Feb-2024	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110, BENNUR_110, HANAWAL_110	22:42	22:49	00:07	TRIPPED ON FAULT
3216	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	10:27	11:10	00:43	LINE CLEAR AVAILED
3217	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KARATAGI_110	06:10	06:40	00:30	TRIPPED ON FAULT
3218	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KARATAGI_110	09:05	10:35	01:30	TRIPPED ON FAULT
3219	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	ALIPUR_220	07:53	12:10	04:17	TRIPPED ON FAULT
3220	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KURUGOD_110	14:45	14:55	00:10	TRIPPED ON FAULT
3221	20-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SIRIGERICROSS_110	06:22	06:27	00:05	TRIPPED ON FAULT
3222	20-Feb-2024	GULBARGA	110	LINE	MALLAT-SIRWAR	SIRWAR_110	23:26	23:31	00:05	TRIPPED ON FAULT
3223	20-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110, MARALIHALLA_110	06:12	06:22	00:10	TRIPPED ON FAULT
3224	20-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	07:35	11:45	04:10	LINE CLEAR AVAILED
3225	20-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	HALWARTHY_220	11:01	14:58	03:57	LINE CLEAR AVAILED
3226	20-Feb-24	HASSAN	66	LINE	BALEHN-MUGLUVALLI	BALEHONNUR_66	11:10	13:04	01:54	LINE CLEAR AVAILED
3227	20-Feb-24	HASSAN	66	LINE	HAGARE-KALSAPURA	HAGARE_66	10:00	17:05	07:05	LINE CLEAR AVAILED
3228	20-Feb-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	10:00	17:44	07:44	LINE CLEAR AVAILED
3229	20-Feb-24	HASSAN	66	LINE	HNPR2-CRPTN	HNPURA_220	10:30	13:18	02:48	LINE CLEAR AVAILED
3230	20-Feb-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	17:10(20.02.2024)			TRIPPED ON FAULT
3231	20-Feb-24	HASSAN	66	TRANSFORMER	HV1	BALEHONNUR_66	05:23	06:01	00:38	TRIPPED ON FAULT
3232	20-Feb-24	HASSAN	66	TRANSFORMER	HV1	HAGARE_66	10:00	17:05	07:05	LINE CLEAR AVAILED
3233	20-Feb-24	HASSAN	66	TRANSFORMER	HV1	HALEBEEDU_66	10:19	17:09	06:50	MAIN SUPPLY FAILURE
3234	20-Feb-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	10:00	17:44	07:44	LINE CLEAR AVAILED
3235	20-Feb-24	HASSAN	66	TRANSFORMER	HV2	HAGARE_66	10:00	17:05	07:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3236	20-Feb-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	10:19	17:09	06:50	MAIN SUPPLY FAILURE
3237	20-Feb-24	HASSAN	66	TRANSFORMER	HV2	HNPURA_66	08:26	09:09	00:43	LINE CLEAR AVAILED
3238	20-Feb-24	HASSAN	66	TRANSFORMER	HV2	HNPURA_66	13:47	14:27	00:40	LINE CLEAR AVAILED
3239	20-Feb-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	15:01	15:06	00:05	LINE CLEAR AVAILED
3240	20-Feb-24	HASSAN	66	LINE	SINGAP-HNPURA	SINGAPURA_66	10:40	13:25	02:45	MAIN SUPPLY FAILURE
3241	20-Feb-24	HASSAN	110	LINE	BANTWA-KAVOOR	BANTWAL_110	11:15	11:20	00:05	LINE CLEAR AVAILED
3242	20-Feb-24	HASSAN	110	LINE	GURUPUR-MDBDRE	GURUPURA_110	09:17	17:37	08:20	LINE CLEAR AVAILED
3243	20-Feb-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	12:49	13:45	00:56	LINE CLEAR AVAILED
3244	20-Feb-24	HASSAN	110	LINE	HOSNGD-HULIKAL	HOSANGADI_110	11:42	12:49	01:07	LINE CLEAR AVAILED
3245	20-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG1	HOSANGADI_110	11:26	12:42	01:16	LINE CLEAR AVAILED
3246	20-Feb-24	HASSAN	110	LINE	HOSNGD-VTRG2	HOSANGADI_110	10:49	11:25	00:36	LINE CLEAR AVAILED
3247	20-Feb-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	13:25	15:35	02:10	LINE CLEAR AVAILED
3248	20-Feb-24	HASSAN	110	TRANSFORMER	HV2	BARANGI_110	17:36	18:09	00:33	LINE CLEAR AVAILED
3249	20-Feb-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	10:25	13:27	03:02	LINE CLEAR AVAILED
3250	20-Feb-24	HASSAN	110	LINE	JOG110-LPH	JOG_110	11:25	12:10	00:45	LINE CLEAR AVAILED
3251	20-Feb-24	HASSAN	110	LINE	JOG-JLT4	gen_mghe	16:11	17:32	01:21	LINE CLEAR AVAILED
3252	20-Feb-24	HASSAN	110	LINE	KAVOOR-GURUPURA	KAVOOR_220	11:16	11:18	00:02	LINE CLEAR AVAILED
3253	20-Feb-24	HASSAN	110	LINE	LPH-JLT3	gen_lph	11:23	12:07	00:44	LINE CLEAR AVAILED
3254	20-Feb-24	HASSAN	110	LINE	LPH-JLT4	gen_lph	16:11	17:32	01:21	LINE CLEAR AVAILED
3255	20-Feb-24	HASSAN	110	LINE	LPH-LST4	gen_lph	12:24	16:08	03:44	LINE CLEAR AVAILED
3256	20-Feb-24	HASSAN	110	LINE	LV1	KEMAR_220	10:32	17:33	07:01	LINE CLEAR AVAILED
3257	20-Feb-24	HASSAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	10:04	13:38	03:34	LINE CLEAR AVAILED
3258	20-Feb-24	HASSAN	220	LINE	CRPATNA-HSN400	CRPATNA_220	13:19	16:28	03:09	TRIPPED ON FAULT
3259	20-Feb-24	HASSAN	220	TRANSFORMER	HV1	KEMAR_220	10:32	17:33	07:01	LINE CLEAR AVAILED
3260	20-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3261	20-Feb-24	MYSORE	66	LINE	BETTADAPURA-CHUNCHUNKATTE	RAVANDUR_66 KITTUR_66	22:25	22:35	00:10	TRIPPED ON FAULT
3262	20-Feb-24	MYSORE	66	LINE	CHIKKMANDYA-HAMPAPURA	HAMPAPURA_66	05:42	05:47	00:05	TRIPPED ON FAULT
3263	20-Feb-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBE_66	21:02 (18/02/2024)	15:45 (20/02/2024)	42:42 HRs	TRIPPED ON FAULT
3264	20-Feb-24	MYSORE	66	LINE	CRNAGAR-BADANGUPPE 1	NO STATIONS EFFECTED	13:58	15:05	01:07	LINE CLEAR AVAILED
3265	20-Feb-24	MYSORE	66	LINE	CRNAGAR-BADANGUPPE 2	NO STATIONS EFFECTED	13:25	13:57	00:32	LINE CLEAR AVAILED
3266	20-Feb-24	MYSORE	66	LINE	CRNAGAR-CHANDAKAWADI	CHANDAKAWADI_66	15:09	15:14	00:04	LINE CLEAR AVAILED
3267	20-Feb-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE 1	NO STATIONS EFFECTED	15:19	16:34	01:15	LINE CLEAR AVAILED
3268	20-Feb-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE 2	NO STATIONS EFFECTED	06:15	15:45	09:30	LINE CLEAR AVAILED
3269	20-Feb-24	MYSORE	66	LINE	CRNAGAR-HONNALLI	HONNALLI_66 ATIGULIPURA_66 ARAKALAWADI_66	15:06	15:17	00:11	LINE CLEAR AVAILED
3270	20-Feb-24	MYSORE	66	LINE	CRNAGAR-KABBALLI	NO STATIONS EFFECTED	06:14	15:18	09:04	LINE CLEAR AVAILED
3271	20-Feb-24	MYSORE	66	LINE	DUNDANAHALLI-BESARGALLI	DUNDANAHLLI_66 HIRASAVE_66	14:10	15:22	01:12	LINE CLEAR AVAILED
3272	20-Feb-24	MYSORE	66	LINE	GAVADGERE-CHUNCHUNKATTE	CHUNCHUNKATTE_66	22:25	22:33	00:08	TRIPPED ON FAULT
3273	20-Feb-24	MYSORE	66	LINE	GUNDALPETE-BOOMLAPURA	BOOMPLAPURA_66	09:46	17:10	07:23	LINE CLEAR AVAILED
3274	20-Feb-24	MYSORE	66	LINE	GUNDALPETE-CRNAGAR2	NO STATIONS EFFECTED	14:33	15:44	01:11	LINE CLEAR AVAILED
3275	20-Feb-24	MYSORE	66	LINE	GUNDALPETE-HANGLA	BHARGI_66 HANGLA_66	10:50	14:48	03:58	LINE CLEAR AVAILED
3276	20-Feb-24	MYSORE	66	LINE	GUNDALPETE-HANGLA	BHARGI_66 HANGLA_66	14:52	17:05	02:13	LINE CLEAR AVAILED
3277	20-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
3278	20-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
3279	20-Feb-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 THUMBLA_66 TALAKADU_66 CHANDALLI_66 CHIDRAVALLI_66	18:47	18:56	00:09	TRIPPED ON FAULT
3280	20-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
3281	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	04:00	04:45	00:45	TRIPPED ON FAULT
3282	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	DUNDANAHALLI_66	09:56	15:22	05:26	LINE CLEAR AVAILED
3283	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	GUNDALPETE_66	15:57	19:05	03:07	LINE CLEAR AVAILED
3284	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	10:38	10:50	00:11	TRIPPED ON FAULT
3285	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHEELUNERE_66	13:50	14:15	00:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3286	20-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3287	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	04:00	06:25	02:25	TRIPPED ON FAULT
3288	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	09:15	09:20	00:05	TRIPPED ON FAULT
3289	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	10:00	17:57	07:57	LINE CLEAR AVAILED
3290	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	GUNDALPETE_66	10:00	18:40	08:40	LINE CLEAR AVAILED
3291	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	KOPPA_66	12:35	14:05	01:30	LINE CLEAR AVAILED
3292	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	KOPPA_66	16:35	16:40	00:05	TRIPPED ON FAULT
3293	20-Feb-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	12:45	13:25	00:40	LINE CLEAR AVAILED
3294	20-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
3295	20-Feb-24	MYSORE	66	LINE	KM DODDI-TKHALI	NO STATIONS EFFECTED	07:52	08:08	00:16	TRIPPED ON FAULT
3296	20-Feb-24	MYSORE	66	LINE	KM DODDI-TKHALI	NO STATIONS EFFECTED	08:09	11:13	03:04	LINE CLEAR AVAILED
3297	20-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	19:03 (19/02/2024)	12:30:00 (20/02/2024)	30:33 HRs	LINE CLEAR AVAILED
3298	20-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3299	20-Feb-24	MYSORE	66	LINE	KOPPA-NAGAMANGALA	NO STATIONS EFFECTED	17:10	18:10	01:00	LINE CLEAR AVAILED
3300	20-Feb-24	MYSORE	66	LINE	KRNAGAR-BILIKERE	BILIKERE_66	10:29	17:06	06:36	LINE CLEAR AVAILED
3301	20-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:12 (19/02/2024)			LINE CLEAR AVAILED
3302	20-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:07	09:11	00:04	TRIPPED ON FAULT
3303	20-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:16	09:22	00:06	TRIPPED ON FAULT
3304	20-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66	14:33	14:37	00:04	TRIPPED ON FAULT
3305	20-Feb-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	12:24	13:05	00:41	LINE CLEAR AVAILED
3306	20-Feb-24	TUMKUR	66	LINE	Davangere SRS _MAYAKONDA_66	MAYAKONDA_66, CHIKKAJAJUR_66, SASALUHALLA_66	12:24	13:05	00:41	LINE CLEAR AVAILED
3307	20-Feb-24	TUMKUR	66	LINE	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	11:11	11:34	00:22	LINE CLEAR AVAILED
3308	20-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	TMTP_66	13:15	14:05	00:50	LINE CLEAR AVAILED
3309	20-Feb-24	TUMKUR	66	LINE	LV1(TR1)	PANDRAHALLI_66	16:45	17:18	00:32	LINE CLEAR AVAILED
3310	20-Feb-24	TUMKUR	66	LINE	LV1(TR1)	THALLAK_66	15:50	17:39	01:49	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3311	20-Feb-24	TUMKUR	66	LINE	LV2(TR2)	ANCHEPALYA_220	06:37	06:53	00:16	TRIPPED ON FAULT
3312	20-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	18:52	19:06	00:14	TRIPPED ON FAULT
3313	20-Feb-24	TUMKUR	66	LINE	MADHURE_220-HALURAMESWARA_66	HALURAMESWARA_66, MADADKERE_66	08:00	08:15	00:15	TRIPPED ON FAULT
3314	20-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3315	20-Feb-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	12:17	12:43	00:26	MAIN SUPPLY FAILURE
3316	20-Feb-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	14:33	14:37	00:04	MAIN SUPPLY FAILURE
3317	20-Feb-24	TUMKUR	110	LINE	LV1(TR1)	KBCROSS_220	10:30	10:42	00:11	TRIPPED ON FAULT
3318	20-Feb-24	TUMKUR	110	LINE	LV2(TR2)	KBCROSS_220	10:30	10:42	00:11	TRIPPED ON FAULT
3319	20-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	KBCROSS_220	10:30	10:41	00:11	TRIPPED ON FAULT
3320	20-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	THALLAK_220	15:51	17:38	01:47	LINE CLEAR AVAILED
3321	20-Feb-24	TUMKUR	220	TRANSFORMER	HV2(TR2)	KBCROSS_220	10:30	10:41	00:11	TRIPPED ON FAULT
3322	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED BEDI_110	14:50	18:05	03:15	TRIPPED ON FAULT
3323	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	YELLAMANAWADI_110	10:05	14:00	03:55	LINE CLEAR AVAILED
3324	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TALIKOT_110	11:22	16:11	04:49	LINE CLEAR AVAILED
3325	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	15:05	15:25	00:20	LINE CLEAR AVAILED
3326	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	TALIKOT_110	11:22	16:11	04:49	LINE CLEAR AVAILED
3327	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	YELLAMANAWADI_110	10:05	16:54	06:49	LINE CLEAR AVAILED
3328	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (10MVA)	STATION NOT AFFECTED KARWAR_110	10:05	14:50	04:45	LINE CLEAR AVAILED
3329	21-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED KUDACHI_110	09:19	17:40	08:21	LINE CLEAR AVAILED
3330	21-Feb-24	BAGALKOTE	110	LINE	110KV AIGALI	220kv Athani	23:59	07:37	07:37	LINE CLEAR AVAILED
3331	21-Feb-24	BAGALKOTE	110	LINE	110kv BINAGA	KARWAR_220	13:10	20:52	07:42	LINE CLEAR AVAILED
3332	21-Feb-24	BAGALKOTE	110	LINE	110kv KARWAR (BUS COUPLER)	KARWAR_220	10:19	13:25	03:06	LINE CLEAR AVAILED
3333	21-Feb-24	BAGALKOTE	110	LINE	110kv KUMTA (KARWAR - ARGA)	KARWAR_220	10:19	13:25	03:06	LINE CLEAR AVAILED
3334	21-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	VAJRAMATTI_220	16:01	18:50	02:49	LINE CLEAR AVAILED
3335	21-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	BAGALKOT_220	06:42	08:44	02:02	TRIPPED ON FAULT
3336	21-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	7:26 (18.02.2024)			LINE CLEAR AVAILED
3337	21-Feb-24	BAGALKOTE	110	LINE	ATHANI- AIGALI	ATHANI_220	7:26 (18.02.2024)	16:20 (21.02.2024)	8:54	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3338	21-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3339	21-Feb-24	BAGALKOTE	110	LINE	ATHARGA-RAILWAY	RAILWAY_110 STATION NOT AFFECTED ATHARGA_110	11:02	11:28	00:26	TRIPPED ON FAULT
3340	21-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
3341	21-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
3342	21-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
3343	21-Feb-24	BAGALKOTE	110	LINE	KALAGHATGI-AB SOLAR	AB SOLAR_110 STATION NOT AFFECTED KALAGHATGI_110	08:00	12:04	04:04	LINE CLEAR AVAILED
3344	21-Feb-24	BAGALKOTE	110	LINE	KUDACHI220- MORAB	KUDACHI_220	10:00	16:05	06:05	LINE CLEAR AVAILED
3345	21-Feb-24	BAGALKOTE	110	LINE	KUDACHI220-KUDACHI	KUDACHI_220	09:30	17:30	08:00	LINE CLEAR AVAILED
3346	21-Feb-24	BAGALKOTE	110	LINE	KULIGOD-GAMESH WIND	GAMESH WIND_110 STATION NOT AFFECTED KULIGOD_110	21:13	21:23	00:10	LINE CLEAR AVAILED
3347	21-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3348	21-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR(B)-TODALBAGI	TODALBAGI_110 STATION NOT AFFECTED MAMADAPUR(B)_110	07:14	07:34	00:20	TRIPPED ON FAULT
3349	21-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3350	21-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3351	21-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- KULIGOD	MUGALKHOD_220	21:12	21:20	00:08	TRIPPED ON FAULT
3352	21-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3353	21-Feb-24	BAGALKOTE	110	LINE	PGHUNASYAL-SATTIS SUGARS	SATTIS SUGARS_110 STATION NOT AFFECTED PGHUNASYAL_110	07:47	11:38	03:51	LINE CLEAR AVAILED
3354	21-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
3355	21-Feb-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-MACHE	SUVARNA SOUDA_110	10:54	14:05	03:11	LINE CLEAR AVAILED
3356	21-Feb-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	11:54	16:13	04:19	LINE CLEAR AVAILED
3357	21-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- JK CEMENT	VAJRAMATTI_220	13:00	14:23	01:23	LINE CLEAR AVAILED
3358	21-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3359	21-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	VAJRAMATTI_220	16:03	18:47	02:44	LINE CLEAR AVAILED
3360	21-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KUDACHI_220	11:15	18:08	06:53	LINE CLEAR AVAILED
3361	21-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KARWAR_220	10:19	13:25	03:06	LINE CLEAR AVAILED
3362	21-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	10:19	13:25	03:06	LINE CLEAR AVAILED
3363	21-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	BAGALKOT_220	13:24	15:23	01:59	LINE CLEAR AVAILED
3364	21-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)			LINE CLEAR AVAILED
3365	21-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3366	21-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGALKHOD1	GHATAPRABHA_220	12:22	17:02	04:40	LINE CLEAR AVAILED
3367	21-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	HUBLI_220	10:36	18:59	08:23	LINE CLEAR AVAILED
3368	21-Feb-24	BAGALKOTE	220	LINE	KARWAR- KADRA1	KARWAR_220	10:18	13:25	03:07	LINE CLEAR AVAILED
3369	21-Feb-24	BAGALKOTE	220	LINE	KARWAR- KADRA2	KARWAR_220	10:19	13:25	03:06	LINE CLEAR AVAILED
3370	21-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA1	MUGALKHOD_220	12:22	17:08	04:46	LINE CLEAR AVAILED
3371	21-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3372	21-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3373	21-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3374	21-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3375	21-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	A STATION 66(HV1)	12:51	12:52	00:01	MAIN SUPPLY FAILURE
3376	21-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	12:51	13:12	00:21	MAIN SUPPLY FAILURE
3377	21-Feb-24	BENGALURU	66	LINE	66KV A STATION 220 - VICTORIA	VICTORIA	12:51	13:12	00:21	MAIN SUPPLY FAILURE
3378	21-Feb-24	BENGALURU	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST	09:36	09:46	00:10	TRIPPED ON FAULT
3379	21-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3380	21-Feb-24	BENGALURU	66	LINE	66KV BAGEPALLI - GULUR	NO STATION AFFECTED	06:20	07:10	00:50	TRIPPED ON FAULT
3381	21-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CB PURA I/A, CB PURA URBAN	13:29	13:48	00:19	MAIN SUPPLY FAILURE
3382	21-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	NALLIMARDANAHALLI	13:29	14:00	00:31	MAIN SUPPLY FAILURE
3383	21-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NANDIGANAHALLI	18:34	18:38	00:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3384	21-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	66/25KV CHINTAMANI RAILWAY TRACTION	08:13	08:24	00:11	TRIPPED ON FAULT
3385	21-Feb-24	BENGALURU	66	LINE	66KV DCROSS - AIR EHT - RAJANKUNTE	AIR(EHT)	13:23	13:47	00:24	MAIN SUPPLY FAILURE
3386	21-Feb-24	BENGALURU	66	LINE	66KV EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:50	12:55	00:05	MAIN SUPPLY FAILURE
3387	21-Feb-24	BENGALURU	66	LINE	66KV EDC 220 - B STATION	B STATION	12:50	12:55	00:05	MAIN SUPPLY FAILURE
3388	21-Feb-24	BENGALURU	66	LINE	66KV EDC 220 - BMTC	BMTC, NATIONAL COLLEGE	12:50	12:55	00:05	MAIN SUPPLY FAILURE
3389	21-Feb-24	BENGALURU	66	LINE	66KV GUNDAMGERE - D CROSS	GUNDAMGERE, SASALU	18:36	18:50	00:14	TRIPPED ON FAULT
3390	21-Feb-24	BENGALURU	66	LINE	66KV GUNDAMGERE - SASALU	SASALU	18:36	19:03	00:27	TRIPPED ON FAULT
3391	21-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	10:02	10:11	00:09	LINE CLEAR AVAILED
3392	21-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	20:03	20:12	00:09	LINE CLEAR AVAILED
3393	21-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE - 1)	JADIGENAHALLI	09:50	10:00	00:10	LINE CLEAR AVAILED
3394	21-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE - 1)	JADIGENAHALLI	10:50	11:05	00:15	LINE CLEAR AVAILED
3395	21-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE - 1)	JADIGENAHALLI	20:03	20:12	00:09	LINE CLEAR AVAILED
3396	21-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	13:00	13:15	00:15	LINE CLEAR AVAILED
3397	21-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASALU	13:23	13:55	00:32	MAIN SUPPLY FAILURE
3398	21-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	13:23	13:47	00:24	MAIN SUPPLY FAILURE
3399	21-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	13:23	13:57	00:34	MAIN SUPPLY FAILURE
3400	21-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	13:23	13:57	00:34	MAIN SUPPLY FAILURE
3401	21-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	13:23	13:47	00:24	MAIN SUPPLY FAILURE
3402	21-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	18:21	18:25	00:04	LINE CLEAR AVAILED
3403	21-Feb-24	BENGALURU	66	LINE	66KV TALGAWARA - Y HUNSENAHALLY	Y HUNSENAHALLI	16:50	16:55	00:05	LINE CLEAR AVAILED
3404	21-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 1	BWSSB(EHT)	19:07	19:22	00:15	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3405	21-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB(EHT)	19:07	19:22	00:15	MAIN SUPPLY FAILURE
3406	21-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 3	BWSSB(EHT)	19:07	19:37	00:30	TRIPPED ON FAULT
3407	21-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 4	BWSSB(EHT)	19:07	19:22	00:15	MAIN SUPPLY FAILURE
3408	21-Feb-24	BENGALURU	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	21:45	22:00	00:15	TRIPPED ON FAULT
3409	21-Feb-24	BENGALURU	66	LINE	66KV WELCAST - ABBIGERE	ABBIGERE	18:13	18:16	00:03	LINE CLEAR AVAILED
3410	21-Feb-24	BENGALURU	66	LINE	GOWRIBIDANUR 220 - AFTL SOLAR	NO STATION AFFECTED	18:15	18:37	00:22	LINE CLEAR AVAILED
3411	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	07:30	08:30	01:00	LINE CLEAR AVAILED
3412	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SADALI	13:00	13:10	00:10	LINE CLEAR AVAILED
3413	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	CHIKKABALLAPURA I/A	18:05	18:35	00:30	TRIPPED ON FAULT
3414	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SUGUTUR	12:20	12:25	00:05	TRIPPED ON FAULT
3415	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KGF	16:56	17:25	00:29	LINE CLEAR AVAILED
3416	21-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TK HALLI 220	19:07	19:22	00:15	MAIN SUPPLY FAILURE
3417	21-Feb-24	BENGALURU	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	00:06	00:13	00:07	TRIPPED ON FAULT
3418	21-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MALUR I/A	09:45	10:00	00:15	TRIPPED ON FAULT
3419	21-Feb-24	BENGALURU	66	TRANSFORMER	HV3	MANYATHA TECH PARK 220	18:10	18:55	00:45	LINE CLEAR AVAILED
3420	21-Feb-24	BENGALURU	66	TRANSFORMER	HV4	MANYATHA TECH PARK 220	18:10	18:50	00:40	TRIPPED ON FAULT
3421	21-Feb-24	BENGALURU	220	LINE	220 DEVANAHALLI 400 GIS - NRS DB PURA 220 1	NO STATION AFFECTED	14:58	17:22	02:24	LINE CLEAR AVAILED
3422	21-Feb-24	BENGALURU	220	LINE	220 DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	13:22	17:22	04:00	MAIN SUPPLY FAILURE
3423	21-Feb-24	BENGALURU	220	LINE	220KV A STATION 220 - EDC	A STATION 220	12:51	12:52	00:01	MAIN SUPPLY FAILURE
3424	21-Feb-24	BENGALURU	220	LINE	220KV EDC 220 - HAL 220	EAST DIVISION COMPOUND 220	12:50	12:55	00:05	TRIPPED ON FAULT
3425	21-Feb-24	BENGALURU	220	LINE	220KV MAGADI 220 - ANCHEPALYA CKT 2	NO STATION AFFECTED	05:59	09:09	03:10	TRIPPED ON FAULT
3426	21-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NRS DB PURA 20	13:29	13:47	00:18	TRIPPED ON FAULT
3427	21-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 2	NRS DB PURA 20	13:29	13:48	00:19	TRIPPED ON FAULT
3428	21-Feb-24	BENGALURU	220	LINE	220KV NRS DB PURA 220 - BIAL BEGUR 220	NRS DB PURA 220	13:23	13:49	00:26	TRIPPED ON FAULT
3429	21-Feb-24	BENGALURU	220	LINE	220KV NRS DB PURA 220 - KIADB DB PURA 220	NO STATION AFFECTED	15:25	15:58	00:33	LINE CLEAR AVAILED
3430	21-Feb-24	BENGALURU	220	TRANSFORMER	HV1	A STATION 220	12:51	12:52	00:01	MAIN SUPPLY FAILURE
3431	21-Feb-24	BENGALURU	220	TRANSFORMER	HV1	NRS DB PURA 220	13:23	13:47	00:24	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3432	21-Feb-24	BENGALURU	220	TRANSFORMER	HV1	TK HALLI 220	19:07	19:21	00:14	TRIPPED ON FAULT
3433	21-Feb-24	BENGALURU	220	TRANSFORMER	HV2	NRS DB PURA 220	13:23	13:47	00:24	MAIN SUPPLY FAILURE
3434	21-Feb-24	BENGALURU	220	TRANSFORMER	HV3	NRS DB PURA 220	13:23	13:47	00:24	MAIN SUPPLY FAILURE
3435	21-Feb-2024	GULBARGA	66	LINE	HANGAL-GUDDEKOTE	CJ HALLI_66, HOSAHALLI_66	20:10	20:20	00:10	TRIPPED ON FAULT
3436	21-Feb-2024	GULBARGA	110	LINE	HALBARGA-KOLHAR	SANTHAPUR_110,AURAD_110,KAMALNAGAR_110,	11:17	15:13	03:56	LINE CLEAR AVAILED
3437	21-Feb-2024	GULBARGA	110	LINE	HALBARGA-SANTHAPUR	SANTHAPUR_110,AURAD_110,KAMALNAGAR_110,	11:16	11:35	00:19	TRIPPED ON FAULT
3438	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KANAKAGIRI_110	14:10	14:25	00:15	TRIPPED ON FAULT
3439	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	GUGAL_110	08:10	08:15	00:05	TRIPPED ON FAULT
3440	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	18:25	18:35	00:10	TRIPPED ON FAULT
3441	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	VENKATAGIRI_110	12:45	13:50	01:05	LINE CLEAR AVAILED
3442	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	VENKATAGIRI_110	03:45	06:30	02:45	LINE CLEAR AVAILED
3443	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	YADGIR_110	08:10	08:15	00:05	TRIPPED ON FAULT
3444	21-Feb-2024	GULBARGA	110	TRANSFORMER	HV7	MUNIRABAD_220	09:26	16:15	06:49	LINE CLEAR AVAILED
3445	21-Feb-2024	GULBARGA	110	LINE	SIRIGUPPA-DHADESUGUR	TEKKALKOTE_110,SIRIGERICROSS_110,SIRIGUPPA_110	00:30	01:15	00:45	MAIN SUPPLY FAILURE
3446	21-Feb-24	HASSAN	66	LINE	HASSN22-HSN66	HASSAN_220	10:15	17:06	06:51	LINE CLEAR AVAILED
3447	21-Feb-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	17:10(20.02.2024)	14:20(21.02.2024)		TRIPPED ON FAULT
3448	21-Feb-24	HASSAN	66	TRANSFORMER	HV1	HASSAN_66	10:08	17:07	06:59	LINE CLEAR AVAILED
3449	21-Feb-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	09:30	12:40	03:10	LINE CLEAR AVAILED
3450	21-Feb-24	HASSAN	66	TRANSFORMER	HV1 CB	UGANE_66	18:49	20:05	01:16	LINE CLEAR AVAILED
3451	21-Feb-24	HASSAN	66	TRANSFORMER	HV2	HASSAN_66	10:06	17:08	07:02	LINE CLEAR AVAILED
3452	21-Feb-24	HASSAN	66	TRANSFORMER	HV2	HIRESAVE_66	12:54	13:01	00:07	TRIPPED ON FAULT
3453	21-Feb-24	HASSAN	66	TRANSFORMER	HV2	MATTNAVILE_66	03:05	03:30	00:25	TRIPPED ON FAULT
3454	21-Feb-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	10:03	11:01	00:58	LINE CLEAR AVAILED
3455	21-Feb-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	12:41	15:20	02:39	TRIPPED ON FAULT
3456	21-Feb-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	15:20	16:45	01:25	LINE CLEAR AVAILED
3457	21-Feb-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	18:01	18:42	00:41	LINE CLEAR AVAILED
3458	21-Feb-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	18:01	18:42	00:41	LINE CLEAR AVAILED
3459	21-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	07:10	07:15	00:05	TRIPPED ON FAULT
3460	21-Feb-24	HASSAN	66	LINE	UGANE-L2 CB	UGANE_66	18:49	20:05	01:16	LINE CLEAR AVAILED
3461	21-Feb-24	HASSAN	110	LINE	ANAVATI-BARNGI	ANAVATTI_110	14:40	15:00	00:20	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3462	21-Feb-24	HASSAN	110	LINE	BARANG-SHR220	BARANGI_110	09:05	15:03	05:58	TRIPPED ON FAULT
3463	21-Feb-24	HASSAN	110	TRANSFORMER	HV1	GANDASI_110	10:02	13:00	02:58	LINE CLEAR AVAILED
3464	21-Feb-24	HASSAN	110	TRANSFORMER	HV2	GANDASI_110	11:39	18:42	07:03	LINE CLEAR AVAILED
3465	21-Feb-24	HASSAN	110	LINE	KADUR-RAILWAY	KADUR_220	03:57	04:02	00:05	TRIPPED ON FAULT
3466	21-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	08:02	08:14	00:12	TRIPPED ON FAULT
3467	21-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	11:00	13:20	02:20	LINE CLEAR AVAILED
3468	21-Feb-24	HASSAN	110	LINE	TOGARSI-BALIGAVI	TOGARSI_110	14:40	14:50	00:10	MAIN SUPPLY FAILURE
3469	21-Feb-24	MYSORE	66	LINE	AYRAHALLI-VAJMANGALA-KADAKOLA 1	AYRALLI_66	08:00	17:40	09:40	LINE CLEAR AVAILED
3470	21-Feb-24	MYSORE	66	LINE	BANNUR-SFC	NO STATIONS EFFECTED	21:47 (03/02/2024)	20:41 (21/02/2024)	430:54 HRs	LINE CLEAR AVAILED
3471	21-Feb-24	MYSORE	66	LINE	BANNUR-VAJMANGALA	NO STATIONS EFFECTED	20:43			LINE CLEAR AVAILED
3472	21-Feb-24	MYSORE	66	LINE	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	07:13	07:19	00:05	TRIPPED ON FAULT
3473	21-Feb-24	MYSORE	66	LINE	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	16:28	16:34	00:06	TRIPPED ON FAULT
3474	21-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 1	FTS_66	19:20	19:52	00:31	TRIPPED ON FAULT
3475	21-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	FTS_66	19:21	19:54	00:32	LINE CLEAR AVAILED
3476	21-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	DEVANOORMYS_66, RAJEEVNAGARA_66	19:20			TRIPPED ON FAULT
3477	21-Feb-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)	10:38 (21/02/2024)	554:43 HRs	LINE CLEAR AVAILED
3478	21-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
3479	21-Feb-24	MYSORE	66	LINE	HONGANURU-YELANDURU	MAMBALLI_66, YELANDUR_66	05:00	05:05	00:05	TRIPPED ON FAULT
3480	21-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
3481	21-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAPA 1	BANNIMANTAP_66, FTS_66, DEVANOORMYS_66, RAJEEVNAGARA_66	19:20	19:34	00:13	TRIPPED ON FAULT
3482	21-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAPA 2	BANNIMANTAP_66, FTS_66, DEVANOORMYS_66, RAJEEVNAGARA_66	19:20	19:36	00:15	TRIPPED ON FAULT
3483	21-Feb-24	MYSORE	66	LINE	HUNSUR 220-KAMPLAPURA	KAMPALAPURA_66	15:12	15:19	00:07	TRIPPED ON FAULT
3484	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	DODDARAYAPET_66	11:15	13:13	01:57	LINE CLEAR AVAILED
3485	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	HURA_66	10:00	16:40	06:40	LINE CLEAR AVAILED
3486	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	KUSHALANAGARA_66	15:19	15:46	00:27	LINE CLEAR AVAILED
3487	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLY_66	10:00	18:15	08:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3488	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	THANDYA_66	11:20	13:24	02:04	LINE CLEAR AVAILED
3489	21-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3490	21-Feb-24	MYSORE	66	TRANSFORMER	HV2	DODDARAYAPET_66	13:10	14:33	01:23	LINE CLEAR AVAILED
3491	21-Feb-24	MYSORE	66	TRANSFORMER	HV2	HURA_66	10:00	16:40	06:40	LINE CLEAR AVAILED
3492	21-Feb-24	MYSORE	66	TRANSFORMER	HV2	SHIVALLY_66	10:00	18:16	08:16	LINE CLEAR AVAILED
3493	21-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
3494	21-Feb-24	MYSORE	66	LINE	KADAKOLA-NANJANGUDU	NANJANGUDU_66	20:23	21:15	00:52	TRIPPED ON FAULT
3495	21-Feb-24	MYSORE	66	LINE	KADAKOLA-THANDYA	THANDYA_66	20:23	20:34	00:11	TRIPPED ON FAULT
3496	21-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3497	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-BETTADAPURA	NO STATIONS EFFECTED	15:17	15:41	00:23	LINE CLEAR AVAILED
3498	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	15:18	15:42	00:23	TRIPPED ON FAULT
3499	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-HARANGI	NO STATIONS EFFECTED	15:16	15:37	00:20	LINE CLEAR AVAILED
3500	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-MADIKERI	MADIKERI	15:18	18:31	03:12	LINE CLEAR AVAILED
3501	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-MUTHINAMULLUSOGE LIS	NO STATIONS EFFECTED	15:19	15:51	00:32	LINE CLEAR AVAILED
3502	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-MYSORE-1	NO STATIONS EFFECTED	15:13	15:41	00:28	TRIPPED ON FAULT
3503	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-PERİYAPATNA-1	PERİYAPATNA_66 PONNAMPET_66 VIRAJPET_66	15:23	15:46	00:22	LINE CLEAR AVAILED
3504	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPURA_66, KANAGAL_66	15:16	15:40	00:23	LINE CLEAR AVAILED
3505	21-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13			TRIPPED ON FAULT
3506	21-Feb-24	MYSORE	66	TRANSFORMER	KUSHALANAGARA-HV3	KUSHALANAGARA_66	15:19	15:45	00:26	LINE CLEAR AVAILED
3507	21-Feb-24	MYSORE	66	TRANSFORMER	KUSHALANAGARA-HV4	KUSHALANAGARA_66	15:19	15:48	00:29	LINE CLEAR AVAILED
3508	21-Feb-24	MYSORE	66	LINE	MADIKERI-KUSHALANAGARA	NO STATIONS EFFECTED	16:15	18:30	02:15	LINE CLEAR AVAILED
3509	21-Feb-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	SUNTIKOPPA_66	15:16	18:41	03:24	LINE CLEAR AVAILED
3510	21-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-KESALAGERE	KESLAGERE_66	14:47	15:04	00:17	TRIPPED ON FAULT
3511	21-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	BESAGARAHALLI_66, DUNDANAHALLI_66, KOPPA_66	14:47	15:00	00:13	TRIPPED ON FAULT
3512	21-Feb-24	MYSORE	66	LINE	NAGAMANGALA-TUBINAKERE 1	NO STATIONS EFFECTED	11:02	12:40	01:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3513	21-Feb-24	MYSORE	66	LINE	PANDAVPURA-CHINKURALLI	BANANGADI_66	10:01	10:09	00:08	TRIPPED ON FAULT
3514	21-Feb-24	MYSORE	66	LINE	SANTHE SARGURU-CHANDRAVADI	CHANDRAVADI_66, HURA_66	10:10	16:35	06:25	LINE CLEAR AVAILED
3515	21-Feb-24	MYSORE	66	LINE	SANTHE SARGURU-KALSON	NO STATIONS EFFECTED	14:25	15:23	00:58	LINE CLEAR AVAILED
3516	21-Feb-24	MYSORE	66	LINE	SATHEGALA-BPCL	NO STATIONS EFFECTED	11:55	18:50	06:54	LINE CLEAR AVAILED
3517	21-Feb-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	11:58			LINE CLEAR AVAILED
3518	21-Feb-24	MYSORE	66	LINE	SHIVALLI-TUBINAKERE	SHIVALLY_66	11:05	12:39	01:34	LINE CLEAR AVAILED
3519	21-Feb-24	MYSORE	220	TRANSFORMER	HV1	KUSHALNAGARA_220	15:13	15:34	00:21	TRIPPED ON FAULT
3520	21-Feb-24	MYSORE	220	TRANSFORMER	HV2	KUSHALNAGARA_220	15:13	15:34	00:21	TRIPPED ON FAULT
3521	21-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:12 (19/02/2024)	7:18 (21/02/2024)	34:06 HRs	LINE CLEAR AVAILED
3522	21-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	08:04	08:30	00:26	TRIPPED ON FAULT
3523	21-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	16:01	16:18	00:17	TRIPPED ON FAULT
3524	21-Feb-24	TUMKUR	66	LINE	BANUVALLI- NANDIGUDI	NANDIGUDI_66	03:50	04:00	00:10	TRIPPED ON FAULT
3525	21-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kv-HIRIYUR_66	IMANGALA_66, JAIN KOTE_66	17:44	17:47	00:03	LINE CLEAR AVAILED
3526	21-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kv-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	15:08	15:12	00:04	TRIPPED ON FAULT
3527	21-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:40	17:43	00:02	LINE CLEAR AVAILED
3528	21-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	10:20	10:30	00:10	TRIPPED ON FAULT
3529	21-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD1&2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	20:12	20:41	00:29	LINE CLEAR AVAILED
3530	21-Feb-24	TUMKUR	66	LINE	HIRIYUR 220kv- SUZLON 2	SUZLON1_IPP_66	20:12	20:41	00:29	LINE CLEAR AVAILED
3531	21-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV-SIRA(RANGANATHAPURA)	SIRA_66	20:12	20:41	00:29	LINE CLEAR AVAILED
3532	21-Feb-24	TUMKUR	66	LINE	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66, DASUDI_66	20:07(21.2.24)			TRIPPED ON FAULT
3533	21-Feb-24	TUMKUR	66	LINE	HIRIYUR220kv-P R PURA	HARIYABBE_66,PDKOTE_66	20:12	20:40	00:28	LINE CLEAR AVAILED
3534	21-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HIRIYUR_66	21:04	21:15	00:10	TRIPPED ON FAULT
3535	21-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	MELLAKATTE_66	13:13	13:20	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3536	21-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	MELLAKATTE_66	13:40	13:50	00:10	TRIPPED ON FAULT
3537	21-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	MELLAKATTE_66	15:50	15:55	00:05	TRIPPED ON FAULT
3538	21-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	SANIKERE_66	16:05	16:10	00:05	TRIPPED ON FAULT
3539	21-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	KADAJJIL_66	03:03	03:07	00:03	TRIPPED ON FAULT
3540	21-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	SANIKERE_66	16:15	16:20	00:05	TRIPPED ON FAULT
3541	21-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI-HIRIYUR	JAVAGONDANAHALLI_66	20:50	21:00	00:10	LINE CLEAR AVAILED
3542	21-Feb-24	TUMKUR	66	LINE	MATHOD_66-GARAGA PANCHANAHALLI LINE	GARAGA PANCHANAHALLI_66	06:20	06:30	00:10	TRIPPED ON FAULT
3543	21-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3544	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV - BGKERE 1 & 2	BGKERE_66	20:10	20:17	00:07	LINE CLEAR AVAILED
3545	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV - SANIKERE	SANIKERE_66	20:10	20:18	00:08	MAIN SUPPLY FAILURE
3546	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV-CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	20:10	20:18	00:08	LINE CLEAR AVAILED
3547	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV-CHALLAKERE-2	CHALLAKERE_66	20:10	20:16	00:06	LINE CLEAR AVAILED
3548	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV-GOWRASAMUDRA	GOWRASAMUDRA_66, KONANSAGARA_66	20:10	20:20	00:10	LINE CLEAR AVAILED
3549	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV-GOWRASAMUDRA	GOWRASAMUDRA_66, KONANSAGARA_66	18:44	18:55	00:11	TRIPPED ON FAULT
3550	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV- SEI DIAMOND SOLAR IPP_66	DIAMOND SOLAR_IPP_66	20:10	20:21	00:11	LINE CLEAR AVAILED
3551	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV- SEI VENUS DIAMOND_IPP_66	VENUS DIAMOND_IPP_66	20:10	20:21	00:11	LINE CLEAR AVAILED
3552	21-Feb-24	TUMKUR	66	LINE	THALLAK 220kV- THALLAK	THALLAK_66	20:12	20:17	00:05	LINE CLEAR AVAILED
3553	21-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	HIRIYUR_220	20:10	20:50	00:40	TRIPPED ON FAULT
3554	21-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	THALLAK_220	16:26	20:25	03:59	LINE CLEAR AVAILED
3555	21-Feb-24	TUMKUR	220	TRANSFORMER	HV2(TR2)	THALLAK_220	18:16	20:15	01:58	LINE CLEAR AVAILED
3556	21-Feb-24	TUMKUR	220	TRANSFORMER	HV3(TR3)	HIRIYUR_220	20:10	20:50	00:40	TRIPPED ON FAULT
3557	21-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV-BEERANAHALLI2	BEERANAHALLI2	10:42	17:34	06:52	LINE CLEAR AVAILED
3558	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MAREGUDDI_110	15:30	15:35	00:05	TRIPPED ON FAULT
3559	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	LAXMESHWAR_110	09:32	18:33	09:01	LINE CLEAR AVAILED
3560	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MALLIGERI_110	12:10	15:06	02:56	LINE CLEAR AVAILED
3561	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NIDAGUNDI_110	11:09	11:13	00:04	TRIPPED ON FAULT
3562	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SAIDAPUR_110	10:03	16:50	06:47	LINE CLEAR AVAILED
3563	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	ANAND NAGAR_110	16:14	16:25	00:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3564	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	LAXMESHWAR_110	09:40	17:35	07:55	LINE CLEAR AVAILED
3565	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	18:08	18:28	00:20	LINE CLEAR AVAILED
3566	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(10MVA)	VADAGOAN_110	09:44	12:48	03:04	LINE CLEAR AVAILED
3567	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA-HV3)	TIKOTA_110	16:45	19:25	02:40	LINE CLEAR AVAILED
3568	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA)	VADAGOAN_110	09:40	12:48	03:08	LINE CLEAR AVAILED
3569	22-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	LAXMESHWAR_110	09:33	18:42	09:09	LINE CLEAR AVAILED
3570	22-Feb-24	BAGALKOTE	110	TRANSFORMER	220/110KV,HV2,LV2	VAJRAMATTI_220	16:33	19:22	02:49	LINE CLEAR AVAILED
3571	22-Feb-24	BAGALKOTE	110	LINE	AEQUES220-HUKKERI	STATION NOT AFFECTED HUKKERI_110	12:16	12:27	00:11	TRIPPED ON FAULT
3572	22-Feb-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	09:29	12:03	02:34	LINE CLEAR AVAILED
3573	22-Feb-24	BAGALKOTE	110	LINE	ATHANI220- ATHANI	ATHANI_220	09:27	12:03	02:36	LINE CLEAR AVAILED
3574	22-Feb-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3575	22-Feb-24	BAGALKOTE	110	LINE	BIDNAL-NAVALGUND	BIDNAL_220	13:32	15:31	01:59	LINE CLEAR AVAILED
3576	22-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG1	CHIKKODI_220	10:50	13:10	02:20	LINE CLEAR AVAILED
3577	22-Feb-24	BAGALKOTE	110	LINE	GAJENDRAGAD-RON1	GAJENDRAGAD_110	15:24	17:13	01:49	LINE CLEAR AVAILED
3578	22-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
3579	22-Feb-24	BAGALKOTE	110	LINE	HUNGUND-ILKAL2	HUNGUND_110	06:45	06:59	00:14	TRIPPED ON FAULT
3580	22-Feb-24	BAGALKOTE	110	LINE	ITNAL-RAIBAG(HIDIKAL)	ITNAL_110	10:39	16:00	05:21	LINE CLEAR AVAILED
3581	22-Feb-24	BAGALKOTE	110	LINE	KONNUR- NAVALGUND(NARGUND)	KONNUR_110	10:37	13:37	03:00	LINE CLEAR AVAILED
3582	22-Feb-24	BAGALKOTE	110	LINE	KUDUCHI- AINAPUR(YELPARATTI)	KUDUCHI_220	10:58	11:19	00:21	TRIPPED ON FAULT
3583	22-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3584	22-Feb-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-HIDAKAL	MAHALINGAPUR_220	10:23	16:01	05:38	LINE CLEAR AVAILED
3585	22-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- BOMMANALLI	MUGALKHOD_220	12:13	12:25	00:12	LINE CLEAR AVAILED
3586	22-Feb-24	BAGALKOTE	110	LINE	NARGUND-BPCL	NARGUND_110	09:35	18:35	09:00	LINE CLEAR AVAILED
3587	22-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	13:44	15:31	01:47	LINE CLEAR AVAILED
3588	22-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-KONNUR	NAVALGUND_110	10:59	13:44	02:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3589	22-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3590	22-Feb-24	BAGALKOTE	110	LINE	PGHUNASYAL-SATISH SUGARS	SATISH SUGARS_110 STATION NOT AFFECTED PGHUNASYAL_110	7:47 (21.02.2024)	11:38 (22.02.2024)	27:51:00	LINE CLEAR AVAILED
3591	22-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
3592	22-Feb-24	BAGALKOTE	110	LINE	RAIBAG-CHIKKODI1	RAIBAG_110	10:50	13:10	02:20	LINE CLEAR AVAILED
3593	22-Feb-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD1	RON_110	15:11	15:40	00:29	LINE CLEAR AVAILED
3594	22-Feb-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD2	RON_110	15:12	15:40	00:28	LINE CLEAR AVAILED
3595	22-Feb-24	BAGALKOTE	110	LINE	TADASINAKOPPA-NARENDRA	TADASINAKOPPA_110	11:43	12:04	00:21	LINE CLEAR AVAILED
3596	22-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3597	22-Feb-24	BAGALKOTE	220	LINE	BAGEWADI- BIJAPUR1&2 (NANDHYAL1&2)	BAGEWADI_220	9:38 (17.02.2024)	5:45 (20.02.2024)	68:07:00	LINE CLEAR AVAILED
3598	22-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3599	22-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	HUBLI_220	10:45	20:25	09:40	LINE CLEAR AVAILED
3600	22-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	12:40	16:08	03:28	LINE CLEAR AVAILED
3601	22-Feb-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI	NARENDRA_220	10:45	20:25	09:40	LINE CLEAR AVAILED
3602	22-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- BELLIGAVI	RANEBENNUR_220	15:20	16:47	01:27	LINE CLEAR AVAILED
3603	22-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3604	22-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3605	22-Feb-24	BENGALURU	66	LINE	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	16:10	16:14	00:04	LINE CLEAR AVAILED
3606	22-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI,	15:33	15:43	00:10	MAIN SUPPLY FAILURE
3607	22-Feb-24	BENGALURU	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA, SHIVANAHALLI, VANDARAGUPPE, ADANI SOLAR, CNNL(EHT)	20:04	20:16	00:12	TRIPPED ON FAULT
3608	22-Feb-24	BENGALURU	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR ROAD, PURVANKARA PALM BEACH	19:01	19:23	00:22	TRIPPED ON FAULT
3609	22-Feb-24	BENGALURU	66	LINE	66KV GUNDAMGERE - D CROSS	GUNDAMGERE	18:57	19:12	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3610	22-Feb-24	BENGALURU	66	LINE	66KV GUNDAMGERE - SASALU	SASALU	18:57	19:17	00:20	TRIPPED ON FAULT
3611	22-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	NO STATION AFFECTED	08:48	11:48	03:00	TRIPPED ON FAULT
3612	22-Feb-24	BENGALURU	66	LINE	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	23:25	23:34	00:09	LINE CLEAR AVAILED
3613	22-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	23:31	23:36	00:05	LINE CLEAR AVAILED
3614	22-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	22:40	22:50	00:10	LINE CLEAR AVAILED
3615	22-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHNS WOOD	21:38	21:42	00:04	LINE CLEAR AVAILED
3616	22-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1	NO STATION AFFECTED	18:50	18:56	00:06	TRIPPED ON FAULT
3617	22-Feb-24	BENGALURU	66	LINE	66KV KENGERI SATELLITE TOWN - SIR. M.V. LAYOUT	SIR MV LAYOUT	15:00	15:05	00:05	LINE CLEAR AVAILED
3618	22-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	08:46	08:50	00:04	MAIN SUPPLY FAILURE
3619	22-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	18:46	18:52	00:06	MAIN SUPPLY FAILURE
3620	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA	08:46	08:50	00:04	MAIN SUPPLY FAILURE
3621	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA	18:46	18:52	00:06	MAIN SUPPLY FAILURE
3622	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE - 1)	JADIGENAHALLI	08:46	08:50	00:04	MAIN SUPPLY FAILURE
3623	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR 66	08:40	08:44	00:04	LINE CLEAR AVAILED
3624	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR 66	18:46	18:52	00:06	MAIN SUPPLY FAILURE
3625	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MAASTHI	08:46	08:50	00:04	MAIN SUPPLY FAILURE
3626	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MAASTHI	08:40	08:44	00:04	LINE CLEAR AVAILED
3627	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MAASTHI	18:46	18:52	00:06	MAIN SUPPLY FAILURE
3628	22-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	18:46	19:17	00:31	TRIPPED ON FAULT
3629	22-Feb-24	BENGALURU	66	LINE	66KV MANDIKAL - PERESANDRA	PERESANDRA	17:50	17:55	00:05	LINE CLEAR AVAILED
3630	22-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHIDS	18:42	18:49	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3631	22-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	18:42	18:49	00:07	LINE CLEAR AVAILED
3632	22-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	15:33	15:43	00:10	MAIN SUPPLY FAILURE
3633	22-Feb-24	BENGALURU	66	LINE	66KV PUTTENAHALLI 220 - RAILWHEEL AND AXLE SECORTES - ATTURU DG4	ATTUR YELAHANKA, WHEEL & AXLE, ESCORTS	20:33	20:44	00:11	TRIPPED ON FAULT
3634	22-Feb-24	BENGALURU	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENNIGADALE	18:50	19:00	00:10	TRIPPED ON FAULT
3635	22-Feb-24	BENGALURU	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	16:00	16:05	00:05	LINE CLEAR AVAILED
3636	22-Feb-24	BENGALURU	66	LINE	66KV SRIGANDA KAVAL - BYADARAHALLI	SRIGANDAKAVALU	15:14	16:08	00:54	LINE CLEAR AVAILED
3637	22-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	17:57	19:00	01:03	TRIPPED ON FAULT
3638	22-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - SIR. M.V LAYOUT	SIR MV LAYOUT	13:55	14:00	00:05	LINE CLEAR AVAILED
3639	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIJAYANAGARA	12:32	12:46	00:14	LINE CLEAR AVAILED
3640	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	15:30	15:38	00:08	LINE CLEAR AVAILED
3641	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DIBBURAHALLI	17:24	17:28	00:04	LINE CLEAR AVAILED
3642	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YENIGADALE	18:50	19:41	00:51	TRIPPED ON FAULT
3643	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TALAGUNDA	16:00	16:42	00:42	TRIPPED ON FAULT
3644	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIJJAHALLI	17:00	17:10	00:10	LINE CLEAR AVAILED
3645	22-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KANAKAPURA 66	11:15	13:21	02:06	LINE CLEAR AVAILED
3646	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIJAYANAGARA	12:32	12:46	00:14	LINE CLEAR AVAILED
3647	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	15:30	15:38	00:08	LINE CLEAR AVAILED
3648	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIDYANAGARA	11:00	11:19	00:19	TRIPPED ON FAULT
3649	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DIBBURAHALLI	16:20	16:24	00:04	LINE CLEAR AVAILED
3650	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	16:15	16:20	00:05	LINE CLEAR AVAILED
3651	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SADALI	13:00	13:05	00:05	LINE CLEAR AVAILED
3652	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	YENIGADALE	17:00	17:05	00:05	LINE CLEAR AVAILED
3653	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DODDABELAVANGALA	00:20	00:50	00:30	LINE CLEAR AVAILED
3654	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TEKAL	15:52	16:03	00:11	TRIPPED ON FAULT
3655	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KANAKAPURA 66	11:15	13:21	02:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3656	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	DOMMASANDRA	10:35	10:43	00:08	LINE CLEAR AVAILED
3657	22-Feb-24	BENGALURU	66	TRANSFORMER	HV2	APPAREL PARK	08:45	08:55	00:10	LINE CLEAR AVAILED
3658	22-Feb-24	BENGALURU	66	LINE	MALUR I/A - ADANI SOLAR (EHT)	ADANI SOLAR(EHT)	08:46	08:55	00:09	MAIN SUPPLY FAILURE
3659	22-Feb-24	BENGALURU	66	LINE	MALUR I/A - ADANI SOLAR (EHT)	ADANI SOLAR(EHT)	18:46	18:53	00:07	MAIN SUPPLY FAILURE
3660	22-Feb-24	BENGALURU	66	LINE	MALUR I/A - BEST STEELS(EHT)	BEST STEELS(EHT)	08:46	08:55	00:09	MAIN SUPPLY FAILURE
3661	22-Feb-24	BENGALURU	66	LINE	MALUR I/A - BEST STEELS(EHT)	BEST STEELS(EHT)	18:46	18:53	00:07	MAIN SUPPLY FAILURE
3662	22-Feb-24	BENGALURU	220	LINE	220KV BRINDAVANA 220 - SRS PEENYA 220	NO STATION AFFECTED	13:20	14:49	01:29	TRIPPED ON FAULT
3663	22-Feb-24	BENGALURU	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 1	NO STATION AFFECTED	11:04	18:35	07:31	LINE CLEAR AVAILED
3664	22-Feb-24	BENGALURU	220	LINE	220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2	NO STATION AFFECTED	11:04	18:06	07:02	LINE CLEAR AVAILED
3665	22-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NRS DB PURA 220	15:33	15:43	00:10	LINE CLEAR AVAILED
3666	22-Feb-24	BENGALURU	220	LINE	220KV NELAMANGALA 400 - DB PURA 2	NRS DB PURA 220	15:33	15:43	00:10	LINE CLEAR AVAILED
3667	22-Feb-24	BENGALURU	220	LINE	220KV YARANADANAHALLI 220 - HOSUR 220	NO STATION AFFECTED	15:09	18:23	03:14	LINE CLEAR AVAILED
3668	22-Feb-24	BENGALURU	220	TRANSFORMER	HV1	MALUR 220	18:46	18:52	00:06	TRIPPED ON FAULT
3669	22-Feb-24	BENGALURU	220	TRANSFORMER	HV2	NRS DB PURA 220	15:33	15:43	00:10	MAIN SUPPLY FAILURE
3670	22-Feb-24	BENGALURU	220	LINE	LV1	MALUR 220	08:46	08:50	00:04	TRIPPED ON FAULT
3671	22-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	SOVENHALLI_66	10:33	13:45	03:12	LINE CLEAR AVAILED
3672	22-Feb-2024	GULBARGA	66	LINE	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_HALLI_66	11:26	13:02	01:36	LINE CLEAR AVAILED
3673	22-Feb-2024	GULBARGA	66	LINE	NEELAGUNDA-HALVAGALU	HALVAGALU_66,HARVI_66,LIS(KNNL)_66	05:41	06:31	00:50	TRIPPED ON FAULT
3674	22-Feb-2024	GULBARGA	110	LINE	CHITAPUR-KORWAR TEMPLE	KORWARTEMPLE_110	13:50	13:59	00:09	TRIPPED ON FAULT
3675	22-Feb-2024	GULBARGA	110	LINE	DUBALGUNDI-BHALKI	BHALKI_110	07:20	10:40	03:20	LINE CLEAR AVAILED
3676	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KALBURGI WEST_110	11:05	15:22	04:17	LINE CLEAR AVAILED
3677	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	12:34	12:48	00:14	TRIPPED ON FAULT
3678	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KARATAGI_110	15:05	15:35	00:30	LINE CLEAR AVAILED
3679	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SHAHAPUR_220	11:55	17:58	06:03	LINE CLEAR AVAILED
3680	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	SHORAPUR_110	16:22	16:52	00:30	TRIPPED ON FAULT
3681	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV4	MUNIRABAD_220	12:03	13:51	01:48	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3682	22-Feb-2024	GULBARGA	110	TRANSFORMER	HV7	MUNIRABAD_220	05:32	05:40	00:08	TRIPPED ON FAULT
3683	22-Feb-2024	GULBARGA	110	LINE	MALLAT-BYAGWAT	BYAGWAT_110	10:32	12:15	01:43	LINE CLEAR AVAILED
3684	22-Feb-2024	GULBARGA	110	LINE	SASTHAPUR-RAJESHWAR	RAJESHWAR_110	07:20	10:40	03:20	LINE CLEAR AVAILED
3685	22-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110	00:39	00:49	00:10	TRIPPED ON FAULT
3686	22-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110	03:30	03:40	00:10	TRIPPED ON FAULT
3687	22-Feb-2024	GULBARGA	110	LINE	TALAKAL-BETAGERA	BETAGERA_110	05:20	05:35	00:15	TRIPPED ON FAULT
3688	22-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	18:35	19:45	01:10	TRIPPED ON FAULT
3689	22-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	19:45	00:00	04:15	LINE CLEAR AVAILED
3690	22-Feb-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	16:36	23:30	06:54	TRIPPED ON FAULT
3691	22-Feb-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	22:09	23:30	01:21	LINE CLEAR AVAILED
3692	22-Feb-24	HASSAN	66	LINE	DUDDA-BASAVAGHATTA	DUDDA_66	19:05	19:15	00:10	MAIN SUPPLY FAILURE
3693	22-Feb-24	HASSAN	66	LINE	DUDDA-BASAVAGHATTA	DUDDA_66	21:00	21:10	00:10	MAIN SUPPLY FAILURE
3694	22-Feb-24	HASSAN	66	LINE	HAGARE-HASSAN	HAGARE_66	13:00	16:20	03:20	MAIN SUPPLY FAILURE
3695	22-Feb-24	HASSAN	66	TRANSFORMER	HV1	HAGARE_66	13:00	16:20	03:20	MAIN SUPPLY FAILURE
3696	22-Feb-24	HASSAN	66	TRANSFORMER	HV1	HALEBEEDU_66	10:55	16:00	05:05	MAIN SUPPLY FAILURE
3697	22-Feb-24	HASSAN	66	TRANSFORMER	HV1	UGANE_66	13:00	16:16	03:16	MAIN SUPPLY FAILURE
3698	22-Feb-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	10:55	16:00	05:05	MAIN SUPPLY FAILURE
3699	22-Feb-24	HASSAN	66	LINE	LV1	MRSMSG_220	14:31	15:08	00:37	TRIPPED ON FAULT
3700	22-Feb-24	HASSAN	66	LINE	LV2	MRSMSG_220	14:31	15:12	00:41	TRIPPED ON FAULT
3701	22-Feb-24	HASSAN	66	LINE	LV3	MRSMSG_220	14:13	15:12	00:59	TRIPPED ON FAULT
3702	22-Feb-24	HASSAN	66	LINE	LV4	MRSMSG_220	14:13	15:12	00:59	TRIPPED ON FAULT
3703	22-Feb-24	HASSAN	66	LINE	MRSSHM-DVG1	MRSMSG_220	14:20	15:23	01:03	TRIPPED ON FAULT
3704	22-Feb-24	HASSAN	66	LINE	MRSSHM-DVG2	MRSMSG_220	14:20	15:05	00:45	TRIPPED ON FAULT
3705	22-Feb-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	15:57	16:10	00:13	LINE CLEAR AVAILED
3706	22-Feb-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	19:05	19:15	00:10	MAIN SUPPLY FAILURE
3707	22-Feb-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	21:00	21:10	00:10	MAIN SUPPLY FAILURE
3708	22-Feb-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	16:16	17:31	01:15	LINE CLEAR AVAILED
3709	22-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHETTANAHALLY_66	14:20	15:10	00:50	MAIN SUPPLY FAILURE
3710	22-Feb-24	HASSAN	66	LINE	UGANE-L2	UGANE_66	13:00	16:16	03:16	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3711	22-Feb-24	HASSAN	110	LINE	ARSK2-ARSKR	ARASIKERE_220	14:18	15:05	00:47	MAIN SUPPLY FAILURE
3712	22-Feb-24	HASSAN	110	LINE	ARSK2-GERUMARA	ARASIKERE_220	14:18	15:06	00:48	MAIN SUPPLY FAILURE
3713	22-Feb-24	HASSAN	110	TRANSFORMER	HV1	ARASIKERE_220	14:18	14:59	00:41	MAIN SUPPLY FAILURE
3714	22-Feb-24	HASSAN	110	TRANSFORMER	HV1	KARKALA_110	14:18	14:35	00:17	TRIPPED ON FAULT
3715	22-Feb-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	14:17	14:37	00:20	TRIPPED ON FAULT
3716	22-Feb-24	HASSAN	110	TRANSFORMER	HV2	KADUR_220	14:17	15:00	00:43	TRIPPED ON FAULT
3717	22-Feb-24	HASSAN	110	TRANSFORMER	HV2	KARKALA_110	14:18	14:35	00:17	TRIPPED ON FAULT
3718	22-Feb-24	HASSAN	110	TRANSFORMER	HV3	MRSMSG_220	14:31	15:08	00:37	TRIPPED ON FAULT
3719	22-Feb-24	HASSAN	110	TRANSFORMER	HV4	MRSMSG_220	14:31	15:08	00:37	TRIPPED ON FAULT
3720	22-Feb-24	HASSAN	110	TRANSFORMER	HV5	MRSMSG_220	14:31	14:48	00:17	TRIPPED ON FAULT
3721	22-Feb-24	HASSAN	110	TRANSFORMER	HV7	KAVOOR_220	10:00	14:17	04:17	LINE CLEAR AVAILED
3722	22-Feb-24	HASSAN	110	LINE	KADUR-AJAMPURA	KADUR_220	14:17	15:01	00:44	TRIPPED ON FAULT
3723	22-Feb-24	HASSAN	110	LINE	KADUR-NERELEKERE	KADUR_220	14:17	14:59	00:42	TRIPPED ON FAULT
3724	22-Feb-24	HASSAN	110	LINE	KADUR-RAILWAY	KADUR_220	14:34	15:00	00:26	TRIPPED ON FAULT
3725	22-Feb-24	HASSAN	110	LINE	KADUR-TNGL	KADUR_220	14:17	15:01	00:44	TRIPPED ON FAULT
3726	22-Feb-24	HASSAN	110	LINE	KADUR-YGTI	KADUR_220	14:17	15:01	00:44	TRIPPED ON FAULT
3727	22-Feb-24	HASSAN	110	LINE	KARKLA-KEMAR	KARKALA_110	14:18	14:35	00:17	TRIPPED ON FAULT
3728	22-Feb-24	HASSAN	110	LINE	LV1	MRSMSG_220	14:20	14:48	00:28	TRIPPED ON FAULT
3729	22-Feb-24	HASSAN	110	LINE	LV1	KADUR_220	14:17	15:00	00:43	TRIPPED ON FAULT
3730	22-Feb-24	HASSAN	110	LINE	LV2	MRSMSG_220	14:20	14:43	00:23	TRIPPED ON FAULT
3731	22-Feb-24	HASSAN	110	LINE	LV2	KADUR_220	14:17	14:59	00:42	TRIPPED ON FAULT
3732	22-Feb-24	HASSAN	110	LINE	LV3	MRSMSG_220	14:20	15:04	00:44	TRIPPED ON FAULT
3733	22-Feb-24	HASSAN	110	LINE	MRSSHM-GAJNUR	MRSMSG_220	14:31	15:08	00:37	TRIPPED ON FAULT
3734	22-Feb-24	HASSAN	110	LINE	MRSSHM-MPM	MRSMSG_220	14:30	15:00	00:30	TRIPPED ON FAULT
3735	22-Feb-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	14:20	14:58	00:38	TRIPPED ON FAULT
3736	22-Feb-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMSG_220	14:30	14:56	00:26	TRIPPED ON FAULT
3737	22-Feb-24	HASSAN	110	LINE	MRSSHM-SS2	MRSMSG_220	14:30	14:56	00:26	TRIPPED ON FAULT
3738	22-Feb-24	HASSAN	110	LINE	MRSSHM-TRKER	MRSMSG_220	14:30	15:14	00:44	TRIPPED ON FAULT
3739	22-Feb-24	HASSAN	110	LINE	SHRLKP-ANVTTI	SHIRALKOPPA_220	14:17	14:43	00:26	LINE CLEAR AVAILED
3740	22-Feb-24	HASSAN	110	LINE	SHRLKP-ANVTTI	SHIRALKOPPA_220	18:10	18:28	00:18	LINE CLEAR AVAILED
3741	22-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	14:17	14:43	00:26	MAIN SUPPLY FAILURE
3742	22-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	18:10	18:29	00:19	LINE CLEAR AVAILED
3743	22-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	19:31	19:35	00:04	LINE CLEAR AVAILED
3744	22-Feb-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	14:17	14:41	00:24	MAIN SUPPLY FAILURE
3745	22-Feb-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:10	19:02	00:52	LINE CLEAR AVAILED
3746	22-Feb-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:31	19:38	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3747	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	14:17	14:39	00:22	MAIN SUPPLY FAILURE
3748	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	18:10	18:32	00:22	LINE CLEAR AVAILED
3749	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	19:31	19:33	00:02	LINE CLEAR AVAILED
3750	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	14:17	14:42	00:25	MAIN SUPPLY FAILURE
3751	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:10	18:24	00:14	LINE CLEAR AVAILED
3752	22-Feb-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:31	19:36	00:05	LINE CLEAR AVAILED
3753	22-Feb-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	18:10	18:28	00:18	LINE CLEAR AVAILED
3754	22-Feb-24	HASSAN	110	LINE	SHRLKP-SORAB	ALDUR_66	19:31	19:36	00:05	LINE CLEAR AVAILED
3755	22-Feb-24	HASSAN	220	LINE	ARSK2-SHMG	ARASIKERE_220	14:18	14:58	00:40	MAIN SUPPLY FAILURE
3756	22-Feb-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	14:20	14:41	00:21	TRIPPED ON FAULT
3757	22-Feb-24	HASSAN	220	TRANSFORMER	HV1	KADUR_220	14:17	14:59	00:42	TRIPPED ON FAULT
3758	22-Feb-24	HASSAN	220	TRANSFORMER	HV2	MRSMSG_220	14:20	14:43	00:23	TRIPPED ON FAULT
3759	22-Feb-24	HASSAN	220	TRANSFORMER	HV2	KADUR_220	14:17	14:59	00:42	TRIPPED ON FAULT
3760	22-Feb-24	HASSAN	220	TRANSFORMER	HV3	MRSMSG_220	14:20	15:03	00:43	TRIPPED ON FAULT
3761	22-Feb-24	HASSAN	220	TRANSFORMER	HV3	KADUR_220	14:17	14:59	00:42	TRIPPED ON FAULT
3762	22-Feb-24	HASSAN	220	LINE	KADUR-SHIVAMOGGA	KADUR_220	14:17	15:01	00:44	TRIPPED ON FAULT
3763	22-Feb-24	HASSAN	220	LINE	MRSSHM-ANTRSNH	MRSMSG_220	14:14	14:38	00:24	TRIPPED ON FAULT
3764	22-Feb-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMSG_220	14:20	15:18	00:58	TRIPPED ON FAULT
3765	22-Feb-24	HASSAN	220	LINE	MRSSHM-DAVANGERE	MRSMSG_220	14:20	15:00	00:40	TRIPPED ON FAULT
3766	22-Feb-24	HASSAN	220	LINE	MRSSHM-HASSAN	MRSMSG_220	14:20	14:58	00:38	TRIPPED ON FAULT
3767	22-Feb-24	HASSAN	220	LINE	MRSSHM-HONNALLI	MRSMSG_220	14:20	15:00	00:40	TRIPPED ON FAULT
3768	22-Feb-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	14:03	14:56	00:53	TRIPPED ON FAULT
3769	22-Feb-24	HASSAN	220	LINE	MRSSHM-KADUR	MRSMSG_220	14:20	14:56	00:36	TRIPPED ON FAULT
3770	22-Feb-24	HASSAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	14:50	15:01	00:11	TRIPPED ON FAULT
3771	22-Feb-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	00:29	12:44	12:15	TRIPPED ON FAULT
3772	22-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	14:20	14:57	00:37	TRIPPED ON FAULT
3773	22-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH2	MRSMSG_220	14:20	14:46	00:26	TRIPPED ON FAULT
3774	22-Feb-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA3	gen_sharavaty	00:29	12:44	12:15	TRIPPED ON FAULT
3775	22-Feb-24	HASSAN	220	LINE	SHRAVITY-SHIRALKOPPA	gen_sharavaty	18:14	19:35	01:21	LINE CLEAR AVAILED
3776	22-Feb-24	HASSAN	220	LINE	SHRAVITY-SHIRALKOPPA	gen_sharavaty	14:18	15:20	01:02	TRIPPED ON FAULT
3777	22-Feb-24	HASSAN	220	LINE	SHRLKP-SHARVITY	SHIRALKOPPA_220	14:17	15:15	00:58	TRIPPED ON FAULT
3778	22-Feb-24	HASSAN	220	LINE	SHRLKP-SHARVITY	SHIRALKOPPA_220	18:14	19:35	01:21	LINE CLEAR AVAILED
3779	22-Feb-24	MYSORE	66	LINE	BANNUR-VAJMANGALA	NO STATIONS EFFECTED	20:43 (21/02/2024)	13:08:00 (22/02/2024)	16:24 HRs	LINE CLEAR AVAILED
3780	22-Feb-24	MYSORE	66	LINE	BGPURA-THALAKADU	NO STATIONS EFFECTED	01:35	3:02:10	01:26	LINE CLEAR AVAILED
3781	22-Feb-24	MYSORE	66	LINE	CHANDALLI-BG PURA	CHANDALLI_66	02:47	03:00	00:13	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3782	22-Feb-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE 2	TERAKANAMBI_66	22:30	23:25	0:54:34	TRIPPED ON FAULT
3783	22-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	DEVANOORMYS_66, RAJEEVNAGARA_66	19:20 (21/02/2024)			TRIPPED ON FAULT
3784	22-Feb-24	MYSORE	66	LINE	HANNUR-ECRN_WND	NO STATIONS EFFECTED	12:34	16:25	03:51	LINE CLEAR AVAILED
3785	22-Feb-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)	12:40 (22/02/2024)	580:01 HRs	LINE CLEAR AVAILED
3786	22-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
3787	22-Feb-24	MYSORE	66	LINE	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	20:56	21:11	00:15	TRIPPED ON FAULT
3788	22-Feb-24	MYSORE	66	LINE	HUNSUR-THAMADAHALLY 1	NO STATIONS EFFECTED	20:56	21:11	00:15	TRIPPED ON FAULT
3789	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	KADABALLY_66	15:36	16:14	00:37	LINE CLEAR AVAILED
3790	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	KRNAGAR_66	10:29	18:19	07:49	LINE CLEAR AVAILED
3791	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLI_66	13:57	14:12	00:14	TRIPPED ON FAULT
3792	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	SUNTIKOPPA_66	12:50	13:05	00:15	LINE CLEAR AVAILED
3793	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHEELUNERE_66	09:15	15:45	06:30	LINE CLEAR AVAILED
3794	22-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3795	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	DATAGALLI_66	12:07	12:47:03	00:39	LINE CLEAR AVAILED
3796	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	KRNAGAR_66	10:25	18:13	07:48	LINE CLEAR AVAILED
3797	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	PANDAVAPURA_66	22:01	22:15	00:14	TRIPPED ON FAULT
3798	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	SUNTIKOPPA_66	12:50	13:05	00:15	LINE CLEAR AVAILED
3799	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	HONNALLI_66	11:25	11:37	00:12	TRIPPED ON FAULT
3800	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	HONNALLI_66	12:10	12:20	00:10	TRIPPED ON FAULT
3801	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	HONNALLI_66	15:15	16:00	00:45	LINE CLEAR AVAILED
3802	22-Feb-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	11:45	12:40	00:55	LINE CLEAR AVAILED
3803	22-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
3804	22-Feb-24	MYSORE	66	LINE	JAKKANAHALLI-NAGMANGLA	GMALLIGERE_66	10:20	15:40	05:20	LINE CLEAR AVAILED
3805	22-Feb-24	MYSORE	66	LINE	KADAKOLA-SARGUR2	DOORA_66HULLAHALLI_66HURA_66 CHANDRAVADI_66	13:22	13:30	00:08	TRIPPED ON FAULT
3806	22-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 1	AYRAHALLI_66 MARADIHUNDI_66	06:34	06:51	00:17	TRIPPED ON FAULT
3807	22-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3808	22-Feb-24	MYSORE	66	LINE	KR NAGAR-KUSHALNAGARA	KRNAGARA_66BHERYA_66SALIGRAMA_66	16:08	18:15	02:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3809	22-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
3810	22-Feb-24	MYSORE	66	LINE	KUSHALNAGARA-MERCERA-1	NO STATIONS EFFECTED	13:01	15:28	02:26	LINE CLEAR AVAILED
3811	22-Feb-24	MYSORE	66	LINE	MUGUR-CLEANSOLAR	NO STATIONS EFFECTED	16:25	18:58	02:32	LINE CLEAR AVAILED
3812	22-Feb-24	MYSORE	66	LINE	PERIAPATNA-HANGUD	NO STATIONS EFFECTED	15:45	16:14	00:29	LINE CLEAR AVAILED
3813	22-Feb-24	MYSORE	66	LINE	POONAMPETE-HANGODU	NO STATIONS EFFECTED	15:46	16:15	00:28	LINE CLEAR AVAILED
3814	22-Feb-24	MYSORE	66	LINE	SATHEGALA-BPCL	NO STATIONS EFFECTED	11:08	18:09	07:01	LINE CLEAR AVAILED
3815	22-Feb-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	11:58 (21/02/2024)			LINE CLEAR AVAILED
3816	22-Feb-24	MYSORE	66	LINE	SRIRANGAPATNA-TUBINKERE	SRIRANGAPATNA_66	10:02	15:23	05:20	LINE CLEAR AVAILED
3817	22-Feb-24	MYSORE	66	LINE	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	13:10	15:40	02:30	LINE CLEAR AVAILED
3818	22-Feb-24	MYSORE	66	LINE	VJAYANAGARA-HOOTGALLY	NO STATIONS EFFECTED	21:27:00 (22/02/2024)			TRIPPED ON FAULT
3819	22-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	12:16	12:44	00:27	TRIPPED ON FAULT
3820	22-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	12:52	17:18	04:26	LINE CLEAR AVAILED
3821	22-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	14:45	17:19	02:34	LINE CLEAR AVAILED
3822	22-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kv-CHANNAGIRI	LINGADAHALLI_66, CHANNAGIRI_66	04:01	05:46	01:45	TRIPPED ON FAULT
3823	22-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	09:25	09:35	00:10	TRIPPED ON FAULT
3824	22-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	09:45	10:45	01:00	MAIN SUPPLY FAILURE
3825	22-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	12:25	12:45	00:20	TRIPPED ON FAULT
3826	22-Feb-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	12:45	12:50	00:05	TRIPPED ON FAULT
3827	22-Feb-24	TUMKUR	66	LINE	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	20:07(21.2.24)			TRIPPED ON FAULT
3828	22-Feb-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	16:41	17:15	00:34	TRIPPED ON FAULT
3829	22-Feb-24	TUMKUR	66	LINE	HOSADURGA_220KV-BAGUR_66KV	HOSADURGA_220KV	06:15	06:40	00:25	TRIPPED ON FAULT
3830	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHANNAGIRI_66	04:00	06:00	02:00	TRIPPED ON FAULT
3831	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	CHANNAGIRI_66	04:00	06:00	02:00	TRIPPED ON FAULT
3832	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HOSADURGA_66	10:10	10:20	00:10	TRIPPED ON FAULT
3833	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	HOSADURGA_66	10:22	10:30	00:08	TRIPPED ON FAULT
3834	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	LINGADAHALLI_66	23:00	23:04	00:04	TRIPPED ON FAULT
3835	22-Feb-24	TUMKUR	66	TRANSFORMER	HV1(TR1)	MATHOD_66	08:35	10:26	01:51	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3836	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	CHANNAGIRI_66	06:10	06:15	00:05	TRIPPED ON FAULT
3837	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	CHANNAGIRI_66	10:15	10:20	00:05	TRIPPED ON FAULT
3838	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	GOPPENAHALLI_66	23:30	23:40	00:10	TRIPPED ON FAULT
3839	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HONNALLI_66	14:26	15:04	00:37	LINE CLEAR AVAILED
3840	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	HONNALLI_66	14:22	15:02	00:40	LINE CLEAR AVAILED
3841	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	KADAJII_66	15:13	15:17	00:04	TRIPPED ON FAULT
3842	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	KUKKAWADA_66	06:38	06:46	00:07	TRIPPED ON FAULT
3843	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	MALEBENNUR_66	10:35	11:55	01:20	LINE CLEAR AVAILED
3844	22-Feb-24	TUMKUR	66	TRANSFORMER	HV2(TR2)	MATHOD_66	08:35	10:26	01:51	LINE CLEAR AVAILED
3845	22-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	08:25	08:30	00:05	MAIN SUPPLY FAILURE
3846	22-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	08:35	08:40	00:05	MAIN SUPPLY FAILURE
3847	22-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	09:20	09:35	00:15	MAIN SUPPLY FAILURE
3848	22-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	14:00	18:35	04:35	MAIN SUPPLY FAILURE
3849	22-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	19:20	21:00	01:40	MAIN SUPPLY FAILURE
3850	22-Feb-24	TUMKUR	66	LINE	KOLALA- ANTHRASANAHALLI	URDIGERE_66, KOLALA_66	12:45	17:15	04:30	MAIN SUPPLY FAILURE
3851	22-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- MADHUGIRI	MADHUGIRI_66, BADAVANAHALLI_66	11:38	12:18	00:40	LINE CLEAR AVAILED
3852	22-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- MEDIGESHI	MEDIGESHI_66	11:38	12:18	00:40	LINE CLEAR AVAILED
3853	22-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- NITRAHALLI	NITRAHALLI_66	11:38	13:12	01:34	LINE CLEAR AVAILED
3854	22-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV- SIRA 1	BUKKAPATNA_66	11:38	12:18	00:40	LINE CLEAR AVAILED
3855	22-Feb-24	TUMKUR	66	LINE	MIDIGESHI-PAVAGADA	MEDIGESHI_66	11:38	13:22	01:44	MAIN SUPPLY FAILURE
3856	22-Feb-24	TUMKUR	66	LINE	PAVAGADA- (GOWRIBIDANUR)VENKATAP URA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3857	22-Feb-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	11:31	11:50	00:18	LINE CLEAR AVAILED
3858	22-Feb-24	TUMKUR	66	LINE	SIRA220-HIRIYUR2 220	SIRA_220	11:31	11:50	00:19	LINE CLEAR AVAILED
3859	22-Feb-24	TUMKUR	66	LINE	SIRA220-MADHUGIRI 1	GULIGENAHALLI_66, MADHUGIRI_66	17:23	17:57	00:34	LINE CLEAR AVAILED
3860	22-Feb-24	TUMKUR	66	LINE	SIRA220-TAVAREKERE	TAVAREKERE_66	14:13	17:50	03:37	LINE CLEAR AVAILED
3861	22-Feb-24	TUMKUR	66	LINE	SIRA220-TAVAREKERE	TAVAREKERE_66	19:27	20:41	01:14	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3862	22-Feb-24	TUMKUR	66	LINE	SIRA66 - KALLAMBELLA	KALLAMBELLA_66(ALTERNATIVE)	12:35	13:10	00:35	LINE CLEAR AVAILED
3863	22-Feb-24	TUMKUR	66	LINE	SIRA66 - MADHUGIRI OLD(BADAVANAHALLI)	SIRA_66	12:00	12:30	00:30	LINE CLEAR AVAILED
3864	22-Feb-24	TUMKUR	66	LINE	TAVAREKERE (H)- I/CSIRA	TAVAREKERE(H)_66	09:10	09:30	00:20	TRIPPED ON FAULT
3865	22-Feb-24	TUMKUR	66	LINE	TAVAREKERE (H)- I/CSIRA	TAVAREKERE(H)_66	14:03	18:15	04:12	TRIPPED ON FAULT
3866	22-Feb-24	TUMKUR	66	LINE	TAVAREKERE (H)- I/CSIRA	TAVAREKERE(H)_66	19:26	20:50	01:24	TRIPPED ON FAULT
3867	22-Feb-24	TUMKUR	66	TRANSFORMER	TRANSFORMER	HV2(TR2)	17:25	17:35	00:10	TRIPPED ON FAULT
3868	22-Feb-24	TUMKUR	66	TRANSFORMER	TRANSFORMER	HV2(TR2)	18:10	18:20	00:10	TRIPPED ON FAULT
3869	22-Feb-24	TUMKUR	110	LINE	HANDANKERE-K B CROSS	C N HALLI_66, HANDANKERE_66	07:17	09:33	02:15	LINE CLEAR AVAILED
3870	22-Feb-24	TUMKUR	110	TRANSFORMER	HV1(TR1)	HONNAVALLI_110	13:29	14:01	00:32	LINE CLEAR AVAILED
3871	22-Feb-24	TUMKUR	110	TRANSFORMER	HV1(TR1)	HANDANAKERE_110	07:17	09:34	02:16	LINE CLEAR AVAILED
3872	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	14:20	14:40	00:20	TRIPPED ON FAULT
3873	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:20	14:40	00:20	TRIPPED ON FAULT
3874	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- TIPTUR	TIPTUR_110	14:20	14:40	00:20	TRIPPED ON FAULT
3875	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	06:40	06:52	00:12	TRIPPED ON FAULT
3876	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	14:20	14:40	00:20	TRIPPED ON FAULT
3877	22-Feb-24	TUMKUR	110	LINE	KB CROSS 220kV- THIMMANAHALLI_110	C N HALLI_110, THIMMANAHALLI_110	14:20	14:40	00:20	TRIPPED ON FAULT
3878	22-Feb-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	14:15	14:26	00:11	TRIPPED ON FAULT
3879	22-Feb-24	TUMKUR	220	LINE	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	15:17	22:47	07:29	TRIPPED ON FAULT
3880	22-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- DAVANAGERE 2	DAVANGERE_SRS_220	15:17(22.02.24)			TRIPPED ON FAULT
3881	22-Feb-24	TUMKUR	220	LINE	HONNALLI 220kV- SHIMOGA 220kV1	HONNALLI_220	14:18	15:00	00:42	MAIN SUPPLY FAILURE
3882	22-Feb-24	TUMKUR	220	LINE	HONNALLI 220kV- SHIMOGA 220kV2	HONNALLI_220	14:18	15:00	00:42	MAIN SUPPLY FAILURE
3883	22-Feb-24	TUMKUR	220	TRANSFORMER	HV1(TR1)	MADHUGIRI_220	11:34	12:16	00:42	LINE CLEAR AVAILED
3884	22-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	04:19	14:38	10:19	TRIPPED ON FAULT
3885	22-Feb-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:07	19:41	09:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3886	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED MELLIGERI_110	12:05	14:04	01:59	LINE CLEAR AVAILED
3887	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED SAMBAPUR_110	12:05	13:35	01:30	LINE CLEAR AVAILED
3888	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BIDI_110	18:21	20:35	02:14	LINE CLEAR AVAILED
3889	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	10:05	10:09	00:04	TRIPPED ON FAULT
3890	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	13:38	13:47	00:09	TRIPPED ON FAULT
3891	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	07:51	08:00	00:09	TRIPPED ON FAULT
3892	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	10:25	10:30	00:05	TRIPPED ON FAULT
3893	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	10:50	10:55	00:05	TRIPPED ON FAULT
3894	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	11:31	11:50	00:19	LINE CLEAR AVAILED
3895	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	09:45	10:05	00:20	LINE CLEAR AVAILED
3896	23-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED LAKSHMESHWER_110	13:28	13:39	00:11	TRIPPED ON FAULT
3897	23-Feb-24	BAGALKOTE	110	LINE	AEQUS220-HUKKERI	STATION NOT AFFECTED AEQUS_220	12:16	12:27	00:11	TRIPPED ON FAULT
3898	23-Feb-24	BAGALKOTE	110	LINE	ATHANI220- GHATANATTI	ATHANI_220	10:06	15:18	05:12	LINE CLEAR AVAILED
3899	23-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
3900	23-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
3901	23-Feb-24	BAGALKOTE	110	LINE	HAVERI220-TILUVALLI(HANGAL)	STATION NOT AFFECTED HAVERI_220	06:50	07:02	00:12	TRIPPED ON FAULT
3902	23-Feb-24	BAGALKOTE	110	LINE	HIREMASALI-F1 (INDI220)	HIREMASALI_110	17:44	18:44	01:00	LINE CLEAR AVAILED
3903	23-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
3904	23-Feb-24	BAGALKOTE	110	LINE	KUDACHI220- AINAPUR	STATION NOT AFFECTED KUDACHI_220	10:04	17:23	07:19	LINE CLEAR AVAILED
3905	23-Feb-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	14:26	14:40	00:14	LINE CLEAR AVAILED
3906	23-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3907	23-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3908	23-Feb-24	BAGALKOTE	110	LINE	MUNDARGI-VIJAYSUGARS	VIJAYSUGARS_110 STATION NOT AFFECTED MUNDARGI_110	17:09	17:25	00:16	TRIPPED ON FAULT
3909	23-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3910	23-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
3911	23-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	02:44	03:23	00:39	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3912	23-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	07:22	07:50	00:28	TRIPPED ON FAULT
3913	23-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR-HOSAHONNATTI	RANEBENNUR_220	02:44	03:23	00:39	LINE CLEAR AVAILED
3914	23-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR-RATTIHALLI(TUMMINKATTE)	RANEBENNUR_220	02:59	03:22	00:23	LINE CLEAR AVAILED
3915	23-Feb-24	BAGALKOTE	110	LINE	SIRSI-KUMTA1	SIRSI_110	14:15	14:35	00:20	TRIPPED ON FAULT
3916	23-Feb-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	14:14	14:32	00:18	TRIPPED ON FAULT
3917	23-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- UDAKERI	STATION NOT AFFECTED SOUDATTI_220	17:40	20:01	02:21	LINE CLEAR AVAILED
3918	23-Feb-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-MACHE	SUVARNA SOUDA_110	10:28	10:39	00:11	LINE CLEAR AVAILED
3919	23-Feb-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	19:45 (23.02.2024)			LINE CLEAR AVAILED
3920	23-Feb-24	BAGALKOTE	110	LINE	UDAKERI-NOKAR BHUMI	UDAKERI_110	17:40	20:08	02:28	LINE CLEAR AVAILED
3921	23-Feb-24	BAGALKOTE	110	LINE	UGAR KHUD-UGAR SUGARS	UGAR KHUD_110	04:05	04:10	00:05	LINE CLEAR AVAILED
3922	23-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3923	23-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1,HV2, HV3	ATHANI_220, ATHANI_110, HALIYAL_110, KSSKN_110, BALIGERI_110	14:19	14:38	00:19	LINE CLEAR AVAILED
3924	23-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	MAHALINGAPUR_220, HIDIKAL_110,RABAKAVI_110,TERDAL_110	16:00	16:08	00:08	TRIPPED ON FAULT
3925	23-Feb-24	BAGALKOTE	220	LINE	ATHANI- KAKMARI1&2	ATHANI_220	14:19	14:38	00:19	LINE CLEAR AVAILED
3926	23-Feb-24	BAGALKOTE	220	LINE	ATHANI- KUDACHI	ATHANI_220	14:19	14:47	00:28	TRIPPED ON FAULT
3927	23-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3928	23-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	07:05	17:37	10:32	TRIPPED ON FAULT
3929	23-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	15:59	17:37	01:38	LINE CLEAR AVAILED
3930	23-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	11:06	19:24	08:18	LINE CLEAR AVAILED
3931	23-Feb-24	BAGALKOTE	220	LINE	MAHALINGAPUR-ATHANI	MAHALINGAPUR_220	14:28	14:38	00:10	TRIPPED ON FAULT
3932	23-Feb-24	BAGALKOTE	220	LINE	MAHALINGAPUR-RABAKAVI	MAHALINGAPUR_220	16:00	16:14	00:14	TRIPPED ON FAULT
3933	23-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	02:44	03:15	00:31	TRIPPED ON FAULT
3934	23-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3935	23-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
3936	23-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3937	23-Feb-24	BAGALKOTE	220	LINE	VAJRAMATTI-KAWATAGI LIS	VAJRAMATTI_220	10:41	12:34	01:53	LINE CLEAR AVAILED
3938	23-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3939	23-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	16:36	17:06	00:30	TRIPPED ON FAULT
3940	23-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - AMARJYOTHI 1 - LEELAVENTURE (TAP)	LEELA VENTURE, AMARJYOTHI	17:04	17:25	00:21	TRIPPED ON FAULT
3941	23-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:25	15:35	00:10	LINE CLEAR AVAILED
3942	23-Feb-24	BENGALURU	66	LINE	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	03:45	04:05	00:20	LINE CLEAR AVAILED
3943	23-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	03:15	03:23	00:08	LINE CLEAR AVAILED
3944	23-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	MARALAVADI, GODUR	09:23	09:33	00:10	TRIPPED ON FAULT
3945	23-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA,ANNABEL(DLF)	10:38	10:46	00:08	LINE CLEAR AVAILED
3946	23-Feb-24	BENGALURU	66	LINE	66KV KHODAYS 220 - FALSON CITY	PRESTIGE FALCON CITY	10:38	10:44	00:06	LINE CLEAR AVAILED
3947	23-Feb-24	BENGALURU	66	LINE	66KV LAKKUR - DEVANAGUNDHI	DEVANAGUNDHI	12:52	13:15	00:23	LINE CLEAR AVAILED
3948	23-Feb-24	BENGALURU	66	LINE	66KV MARALAVADI - GODUR	GODUR	20:02	20:12	00:10	TRIPPED ON FAULT
3949	23-Feb-24	BENGALURU	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	10:02	10:04	00:02	LINE CLEAR AVAILED
3950	23-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - MUDDENAHALLI (NANDI)	CB PURA I/A, CB PURA URBAN, NALLIMARADANAHALLI, NANDI	22:14	22:33	00:19	TRIPPED ON FAULT
3951	23-Feb-24	BENGALURU	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	06:47	07:02	00:15	TRIPPED ON FAULT
3952	23-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	11:43	12:40	00:57	MAIN SUPPLY FAILURE
3953	23-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:42	12:40	00:58	MAIN SUPPLY FAILURE
3954	23-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:43	12:38	00:55	MAIN SUPPLY FAILURE
3955	23-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML(EHT), TEKAL, THORALAKKI, BUDIKOTE	05:37	06:00	00:23	TRIPPED ON FAULT
3956	23-Feb-24	BENGALURU	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML(EHT), TEKAL, THORALAKKI, BUDIKOTE	05:37	06:00	00:23	TRIPPED ON FAULT
3957	23-Feb-24	BENGALURU	66	LINE	66KV TALGAWARA - Y HUNSENAHALLY	Y HUNSENAHALLI	18:45	18:50	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3958	23-Feb-24	BENGALURU	66	LINE	66KV TEKAL - BUDIKOTE	BUDIKOTE	08:10	08:20	00:10	LINE CLEAR AVAILED
3959	23-Feb-24	BENGALURU	66	LINE	66KV TEKAL - THORALAKKI	THORALAKKI	08:10	08:20	00:10	LINE CLEAR AVAILED
3960	23-Feb-24	BENGALURU	66	LINE	66KV TUBAGERE - CB PURA I/A 1	CB PURA I/A	06:48	07:05	00:17	TRIPPED ON FAULT
3961	23-Feb-24	BENGALURU	66	LINE	66KV TUBAGERE - CB PURA I/A 1	CB PURA I/A, CB PURA URBAN, NALLIMARADANAHALLI, NANDI	22:13	22:35	00:22	TRIPPED ON FAULT
3962	23-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	03:16	03:27	00:11	LINE CLEAR AVAILED
3963	23-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	23:19	23:40	00:21	TRIPPED ON FAULT
3964	23-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TEKAL	08:10	08:20	00:10	LINE CLEAR AVAILED
3965	23-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	03:16	03:33	00:17	TRIPPED ON FAULT
3966	23-Feb-24	BENGALURU	66	TRANSFORMER	HV1	CHANDAPURA	13:15	13:43	00:28	LINE CLEAR AVAILED
3967	23-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	11:43	12:35	00:52	MAIN SUPPLY FAILURE
3968	23-Feb-24	BENGALURU	66	TRANSFORMER	HV2	YENNIGADALE	14:51	15:08	00:17	TRIPPED ON FAULT
3969	23-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KANASAWADI	14:30	14:50	00:20	LINE CLEAR AVAILED
3970	23-Feb-24	BENGALURU	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	23:19	23:40	00:21	TRIPPED ON FAULT
3971	23-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TEKAL	08:10	08:20	00:10	LINE CLEAR AVAILED
3972	23-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	11:43	12:37	00:54	MAIN SUPPLY FAILURE
3973	23-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 2	SARJAPURA 220	11:43	12:33	00:50	TRIPPED ON FAULT
3974	23-Feb-2024	GULBARGA	66	LINE	HPHALLI-ITTAGGI(IDLE LINE)	HARAPANAHALLI_66,UPNAYAKAN AHALLI_66	14:10	14:30	00:20	LINE CLEAR AVAILED
3975	23-Feb-2024	GULBARGA	66	LINE	ITTAGI-BENNEHALLI	BENNEHALLI_66, KOTTUR_66	11:00	16:55	05:55	LINE CLEAR AVAILED
3976	23-Feb-2024	GULBARGA	66	LINE	TELAGI-YARAGUNTA,KURUBARAHALLI	YARAGUNTA_66,OBBIJJIHALLI_66, KURUBARAHALLI_66	07:00	07:15	00:15	TRIPPED ON FAULT
3977	23-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	CHICKSUGUR_110	07:55	11:20	03:25	LINE CLEAR AVAILED
3978	23-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	08:05	08:13	00:08	TRIPPED ON FAULT
3979	23-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	13:56	13:59	00:03	TRIPPED ON FAULT
3980	23-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	13:35	13:45	00:10	TRIPPED ON FAULT
3981	23-Feb-2024	GULBARGA	220	LINE	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	22:57	00:00	01:03	LINE CLEAR AVAILED
3982	23-Feb-2024	GULBARGA	220	LINE	KUSHTAGI-SULEKAL	SULEKAL_220	16:27	16:35	00:08	TRIPPED ON FAULT
3983	23-Feb-2024	GULBARGA	220	LINE	KUSHTAGI-SULEKAL	SULEKAL_220	16:35	18:38	02:03	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3984	23-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	06:50	09:24	02:34	LINE CLEAR AVAILED
3985	23-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	00:00	09:24	09:24	LINE CLEAR AVAILED
3986	23-Feb-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	07:24	07:58	00:34	MAIN SUPPLY FAILURE
3987	23-Feb-24	HASSAN	66	LINE	ALDURCHIKKAMAGLUR	ALDUR_66	07:24	07:58	00:34	MAIN SUPPLY FAILURE
3988	23-Feb-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	11:30	12:47	01:17	LINE CLEAR AVAILED
3989	23-Feb-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	11:30	12:47	01:17	LINE CLEAR AVAILED
3990	23-Feb-24	HASSAN	66	TRANSFORMER	HV1	HIRESAVE_66	11:55	13:35	01:40	LINE CLEAR AVAILED
3991	23-Feb-24	HASSAN	66	TRANSFORMER	HV1	HIRESAVE_66	15:10	15:25	00:15	LINE CLEAR AVAILED
3992	23-Feb-24	HASSAN	66	TRANSFORMER	HV1	RAMESHWARNAGRA_66	12:02	15:13	03:11	LINE CLEAR AVAILED
3993	23-Feb-24	HASSAN	66	TRANSFORMER	HV2	HARIHARPURA_66	11:30	12:47	01:17	LINE CLEAR AVAILED
3994	23-Feb-24	HASSAN	66	TRANSFORMER	HV2	HIRESAVE_66	15:10	15:50	00:40	LINE CLEAR AVAILED
3995	23-Feb-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGRA_66	10:05	13:50	03:45	LINE CLEAR AVAILED
3996	23-Feb-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	13:15	13:30	00:15	TRIPPED ON FAULT
3997	23-Feb-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	14:55	15:00	00:05	TRIPPED ON FAULT
3998	23-Feb-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	18:15	18:54	00:39	MAIN SUPPLY FAILURE
3999	23-Feb-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	18:15	18:54	00:39	MAIN SUPPLY FAILURE
4000	23-Feb-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	18:15	18:54	00:39	MAIN SUPPLY FAILURE
4001	23-Feb-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	18:15	19:04	00:49	MAIN SUPPLY FAILURE
4002	23-Feb-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	18:15	19:11	00:56	MAIN SUPPLY FAILURE
4003	23-Feb-24	HASSAN	110	LINE	KADUR-NAGENAHALLI	KADUR_220	11:25	11:37	00:12	LINE CLEAR AVAILED
4004	23-Feb-24	HASSAN	110	LINE	KADUR-YGTI	KADUR_220	11:25	11:37	00:12	LINE CLEAR AVAILED
4005	23-Feb-24	HASSAN	110	LINE	KARKLA-HIRIYADKA	KARKLA_110	18:16	18:30	00:14	MAIN SUPPLY FAILURE
4006	23-Feb-24	HASSAN	110	LINE	KARKLA-KEMAR	KARKLA_110	18:16	18:30	00:14	MAIN SUPPLY FAILURE
4007	23-Feb-24	HASSAN	110	LINE	KEMAR-BELMAN	KEMAR_220	18:15	18:54	00:39	MAIN SUPPLY FAILURE
4008	23-Feb-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	18:15	18:54	00:39	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4009	23-Feb-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	18:15	18:54	00:39	MAIN SUPPLY FAILURE
4010	23-Feb-24	HASSAN	110	LINE	KEMAR-KARKALA	KEMAR_220	18:15	18:33	00:18	MAIN SUPPLY FAILURE
4011	23-Feb-24	HASSAN	110	LINE	KEMAR-MOBBIDRE	KEMAR_220	18:15	18:29	00:14	MAIN SUPPLY FAILURE
4012	23-Feb-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	18:15	18:58	00:43	MAIN SUPPLY FAILURE
4013	23-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	15:35	17:27	01:52	LINE CLEAR AVAILED
4014	23-Feb-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	15:35	15:46	00:11	LINE CLEAR AVAILED
4015	23-Feb-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	17:21	17:27	00:06	LINE CLEAR AVAILED
4016	23-Feb-24	HASSAN	110	LINE	LV2	KEMAR_220	18:15	18:53	00:38	MAIN SUPPLY FAILURE
4017	23-Feb-24	HASSAN	110	LINE	LV3	KEMAR_220	18:15	19:09	00:54	MAIN SUPPLY FAILURE
4018	23-Feb-24	HASSAN	110	LINE	MRSSHM-TRKER	MRSMSG_220	14:47	19:43	04:56	TRIPPED ON FAULT
4019	23-Feb-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	15:40	17:22	01:42	LINE CLEAR AVAILED
4020	23-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPPA_220	10:14	17:44	07:30	LINE CLEAR AVAILED
4021	23-Feb-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPPA_220	01:55	02:21	00:26	TRIPPED ON FAULT
4022	23-Feb-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_110	15:40	17:22	01:42	LINE CLEAR AVAILED
4023	23-Feb-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	18:15	18:52	00:37	TRIPPED ON FAULT
4024	23-Feb-24	HASSAN	220	TRANSFORMER	HV3	KEMAR_220	18:15	19:07	00:52	TRIPPED ON FAULT
4025	23-Feb-24	HASSAN	220	LINE	MRSSHM-ANTRSNH	MRSMSG_220	14:59	15:53	00:54	TRIPPED ON FAULT
4026	23-Feb-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	11:20	13:44	02:24	TRIPPED ON FAULT
4027	23-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMSG_220	12:05	17:43	05:38	TRIPPED ON FAULT
4028	23-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMSG_220	14:56	16:23	01:27	TRIPPED ON FAULT
4029	23-Feb-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	12:05	17:43	05:38	TRIPPED ON FAULT
4030	23-Feb-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	14:56	16:23	01:27	TRIPPED ON FAULT
4031	23-Feb-24	MYSORE	66	LINE	AYRALLI-VAJMANANGALA-KADAKOLA 1	AYRALLI_66	07:50	17:40	09:50	LINE CLEAR AVAILED
4032	23-Feb-24	MYSORE	66	LINE	BG PURA-CHANDALLI	CHANDALLI_66	13:50	14:47	00:56	LINE CLEAR AVAILED
4033	23-Feb-24	MYSORE	66	LINE	CHAMALAPURA-GAMANAHALLI	GAMANAHALLY_66	23:02	23:05	00:03	LINE CLEAR AVAILED
4034	23-Feb-24	MYSORE	66	LINE	CHANDALLI-THALAKADU	NO STATIONS EFFECTED	14:21	14:38	00:17	LINE CLEAR AVAILED
4035	23-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:42			LINE CLEAR AVAILED
4036	23-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	DEVANOORMYS_66, RAJEEVNAGARA_66	19:20 (21/02/2024)			TRIPPED ON FAULT
4037	23-Feb-24	MYSORE	66	LINE	FTS-VIJAYANAGARA	VIJAYANAGRAMYS_66	16:19	16:40	00:20	TRIPPED ON FAULT
4038	23-Feb-24	MYSORE	66	LINE	HANNUR-ECOREN_WIND	NO STATIONS EFFECTED	15:21	17:28	02:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4039	23-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4040	23-Feb-24	MYSORE	66	LINE	HUNSUR-BANNIKUPPE	BANNIKUPPE_66	06:20	06:33	00:13	TRIPPED ON FAULT
4041	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	16:32	18:03	01:31	LINE CLEAR AVAILED
4042	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	16:25	16:35	00:10	TRIPPED ON FAULT
4043	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	KIRUGAVALU_66	14:24	17:56	03:32	LINE CLEAR AVAILED
4044	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	VIJAYANAGRAMYS_66	19:34	19:36	00:02	MAIN SUPPLY FAILURE
4045	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	VYASRAJPURA_66	10:04	17:36	07:32	LINE CLEAR AVAILED
4046	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	VYASRAJPURA_66	19:32	19:35	00:03	TRIPPED ON FAULT
4047	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	DODDINADUVADI_66	20:47			TRIPPED ON FAULT
4048	23-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4049	23-Feb-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	20:09	20:15	00:06	TRIPPED ON FAULT
4050	23-Feb-24	MYSORE	66	TRANSFORMER	HV2	VIJAYANAGRAMYS_66	19:34	19:37	00:02	MAIN SUPPLY FAILURE
4051	23-Feb-24	MYSORE	66	TRANSFORMER	HV2	VYASRAJPURA_66	10:04	17:36	07:32	LINE CLEAR AVAILED
4052	23-Feb-24	MYSORE	66	TRANSFORMER	HV2	CHANDAKAVADI_66	17:30			TRIPPED ON FAULT
4053	23-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
4054	23-Feb-24	MYSORE	66	LINE	KIRUGAVLU-MALIYUR	NO STATIONS EFFECTED	16:41	18:01	01:20	LINE CLEAR AVAILED
4055	23-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4056	23-Feb-24	MYSORE	66	LINE	KOTHANUR-DODDINDHUVADI	NO STATIONS EFFECTED	20:50	22:45	01:55	TRIPPED ON FAULT
4057	23-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
4058	23-Feb-24	MYSORE	66	LINE	MANDYA-KK HALLI	NO STATIONS EFFECTED	11:23			LINE CLEAR AVAILED
4059	23-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-KESALAGERE	NO STATIONS EFFECTED	15:47	16:12	00:25	TRIPPED ON FAULT
4060	23-Feb-24	MYSORE	66	LINE	SATHEGALA-BPCL	NO STATIONS EFFECTED	09:20	14:41	05:21	LINE CLEAR AVAILED
4061	23-Feb-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	11:58 (21/02/2024)	15:09 (23/02/2024)	51:11 HRs	LINE CLEAR AVAILED
4062	23-Feb-24	MYSORE	66	LINE	VIJAYANAGARA-FTS	NO STATIONS EFFECTED	19:34			LINE CLEAR AVAILED
4063	23-Feb-24	MYSORE	66	LINE	VJAYANAGARA-HOOTGALLY	NO STATIONS EFFECTED	21:27:00 (22/02/2024)	19:36 (23/02/2024)	22:09 HRs	TRIPPED ON FAULT
4064	23-Feb-24	MYSORE	220	LINE	MADHUVANAHALLI-WARDHA SOLAR	NO STATIONS EFFECTED	18:00	18:40	00:40	LINE CLEAR AVAILED
4065	23-Feb-24	TUMKUR	66	LINE	SIRA 220-TAVAREKERE66 L 9	TAVAREKERE_66	11:35	17:15	05:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4066	23-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66 ,MALLADIHALLI_66,NALLUR_66	15:43	15:46	00:03	TRIPPED ON FAULT
4067	23-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-HIREMALLANAHOLE 220	CHITRADURGA_220	12:28	17:43	05:15	LINE CLEAR AVAILED
4068	23-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-HIREMALLANAHOLE 220	CHITRADURGA_220	19:22	19:26	00:04	LINE CLEAR AVAILED
4069	23-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS- ANGODU 66	ANGODU_66	14:10	15:12	01:02	TRIPPED ON FAULT
4070	23-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MAYAKONDA 66	MAYAKONDA_66	12:37	13:17	00:40	TRIPPED ON FAULT
4071	23-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	20:10 (21.02.2024)	13:10 (23.02.2024)	1DAY,17Hr	LINE CLEAR AVAILED
4072	23-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	04:15	04:45	00:30	TRIPPED ON FAULT
4073	23-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	20:35	20:55	00:20	TRIPPED ON FAULT
4074	23-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	11:35	13:16	01:41	MAIN SUPPLY FAILURE
4075	23-Feb-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	12:50	13:16	00:26	LINE CLEAR AVAILED
4076	23-Feb-24	TUMKUR	66	LINE	LOKIKERE-KEREBILCHI_66	KEREBILCHI_66, SANTHEBENNURU_66	10:30	11:15	00:45	TRIPPED ON FAULT
4077	23-Feb-24	TUMKUR	66	LINE	PAVAGADA 220kV-SHYLAPURA	SHYLAPURA_66	17:20	17:40	00:20	TRIPPED ON FAULT
4078	23-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4079	23-Feb-24	TUMKUR	66	LINE	SHYLAPURA- PAVAGADA	SHYLAPURA_66	17:20	17:40	00:20	TRIPPED ON FAULT
4080	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRADURGA_66	09:00	09:05	00:05	TRIPPED ON FAULT
4081	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	LOKERE_66	02:32	02:40	00:08	TRIPPED ON FAULT
4082	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	KADAJII_66	08:45	08:50	00:05	TRIPPED ON FAULT
4083	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MYLANAHALLI_66	06:40	06:45	00:05	TRIPPED ON FAULT
4084	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-1&TR-2	JAVAGONDANAHALLI_66	13:10	13:16	00:06	LINE CLEAR AVAILED
4085	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	BENNIKERE_66	07:10	07:20	00:10	TRIPPED ON FAULT
4086	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	BENNIKERE_66	06:50	07:00	00:10	TRIPPED ON FAULT
4087	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KADAJII_66	20:35	20:40	00:05	TRIPPED ON FAULT
4088	23-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	NAYAKANAHATTI_66	14:45	14:55	00:10	TRIPPED ON FAULT
4089	23-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HONNALLI 220KV -2	BENKIKERE_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4090	23-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HONNALLI 220KV -2	BENKIKERE_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4091	23-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HOSADURGA220 1	HOSADURGA_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4092	23-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HOSADURGA220 2	HOSADURGA_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4093	23-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- HONNALLI-1	HONNALLI_220	15:04	15:20	00:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4094	23-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV-DAVANAGERE 2	DAVANGERE_SRS_220	15:17 (22.02.2024)	14:46 (23.02.2024)	23:28	TRIPPED ON FAULT
4095	23-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	07:04	17:36	10:32	TRIPPED ON FAULT
4096	23-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:59	17:37	01:38	LINE CLEAR AVAILED
4097	23-Feb-24	TUMKUR	220	LINE	GUTUR 400-DAVANGERE SRS 1	GUTUR_400	14:13	14:55	00:42	TRIPPED ON FAULT
4098	23-Feb-24	TUMKUR	220	LINE	GUTUR_400-DAVANGERE SRS 3	GUTUR_220	14:13	14:52	00:39	TRIPPED ON FAULT
4099	23-Feb-24	TUMKUR	220	LINE	GUTUR_400-RANEBENNUR	GUTUR_400	02:45	03:15	00:30	TRIPPED ON FAULT
4100	23-Feb-24	TUMKUR	220	LINE	JAGALUR_400-CHITRADURGA220KV 1	CHITRADURGA_220	15:11	17:54	02:43	LINE CLEAR AVAILED
4101	23-Feb-24	TUMKUR	220	LINE	JAGALUR_400-KUDLIGE 220KV 2	JAGALUR_400	16:58	17:35	00:37	LINE CLEAR AVAILED
4102	23-Feb-24	TUMKUR	220	LINE	JAGALUR_400-THALLAKK 220 1	THALLAKK_220	15:13	17:58	02:45	LINE CLEAR AVAILED
4103	23-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	11:25	11:40	00:15	LOAD CURTAILMENT
4104	23-Feb-24	TUMKUR	220	TRANSFORMER	TR-1	DAVANGERE_SRS_220	14:10	15:14	01:04	TRIPPED ON FAULT
4105	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BENAKATTI(BGM)_110	09:04	11:30	02:26	TRIPPED ON FAULT
4106	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	16:29	17:19	00:50	LINE CLEAR AVAILED
4107	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	16:29	17:19	00:50	LINE CLEAR AVAILED
4108	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	09:35	10:17	00:42	LINE CLEAR AVAILED
4109	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	NANADI_110	10:05	15:03	04:58	LINE CLEAR AVAILED
4110	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	SADALAGA_110	10:10	18:00	07:50	LINE CLEAR AVAILED
4111	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	12:29	12:44	00:15	TRIPPED ON FAULT
4112	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KADAKLAT_110	14:05 (24.02.2024)			LINE CLEAR AVAILED
4113	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	SADALAGA_110	10:12	17:40	07:28	LINE CLEAR AVAILED
4114	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	NANADI_110	10:00	17:23	07:23	LINE CLEAR AVAILED
4115	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	SADALAGA_110	10:10	18:00	07:50	LINE CLEAR AVAILED
4116	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	ZALKI_110	06:08	06:13	00:05	TRIPPED ON FAULT
4117	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YARAGATTI_110	03:39	09:05	05:26	LINE CLEAR AVAILED
4118	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	RAIBAG_110	17:09	19:50	02:41	LINE CLEAR AVAILED
4119	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	VAJRAMATTI_110	16:50	16:55	0:05	TRIPPED ON FAULT
4120	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	YARAGATTI_110	03:39	09:05	05:26	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4121	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA-HV1)	RAIBAG_110	09:54	12:28	02:34	LINE CLEAR AVAILED
4122	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GULEDAGUDDA_110	17:30	17:35	0:05	LINE CLEAR AVAILED
4123	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	SADALAGA_110	10:10	18:00	07:50	LINE CLEAR AVAILED
4124	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	ZALKI_110	12:19	14:08	01:49	LINE CLEAR AVAILED
4125	24-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA-HV4)	KULIGOD_110	14:10	20:46	06:36	TRIPPED ON FAULT
4126	24-Feb-24	BAGALKOTE	110	LINE	AEQUS220-SANKESHWAR	STATION NOT AFFECTED AEQUS_220	12:20	15:01	2:41	LINE CLEAR AVAILED
4127	24-Feb-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	STATION NOT AFFECTED ATHANI_220	23:59	19:01	19:01	LINE CLEAR AVAILED
4128	24-Feb-24	BAGALKOTE	110	LINE	ATHANI220-ATHANI	STATION NOT AFFECTED ATHANI_220	17:09	18:59	1:50	LINE CLEAR AVAILED
4129	24-Feb-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4130	24-Feb-24	BAGALKOTE	110	LINE	BENAKATTI(BGM)- YARAGATTI	BENAKATTI(BGM)_110	03:24	09:02	05:38	LINE CLEAR AVAILED
4131	24-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- BHOJ(NANADI)	STATION NOT AFFECTED CHIKKODI_220	10:27	13:05	02:38	LINE CLEAR AVAILED
4132	24-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- NIPPANI (KHADAKALAT)	STATION NOT AFFECTED CHIKKODI_220	11:03	13:36	02:33	LINE CLEAR AVAILED
4133	24-Feb-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSTAGI (HANAMSAGAR)	GAJENDRAGAD_110	02:24	02:33	00:09	LINE CLEAR AVAILED
4134	24-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA- MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
4135	24-Feb-24	BAGALKOTE	110	LINE	HIREBEVANUR-INDI (ROODAGI)	ROODAGI_110 STATION NOT AFFECTED HIREBEVANUR_110	21:19	21:28	00:09	TRIPPED ON FAULT
4136	24-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
4137	24-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4138	24-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4139	24-Feb-24	BAGALKOTE	110	LINE	NANADI-CHIKKODI220	NANADI_110	10:15	13:06	02:51	LINE CLEAR AVAILED
4140	24-Feb-24	BAGALKOTE	110	LINE	NANADI-DODNVR (BGPL SOLAR)	BGPL SOLAR_110 NANADI_110	10:25	13:15	02:50	LINE CLEAR AVAILED
4141	24-Feb-24	BAGALKOTE	110	LINE	NAVALAGUND-KONNUR	STATION NOT AFFECTED NAVALAGUND_110	09:08 (24.02.2024)			LINE CLEAR AVAILED
4142	24-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4143	24-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4144	24-Feb-24	BAGALKOTE	110	LINE	SANKESHWER-AEQUUS220	SANKESHWER_110	12:20	15:15	2:55	LINE CLEAR AVAILED
4145	24-Feb-24	BAGALKOTE	110	LINE	SANKESHWER-CHIKKODI	SANKESHWER_110	12:15	15:17	03:02	LINE CLEAR AVAILED
4146	24-Feb-24	BAGALKOTE	110	LINE	SANKESHWER-HIRASUGARS1	HIRASUGARS_110 SANKESHWER_110	12:40	15:18	02:38	LINE CLEAR AVAILED
4147	24-Feb-24	BAGALKOTE	110	LINE	SANKESHWER-HIRASUGARS2	HIRASUGARS_110 SANKESHWER_110	12:40	15:18	02:38	LINE CLEAR AVAILED
4148	24-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220-BENAKATTI	STATION NOT AFFECTED SOUDATTI_220	2:38	3:25	0:47	TRIPPED ON FAULT
4149	24-Feb-24	BAGALKOTE	110	LINE	SOUDATTI-ENERCON2	SOUDATTI_110	13:31	14:35	01:04	LINE CLEAR AVAILED
4150	24-Feb-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	19:45 (23.02.2024)	4:49 (24.02.2024)	09:04	LINE CLEAR AVAILED
4151	24-Feb-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	19:01 (24.02.2024)			LINE CLEAR AVAILED
4152	24-Feb-24	BAGALKOTE	110	LINE	UGAR KHUD-KAGAWAD	UGAR KHUD_110	18:52	20:17	01:25	TRIPPED ON FAULT
4153	24-Feb-24	BAGALKOTE	110	LINE	UGAR KHUD-UGAR SUGARS	UGAR KHUD_110	18:51	19:00	00:09	TRIPPED ON FAULT
4154	24-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4155	24-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220-KATARAKI	STATION NOT AFFECTED VAJRAMATTI_220	04:15	04:25	00:10	TRIPPED ON FAULT
4156	24-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)			LINE CLEAR AVAILED
4157	24-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)			LINE CLEAR AVAILED
4158	24-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4159	24-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:57	20:14	09:17	LINE CLEAR AVAILED
4160	24-Feb-24	BAGALKOTE	220	LINE	KARWAR- KADRA1	STATION NOT AFFECTED KARWAR_220	07:35	08:00	00:25	LINE CLEAR AVAILED
4161	24-Feb-24	BAGALKOTE	220	LINE	KARWAR- KADRA2	KARWAR_220	07:35	08:00	0:25	LINE CLEAR AVAILED
4162	24-Feb-24	BAGALKOTE	220	LINE	NARENDRA- HUBLI1	STATION NOT AFFECTED NARENDRA_220	11:02	20:15	09:13	LINE CLEAR AVAILED
4163	24-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4164	24-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4165	24-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4166	24-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4167	24-Feb-24	BENGALURU	66	LINE	66KV BOMMEPALLI - YENIGADALE	BOMMEPALLI CROSS	22:28	22:30	00:02	LINE CLEAR AVAILED
4168	24-Feb-24	BENGALURU	66	LINE	66KV BOMMEPALLI - YENNIGADALE	YENNIGADALE	18:05	18:07	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4169	24-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDAGUNTE	22:28	22:32	00:04	LINE CLEAR AVAILED
4170	24-Feb-24	BENGALURU	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	18:03	18:15	00:12	LINE CLEAR AVAILED
4171	24-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLY	IRGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	18:28	18:33	00:05	LINE CLEAR AVAILED
4172	24-Feb-24	BENGALURU	66	LINE	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION	16:30	16:39	00:09	TRIPPED ON FAULT
4173	24-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJ PURA 220	HOSKOTE 66	15:25	15:30	00:05	LINE CLEAR AVAILED
4174	24-Feb-24	BENGALURU	66	LINE	66KV EDC 220 - AUSTIN TOWN	AUSTIN TOWN	11:44	11:47	00:03	LINE CLEAR AVAILED
4175	24-Feb-24	BENGALURU	66	LINE	66KV GANJIGUNTE - PALICHERLU	PALLICHERLU	18:05	18:15	00:10	LINE CLEAR AVAILED
4176	24-Feb-24	BENGALURU	66	LINE	66KV GANJIGUNTE - PALICHERLU	PALLICHERLU	22:38	22:46	00:08	LINE CLEAR AVAILED
4177	24-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)	LEELAVENTURE	14:54	15:00	00:06	LINE CLEAR AVAILED
4178	24-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:28	11:30	00:02	LINE CLEAR AVAILED
4179	24-Feb-24	BENGALURU	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK, PRIMAL	10:50	10:52	00:02	LINE CLEAR AVAILED
4180	24-Feb-24	BENGALURU	66	LINE	66KV IRGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	18:27	18:34	00:07	LINE CLEAR AVAILED
4181	24-Feb-24	BENGALURU	66	LINE	66KV IRGAMPALLI - BURUDAGUNTE	IRGAMPALLI, M GOLLAHALLI	22:20	22:25	00:05	LINE CLEAR AVAILED
4182	24-Feb-24	BENGALURU	66	LINE	66KV KHODAYS GLASS FACTORY 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	09:36	09:42	00:06	LINE CLEAR AVAILED
4183	24-Feb-24	BENGALURU	66	LINE	66KV KHODAYS GLASS FACTORY 220 - FALSON CITY	PRESTIGE FALCON CITY	09:35	09:42	00:07	LINE CLEAR AVAILED
4184	24-Feb-24	BENGALURU	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	AUSTIN TOWN	17:24	17:26	00:02	LINE CLEAR AVAILED
4185	24-Feb-24	BENGALURU	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN-2	AUSTIN TOWN	17:24	17:26	00:02	LINE CLEAR AVAILED
4186	24-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	12:08	12:17	00:09	TRIPPED ON FAULT
4187	24-Feb-24	BENGALURU	66	LINE	66KV MEI L/O - WIDIA	NO STATION AFFECTED	09:23	10:41	01:18	TRIPPED ON FAULT
4188	24-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	15:00	15:10	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4189	24-Feb-24	BENGALURU	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	SOMENAHALLI, PERESANDRA	15:00	15:10	00:10	LINE CLEAR AVAILED
4190	24-Feb-24	BENGALURU	66	LINE	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURAHALLI	22:38	22:48	00:10	LINE CLEAR AVAILED
4191	24-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	07:44	07:47	00:03	LINE CLEAR AVAILED
4192	24-Feb-24	BENGALURU	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI CROSS, YENIGADALE	18:10	18:12	00:02	LINE CLEAR AVAILED
4193	24-Feb-24	BENGALURU	66	LINE	66KV SIDDALAGHATTA - MELUR	MELUR	18:36	18:44	00:08	LINE CLEAR AVAILED
4194	24-Feb-24	BENGALURU	66	LINE	66KV SOMENAHALLI - NALLIMARADANAHALLI	SOMENAHALLI, PERESANDRA	18:20	18:25	00:05	LINE CLEAR AVAILED
4195	24-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA - REMCO 2 - RR NAGARA - GLOBAL (EHT)	RR NAGAR	16:47	16:50	00:03	LINE CLEAR AVAILED
4196	24-Feb-24	BENGALURU	66	LINE	66KV TALAGUNDA - VEMGAL	VEMGAL, KYALANUR	15:00	15:25	00:25	TRIPPED ON FAULT
4197	24-Feb-24	BENGALURU	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	08:58	09:08	00:10	TRIPPED ON FAULT
4198	24-Feb-24	BENGALURU	66	LINE	66KV VEMGAL - KYALANUR	KYALANUR	15:00	15:35	00:35	TRIPPED ON FAULT
4199	24-Feb-24	BENGALURU	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	MELUR	22:23	22:30	00:07	LINE CLEAR AVAILED
4200	24-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - GTP	DEVARABISANAHALLI, GLOBAL TECH PARK, PRIMAL	19:15	19:18	00:03	LINE CLEAR AVAILED
4201	24-Feb-24	BENGALURU	66	LINE	66KV VRUSHBHAVATHI 220 - RR NAGAR	RR NAGAR	10:03	10:06	00:03	LINE CLEAR AVAILED
4202	24-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 200 - SURYA CITY	SURYA CITY, ANEKAL	19:35	19:45	00:10	LINE CLEAR AVAILED
4203	24-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE, SAMANDURU	19:35	19:53	00:18	LINE CLEAR AVAILED
4204	24-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - BMRCL (EHT)	BMRCL(EHT)	19:37	19:43	00:06	LINE CLEAR AVAILED
4205	24-Feb-24	BENGALURU	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	YENNIGADALE	22:27	22:32	00:05	LINE CLEAR AVAILED
4206	24-Feb-24	BENGALURU	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	17:36	17:52	00:16	TRIPPED ON FAULT
4207	24-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	18:12	18:19	00:07	TRIPPED ON FAULT
4208	24-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ISRO LAYOUT	21:32	21:44	00:12	TRIPPED ON FAULT
4209	24-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIJJAHALLI	10:05	11:05	01:00	LINE CLEAR AVAILED
4210	24-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YARANDANAHALLI 220	10:35	10:37	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4211	24-Feb-24	BENGALURU	66	TRANSFORMER	HV2	NGEF	11:43	11:46	00:03	LINE CLEAR AVAILED
4212	24-Feb-24	BENGALURU	66	TRANSFORMER	HV2	CHIKKABALLAPURA URBAN	02:00	02:10	00:10	TRIPPED ON FAULT
4213	24-Feb-24	BENGALURU	66	TRANSFORMER	HV2	YARANDANAHALLI 220	19:37	20:02	00:25	LINE CLEAR AVAILED
4214	24-Feb-24	BENGALURU	220	LINE	220KV HOODY 400 - HAL 1	NO STATION AFFECTED	11:25	16:23	04:58	LINE CLEAR AVAILED
4215	24-Feb-2024	GULBARGA	66	LINE	ITTAGI-RENEW SOLAR	ITTAGI_220	18:42	24:00:00	05:18	LINE CLEAR AVAILED
4216	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	04:06	04:15	00:09	TRIPPED ON FAULT
4217	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	04:18	04:25	00:07	TRIPPED ON FAULT
4218	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	10:40	10:45	00:05	TRIPPED ON FAULT
4219	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUNDRA_110	13:58	14:07	00:09	TRIPPED ON FAULT
4220	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	12:38	12:48	00:10	TRIPPED ON FAULT
4221	24-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	SHAHAPUR_220	07:00	07:24	00:24	TRIPPED ON FAULT
4222	24-Feb-2024	GULBARGA	110	LINE	KUDITINI-ALIPUR	KIADB KUDITINI_110,KUDITINI_110,TORANGALU_110,KURUGOD_110,KAMALAPUR_110,METRI_110,SHATHVAHANA_IPP, AGRAWAL_IPP,SUZLON_IPP,RBNS FACTORY.	14:45	14:55	00:10	LINE CLEAR AVAILED
4223	24-Feb-2024	GULBARGA	110	LINE	KUDITINI-ALIPUR	KIADB KUDITINI_110,KUDITINI_110,TORANGALU_110KURUGOD_110,KAMALAPUR_110,METRI_110,SHATHVAHANA_IPP, AGRAWAL_IPP,SUZLON_IPP,RBNS FACTORY.	20:55	21:05	00:10	LINE CLEAR AVAILED
4224	24-Feb-2024	GULBARGA	110	LINE	LINGASUGUR-MUDAGAL	BAYYAPUR_110	06:34	06:46	00:12	TRIPPED ON FAULT
4225	24-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	13:25	13:35	00:10	TRIPPED ON FAULT
4226	24-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	13:46	13:56	00:10	TRIPPED ON FAULT
4227	24-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	14:03	14:13	00:10	TRIPPED ON FAULT
4228	24-Feb-2024	GULBARGA	110	LINE	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,SIRIGERICROSS_110,TEKKALKOTE_110,DHADESUGUR_110,NSL SUGAR_IPP	13:25	14:55	01:30	MAIN SUPPLY FAILURE
4229	24-Feb-2024	GULBARGA	110	LINE	SIRIGUPPA-SINDHANOOR	SIRIGUPPA_110,SIRIGERICROSS_110,TEKKALKOTE_110,DHADESUGUR_110,NSL SUGAR_IPP	19:47	20:00	00:13	MAIN SUPPLY FAILURE
4230	24-Feb-2024	GULBARGA	220	LINE	KUSHTAGI-LINGASUGUR	KUSHTAGI_220	00:00	01:35	01:35	LINE CLEAR AVAILED
4231	24-Feb-2024	GULBARGA	220	LINE	KUSHTAGI-SULEKAL	SULEKAL_220	00:00	01:32	01:32	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4232	24-Feb-24	HASSAN	66	LINE	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	16:15	17:55	01:40	LINE CLEAR AVAILED
4233	24-Feb-24	HASSAN	66	LINE	CRPATNA-CRPTNA1	CRPATNA_220	16:46	17:57	01:11	TRIPPED ON FAULT
4234	24-Feb-24	HASSAN	66	LINE	CRPATNA-CRPTNA2	CRPATNA_220	16:46	20:28	03:42	TRIPPED ON FAULT
4235	24-Feb-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	17:51	18:02	00:11	LINE CLEAR AVAILED
4236	24-Feb-24	HASSAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	14:35	15:40	01:05	LINE CLEAR AVAILED
4237	24-Feb-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	14:35	15:40	01:05	LINE CLEAR AVAILED
4238	24-Feb-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	14:35	15:40	01:05	LINE CLEAR AVAILED
4239	24-Feb-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	10:45	11:45	01:00	LINE CLEAR AVAILED
4240	24-Feb-24	HASSAN	66	TRANSFORMER	HV1 CB	MANJUNATHPURA_66	12:42	13:14	00:32	LINE CLEAR AVAILED
4241	24-Feb-24	HASSAN	66	TRANSFORMER	HV2	HARIHARPURA_66	14:35	15:40	01:05	LINE CLEAR AVAILED
4242	24-Feb-24	HASSAN	66	TRANSFORMER	HV2 CB	MANJUNATHPURA_66	12:42	13:14	00:32	LINE CLEAR AVAILED
4243	24-Feb-24	HASSAN	66	LINE	KANDLI-HASSAN	KANDLI_66	08:25	09:00	00:35	LINE CLEAR AVAILED
4244	24-Feb-24	HASSAN	66	LINE	L1 CB	MANJUNATHPURA_66	12:42	13:14	00:32	LINE CLEAR AVAILED
4245	24-Feb-24	HASSAN	66	LINE	L2 CB	MANJUNATHPURA_66	12:42	13:14	00:32	LINE CLEAR AVAILED
4246	24-Feb-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	12:44	12:50	00:06	LINE CLEAR AVAILED
4247	24-Feb-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	12:44	12:50	00:06	LINE CLEAR AVAILED
4248	24-Feb-24	HASSAN	110	TRANSFORMER	HV1	SAGARA_110	10:45	10:50	00:05	TRIPPED ON FAULT
4249	24-Feb-24	MYSORE	66	LINE	CHANDAKAVADI-D.R PETE	CHANDAKAVADI_66	13:10	13:30	00:20	LINE CLEAR AVAILED
4250	24-Feb-24	MYSORE	66	LINE	CHIKKAMANDYA-HAMPAPURA	NO STATIONS EFFECTED	09:50	15:30	05:40	LINE CLEAR AVAILED
4251	24-Feb-24	MYSORE	66	LINE	CHIKKAMANDYA-MANDYA	CHIKKA_MANDYA_66	09:50	16:02	06:12	LINE CLEAR AVAILED
4252	24-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	10:23 (24/02/2024)			LINE CLEAR AVAILED
4253	24-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:42 (23/02/2024)			LINE CLEAR AVAILED
4254	24-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	RAJEEVNAGARA_66	13:50	16:29	02:38	TRIPPED ON FAULT
4255	24-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	DEVANOORMYS_66, RAJEEVNAGARA_66	19:20 (21/02/2024)	13:25 (24/02/2024)	66:05 Hrs	TRIPPED ON FAULT
4256	24-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
4257	24-Feb-24	MYSORE	66	LINE	HANNUR-AJJIPURA	AJJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	18:18	18:25	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4258	24-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4259	24-Feb-24	MYSORE	66	LINE	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66 MANDAKALLI_66 RAJEEVNAGARA_66	13:44	14:32	00:48	TRIPPED ON FAULT
4260	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	CHIKKA_MANDYA_66	08:30	15:30	07:00	LINE CLEAR AVAILED
4261	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	CHUNCHUNKATTE_66	10:00	17:05	07:05	LINE CLEAR AVAILED
4262	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	KIADB SOMANAHALLI _66	09:16	16:16	07:00	LINE CLEAR AVAILED
4263	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	MADDUR_66	09:15	17:56	08:41	LINE CLEAR AVAILED
4264	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	09:28	15:55	06:27	LINE CLEAR AVAILED
4265	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	DODDINADUVADI_66	20:47 (23/02/2024	20:55 (24/02/2024)	24:08 HRs	TRIPPED ON FAULT
4266	24-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4267	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	CHIKKA_MANDYA_66	08:30	15:30	07:00	LINE CLEAR AVAILED
4268	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	CHUNCHUNKATTE_66	10:00	17:05	07:05	LINE CLEAR AVAILED
4269	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	18:30	18:45	00:15	TRIPPED ON FAULT
4270	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	KIADB SOMANAHALLI _66	09:16	16:16	07:00	LINE CLEAR AVAILED
4271	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADDUR_66	09:15	18:14	08:59	LINE CLEAR AVAILED
4272	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	09:28	15:55	06:27	LINE CLEAR AVAILED
4273	24-Feb-24	MYSORE	66	TRANSFORMER	HV2	CHANDAKAVADI_66	17:30 (23/02/2024)	13:30 (24/02/2024)	19:59 HRs	TRIPPED ON FAULT
4274	24-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
4275	24-Feb-24	MYSORE	66	LINE	KADAKOLA-DOORA	CHANDRAVADI_66 DOORA_66 HURA_66 HULLAHALLI_66	15:42	15:48	00:05	TRIPPED ON FAULT
4276	24-Feb-24	MYSORE	66	LINE	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 TUMBEKERE_66	09:05	17:27	08:22	LINE CLEAR AVAILED
4277	24-Feb-24	MYSORE	66	LINE	KK DODDI-MADDUR	MADDUR_66 KIADB SOMANAHALLI_66	09:24	15:55	06:30	LINE CLEAR AVAILED
4278	24-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4279	24-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
4280	24-Feb-24	MYSORE	66	LINE	MANDYA-KIADB MANDYA	NO STATIONS EFFECTED	09:05	16:30	07:25	LINE CLEAR AVAILED
4281	24-Feb-24	MYSORE	66	LINE	MANDYA-KK HALLI	NO STATIONS EFFECTED	11:23 (23/02/2024)			LINE CLEAR AVAILED
4282	24-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	06:30	06:38	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4283	24-Feb-24	MYSORE	66	LINE	NANJANGUDU-SINDHUVALLI	NO STATIONS EFFECTED	06:35	06:42	00:07	TRIPPED ON FAULT
4284	24-Feb-24	MYSORE	66	LINE	TUBINAKERE-MC-2	MANDYA_66	09:40	15:37	05:57	LINE CLEAR AVAILED
4285	24-Feb-24	MYSORE	66	LINE	TUBINAKERE-MC-4	MANDYA_66	09:40	15:37	05:57	LINE CLEAR AVAILED
4286	24-Feb-24	MYSORE	66	LINE	VAJAMANGALA-DEVNUR(MYS)	DEVANOORMYS_66	13:48	16:24	02:36	TRIPPED ON FAULT
4287	24-Feb-24	MYSORE	66	LINE	VIJAYANAGARA-FTS	NO STATIONS EFFECTED	19:34 (23/02/2024)			LINE CLEAR AVAILED
4288	24-Feb-24	TUMKUR	66	LINE	HONNALI 220kV-HONNALI_66	HONNALI_66,KATTIGE_66	16:32	16:42	00:10	TRIPPED ON FAULT
4289	24-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	07:56	08:00	00:04	TRIPPED ON FAULT
4290	24-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	08:33	08:38	00:05	TRIPPED ON FAULT
4291	24-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	12:30	12:35	00:05	TRIPPED ON FAULT
4292	24-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	12:36	12:51	00:15	TRIPPED ON FAULT
4293	24-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66,BASAVAPATNA_66,SANTEBENNUR_66	06:50	06:59	00:09	TRIPPED ON FAULT
4294	24-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	02:30	02:40	00:10	TRIPPED ON FAULT
4295	24-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	03:15	03:40	00:25	TRIPPED ON FAULT
4296	24-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4297	24-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRADURGA_66	11:52	14:27	02:35	LINE CLEAR AVAILED
4298	24-Feb-24	TUMKUR	66	TRANSFORMER	TR-1(LV SIDE)	CHITRADURGA_220	09:19	09:32	00:13	TRIPPED ON FAULT
4299	24-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHITRADURGA_66	14:45	15:06	00:21	LINE CLEAR AVAILED
4300	24-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KADAJII_66	08:45	08:50	00:05	TRIPPED ON FAULT
4301	24-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KADAJII_66	08:45	08:50	00:05	TRIPPED ON FAULT
4302	24-Feb-24	TUMKUR	66	LINE	TURUVANUR_66KV-CHITRADURGA220	TURUVANUR_66KV	06:57	07:03	00:06	MAIN SUPPLY FAILURE
4303	24-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	15:30	16:05	00:15	LOAD CURTAILMENT
4304	24-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	CHITRADURGA_220	09:19	09:32	00:13	TRIPPED ON FAULT
4305	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KADAKLAT_110	14:05 (24.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4306	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	STATION NOT AFFECTED RATTIHALLI_110	18:07	18:10	00:03	TRIPPED ON FAULT
4307	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	11:33	11:38	00:05	TRIPPED ON FAULT
4308	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	12:21	12:26	00:05	TRIPPED ON FAULT
4309	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (10MVA)	CHIKKODI_110	10:45	15:29	04:44	LINE CLEAR AVAILED
4310	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED SINDAGI_110	12:29	12:39	00:10	TRIPPED ON FAULT
4311	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED SINDAGI_110	12:43	13:17	00:34	TRIPPED ON FAULT
4312	25-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA-HV4)	KULIGOD_110	15:17	17:13	01:56	LINE CLEAR AVAILED
4313	25-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4314	25-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- ANKALI	STATION NOT AFFECTED CHIKKODI_220	11:06	13:26	02:20	LINE CLEAR AVAILED
4315	25-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG1	STATION NOT AFFECTED CHIKKODI_220	10:10	14:40	04:30	LINE CLEAR AVAILED
4316	25-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG2	STATION NOT AFFECTED CHIKKODI_220	10:10	14:40	04:30	LINE CLEAR AVAILED
4317	25-Feb-24	BAGALKOTE	110	LINE	CHIKKODI220- SADALAGA	STATION NOT AFFECTED CHIKKODI_220	10:19	12:10	01:51	LINE CLEAR AVAILED
4318	25-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
4319	25-Feb-24	BAGALKOTE	110	LINE	HATTARGI-HUKKERI(GHATAPRABHA-1)	STATION NOT AFFECTED HATTARGI_110	08:46	15:42	06:56	LINE CLEAR AVAILED
4320	25-Feb-24	BAGALKOTE	110	LINE	HOSAHONNATTI- F2 (BELUR-HEELADAHALLI)	STATION NOT AFFECTED HOSAHONNATTI_110	16:39	17:10	00:31	LINE CLEAR AVAILED
4321	25-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
4322	25-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4323	25-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4324	25-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220- RAIBAG1&2	MUGALKHOD_220	09:53	15:26	05:33	LINE CLEAR AVAILED
4325	25-Feb-24	BAGALKOTE	110	LINE	NAVALAGUND-KONNUR	STATION NOT AFFECTED NAVALAGUND_110	09:08 (24.02.2024)	09:09 (25.02.2024)	24:01:00	LINE CLEAR AVAILED
4326	25-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4327	25-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
4328	25-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	13:40	14:19	00:39	LINE CLEAR AVAILED
4329	25-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR-HOSAHONNATTI	RANEBENNUR_220	13:30	17:08	03:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4330	25-Feb-24	BAGALKOTE	110	LINE	SADALAGA-BORGAON	BORGAON_110 SADALAGA_110	10:17	12:13	01:56	LINE CLEAR AVAILED
4331	25-Feb-24	BAGALKOTE	110	LINE	SADALAGA-CHIKKODI	SADALAGA_110	10:15	12:09	01:54	LINE CLEAR AVAILED
4332	25-Feb-24	BAGALKOTE	110	LINE	SADALAGA-VPPL IPP	VPPL IPP_110 SADALAGA_110	10:11	12:38	02:27	LINE CLEAR AVAILED
4333	25-Feb-24	BAGALKOTE	110	LINE	TALIKOT-FPEL	TALIKOT_110	19:01 (24.02.2024)	20:09 (25.02.2024)	25:08:00	LINE CLEAR AVAILED
4334	25-Feb-24	BAGALKOTE	110	LINE	UGAR KHUD-KAGAWAD	UGAR KHUD_110	07:51	07:52	00:01	LINE CLEAR AVAILED
4335	25-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4336	25-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)			LINE CLEAR AVAILED
4337	25-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)			LINE CLEAR AVAILED
4338	25-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4339	25-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	STATION NOT AFFECTED HUBLI_220	12:24	19:12	06:48	LINE CLEAR AVAILED
4340	25-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	13:35	17:03	03:28	LINE CLEAR AVAILED
4341	25-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4342	25-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4343	25-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4344	25-Feb-24	BENGALURU	66	LINE	66KV AREHALLI - BANASHANKARI	AREHALLI	18:24	18:27	00:03	LINE CLEAR AVAILED
4345	25-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4346	25-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	18:15	18:25	00:10	LINE CLEAR AVAILED
4347	25-Feb-24	BENGALURU	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	08:09	08:25	00:16	TRIPPED ON FAULT
4348	25-Feb-24	BENGALURU	66	LINE	66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)	BANASAWADI(HV2)	08:47	09:07	00:20	TRIPPED ON FAULT
4349	25-Feb-24	BENGALURU	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	03:39	03:52	00:13	TRIPPED ON FAULT
4350	25-Feb-24	BENGALURU	66	LINE	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	MAGADI 66	15:00	17:10	02:10	LINE CLEAR AVAILED
4351	25-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	10:15	10:18	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4352	25-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	10:18	10:20	00:02	LINE CLEAR AVAILED
4353	25-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO	18:28	18:36	00:08	LINE CLEAR AVAILED
4354	25-Feb-24	BENGALURU	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	14:50	15:05	00:15	TRIPPED ON FAULT
4355	25-Feb-24	BENGALURU	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	18:26	18:48	00:22	TRIPPED ON FAULT
4356	25-Feb-24	BENGALURU	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	18:27	18:49	00:22	TRIPPED ON FAULT
4357	25-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BRINDAVANA 220	08:26	08:31	00:05	LINE CLEAR AVAILED
4358	25-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NAGANATHPURA	23:05	23:14	00:09	LINE CLEAR AVAILED
4359	25-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	17:10	21:10	04:00	TRIPPED ON FAULT
4360	25-Feb-24	BENGALURU	66	TRANSFORMER	HV1	KUMBARANAHALLI	11:45	14:50	03:05	LINE CLEAR AVAILED
4361	25-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YARANDANAHALLI 220	12:23	12:27	00:04	TRIPPED ON FAULT
4362	25-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BANASAWADI	08:47	09:07	00:20	MAIN SUPPLY FAILURE
4363	25-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TUBAGERE	11:05	11:15	00:10	TRIPPED ON FAULT
4364	25-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KUMBARANAHALLI	11:45	14:50	03:05	LINE CLEAR AVAILED
4365	25-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	SOVENHALLI_66	01:28	01:38	00:10	TRIPPED ON FAULT
4366	25-Feb-2024	GULBARGA	66	LINE	ITTAGI-RENEW SOLAR	ITTAGI_220	00:00	6:22:00	06:22	LINE CLEAR AVAILED
4367	25-Feb-2024	GULBARGA	110	LINE	HANWAL-MARALIHALLA	HANWAL_110, YERADONA_110, BENNUR_110	04:05	04:20	00:15	TRIPPED ON FAULT
4368	25-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	10:15	12:17	02:02	LINE CLEAR AVAILED
4369	25-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	MANVI_110	12:05	13:40	01:35	LINE CLEAR AVAILED
4370	25-Feb-2024	GULBARGA	110	LINE	KADECHUR-SAIDAPUR	SAIDAPUR_110	03:53	04:05	00:12	TRIPPED ON FAULT
4371	25-Feb-2024	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	10:00	16:10	06:10	LINE CLEAR AVAILED
4372	25-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110,JEWARGI_110	20:45	20:50	00:05	LINE CLEAR AVAILED
4373	25-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MARALIHALLA_110, MUKUNDA_110	10:40	11:05	00:25	TRIPPED ON FAULT
4374	25-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-FEROZABAD2	SHAHAPUR_220	23:55(25.02.2024)			TRIPPED ON FAULT
4375	25-Feb-24	HASSAN	66	TRANSFORMER	HV1	SBELAGOLA_66	07:15	18:40	11:25	LINE CLEAR AVAILED
4376	25-Feb-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	07:15	18:40	11:25	LINE CLEAR AVAILED
4377	25-Feb-24	HASSAN	66	LINE	SBELAG-YACHENHLLI	SBELAGOLA_66	07:15	18:40	11:25	LINE CLEAR AVAILED
4378	25-Feb-24	MYSORE	66	LINE	BHERYA-SALIGRAMA	SALIGRAMA_66BHERYA_66	08:50	09:10	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4379	25-Feb-24	MYSORE	66	LINE	DK MAIDANA-KADAKOLA	NO STATIONS EFFECTED	10:23 (24/02/2024)	10:15 (25/02/2024)	23:51 HRs	LINE CLEAR AVAILED
4380	25-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:42 (23/02/2024)			LINE CLEAR AVAILED
4381	25-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:42 (23/02/2024)			LINE CLEAR AVAILED
4382	25-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
4383	25-Feb-24	MYSORE	66	LINE	HANNUR-ECRON SOLAR	NO STATIONS EFFECTED	10:20	10:55	00:35	LINE CLEAR AVAILED
4384	25-Feb-24	MYSORE	66	LINE	HANNUR-ECRON SOLAR	NO STATIONS EFFECTED	15:59	17:16:19	01:16	LINE CLEAR AVAILED
4385	25-Feb-24	MYSORE	66	LINE	HEBBANI-MEGALAPURA	CHIDRAVALLI_66BGPURA_66THUMBLA_66 VYSARAJAPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	21:02	21:15	00:13	TRIPPED ON FAULT
4386	25-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4387	25-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	18:14	19:02	00:47	LINE CLEAR AVAILED
4388	25-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLI_66	14:29	14:47	00:18	TRIPPED ON FAULT
4389	25-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLI_66	15:01	15:15	00:13	TRIPPED ON FAULT
4390	25-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4391	25-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	19:03 (25/02/2024)			LINE CLEAR AVAILED
4392	25-Feb-24	MYSORE	66	TRANSFORMER	HV2	ANEGOLA_66	20:50	21:05	00:15	TRIPPED ON FAULT
4393	25-Feb-24	MYSORE	66	TRANSFORMER	HV2	HOOTAGALLI_220	07:10	07:29	00:18	TRIPPED ON FAULT
4394	25-Feb-24	MYSORE	66	TRANSFORMER	HV2	HOOTAGALLI_220	12:39	13:51	01:12	TRIPPED ON FAULT
4395	25-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
4396	25-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 1	AYRALLI_66MARADIHUNDI_66	07:53	12:51	04:58	LINE CLEAR AVAILED
4397	25-Feb-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 2	NO STATIONS EFFECTED	07:53	12:51	04:58	LINE CLEAR AVAILED
4398	25-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4399	25-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
4400	25-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	06:30	06:35	00:04	TRIPPED ON FAULT
4401	25-Feb-24	MYSORE	66	LINE	RAJEEVNAGARA -FTS	NO STATIONS EFFECTED	08:44	08:57	00:13	TRIPPED ON FAULT
4402	25-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:28 (25/02/2024)			LINE CLEAR AVAILED
4403	25-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV-BENKIKERE	BENKIKERE_66	09:12	09:42	00:30	MAIN SUPPLY FAILURE
4404	25-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV-BENKIKERE	BENKIKERE_66	09:50	11:10	01:20	MAIN SUPPLY FAILURE
4405	25-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-HOSADURGA220 1	HOSADURGA_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4406	25-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-HOSADURGA220 2	HOSADURGA_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4407	25-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:37	16:08	00:31	LINE CLEAR AVAILED
4408	25-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	17:14	17:29	00:15	TRIPPED ON FAULT
4409	25-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 2	HOLAKERE_66,HDPURA_66, CHITRAHALLI_66	17:14	17:33	00:19	TRIPPED ON FAULT
4410	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66, KADAJJI_66	09:13	09:34	00:21	MAIN SUPPLY FAILURE
4411	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66, KADAJJI_66	09:53	10:29	00:36	MAIN SUPPLY FAILURE
4412	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	09:13	09:34	00:21	MAIN SUPPLY FAILURE
4413	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	09:49	10:25	00:36	LINE CLEAR AVAILED
4414	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:25	11:07	00:42	LINE CLEAR AVAILED
4415	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66,KADAJJI_66	09:49	10:25	00:36	LINE CLEAR AVAILED
4416	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66,KADAJJI_66	10:25	12:55	02:30	LINE CLEAR AVAILED
4417	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66,KADAJJI_66	17:25	17:40	00:15	LINE CLEAR AVAILED
4418	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MYLANAHALLI_66	MYLANAHALLI_66	09:10	09:35	00:25	MAIN SUPPLY FAILURE
4419	25-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MYLANAHALLI_66	MYLANAHALLI_66	17:25	17:40	00:15	MAIN SUPPLY FAILURE
4420	25-Feb-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	PANDRAHALLI_66	17:15	17:30	00:15	MAIN SUPPLY FAILURE
4421	25-Feb-24	TUMKUR	66	LINE	LOKIKERE-KUKKAWADA	LOKIKERE_66,KEREBILCHI_66,SAN THEBENNURU_66	09:10	09:25	00:15	MAIN SUPPLY FAILURE
4422	25-Feb-24	TUMKUR	66	LINE	LOKIKERE-KUKKAWADA	LOKIKERE_66,KEREBILCHI_66,SAN THEBENNURU_66	09:50	10:10	00:20	MAIN SUPPLY FAILURE
4423	25-Feb-24	TUMKUR	66	LINE	LOKIKERE-KUKKAWADA	LOKIKERE_66,KEREBILCHI_66,SAN THEBENNURU_66	14:00	14:10	00:10	MAIN SUPPLY FAILURE
4424	25-Feb-24	TUMKUR	66	LINE	PAVAGADA 220kV-SHYLAPURA	SHY LAPURA_66	14:05	14:20	00:20	TRIPPED ON FAULT
4425	25-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4426	25-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MATHOD_66	12:42	12:52	00:10	TRIPPED ON FAULT
4427	25-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	MYLANAHALLI_66	18:30	18:35	00:05	TRIPPED ON FAULT
4428	25-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KUKAWADA_66	12:10	13:35	01:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4429	25-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KADAJII_66	15:15	15:20	00:05	TRIPPED ON FAULT
4430	25-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HONNALLI 220KV -1	BENKIKERE_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4431	25-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HONNALLI 220KV -2	BENKIKERE_220	14:10	15:18	01:08	MAIN SUPPLY FAILURE
4432	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	09:13	09:28	00:15	TRIPPED ON FAULT
4433	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	09:43	10:50	01:07	TRIPPED ON FAULT
4434	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	10:50	12:36	01:46	LINE CLEAR AVAILED
4435	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	09:13	09:35	00:22	TRIPPED ON FAULT
4436	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	09:53	10:25	00:32	TRIPPED ON FAULT
4437	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	09:13	09:28	00:15	MAIN SUPPLY FAILURE
4438	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	09:53	10:07	00:14	TRIPPED ON FAULT
4439	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:30	13:30	02:00	LINE CLEAR AVAILED
4440	25-Feb-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	13:30	17:08	03:38	LINE CLEAR AVAILED
4441	25-Feb-24	TUMKUR	220	LINE	GUTUR_400-DAVANGERE SRS 3	GUTUR_220	11:42	12:32	00:50	LINE CLEAR AVAILED
4442	25-Feb-24	TUMKUR	220	LINE	GUTUR_400-RANEBENNUR	GUTUR_400	16:38	17:03	00:25	LINE CLEAR AVAILED
4443	25-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	07:35	09:42	00:15	LINE CLEAR AVAILED
4444	25-Feb-24	TUMKUR	220	LINE	KB CROSS 220kV- ANTHARASANAHALLI	KB CROSS_220	18:04	18:14	00:10	LINE CLEAR AVAILED
4445	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KADAKLAT_110	14:05 (24.02.2024)			LINE CLEAR AVAILED
4446	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ISLMAPUR_110	09:07	13:33	04:26	LINE CLEAR AVAILED
4447	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KADAKLAT_110	12:45	13:36	00:51	LINE CLEAR AVAILED
4448	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RANNABELAGALI_110	11:38	18:01	06:23	LINE CLEAR AVAILED
4449	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	VADAGOAN_110	09:10	17:00	07:50	LINE CLEAR AVAILED
4450	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	VADAGOAN_110	09:12	17:07	07:55	LINE CLEAR AVAILED
4451	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA-HV3)	TOLAMATTI_110	01:25	01:26	00:01	TRIPPED ON FAULT
4452	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(10MVA-HV1)	VADAGOAN_110	09:15	17:09	07:54	LINE CLEAR AVAILED
4453	26-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA-HV4)	VADAGOAN_110	09:13	17:09	07:56	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4454	26-Feb-24	BAGALKOTE	110	LINE	ANKALAGI-HIDAKAL	ANKALAGI_110	09:41	13:26	03:45	LINE CLEAR AVAILED
4455	26-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4456	26-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
4457	26-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
4458	26-Feb-24	BAGALKOTE	110	LINE	ISLMAPUR-F2(ANKALAGI)	ISLMAPUR_110	09:41	13:37	03:56	LINE CLEAR AVAILED
4459	26-Feb-24	BAGALKOTE	110	LINE	ISLMAPUR-F2(HIDAKAL DAM)	ISLMAPUR_110	04:41	05:14	00:33	TRIPPED ON FAULT
4460	26-Feb-24	BAGALKOTE	110	LINE	ISLMAPUR-F2(HIDAKAL DAM)	ISLMAPUR_110	09:41	13:26	03:45	LINE CLEAR AVAILED
4461	26-Feb-24	BAGALKOTE	110	LINE	KADAKLAT-F1(CHIKKODI)	KADAKLAT_110	12:46	13:35	00:49	LINE CLEAR AVAILED
4462	26-Feb-24	BAGALKOTE	110	LINE	KADAKLAT-F2(NIPPANI	KADAKLAT_110	12:46	13:40	00:54	LINE CLEAR AVAILED
4463	26-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4464	26-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4465	26-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4466	26-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
4467	26-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- MMCL	SOUDATTI_220	09:02	10:33	01:31	LINE CLEAR AVAILED
4468	26-Feb-24	BAGALKOTE	110	LINE	SOUDATTI220- MMCL	SOUDATTI_220	09:02	10:33	01:31	LINE CLEAR AVAILED
4469	26-Feb-24	BAGALKOTE	110	LINE	VADAGOAN-BELGAUM	VADAGOAN_110	14:32	16:01	01:29	LINE CLEAR AVAILED
4470	26-Feb-24	BAGALKOTE	110	LINE	VADAGOAN-MACHE	VADAGOAN_110	14:30	16:02	01:32	LINE CLEAR AVAILED
4471	26-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4472	26-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)	7:31 (26.02.2024)	33:05:00	LINE CLEAR AVAILED
4473	26-Feb-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	STATION NOT AFFECTED AMBEWADI_220	22:26 (24.02.2024)	7:31 (26.02.2024)	33:05:00	LINE CLEAR AVAILED
4474	26-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4475	26-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-MUGALKHOD1	GHATAPRABHA_220	12:09	18:34	06:25	LINE CLEAR AVAILED
4476	26-Feb-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA1	HUBLI_220	10:37	17:25	06:48	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4477	26-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD-GHATAPRABHA1	MUGALKHOD_220	12:09	18:35	06:26	LINE CLEAR AVAILED
4478	26-Feb-24	BAGALKOTE	220	LINE	NARENDRA- HUBLI1	NARENDRA_220	10:37	17:25	06:48	LINE CLEAR AVAILED
4479	26-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4480	26-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4481	26-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4482	26-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4483	26-Feb-24	BENGALURU	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	12:19	12:26	00:07	LINE CLEAR AVAILED
4484	26-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	10:28	10:38	00:10	LINE CLEAR AVAILED
4485	26-Feb-24	BENGALURU	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	04:30	04:44	00:14	TRIPPED ON FAULT
4486	26-Feb-24	BENGALURU	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	NO STATION AFFECTED	10:52	15:52	05:00	TRIPPED ON FAULT
4487	26-Feb-24	BENGALURU	66	LINE	66KV KACHAMARANAHALLI - PRESTIGE LAKESIDE HABITAT	PRESTIGE LAKESIDE HABITAT	04:14	05:13	00:59	LINE CLEAR AVAILED
4488	26-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	06:05	06:09	00:04	LINE CLEAR AVAILED
4489	26-Feb-24	BENGALURU	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	09:50	10:10	00:20	TRIPPED ON FAULT
4490	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SOLADEVANAHALLI	05:40	05:45	00:05	LINE CLEAR AVAILED
4491	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NAGANATHPURA 220	17:01	17:06	00:05	LINE CLEAR AVAILED
4492	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BUDIGERE	16:22	17:17	00:55	LINE CLEAR AVAILED
4493	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DEVANAHALLI 66	10:48	11:03	00:15	TRIPPED ON FAULT
4494	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	DODDABELAVANGALA	04:45	04:48	00:03	TRIPPED ON FAULT
4495	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	THONDEBHAVI	12:40	12:55	00:15	TRIPPED ON FAULT
4496	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	LAKKUR	14:25	14:30	00:05	TRIPPED ON FAULT
4497	26-Feb-24	BENGALURU	66	TRANSFORMER	HV1	MAASTHI	17:50	18:25	00:35	LINE CLEAR AVAILED
4498	26-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	11:48	11:52	00:04	LINE CLEAR AVAILED
4499	26-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	23:05	23:15	00:10	TRIPPED ON FAULT
4500	26-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VATADAHOSAHALLI	16:15	16:17	00:02	LINE CLEAR AVAILED
4501	26-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	13:20	13:25	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4502	26-Feb-24	BENGALURU	66	TRANSFORMER	HV3	IGGALUR	13:47	13:52	00:05	TRIPPED ON FAULT
4503	26-Feb-24	BENGALURU	66	TRANSFORMER	HV3	YARANDANAHALLI 220	09:31	09:37	00:06	LINE CLEAR AVAILED
4504	26-Feb-2024	GULBARGA	66	LINE	ITTAGI-TAMBRALLI	HAMPASAGAR_66, TAMBRALLI_66, MORAGERA_66	18:50	19:06	00:16	TRIPPED ON FAULT
4505	26-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	HANAWAL_110	12:55	14:25	01:30	LINE CLEAR AVAILED
4506	26-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	12:48	13:01	00:13	TRIPPED ON FAULT
4507	26-Feb-2024	GULBARGA	110	TRANSFORMER	HV2	KALABURGI NORTH_110	11:05	11:30	00:25	LINE CLEAR AVAILED
4508	26-Feb-2024	GULBARGA	110	TRANSFORMER	HV3	S R NAGAR_110	11:00	11:40	00:40	TRIPPED ON FAULT
4509	26-Feb-2024	GULBARGA	110	LINE	KAPNOOR-KALABURGI_WEST	KALABURGI_WEST_110	06:17	08:15	01:58	TRIPPED ON FAULT
4510	26-Feb-2024	GULBARGA	220	LINE	LINGAPUR-BTPS	LINGAPUR_220	10:57	13:49	02:52	LINE CLEAR AVAILED
4511	26-Feb-2024	GULBARGA	220	LINE	LINGAPUR-HALWARTHY	LINGAPUR_220	14:21	16:55	02:34	LINE CLEAR AVAILED
4512	26-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-FEROZABAD2	SHAHAPUR_220	23:55(25.02.2024)	0:15(26.02.02024)	00:20	TRIPPED ON FAULT
4513	26-Feb-24	HASSAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	12:47	13:31	00:44	LINE CLEAR AVAILED
4514	26-Feb-24	HASSAN	66	LINE	CHANNAR-CRPATNA2	CHANNARAYAPATNA_220	12:19	12:37	00:18	TRIPPED ON FAULT
4515	26-Feb-24	HASSAN	66	LINE	CRPATNA-SBELAGOLA	CRPATNA_66	07:47	15:19	07:32	LINE CLEAR AVAILED
4516	26-Feb-24	HASSAN	66	LINE	HNPR2-HASS1	HNPURA_220	23:58(26.02.2024)			TRIPPED ON FAULT
4517	26-Feb-24	HASSAN	66	TRANSFORMER	HV1	CRPATNA_66	11:55	15:36	03:41	LINE CLEAR AVAILED
4518	26-Feb-24	HASSAN	66	TRANSFORMER	HV1	HALEBEEDU_66	22:59	23:04	00:05	TRIPPED ON FAULT
4519	26-Feb-24	HASSAN	66	TRANSFORMER	HV1	SBELAGOLA_66	07:45	15:25	07:40	LINE CLEAR AVAILED
4520	26-Feb-24	HASSAN	66	TRANSFORMER	HV2	CHIKKAKONDAGOLA_66	15:56	16:24	00:28	LINE CLEAR AVAILED
4521	26-Feb-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	07:45	15:25	07:40	LINE CLEAR AVAILED
4522	26-Feb-24	HASSAN	66	LINE	SBELAG-YACHENHALLI	SBELAGOLA_66	07:45	15:25	07:40	LINE CLEAR AVAILED
4523	26-Feb-24	HASSAN	110	LINE	GURUPUR-MDBDRE	GURUPURA_110	10:13	13:26	03:13	LINE CLEAR AVAILED
4524	26-Feb-24	HASSAN	110	TRANSFORMER	HV1	SORABA_110	20:59(26.02.2024)			TRIPPED ON FAULT
4525	26-Feb-24	HASSAN	220	LINE	KAVOOR-KVRBJP1	KAVOOR_220	10:34	17:09	06:35	LINE CLEAR AVAILED
4526	26-Feb-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	10:05	17:09	07:04	LINE CLEAR AVAILED
4527	26-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:42 (23/02/2024)	13:45 (27/02/2024)	91:03 HRs	LINE CLEAR AVAILED
4528	26-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
4529	26-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4530	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	ADDIHALLI_66	10:35	10:47	00:12	TRIPPED ON FAULT
4531	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	10:15	11:05	00:49	LINE CLEAR AVAILED
4532	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	11:05	16:12	05:07	LINE CLEAR AVAILED
4533	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	16:15	16:25	00:09	LINE CLEAR AVAILED
4534	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	16:33	16:41	00:08	LINE CLEAR AVAILED
4535	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLI_66	10:46	12:57	02:11	LINE CLEAR AVAILED
4536	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHEELUNERE_66	07:33	07:38	00:05	TRIPPED ON FAULT
4537	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4538	26-Feb-24	MYSORE	66	TRANSFORMER	HV1	HEBBAL_66	19:03 (25/02/2024)	10:11 (26/02/2024)	15:07 HRs	LINE CLEAR AVAILED
4539	26-Feb-24	MYSORE	66	TRANSFORMER	HV2	JAKKANAHALLY_66	14:50	15:59	01:09	LINE CLEAR AVAILED
4540	26-Feb-24	MYSORE	66	TRANSFORMER	HV2	DODDABYADARAHALLI_66	14:10	14:20	00:10	TRIPPED ON FAULT
4541	26-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
4542	26-Feb-24	MYSORE	66	LINE	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	12:16	12:24	00:08	TRIPPED ON FAULT
4543	26-Feb-24	MYSORE	66	LINE	KADAKOLA-JAYAPURA	NO STATIONS EFFECTED	18:48	18:53	00:05	TRIPPED ON FAULT
4544	26-Feb-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	12:16	12:24	00:08	TRIPPED ON FAULT
4545	26-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4546	26-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
4547	26-Feb-24	MYSORE	66	LINE	MANDYA-MC-2	NO STATIONS EFFECTED	21:19	22:04	00:44	LINE CLEAR AVAILED
4548	26-Feb-24	MYSORE	66	LINE	TUBINKERE-G UKKADA	GARUDANAUKADDA_66SRIRANGA PATNA_66	12:16	12:29	00:13	TRIPPED ON FAULT
4549	26-Feb-24	MYSORE	66	LINE	TUBINKERE-PANDAVAPURA	BANANGADI_66	12:16	12:29	00:13	TRIPPED ON FAULT
4550	26-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:28 (25/02/2024)	7:25 (26/02/2024)	9:56 HRs	LINE CLEAR AVAILED
4551	26-Feb-24	TUMKUR	66	LINE	DAVANGERE220kV-DAVANGERE	DAVANAGERE_66	14:26	14:39	00:13	LINE CLEAR AVAILED
4552	26-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 220kV-KUNIGAL	KUNIGAL_66	11:23	11:37	00:14	LINE CLEAR AVAILED
4553	26-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	16:07	16:17	00:10	TRIPPED ON FAULT
4554	26-Feb-24	TUMKUR	66	LINE	ANCHEPALYA 220kV-ANCHEPALYA 1	ANCHEPALYA_66	11:15	11:20	00:05	LINE CLEAR AVAILED
4555	26-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:38	14:50	00:12	TRIPPED ON FAULT
4556	26-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-CHITRADURGA 4	CHITRADURGA_220	14:40	14:55	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4557	26-Feb-24	TUMKUR	66	LINE	CHITRADURGA 220kV-J.N.KOTE_66	J.N.KOTE,AIMAGALA_66,MALLAPANAHALLI_66	12:34	12:41	00:07	MAIN SUPPLY FAILURE
4558	26-Feb-24	TUMKUR	66	LINE	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66H D PURA_66,CHITRAHLLI_66	14:41	15:17	00:36	TRIPPED ON FAULT
4559	26-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	14:22	14:26	00:04	LINE CLEAR AVAILED
4560	26-Feb-24	TUMKUR	66	LINE	H D PURA- PANDARAHALLI (CHITRADURGA220)	H D PURA_66,CHITRAHLLI_66	14:40	15:16	00:36	MAIN SUPPLY FAILURE
4561	26-Feb-24	TUMKUR	66	LINE	HIRIYUR220-HIRIYUR_66	HIRIYUR_66	12:33	12:44	00:11	TRIPPED ON FAULT
4562	26-Feb-24	TUMKUR	66	LINE	HIRIYUR220-HIRIYUR_66	HIRIYUR_66,KATTIGE_66	02:56	03:06	00:10	TRIPPED ON FAULT
4563	26-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	16:15	16:28	00:13	TRIPPED ON FAULT
4564	26-Feb-24	TUMKUR	66	LINE	PAVAGADA 220kV-SHYLAPURA	SHYLAPURA_66	03:20	04:05	00:45	TRIPPED ON FAULT
4565	26-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4566	26-Feb-24	TUMKUR	66	LINE	SANIKERE- HIRIYUR	SANIKERE_66	11:56	13:10	01:14	LINE CLEAR AVAILED
4567	26-Feb-24	TUMKUR	66	LINE	SHYLAPURA-PAVAGADA	SHYLAPURA_66	14:05	14:25	00:20	MAIN SUPPLY FAILURE
4568	26-Feb-24	TUMKUR	66	TRANSFORMER	TR1	PANDARAHALLI_66,	17:30	17:35	00:05	LINE CLEAR AVAILED
4569	26-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HIRIYUR_220	11:10	11:20	00:10	TRIPPED ON FAULT
4570	26-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADHUGIRI_66	11:30	11:53	00:23	LINE CLEAR AVAILED
4571	26-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BILCHODU_66	15:57	16:19	00:22	TRIPPED ON FAULT
4572	26-Feb-24	TUMKUR	66	TRANSFORMER	TR-1&TR-2	SANIKERE_66	11:56	13:10	01:14	LINE CLEAR AVAILED
4573	26-Feb-24	TUMKUR	66	TRANSFORMER	TR2	PANDARAHALLI_66,	17:08	17:20	00:12	LINE CLEAR AVAILED
4574	26-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	HALURAMESWARA_66	14:05	14:15	00:10	TRIPPED ON FAULT
4575	26-Feb-24	TUMKUR	110	TRANSFORMER	TR-1	KADEHALLI_110	22:05	23:30	01:25	TRIPPED ON FAULT
4576	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KAVALWADA_110	11:51	16:04	04:13	LINE CLEAR AVAILED
4577	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	VAJRAMATTI_110	14:10	16:54	02:44	LINE CLEAR AVAILED
4578	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	CHIKKODI_110	15:33	15:55	00:22	TRIPPED ON FAULT
4579	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	VAJRAMATTI_110	14:10	18:35	04:25	LINE CLEAR AVAILED
4580	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	SINDAGI_110	13:45	14:30	00:45	LINE CLEAR AVAILED
4581	27-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA-HV1)	KARWAR_110	11:08	11:54	00:46	LINE CLEAR AVAILED
4582	27-Feb-24	BAGALKOTE	110	LINE	ATHANI220- KSSKN	STATION NOT AFFECTED ATHANI_220	11:35	12:47	01:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4583	27-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4584	27-Feb-24	BAGALKOTE	110	LINE	ATHARGA-FPI	ATHARGA_110	20:00 (26.02.2024)	6:02 (27.02.2024)	10:02	LINE CLEAR AVAILED
4585	27-Feb-24	BAGALKOTE	110	LINE	BIJAPUR220-BAGEWADI(ENERCON)	STATION NOT AFFECTED BIJAPUR_220	13:27	15:50	02:23	LINE CLEAR AVAILED
4586	27-Feb-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR CITY	STATION NOT AFFECTED BIJAPUR_220	09:24	15:51	06:27	LINE CLEAR AVAILED
4587	27-Feb-24	BAGALKOTE	110	LINE	BIJAPUR220- KIADB1	STATION NOT AFFECTED BIJAPUR_220	09:25	15:50	06:25	LINE CLEAR AVAILED
4588	27-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
4589	27-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
4590	27-Feb-24	BAGALKOTE	110	LINE	HUNGUND-ILKAL1	HUNGUND_110	13:40	14:16	00:36	LINE CLEAR AVAILED
4591	27-Feb-24	BAGALKOTE	110	LINE	HUNGUND-ILKAL2	HUNGUND_110	13:40	14:16	00:36	LINE CLEAR AVAILED
4592	27-Feb-24	BAGALKOTE	110	LINE	KADANAKOPPA-KAVALWADA(AMBEWADI)	KADANAKOPPA_110	19:16 (27.02.2024)			LINE CLEAR AVAILED
4593	27-Feb-24	BAGALKOTE	110	LINE	KIRUVATTI-UMMACHAGI	KIRUVATTI_110	12:15	13:20	01:05	LINE CLEAR AVAILED
4594	27-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4595	27-Feb-24	BAGALKOTE	110	LINE	MAMADAPUR-BAGEWADI1	MAMADAPUR(B)_110	06:27	06:38	00:11	TRIPPED ON FAULT
4596	27-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4597	27-Feb-24	BAGALKOTE	110	LINE	MUDDEBIHAL-KNMSLR(HIREMURAL)	MUDDEBIHAL_110	18:44	18:56	00:12	TRIPPED ON FAULT
4598	27-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4599	27-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
4600	27-Feb-24	BAGALKOTE	110	LINE	TAKKALAKI-TRV(KIADB BIJAPUR)	TAKKALAKI_110	09:28	15:22	05:54	LINE CLEAR AVAILED
4601	27-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4602	27-Feb-24	BAGALKOTE	110	LINE	YARAGATTI	YARAGATTI_110	16:37	17:29	00:52	TRIPPED ON FAULT
4603	27-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	STATION NOT AFFECTED BIJAPUR_220	11:14	13:49	02:35	LINE CLEAR AVAILED
4604	27-Feb-24	BAGALKOTE	220	TRANSFORMER	220/110KV, LV2	STATION NOT AFFECTED BIJAPUR_220	11:22	13:51	02:29	LINE CLEAR AVAILED
4605	27-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4606	27-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-MUGALKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	12:59	17:20	04:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4607	27-Feb-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	10:32	17:20	06:48	LINE CLEAR AVAILED
4608	27-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	12:58	19:01	06:03	LINE CLEAR AVAILED
4609	27-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4610	27-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4611	27-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4612	27-Feb-24	BENGALURU	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE	15:16	15:20	00:04	LINE CLEAR AVAILED
4613	27-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4614	27-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNASENAHALLI	17:03	18:07	01:04	TRIPPED ON FAULT
4615	27-Feb-24	BENGALURU	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, GOWNIPALLI, RAYALPADU	15:10	17:30	02:20	LINE CLEAR AVAILED
4616	27-Feb-24	BENGALURU	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	03:37	04:03	00:26	TRIPPED ON FAULT
4617	27-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE - 1)	JADIGENAHALLI	03:37	04:01	00:24	MAIN SUPPLY FAILURE
4618	27-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	16:23	16:28	00:05	LINE CLEAR AVAILED
4619	27-Feb-24	BENGALURU	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	03:37	04:01	00:24	MAIN SUPPLY FAILURE
4620	27-Feb-24	BENGALURU	66	LINE	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY P2 S2, HUSKUR	15:05	15:15	00:10	LINE CLEAR AVAILED
4621	27-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	16:04	16:12	00:08	LINE CLEAR AVAILED
4622	27-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:04	16:12	00:08	LINE CLEAR AVAILED
4623	27-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	17:15	17:20	00:05	LINE CLEAR AVAILED
4624	27-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	18:27	18:31	00:04	LINE CLEAR AVAILED
4625	27-Feb-24	BENGALURU	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYANAGARA	14:33	14:51	00:18	LINE CLEAR AVAILED
4626	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	02:05	02:29	00:24	MAIN SUPPLY FAILURE
4627	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	12:38	13:04	00:26	MAIN SUPPLY FAILURE
4628	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 1	BWSSB 1	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4629	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 1	BWSSB 1	12:38	12:59	00:21	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4630	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB 2	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4631	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB 2	12:38	12:59	00:21	MAIN SUPPLY FAILURE
4632	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 3	BWSSB 3	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4633	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 3	BWSSB 3	12:38	12:59	00:21	MAIN SUPPLY FAILURE
4634	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 4	BWSSB 4	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4635	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - BWSSB 4	BWSSB 4	12:38	12:59	00:21	MAIN SUPPLY FAILURE
4636	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	02:05	02:17	00:12	MAIN SUPPLY FAILURE
4637	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	12:38	13:01	00:23	MAIN SUPPLY FAILURE
4638	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU	02:05	02:30	00:25	MAIN SUPPLY FAILURE
4639	27-Feb-24	BENGALURU	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU	12:38	13:01	00:23	MAIN SUPPLY FAILURE
4640	27-Feb-24	BENGALURU	66	LINE	66KV WELCAST - ABBIGERE	WELCAST	13:30	13:34	00:04	LINE CLEAR AVAILED
4641	27-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	14:33	14:51	00:18	LINE CLEAR AVAILED
4642	27-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA, BIOCON	14:22	14:50	00:28	LINE CLEAR AVAILED
4643	27-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	14:22	14:53	00:31	LINE CLEAR AVAILED
4644	27-Feb-24	BENGALURU	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA(EHT)	14:22	14:53	00:31	LINE CLEAR AVAILED
4645	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ABBIGERE	16:49	16:50	00:01	LINE CLEAR AVAILED
4646	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BIEC	12:50	12:55	00:05	LINE CLEAR AVAILED
4647	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YELDUR	13:00	13:50	00:50	TRIPPED ON FAULT
4648	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HAROBELA	14:45	14:50	00:05	LINE CLEAR AVAILED
4649	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TK HALLI 220	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4650	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TK HALLI 220	12:38	12:59	00:21	MAIN SUPPLY FAILURE
4651	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	16:02	16:12	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4652	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SARJAPURA 220	17:15	17:20	00:05	LINE CLEAR AVAILED
4653	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	YARANDANAHALLI 220	14:26	14:50	00:24	LINE CLEAR AVAILED
4654	27-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TALAGUNDA	10:50	11:05	00:15	TRIPPED ON FAULT
4655	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BIEC	10:25	10:30	00:05	LINE CLEAR AVAILED
4656	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MELUR	00:10	00:20	00:10	TRIPPED ON FAULT
4657	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	D PALYA	03:30	03:50	00:20	TRIPPED ON FAULT
4658	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	VEMGAL	09:45	09:55	00:10	TRIPPED ON FAULT
4659	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	HAROBEL	15:20	15:25	00:05	LINE CLEAR AVAILED
4660	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	KODIGEHALLI	09:06	09:19	00:13	TRIPPED ON FAULT
4661	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TK HALLI 220	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4662	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TK HALLI 220	12:38	13:00	00:22	MAIN SUPPLY FAILURE
4663	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	JIGANI 66	00:45	01:15	00:30	TRIPPED ON FAULT
4664	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SARJAPURA 220	16:02	16:12	00:10	LINE CLEAR AVAILED
4665	27-Feb-24	BENGALURU	66	TRANSFORMER	HV2	TALAGUNDA	13:25	13:40	00:15	TRIPPED ON FAULT
4666	27-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 1	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, TUMGERE	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4667	27-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 1	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, TUMGERE	12:38	13:03	00:25	MAIN SUPPLY FAILURE
4668	27-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, TUMGERE	02:05	02:18	00:13	MAIN SUPPLY FAILURE
4669	27-Feb-24	BENGALURU	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, TUMGERE	12:38	13:03	00:25	MAIN SUPPLY FAILURE
4670	27-Feb-24	BENGALURU	220	LINE	220KV MYLASANDRA 400 - YARANDANAHALLI 1	YARANDANAHALLI 220	14:57	15:10	00:13	LINE CLEAR AVAILED
4671	27-Feb-24	BENGALURU	220	LINE	220KV TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	02:05	02:18	00:13	TRIPPED ON FAULT
4672	27-Feb-24	BENGALURU	220	LINE	220KV TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	12:38	12:58	00:20	TRIPPED ON FAULT
4673	27-Feb-24	BENGALURU	220	TRANSFORMER	HV1	YARANDANAHALLI 220	14:28	14:48	00:20	LINE CLEAR AVAILED
4674	27-Feb-24	BENGALURU	220	LINE	LV1	MALUR 220	03:37	04:01	00:24	TRIPPED ON FAULT
4675	27-Feb-2024	GULBARGA	66	LINE	HANAGAL-GUDDEKOTE	CJ HALLI_66, HOSAHALLI_66	10:25	10:40	00:15	TRIPPED ON FAULT
4676	27-Feb-2024	GULBARGA	66	TRANSFORMER	HV1	BANAVEKAL_66	17:05	17:30	00:25	LINE CLEAR AVAILED
4677	27-Feb-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	SOVENHALLI_66, TBPCL	17:55	18:01	00:06	TRIPPED ON FAULT
4678	27-Feb-2024	GULBARGA	66	LINE	ITTAGI-RENEW SOLAR	ITTAGI_220	20:25	21:04	00:39	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4679	27-Feb-2024	GULBARGA	66	LINE	MUNIRABAD-UPHALLI(MHD LINE)	VENKATAPURA_66,UP_HALLI_66	10:48	10:54	00:06	LINE CLEAR AVAILED
4680	27-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	FARTHABAD_110	11:05	13:15	02:10	LINE CLEAR AVAILED
4681	27-Feb-2024	GULBARGA	110	LINE	KALABURGI SOUTH-FARTHABAD	FARTHABAD_110	12:55	13:45	00:50	LINE CLEAR AVAILED
4682	27-Feb-2024	GULBARGA	110	LINE	KAMALAPUR-MUNIRABAD	KAMALAPUR_110	09:15	19:15	10:00	LINE CLEAR AVAILED
4683	27-Feb-2024	GULBARGA	110	LINE	SHAHAPUR-SHORAPUR(DEVAPUR)	SHORAPUR_110,DEVAPUR_110	21:41	21:45	00:04	TRIPPED ON FAULT
4684	27-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	ITTAGI_220	19:15	21:05	01:50	LINE CLEAR AVAILED
4685	27-Feb-2024	GULBARGA	220	LINE	SHAHAPUR-RTPS1	SHAHAPUR_220	20:44	21:02	00:18	TRIPPED ON FAULT
4686	27-Feb-24	HASSAN	66	LINE	BASAVAGT-DUDDA	BASAVAGHATTA_66	10:58	16:35	05:37	LINE CLEAR AVAILED
4687	27-Feb-24	HASSAN	66	LINE	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	10:35	13:50	03:15	LINE CLEAR AVAILED
4688	27-Feb-24	HASSAN	66	LINE	DUDDA-BASAVAGHATTA	DUDDA_66	10:11	16:22	06:11	LINE CLEAR AVAILED
4689	27-Feb-24	HASSAN	66	LINE	DUDDA-CKNDGL	DUDDA_66	10:11	15:36	05:25	LINE CLEAR AVAILED
4690	27-Feb-24	HASSAN	66	LINE	HASSN220-SUZLON	HASSAN_220	10:36	11:36	01:00	LINE CLEAR AVAILED
4691	27-Feb-24	HASSAN	66	LINE	HASSN220-UDDURKOPLU	HASSAN_220	11:38	12:41	01:03	LINE CLEAR AVAILED
4692	27-Feb-24	HASSAN	66	LINE	HNPR2-HASS1	HNPURA_220	23:58(26.02.2024)	00:08(27.02.2024)		TRIPPED ON FAULT
4693	27-Feb-24	HASSAN	66	LINE	HNPR2-HASS1	HNPURA_220	01:53	02:04	00:11	TRIPPED ON FAULT
4694	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	BASAVAGHATTA_66	10:58	16:35	05:37	LINE CLEAR AVAILED
4695	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	DUDDA_66	10:11	15:37	05:26	LINE CLEAR AVAILED
4696	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	19:35	20:36	01:01	MAIN SUPPLY FAILURE
4697	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	23:00	23:25	00:25	LINE CLEAR AVAILED
4698	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	10:00	15:15	05:15	LINE CLEAR AVAILED
4699	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	SHANTHIGRAMA_66	10:04	14:03	03:59	LINE CLEAR AVAILED
4700	27-Feb-24	HASSAN	66	TRANSFORMER	HV1	MANJUNATHPURA_66	14:00	14:20	00:20	MAIN SUPPLY FAILURE
4701	27-Feb-24	HASSAN	66	TRANSFORMER	HV2	BASAVAGHATTA_66	10:58	16:35	05:37	LINE CLEAR AVAILED
4702	27-Feb-24	HASSAN	66	TRANSFORMER	HV2	DUDDA_66	10:11	15:37	05:26	LINE CLEAR AVAILED
4703	27-Feb-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	10:00	15:15	05:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4704	27-Feb-24	HASSAN	66	TRANSFORMER	HV2	SHANTHIGRAMA_66	10:04	14:03	03:59	LINE CLEAR AVAILED
4705	27-Feb-24	HASSAN	66	TRANSFORMER	HV2	MANJUNATHPURA_66	14:00	14:20	00:20	MAIN SUPPLY FAILURE
4706	27-Feb-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	13:05	14:00	00:55	LINE CLEAR AVAILED
4707	27-Feb-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	19:35	23:22	03:47	LINE CLEAR AVAILED
4708	27-Feb-24	HASSAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	19:35	23:22	03:47	TRIPPED ON FAULT
4709	27-Feb-24	HASSAN	66	LINE	MANJUNTH-L1	MANJUNATHPURA_66	14:00	14:20	00:20	MAIN SUPPLY FAILURE
4710	27-Feb-24	HASSAN	66	LINE	MANJUNTH-L2	MANJUNATHPURA_66	14:00	14:20	00:20	MAIN SUPPLY FAILURE
4711	27-Feb-24	HASSAN	66	LINE	SHNTHI-RMSWRNGR	SHANTHIGRAMA_66	10:04	14:03	03:59	LINE CLEAR AVAILED
4712	27-Feb-24	HASSAN	66	LINE	SHNTHI-UDYAPURA	SHANTHIGRAMA_66	10:04	14:03	03:59	LINE CLEAR AVAILED
4713	27-Feb-24	HASSAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPPLU_66	10:10	15:10	05:00	LINE CLEAR AVAILED
4714	27-Feb-24	HASSAN	66	LINE	UDDURKO-HASSAN1	UDDURKOPPLU_66	10:40	11:36	00:56	LINE CLEAR AVAILED
4715	27-Feb-24	HASSAN	66	LINE	UDDURKOHASSAN2	UDDURKOPPLU_66	11:40	12:40	01:00	LINE CLEAR AVAILED
4716	27-Feb-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	10:45	10:50	00:05	TRIPPED ON FAULT
4717	27-Feb-24	HASSAN	110	LINE	HGUNJE-HIRIYADKA	HEEGUNJE_220	11:36	17:21	05:45	LINE CLEAR AVAILED
4718	27-Feb-24	HASSAN	110	LINE	HIRIYA-HGUNJE	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4719	27-Feb-24	HASSAN	110	LINE	HIRIYA-HGUNJE	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4720	27-Feb-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4721	27-Feb-24	HASSAN	110	LINE	HIRIYA-MANIPAL	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4722	27-Feb-24	HASSAN	110	TRANSFORMER	HV1	SORABA_110	20:59(26.02.2024)	00:00(28.02.2024)		TRIPPED ON FAULT
4723	27-Feb-24	HASSAN	110	TRANSFORMER	HV1	ARASIKERE_110	08:25	08:36	00:11	TRIPPED ON FAULT
4724	27-Feb-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4725	27-Feb-24	HASSAN	110	TRANSFORMER	HV2	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4726	27-Feb-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	11:36	17:21	05:45	LINE CLEAR AVAILED
4727	27-Feb-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	09:36	10:06	00:30	TRIPPED ON FAULT
4728	27-Feb-24	HASSAN	110	LINE	LV2	SHIRALKOPA_220	16:11	18:39	02:28	LINE CLEAR AVAILED
4729	27-Feb-24	HASSAN	220	TRANSFORMER	HV2	HEGGUNJE_220	11:37	15:00	03:23	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4730	27-Feb-24	HASSAN	220	TRANSFORMER	HV2	SHIRALKOPPA_220	16:11	18:39	02:28	LINE CLEAR AVAILED
4731	27-Feb-24	HASSAN	220	LINE	KAVOOR-KVRBJPE2	KAVOOR_220	10:44	15:18	04:34	LINE CLEAR AVAILED
4732	27-Feb-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMSG_220	10:47	11:40	00:53	TRIPPED ON FAULT
4733	27-Feb-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	10:44	15:18	04:34	LINE CLEAR AVAILED
4734	27-Feb-24	HASSAN	220	LINE	VARAH1-SHMG3	gen-varahi	10:47	11:40	00:53	TRIPPED ON FAULT
4735	27-Feb-24	MYSORE	66	LINE	B MATKERE-BEGUR	BMATKERE_66	05:35	05:40	00:05	TRIPPED ON FAULT
4736	27-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	06:40	06:54	00:14	TRIPPED ON FAULT
4737	27-Feb-24	MYSORE	66	LINE	CHANDRAVADI-KADAKOLA	CHANDRAVADI_66 HURA_66	17:32	19:03	01:31	LINE CLEAR AVAILED
4738	27-Feb-24	MYSORE	66	LINE	DEVNUR(MYS)-RAJEEVNAGAR	NO STATIONS EFFECTED	14:36	15:31	00:55	LINE CLEAR AVAILED
4739	27-Feb-24	MYSORE	66	LINE	DEVNUR(MYS)-VAJMANGALA	NO STATIONS EFFECTED	14:18	17:12	02:54	LINE CLEAR AVAILED
4740	27-Feb-24	MYSORE	66	LINE	DODDINDUVADI-MADHUVANAHALLI	NO STATIONS EFFECTED	05:55	06:40	00:45	TRIPPED ON FAULT
4741	27-Feb-24	MYSORE	66	LINE	ELIVALA-HOOTGALLY	NO STATIONS EFFECTED	16:05	17:38	01:32	LINE CLEAR AVAILED
4742	27-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 1	NO STATIONS EFFECTED	10:30	13:45	03:15	LINE CLEAR AVAILED
4743	27-Feb-24	MYSORE	66	LINE	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	10:30	13:45	03:15	LINE CLEAR AVAILED
4744	27-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
4745	27-Feb-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	CHIDRAVALLI_66BGPURA_66THUMBLA_66 VYSARAJAPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	09:21	09:32	00:11	TRIPPED ON FAULT
4746	27-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4747	27-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAPA 1	NO STATIONS EFFECTED	17:12	17:30	00:18	LINE CLEAR AVAILED
4748	27-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	17:09	17:33	00:23	LINE CLEAR AVAILED
4749	27-Feb-24	MYSORE	66	LINE	HOOTAGALLI-DATTGALLI	NO STATIONS EFFECTED	17:46	17:59	00:13	LINE CLEAR AVAILED
4750	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	ATTIGULIPURA_66	12:12	13:34	01:22	LINE CLEAR AVAILED
4751	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	KHBCOLONY_66	14:03	14:51	00:48	LINE CLEAR AVAILED
4752	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	MYSORESOUTH_66	13:54	14:36	00:42	LINE CLEAR AVAILED
4753	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	VAJAMANGALA_66	10:51	12:15	01:24	LINE CLEAR AVAILED
4754	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	BILIKERE_66	16:20	16:35	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4755	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	SHEELUNERE_66	11:10	17:00	05:50	LINE CLEAR AVAILED
4756	27-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4757	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	ATTIGULIPURA_66	13:40	15:10	01:30	LINE CLEAR AVAILED
4758	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	DEVNUR(N'GUD)_66	07:45	07:55	00:10	TRIPPED ON FAULT
4759	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	KHBCOLONY_66	14:47	15:31	00:44	LINE CLEAR AVAILED
4760	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	13:35	13:40	00:04	LINE CLEAR AVAILED
4761	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADDUR_66	11:18	13:01	01:43	LINE CLEAR AVAILED
4762	27-Feb-24	MYSORE	66	TRANSFORMER	HV2	BILIKERE_66	16:36	16:53	00:17	LINE CLEAR AVAILED
4763	27-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
4764	27-Feb-24	MYSORE	66	LINE	JAIPUR-KADAKOLA	NO STATIONS EFFECTED	09:00	09:09	00:09	TRIPPED ON FAULT
4765	27-Feb-24	MYSORE	66	LINE	KIKKERI-KRPETE 1	NO STATIONS EFFECTED	12:26	12:53	00:27	LINE CLEAR AVAILED
4766	27-Feb-24	MYSORE	66	LINE	KIKKERI-KRPETE 1	NO STATIONS EFFECTED	16:20	16:42	00:22	LINE CLEAR AVAILED
4767	27-Feb-24	MYSORE	66	TRANSFORMER	KOLKARANADODDI-HV1	KIADBMANDYA_66 TUMBEKERE_66KMDODDI_66KOLKARANADODDI_66KHONNALAGERE_66THALAGAVADI_66YETTAMBADI_66	02:10	02:18	00:08	LINE CLEAR AVAILED
4768	27-Feb-24	MYSORE	66	TRANSFORMER	KOLKARANADODDI-HV1	KIADBMANDYA_66 TUMBEKERE_66KMDODDI_66KOLKARANADODDI_66KHONNALAGERE_66THALAGAVADI_66YETTAMBADI_66	12:37	13:03	00:26	LINE CLEAR AVAILED
4769	27-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
4770	27-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
4771	27-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	05:51	06:06	00:15	TRIPPED ON FAULT
4772	27-Feb-24	MYSORE	66	LINE	MAMBALLI-YELANDURU	MAMBALLI_66	16:55	17:25	00:30	LINE CLEAR AVAILED
4773	27-Feb-24	MYSORE	66	LINE	NAGAMANGALA 220-KASALGERE	KASALGERE_66	08:16	08:23	00:07	TRIPPED ON FAULT
4774	27-Feb-24	MYSORE	66	LINE	SFCSIVA-10 MW SOLAR	NO STATIONS EFFECTED	09:22	09:24	00:02	TRIPPED ON FAULT
4775	27-Feb-24	MYSORE	66	LINE	SFCSIVA-5 MW SOLAR	NO STATIONS EFFECTED	09:22	09:24	00:02	TRIPPED ON FAULT
4776	27-Feb-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	09:44	11:30	01:46	LINE CLEAR AVAILED
4777	27-Feb-24	MYSORE	220	TRANSFORMER	HV1	HEBBANI_220	14:17	14:27	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4778	27-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:16 (27/02/2024)			LINE CLEAR AVAILED
4779	27-Feb-24	MYSORE	220	LINE	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	02:05	02:18	00:13	TRIPPED ON FAULT
4780	27-Feb-24	MYSORE	220	LINE	VAJMANGALA-TKHALLI	NO STATIONS EFFECTED	12:38	12:58	00:20	TRIPPED ON FAULT
4781	27-Feb-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:30	15:38	00:08	TRIPPED ON FAULT
4782	27-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	17:12	17:30	00:18	TRIPPED ON FAULT
4783	27-Feb-24	TUMKUR	66	LINE	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	10:22	10:31	00:09	TRIPPED ON FAULT
4784	27-Feb-24	TUMKUR	66	LINE	HIREHALLI - HONNUDIKE_66,BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	16:10	16:40	00:30	LINE CLEAR AVAILED
4785	27-Feb-24	TUMKUR	66	LINE	HONNALLI 220kV- NALLUR_66	NALLUR_66	06:40	06:50	00:10	TRIPPED ON FAULT
4786	27-Feb-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	09:07	09:10	00:03	TRIPPED ON FAULT
4787	27-Feb-24	TUMKUR	66	LINE	KORATAGERE-MADHUGIRI 1	KORATAGERE_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4788	27-Feb-24	TUMKUR	66	LINE	KORATAGERE-MADHUGIRI 2	KORATAGERE_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4789	27-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-BADAVANAHALLI	MADHUGIRI_66, BADAVANAHALLI_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4790	27-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-MEDIGESHI	MEDIGESHI_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4791	27-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4792	27-Feb-24	TUMKUR	66	LINE	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	12:23	14:25	02:02	LINE CLEAR AVAILED
4793	27-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4794	27-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4795	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BELLAVI_66	09:03	09:13	00:10	TRIPPED ON FAULT
4796	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BEVINAHALLI_66	10:40	11:15	00:35	LINE CLEAR AVAILED
4797	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRADURGA_66	21:57	22:04	00:07	TRIPPED ON FAULT
4798	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HOSADURGA_66	13:40	13:45	00:05	TRIPPED ON FAULT
4799	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MELLEKATTE_66	19:30	19:40	00:10	LINE CLEAR AVAILED
4800	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1(LV SIDE)	DAVANAGERE SRS_220	17:40	18:40	01:00	LINE CLEAR AVAILED
4801	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-1(LV SIDE)	MADHUGIRI_220	13:53	14:20	00:27	LINE CLEAR AVAILED
4802	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHITRADURGA_66	10:07	19:08	09:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4803	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	P.D.KOTE_66	12:05	12:10	00:05	TRIPPED ON FAULT
4804	27-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	P.D.KOTE_66	12:10	12:20	00:10	TRIPPED ON FAULT
4805	27-Feb-24	TUMKUR	110	TRANSFORMER	TR-2	NITTUR_220	08:40	08:50	00:10	TRIPPED ON FAULT
4806	27-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	DAVANAGERE SRS_220	17:58	18:35	00:37	LINE CLEAR AVAILED
4807	27-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	MADHUGIRI_220	12:23	12:55	00:32	LINE CLEAR AVAILED
4808	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	10:45	13:00	02:15	LINE CLEAR AVAILED
4809	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	STATION NOT AFFECTED VAJRAMATTI_220	15:43	18:53	03:10	LINE CLEAR AVAILED
4810	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SULTANPUR_110	12:12	13:00	00:48	LINE CLEAR AVAILED
4811	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TOLAMATTI_110	18:05	18:25	00:20	LINE CLEAR AVAILED
4812	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	THORVI_110	10:15	10:49	00:34	LINE CLEAR AVAILED
4813	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	NAVALGUND_110	10:00	17:05	07:05	LINE CLEAR AVAILED
4814	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	SULTANPUR_110	12:12	13:00	00:48	LINE CLEAR AVAILED
4815	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	08:25	08:40	00:15	TRIPPED ON FAULT
4816	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	08:07	08:10	00:03	TRIPPED ON FAULT
4817	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	GAGAG_110	10:05	18:50	08:45	LINE CLEAR AVAILED
4818	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(10MVA)	JAMAKHANDI_110	14:03	14:14	00:11	TRIPPED ON FAULT
4819	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(10MVA)	GAGAG_110	10:15	18:45	08:30	LINE CLEAR AVAILED
4820	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	GAGAG_110	10:04	19:20	09:16	LINE CLEAR AVAILED
4821	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	GAGAG_110	10:04	19:20	09:16	LINE CLEAR AVAILED
4822	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	HIDIKAL_110	19:05	19:39	00:34	LINE CLEAR AVAILED
4823	28-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	SINDAGI_110	10:28	10:50	00:22	LINE CLEAR AVAILED
4824	28-Feb-24	BAGALKOTE	110	LINE	AEQUS220-HUKKERI	STATION NOT AFFECTED AEQUS_220	10:06	13:18	03:12	LINE CLEAR AVAILED
4825	28-Feb-24	BAGALKOTE	110	LINE	AMBEWADI220- NK-1(HALIYAL)	STATION NOT AFFECTED AMBEWADI_220	10:19	13:09	02:50	LINE CLEAR AVAILED
4826	28-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
4827	28-Feb-24	BAGALKOTE	110	LINE	BABLESHWAR-F2(MAMDAPUR)TIKOTA	BABLESHWAR_110	10:12	13:20	03:08	LINE CLEAR AVAILED
4828	28-Feb-24	BAGALKOTE	110	LINE	BETAGERI-NAREGAL	BETAGERI_110	10:03	18:48	08:45	LINE CLEAR AVAILED
4829	28-Feb-24	BAGALKOTE	110	LINE	GADAG220- GADAG	STATION NOT AFFECTED GADAG_220	12:10	18:38	06:28	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4830	28-Feb-24	BAGALKOTE	110	LINE	GADAG220- SHIRAHATTI	STATION NOT AFFECTED GADAG_220	10:30	18:40	08:10	LINE CLEAR AVAILED
4831	28-Feb-24	BAGALKOTE	110	LINE	GADAG220-BETAGERI	STATION NOT AFFECTED GADAG_220	10:25	17:44	07:19	LINE CLEAR AVAILED
4832	28-Feb-24	BAGALKOTE	110	LINE	GHATAPRABHA220- GOKAK	STATION NOT AFFECTED GHATAPRABHA_220	06:22	06:39	00:17	TRIPPED ON FAULT
4833	28-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
4834	28-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
4835	28-Feb-24	BAGALKOTE	110	TRANSFORMER	HUKKERI-VISHVANATH SUGARS	HUKKERI_110	10:01	13:25	03:24	LINE CLEAR AVAILED
4836	28-Feb-24	BAGALKOTE	110	LINE	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	10:48	10:55	00:07	LINE CLEAR AVAILED
4837	28-Feb-24	BAGALKOTE	110	LINE	KADANAKOPPA-KAVALWADA(AMBEWADI)	KADANAKOPPA_110	19:16 (27.02.2024)	10:45 (28.02.2024)	15:29:00	LINE CLEAR AVAILED
4838	28-Feb-24	BAGALKOTE	110	LINE	LAKMESHWAR-SHIRAHATTI	LAKMESHWAR_110	13:31	18:19	04:48	LINE CLEAR AVAILED
4839	28-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4840	28-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4841	28-Feb-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN7(MAHALINGAPUR)	STATION NOT AFFECTED MUGALKHOD_220	10:26	12:58	02:32	LINE CLEAR AVAILED
4842	28-Feb-24	BAGALKOTE	110	LINE	NAVALGUND-NOKAR BHOMI	NAVALGUND_110	10:00	15:42	05:42	LINE CLEAR AVAILED
4843	28-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4844	28-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
4845	28-Feb-24	BAGALKOTE	110	LINE	RANEBENNUR- RATTIHALLI (TUMMINKATTI)	STATION NOT AFFECTED RANEBENNUR_220	14:56	18:51	03:55	LINE CLEAR AVAILED
4846	28-Feb-24	BAGALKOTE	110	LINE	RATTIHALLI-HIREKERUR	RATTIHALLI_110	10:45	13:30	02:45	LINE CLEAR AVAILED
4847	28-Feb-24	BAGALKOTE	110	LINE	RATTIHALLI-TUMMINAKATTI	RATTIHALLI_110	12:50	14:50	02:00	LINE CLEAR AVAILED
4848	28-Feb-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	10:03	17:45	07:42	LINE CLEAR AVAILED
4849	28-Feb-24	BAGALKOTE	110	LINE	SULTANPUR-F2(MUGALKHOD)	SULTANPUR_110	12:10	13:00	00:50	LINE CLEAR AVAILED
4850	28-Feb-24	BAGALKOTE	110	LINE	TAKKALAKI-TIKOTA	TAKKALAKI_110	10:06	13:03	02:57	LINE CLEAR AVAILED
4851	28-Feb-24	BAGALKOTE	110	LINE	THORVI-TIKOTA	THORVI_110	10:15	13:30	03:15	LINE CLEAR AVAILED
4852	28-Feb-24	BAGALKOTE	110	LINE	TUMMINAKATTI-F1(RANEBENNUR)	TUMMINKATTI_110	14:53	18:57	04:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4853	28-Feb-24	BAGALKOTE	110	LINE	TUMMINAKATTI-F2(RATTIHALLI)	TUMMINKATTI_110	12:51	14:53	02:02	LINE CLEAR AVAILED
4854	28-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4855	28-Feb-24	BAGALKOTE	220	LINE	AEQUS -BELGAUM1	STATION NOT AFFECTED AEQUS_220	9:28	12:09	02:41	LINE CLEAR AVAILED
4856	28-Feb-24	BAGALKOTE	220	LINE	AEQUS -BELGAUM2	STATION NOT AFFECTED AEQUS_220	12:14	14:51	02:37	LINE CLEAR AVAILED
4857	28-Feb-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1(XELDOM)	STATION NOT AFFECTED AMBEWADI_220	14:20	15:46	01:26	TRIPPED ON FAULT
4858	28-Feb-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS1	STATION NOT AFFECTED BELGAUM_220	09:33	12:01	02:28	LINE CLEAR AVAILED
4859	28-Feb-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS2	STATION NOT AFFECTED BELGAUM_220	12:14	14:50	02:36	LINE CLEAR AVAILED
4860	28-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4861	28-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-MUGLKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	12:55	18:58	06:03	LINE CLEAR AVAILED
4862	28-Feb-24	BAGALKOTE	220	LINE	GHATAPRABHA-MUGLKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	06:20	08:03	01:43	TRIPPED ON FAULT
4863	28-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	STATION NOT AFFECTED HAVERI_220	12:18	18:12	05:54	LINE CLEAR AVAILED
4864	28-Feb-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	STATION NOT AFFECTED HAVERI_220	12:18	18:13	05:55	LINE CLEAR AVAILED
4865	28-Feb-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI2	STATION NOT AFFECTED HUBLI_220	11:04	17:20	06:16	LINE CLEAR AVAILED
4866	28-Feb-24	BAGALKOTE	220	LINE	MUGALKHOD-GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	13:16	15:12	01:56	LINE CLEAR AVAILED
4867	28-Feb-24	BAGALKOTE	220	LINE	RANEBENNUR- BALLIGAVI	STATION NOT AFFECTED RANEBENNUR_220	13:28	17:29	04:01	TRIPPED ON FAULT
4868	28-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4869	28-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
4870	28-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4871	28-Feb-24	BENGALURU	66	LINE	66KV ARMY WELFARE HOUSING ORGANISATION - KONDASAPURA (SAFAL)	ARMY WELFARE HOUSING ORGANISATION, KADUGODI	18:36	18:41	00:05	LINE CLEAR AVAILED
4872	28-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4873	28-Feb-24	BENGALURU	66	LINE	66KV BYADARAHALLI - KODIGEHALLI	KODIGEHALLI	23:15	23:18	00:03	LINE CLEAR AVAILED
4874	28-Feb-24	BENGALURU	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	HOSKOTE 66	17:20	17:25	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4875	28-Feb-24	BENGALURU	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC 2(MALGUDI 2), HUSKUR	15:37	15:51	00:14	LINE CLEAR AVAILED
4876	28-Feb-24	BENGALURU	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	BAGHMANE WORLD TECH PARK	21:37	21:45	00:08	LINE CLEAR AVAILED
4877	28-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - BAGAMANE WTC 1	BAGHMANE WORLD TECH PARK	11:12	11:18	00:06	LINE CLEAR AVAILED
4878	28-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - BAGAMANE WTC 2	BAGHMANE WORLD TECH PARK	11:12	11:18	00:06	LINE CLEAR AVAILED
4879	28-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	10:50	10:55	00:05	LINE CLEAR AVAILED
4880	28-Feb-24	BENGALURU	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTINIKETHAN	11:16	11:19	00:03	LINE CLEAR AVAILED
4881	28-Feb-24	BENGALURU	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	ARMY WELFARE HOUSING ORGANISATION, KADUGODI	17:50	18:26	00:36	TRIPPED ON FAULT
4882	28-Feb-24	BENGALURU	66	LINE	66KV MELEHALLI - JALAMANGALA	MATHIKERE, JALAMANGALA, KUTAGAL, CHIKKAGANGANAWADI,	12:58	13:08	00:10	TRIPPED ON FAULT
4883	28-Feb-24	BENGALURU	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	BEVOOR	11:12	11:16	00:04	LINE CLEAR AVAILED
4884	28-Feb-24	BENGALURU	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	BEVOOR	16:10	18:24	02:14	LINE CLEAR AVAILED
4885	28-Feb-24	BENGALURU	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	BYADARAHALLI, SRIGANDA KAVALU	23:22	23:56	00:34	LINE CLEAR AVAILED
4886	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	BANASAWADI	17:45	17:52	00:07	TRIPPED ON FAULT
4887	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOODY 220	11:30	11:40	00:10	LINE CLEAR AVAILED
4888	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HOODY 220	16:31	16:42	00:11	LINE CLEAR AVAILED
4889	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	ISRO LAYOUT	15:55	15:57	00:02	LINE CLEAR AVAILED
4890	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	G KODIHALLI	16:24	16:26	00:02	LINE CLEAR AVAILED
4891	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	D CROSS	12:48	12:58	00:10	TRIPPED ON FAULT
4892	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	NALLIMARADANAHALLI	16:20	16:30	00:10	LINE CLEAR AVAILED
4893	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HANUMANTHANAGARA	12:35	14:00	01:25	LINE CLEAR AVAILED
4894	28-Feb-24	BENGALURU	66	TRANSFORMER	HV1	HANUMANTHANAGARA	17:00	17:50	00:50	LINE CLEAR AVAILED
4895	28-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BUDIGERE	08:44	08:49	00:05	TRIPPED ON FAULT
4896	28-Feb-24	BENGALURU	66	TRANSFORMER	HV2	BANASAWADI	17:45	17:52	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4897	28-Feb-24	BENGALURU	66	TRANSFORMER	HV2	G KODIHALLI	17:18	17:20	00:02	LINE CLEAR AVAILED
4898	28-Feb-24	BENGALURU	66	TRANSFORMER	HV2	D CROSS	04:52	04:57	00:05	TRIPPED ON FAULT
4899	28-Feb-24	BENGALURU	66	TRANSFORMER	HV3	BANASAWADI	17:45	17:52	00:07	TRIPPED ON FAULT
4900	28-Feb-2024	GULBARGA	66	LINE	CJ HALLI-HOSAHALLI	HOSAHALLI_66	16:20	18:10	01:50	LINE CLEAR AVAILED
4901	28-Feb-2024	GULBARGA	66	LINE	ITTAGI-BENNEHALLI	KOTTUR_66, BENNEHALLI_66	10:00	17:44	07:44	LINE CLEAR AVAILED
4902	28-Feb-2024	GULBARGA	110	LINE	HALBARGA-HUMNABAD	HUMNABAD_110	15:15	17:04	01:49	LINE CLEAR AVAILED
4903	28-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	KALBURGI NORTH_110	18:02	18:12	00:10	TRIPPED ON FAULT
4904	28-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	13:28	14:03	00:35	LINE CLEAR AVAILED
4905	28-Feb-2024	GULBARGA	110	LINE	JAWALGERA-VALABALLARY	JAVALGERA_110	09:30	14:10	04:40	LINE CLEAR AVAILED
4906	28-Feb-2024	GULBARGA	110	LINE	KALABURGI SOUTH-UNIVERSITY	UNIVERSITY_110	12:25	15:00	02:35	LINE CLEAR AVAILED
4907	28-Feb-2024	GULBARGA	110	LINE	SHAHBAD-BAGEWADI LINE-1	YEDRAMI_110	13:15	13:55	00:40	MAIN SUPPLY FAILURE
4908	28-Feb-2024	GULBARGA	110	LINE	SHAHBAD-BAGEWADI LINE-2	MANDEWAL_110	14:40	15:10	00:30	MAIN SUPPLY FAILURE
4909	28-Feb-2024	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	09:35	13:38	04:03	LINE CLEAR AVAILED
4910	28-Feb-2024	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	13:10	13:44	00:34	TRIPPED ON FAULT
4911	28-Feb-2024	GULBARGA	220	LINE	MALLAT-LINGASUGUR	LINGASUGUR_220	12:56	13:10	00:14	TRIPPED ON FAULT
4912	28-Feb-2024	GULBARGA	220	LINE	NEELAGUNDA-GUTTUR	NEELAGUNDA_220	13:13	16:40	03:27	LINE CLEAR AVAILED
4913	28-Feb-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	18:49	19:07	00:18	TRIPPED ON FAULT
4914	28-Feb-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
4915	28-Feb-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	21:25	22:50	01:25	MAIN SUPPLY FAILURE
4916	28-Feb-24	HASSAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
4917	28-Feb-24	HASSAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	21:25	23:01	01:36	MAIN SUPPLY FAILURE
4918	28-Feb-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	11:25	14:06	02:41	TRIPPED ON FAULT
4919	28-Feb-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	10:50	13:00	02:10	LINE CLEAR AVAILED
4920	28-Feb-24	HASSAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	00:00	00:15	00:15	LINE CLEAR AVAILED
4921	28-Feb-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	12:43	14:27	01:44	LINE CLEAR AVAILED
4922	28-Feb-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	21:04	21:16	00:12	TRIPPED ON FAULT
4923	28-Feb-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	21:22	21:56	00:34	TRIPPED ON FAULT
4924	28-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
4925	28-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	21:25	22:50	01:25	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4926	28-Feb-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	12:43	14:27	01:44	LINE CLEAR AVAILED
4927	28-Feb-24	HASSAN	66	TRANSFORMER	HV1	MALLAPURA_66	10:05	16:56	06:51	LINE CLEAR AVAILED
4928	28-Feb-24	HASSAN	66	TRANSFORMER	HV2	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
4929	28-Feb-24	HASSAN	66	TRANSFORMER	HV2	ARAKALGUD_66	21:25	22:50	01:25	MAIN SUPPLY FAILURE
4930	28-Feb-24	HASSAN	66	TRANSFORMER	HV2	MALLAPURA_66	10:05	16:56	06:51	LINE CLEAR AVAILED
4931	28-Feb-24	HASSAN	66	LINE	MALLAPU-SHIMOGA	MALLAPURA_66	10:05	16:56	06:51	LINE CLEAR AVAILED
4932	28-Feb-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	21:05	21:15	00:10	MAIN SUPPLY FAILURE
4933	28-Feb-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	21:20	23:00	01:40	MAIN SUPPLY FAILURE
4934	28-Feb-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	09:55	10:00	00:05	TRIPPED ON FAULT
4935	28-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHLLI_66	09:55	10:05	00:10	MAIN SUPPLY FAILURE
4936	28-Feb-24	HASSAN	66	LINE	UDDURKO-HASSAN2	UDDURKOPPLU_66	21:05	21:20	00:15	TRIPPED ON FAULT
4937	28-Feb-24	HASSAN	110	LINE	HIRIYA-KEMAR	HIRIYADKA_110	08:16	08:25	00:09	LINE CLEAR AVAILED
4938	28-Feb-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	15:29	18:46	03:17	LINE CLEAR AVAILED
4939	28-Feb-24	HASSAN	110	TRANSFORMER	HV1	KONAJE_110	10:33	12:39	02:06	LINE CLEAR AVAILED
4940	28-Feb-24	HASSAN	110	TRANSFORMER	HV2	BARANGI_110	10:10	17:58	07:48	LINE CLEAR AVAILED
4941	28-Feb-24	HASSAN	110	TRANSFORMER	HV2	ESSUR_110	15:10	15:55	00:45	LINE CLEAR AVAILED
4942	28-Feb-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	11:16	13:50	02:34	LINE CLEAR AVAILED
4943	28-Feb-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	13:16	15:32	02:16	LINE CLEAR AVAILED
4944	28-Feb-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	10:28	14:44	04:16	LINE CLEAR AVAILED
4945	28-Feb-24	HASSAN	110	TRANSFORMER	HV5	MRSMSG_220	09:20	14:30	05:10	LINE CLEAR AVAILED
4946	28-Feb-24	HASSAN	110	LINE	KONAJE-JAPPU	KONAJE_110	11:17	12:38	01:21	LINE CLEAR AVAILED
4947	28-Feb-24	HASSAN	110	LINE	MRSSHM-BADRAVATY3	MRSMSG_220	13:23	16:21	02:58	TRIPPED ON FAULT
4948	28-Feb-24	HASSAN	110	LINE	SHRLKP-ANVATTI	SHIRALKOPPA_220	05:23	06:06	00:43	TRIPPED ON FAULT
4949	28-Feb-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	05:23	06:06	00:43	LINE CLEAR AVAILED
4950	28-Feb-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	05:23	06:21	00:58	LINE CLEAR AVAILED
4951	28-Feb-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	05:23	06:17	00:54	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4952	28-Feb-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	05:23	06:17	00:54	LINE CLEAR AVAILED
4953	28-Feb-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	05:23	06:18	00:55	LINE CLEAR AVAILED
4954	28-Feb-24	HASSAN	220	TRANSFORMER	HV1	SHIRALKOPPA_220	05:23	06:16	00:53	TRIPPED ON FAULT
4955	28-Feb-24	HASSAN	220	LINE	KAVOOR-KEMAR3	KAVOOR_220	10:37	15:30	04:53	LINE CLEAR AVAILED
4956	28-Feb-24	HASSAN	220	LINE	MRSSHM-MYSR2	MRSMSG_220	08:12	18:30	10:18	LINE CLEAR AVAILED
4957	28-Feb-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA4	gen_sharavathy	14:58	15:31	00:33	TRIPPED ON FAULT
4958	28-Feb-24	HASSAN	220	LINE	SHRLKP-BLGVERANIBNR	SHIRALKOPPA_220	13:28	17:29	04:01	TRIPPED ON FAULT
4959	28-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	BEGUR_66 B MATKERE_66	09:38	09:47	00:09	TRIPPED ON FAULT
4960	28-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	BEGUR_66 B MATKERE_66	10:24	10:37	00:13	TRIPPED ON FAULT
4961	28-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 2	BEGUR_66 B MATKERE_66	09:38	09:46	00:08	TRIPPED ON FAULT
4962	28-Feb-24	MYSORE	66	LINE	BEGUR 220-BEGUR 2	BEGUR_66 B MATKERE_66	10:24	10:36	00:12	TRIPPED ON FAULT
4963	28-Feb-24	MYSORE	66	LINE	BEGUR 220-HARAVE	NO STATIONS EFFECTED	09:38	09:54	00:16	TRIPPED ON FAULT
4964	28-Feb-24	MYSORE	66	LINE	BEGUR 220-HARAVE	NO STATIONS EFFECTED	10:24	10:34	00:10	TRIPPED ON FAULT
4965	28-Feb-24	MYSORE	66	LINE	BEGUR 220-SARGUR	ANTARSANTE_66YEREHALLIHAND POST_66 HDKOTE_66HAMPAPURA_66	09:38	09:49	00:11	TRIPPED ON FAULT
4966	28-Feb-24	MYSORE	66	LINE	BEGUR 220-SARGUR	ANTARSANTE_66YEREHALLIHAND POST_66 HDKOTE_66HAMPAPURA_66	10:24	10:58	00:34	TRIPPED ON FAULT
4967	28-Feb-24	MYSORE	66	LINE	BEGUR 220-SINDUVALLIPURA	SINDHUVALLI_66	09:38	09:44	00:06	TRIPPED ON FAULT
4968	28-Feb-24	MYSORE	66	LINE	BEGUR 220-SINDUVALLIPURA	SINDHUVALLI_66	10:24	10:32	00:08	TRIPPED ON FAULT
4969	28-Feb-24	MYSORE	66	LINE	BOGADHI-HOOTGALLY	NO STATIONS EFFECTED	10:45	11:18	00:33	LINE CLEAR AVAILED
4970	28-Feb-24	MYSORE	66	LINE	CHIKAMANDYA-HAMPAPURA	HAMPAPURA_66	06:37	06:47	00:10	TRIPPED ON FAULT
4971	28-Feb-24	MYSORE	66	LINE	CR NAGAR-CHANDAKAVADI	CHANDAKAVADI_66	09:38	09:45	00:07	TRIPPED ON FAULT
4972	28-Feb-24	MYSORE	66	LINE	CR NAGAR-CHANDAKAVADI	CHANDAKAVADI_66	10:24	10:33	00:08	TRIPPED ON FAULT
4973	28-Feb-24	MYSORE	66	LINE	CR NAGAR-DR PETE1	NO STATIONS EFFECTED	09:38	09:46	00:08	TRIPPED ON FAULT
4974	28-Feb-24	MYSORE	66	LINE	CR NAGAR-DR PETE1	NO STATIONS EFFECTED	10:24	10:35	00:10	TRIPPED ON FAULT
4975	28-Feb-24	MYSORE	66	LINE	CR NAGAR-HONGANUR	HONGANUR_66YELANDUR_66MAM BALLI_66	09:38	09:44	00:06	TRIPPED ON FAULT
4976	28-Feb-24	MYSORE	66	LINE	CR NAGAR-HONGANUR	HONGANUR_66YELANDUR_66MAM BALLI_66	10:24	10:34	00:09	TRIPPED ON FAULT
4977	28-Feb-24	MYSORE	66	LINE	CR NAGAR-KOLLEGALA	MUGUR_66 JAMMUR_66 THAYUR_66TNARSIPURA_66GARG ESHWARI_66	09:38	09:44	00:06	TRIPPED ON FAULT
4978	28-Feb-24	MYSORE	66	LINE	CR NAGAR-KOLLEGALA	MUGUR_66 JAMMUR_66 THAYUR_66TNARSIPURA_66GARG ESHWARI_66	10:24	10:32	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4979	28-Feb-24	MYSORE	66	LINE	CR NAGAR-KOLLEGALA	MUGUR_66 JAMMUR_66 THAYUR_66TNARSIPURA_66GARG ESHWARI_66	17:13	17:19	00:05	TRIPPED ON FAULT
4980	28-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
4981	28-Feb-24	MYSORE	66	LINE	HANNUR-KOTHUNUR	KOTHNUR_66	10:20	16:01	05:41	LINE CLEAR AVAILED
4982	28-Feb-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	CHIDRAVALLI_66BGPURA_66THU MBLA_66 VYSARAJAPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	23:01	23:12	00:11	TRIPPED ON FAULT
4983	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4984	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI- BANNIMANTAPA 1	FTS_66RAJEEVNAGARA_66BANNI MANTAPA_66	09:38	10:09	00:31	TRIPPED ON FAULT
4985	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI- BANNIMANTAPA 1	KHBCOLONY_66 DMGHALLI_66	10:24	10:42	00:17	TRIPPED ON FAULT
4986	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI- BANNIMANTAPA 2	FTS_66RAJEEVNAGARA_66BANNI MANTAPA_66	09:38	10:10	00:32	TRIPPED ON FAULT
4987	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI- BANNIMANTAPA 2	VIJAYANAGRAMYS_66	10:24	10:42	00:17	TRIPPED ON FAULT
4988	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	BOGADHI _66 KALAMANDIRA_66MYSORESOUTH _66	09:47	10:14	00:26	TRIPPED ON FAULT
4989	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	FTS_66RAJEEVNAGARA_66BANNI MANTAPA_66	10:33	10:49	00:15	TRIPPED ON FAULT
4990	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	KAGGERE HAMPAPURA_66DODDALLI_66	11:07	11:14	00:07	TRIPPED ON FAULT
4991	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-DATAGALLI	DATTAGALLY_66 RKNAGARA_66	09:38	10:14	00:36	TRIPPED ON FAULT
4992	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-DATAGALLI	FTS_66RAJEEVNAGARA_66BANNI MANTAPA_66	10:24	10:47	00:22	TRIPPED ON FAULT
4993	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-HAMPAPURA	KAGGERE HAMPAPURA_66DODDALLI_66	09:38	10:15	00:36	TRIPPED ON FAULT
4994	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-KHB COLONY	KHBCOLONY_66 DMGHALLI_66	09:38	10:11	00:33	TRIPPED ON FAULT
4995	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-KHB COLONY	BOGADHI _66 KALAMANDIRA_66MYSORESOUTH _66	10:24	10:48	00:24	TRIPPED ON FAULT
4996	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-VIJAYNAGARA	VIJAYANAGRAMYS_66	09:38	10:18	00:39	TRIPPED ON FAULT
4997	28-Feb-24	MYSORE	66	LINE	HOOTAGALLI-VIJAYNAGARA	DATTAGALLY_66 RKNAGARA_66	10:24	10:46	00:21	TRIPPED ON FAULT
4998	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	09:07	11:37	02:30	LINE CLEAR AVAILED
4999	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	DEVNUR(N'GUD)_66	11:50	14:15	02:25	LINE CLEAR AVAILED
5000	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	HOOTAGALLI_66	09:38	09:58	00:20	TRIPPED ON FAULT
5001	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	HOOTAGALLI_66	10:24	10:40	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5002	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	NANJANGUD_66	12:32	14:08	01:36	LINE CLEAR AVAILED
5003	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	VAJMANGALA_66	10:03	15:30	05:27	LINE CLEAR AVAILED
5004	28-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5005	28-Feb-24	MYSORE	66	TRANSFORMER	HV2	NANJANGUD_66	13:42	14:27	00:45	LINE CLEAR AVAILED
5006	28-Feb-24	MYSORE	66	TRANSFORMER	HV2	VAJMANGALA_66	10:50	12:16	01:26	LINE CLEAR AVAILED
5007	28-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
5008	28-Feb-24	MYSORE	66	LINE	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	09:38	10:13	00:35	TRIPPED ON FAULT
5009	28-Feb-24	MYSORE	66	LINE	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	10:24	10:36	00:11	TRIPPED ON FAULT
5010	28-Feb-24	MYSORE	66	LINE	KADAKOLA-MANTAKALLI	MANDAKALLI_66	09:38	10:13	00:35	TRIPPED ON FAULT
5011	28-Feb-24	MYSORE	66	LINE	KADAKOLA-MANTAKALLI	MANDAKALLI_66	10:24	10:36	00:11	TRIPPED ON FAULT
5012	28-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
5013	28-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)			TRIPPED ON FAULT
5014	28-Feb-24	MYSORE	66	LINE	KUSHALNAGARA-MADIKER1	MADIKER_66SUNTIKOPPA_66VIRAJPETE_66PONNAMPETE_66SRIMANGALA_66	20:18	21:25	01:07	TRIPPED ON FAULT
5015	28-Feb-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	MADIKER_66SUNTIKOPPA_66	22:50	23:34	00:44	LINE CLEAR AVAILED
5016	28-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	10:56	11:07	00:10	LINE CLEAR AVAILED
5017	28-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	11:15	21:23	10:07	LINE CLEAR AVAILED
5018	28-Feb-24	MYSORE	66	LINE	PERIAPATNA-HANGODU	SUNTIKOPPA_66VIRAJPETE_66PONNAMPETE_66SRIMANGALA_66	20:18	20:25	00:06	TRIPPED ON FAULT
5019	28-Feb-24	MYSORE	66	TRANSFORMER	SHANIVARSANTE-HV1	SHANIVARSANTE_6YESSLURU_66HETTUR_66	21:05	21:15	00:10	LINE CLEAR AVAILED
5020	28-Feb-24	MYSORE	66	TRANSFORMER	SHANIVARSANTE-HV1	SHANIVARSANTE_6YESSLURU_66HETTUR_66	21:20	23:05	01:45	LINE CLEAR AVAILED
5021	28-Feb-24	MYSORE	66	LINE	TUBINKERE-G UKKADA	PANDAVAPURA_66DODDABYADARAHALLI_66SRIRANGAPATNA_66BELAGOLA_66GARUDANAUKADDA_66BANANGADI_66	09:38	09:48	00:10	TRIPPED ON FAULT
5022	28-Feb-24	MYSORE	66	LINE	TUBINKERE-G UKKADA	PANDAVAPURA_66DODDABYADARAHALLI_66SRIRANGAPATNA_66BELAGOLA_66GARUDANAUKADDA_66BANANGADI_66	10:24	10:31	00:07	TRIPPED ON FAULT
5023	28-Feb-24	MYSORE	66	LINE	VAJMANGALA-MEGHALAPURA	MEGHALAPURA_66	09:38	09:45	00:07	TRIPPED ON FAULT
5024	28-Feb-24	MYSORE	66	LINE	VAJMANGALA-MEGHALAPURA	MEGHALAPURA_66	10:24	10:31	00:07	TRIPPED ON FAULT
5025	28-Feb-24	MYSORE	66	LINE	YELANDUR-CR NAGAR	NO STATIONS EFFECTED	11:49	20:04	08:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5026	28-Feb-24	MYSORE	220	TRANSFORMER	HOOTAGALLI-HV3	HOOTAGALLI_220	10:24	10:36	00:11	TRIPPED ON FAULT
5027	28-Feb-24	MYSORE	220	TRANSFORMER	HV3	HOOTAGALLI_220	09:38	10:05	00:26	TRIPPED ON FAULT
5028	28-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	STATIONS NOT INTERRUPTED	20:48	07:06	09:05	LINE CLEAR AVAILED
5029	28-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	21:16 (27/02/2024)	6:08:20 (28/02/2024)	8:52 HRs	LINE CLEAR AVAILED
5030	28-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48:48 (28/02/2024)			LINE CLEAR AVAILED
5031	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV - BENKIKERE66	BENKIKERE_66	16:00	16:12	00:12	TRIPPED ON FAULT
5032	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	13:24	14:10	00:46	LINE CLEAR AVAILED
5033	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	16:25	17:34	01:09	LINE CLEAR AVAILED
5034	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-CHANNAGIRI 66	CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	17:09	17:24	00:15	LINE CLEAR AVAILED
5035	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	08:08	08:17	00:09	TRIPPED ON FAULT
5036	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	09:00	09:05	00:05	TRIPPED ON FAULT
5037	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	16:16	16:41	00:25	LINE CLEAR AVAILED
5038	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	21:08	21:11	00:03	TRIPPED ON FAULT
5039	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-GOPPENAHALLI66	GOPPENAHALLI66	17:30	17:47	00:17	LINE CLEAR AVAILED
5040	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220KV-NALLUR 66	NALLUR_66	16:59	17:08	00:09	LINE CLEAR AVAILED
5041	28-Feb-24	TUMKUR	66	LINE	BENKIKERE 220--RAMAGIRI66	RAMAGIRI_66	10:25	17:55	07:30	LINE CLEAR AVAILED
5042	28-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:51	12:55	00:04	LINE CLEAR AVAILED
5043	28-Feb-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:58	13:06	00:08	LINE CLEAR AVAILED
5044	28-Feb-24	TUMKUR	66	LINE	HALURAMESWARA-MADURE220	HALURAMESWARA_66, HOSADURGA_66	10:00	18:00	08:00	MAIN SUPPLY FAILURE
5045	28-Feb-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	10:27	18:20	07:53	LINE CLEAR AVAILED
5046	28-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66,PDKOTE_66	03:28	03:38	00:10	TRIPPED ON FAULT
5047	28-Feb-24	TUMKUR	66	LINE	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66,PDKOTE_66	10:27	18:20	07:53	LINE CLEAR AVAILED
5048	28-Feb-24	TUMKUR	66	LINE	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:55	16:15	00:20	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5049	28-Feb-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	PANDRAHALLI_66	15:55	16:15	00:20	MAIN SUPPLY FAILURE
5050	28-Feb-24	TUMKUR	66	LINE	HOSADURGA220-BAGUR 66	BAGUR_66	10:25	17:45	07:20	LINE CLEAR AVAILED
5051	28-Feb-24	TUMKUR	66	LINE	HOSADURGA220-HALURAMESHWARA66	HALURAMESHWARA_66	10:15	17:45	07:30	LINE CLEAR AVAILED
5052	28-Feb-24	TUMKUR	66	LINE	HOSADURGA220-HOSADURGA 66	HOSADURGA_66	10:05	17:45	07:40	LINE CLEAR AVAILED
5053	28-Feb-24	TUMKUR	66	LINE	MADADAKERE_66-MADURE_220KV	MADADAKERE_66	10:00	18:00	08:00	MAIN SUPPLY FAILURE
5054	28-Feb-24	TUMKUR	66	LINE	MATHOD_66-GARAGA PANCHANAHALLI LINE	GARAGA PANCHANAHALLI_66	14:25	16:30	02:05	LINE CLEAR AVAILED
5055	28-Feb-24	TUMKUR	66	LINE	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,	15:57	16:15	00:18	TRIPPED ON FAULT
5056	28-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
5057	28-Feb-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE	PDKOTE_66	03:30	03:45	00:15	MAIN SUPPLY FAILURE
5058	28-Feb-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE	PDKOTE_66	09:42	09:48	00:06	MAIN SUPPLY FAILURE
5059	28-Feb-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE	PDKOTE_66	18:52	18:57	00:05	MAIN SUPPLY FAILURE
5060	28-Feb-24	TUMKUR	66	TRANSFORMER	TR(LV SIDE)	DAVANAGERE SRS_220	0.430555556	0.565277778	03:14	LINE CLEAR AVAILED
5061	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	BELLAVI_66	00:06	00:14	00:08	TRIPPED ON FAULT
5062	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HALURAMESWARA_66	02:00	02:10	00:10	TRIPPED ON FAULT
5063	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HALURAMESWARA_66	18:10	18:20	00:10	TRIPPED ON FAULT
5064	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	MADADKERE_66	08:30	08:35	00:05	TRIPPED ON FAULT
5065	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	RAMAPURA_66	10:05	10:10	00:05	TRIPPED ON FAULT
5066	28-Feb-24	TUMKUR	66	TRANSFORMER	TR1&TR2	HOSADURGA_66	10:00	17:50	07:50	MAIN SUPPLY FAILURE
5067	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	PDKOTE_66	00:05	00:10	00:05	TRIPPED ON FAULT
5068	28-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	RAMAPURA_66	09:40	15:50	06:10	LINE CLEAR AVAILED
5069	28-Feb-24	TUMKUR	220	LINE	BENKIKERE 220KV-HOSADURGA220 1	HOSADURGA_220	10:30	17:43	07:13	LINE CLEAR AVAILED
5070	28-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	12:18	18:02	05:44	LINE CLEAR AVAILED
5071	28-Feb-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	12:18	18:13	05:55	LINE CLEAR AVAILED
5072	28-Feb-24	TUMKUR	220	LINE	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	13:13	00:00	10:47	LINE CLEAR AVAILED
5073	28-Feb-24	TUMKUR	220	LINE	HOSADURGA220-BENKIKERE 220KV 1	HOSADURGA_220	10:25	17:50	07:25	LINE CLEAR AVAILED
5074	28-Feb-24	TUMKUR	220	LINE	HOSADURGA220-BENKIKERE 220KV 2	HOSADURGA_220	10:25	17:50	07:25	LINE CLEAR AVAILED
5075	28-Feb-24	TUMKUR	220	LINE	HOSADURGA220-BENKIKERE 220KV 2	HOSADURGA_220	10:25	17:50	07:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5076	28-Feb-24	TUMKUR	220	LINE	JAGALUR_400-CHITRADURGA220KV 2	CHITRADURGA_220	10:30	17:43	07:13	LINE CLEAR AVAILED
5077	28-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	DAVANAGERE SRS_220	0.430555556	0.565277778	03:14	LINE CLEAR AVAILED
5078	28-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	HOSADURGA_220	10:25	17:50	07:25	LINE CLEAR AVAILED
5079	28-Feb-24	TUMKUR	220	TRANSFORMER	TR-1(LV SIDE)	HOSADURGA_220	10:25	17:50	07:25	LINE CLEAR AVAILED
5080	28-Feb-24	TUMKUR	220	TRANSFORMER	TR-2(HV SIDE)	BENKIKERE_220	14:58	17:29	02:31	LINE CLEAR AVAILED
5081	28-Feb-24	TUMKUR	400	TRANSFORMER	ICT-2(HV SIDE)	GUTTUR_400	12:23	18:04	05:41	LINE CLEAR AVAILED
5082	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MURDESHWAR_110	11:42	12:05	00:23	LINE CLEAR AVAILED
5083	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BIDI_110	14:15	16:29	02:14	TRIPPED ON FAULT
5084	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SIRSI_110	16:06	16:50	00:44	LINE CLEAR AVAILED
5085	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KANABARGI LAYOUT_110	12:00	15:09	03:09	LINE CLEAR AVAILED
5086	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	ZALKI_110	14:54	14:59	00:05	TRIPPED ON FAULT
5087	29-Feb-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA)	MURDESHWAR_110	10:54	11:43	00:49	LINE CLEAR AVAILED
5088	29-Feb-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(INDI220)	STATION NOT AFFECTED ATHARGA_110	18:56 (14.02.2024)			LINE CLEAR AVAILED
5089	29-Feb-24	BAGALKOTE	110	LINE	GOPPANAKOPPA-MRUTHYUNJAYANAGAR1	STATION NOT AFFECTED GOPPANAKOPPA_110	14:17 (15.02.2023)			LINE CLEAR AVAILED
5090	29-Feb-24	BAGALKOTE	110	LINE	HAVERI220-HANGAL(TILUVALLI)	HAVERI_220	11:32	14:04	02:32	LINE CLEAR AVAILED
5091	29-Feb-24	BAGALKOTE	110	LINE	HIREBEVANUR-ROODAGI	HIREBEVANUR_110	11:05	11:10	00:05	TRIPPED ON FAULT
5092	29-Feb-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUD	STATION NOT AFFECTED HUBLI_220	10:31 (07.02.2024)			LINE CLEAR AVAILED
5093	29-Feb-24	BAGALKOTE	110	LINE	HUBLI220- TARIHAL1	STATION NOT AFFECTED HUBLI_220	8:23 (29.02.2024)			LINE CLEAR AVAILED
5094	29-Feb-24	BAGALKOTE	110	LINE	HUBLI220- TARIHAL2	STATION NOT AFFECTED HUBLI_220	8:23 (29.02.2024)			LINE CLEAR AVAILED
5095	29-Feb-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
5096	29-Feb-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- HIDIKAL	MAHALINGAPUR_220	15:04	15:41	00:37	TRIPPED ON FAULT
5097	29-Feb-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5098	29-Feb-24	BAGALKOTE	110	LINE	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
5099	29-Feb-24	BAGALKOTE	110	LINE	PH COMPOUND-HUBLI	PH COMPOUND_110	10:05 (07.02.2024)			LINE CLEAR AVAILED
5100	29-Feb-24	BAGALKOTE	110	LINE	SIRSI220- SIRSI1	STATION NOT AFFECTED SIRSI_220	10:54	14:45	03:51	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5101	29-Feb-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
5102	29-Feb-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
5103	29-Feb-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI3	STATION NOT AFFECTED HUBLI_220	10:48	13:23	02:35	LINE CLEAR AVAILED
5104	29-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
5105	29-Feb-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	16:23 (08.02.2024)			LINE CLEAR AVAILED
5106	29-Feb-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
5107	29-Feb-24	BENGALURU	66	LINE	66KV AVANI - KC VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
5108	29-Feb-24	BENGALURU	66	LINE	66KV BYADARAHALLI - KODIGEHALLI	SRIGANDA KAVALU, BYADARAHALLI	01:57	02:06	00:09	LINE CLEAR AVAILED
5109	29-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CB PURA I/A, CB PURA URBAN	07:12	07:37	00:25	LINE CLEAR AVAILED
5110	29-Feb-24	BENGALURU	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	CB PURA I/A	08:55	09:05	00:10	LINE CLEAR AVAILED
5111	29-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	06:58	07:06	00:08	LINE CLEAR AVAILED
5112	29-Feb-24	BENGALURU	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL, CESSNA(EHT)	06:25	06:30	00:05	MAIN SUPPLY FAILURE
5113	29-Feb-24	BENGALURU	66	LINE	66KV DG4_MANYATA 220 - BYATRAYANAPURA (L&T)	BYATARAYANAPURA	12:33	12:39	00:06	LINE CLEAR AVAILED
5114	29-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	18:45	19:13	00:28	TRIPPED ON FAULT
5115	29-Feb-24	BENGALURU	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	06:08	06:22	00:14	TRIPPED ON FAULT
5116	29-Feb-24	BENGALURU	66	LINE	66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1	KUNURU, HAROBELE, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNASENAHALLI	19:37	19:42	00:05	LINE CLEAR AVAILED
5117	29-Feb-24	BENGALURU	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	17:12	17:17	00:05	LINE CLEAR AVAILED
5118	29-Feb-24	BENGALURU	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	BEVOOR	12:58	13:08	00:10	TRIPPED ON FAULT
5119	29-Feb-24	BENGALURU	66	LINE	66KV SAHAKARANAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	14:14	14:24	00:10	LINE CLEAR AVAILED
5120	29-Feb-24	BENGALURU	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	12:20	12:46	00:26	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5121	29-Feb-24	BENGALURU	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	13:07	13:20	00:13	TRIPPED ON FAULT
5122	29-Feb-24	BENGALURU	66	LINE	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI	02:27	02:33	00:06	LINE CLEAR AVAILED
5123	29-Feb-24	BENGALURU	66	LINE	66KV TUBAGERE - CB PURA I/A 1	CB PURA I/A	07:41	08:58	01:17	LINE CLEAR AVAILED
5124	29-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	06:24	06:44	00:20	MAIN SUPPLY FAILURE
5125	29-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	06:24	06:44	00:20	MAIN SUPPLY FAILURE
5126	29-Feb-24	BENGALURU	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	06:24	06:44	00:20	MAIN SUPPLY FAILURE
5127	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SAHAKARINAGAR 66	12:15	12:20	00:05	TRIPPED ON FAULT
5128	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	M GOLLAHALLI	15:45	15:50	00:05	LINE CLEAR AVAILED
5129	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	GOWNIPALLI	15:10	15:25	00:15	TRIPPED ON FAULT
5130	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	TEKAL	07:50	08:14	00:24	TRIPPED ON FAULT
5131	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	T BEGUR	12:29	13:02	00:33	LINE CLEAR AVAILED
5132	29-Feb-24	BENGALURU	66	TRANSFORMER	HV1	SHIVANAHALLI	11:27	11:36	00:09	LINE CLEAR AVAILED
5133	29-Feb-24	BENGALURU	66	TRANSFORMER	HV2	K&C VALLEY	08:55	09:15	00:20	TRIPPED ON FAULT
5134	29-Feb-24	BENGALURU	66	TRANSFORMER	HV2	MAASTHI	16:40	16:50	00:10	LINE CLEAR AVAILED
5135	29-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SHIVANAHALLI	12:15	12:38	00:23	LINE CLEAR AVAILED
5136	29-Feb-24	BENGALURU	66	TRANSFORMER	HV2	SHIVANAHALLI	14:50	14:55	00:05	LINE CLEAR AVAILED
5137	29-Feb-24	BENGALURU	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	VIKAS TECH PARK 220, EXORA 220	06:24	06:52	00:28	TRIPPED ON FAULT
5138	29-Feb-2024	GULBARGA	66	TRANSFORMER	HV2	HARAPANAHALLI_66	07:00	07:55	00:55	TRIPPED ON FAULT
5139	29-Feb-2024	GULBARGA	110	LINE	HUMNABAD-ALAND	ALAND_110	19:09	19:24	00:15	TRIPPED ON FAULT
5140	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	07:23	07:33	00:10	TRIPPED ON FAULT
5141	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	10:00	10:37	00:37	TRIPPED ON FAULT
5142	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	12:25	13:25	01:00	TRIPPED ON FAULT
5143	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	TEKKALKOTE_110	20:10	20:23	00:13	TRIPPED ON FAULT
5144	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV1	GANGAVATI_110	15:35	15:50	00:15	TRIPPED ON FAULT
5145	29-Feb-2024	GULBARGA	110	TRANSFORMER	HV7	MUNIRBAD_220	16:40	17:33	00:53	LINE CLEAR AVAILED
5146	29-Feb-2024	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	19:12	19:27	00:15	TRIPPED ON FAULT
5147	29-Feb-2024	GULBARGA	110	LINE	KIADB KUDITINI-KURUGOD	KURUGOD_110	02:25	02:35	00:10	MAIN SUPPLY FAILURE
5148	29-Feb-2024	GULBARGA	110	LINE	SHAHBAD-FARTHABAD	FARTHABAD_110	12:35	13:08	00:33	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5149	29-Feb-2024	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	04:43	04:53	00:10	TRIPPED ON FAULT
5150	29-Feb-2024	GULBARGA	220	LINE	HALBARGA-HUMNABAD LINE-2	HUMANABAD_220	14:48	16:32	01:44	LINE CLEAR AVAILED
5151	29-Feb-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
5152	29-Feb-24	HASSAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
5153	29-Feb-24	HASSAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	00:00	00:15	00:15	LINE CLEAR AVAILED
5154	29-Feb-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	21:04	21:15	00:11	TRIPPED ON FAULT
5155	29-Feb-24	HASSAN	66	LINE	HNPR2-RNPR2	HNPUA_220	21:54	22:06	00:12	TRIPPED ON FAULT
5156	29-Feb-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
5157	29-Feb-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	09:45	14:20	04:35	MAIN SUPPLY FAILURE
5158	29-Feb-24	HASSAN	66	TRANSFORMER	HV2	ARAKALGUD_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
5159	29-Feb-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGAR_66	10:35	11:00	00:25	LINE CLEAR AVAILED
5160	29-Feb-24	HASSAN	66	TRANSFORMER	HV2	SHANTHIGRAMA_66	11:30	12:06	00:36	LINE CLEAR AVAILED
5161	29-Feb-24	HASSAN	66	TRANSFORMER	HV2	TAVARECHATNAHALLI_66	09:45	14:20	04:35	MAIN SUPPLY FAILURE
5162	29-Feb-24	HASSAN	66	LINE	LV2	MRSMSG_220	10:24	14:00	03:36	LINE CLEAR AVAILED
5163	29-Feb-24	HASSAN	66	LINE	LV3	MRSMSG_220	10:24	14:01	03:37	LINE CLEAR AVAILED
5164	29-Feb-24	HASSAN	66	LINE	LV4	MRSMSG_220	10:23	14:02	03:39	LINE CLEAR AVAILED
5165	29-Feb-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	09:43	14:21	04:38	LINE CLEAR AVAILED
5166	29-Feb-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPUA_66	10:15	18:05	07:50	LINE CLEAR AVAILED
5167	29-Feb-24	HASSAN	66	LINE	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	14:49	16:54	02:05	LINE CLEAR AVAILED
5168	29-Feb-24	HASSAN	66	LINE	TAVAREC-SHMG	TAVARECHATNAHALLI_66	09:45	14:20	04:35	MAIN SUPPLY FAILURE
5169	29-Feb-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	02:50	03:08	00:18	TRIPPED ON FAULT
5170	29-Feb-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	04:18	06:01	01:43	TRIPPED ON FAULT
5171	29-Feb-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	06:03	06:08	00:05	TRIPPED ON FAULT
5172	29-Feb-24	HASSAN	110	LINE	HIRIYA-KARKALA	HIRIYADKA_66	13:25	14:35	01:10	LINE CLEAR AVAILED
5173	29-Feb-24	HASSAN	110	TRANSFORMER	HV1	MSEZ_220	10:02	13:16	03:14	LINE CLEAR AVAILED
5174	29-Feb-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_66	11:37	14:15	02:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5175	29-Feb-24	HASSAN	110	LINE	MANIPAL-HIRIYADKA	MANIPAL_110	12:15	13:46	01:31	LINE CLEAR AVAILED
5176	29-Feb-24	HASSAN	220	LINE	GERSOPA-TALGUPA2	gen_gersoppa	13:55	14:25	00:30	TRIPPED ON FAULT
5177	29-Feb-24	HASSAN	220	LINE	MRSSHM-MYSRMUGLVL	MRSMSG_220	07:26	18:24	10:58	LINE CLEAR AVAILED
5178	29-Feb-24	HASSAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	13:55	14:24	00:29	TRIPPED ON FAULT
5179	29-Feb-24	MYSORE	66	LINE	BANNIMANTAPA-FTS-2	NO STATIONS EFFECTED	06:31	06:47	00:16	TRIPPED ON FAULT
5180	29-Feb-24	MYSORE	66	LINE	DEVNUR(MYS)-VAJAMANGALA	NO STATIONS EFFECTED	07:42	14:46	07:03	LINE CLEAR AVAILED
5181	29-Feb-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	RAJEEVNAGARA_66	06:30	06:51	00:21	TRIPPED ON FAULT
5182	29-Feb-24	MYSORE	66	LINE	GAVADGERE-K R NAGARA	BHERYA_66 BILIKERE_66 DMG_HALLI_66 GVGUDI_66 KRNAGARA_66 MIRLE_66 SALIGRAMA_66	08:56	09:12	00:16	TRIPPED ON FAULT
5183	29-Feb-24	MYSORE	66	LINE	HAMPAPURA-CHIKK MANDYA	NO STATIONS EFFECTED	22:07 (24/02/2024)			LINE CLEAR AVAILED
5184	29-Feb-24	MYSORE	66	LINE	HARADANAHALLI(JAK)-LAXJEET IPP	NO STATIONS EFFECTED	11:50	11:55	00:05	TRIPPED ON FAULT
5185	29-Feb-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
5186	29-Feb-24	MYSORE	66	LINE	HOOTAGALLI-KAGGERE-HAMPAPURA	KAGGERE HAMPAPURA_66	17:37	17:47	00:10	TRIPPED ON FAULT
5187	29-Feb-24	MYSORE	66	TRANSFORMER	HV1	KIRUGAVALU_66	10:42	12:39	01:57	LINE CLEAR AVAILED
5188	29-Feb-24	MYSORE	66	TRANSFORMER	HV1	MADIKERI_66	10:35	17:10	06:34	LINE CLEAR AVAILED
5189	29-Feb-24	MYSORE	66	TRANSFORMER	HV1	METAGALLY_66	04:47	07:05	02:17	LINE CLEAR AVAILED
5190	29-Feb-24	MYSORE	66	TRANSFORMER	HV1	SUNTIKOPPA_66	10:00	18:15	08:15	LINE CLEAR AVAILED
5191	29-Feb-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5192	29-Feb-24	MYSORE	66	TRANSFORMER	HV2	BEGUR_66	11:25	13:40	02:15	LINE CLEAR AVAILED
5193	29-Feb-24	MYSORE	66	TRANSFORMER	HV2	KIRUGAVALU_66	14:16	16:15	01:58	LINE CLEAR AVAILED
5194	29-Feb-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	10:35	17:10	06:35	LINE CLEAR AVAILED
5195	29-Feb-24	MYSORE	66	TRANSFORMER	HV2	METAGALLY_66	04:39	14:10	09:30	TRIPPED ON FAULT
5196	29-Feb-24	MYSORE	66	TRANSFORMER	HV2	SUNTIKOPPA_66	10:00	18:15	08:15	LINE CLEAR AVAILED
5197	29-Feb-24	MYSORE	66	TRANSFORMER	HV3	SFCSHIVA_66	10:15	12:43	02:28	LINE CLEAR AVAILED
5198	29-Feb-24	MYSORE	66	TRANSFORMER	HV5	SFCSIVA_66	18:40:00 (12/2/2024)			LINE CLEAR AVAILED
5199	29-Feb-24	MYSORE	66	LINE	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	08:40	08:52	00:11	TRIPPED ON FAULT
5200	29-Feb-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
5201	29-Feb-24	MYSORE	66	LINE	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	18:05			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5202	29-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-MYSORE-1	BHERYA_66 KRNAGARA_66 MIRLE_66 SALIGRAMA_66	08:52	09:06	00:14	TRIPPED ON FAULT
5203	29-Feb-24	MYSORE	66	LINE	KUSHALANAGARA 220-SUNTIKOPPA	SUNTIKOPPA_66	15:13 (21/02/2024)	18:39 (29/02/2024)	195:26 HRs	TRIPPED ON FAULT
5204	29-Feb-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	17:09	17:14	00:05	TRIPPED ON FAULT
5205	29-Feb-24	MYSORE	66	LINE	METAGALLI-HEBBAL	METAGALLY_66	04:39	06:03	01:23	TRIPPED ON FAULT
5206	29-Feb-24	MYSORE	66	LINE	METAGALLI-VIKRANTH	NO STATIONS EFFECTED	04:40	06:11	01:31	MAIN SUPPLY FAILURE
5207	29-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	07:25	08:38	01:13	LINE CLEAR AVAILED
5208	29-Feb-24	MYSORE	66	LINE	MYSORE SOUTH-BOGADHI	NO STATIONS EFFECTED	16:10	22:03	05:52	LINE CLEAR AVAILED
5209	29-Feb-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	15:23	15:36	00:12	TRIPPED ON FAULT
5210	29-Feb-24	MYSORE	66	LINE	TARIPURA-MHS	NO STATIONS EFFECTED	10:45	11:10	00:25	LINE CLEAR AVAILED
5211	29-Feb-24	MYSORE	66	LINE	YELANDURU-CR NAGARA	NO STATIONS EFFECTED	09:10	18:07	08:57	LINE CLEAR AVAILED
5212	29-Feb-24	MYSORE	66	LINE	YELANDURU-MADHUVANAHALLI	NO STATIONS EFFECTED	18:10			LINE CLEAR AVAILED
5213	29-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48			LINE CLEAR AVAILED
5214	29-Feb-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	20:48:48 (28/02/2024)	7:06 (29/02/2024)	10:17 HRs	LINE CLEAR AVAILED
5215	29-Feb-24	TUMKUR	66	LINE	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	08:38	08:46	00:08	TRIPPED ON FAULT
5216	29-Feb-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66,	10:20	10:30	00:10	TRIPPED ON FAULT
5217	29-Feb-24	TUMKUR	66	LINE	PANDRAHALLI2-HOLALKERE_66	PANDRAHALLI_66	08:30	08:50	00:20	TRIPPED ON FAULT
5218	29-Feb-24	TUMKUR	66	LINE	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
5219	29-Feb-24	TUMKUR	66	LINE	PULAMAGHATTA_66-MADHIGIRI	PULAMAGHATTA_66	21:30	21:35	00:05	LINE CLEAR AVAILED
5220	29-Feb-24	TUMKUR	66	LINE	THALLAK 220-DYAVARANAHALLI_66	DYAVARANAHALLI_66	06:20	06:34	00:14	TRIPPED ON FAULT
5221	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	ANCHEPALYA_66	05:50	06:05	00:15	TRIPPED ON FAULT
5222	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HAGALAWADI_66	00:01	00:09	00:08	TRIPPED ON FAULT
5223	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	HOSADURGA_66	09:25	09:30	00:05	TRIPPED ON FAULT
5224	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-1	CHITRAHALLI_66	13:10	13:40	00:30	LINE CLEAR AVAILED
5225	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	HALURAMESHWARA_66	14:40	14:50	00:10	TRIPPED ON FAULT
5226	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	HALURAMESHWARA_66	15:20	15:35	00:15	TRIPPED ON FAULT
5227	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	HALURAMESHWARA_66	17:10	17:20	00:10	TRIPPED ON FAULT
5228	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	KUKKAWADA_66,	11:32	11:37	00:05	TRIPPED ON FAULT
5229	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	P.D,KOTE_66	10:50	10:55	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
5230	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	PULAMAGHATTA_66	10:05	21:35	11:30	LINE CLEAR AVAILED
5231	29-Feb-24	TUMKUR	66	TRANSFORMER	TR-2	CHITRAHALLI_66	12:12	12:17	00:05	LINE CLEAR AVAILED