

400/220/110/66 kV TRANSMISSION INTERRUPTIONS LC, LS, MSF & FAULTS FOR THE MONTH OF JULY-2024

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TAKKALAKI_110	16:11	16:18	00:07	TRIPPED ON FAULT
2	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	13:50	15:31	01:41	LINE CLEAR AVAILED
3	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	15:37	15:46	00:09	LINE CLEAR AVAILED
4	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	16:11	16:41	00:30	LINE CLEAR AVAILED
5	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	17:07	18:07	01:00	LINE CLEAR AVAILED
6	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	18:14	18:18	00:04	LINE CLEAR AVAILED
7	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	14:40	15:06	00:26	LINE CLEAR AVAILED
8	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	HUKKERI_110	09:00	09:25	00:25	LINE CLEAR AVAILED
9	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	HUKKERI_110	09:30	14:28	04:58	LINE CLEAR AVAILED
10	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3(20MVA)	HUKKERI_110	14:31	14:54	00:23	LINE CLEAR AVAILED
11	01-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA)	HUKKERI_110	14:31	14:54	00:23	LINE CLEAR AVAILED
12	01-Jul-24	BAGALKOTE	110	LINE	ATHANI220- ATHANI	ATHANI_220	08:40	09:01	00:21	LINE CLEAR AVAILED
13	01-Jul-24	BAGALKOTE	110	LINE	ATHARGA-KNI SOLAR	ATHANI_110	04:03	04:45	00:42	TRIPPED ON FAULT
14	01-Jul-24	BAGALKOTE	110	LINE	HATTARAGI-HUKKERI(SANGAM SUGARS)	HATTARAGI_110	06:01	06:20	00:19	TRIPPED ON FAULT
15	01-Jul-24	BAGALKOTE	110	LINE	HIDIKAL DAM-GHATAPRABHA	HIDIKAL DAM_110	06:04	06:31	00:27	LINE CLEAR AVAILED
16	01-Jul-24	BAGALKOTE	110	LINE	ITNAL-RAIBAG(HIDIKAL)	ITNAL_110	10:16 (30.06.2024)	12:30 (01.07.2024)	26:14:00	LINE CLEAR AVAILED
17	01-Jul-24	BAGALKOTE	110	LINE	MAMADAPUR-SHIRBUR	MAMADAPUR(B)_110	05:27	05:37	00:10	TRIPPED ON FAULT
18	01-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
19	01-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
20	01-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
21	01-Jul-24	BAGALKOTE	110	LINE	UTTUR- MAHALINGPUR (RANNABELAGALI)	UTTUR_110	03:21	03:30	00:09	TRIPPED ON FAULT
22	01-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
23	01-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI	11:18 (29.06.2024)			LINE CLEAR AVAILED
24	01-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI	11:15 (29.06.2024)			LINE CLEAR AVAILED
25	01-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - KOPPAL LIS	BAGALKOT_220	16:05	18:41	02:36	LINE CLEAR AVAILED
26	01-Jul-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI2	STATION NOT AFFECTED BIDNAL_220	7:26 (27.06.2024)	19:54 (01.07.2024)	108:28:00	LINE CLEAR AVAILED
27	01-Jul-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	HUBLI_220	11:17	19:24	08:07	TRIPPED ON FAULT
28	01-Jul-24	BAGALKOTE	220	LINE	KARWAR-KADRA1	KARWAR_220	12:13	13:06	00:53	LINE CLEAR AVAILED
29	01-Jul-24	BAGALKOTE	220	LINE	NARENDRA-KANABARGI1	NARENDRA_220	12:40	15:00	02:20	LINE CLEAR AVAILED
30	01-Jul-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
31	01-Jul-24	BAGALKOTE	220	LINE	SOUDATTI-MAHALINGAPUR (BIDNAL2)	STATION NOT AFFECTED SOUDATTI_220	7:24 (27.06.2024)	19:54 (01.07.2024)	108:30:00	LINE CLEAR AVAILED
32	01-Jul-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	08:20	08:27	00:07	TRIPPED ON FAULT
33	01-Jul-24	BANGALORE	66	LINE	66KV DRDO - T D HALLI (MALLASANDRA)	MALLASANDRA	10:45	10:50	00:05	LINE CLEAR AVAILED
34	01-Jul-24	BANGALORE	66	LINE	66KV DRDO - T D HALLI (MALLASANDRA)	MALLASANDRA	13:05	13:25	00:20	LINE CLEAR AVAILED
35	01-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	HBR LAYOUT 66, LR BANDE	02:15	02:41	00:26	MAIN SUPPLY FAILURE
36	01-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - POTTERY ROAD	POTTERY ROAD	02:16	02:37	00:21	MAIN SUPPLY FAILURE
37	01-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR, PURVANKARA PALM BEACH	02:15	02:47	00:32	MAIN SUPPLY FAILURE
38	01-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - KEMBODI	KEMBODI	08:05	08:12	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
39	01-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	17:06	17:23	00:17	TRIPPED ON FAULT
40	01-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	18:28	18:30	00:02	TRIPPED ON FAULT
41	01-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	08:05	08:10	00:05	LINE CLEAR AVAILED
42	01-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	18:40	18:46	00:06	LINE CLEAR AVAILED
43	01-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - BYATARAYANAPURA (L&T) _DG4	BYATARAYANAPURA	02:15	02:47	00:32	MAIN SUPPLY FAILURE
44	01-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66 _DG3	MANYATHA 66	02:16	03:09	00:53	MAIN SUPPLY FAILURE
45	01-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY _DG3	SHOBHA CITY	02:15	02:47	00:32	MAIN SUPPLY FAILURE
46	01-Jul-24	BANGALORE	66	LINE	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 1 (VELANKANI)	ELECTRONIC CITY PH2 SEC 1	12:36	14:20	01:44	TRIPPED ON FAULT
47	01-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGAR	11:07	11:15	00:08	TRIPPED ON FAULT
48	01-Jul-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGAR	11:06	11:14	00:08	TRIPPED ON FAULT
49	01-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	18:15	18:18	00:03	LINE CLEAR AVAILED
50	01-Jul-24	BANGALORE	66	LINE	66KV SOMENAHALLI - NALLIMARADANAHALLI	NALLIMARADANAHALLI	18:05	18:20	00:15	LINE CLEAR AVAILED
51	01-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, BEML, KAMASAMUDRA, BANGARPETE	15:09	15:20	00:11	TRIPPED ON FAULT
52	01-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, BEML, KAMASAMUDRA, BANGARPETE	15:10	15:22	00:12	TRIPPED ON FAULT
53	01-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:01	10:13	00:12	LINE CLEAR AVAILED
54	01-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	18:01	18:08	00:07	LINE CLEAR AVAILED
55	01-Jul-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI) _DG4	HENNUR, PURVANKARA PALM BEACH	06:14	06:17	00:03	LINE CLEAR AVAILED
56	01-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA, INFOSYS	14:14	14:47	00:33	TRIPPED ON FAULT
57	01-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA, INFOSYS	15:25	15:35	00:10	LINE CLEAR AVAILED
58	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	02:15	02:27	00:12	MAIN SUPPLY FAILURE
59	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	EPIP 220	00:50	01:00	00:10	TRIPPED ON FAULT
60	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	06:28	06:38	00:10	TRIPPED ON FAULT
61	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	16:30	16:35	00:05	TRIPPED ON FAULT
62	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KAMASAMUDRA	14:15	14:25	00:10	LINE CLEAR AVAILED
63	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	07:30	07:35	00:05	LINE CLEAR AVAILED
64	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SOMENAHALLI	12:55	13:00	00:05	LINE CLEAR AVAILED
65	01-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	15:25	15:36	00:11	TRIPPED ON FAULT
66	01-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KAMASAMUDRA	14:00	14:10	00:10	LINE CLEAR AVAILED
67	01-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	06:36	06:40	00:04	LINE CLEAR AVAILED
68	01-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	13:45	13:46	00:01	LINE CLEAR AVAILED
69	01-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	07:30	07:35	00:05	LINE CLEAR AVAILED
70	01-Jul-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	02:15	02:27	00:12	MAIN SUPPLY FAILURE
71	01-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	MANYATHA 220, HBR LAYOUT 220	02:15	02:41	00:26	TRIPPED ON FAULT
72	01-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - SAHAKARNAGAR 220	HBR LAYOUT 220	02:15	02:44	00:29	TRIPPED ON FAULT
73	01-Jul-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	18:34	23:59	05:25	TRIPPED ON FAULT
74	1-Jul-2024	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	01:25	01:35	00:10	TRIPPED ON FAULT
75	1-Jul-2024	GULBARGA	110	LINE	KAPNOOR-MAHAGOAN	MAHAGOAN_110	10:30	12:00	01:30	LINE CLEAR AVAILED
76	1-Jul-2024	GULBARGA	110	LINE	KHANAPUR-RAILWAY	KHANAPUR_110	01:15	01:20	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
77	1-Jul-2024	GULBARGA	110	LINE	MALLAPURA-MUNIRABAD	MALLAPURA_110	12:25	13:22	00:57	MAIN SUPPLY FAILURE
78	1-Jul-2024	GULBARGA	110	LINE	MANDEWAL-YADRAMI	YADRAMI_110	00:39	01:01	00:22	MAIN SUPPLY FAILURE
79	1-Jul-2024	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110, GABUR_110	04:55	05:08	00:13	TRIPPED ON FAULT
80	1-Jul-2024	GULBARGA	110	LINE	SHAHBAD-JEEWARGI	JEEWARGI_110	02:03	02:10	00:07	MAIN SUPPLY FAILURE
81	1-Jul-2024	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	19:20	19:30	00:10	TRIPPED ON FAULT
82	1-Jul-2024	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	19:50	19:55	00:05	TRIPPED ON FAULT
83	1-Jul-2024	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	02:34	02:39	00:05	TRIPPED ON FAULT
84	1-Jul-2024	GULBARGA	220	LINE	ALLIPUR-RAGALPADU	ALLIPUR_220	06:50	23:59	17:09	LINE CLEAR AVAILED
85	1-Jul-2024	GULBARGA	220	TRANSFORMER	HV1	MUNIRABAD_220	12:24	13:08	00:44	TRIPPED ON FAULT
86	1-Jul-2024	GULBARGA	220	TRANSFORMER	HV2	MUNIRABAD_220	12:24	13:55	01:31	TRIPPED ON FAULT
87	1-Jul-2024	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
88	01-Jul-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	07:45	09:10	01:25	MAIN SUPPLY FAILURE
89	01-Jul-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	11:10	11:25	00:15	MAIN SUPPLY FAILURE
90	01-Jul-24	HASSAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	07:45	09:10	01:25	MAIN SUPPLY FAILURE
91	01-Jul-24	HASSAN	66	LINE	ARAKAL-MALLIPATNA	ARAKALGUD_66	11:10	11:25	00:15	MAIN SUPPLY FAILURE
92	01-Jul-24	HASSAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLY-66	12:25	12:40	00:15	TRIPPED ON FAULT
93	01-Jul-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	07:43	09:26	01:43	TRIPPED ON FAULT
94	01-Jul-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMENAHALLY_66	02:15	02:20	00:05	TRIPPED ON FAULT
95	01-Jul-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMENAHALLY_66	06:05	06:10	00:05	TRIPPED ON FAULT
96	01-Jul-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	19:24	19:38	00:14	TRIPPED ON FAULT
97	01-Jul-24	HASSAN	66	LINE	MRSSHM-DVG2	MRSMSG_220	06:36	06:56	00:20	TRIPPED ON FAULT
98	01-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	15:35	15:38	00:03	LINE CLEAR AVAILED
99	01-Jul-24	HASSAN	110	TRANSFORMER	HV1	KARKALA_110	13:06	13:31	00:25	TRIPPED ON FAULT
100	01-Jul-24	HASSAN	110	TRANSFORMER	HV2	BRAHMAVARA_110	19:49	20:05	00:16	TRIPPED ON FAULT
101	01-Jul-24	HASSAN	110	LINE	KADUR-NAGENAHLI	KADUR_220	11:53	12:45	00:52	TRIPPED ON FAULT
102	01-Jul-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	18:42	18:54	00:12	LINE CLEAR AVAILED
103	01-Jul-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:42	18:54	00:12	LINE CLEAR AVAILED
104	01-Jul-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	18:42	18:54	00:12	LINE CLEAR AVAILED
105	01-Jul-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	18:42	18:54	00:12	LINE CLEAR AVAILED
106	01-Jul-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	18:42	18:54	00:12	LINE CLEAR AVAILED
107	01-Jul-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gerusoppa	13:35(28.6.2024)	16:42(01.07.2024)	75:07HRS	LINE CLEAR AVAILED
108	01-Jul-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gerusoppa	17:22(1.07.2024)			TRIPPED ON FAULT
109	01-Jul-24	HASSAN	220	LINE	HGUNJE-VARAH	HEGGUNJE_220	10:27	12:57	02:30	LINE CLEAR AVAILED
110	01-Jul-24	HASSAN	220	LINE	MRSSHM-STRP1	MRSMSG_220	13:35(28.6.2024)	16:36(01.07.2024)	75:01HRS	LINE CLEAR AVAILED
111	01-Jul-24	HASSAN	220	LINE	MRSSHM-STRP1	MRSMSG_220	17:22(01.07.2024)			TRIPPED ON FAULT
112	01-Jul-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	20:46	20:56	00:10	TRIPPED ON FAULT
113	01-Jul-24	HASSAN	220	LINE	SHRAVITY-SHIRALKOPPA	gen_sharavaty	18:41(01.07.2024)			TRIPPED ON FAULT
114	01-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	18:41(01.07.2024)			TRIPPED ON FAULT
115	01-Jul-24	HASSAN	220	LINE	VARAH-KEMAR2	gen_varahi	20:57	21:12	00:15	TRIPPED ON FAULT
116	01-Jul-24	HASSAN	220	LINE	VARAH-KEMAR3	gen_varahi	10:27	12:57	02:30	LINE CLEAR AVAILED
117	1-Jul-24	MYSORE	66	LINE	BADANGUPPE-GRASIM	NO STATIONS EFFECTED	03:50	03:55	00:05	TRIPPED ON FAULT
118	1-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
119	1-Jul-24	MYSORE	66	LINE	HDKOTE-TARAKA	NO STATIONS EFFECTED	11:01	11:04	00:03	TRIPPED ON FAULT
120	1-Jul-24	MYSORE	66	LINE	HEBBANI-SFC 9	NO STATIONS EFFECTED	06:02	06:25	00:23	TRIPPED ON FAULT
121	1-Jul-24	MYSORE	66	LINE	HEBBANI-SIMSHA	NO STATIONS EFFECTED	11:45	17:01	05:16	LINE CLEAR AVAILED
122	1-Jul-24	MYSORE	66	LINE	HOOTGALLY-KHB	KHB_66 DMGHALLI_66	02:55	03:25	00:30	TRIPPED ON FAULT
123	1-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
124	1-Jul-24	MYSORE	66	TRANSFORMER	HV2	BGNAGAR_66	15:45	16:15	00:30	LINE CLEAR AVAILED
125	1-Jul-24	MYSORE	66	TRANSFORMER	HV2	BYLUKUPPE_66	14:10	14:50	00:40	LINE CLEAR AVAILED
126	1-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
127	1-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-DODDINDUNDI	DODDINDUVADI_66	18:40	19:04	00:24	TRIPPED ON FAULT
128	1-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
129	1-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
130	1-Jul-24	MYSORE	66	LINE	MANDAKALLI-KADAKOLA	NO STATIONS EFFECTED	07:14	07:27	00:13	TRIPPED ON FAULT
131	1-Jul-24	MYSORE	66	LINE	MYSORESOUTH-BOGADHI	NO STATIONS EFFECTED	03:28	06:06	02:38	LINE CLEAR AVAILED
132	1-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
133	1-Jul-24	MYSORE	66	LINE	PERIAPATNA-HANGUD	NO STATIONS EFFECTED	10:32	14:38	04:06	LINE CLEAR AVAILED
134	1-Jul-24	MYSORE	66	LINE	SATHESARGUR-HAMPAPURA	HDKOTE_66 ANTARSANTE_66 YEREHALLIHANDPOST_66	05:50	05:57	00:07	TRIPPED ON FAULT
135	1-Jul-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	06:17	06:27	00:10	TRIPPED ON FAULT
136	1-Jul-24	MYSORE	220	LINE	HUNSUR 220-BASTIPURA1	NO STATIONS EFFECTED	02:53	08:39	05:46	TRIPPED ON FAULT
137	1-Jul-24	MYSORE	220	LINE	KADAKOLA-ADAKANAHLLI 1	NO STATIONS EFFECTED	02:52	08:30	05:38	TRIPPED ON FAULT
138	1-Jul-24	MYSORE	220	LINE	KADAKOLA-ADAKANAHLLI 1	NO STATIONS EFFECTED	10:25	13:21	02:56	LINE CLEAR AVAILED
139	1-Jul-24	MYSORE	220	LINE	KADAKOLA-ADAKANAHLLI 2	NO STATIONS EFFECTED	02:52	08:10	05:18	TRIPPED ON FAULT
140	1-Jul-24	MYSORE	220	LINE	KADAKOLA-BASTIPURA1	DEVANOGURMYS_66 DEVANOORNGUDU_66 JAYAPURA_66 HURA_66 HULLALI_66 NANJANGUD_66 THANDYA_66 HANNUR_66 LOKKANHALLI_66 PGPALYA_66 HONGANUR_66 YELANDUR_66 MAMBALLI_66 KOLLEGALA_66 AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66 KUNTHUR_66 JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYURU_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66 B MATKERE_66, SANTHESARAGUR_66 YERALLI HAND POST_66 ARKALVADI_66 ATTIGULIPURA_66 BADANAGUPPE_66 GUNDULPET_66 HARVEY_66 HEMMARGALA_66 HONNALY_MYS_66 KADABALLY_66 KARYA_66 KIRUGAVALU_66 RANDEKALHUNDI_66	02:52	08:20	05:28	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
141	1-Jul-24	MYSORE	220	LINE	KADAKOLA-BASTIPURA2	DEVANOORNGUDU_66 JAYAPURA_66 HURA_66 HULLALI_66 NANJANGUD_66 THANDYA_66 HANNUR_66 LOKKANHALLI_66 PGPALYA_66 HONGANUR_66 YELANDUR_66 MAMBALLI_66 KOLLEGALA_66 AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66 KUNTHUR_66 JANNUR_66 MUGUR_66 SANTHEMARAHALLI_66 TNARASIPURA_66 THAYURU_66 ANTHARSANTHE_66 HAMPAPURA(K)_66 HDKOTE_66 JAIPUR_66 B MATKERE_66, SANTHESARAGUR_66 YERALLI HAND POST_66 ARKALVADI_66 ATTIGULIPURA_66 BADANAGUPPE_66 GUNDULPET_66 HARVEY_66 HEMMARGALA_66 HONNALY_MYS_66 KADABALLY_66 KARYA_66 KIRUGAVALU_66 BANDYADAHALLI_66	02:52	08:25	05:33	TRIPPED ON FAULT
142	1-Jul-24	TUMKUR	66	TRANSFORMER	100MVA TRANSFORMER-2-220KV MADHUGIRI	66KV NITARAHALLI, BADAVANAHALLI,MADHUGIRI,MIDIGESHI	16:36	16:53	00:17	TRIPPED ON FAULT
143	1-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	11:23	13:50	02:27	TRIPPED ON FAULT
144	1-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-MALLADIHALLI	MALLADIHALLI_66	15:32	15:54	00:22	LINE CLEAR AVAILED
145	1-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	09:39	17:24	07:45	LINE CLEAR AVAILED
146	1-Jul-24	TUMKUR	66	LINE	MADHUGIRI 220KV- MADHUGIRI LINE-1	MADHUGIRI_66, BADAVANAHALLI_66	16:48	16:56	00:08	LINE CLEAR AVAILED
147	1-Jul-24	TUMKUR	66	LINE	MADHUGIRI 220KV- MEDIGESHI LINE-1&LINE-2	MEDIGESHI_66	16:48	16:54	00:06	TRIPPED ON FAULT
148	1-Jul-24	TUMKUR	66	LINE	MADHUGIRI 220KV- NITRAHALLI	NITRAHALLI_66	16:48	16:55	00:07	LINE CLEAR AVAILED
149	1-Jul-24	TUMKUR	66	LINE	MADHUGIRI_220-MIDIGESHI_66-2 LINE (IDLE LINE)	MEDIGESHI_66	16:36	16:53	00:17	TRIPPED ON FAULT
150	1-Jul-24	TUMKUR	66	LINE	PANDRAHALLI -HOLALKERE LINE -1-CHICKJAJUR	66KVHOLALKERE, CHICKJAJUR SASALUHALLA	17:45	18:25	00:40	TRIPPED ON FAULT
151	1-Jul-24	TUMKUR	66	LINE	SHYAGALE_66-KEREBILCHI_66	Water Works	15:20	15:35	00:15	TRIPPED ON FAULT
152	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-1	MADHUGIRI_66KV	05:25	05:34	00:09	TRIPPED ON FAULT
153	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5MVA	HARIYABBE_66	16:05	16:10	00:05	TRIPPED ON FAULT
154	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5MVA	HOSADURGA_66	23:00	23:10	00:10	TRIPPED ON FAULT
155	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5MVA	PAVAGADA_66	18:25	18:30	00:05	TRIPPED ON FAULT
156	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-8MVA	CHANNAGIRI_66	21:10	21:16	00:06	TRIPPED ON FAULT
157	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 (LVSIDE)	MADHUGIRI_66KV	16:36	16:50	00:14	TRIPPED ON FAULT
158	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-8MVA	HARIYABBE_66	16:50	17:05	00:15	TRIPPED ON FAULT
159	1-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-8MVA	KALMARANAHALLI_66	11:05	11:10	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
160	1-Jul-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	JAGALUR_66,BIDARKERE_66	19:18	19:40	00:22	LINE CLEAR AVAILED
161	1-Jul-24	TUMKUR	220	TRANSFORMER	TR-2(HVSIDE)	MADHUGIRI_220	16:36	16:50	00:14	TRIPPED ON FAULT
162	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MUKARTIHAL_110	10:58	11:01	00:03	TRIPPED ON FAULT
163	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RAMANKOPPA_110	14:12	15:00	00:48	TRIPPED ON FAULT
164	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	BAGALKOT_110	12:37	13:00	00:23	LINE CLEAR AVAILED
165	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MALGHAN(S)_110	06:29	06:35	00:06	TRIPPED ON FAULT
166	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MALGHAN(S)_110	08:13	08:22	00:09	TRIPPED ON FAULT
167	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	ITANAL_110	14:08	14:44	00:36	LINE CLEAR AVAILED
168	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	LOKAPUR_110	09:24	09:31	00:07	TRIPPED ON FAULT
169	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	LOKAPUR_110	18:09	18:16	00:07	TRIPPED ON FAULT
170	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MALGHAN(S)_110	08:13	08:22	00:09	TRIPPED ON FAULT
171	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	MUNDARGI_110	17:12	17:21	00:09	TRIPPED ON FAULT
172	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1	CHIKODI_220	21:55	22:00	00:05	TRIPPED ON FAULT
173	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1	MK HUBLI_220	08:40	08:55	00:15	TRIPPED ON FAULT
174	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1	MK HUBLI_220	14:25	14:45	00:20	TRIPPED ON FAULT
175	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1(20MVA)	CHIKKODI_110	21:55	22:04	00:09	TRIPPED ON FAULT
176	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GAJENDRAGAD_110	14:23	14:47	00:24	TRIPPED ON FAULT
177	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2	GANESHGUDI_110	12:13	12:20	00:07	TRIPPED ON FAULT
178	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	SINDAGI_110	17:00	17:32	00:32	LINE CLEAR AVAILED
179	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	SINDAGI_110	18:30	18:51	00:21	TRIPPED ON FAULT
180	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	SINDAGI_110	19:59	20:03	00:04	TRIPPED ON FAULT
181	02-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	SINDAGI_110	22:04	22:07	00:03	TRIPPED ON FAULT
182	02-Jul-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(RAILWAY LINE)	ATHARGA_110	15:20	15:48	00:28	TRIPPED ON FAULT
183	02-Jul-24	BAGALKOTE	110	LINE	GADAG-GADAG1(BETAGERI)	GADAG_220	11:52	11:58	00:06	LINE CLEAR AVAILED
184	02-Jul-24	BAGALKOTE	110	LINE	HIDIKAL DAM- GHATAPRABHA	HIDIKAL DAM_110	21:16	21:42	00:26	LINE CLEAR AVAILED
185	02-Jul-24	BAGALKOTE	110	LINE	ITANAL- RAIBAG2(KABBUR1)	ITANAL_110	11:08	12:33	01:25	LINE CLEAR AVAILED
186	02-Jul-24	BAGALKOTE	110	LINE	MK HUBLI-HIREBAGEWADI	MK HUBLI_220	00:44	01:03	00:19	TRIPPED ON FAULT
187	02-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
188	02-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
189	02-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
190	02-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)	15:34 (02.07.2024)	3551:50:00	LINE CLEAR AVAILED
191	02-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	SOUNDATTI_220	14:13	15:25	01:12	LINE CLEAR AVAILED
192	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NAGJHARI-1	AMBEWADI_220	14:19	14:43	00:24	LINE CLEAR AVAILED
193	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NAGJHARI-2	AMBEWADI_220	12:49	14:10	01:21	LINE CLEAR AVAILED
194	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA1	AMBEWADI_220	14:22	14:45	00:23	LINE CLEAR AVAILED
195	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA2	AMBEWADI_220	08:43	14:11	05:28	LINE CLEAR AVAILED
196	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI	11:18 (29.06.2024)			LINE CLEAR AVAILED
197	02-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI	11:15 (29.06.2024)			LINE CLEAR AVAILED
198	02-Jul-24	BAGALKOTE	220	LINE	BIDNAL-SOUDATTI1	BIDNAL_220	8:03	12:47	04:44	LINE CLEAR AVAILED
199	02-Jul-24	BAGALKOTE	220	LINE	BIDNAL-SOUDATTI1	BIDNAL_220	14:34	19:07	04:33	LINE CLEAR AVAILED
200	02-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	10:02 (12.03.2024)	19:0 (2.07.2024)	2696:58:00	LINE CLEAR AVAILED
201	02-Jul-24	BAGALKOTE	220	LINE	MUGALKHOD-ITNAL-1	MUGALKHOD_220	11:07	12:32	01:25	LINE CLEAR AVAILED
202	02-Jul-24	BAGALKOTE	220	LINE	MUGALKHOD-RAIBAG-1	MUGALKHOD_220	11:46	14:05	02:19	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
203	02-Jul-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)	20:05 (02.07.2024)	2697:59:00	LINE CLEAR AVAILED
204	02-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL	SOUNDATTI_220	08:01	12:48	04:47	LINE CLEAR AVAILED
205	02-Jul-24	BANGALORE	66	LINE	220KV HOODY 220 - RAILWAYS 2	BANGARPETE RAILWAY TRACTION	09:04	15:40	06:36	LINE CLEAR AVAILED
206	02-Jul-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	ADUGODI	14:08	14:21	00:13	TRIPPED ON FAULT
207	02-Jul-24	BANGALORE	66	LINE	66KV HSR 220 - JAKKASANDRA	JAKKASANDRA	14:08	14:30	00:22	TRIPPED ON FAULT
208	02-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	NO STATION AFFECTED	13:03	13:49	00:46	TRIPPED ON FAULT
209	02-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:03	10:20	00:17	LINE CLEAR AVAILED
210	02-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	18:17	18:22	00:05	LINE CLEAR AVAILED
211	02-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRLCE	13:00	13:10	00:10	TRIPPED ON FAULT
212	02-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	06:52	06:57	00:05	TRIPPED ON FAULT
213	02-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DASHAVARA	14:15	14:20	00:05	TRIPPED ON FAULT
214	02-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	08:36	08:47	00:11	LINE CLEAR AVAILED
215	02-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANDINI LAYOUT	12:06	12:11	00:05	LINE CLEAR AVAILED
216	02-Jul-24	BANGALORE	220	LINE	220KV HOODY 220 - RAILWAYS 1	BANGARPETE RAILWAY TRACTION	09:04	15:40	06:36	LINE CLEAR AVAILED
217	02-Jul-24	GULBARGA	66	LINE	BADALADUKU-CJHALLI	CJHALLI_66,HOSAHALLI_66,HUDEM	22:20	22:25	00:05	TRIPPED ON FAULT
218	02-Jul-24	GULBARGA	66	LINE	BADALADUKU-HOSAHALLI	HOSAHALLI_66,HUDEM	22:20	22:25	00:05	TRIPPED ON FAULT
219	02-Jul-24	GULBARGA	66	LINE	BADALADUKU-HUDEM	HUDEM	22:20	22:25	00:05	TRIPPED ON FAULT
220	02-Jul-24	GULBARGA	66	TRANSFORMER	HV3	KUDALGI_220	05:35	05:40	00:05	TRIPPED ON FAULT
221	02-Jul-24	GULBARGA	110	LINE	CHITAPUR-SHAHBAD	CHITAPUR_110,KORWAR_110	21:30	21:50	00:20	MAIN SUPPLY FAILURE
222	02-Jul-24	GULBARGA	110	LINE	HUMNABAD-BHALKI	BHALKI_110	20:40	20:55	00:15	TRIPPED ON FAULT
223	02-Jul-24	GULBARGA	110	TRANSFORMER	HV1	SRIRAMNAGARA_110	14:55	15:00	00:05	TRIPPED ON FAULT
224	02-Jul-24	GULBARGA	110	TRANSFORMER	HV3	ALLIPUR_220	09:15	09:22	00:07	TRIPPED ON FAULT
225	02-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	SANOTHI_110	05:21	05:31	00:10	TRIPPED ON FAULT
226	02-Jul-24	GULBARGA	110	LINE	KORWAR-SHAHBAD	CHITAPUR_110,KORWAR_110	21:30	21:50	00:20	MAIN SUPPLY FAILURE
227	02-Jul-24	GULBARGA	110	LINE	SANTHAPUR-HALBARGA	SANTHAPUR_110	22:25	22:35	00:10	TRIPPED ON FAULT
228	02-Jul-24	GULBARGA	110	LINE	SHAHPUR-NAGNOOR	NAGNOOR_110	03:08	03:14	00:06	TRIPPED ON FAULT
229	02-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	SR NAGAR_110, KARATAGI_110	03:30	03:45	00:15	TRIPPED ON FAULT
230	02-Jul-24	GULBARGA	110	LINE	TORANGALU-ALLIPUR	TORANGALU_110, METRI_110, YAMIGNUR_110	10:30	14:15	03:45	LINE CLEAR AVAILED
231	02-Jul-24	GULBARGA	110	LINE	WALKAMDINI-MALLAT	WALKAMDINI_110	13:30	13:35	00:05	MAIN SUPPLY FAILURE
232	02-Jul-24	GULBARGA	220	LINE	KAPNOOR-SHAHBAD	SHAHBAD_220	23:00	23:42	00:42	TRIPPED ON FAULT
233	02-Jul-24	GULBARGA	220	LINE	KUDALAGI-CYCLIC_IPP	KUDALGI_220	10:25	10:45	00:20	TRIPPED ON FAULT
234	02-Jul-24	GULBARGA	220	LINE	KUDALAGI-CYCLIC_IPP	KUDALGI_220	13:25	14:00	00:35	TRIPPED ON FAULT
235	02-Jul-24	GULBARGA	220	LINE	LINGASUGUR-BASAVANABAGEWADI2	LINGASUGUR_220	14:22	14:47	00:25	TRIPPED ON FAULT
236	02-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	13:10	13:19	00:09	TRIPPED ON FAULT
237	02-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
238	02-Jul-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	05:55	06:10	00:15	TRIPPED ON FAULT
239	02-Jul-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	07:05	07:15	00:10	TRIPPED ON FAULT
240	02-Jul-24	HASSAN	66	TRANSFORMER	HV2	SINGAPURA_66	11:40	13:01	01:21	LINE CLEAR AVAILED
241	02-Jul-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	08:50	09:18	00:28	TRIPPED ON FAULT
242	02-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA-66	07:27	19:01	11:34	LINE CLEAR AVAILED
243	02-Jul-24	HASSAN	110	LINE	DMKURK-HONNAVALI	DMKURKE_110	10:05	13:50	03:45	LINE CLEAR AVAILED
244	02-Jul-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	06:39	06:45	00:06	LINE CLEAR AVAILED
245	02-Jul-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	10:05	13:50	03:45	LINE CLEAR AVAILED
246	02-Jul-24	HASSAN	110	TRANSFORMER	HV1	MADHUVANA_110	04:54	06:00	01:06	TRIPPED ON FAULT
247	02-Jul-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	10:05	13:50	03:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
248	02-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	02:56	03:03	00:07	TRIPPED ON FAULT
249	02-Jul-24	HASSAN	110	LINE	MADHUV-BRK_HRD CBreaker	MADHUVANA_110	04:54	06:00	01:06	TRIPPED ON FAULT
250	02-Jul-24	HASSAN	110	LINE	MADHUV-HIRIYADKA	MADHUVANA_110	04:54	06:00	01:06	TRIPPED ON FAULT
251	02-Jul-24	HASSAN	220	LINE	ARSK2-HSN	ARSIKERE_220	11:14	13:30	02:16	TRIPPED ON FAULT
252	02-Jul-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gerusoppa	17:22(1.07.2024)	17:57(02.07.2024)	24:31HRS	LINE CLEAR AVAILED
253	02-Jul-24	HASSAN	220	LINE	HBNHL-L2	HEBBANAHALLY_220	10:12	15:02	04:50	LINE CLEAR AVAILED
254	02-Jul-24	HASSAN	220	LINE	MRSSHM-STRP1	MRSMSG_220	17:22(1.07.2024)	17:52(02.07.2024)	24:26HRS	LINE CLEAR AVAILED
255	02-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMSG_220	18:03	19:46	01:43	TRIPPED ON FAULT
256	02-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavaty	18:41(01.07.2024)	10:45(02.07.2024)	16:04HRS	TRIPPED ON FAULT
257	02-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	18:41(01.07.2024)	10:45(02.07.2024)	16:04HRS	LINE CLEAR AVAILED
258	02-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	18:03	19:58	01:55	TRIPPED ON FAULT
259	02-Jul-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	13:40	13:55	00:15	TRIPPED ON FAULT
260	02-Jul-24	HASSAN	400	LINE	UPCL-HASSAN1	upcl_gen	10:12	15:02	04:50	LINE CLEAR AVAILED
261	02-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
262	02-Jul-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	07:13	12:16	05:03	TRIPPED ON FAULT
263	02-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
264	02-Jul-24	MYSORE	66	TRANSFORMER	HV1	VAJAMANGALA_220	04:12	04:18	00:06	TRIPPED ON FAULT
265	02-Jul-24	MYSORE	66	TRANSFORMER	HV1	VAJAMANGALA_220	14:56	15:03	00:07	TRIPPED ON FAULT
266	02-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
267	02-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
268	02-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
269	02-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
270	02-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	10:19	15:27	05:08	TRIPPED ON FAULT
271	02-Jul-24	MYSORE	66	LINE	RAVANDUR-ADANI	NO STATIONS EFFECTED	16:10	16:16	00:05	TRIPPED ON FAULT
272	02-Jul-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	12:53	12:59	00:06	TRIPPED ON FAULT
273	02-Jul-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	15:20	15:30	00:10	TRIPPED ON FAULT
274	02-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA,SASALUHALLA	12:31	13:10	00:39	TRIPPED ON FAULT
275	02-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALARAMESHWARA LINE 1	66KV HALRAMESHWARA,MADADAKERE	19:15	19:30	00:15	TRIPPED ON FAULT
276	02-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	15:52	16:08	00:16	LINE CLEAR AVAILED
277	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:06	11:18	00:12	LINE CLEAR AVAILED
278	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:56	13:07	00:11	LINE CLEAR AVAILED
279	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA LINE-1&LINE-2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	11:06	11:18	00:12	LINE CLEAR AVAILED
280	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA LINE-1&LINE-2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	11:48	14:28	02:40	LINE CLEAR AVAILED
281	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MAYAKONDA_66	MAYAKONDA_66,SASALUHALLA_66	11:06	11:25	00:19	LINE CLEAR AVAILED
282	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:06	11:18	00:12	LINE CLEAR AVAILED
283	02-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:55	13:06	00:11	LINE CLEAR AVAILED
284	02-Jul-24	TUMKUR	66	LINE	HARIYABBE-HIRIYUR	HARIYABBE_66	08:55	09:00	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
285	02-Jul-24	TUMKUR	66	LINE	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	12:30	14:00	01:30	LINE CLEAR AVAILED
286	02-Jul-24	TUMKUR	66	LINE	KEREBILCHI-SANTHEBENNUR	SANTHEBENNUR_66	13:00	13:10	00:10	LINE CLEAR AVAILED
287	02-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	12:00	14:20	02:20	LINE CLEAR AVAILED
288	02-Jul-24	TUMKUR	66	TRANSFORMER	TR1	HANGAL_66	17:27	17:37	00:10	LINE CLEAR AVAILED
289	02-Jul-24	TUMKUR	66	TRANSFORMER	TR1	KANCHIPUR_66	12:45	13:20	00:35	LINE CLEAR AVAILED
290	02-Jul-24	TUMKUR	66	TRANSFORMER	TR1	MYLANAHALLI_66	07:35	07:55	00:20	LINE CLEAR AVAILED
291	02-Jul-24	TUMKUR	66	TRANSFORMER	TR1	MYLANAHALLI_66	13:15	13:27	00:12	TRIPPED ON FAULT
292	02-Jul-24	TUMKUR	66	TRANSFORMER	TR1	TYAVANAGI_66	11:08	11:40	00:32	LINE CLEAR AVAILED
293	02-Jul-24	TUMKUR	66	TRANSFORMER	TR2	PULAMAGHATTA	12:15	13:15	01:00	LINE CLEAR AVAILED
294	02-Jul-24	TUMKUR	66	TRANSFORMER	TR2	BILCHODU_66	10:20	10:40	00:20	LINE CLEAR AVAILED
295	02-Jul-24	TUMKUR	66	TRANSFORMER	TR2	HARIYABBE_66	04:10	04:18	00:08	TRIPPED ON FAULT
296	02-Jul-24	TUMKUR	66	TRANSFORMER	TR2	KUKKAWADA	10:35	10:45	00:10	TRIPPED ON FAULT
297	02-Jul-24	TUMKUR	66	TRANSFORMER	TR2	MAVINAKATTE_66	14:35	15:15	00:40	LINE CLEAR AVAILED
298	02-Jul-24	TUMKUR	66	LINE	TYVANGI_66-KUKKAWADA_66	TYAVANAGI_66	11:10	12:20	01:10	MAIN SUPPLY FAILURE
299	02-Jul-24	TUMKUR	66	LINE	TYVANGI_66-KUKKAWADA_66	TYAVANAGI_66	11:53	14:30	02:37	MAIN SUPPLY FAILURE
300	02-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-1	CHITRADURGA- 220KV	15:40	15:46	00:06	TRIPPED ON FAULT
301	02-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-1	CHITRADURGA- 220KV	15:51	15:52	00:01	TRIPPED ON FAULT
302	02-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-3	THALLAK-220KV	19:05	19:30	00:25	TRIPPED ON FAULT
303	02-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA- 220KV PGCIL LINE	CHITRADURGA- 220KV	12:41	14:00	01:19	TRIPPED ON FAULT
304	02-Jul-24	TUMKUR	220	LINE	220KV HIRIYUR-220KV THALLAK LINE	HIRIYUR_220KV	19:04	19:57	00:53	TRIPPED ON FAULT
305	02-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV CHITRADURGA LINE	THALLAK-220KV	19:05	20:23	01:18	TRIPPED ON FAULT
306	02-Jul-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV- SHIMOGA	ANTHRASANAHALLI_220	11:31	18:14	06:43	LINE CLEAR AVAILED
307	02-Jul-24	TUMKUR	220	LINE	NITTUR 220KV- ARASIKERE	NITTUR_220	11:11	13:30	02:19	TRIPPED ON FAULT
308	02-Jul-24	TUMKUR	110	TRANSFORMER	HV1	SAGARA_110	11:55	12:39	00:44	LINE CLEAR AVAILED
309	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MALGHAN(B)_110	18:20	18:25	00:05	TRIPPED ON FAULT
310	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	11:46	12:04	00:18	LINE CLEAR AVAILED
311	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	SIDDAPUR_110	11:26	12:04	00:38	LINE CLEAR AVAILED
312	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	SIRSI_110	12:44	13:07	00:23	LINE CLEAR AVAILED
313	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TAKKALAKI_110	10:19	10:45	00:26	LINE CLEAR AVAILED
314	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MERDESHWAR_110	11:27	12:58	01:31	LINE CLEAR AVAILED
315	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HEBBALLI_110	09:23	11:03	01:40	LINE CLEAR AVAILED
316	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KALADAGI_110	18:43	19:00	00:17	LINE CLEAR AVAILED
317	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KAVALWADA_110	11:45	13:26	01:41	LINE CLEAR AVAILED
318	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KULAGERE CROSS_110	17:16	17:23	00:07	LINE CLEAR AVAILED
319	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KULAGERE CROSS_110	17:17	17:23	00:06	LINE CLEAR AVAILED
320	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	GAJENDRAGAD_110	15:23	15:38	00:15	LINE CLEAR AVAILED
321	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	MACHE_110	11:11	11:52	00:41	LINE CLEAR AVAILED
322	03-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	MACHE_110	11:11	11:53	00:42	LINE CLEAR AVAILED
323	03-Jul-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI(HIREMASALI)	ATHARGA_110	03:41	04:05	00:24	TRIPPED ON FAULT
324	03-Jul-24	BAGALKOTE	110	LINE	HUBLI220- KADANKOPPA	HUBLI_220	09:44	12:28	02:44	LINE CLEAR AVAILED
325	03-Jul-24	BAGALKOTE	110	LINE	HUBLI220- PH COMPOUND	HUBLI_220	12:54	14:42	01:48	LINE CLEAR AVAILED
326	03-Jul-24	BAGALKOTE	110	LINE	HUBLI220-SIRSI(KALGHATAGI)	HUBLI_220	08:06	10:33	02:27	LINE CLEAR AVAILED
327	03-Jul-24	BAGALKOTE	110	LINE	KADANAKOPPA-HUBLI	KADANAKOPPA_110	11:06	12:31	01:25	LINE CLEAR AVAILED
328	03-Jul-24	BAGALKOTE	110	LINE	KALAGATAGI-HUBLI	KALAGATAGI_110	07:51	10:36	02:45	LINE CLEAR AVAILED
329	03-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	11:10	15:01	03:51	LINE CLEAR AVAILED
330	03-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI2	KUMTA_110	11:10	14:10	03:00	LINE CLEAR AVAILED
331	03-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-BIDI	MKHUBLI_220	01:45	01:55	00:10	TRIPPED ON FAULT
332	03-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
333	03-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN2(RAIBAG2)	MUGALKHOD_220	10:58	12:06	01:08	LINE CLEAR AVAILED
334	03-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN4(BOMMANAL)	MUGALKHOD_220	10:38	12:00	01:22	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
335	03-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
336	03-Jul-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	11:39	14:11	02:32	LINE CLEAR AVAILED
337	03-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA1	SOUDATTI_220	04:58	05:23	00:25	TRIPPED ON FAULT
338	03-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA2	SOUDATTI_220	04:58	05:23	00:25	TRIPPED ON FAULT
339	03-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
340	03-Jul-24	BAGALKOTE	110	LINE	UDYAMBAG- MACHE	UDYAMBAG_110	8:25	8:46	00:21	LINE CLEAR AVAILED
341	03-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI	11:18 (29.06.2024)	19:27 (03.07.2024)	104:09:00	LINE CLEAR AVAILED
342	03-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI	11:15 (29.06.2024)			LINE CLEAR AVAILED
343	03-Jul-24	BANGALORE	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	PLATINUM CITY	12:59	13:03	00:04	LINE CLEAR AVAILED
344	03-Jul-24	BANGALORE	66	LINE	66KV BYADARAHALLI - KODIGEHALLI	KODIGEHALLI	15:22	15:45	00:23	TRIPPED ON FAULT
345	03-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	01:55	02:02	00:07	TRIPPED ON FAULT
346	03-Jul-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	14:16	14:23	00:07	LINE CLEAR AVAILED
347	03-Jul-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	ADUGODI	08:18	10:30	02:12	TRIPPED ON FAULT
348	03-Jul-24	BANGALORE	66	LINE	66KV HSR 220 - JAKKASANDRA	NO STATION AFFECTED	08:18	10:28	02:10	TRIPPED ON FAULT
349	03-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	NO STATION AFFECTED	11:15	11:42	00:27	TRIPPED ON FAULT
350	03-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:01	10:09	00:08	LINE CLEAR AVAILED
351	03-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:01	10:09	00:08	LINE CLEAR AVAILED
352	03-Jul-24	BANGALORE	66	LINE	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI	16:24	16:27	00:03	LINE CLEAR AVAILED
353	03-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	15:35	15:49	00:14	TRIPPED ON FAULT
354	03-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	11:15	12:20	01:05	LINE CLEAR AVAILED
355	03-Jul-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	15:33	15:53	00:20	LINE CLEAR AVAILED
356	03-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	11:45	14:20	02:35	LINE CLEAR AVAILED
357	03-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ELECTRONIC CITY	12:36	13:41	01:05	LINE CLEAR AVAILED
358	03-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANASAWADI	12:37	12:52	00:15	LINE CLEAR AVAILED
359	03-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MARALAWADI	13:20	14:20	01:00	LINE CLEAR AVAILED
360	03-Jul-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	18:35	18:55	00:20	TRIPPED ON FAULT
361	03-Jul-24	BANGALORE	66	TRANSFORMER	HV2	WIDIA	17:28	17:32	00:04	TRIPPED ON FAULT
362	03-Jul-24	BANGALORE	66	TRANSFORMER	HV3	KGF	14:30	15:25	00:55	LINE CLEAR AVAILED
363	03-Jul-24	GULBARGA	66	LINE	BADALADUKU-CJHALLI	CJHALLI_66,HOSAHALLI_66,HUDEM	19:15	19:25	00:10	TRIPPED ON FAULT
364	03-Jul-24	GULBARGA	66	LINE	HALAVAGALU-KNNL NITTUR	KNNL NITTUR_66	03:50	04:15	00:25	TRIPPED ON FAULT
365	03-Jul-24	GULBARGA	110	TRANSFORMER	HV2	KANAKAGIRI_110	13:00	13:20	00:20	TRIPPED ON FAULT
366	03-Jul-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	10:05	16:30	06:25	LINE CLEAR AVAILED
367	03-Jul-24	GULBARGA	110	LINE	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	05:57	06:10	00:13	TRIPPED ON FAULT
368	03-Jul-24	GULBARGA	110	LINE	M KOLLUR-DEODURGA	M KOLLUR_110	00:45	00:58	00:13	TRIPPED ON FAULT
369	03-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIRI	YADGIRI_110	06:14	17:42	11:28	LINE CLEAR AVAILED
370	03-Jul-24	GULBARGA	110	LINE	SHAHABAD-MANDEWAL	MANDEWAL_110, YADRAMI_110	15:36	16:13	00:37	LINE CLEAR AVAILED
371	03-Jul-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	GOOGAL_110	00:44	00:55	00:11	TRIPPED ON FAULT
372	03-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
373	03-Jul-24	HASSAN	66	LINE	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	13:00	13:35	00:35	LINE CLEAR AVAILED
374	03-Jul-24	HASSAN	66	LINE	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	12:19	14:04	01:45	LINE CLEAR AVAILED
375	03-Jul-24	HASSAN	66	LINE	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	13:34	14:04	00:30	LINE CLEAR AVAILED
376	03-Jul-24	HASSAN	66	LINE	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:34	14:04	00:30	LINE CLEAR AVAILED
377	03-Jul-24	HASSAN	66	LINE	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	13:34	14:04	00:30	LINE CLEAR AVAILED
378	03-Jul-24	HASSAN	66	TRANSFORMER	HV1	CHANNARAYAPATNA_66	13:34	14:04	00:30	LINE CLEAR AVAILED
379	03-Jul-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	10:45	17:00	06:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
380	03-Jul-24	HASSAN	66	TRANSFORMER	HV2	CHANNARAYAPATNA_66	13:34	14:04	00:30	LINE CLEAR AVAILED
381	03-Jul-24	HASSAN	66	TRANSFORMER	HV2	SAKALESH PURA_66	14:20	14:50	00:30	LINE CLEAR AVAILED
382	03-Jul-24	HASSAN	66	LINE	YESLUR-SNVRSNT	YESLUR_66	10:45	17:00	06:15	LINE CLEAR AVAILED
383	03-Jul-24	HASSAN	110	TRANSFORMER	HV1	BARANGI-110	19:49(03.07.2024)			TRIPPED ON FAULT
384	03-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	19:12	19:29	00:17	TRIPPED ON FAULT
385	03-Jul-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	22:33	22:47	00:14	TRIPPED ON FAULT
386	03-Jul-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	10:41	12:16	01:35	LINE CLEAR AVAILED
387	03-Jul-24	HASSAN	110	TRANSFORMER	HV3	GURUVAYANKERE_110	10:31	16:48	06:17	LINE CLEAR AVAILED
388	03-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA_110	11:07	11:36	00:29	TRIPPED ON FAULT
389	03-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	22:57(03.07.2024)			LINE CLEAR AVAILED
390	03-Jul-24	HASSAN	110	LINE	MADHUV-BRK_MDV CBreaker	MADHUVANA_110	05:47	05:57	00:10	TRIPPED ON FAULT
391	03-Jul-24	HASSAN	110	LINE	MRSSHM-SS2	MRSMG_220	10:48	13:11	02:23	LINE CLEAR AVAILED
392	03-Jul-24	HASSAN	110	LINE	PUTTUR-SULIA	PUTTUR_110	09:07	09:28	00:21	TRIPPED ON FAULT
393	03-Jul-24	HASSAN	220	LINE	MRSSHM-HONNALLI	MRSMG_220	18:11	18:42	00:31	TRIPPED ON FAULT
394	03-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMG_220	14:03	18:03	04:00	TRIPPED ON FAULT
395	03-Jul-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA4	gen_sharavathy	14:16	15:30	01:14	TRIPPED ON FAULT
396	03-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	14:02	18:04	04:02	TRIPPED ON FAULT
397	03-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
398	03-Jul-24	MYSORE	66	LINE	HAMPAPURA-MANDYA	NO STATIONS EFFECTED	17:04	19:24	02:19	LINE CLEAR AVAILED
399	03-Jul-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66	06:09	06:23	00:14	TRIPPED ON FAULT
400	03-Jul-24	MYSORE	66	LINE	HEBBANI-T K HALLI	NO STATIONS EFFECTED	19:08	19:18	00:10	TRIPPED ON FAULT
401	03-Jul-24	MYSORE	66	LINE	HONGANURU-YELANDUR	NO STATIONS EFFECTED	08:00	08:05	00:05	TRIPPED ON FAULT
402	03-Jul-24	MYSORE	66	TRANSFORMER	HV1	BANNIMANTAP_66	11:24	16:52	05:28	LINE CLEAR AVAILED
403	03-Jul-24	MYSORE	66	TRANSFORMER	HV1	BEGUR_220	16:00	17:20	01:20	LINE CLEAR AVAILED
404	03-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
405	03-Jul-24	MYSORE	66	TRANSFORMER	HV2	HULLAHALLI_66	22:13	22:25	00:11	TRIPPED ON FAULT
406	03-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
407	03-Jul-24	MYSORE	66	LINE	KADAKOLA-GOLURU	GOLURU(GEEKALLI)_66 DEVANOORNGUDU_66 SUTTUR_66	04:15	04:18	00:03	TRIPPED ON FAULT
408	03-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	3.7.24 @ 23.51			TRIPPED ON FAULT
409	03-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
410	03-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
411	03-Jul-24	MYSORE	66	LINE	MAMBALLI-YELANDUR	NO STATIONS EFFECTED	18:55	19:00	00:05	TRIPPED ON FAULT
412	03-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
413	03-Jul-24	MYSORE	66	LINE	SFC SIVA-5MW	NO STATIONS EFFECTED	19:08	19:12	00:04	TRIPPED ON FAULT
414	03-Jul-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	19:08	19:12	00:03	TRIPPED ON FAULT
415	03-Jul-24	MYSORE	220	TRANSFORMER	HV1	HUNSUR (THAMADANAHALLI)_220	12:05	12:30	00:25	LINE CLEAR AVAILED
416	03-Jul-24	MYSORE	220	TRANSFORMER	HV1	NAGAMANGALA_220	17:05	19:16	02:11	LINE CLEAR AVAILED
417	03-Jul-24	MYSORE	220	TRANSFORMER	HV2	HUNSUR (THAMADANAHALLI)_220	11:20	11:58	00:38	LINE CLEAR AVAILED
418	03-Jul-24	MYSORE	220	TRANSFORMER	HV2	NAGAMANGALA_220	17:05	19:16	02:11	LINE CLEAR AVAILED
419	03-Jul-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 1	NO STATIONS EFFECTED	17:05	19:14	02:09	LINE CLEAR AVAILED
420	03-Jul-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	17:05	19:14	02:09	LINE CLEAR AVAILED
421	03-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV THALLAK LINE	66KV RANGENAHALLY	15:45	18:40	02:55	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
422	03-Jul-24	TUMKUR	66	LINE	66KV KUKKAWADA-66KV BASAVAPATNA LINE	66KV THAVANAGI	09:20	09:30	00:10	TRIPPED ON FAULT
423	03-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	13:13	13:22	00:09	TRIPPED ON FAULT
424	03-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	16:47	19:27	02:40	TRIPPED ON FAULT
425	03-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	14:40	15:05	00:25	LINE CLEAR AVAILED
426	03-Jul-24	TUMKUR	66	LINE	HARIYABBE-HIRIYUR	HARIYABBE_66	17:25	18:40	01:15	MAIN SUPPLY FAILURE
427	03-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- BARAMAGIRI	BARAMAGIRI_66	17:25	18:40	01:15	MAIN SUPPLY FAILURE
428	03-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	17:25	18:40	01:15	MAIN SUPPLY FAILURE
429	03-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	17:20	18:20	01:00	LINE CLEAR AVAILED
430	03-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:08	16:44	00:36	LINE CLEAR AVAILED
431	03-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV-SIRA(RANGANATHAPURA)	SIRA_66	17:15	18:35	01:20	LINE CLEAR AVAILED
432	03-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	17:15	18:37	01:22	LINE CLEAR AVAILED
433	03-Jul-24	TUMKUR	66	TRANSFORMER	TR1-20MVA	BUKKAPATNA_66	12:45	14:55	02:10	LINE CLEAR AVAILED
434	03-Jul-24	TUMKUR	66	TRANSFORMER	TR1-8MVA	CHITRAHALLI_66	15:05	15:10	00:05	TRIPPED ON FAULT
435	03-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5MVA	BUKKAPATNA_66	13:30	13:35	00:05	LINE CLEAR AVAILED
436	03-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5MVA	KADAJI_66	16:35	16:40	00:05	TRIPPED ON FAULT
437	03-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5MVA	KUKKAWADA	13:25	13:30	00:05	TRIPPED ON FAULT
438	03-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5MVA	YEDIYUR_66	11:00	11:20	00:20	LINE CLEAR AVAILED
439	03-Jul-24	TUMKUR	66	TRANSFORMER	TR2-20MVA	CHITRADURGA-66	12:30	13:03	00:33	LINE CLEAR AVAILED
440	03-Jul-24	TUMKUR	66	LINE	YEDIYUR- ANCHEPALYA220KV	YADIYUR_66	13:15	13:45	00:30	LINE CLEAR AVAILED
441	03-Jul-24	TUMKUR	66	LINE	YEDIYUR- ANCHEPALYA220KV	YADIYUR_66	17:10	19:30	02:20	LINE CLEAR AVAILED
442	03-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-2-220KV	HIRIYUR_220KV	17:06	17:15	00:09	LINE CLEAR AVAILED
443	03-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-3-220KV	HIRIYUR_220KV	17:35	18:34	00:59	LINE CLEAR AVAILED
444	03-Jul-24	TUMKUR	220	LINE	ANCHEPALYA 220KV- NELMANGALA LINE-1&LINE-2 (NAGAMANGALA 2)(MAGADI)	ANCHEPALYA_220	16:28	19:13	02:45	LINE CLEAR AVAILED
445	04-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADAKALAT_110	00:58	01:10	00:12	LINE CLEAR AVAILED
446	04-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULAGERICROSS_110	14:27	18:16	03:49	LINE CLEAR AVAILED
447	04-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	MUNDAGOD_110	10:49	13:52	03:03	LINE CLEAR AVAILED
448	04-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	HIDAKAL_110	12:01	12:33	00:32	LINE CLEAR AVAILED
449	04-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	MALAGHAN_110	02:58	03:05	00:07	TRIPPED ON FAULT
450	04-Jul-24	BAGALKOTE	110	LINE	ATHANI-HALYAL	ATHANI_220	04:56	05:20	00:24	TRIPPED ON FAULT
451	04-Jul-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	13:00	13:52	00:52	LINE CLEAR AVAILED
452	04-Jul-24	BAGALKOTE	110	LINE	HATTARGI-HUKKEREI (SANGAMSUGARS)	HATTARGI_110	09:52	13:38	03:46	LINE CLEAR AVAILED
453	04-Jul-24	BAGALKOTE	110	LINE	HUNAGUND-BAGEWADI(KUDALASANGAM)	HUNAGUND_110	21:28	21:34	00:06	TRIPPED ON FAULT
454	04-Jul-24	BAGALKOTE	110	LINE	ITNAL-HIDKAL(KABBUR3)	ITNAL_110	10:35	12:11	01:36	LINE CLEAR AVAILED
455	04-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
456	04-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN5(ITNAL-3)	MUGALAKHOD_220	10:36	12:10	01:34	LINE CLEAR AVAILED
457	04-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN6(HIDKAL)	MUGALAKHOD_220	11:38	13:15	01:37	LINE CLEAR AVAILED
458	04-Jul-24	BAGALKOTE	110	LINE	RANEENNUR-BYADAGI	RANEENNUR_220	11:39	13:13	01:34	LINE CLEAR AVAILED
459	04-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
460	04-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA 2	SOUNDATTI_220	12:21	16:42	04:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
461	04-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
462	04-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI	11:15 (29.06.2024)	13:58 (04.07.2024)	122:43:00	LINE CLEAR AVAILED
463	04-Jul-24	BAGALKOTE	220	LINE	BIDNAL-SOUDATTI2	BIDNAL_220	11:50	14:12	02:22	LINE CLEAR AVAILED
464	04-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:48 (04.07.2024)			LINE CLEAR AVAILED
465	04-Jul-24	BAGALKOTE	220	LINE	SOUDATTI220-BIDNAL-2	SOUNDATTI_220	11:55	14:02	02:07	LINE CLEAR AVAILED
466	04-Jul-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA HOSPITAL	06:53	06:55	00:02	LINE CLEAR AVAILED
467	04-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	06:02	06:21	00:19	TRIPPED ON FAULT
468	04-Jul-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	NANDAGUDI	11:37	11:47	00:10	TRIPPED ON FAULT
469	04-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	05:20	05:33	00:13	TRIPPED ON FAULT
470	04-Jul-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220_DG4	GRINDWELL(EHT)	06:44	07:24	00:40	TRIPPED ON FAULT
471	04-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	10:43	10:48	00:05	LINE CLEAR AVAILED
472	04-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - NANDINI LAYOUT	NANDINI LAYOUT	07:55	08:46	00:51	TRIPPED ON FAULT
473	04-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANUKUNTE	11:40	11:50	00:10	LINE CLEAR AVAILED
474	04-Jul-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI, RAYALPADU, GOWNIPALLI, SOLAR IPP	07:40	07:52	00:12	TRIPPED ON FAULT
475	04-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVANA 220	NANDINI LAYOUT, MAHALAKSHMI LAYOUT	07:14	08:28	01:14	TRIPPED ON FAULT
476	04-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	07:13	08:47	01:34	LINE CLEAR AVAILED
477	04-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - NANDINI LAYOUT	NANDINI LAYOUT	07:13	07:48	00:35	MAIN SUPPLY FAILURE
478	04-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	TAYALUR, NG HULKUR, MN HALLI	16:39	16:57	00:18	TRIPPED ON FAULT
479	04-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:00	10:10	00:10	LINE CLEAR AVAILED
480	04-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	17:47	18:00	00:13	LINE CLEAR AVAILED
481	04-Jul-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	21:05	21:15	00:10	TRIPPED ON FAULT
482	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	05:20	05:33	00:13	MAIN SUPPLY FAILURE
483	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	07:53	07:55	00:02	LINE CLEAR AVAILED
484	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	18:56	19:00	00:04	LINE CLEAR AVAILED
485	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUDUR	14:50	14:55	00:05	LINE CLEAR AVAILED
486	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	23:12	23:46	00:34	LINE CLEAR AVAILED
487	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	PALLICHERLU	09:10	09:15	00:05	LINE CLEAR AVAILED
488	04-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SURYANAGAR	19:11	19:30	00:19	TRIPPED ON FAULT
489	04-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DODDALAHALLI	05:25	05:45	00:20	TRIPPED ON FAULT
490	04-Jul-24	BANGALORE	66	TRANSFORMER	HV2	G KODIHALLI	11:22	11:32	00:10	LINE CLEAR AVAILED
491	04-Jul-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	09:51	10:07	00:16	TRIPPED ON FAULT
492	04-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	07:53	07:55	00:02	LINE CLEAR AVAILED
493	04-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	18:56	19:00	00:04	LINE CLEAR AVAILED
494	04-Jul-24	BANGALORE	66	TRANSFORMER	HV3	A STATION 66	06:40	06:43	00:03	LINE CLEAR AVAILED
495	04-Jul-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	05:20	05:33	00:13	MAIN SUPPLY FAILURE
496	04-Jul-24	BANGALORE	66	TRANSFORMER	HV3	HOSKOTE 66	17:10	18:45	01:35	LINE CLEAR AVAILED
497	04-Jul-24	BANGALORE	66	TRANSFORMER	HV4	A STATION 66	06:40	06:43	00:03	LINE CLEAR AVAILED
498	04-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 1	BANGARPET RAILWAY	09:10	16:15	07:05	LINE CLEAR AVAILED
499	04-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 2	BANGARPET RAILWAY	09:10	16:15	07:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
500	04-Jul-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - SRS PEENYA 3	NO STATION AFFECTED	12:22	14:43	02:21	TRIPPED ON FAULT
501	04-Jul-24	BANGALORE	220	TRANSFORMER	HV2	BRINDAVANA 220	07:14	07:31	00:17	TRIPPED ON FAULT
502	04-Jul-24	BANGALORE	220	TRANSFORMER	HV2	SRS PEENYA 220	07:50	23:59	16:09	TRIPPED ON FAULT
503	04-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	18:20	18:25	00:05	TRIPPED ON FAULT
504	04-Jul-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HOLAGUNDI_66	17:02	17:56	00:54	LINE CLEAR AVAILED
505	04-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	01:07	01:17	00:10	MAIN SUPPLY FAILURE
506	04-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-SHAHPUR-2	SHAHAPUR_110	19:52	20:13	00:21	TRIPPED ON FAULT
507	04-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	05:34	05:47	00:13	TRIPPED ON FAULT
508	04-Jul-24	GULBARGA	110	TRANSFORMER	HV1&HV2	MANVI_110	10:30	16:30	06:00	LINE CLEAR AVAILED
509	04-Jul-24	GULBARGA	110	LINE	KHANAPUR-SHIRWAL	KAHNAPUR_110	20:04	20:14	00:10	TRIPPED ON FAULT
510	04-Jul-24	GULBARGA	110	LINE	KHANAPUR-SONOTHI	KHANAPUR_110	02:55	03:05	00:10	TRIPPED ON FAULT
511	04-Jul-24	GULBARGA	110	LINE	KHANAPUR-SONOTHI	KHANAPUR_110	04:04	04:12	00:08	TRIPPED ON FAULT
512	04-Jul-24	GULBARGA	110	LINE	MALLAT-MADALAPUR	MADALAPUR_110	05:30	05:37	00:07	TRIPPED ON FAULT
513	04-Jul-24	GULBARGA	110	LINE	NALWAR-SHAHABAD	NALWAR_110	19:52	19:58	00:06	TRIPPED ON FAULT
514	04-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	10:13	17:35	07:22	LINE CLEAR AVAILED
515	04-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	15:25	15:45	00:20	LINE CLEAR AVAILED
516	04-Jul-24	GULBARGA	110	LINE	SULEKAL-HANAWAL	HANAWAL_110	01:07	01:12	00:05	TRIPPED ON FAULT
517	04-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-FIROZABAD-2	HATTIGUDUR_220	03:26	04:11	00:45	TRIPPED ON FAULT
518	04-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
519	04-Jul-24	HASSAN	66	TRANSFORMER	HV1	GORUR_66	08:15	09:00	00:45	LINE CLEAR AVAILED
520	04-Jul-24	HASSAN	66	LINE	IDLE	TAVARECHATNAHLLI_66	11:13	11:50	00:37	LINE CLEAR AVAILED
521	04-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESH PURA_66	08:10	18:50	10:40	LINE CLEAR AVAILED
522	04-Jul-24	HASSAN	110	LINE	BANTWA-KAVOOR	BANTWAL_110	12:20	13:25	01:05	LINE CLEAR AVAILED
523	04-Jul-24	HASSAN	110	LINE	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	10:20	12:25	02:05	LINE CLEAR AVAILED
524	04-Jul-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	19:49(03.07.2024)	12:55(4.07.2024)	17:05 hrs	LINE CLEAR AVAILED
525	04-Jul-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	00:30	00:38	00:08	TRIPPED ON FAULT
526	04-Jul-24	HASSAN	110	TRANSFORMER	HV2 CB	JADE_110	14:00	14:45	00:45	TRIPPED ON FAULT
527	04-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	02:36	02:47	00:11	TRIPPED ON FAULT
528	04-Jul-24	HASSAN	110	TRANSFORMER	KARKLA-HV1CBreaker	KARKLA_110	05:26	05:51	00:25	TRIPPED ON FAULT
529	04-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR2	KEMAR_220	05:42	05:53	00:11	TRIPPED ON FAULT
530	04-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	22:57(03.07.2024)	00:17(4.07.2024)	1:19 hrs	LINE CLEAR AVAILED
531	04-Jul-24	HASSAN	110	LINE	LV2	KEMAR_220	11:16	16:07	04:51	LINE CLEAR AVAILED
532	04-Jul-24	HASSAN	110	LINE	MRSSHM-GAJNUR	MRSMG_220	10:20	12:25	02:05	LINE CLEAR AVAILED
533	04-Jul-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	11:16	16:07	04:51	LINE CLEAR AVAILED
534	04-Jul-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	11:50	14:57	03:07	LINE CLEAR AVAILED
535	04-Jul-24	HASSAN	220	LINE	KEMAR-UPCL2	KEMAR_220	05:42	05:55	00:13	TRIPPED ON FAULT
536	04-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
537	04-Jul-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66 CHIDRAVALLI_66	12:18	12:30	00:12	TRIPPED ON FAULT
538	04-Jul-24	MYSORE	66	LINE	HEBBANI-SATHEGALA	CHANDALLI_66 KOLLEGALA_66 PARINAMIPURA_66 SATHEGALA_66 THALAKADU_66	05:26	05:43	00:17	TRIPPED ON FAULT
539	04-Jul-24	MYSORE	66	TRANSFORMER	HV1	BANNIMANTAP_66	10:58	11:54	00:56	LINE CLEAR AVAILED
540	04-Jul-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	08:09	09:56	01:47	LINE CLEAR AVAILED
541	04-Jul-24	MYSORE	66	TRANSFORMER	HV1	KHBCOLONY_66	11:31	15:47	04:16	LINE CLEAR AVAILED
542	04-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
543	04-Jul-24	MYSORE	66	TRANSFORMER	HV2	BANNIMANTAP_66	11:00	11:15	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
544	04-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
545	04-Jul-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	08:00	14:38	06:37	LINE CLEAR AVAILED
546	04-Jul-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	15:31 (05/07/2024)			LINE CLEAR AVAILED
547	04-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (4/7/2024)			LINE CLEAR AVAILED
548	04-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	09:14	12:24	03:10	LINE CLEAR AVAILED
549	04-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	23:51 (3/7/2024)	12:24:00 (4/7/2024)	12:33 Hrs	TRIPPED ON FAULT
550	04-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTTINMULLSOGE	NO STATIONS EFFECTED	11:03	12:25	01:22	LINE CLEAR AVAILED
551	04-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
552	04-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
553	04-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	05:26	05:33	00:07	TRIPPED ON FAULT
554	04-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	18:46	18:51	00:04	TRIPPED ON FAULT
555	04-Jul-24	MYSORE	66	LINE	MUGURU-THAYURU	THAYUR_66 TNARSIPURA_66	18:45	18:50	00:05	TRIPPED ON FAULT
556	04-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
557	04-Jul-24	MYSORE	66	LINE	PANYADAHUNDI-KEREHALLI	NO STATIONS EFFECTED	23:05	23:10	00:05	TRIPPED ON FAULT
558	04-Jul-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	01:56	02:10	00:14	TRIPPED ON FAULT
559	04-Jul-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	14:00	14:10	00:10	TRIPPED ON FAULT
560	04-Jul-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	16:40	16:50	00:10	TRIPPED ON FAULT
561	04-Jul-24	MYSORE	66	LINE	RAVANDURU-ADANI	NO STATIONS EFFECTED	12:52	13:04	00:12	TRIPPED ON FAULT
562	04-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV BASAVAPATTANA	16:11	16:21	00:10	TRIPPED ON FAULT
563	04-Jul-24	TUMKUR	66	LINE	66 KV INCOMING LINE (TELIGI LINE EXPORT)	66KV KURUBARAHALLI	23:55	23:59	00:05	MAIN SUPPLY FAILURE
564	04-Jul-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMAGHATTA	05:55	06:53	00:58	TRIPPED ON FAULT
565	04-Jul-24	TUMKUR	66	LINE	THERIYUR_66-PAVAGADA_66	66KV THAVANAGI	19:20	19:30	00:10	TRIPPED ON FAULT
566	04-Jul-24	TUMKUR	66	TRANSFORMER	TR1-12.5MVA	THAVANAGI_66	09:36	09:40	00:04	TRIPPED ON FAULT
567	04-Jul-24	TUMKUR	66	TRANSFORMER	TR1-20 MVA	KORATAGERE_66	12:45	13:00	00:15	LINE CLEAR AVAILED
568	04-Jul-24	TUMKUR	66	TRANSFORMER	TR2 12.5MVA	HALURAMESWARA_66	09:15	09:25	00:10	TRIPPED ON FAULT
569	04-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5 MVA	SANIKERE_66	05:50	06:00	00:10	TRIPPED ON FAULT
570	04-Jul-24	TUMKUR	66	TRANSFORMER	TR2-20 MVA	KORATAGERE_66	13:00	13:20	00:20	LINE CLEAR AVAILED
571	04-Jul-24	TUMKUR	220	LINE	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	17:27	17:42	00:15	TRIPPED ON FAULT
572	04-Jul-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	14:18 (04.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
573	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULAGERICROSS_110	16:03	16:26	00:23	LINE CLEAR AVAILED
574	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	SIRSI_110	13:08	13:31	00:23	LINE CLEAR AVAILED
575	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KULAGERICROSS_110	16:03	16:26	00:23	LINE CLEAR AVAILED
576	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	NIPPANI_110	00:10	01:21	01:11	LINE CLEAR AVAILED
577	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KALADAGI_110	18:55	19:06	00:11	TRIPPED ON FAULT
578	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TALIKOT_110	11:15	11:21	00:06	TRIPPED ON FAULT
579	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TUMMINAKATTI_110	14:26	15:11	00:45	TRIPPED ON FAULT
580	05-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	ZALKI_110,HALASANGI_33,DHULKHED_33	13:53	14:44	00:51	TRIPPED ON FAULT
581	05-Jul-24	BAGALKOTE	110	LINE	ANKALI-HERMES BIO	HERMES BIO_110 ANKALI_110	00:10	01:38	01:28	LINE CLEAR AVAILED
582	05-Jul-24	BAGALKOTE	110	LINE	CHIKKODI-HUKKERI	CHIKODI_220	00:15	11:06	10:51	TRIPPED ON FAULT
583	05-Jul-24	BAGALKOTE	110	LINE	HUNAGUND-BAGEWADI(KUDALASANGAM)	HUNAGUND_110	02:40	02:46	00:06	TRIPPED ON FAULT
584	05-Jul-24	BAGALKOTE	110	LINE	INDI220-ZALKI 1	INDI_220	15:17	15:40	00:23	TRIPPED ON FAULT
585	05-Jul-24	BAGALKOTE	110	LINE	INDI220-ZALKI 2	INDI_220	15:19	15:38	00:19	TRIPPED ON FAULT
586	05-Jul-24	BAGALKOTE	110	LINE	KADAKALAT-CHIKKODI220	KADAKALAT_110	00:10	01:10	01:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
587	05-Jul-24	BAGALKOTE	110	LINE	KUD DHARWAD-LAKAMANAHALLI	KUD DHARWAD_110	06:05	06:30	00:25	LINE CLEAR AVAILED
588	05-Jul-24	BAGALKOTE	110	LINE	KUD DHARWAD-NARENDRA	KUD DHARWAD_110	06:18	10:52	04:34	LINE CLEAR AVAILED
589	05-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-KERUR	KULAGERICROSS_110	16:20	16:26	00:06	LINE CLEAR AVAILED
590	05-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-MRN SUGARS	KULAGERICROSS_110	12:40	12:46	00:06	TRIPPED ON FAULT
591	05-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
592	05-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN12(PG HUNASHAL)	MUGALAKHOD_220	10:38	12:13	01:35	LINE CLEAR AVAILED
593	05-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD-LN7(MAHALINGAPUR)	MUGALAKHOD_220	11:35	13:09	01:34	LINE CLEAR AVAILED
594	05-Jul-24	BAGALKOTE	110	LINE	NIPPANI-CHIKKODI220	NIPPANI_110	00:10	01:25	01:15	LINE CLEAR AVAILED
595	05-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
596	05-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
597	05-Jul-24	BAGALKOTE	110	LINE	VADAGOAN-BELGAUM	VADAGOAN_110	15:57	17:30	01:33	LINE CLEAR AVAILED
598	05-Jul-24	BAGALKOTE	110	LINE	VADAGOAN-MACHE	VADAGOAN_110	08:07	11:13	03:06	TRIPPED ON FAULT
599	05-Jul-24	BAGALKOTE	110	LINE	VADAGOAN-MACHE	VADAGOAN_110	11:42	17:31	05:49	LINE CLEAR AVAILED
600	05-Jul-24	BAGALKOTE	110	LINE	VADAGOAN-MACHE	VADAGOAN_110	18:18 (05.07.2024)			LINE CLEAR AVAILED
601	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1,LV1	CHIKODI_220	00:25	11:22	10:57	TRIPPED ON FAULT
602	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	CHIKODI_220,ANKALI_110,RAIBAG_110,CHIKKODI_110,KADAKLAT_110,SADALAGA_110,BHOJ_110,CBSSK_110,NANADI_110	00:15	01:08	00:53	TRIPPED ON FAULT
603	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	BELAGAVI_220	13:16	13:36	00:20	LINE CLEAR AVAILED
604	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	HAVERI_220	11:13	11:43	00:30	LINE CLEAR AVAILED
605	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	CHIKODI_220	00:15	01:29	01:14	TRIPPED ON FAULT
606	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	INDI_220	11:35	12:02	00:27	LINE CLEAR AVAILED
607	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV1	CHIKODI_220	00:15	11:23	11:08	TRIPPED ON FAULT
608	05-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV2	CHIKODI_220,ANKALI_110,RAIBAG_110,CHIKKODI_110,KADAKLAT_110,SADALAGA_110,BHOJ_110,CBSSK_110,NANADI_110	00:15	01:09	00:54	TRIPPED ON FAULT
609	05-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI1(ALAMATTI-2)	BAGAKOT_220	10:28	17:02	06:34	LINE CLEAR AVAILED
610	05-Jul-24	BAGALKOTE	220	LINE	BELGAUM-VADAGOAN	BELAGAVI_220	15:57	17:30	01:33	LINE CLEAR AVAILED
611	05-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:48 (04.07.2024)	11:57 (05.07.2024)	21:09	LINE CLEAR AVAILED
612	05-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUT2	HAVERI_220	12:15 (05.07.2024)			LINE CLEAR AVAILED
613	05-Jul-24	BAGALKOTE	220	LINE	NARENDRA-KUD	NARENDRA_220	06:03	10:53	04:50	TRIPPED ON FAULT
614	05-Jul-24	BANGALORE	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	ATTUR, SAHAKARINAGAR 66	12:44	12:45	00:01	TRIPPED ON FAULT
615	05-Jul-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - BUDIGERE	BUDIGERE	15:47	15:53	00:06	TRIPPED ON FAULT
616	05-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	DASHAVARA, BEVOOR, SANKALGERE, VANDARAGUPPE	17:54	18:18	00:24	TRIPPED ON FAULT
617	05-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	11:00	11:05	00:05	LINE CLEAR AVAILED
618	05-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	NO STATION AFFECTED	09:19	09:34	00:15	TRIPPED ON FAULT
619	05-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:26	14:56	00:30	LINE CLEAR AVAILED
620	05-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:37	16:50	00:13	LINE CLEAR AVAILED
621	05-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:37	17:13	00:36	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
622	05-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	03:45	03:56	00:11	TRIPPED ON FAULT
623	05-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:00	10:10	00:10	LINE CLEAR AVAILED
624	05-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	17:47	18:01	00:14	LINE CLEAR AVAILED
625	05-Jul-24	BANGALORE	66	LINE	66KV WELCAST - ABBIGERE	WELCAST	13:35	13:38	00:03	LINE CLEAR AVAILED
626	05-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	14:47	14:57	00:10	LINE CLEAR AVAILED
627	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHANDAPURA	14:57	15:01	00:04	LINE CLEAR AVAILED
628	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	16:45	18:40	01:55	LINE CLEAR AVAILED
629	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	11:30	14:30	03:00	LINE CLEAR AVAILED
630	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SARAKKI	16:20	17:40	01:20	TRIPPED ON FAULT
631	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TELECOM LAYOUT	09:00	09:40	00:40	TRIPPED ON FAULT
632	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	16:00	16:30	00:30	LINE CLEAR AVAILED
633	05-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	16:45	18:05	01:20	LINE CLEAR AVAILED
634	05-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHANDAPURA	13:23	13:28	00:05	LINE CLEAR AVAILED
635	05-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MARALAWADI	11:35	13:22	01:47	LINE CLEAR AVAILED
636	05-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MARALAWADI	21:12	21:36	00:24	TRIPPED ON FAULT
637	05-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MARALAWADI	22:38	23:59	01:21	TRIPPED ON FAULT
638	05-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VOLVO	16:30	16:45	00:15	LINE CLEAR AVAILED
639	05-Jul-24	BANGALORE	66	TRANSFORMER	HV3	A STATION 66	07:42	07:45	00:03	LINE CLEAR AVAILED
640	05-Jul-24	BANGALORE	66	TRANSFORMER	HV4	A STATION 66	07:42	07:45	00:03	LINE CLEAR AVAILED
641	05-Jul-24	GULBARGA	66	LINE	BADALADUKU-HIREHADAGALI-2	HIREHADAGALI-2_66	19:06	19:20	00:14	TRIPPED ON FAULT
642	05-Jul-24	GULBARGA	66	LINE	CHILAKANAHATTI-HANASI	HANASI_66	20:40	21:00	00:20	TRIPPED ON FAULT
643	05-Jul-24	GULBARGA	66	LINE	HIREHADAGALI-ITTAGI	HIREHADAGALI_66	19:06	19:20	00:14	TRIPPED ON FAULT
644	05-Jul-24	GULBARGA	66	LINE	KUDLIGI-KOGALI	KOGALI_66	13:00	13:20	00:20	LINE CLEAR AVAILED
645	05-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	17:15	17:27	00:12	TRIPPED ON FAULT
646	05-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	19:24	19:30	00:06	TRIPPED ON FAULT
647	05-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	19:30	19:49	00:19	TRIPPED ON FAULT
648	05-Jul-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	01:55	02:10	00:15	TRIPPED ON FAULT
649	05-Jul-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	01:55	02:10	00:15	TRIPPED ON FAULT
650	05-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	15:30	15:45	00:15	TRIPPED ON FAULT
651	05-Jul-24	GULBARGA	110	LINE	KIDB KUDTINI-TORANGALU	TORANGALU_110, KURGOD_110, KUDTINI_110	03:25	03:37	00:12	TRIPPED ON FAULT
652	05-Jul-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	05:44	06:02	00:18	TRIPPED ON FAULT
653	05-Jul-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	06:15	06:22	00:07	LINE CLEAR AVAILED
654	05-Jul-24	GULBARGA	110	LINE	MALLAPURA-MUNIRABAD	MALLAPURA_110	13:00	13:20	00:20	LINE CLEAR AVAILED
655	05-Jul-24	GULBARGA	110	LINE	NALWAR-YADGIR	YADGIR_110	19:50	20:00	00:10	TRIPPED ON FAULT
656	05-Jul-24	GULBARGA	110	LINE	NALWAR-YADGIR	YADGIR_110	19:50	20:00	00:10	TRIPPED ON FAULT
657	05-Jul-24	GULBARGA	110	LINE	VADAVATTI-YAPALDINI	VADAVATTI_110	20:45	21:00	00:15	TRIPPED ON FAULT
658	05-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:22	05:34	00:12	TRIPPED ON FAULT
659	05-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:22	05:27	00:05	TRIPPED ON FAULT
660	05-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
661	05-Jul-24	HASSAN	66	TRANSFORMER	HV1	AREHALLI_66	16:40	17:31	00:51	LINE CLEAR AVAILED
662	05-Jul-24	HASSAN	66	TRANSFORMER	HV1	GORUR_66	11:05	11:45	00:40	LINE CLEAR AVAILED
663	05-Jul-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGAR_66	11:03	12:53	01:50	LINE CLEAR AVAILED
664	05-Jul-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	20:20	23:00	02:40	LINE CLEAR AVAILED
665	05-Jul-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	15:57	16:15	00:18	TRIPPED ON FAULT
666	05-Jul-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	20:20	23:00	02:40	LINE CLEAR AVAILED
667	05-Jul-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	12:07	12:21	00:14	TRIPPED ON FAULT
668	05-Jul-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	11:27	11:44	00:17	TRIPPED ON FAULT
669	05-Jul-24	HASSAN	110	TRANSFORMER	HV1	MANIPAL_110	10:08	12:05	01:57	LINE CLEAR AVAILED
670	05-Jul-24	HASSAN	110	TRANSFORMER	HV1	NANDIKUR_110	12:35	13:08	00:33	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
671	05-Jul-24	HASSAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	20:28	20:50	00:22	TRIPPED ON FAULT
672	05-Jul-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	20:28	20:47	00:19	TRIPPED ON FAULT
673	05-Jul-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	20:28	20:47	00:19	TRIPPED ON FAULT
674	05-Jul-24	HASSAN	110	LINE	MSEZ-KAVOOR	MSEZ_220	20:28	20:48	00:20	TRIPPED ON FAULT
675	05-Jul-24	HASSAN	110	LINE	SHIRAL-SHKARPURA	SHIRALKOPPA_110	06:25	06:30	00:05	TRIPPED ON FAULT
676	05-Jul-24	HASSAN	110	LINE	SHIRAL--SHKARPURA	SHIRALKOPPA_110	16:38	17:43	01:05	TRIPPED ON FAULT
677	05-Jul-24	HASSAN	220	TRANSFORMER	HV1	SHIRALKOPPA_220	11:44	16:44	05:00	LINE CLEAR AVAILED
678	05-Jul-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	11:07	12:00	00:53	LINE CLEAR AVAILED
679	05-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	11:07	12:00	00:53	LINE CLEAR AVAILED
680	05-Jul-24	MYSORE	66	LINE	D.R PETE-CR NAGARA 2	NO STATIONS EFFECTED	13:38	13:46	00:07	LINE CLEAR AVAILED
681	05-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
682	05-Jul-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	15:05	15:17	00:12	TRIPPED ON FAULT
683	05-Jul-24	MYSORE	66	LINE	HEBBANI-SFC-9	NO STATIONS EFFECTED	08:40	08:56	00:16	TRIPPED ON FAULT
684	05-Jul-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	14:48	14:55	00:07	MAIN SUPPLY FAILURE
685	05-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
686	05-Jul-24	MYSORE	66	TRANSFORMER	HV2	MALAVALLI_66	14:48	14:55	00:07	MAIN SUPPLY FAILURE
687	05-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:16 (05/07/2024)			LINE CLEAR AVAILED
688	05-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)	18:16 (05/07/2024)	1728:32 HRs	LINE CLEAR AVAILED
689	05-Jul-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	15:31 (04/07/2024)	12:48 (05/07/2024)	21:16 HRs	LINE CLEAR AVAILED
690	05-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (4/7/2024)			LINE CLEAR AVAILED
691	05-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-DODDINDHUVADI	DODDINADUVADI_66 KOTTANUR_66	14:07	14:12	00:05	TRIPPED ON FAULT
692	05-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
693	05-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR1	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	14:07	14:14	00:07	TRIPPED ON FAULT
694	05-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
695	05-Jul-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	17:05	17:10	00:05	TRIPPED ON FAULT
696	05-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
697	05-Jul-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	06:05	06:10	00:04	TRIPPED ON FAULT
698	05-Jul-24	MYSORE	66	LINE	THALAKADU-PARINAMIPURA	BGPURA_66 CHIDRAVALLI_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	15:05	15:10	00:05	TRIPPED ON FAULT
699	05-Jul-24	MYSORE	220	TRANSFORMER	HV2	MADHUVANAHALLI_220	16:16	17:08	00:52	LINE CLEAR AVAILED
700	05-Jul-24	TUMKUR	66	LINE	DAVANGERE220KV-DAVANGERE	DAVANAGERE_66	11:21	12:25	01:04	LINE CLEAR AVAILED
701	05-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	11:20	12:11	00:51	LINE CLEAR AVAILED
702	05-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	11:20	11:47	00:27	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
703	05-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	11:21	11:50	00:29	LINE CLEAR AVAILED
704	05-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:21	11:52	00:31	LINE CLEAR AVAILED
705	05-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	09:02	09:04	00:02	LINE CLEAR AVAILED
706	05-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	10:14	16:30	06:16	LINE CLEAR AVAILED
707	05-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	16:11	16:21	00:10	TRIPPED ON FAULT
708	05-Jul-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	08:52	08:58	00:06	TRIPPED ON FAULT
709	05-Jul-24	TUMKUR	66	LINE	TMTP66- KORA BRAHMASANDRA	BRAHMASANDRA_66, ANANKSANDRA_66, SUNVIK_66	11:53	12:05	00:12	TRIPPED ON FAULT
710	05-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 -12.5 MVA	C.T.KERE_66	12:02	12:16	00:14	LINE CLEAR AVAILED
711	05-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 -12.5 MVA	HONALLI_66	13:05	13:30	00:25	LINE CLEAR AVAILED
712	05-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5 MVA	MELLEKATTE	16:55	17:40	00:45	TRIPPED ON FAULT
713	05-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-8MVA	CHITRAHALLI_66	14:20	14:25	00:05	TRIPPED ON FAULT
714	05-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-8MVA	CHITRAHALLI_66	23:50	23:55	00:05	TRIPPED ON FAULT
715	05-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5 MVA	THAVANAGI_66	11:20	11:50	00:30	TRIPPED ON FAULT
716	05-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5 MVA	SANIKERE_66	07:46	07:57	00:11	TRIPPED ON FAULT
717	05-Jul-24	TUMKUR	66	TRANSFORMER	TR2-12.5 MVA	TURUVANUR_66	06:00	06:13	00:13	TRIPPED ON FAULT
718	05-Jul-24	TUMKUR	66	LINE	TYVANGI_66-KUKKAWADA_66	TYAVANAGI_66	11:20	11:50	00:30	MAIN SUPPLY FAILURE
719	05-Jul-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV- SHIMOGA	ANTHRASANAHALLI_220	11:42	16:55	05:13	LINE CLEAR AVAILED
720	05-Jul-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	14:18 (04.07.2024)	11:58 (05.07.2024)	21:40	LINE CLEAR AVAILED
721	05-Jul-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	12:16 (05.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
722	06-Jul-24	BAGALKOTE	110	LINE	BAGALKOT-F3 NAVANAGAR-1	BAGALKOT_220	12:21	13:18	00:57	LINE CLEAR AVAILED
723	06-Jul-24	BAGALKOTE	110	LINE	BAGALKOT-F5 GULEDGUDDA	BAGALKOT_220	12:20	13:12	00:52	LINE CLEAR AVAILED
724	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110//11KV, HV1 (10MVA)	SHIGGAON_110	03:55	04:03	00:08	TRIPPED ON FAULT
725	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BENAKATTI_110	16:06	16:24	00:18	LINE CLEAR AVAILED
726	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULAGERICROSS_110	16:37	18:54	02:17	LINE CLEAR AVAILED
727	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	SIRSI_110	13:05	15:29	02:24	TRIPPED ON FAULT
728	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BENAKATTI_110	16:06	16:24	00:18	LINE CLEAR AVAILED
729	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KULAGERICROSS_110	16:37	18:08	01:31	LINE CLEAR AVAILED
730	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	NAVALAGI_110	16:16	16:51	00:35	LINE CLEAR AVAILED
731	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	SUARNASOUDHA_110	12:02	12:31	00:29	LINE CLEAR AVAILED
732	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	TUMMINAKATTI_110	13:32	13:42	00:10	TRIPPED ON FAULT
733	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	TUMMINAKATTI_110	13:42	16:34	02:52	TRIPPED ON FAULT
734	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KALADAGI_110	12:12	13:12	00:59	LINE CLEAR AVAILED
735	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	ZALKI_110	07:50	07:55	00:05	TRIPPED ON FAULT
736	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	ZALKI_110	11:54	16:50	04:56	LINE CLEAR AVAILED
737	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2	BAGALKOT_220	12:20	13:11	00:51	LINE CLEAR AVAILED
738	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (10MVA)	MATTIHAL_110	15:16	15:51	00:35	LINE CLEAR AVAILED
739	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	ZALKI_110	11:54	16:50	04:56	LINE CLEAR AVAILED
740	06-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2	GANESHGUDI_110	18:20	18:35	00:15	TRIPPED ON FAULT
741	06-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	BAGALKOT_220	12:21	13:10	00:49	LINE CLEAR AVAILED
742	06-Jul-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-02(103)	AHERI_220	22:50	23:00	00:10	TRIPPED ON FAULT
743	06-Jul-24	BAGALKOTE	110	LINE	AHERI220-CHANDAKAVATE (106)	AHERI_220	21:50	22:07	00:17	TRIPPED ON FAULT
744	06-Jul-24	BAGALKOTE	110	LINE	BIDNAL-NAVALGUND	BIDNAL_220	18:25	19:25	01:00	LINE CLEAR AVAILED
745	06-Jul-24	BAGALKOTE	110	LINE	DEVANAGAON-F1 RENUKA SUAGARS)	DEVANAGAON_110	16:19	17:18	00:59	LINE CLEAR AVAILED
746	06-Jul-24	BAGALKOTE	110	LINE	GADAGROAD-ANNIGERI	GADAGROAD_110	18:44	19:25	00:41	LINE CLEAR AVAILED
747	06-Jul-24	BAGALKOTE	110	LINE	INDI220-ZALKI 1	INDI_220	11:35	16:55	05:20	LINE CLEAR AVAILED
748	06-Jul-24	BAGALKOTE	110	LINE	INDI220-ZALKI 2	INDI_220	11:35	16:55	05:20	LINE CLEAR AVAILED
749	06-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	18:30	18:52	00:22	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
750	06-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
751	06-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN10 KULAGOD	MUGALAKHOD_220	11:27	13:12	01:45	LINE CLEAR AVAILED
752	06-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN11 NAGANUR	MUGALAKHOD_220	09:48	11:26	01:38	LINE CLEAR AVAILED
753	06-Jul-24	BAGALKOTE	110	LINE	NAVALAGUND-BIDNAL	NAVALAGUND_110	18:24 (06.07.2024)			LINE CLEAR AVAILED
754	06-Jul-24	BAGALKOTE	110	LINE	NAVANMAGAR(B)-220BAGALKOT 2	NAVANAGAR(B)_110	12:20	12:34	00:14	LINE CLEAR AVAILED
755	06-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
756	06-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
757	06-Jul-24	BAGALKOTE	110	LINE	SUARNASOUDAHA-MACHE	SUARNASOUDHA_110	12:49	14:49	02:00	LINE CLEAR AVAILED
758	06-Jul-24	BAGALKOTE	110	LINE	TODALBAGI-JAMAKHANDI SUGARS	TODLABAGI_110	19:56	20:00	00:04	TRIPPED ON FAULT
759	06-Jul-24	BAGALKOTE	110	LINE	VADAGOAN-MACHE	VADAGOAN_110	18:18 (05.07.2024)	07:20 (06.07.2024)	13:02:00	LINE CLEAR AVAILED
760	06-Jul-24	BAGALKOTE	110	LINE	VADGAON-MACHE	VADGAON_110	07:34	14:46	07:12	LINE CLEAR AVAILED
761	06-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
762	06-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	BAGALKOT_220	12:21	13:09	00:48	LINE CLEAR AVAILED
763	06-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1,LV1	BIDNAL_220,ANNIGERI_110,NAVAL GUND_110,GADAG ROAD_110,PH COMPOUND_110	18:25	18:50	00:25	TRIPPED ON FAULT
764	06-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUT2	HAVERI_220	12:15 (05.07.2024)	20:56 (06.07.2024)	32:41:00	LINE CLEAR AVAILED
765	06-Jul-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1(SHARAVATHI2)	SIRSI_220	12:43	16:56	04:13	LINE CLEAR AVAILED
766	06-Jul-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	16:25	16:30	00:05	LINE CLEAR AVAILED
767	06-Jul-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	16:33	17:01	00:28	TRIPPED ON FAULT
768	06-Jul-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - ORACLE EHT	ORACLE(EHT)	12:25	12:30	00:05	LINE CLEAR AVAILED
769	06-Jul-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	16:09	16:18	00:09	TRIPPED ON FAULT
770	06-Jul-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADUBISANAHALLI (TAP)	BAGMANE WORLD TECH PARK	16:48	16:52	00:04	LINE CLEAR AVAILED
771	06-Jul-24	BANGALORE	66	LINE	66KV HANUMANTHANAGARA - YEDAMADU	HANUMANTHANAGARA	08:00	08:05	00:05	LINE CLEAR AVAILED
772	06-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	07:33	07:47	00:14	TRIPPED ON FAULT
773	06-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	08:20	08:43	00:23	TRIPPED ON FAULT
774	06-Jul-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST	22:03	22:07	00:04	LINE CLEAR AVAILED
775	06-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	HANUMANTHANAGARA	16:05	16:10	00:05	LINE CLEAR AVAILED
776	06-Jul-24	BANGALORE	66	LINE	66KV KEMPANAHALLI - AGALAKOTE	AGALAKOTE	19:20	19:30	00:10	TRIPPED ON FAULT
777	06-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66 _DG3	MANYATHA TECH PARK 66	15:48	15:51	00:03	LINE CLEAR AVAILED
778	06-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY _DG3	SHOBHA CITY	16:35	16:37	00:02	LINE CLEAR AVAILED
779	06-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASLU	19:04	19:26	00:22	TRIPPED ON FAULT
780	06-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	19:04	19:26	00:22	TRIPPED ON FAULT
781	06-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	07:28	07:42	00:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
782	06-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELCAST	10:30	10:33	00:03	LINE CLEAR AVAILED
783	06-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:01	10:10	00:09	LINE CLEAR AVAILED
784	06-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	18:06	18:10	00:04	LINE CLEAR AVAILED
785	06-Jul-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE RAILWAY	16:00	23:59	07:59	TRIPPED ON FAULT
786	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	07:33	07:47	00:14	MAIN SUPPLY FAILURE
787	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	08:20	08:48	00:28	MAIN SUPPLY FAILURE
788	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CESSNA	14:10	14:15	00:05	LINE CLEAR AVAILED
789	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CESSNA	16:33	17:00	00:27	TRIPPED ON FAULT
790	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GUNDAMGERE	19:05	19:32	00:27	TRIPPED ON FAULT
791	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUDUR	07:50	07:55	00:05	TRIPPED ON FAULT
792	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	14:40	15:15	00:35	LINE CLEAR AVAILED
793	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	15:40	17:05	01:25	LINE CLEAR AVAILED
794	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SULIBELE	13:51	13:58	00:07	TRIPPED ON FAULT
795	06-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TAYALUR	14:20	14:22	00:02	LINE CLEAR AVAILED
796	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CESSNA	12:20	12:25	00:05	LINE CLEAR AVAILED
797	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CESSNA	16:33	17:30	00:57	TRIPPED ON FAULT
798	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GUNDAMGERE	12:15	12:30	00:15	TRIPPED ON FAULT
799	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GUNDAMGERE	12:30	12:56	00:26	LINE CLEAR AVAILED
800	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GUNDLU KOTTUR	13:45	13:50	00:05	LINE CLEAR AVAILED
801	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MARALAWADI	00:00	00:05	00:05	TRIPPED ON FAULT
802	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	10:50	11:20	00:30	LINE CLEAR AVAILED
803	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	05:13	05:26	00:13	TRIPPED ON FAULT
804	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TAMAKA	10:40	11:30	00:50	LINE CLEAR AVAILED
805	06-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TAYALUR	10:30	14:20	03:50	LINE CLEAR AVAILED
806	06-Jul-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	07:33	07:47	00:14	MAIN SUPPLY FAILURE
807	06-Jul-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	08:20	08:48	00:28	MAIN SUPPLY FAILURE
808	06-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 1	BANGARPET RAILWAY	09:21	15:15	05:54	LINE CLEAR AVAILED
809	06-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 1	BANGARPET RAILWAY	09:21	15:15	05:54	LINE CLEAR AVAILED
810	06-Jul-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	EXORA 220	18:53	19:17	00:24	TRIPPED ON FAULT
811	06-Jul-24	BANGALORE	220	LINE	220KV MALUR 220 - SARJAPURA 220 - VIKAS TECH PARK 220 - EXORA 220 1	EXORA 220	19:25	19:43	00:18	TRIPPED ON FAULT
812	06-Jul-24	BANGALORE	220	TRANSFORMER	HV2	EXORA 220	16:33	16:57	00:24	TRIPPED ON FAULT
813	06-Jul-24	BANGALORE	220	TRANSFORMER	HV2	EXORA 220	18:53	19:17	00:24	TRIPPED ON FAULT
814	06-Jul-24	BANGALORE	220	TRANSFORMER	HV2	EXORA 220	19:25	19:43	00:18	TRIPPED ON FAULT
815	06-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HARAPPANAHALLI	HARAPPANAHALLI_66	05:57	06:03	00:06	TRIPPED ON FAULT
816	06-Jul-24	GULBARGA	110	LINE	AFZALPUR-AHERI	KARAJAGI_110,AFZALPUR_110	15:57	16:10	00:13	MAIN SUPPLY FAILURE
817	06-Jul-24	GULBARGA	110	LINE	AFZALPUR-AHERI	KARAJAGI_110,AFZALPUR_110	16:27	17:10	00:43	MAIN SUPPLY FAILURE
818	06-Jul-24	GULBARGA	110	LINE	AFZALPUR-AHERI	KARAJAGI_110,AFZALPUR_110	15:57	16:10	00:13	MAIN SUPPLY FAILURE
819	06-Jul-24	GULBARGA	110	LINE	AFZALPUR-AHERI	KARAJAGI_110,AFZALPUR_110	16:27	17:10	00:43	LINE CLEAR AVAILED
820	06-Jul-24	GULBARGA	110	LINE	CHITAPUR-KORWAR	KORWAR_110	20:30	20:35	00:05	MAIN SUPPLY FAILURE
821	06-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-KEMBHAVI	KEMBHAVI_110	04:25	04:41	00:16	TRIPPED ON FAULT
822	06-Jul-24	GULBARGA	110	TRANSFORMER	HV1	BISILHALLI_110	19:24	19:34	00:10	TRIPPED ON FAULT
823	06-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	16:22	17:12	00:50	LINE CLEAR AVAILED
824	06-Jul-24	GULBARGA	110	LINE	KALBURGI SOUTH-WEST1	KALBURGI SOUTH_110	20:40	21:10	00:30	TRIPPED ON FAULT
825	06-Jul-24	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	23:17	23:27	00:10	TRIPPED ON FAULT
826	06-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	03:40	03:50	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
827	06-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	23:15	23:25	00:10	TRIPPED ON FAULT
828	06-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SUZLON	SINDHANOOR_220	04:30	04:40	00:10	TRIPPED ON FAULT
829	06-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADIR_110	04:40	04:50	00:10	MAIN SUPPLY FAILURE
830	06-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADIR_110	04:40	17:45	13:05	MAIN SUPPLY FAILURE
831	06-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	01:51	02:02	00:11	TRIPPED ON FAULT
832	06-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
833	06-Jul-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	11:25	11:42	00:17	TRIPPED ON FAULT
834	06-Jul-24	HASSAN	66	LINE	HNPR2-HASS3	HNPUA_220	11:16	11:20	00:04	LINE CLEAR AVAILED
835	06-Jul-24	HASSAN	66	TRANSFORMER	HV1 CB	UGANE_66	10:35	12:00	01:25	LINE CLEAR AVAILED
836	06-Jul-24	HASSAN	66	TRANSFORMER	HV2	MALLIPATNA_66	11:20	12:30	01:10	TRIPPED ON FAULT
837	06-Jul-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	09:50	10:10	00:20	TRIPPED ON FAULT
838	06-Jul-24	HASSAN	66	LINE	UGANE-L2 CB	UGANE_66	10:35	12:00	01:25	LINE CLEAR AVAILED
839	06-Jul-24	HASSAN	110	TRANSFORMER	HV1	GERUMARA_110	16:16	17:09	00:53	LINE CLEAR AVAILED
840	06-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	10:54	11:26	00:32	LINE CLEAR AVAILED
841	06-Jul-24	HASSAN	110	TRANSFORMER	HV1CBreaker	KARKALA_110	11:20	11:30	00:10	LINE CLEAR AVAILED
842	06-Jul-24	HASSAN	110	TRANSFORMER	HV2	GERUMARA_110	16:17	17:09	00:52	LINE CLEAR AVAILED
843	06-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	11:12	11:32	00:20	LINE CLEAR AVAILED
844	06-Jul-24	HASSAN	110	LINE	MRSSHM-TRKER	MRSMSG_220	09:30	13:11	03:41	LINE CLEAR AVAILED
845	06-Jul-24	HASSAN	110	LINE	MSEZ-KAVOR	MSEZ_220	08:00	08:33	00:33	TRIPPED ON FAULT
846	06-Jul-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:02	12:40	01:38	LINE CLEAR AVAILED
847	06-Jul-24	HASSAN	220	LINE	HGUNJE-VRH CBreaker	HEGGUNJE_220	11:50	20:01	08:11	TRIPPED ON FAULT
848	06-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMSG_220	02:21	09:51	07:30	TRIPPED ON FAULT
849	06-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR3	gen_varahi	11:50	20:03	08:13	TRIPPED ON FAULT
850	06-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	02:21	09:51	07:30	TRIPPED ON FAULT
851	06-Jul-24	MYSORE	66	LINE	CHUNCHUNKATTE-BETTADAPURA	KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66	07:05	07:15	00:10	TRIPPED ON FAULT
852	06-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
853	06-Jul-24	MYSORE	66	LINE	GAVADGERE-CHUNCHUNKATTE	NO STATIONS EFFECTED	07:05	07:17	00:12	TRIPPED ON FAULT
854	06-Jul-24	MYSORE	66	LINE	GOLUR-DEVNUR(N'GUD)	GOLURU(GEEKALLI)_66 DEVANOORNGUDU_66 SUTTUR_66	06:29	06:34	00:05	TRIPPED ON FAULT
855	06-Jul-24	MYSORE	66	LINE	GOLUR-KADAKOLA	GOLURU(GEEKALLI)_66	06:29	06:34	00:05	TRIPPED ON FAULT
856	06-Jul-24	MYSORE	66	LINE	HANNUR-AJJIPURA	BANDALLI_66 AJJIPURA_66 RAMAPURA_66 COWDALLI_66 &MARTHALLI_66	09:45	09:50	00:04	TRIPPED ON FAULT
857	06-Jul-24	MYSORE	66	LINE	HARADANJ-LAXJEET	NO STATIONS EFFECTED	23:50	23:55	00:05	TRIPPED ON FAULT
858	06-Jul-24	MYSORE	66	LINE	HEBBANI-SFC8	NO STATIONS EFFECTED	05:50	06:02	00:12	TRIPPED ON FAULT
859	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	GARUDANAUKKADA_66	11:25	12:33	01:08	TRIPPED ON FAULT
860	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	MYSORESOUTH_66	11:50	12:47	00:56	LINE CLEAR AVAILED
861	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	14:29	14:34	00:04	TRIPPED ON FAULT
862	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_66	15:00	15:04	00:03	TRIPPED ON FAULT
863	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
864	06-Jul-24	MYSORE	66	TRANSFORMER	HV1	VAJMANGALA_66	12:45	12:51	00:06	TRIPPED ON FAULT
865	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	GARUDANAUKKADA_66	11:25	12:33	01:08	TRIPPED ON FAULT
866	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	GUNDLUPETE_66	11:08	11:18	00:10	TRIPPED ON FAULT
867	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	11:21	11:50	00:28	LINE CLEAR AVAILED
868	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	12:49	13:46	00:57	LINE CLEAR AVAILED
869	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	NAGAMANGALA_66	10:35	16:50	06:15	LINE CLEAR AVAILED
870	06-Jul-24	MYSORE	66	TRANSFORMER	HV2	SFCSIVA_66	12:48	16:24	03:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
871	06-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:16 (05/07/2024)			LINE CLEAR AVAILED
872	06-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (4/7/2024)			LINE CLEAR AVAILED
873	06-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-BETTADAPURA	BETTADAPURA_66	07:04	07:15	00:11	TRIPPED ON FAULT
874	06-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
875	06-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
876	06-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
877	06-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (6/7/24)			LINE CLEAR AVAILED
878	06-Jul-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI-66KV CHELUR LINE	66KV CHELUR, HOSAKERE, HAGALAWADI, NANDIHALLI CROSS	05:57	06:24	00:27	TRIPPED ON FAULT
879	06-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV HIRIYUR LINE	66KV J N KOTE, AIMANGALA,MALLAPANAHALLI	14:04	14:13	00:09	TRIPPED ON FAULT
880	06-Jul-24	TUMKUR	66	LINE	66KV KEREILACHI-66KV SHYGALE LINE	WATER SUPPLY	10:20	10:35	00:15	TRIPPED ON FAULT
881	06-Jul-24	TUMKUR	66	LINE	66KV SANTEBENNUR-66KV KEREILACHI LINE	66KV KEREILACHI,SHYGALE	10:20	10:25	00:05	TRIPPED ON FAULT
882	06-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	04:28	04:50	00:22	LINE CLEAR AVAILED
883	06-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
884	06-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
885	06-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- SUZLON 1	SUZLON1_IPP_66	18:30	18:35	00:05	MAIN SUPPLY FAILURE
886	06-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	04:56	05:16	00:20	LINE CLEAR AVAILED
887	06-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	16:08	16:34	00:26	LINE CLEAR AVAILED
888	06-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:08	16:34	00:26	LINE CLEAR AVAILED
889	06-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	16:08	16:34	00:26	LINE CLEAR AVAILED
890	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	KOLALA_66	12:41	19:07	06:26	LINE CLEAR AVAILED
891	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	TURUVANUR_66	09:11	09:26	00:15	TRIPPED ON FAULT
892	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	CHANNAGIRI_66	10:25	11:20	00:55	LINE CLEAR AVAILED
893	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	CHANNAGIRI_66	12:48	13:08	00:20	LINE CLEAR AVAILED
894	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-2(12.5MVA)	KOLALA_66	12:41	19:08	06:27	LINE CLEAR AVAILED
895	06-Jul-24	TUMKUR	66	TRANSFORMER	TR-2(20MVA)	GOPPENAHALLI_66	11:30	11:35	00:05	TRIPPED ON FAULT
896	06-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER - 3-220KV CHITRADURGA	66KV BHARAMSAGARA, KNNL,VIJAPURA,SIRIGERE,J N KOTE, AIMANGALA,MALLAPANAHALLI	18:30	18:35	00:05	TRIPPED ON FAULT
897	06-Jul-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	12:16 (05.07.2024)	20:56 (06.07.2024)	1 DAY 8 HRS 40 MINS	LINE CLEAR AVAILED
898	06-Jul-24	TUMKUR	220	LINE	HONNALLI 220KV- SUZLON1	SUZLON_IPP_66	15:44	15:52	00:08	LINE CLEAR AVAILED
899	06-Jul-24	TUMKUR	220	LINE	HONNALLI 220KV- SUZLON1	SUZLON_IPP_66	14:15	14:55	00:40	LINE CLEAR AVAILED
900	06-Jul-24	TUMKUR	220	LINE	HONNALLI 220KV- SUZLON2	SUZLON_IPP_66	15:00	15:37	00:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
901	06-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 220KV 2	GUTUR_400	14:13 (06.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
902	06-Jul-24	TUMKUR	400	TRANSFORMER	TR-1(315MVA)	GUTTUR_400	12:50	19:58	07:07	LINE CLEAR AVAILED
903	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- GHATNATTI	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
904	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- KARIMASUTI	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
905	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110//11KV, HV1 (20MVA)	RATTIHALLI_110	12:46	12:55	00:09	TRIPPED ON FAULT
906	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HEBBALLI_110	10:58	16:05	05:07	LINE CLEAR AVAILED
907	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULAGERICROSS_110	15:00 (07.07.2024)			LINE CLEAR AVAILED
908	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BJCTY (THORVI)_110	11:28	14:33	03:05	TRIPPED ON FAULT
909	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (HV2 20MVA)	MACHE_110	12:42	13:30	00:48	LINE CLEAR AVAILED
910	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KULAGERICROSS_110	15:00	15:11	00:11	LINE CLEAR AVAILED
911	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (20MVA)	BELAGAVI_110	12:40	13:23	00:43	LINE CLEAR AVAILED
912	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
913	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	08:40	08:55	00:15	TRIPPED ON FAULT
914	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	14:25	14:45	00:20	TRIPPED ON FAULT
915	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	RANEBENNUR_220	07:50	07:58	00:08	TRIPPED ON FAULT
916	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (10 MVA)	ANKOLA_110	12:53	13:08	00:15	TRIPPED ON FAULT
917	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2	GANESHGUDI_110	21:07 (07.07.2024)			TRIPPED ON FAULT
918	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	HALIYAL_110	12:0 (07.07.2024)			TRIPPED ON FAULT
919	07-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	HALIYAL_110	12:00	23:59	11:59	TRIPPED ON FAULT
920	07-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
921	07-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
922	07-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV3	ATHANI_220	21:30	23:03	01:33	TRIPPED ON FAULT
923	07-Jul-24	BAGALKOTE	110	LINE	AHERI220-SINDAGI (107)	AHERI_220	11:45	13:10	01:25	LINE CLEAR AVAILED
924	07-Jul-24	BAGALKOTE	110	LINE	AHERI220-SINDAGI (107)	AHERI_220	11:45	13:10	01:25	LINE CLEAR AVAILED
925	07-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA 1	AMBEWADI_220	21:07 (07.07.2024)			TRIPPED ON FAULT
926	07-Jul-24	BAGALKOTE	110	LINE	ANMOD-GOA-2	ANMOD_110	05:40	06:00	00:20	TRIPPED ON FAULT
927	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- AIGALI 1	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
928	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- AIGALI 2	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
929	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- HALYAL	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
930	07-Jul-24	BAGALKOTE	110	LINE	ATHANI- KSSKN	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
931	07-Jul-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
932	07-Jul-24	BAGALKOTE	110	LINE	ATHANI220- ATHANI	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
933	07-Jul-24	BAGALKOTE	110	LINE	BELGAUM220-HUKKERI(UCHAGOAN)	BELGAUM_220	12:08	12:23	00:15	TRIPPED ON FAULT
934	07-Jul-24	BAGALKOTE	110	LINE	KAMBAGI-F1 (MAMADAPUR)	KAMBAGI_110	21:50	22:23	00:33	LINE CLEAR AVAILED
935	07-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-KONNUR	KULAGERICROSS_110	10:51	15:59	05:08	LINE CLEAR AVAILED
936	07-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-MRN SUGARS	KULAGERICROSS_110	14:37	14:44	00:07	TRIPPED ON FAULT
937	07-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
938	07-Jul-24	BAGALKOTE	110	LINE	NAVALAGUND-BIDNAL	NAVALAGUND_110	18:24 (06.07.2024)	08:31 (07.07.2024)	14:07	LINE CLEAR AVAILED
939	07-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
940	07-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
941	07-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 1	ATHANI_220	21:30	22:55	01:25	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
942	07-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 2	STATION NOT AFFECTED ATHANI_220	21:12 (07.07.2024)			TRIPPED ON FAULT
943	07-Jul-24	BAGALKOTE	220	LINE	ATHANI-KUDUCHI	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
944	07-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
945	07-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
946	07-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	ATHANI_220	21:30	22:30	01:00	MAIN SUPPLY FAILURE
947	07-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	ATHANI_220	21:30	22:58	01:28	TRIPPED ON FAULT
948	07-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	KUDUCHI_220	21:49	22:03	00:14	TRIPPED ON FAULT
949	07-Jul-24	BAGALKOTE	220	LINE	ATHANI-MAHALINGPUR	ATHANI_220	21:30	22:49	01:19	MAIN SUPPLY FAILURE
950	07-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUT1	HAVERI_220	9:36 (07.07.2024)			LINE CLEAR AVAILED
951	07-Jul-24	BAGALKOTE	220	LINE	KUDUCHI-ATHANI	KUDUCHI_220	21:49	22:30	00:41	TRIPPED ON FAULT
952	07-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR-ATHANI	MAHALINGAPUR_220	21:49	22:44	00:55	TRIPPED ON FAULT
953	07-Jul-24	BAGALKOTE	220	LINE	SIRSI-SHARAVATHI1(SHARAVATHI2)	SIRSI_220	07:57	18:23	10:26	TRIPPED ON FAULT
954	07-Jul-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - ALIPURA	ALIPURA, THONDEBHAVI	12:15	12:50	00:35	MAIN SUPPLY FAILURE
955	07-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURVANKARA PALM BEACH	10:21	10:24	00:03	LINE CLEAR AVAILED
956	07-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY_DG3	SHOBHA CITY	11:07	12:11	01:04	LINE CLEAR AVAILED
957	07-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	10:22	10:30	00:08	LINE CLEAR AVAILED
958	07-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST VIEW	15:21	15:25	00:04	LINE CLEAR AVAILED
959	07-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	15:40	15:48	00:08	LINE CLEAR AVAILED
960	07-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	08:45	20:40	11:55	LINE CLEAR AVAILED
961	07-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI	08:45	20:40	11:55	LINE CLEAR AVAILED
962	07-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	10:01	10:09	00:08	LINE CLEAR AVAILED
963	07-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA, TALAGAWARA	17:43	17:49	00:06	LINE CLEAR AVAILED
964	07-Jul-24	BANGALORE	66	LINE	66KV VIDYANAGAR - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURVANKARA PALM BEACH	12:14	12:17	00:03	LINE CLEAR AVAILED
965	07-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	22:58	23:03	00:05	LINE CLEAR AVAILED
966	07-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SHIVANAHALLI DAIRY	09:45	13:00	03:15	TRIPPED ON FAULT
967	07-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KODIGEHALLI	14:14	15:00	00:46	LINE CLEAR AVAILED
968	07-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KONDASAPURA	22:58	23:03	00:05	LINE CLEAR AVAILED
969	07-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	SHIMSHA	13:05	13:40	00:35	TRIPPED ON FAULT
970	07-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2	NO STATION AFFECTED	20:57	23:59	03:02	TRIPPED ON FAULT
971	07-Jul-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	11:20	11:30	00:10	TRIPPED ON FAULT
972	07-Jul-24	GULBARGA	66	LINE	TELGI-YARGUNTA	OBJ HALLI_66	12:30	17:35	05:05	LINE CLEAR AVAILED
973	07-Jul-24	GULBARGA	110	LINE	CHITAPUR-KORWAR	KORWAR_110	05:31	05:38	00:07	TRIPPED ON FAULT
974	07-Jul-24	GULBARGA	110	LINE	CHITAPUR-KORWAR	KORWAR_110	05:38	06:06	00:28	TRIPPED ON FAULT
975	07-Jul-24	GULBARGA	110	LINE	CHITAPUR-KORWAR	KORWAR_110	05:31	05:38	00:07	TRIPPED ON FAULT
976	07-Jul-24	GULBARGA	110	LINE	CHITAPUR-KORWAR	KORWAR_110	05:38	06:06	00:28	TRIPPED ON FAULT
977	07-Jul-24	GULBARGA	110	LINE	HALBARGA-HALLIKHED	HALLIKHED_110	19:00	19:15	00:15	TRIPPED ON FAULT
978	07-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	23:50	23:59	00:09	TRIPPED ON FAULT
979	07-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	23:50	23:55	00:05	TRIPPED ON FAULT
980	07-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	01:09	01:14	00:05	TRIPPED ON FAULT
981	07-Jul-24	GULBARGA	110	LINE	KAPNOOR-WEST2	KALBURGI WEST_110	00:35	00:55	00:20	TRIPPED ON FAULT
982	07-Jul-24	GULBARGA	110	LINE	KHANAPUR-YADGIR	YADGIR_110	00:10	00:20	00:10	TRIPPED ON FAULT
983	07-Jul-24	GULBARGA	110	LINE	KHANAPUR-YADGIR	YADGIR_110	03:10	05:14	02:04	TRIPPED ON FAULT
984	07-Jul-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	01:05	01:10	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
985	07-Jul-24	GULBARGA	110	LINE	SHAHBAD-CHOWDAPUR	SAGNOOR_110	04:04	04:14	00:10	TRIPPED ON FAULT
986	07-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SUZLON	SINDHANOOR_220	05:25	05:35	00:10	TRIPPED ON FAULT
987	07-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	03:20	03:35	00:15	TRIPPED ON FAULT
988	07-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:40	05:45	00:05	TRIPPED ON FAULT
989	07-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:40	05:45	00:05	TRIPPED ON FAULT
990	07-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-FIROZABAD-2	HATTIGUDUR_220	02:22	02:38	00:16	TRIPPED ON FAULT
991	07-Jul-24	GULBARGA	220	TRANSFORMER	HV2	BADALADUKU_220	09:05	11:00	01:55	LINE CLEAR AVAILED
992	07-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
993	07-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	12:05	19:45	07:40	TRIPPED ON FAULT
994	07-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	12:07	20:28	08:21	TRIPPED ON FAULT
995	07-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	14:15	14:25	00:10	TRIPPED ON FAULT
996	07-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	18:05	18:15	00:10	TRIPPED ON FAULT
997	07-Jul-24	HASSAN	110	TRANSFORMER	HV2 CB	JADE_110	17:20	18:02	00:42	TRIPPED ON FAULT
998	07-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	15:32	16:00	00:28	TRIPPED ON FAULT
999	07-Jul-24	HASSAN	110	LINE	MSEZ-BAIKAMPADY	MSEZ_220	08:00	08:24	00:24	TRIPPED ON FAULT
1000	07-Jul-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	15:32	15:58	00:26	TRIPPED ON FAULT
1001	07-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharaavthy	21:23(7.7.2024)			LINE CLEAR AVAILED
1002	07-Jul-24	HASSAN	220	LINE	SHRAVTY-TALAGUPPA 2	gen_sharaavthy	15:50(7.7.2024)			TRIPPED ON FAULT
1003	07-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	21:23(7.7.2024)			LINE CLEAR AVAILED
1004	07-Jul-24	HASSAN	220	LINE	TALAGU-SGS2	TALAGUPPA_400	15:50(07.07.2023)			TRIPPED ON FAULT
1005	07-Jul-24	HASSAN	400	LINE	HASSAN4-UPCL2	HASSAN_400	08:49	17:32	08:43	LINE CLEAR AVAILED
1006	07-Jul-24	HASSAN	400	LINE	HBNHL-SHANTHIGRAMA	HEBBANAHALLI_400	08:49	17:32	08:43	LINE CLEAR AVAILED
1007	07-Jul-24	HASSAN	400	LINE	HBNHL-UPCL2	HEBBANAHALLI_400	09:06	17:32	08:26	LINE CLEAR AVAILED
1008	07-Jul-24	HASSAN	400	LINE	UPCL-HASSAN2	UPCL_gen	09:06	18:37	09:31	LINE CLEAR AVAILED
1009	07-Jul-24	MYSORE	66	LINE	CR NAGARA-DR PETE 1	DODDARAYAPET_66	09:27	16:59	07:32	LINE CLEAR AVAILED
1010	07-Jul-24	MYSORE	66	LINE	CR NAGARA-DR PETE 2	NO STATIONS EFFECTED	09:27	16:57	07:30	LINE CLEAR AVAILED
1011	07-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
1012	07-Jul-24	MYSORE	66	LINE	HANNUR-ECOREN_WIND	NO STATIONS EFFECTED	12:37 (07/07/2024)			LINE CLEAR AVAILED
1013	07-Jul-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	13:54	14:18	00:24	TRIPPED ON FAULT
1014	07-Jul-24	MYSORE	66	LINE	HOOTAGALLI-BEML	NO STATIONS EFFECTED	00:50	01:14	00:23	TRIPPED ON FAULT
1015	07-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	17:06	17:09	00:03	TRIPPED ON FAULT
1016	07-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1017	07-Jul-24	MYSORE	66	TRANSFORMER	HV2	YELANDUR_66	05:40	06:15	00:35	TRIPPED ON FAULT
1018	07-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:16 (05/07/2024)			LINE CLEAR AVAILED
1019	07-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (4/7/2024)			LINE CLEAR AVAILED
1020	07-Jul-24	MYSORE	66	LINE	KOTTANUR-HANNUR1	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	12:37	13:05	00:28	TRIPPED ON FAULT
1021	07-Jul-24	MYSORE	66	LINE	MADDUR-SOMANAHALLI	MADDUR_66SOMANAHALLI_66	14:51	15:01	00:10	TRIPPED ON FAULT
1022	07-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1023	07-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1024	07-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	05:31	05:37	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1025	07-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-BG NAGARA	BGNAGARA_66VADERALLI_66ADICHUNCHANAGIRI_66KADABALLI_66	05:44	05:52	00:08	TRIPPED ON FAULT
1026	07-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
1027	07-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (6/7/24)			LINE CLEAR AVAILED
1028	07-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 2	66KV KUKKUWADA, SHYAGALE, THAVANAGI, WATER WORKS	13:01	13:14	00:13	TRIPPED ON FAULT
1029	07-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MELLEKATTE LINE	66KV MELLEKATTE,KADAJJI	12:17	12:27	00:10	TRIPPED ON FAULT
1030	07-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV BEVINAHALLI LINE	66KV BEVINAHALLI, J G HALLI, K R HALLI	17:20	17:40	00:20	TRIPPED ON FAULT
1031	07-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV THALLAK LINE	66KV RANGENAHALLY	13:01	13:25	00:24	TRIPPED ON FAULT
1032	07-Jul-24	TUMKUR	66	LINE	66KV KUKKAWADA-220KV DAVANGERE LINE 1	KUKKAWADA_66	12:58	13:08	00:10	TRIPPED ON FAULT
1033	07-Jul-24	TUMKUR	66	LINE	66KV MATHOD-66KV KANCHIPURA LINE	66KV KANCHIPURA	09:50	10:00	00:10	TRIPPED ON FAULT
1034	07-Jul-24	TUMKUR	66	LINE	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	05:49	06:07	00:17	TRIPPED ON FAULT
1035	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	ANCHEPALYA_66	16:30	16:55	00:25	LINE CLEAR AVAILED
1036	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	MATHOD_66	09:00	09:11	00:11	TRIPPED ON FAULT
1037	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	MATHOD_66	15:22	15:33	00:11	TRIPPED ON FAULT
1038	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	CHANNAGIRI_66	11:21	11:26	00:05	TRIPPED ON FAULT
1039	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	CHANNAGIRI_66	12:00	12:36	00:36	LINE CLEAR AVAILED
1040	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	HALURAMESHWARA_66	22:46	22:55	00:09	TRIPPED ON FAULT
1041	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-2(12.5MVA)	HOSADURGA_66	09:30	13:35	04:05	LINE CLEAR AVAILED
1042	07-Jul-24	TUMKUR	66	TRANSFORMER	TR-2(20MVA)	CHANNAGIRI_66	12:00	12:36	00:36	LINE CLEAR AVAILED
1043	07-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER - 3-220KV THALLAK	66KV CHALLAKERE ,MYLANAHALLI, VV.PURA ,GOWRASAMUDRA ,WELSPUN	12:31	12:37	00:06	TRIPPED ON FAULT
1044	07-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-220KV PGCIL LINE	CHITRADURGA_220	12:28	20:44	08:16	TRIPPED ON FAULT
1045	07-Jul-24	TUMKUR	220	LINE	220kv THALLAK - 220kv HIRIYUR LINE	220KV HIRIYUR	15:33	15:44	00:11	LINE CLEAR AVAILED
1046	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV BARC LINE-1	220KV BARC	12:31	13:23	00:52	TRIPPED ON FAULT
1047	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV BARC LINE-1	220KV BARC	13:42	14:36	00:54	TRIPPED ON FAULT
1048	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV CHITRADURGA LINE	220KV THALLAK	12:31	18:48	06:17	TRIPPED ON FAULT
1049	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV H.M HOLE LINE 1	220KV THALLAK	12:31	13:58	01:27	TRIPPED ON FAULT
1050	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITAU LINE-1	220KV SAGITAU	12:59	13:20	00:21	TRIPPED ON FAULT
1051	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITAU LINE-1	220KV SAGITAU	13:42	14:37	00:55	TRIPPED ON FAULT
1052	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITAU LINE-1 & 2	220KV SAGITAU	12:31	12:56	00:25	TRIPPED ON FAULT
1053	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITAU LINE-2	220KV SAGITAU	12:59	13:27	00:28	TRIPPED ON FAULT
1054	07-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITAU LINE-2	220KV SAGITAU	13:42	14:38	00:56	TRIPPED ON FAULT
1055	07-Jul-24	TUMKUR	220	LINE	400KV GUTTUR - 220KV CHITRADURGA LINE	CHITRADURGA_220	11:57	14:09	02:12	TRIPPED ON FAULT
1056	07-Jul-24	TUMKUR	220	LINE	400KV GUTTUR - 220KV CHITRADURGA LINE	CHITRADURGA_220	14:10	20:30	06:20	LINE CLEAR AVAILED
1057	07-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- 220KV KAIGA LINE 2	GUTUR_400	14:13 (06.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
1058	07-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI LINE 1	HAVERI_220	11:45 (07.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
1059	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULAGERICROSS_110	15:00 (07.07.2024)	20:09 (08.07.2024)	29:09:00	LINE CLEAR AVAILED
1060	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	12:24	13:12	00:48	LINE CLEAR AVAILED
1061	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	08:40	08:55	00:15	TRIPPED ON FAULT
1062	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MK HUBLI_220	14:25	14:45	00:20	TRIPPED ON FAULT
1063	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NAVALGUND_110	13:20	15:54	02:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1064	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MRUTHYUNJAYANAGAR_110	18:41	18:46	00:05	TRIPPED ON FAULT
1065	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	RAIBAG_110	10:25	11:06	00:41	TRIPPED ON FAULT
1066	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	RAIBAG_110	12:06	13:29	01:23	TRIPPED ON FAULT
1067	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1A(10MVA)	JAMAKHANDI_110	12:26	13:37	01:11	LINE CLEAR AVAILED
1068	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	ALBAL_110	16:07	17:44	01:37	LINE CLEAR AVAILED
1069	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2A(10MVA)	JAMAKHANDI_110	12:26	13:37	01:11	LINE CLEAR AVAILED
1070	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2	GANESHGUDI_110	21:07 (07.07.2024)	11:53 (08.07.2024)	14:46:00	TRIPPED ON FAULT
1071	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	HALIYAL_110	12:0 (07.07.2024)	10:55 (08.07.2024)	22:55:00	TRIPPED ON FAULT
1072	08-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3	HALIYAL_110	12:10	19:25	07:15	TRIPPED ON FAULT
1073	08-Jul-24	BAGALKOTE	110	LINE	ALBAL-RAY SOLAR	ALBAL_110	11:30	13:30	02:00	LINE CLEAR AVAILED
1074	08-Jul-24	BAGALKOTE	110	LINE	ALBAL-SAI PRIYA SUGAR	ALBAL_110	11:38	13:30	01:52	LINE CLEAR AVAILED
1075	08-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA 1	AMBEWADI_220	21:07 (07.07.2024)	11:54 (08.07.2024)	14:47:00	TRIPPED ON FAULT
1076	08-Jul-24	BAGALKOTE	110	LINE	BANAHATTI-JAMAKANDI(NAVALAGI)	BANAHATTI_110	12:27	16:55	04:28	LINE CLEAR AVAILED
1077	08-Jul-24	BAGALKOTE	110	LINE	HUBLI-TARIHAL 1	HUBLI_220	08:07	13:23	05:16	TRIPPED ON FAULT
1078	08-Jul-24	BAGALKOTE	110	LINE	HUBLI-TARIHAL 2	HUBLI_220	10:39	13:24	02:45	LINE CLEAR AVAILED
1079	08-Jul-24	BAGALKOTE	110	LINE	INDI220-HIRE BENUR	HIRE BENUR_110	20:07	20:17	00:10	TRIPPED ON FAULT
1080	08-Jul-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR(NAVALAGI)	JAMAKHANDI_110	12:14	17:03	04:49	LINE CLEAR AVAILED
1081	08-Jul-24	BAGALKOTE	110	LINE	JAMAKHANDI-PRABHULINGESHWAR(SIDDAPUR)	JAMAKHANDI_110	16:58 (08.07.2024)			LINE CLEAR AVAILED
1082	08-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1083	08-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN12(PG HUNSHYAL)	220KV MUGALAKHOD	11:28	11:45	00:17	TRIPPED ON FAULT
1084	08-Jul-24	BAGALKOTE	110	LINE	NAVALAGI-F1(JAMAKHANDI)	NAVALAGI_110	12:24	16:25	04:01	LINE CLEAR AVAILED
1085	08-Jul-24	BAGALKOTE	110	LINE	NAVALAGI-F2(BANAHATTI)	NAVALAGI_110	12:24 (08.07.2024)			LINE CLEAR AVAILED
1086	08-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1087	08-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1088	08-Jul-24	BAGALKOTE	110	LINE	TARIHAL-HUBLI1	TARIHAL_110	08:07	13:28	05:21	TRIPPED ON FAULT
1089	08-Jul-24	BAGALKOTE	110	LINE	TARIHAL-HUBLI2	TARIHAL_110	10:26	13:27	03:01	LINE CLEAR AVAILED
1090	08-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 1	STATION NOT AFFECTED ATHANI_220	13:58	21:25	07:27	LINE CLEAR AVAILED
1091	08-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 2	STATION NOT AFFECTED ATHANI_220	21:12 (07.07.2024)			TRIPPED ON FAULT
1092	08-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1093	08-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	KARWAR_220	11:48	12:03	00:15	LINE CLEAR AVAILED
1094	08-Jul-24	BAGALKOTE	220	LINE	HAVERI-GUTTUT1	HAVERI_220	9:36 (07.07.2024)	19:14 (08.07.2024)	33:38:00	LINE CLEAR AVAILED
1095	08-Jul-24	BAGALKOTE	220	LINE	KUDACH220-SHIRAGUPPI	KUDACHI_220	03:15	03:25	00:10	TRIPPED ON FAULT
1096	08-Jul-24	BANGALORE	66	LINE	66KV CB PURA I/A - CB PURA URBAN	CB PURA URBAN	07:08	07:33	00:25	TRIPPED ON FAULT
1097	08-Jul-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADUBISANAHALLI (TAP)	KADUBISANAHALLI	14:44	15:15	00:31	TRIPPED ON FAULT
1098	08-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	10:37	11:00	00:23	LINE CLEAR AVAILED
1099	08-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	17:39	17:50	00:11	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1100	08-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	10:37	11:12	00:35	MAIN SUPPLY FAILURE
1101	08-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	17:37	17:51	00:14	MAIN SUPPLY FAILURE
1102	08-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	14:24	14:30	00:06	LINE CLEAR AVAILED
1103	08-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	09:54	17:21	07:27	LINE CLEAR AVAILED
1104	08-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	17:23	19:27	02:04	TRIPPED ON FAULT
1105	08-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	KYALANUR, VEMGAL	19:45	19:52	00:07	LINE CLEAR AVAILED
1106	08-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	16:45	17:07	00:22	TRIPPED ON FAULT
1107	08-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II	ALUR, BIEC	06:03	08:54	02:51	TRIPPED ON FAULT
1108	08-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETHAMBADI, K HONALGERE	01:00	01:11	00:11	TRIPPED ON FAULT
1109	08-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETHAMBADI, K HONALGERE	01:11	01:48	00:37	TRIPPED ON FAULT
1110	08-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	10:35	11:19	00:44	LINE CLEAR AVAILED
1111	08-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	17:38	17:54	00:16	LINE CLEAR AVAILED
1112	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BUDIGERE	13:51	14:20	00:29	LINE CLEAR AVAILED
1113	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDAKARI	14:00	14:10	00:10	LINE CLEAR AVAILED
1114	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	08:50	08:58	00:08	TRIPPED ON FAULT
1115	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HSR LAYOUT 220	10:37	11:00	00:23	MAIN SUPPLY FAILURE
1116	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	REMCO	07:24	07:27	00:03	LINE CLEAR AVAILED
1117	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	REMCO	14:25	14:27	00:02	LINE CLEAR AVAILED
1118	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SM MANGALA	17:30	17:37	00:07	TRIPPED ON FAULT
1119	08-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	16:54	16:57	00:03	TRIPPED ON FAULT
1120	08-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DODDAKARI	13:50	14:00	00:10	LINE CLEAR AVAILED
1121	08-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HSR LAYOUT 220	10:37	11:00	00:23	MAIN SUPPLY FAILURE
1122	08-Jul-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	15:45	16:40	00:55	LINE CLEAR AVAILED
1123	08-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SOMENAHALLI	18:40	18:55	00:15	TRIPPED ON FAULT
1124	08-Jul-24	BANGALORE	66	TRANSFORMER	HV3	HSR LAYOUT 220	10:37	11:00	00:23	MAIN SUPPLY FAILURE
1125	08-Jul-24	BANGALORE	66	LINE	KIADB HARDWARE PARK 220 - BPH	BPH(EHT)	10:10	18:43	08:33	LINE CLEAR AVAILED
1126	08-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - SHIMSHA	SHIMSHA	11:06	11:28	00:22	TRIPPED ON FAULT
1127	08-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2	NO STATION AFFECTED	00:00	12:37	12:37	LINE CLEAR AVAILED
1128	08-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2	NO STATION AFFECTED	17:23	23:59	06:36	TRIPPED ON FAULT
1129	08-Jul-24	BANGALORE	220	TRANSFORMER	HV1	HSR LAYOUT 220	10:37	11:00	00:23	TRIPPED ON FAULT
1130	08-Jul-24	BANGALORE	220	TRANSFORMER	HV3	HSR LAYOUT 220	10:37	11:15	00:38	TRIPPED ON FAULT
1131	08-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HALAVAGALU_66	13:10	13:25	00:15	LINE CLEAR AVAILED
1132	08-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	14:55	15:05	00:10	TRIPPED ON FAULT
1133	08-Jul-24	GULBARGA	66	TRANSFORMER	HV3	NEELGUNDA_220	13:00	13:05	00:05	TRIPPED ON FAULT
1134	08-Jul-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	13:30	18:25	04:55	TRIPPED ON FAULT
1135	08-Jul-24	GULBARGA	110	LINE	GANGAVATHI-MUNIRABAD-1'	VENKATGIRI_110	06:42	06:55	00:13	MAIN SUPPLY FAILURE
1136	08-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-WARDHASLR	WARDHASLR_IPP	01:11	01:34	00:23	TRIPPED ON FAULT
1137	08-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	11:59	19:32	07:33	LINE CLEAR AVAILED
1138	08-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	20:53	21:05	00:12	TRIPPED ON FAULT
1139	08-Jul-24	GULBARGA	110	LINE	HUMNABAD-HALBARGA	HUMNABAD_110	15:00	16:25	01:25	LINE CLEAR AVAILED
1140	08-Jul-24	GULBARGA	110	TRANSFORMER	HV1	YADRAMI_110	10:20	13:30	03:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1141	08-Jul-24	GULBARGA	110	TRANSFORMER	HV2	YADRAMI_110	11:35	16:45	05:10	LINE CLEAR AVAILED
1142	08-Jul-24	GULBARGA	110	TRANSFORMER	HV3	KANAKAGIRI_110	18:05	18:45	00:40	LINE CLEAR AVAILED
1143	08-Jul-24	GULBARGA	110	TRANSFORMER	HV3	KANAKAGIRI_110	18:05	18:45	00:40	LINE CLEAR AVAILED
1144	08-Jul-24	GULBARGA	110	LINE	JAWALGERA-ADAVIAMARESHWAR	ADAVIAMARESHWAR_110	10:30	14:40	04:10	LINE CLEAR AVAILED
1145	08-Jul-24	GULBARGA	110	LINE	KALBURGI SOUTH-WEST2	KALBURGI WEST_110	05:44	05:54	00:10	TRIPPED ON FAULT
1146	08-Jul-24	GULBARGA	110	LINE	KAVITAL-MALLAT	KAVITAL_110	05:45	06:05	00:20	TRIPPED ON FAULT
1147	08-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	20:32	20:49	00:17	TRIPPED ON FAULT
1148	08-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	21:31	21:39	00:08	TRIPPED ON FAULT
1149	08-Jul-24	GULBARGA	110	LINE	KORWAR-SHAHBAD	KORWAR_11001:10	01:10	01:20	00:10	TRIPPED ON FAULT
1150	08-Jul-24	GULBARGA	110	LINE	KORWAR-SHAHBAD	KORWAR_11001:10	03:50	04:00	00:10	TRIPPED ON FAULT
1151	08-Jul-24	GULBARGA	110	LINE	LADHA-KAMALNAGAR	KAMALNAGAR_110	02:45	02:55	00:10	TRIPPED ON FAULT
1152	08-Jul-24	GULBARGA	110	LINE	MANDEWAL-BAGEWADI-1	MANDEWAL_110,YADRAMI_110	21:55	22:00	00:05	LINE CLEAR AVAILED
1153	08-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	21:47	21:57	00:10	TRIPPED ON FAULT
1154	08-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	22:10	22:19	00:09	TRIPPED ON FAULT
1155	08-Jul-24	GULBARGA	110	LINE	VALKMADINI-BYGWAT	VALKAMDINI_110	10:00	10:05	00:05	LINE CLEAR AVAILED
1156	08-Jul-24	GULBARGA	110	LINE	VALKMADINI-BYGWAT	VALKAMDINI_110	10:00	15:15	05:15	LINE CLEAR AVAILED
1157	08-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	23:43	23:53	00:10	TRIPPED ON FAULT
1158	08-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1159	08-Jul-24	HASSAN	66	LINE	HNPR2-HASS2	HNPURA_220	12:15	14:58	02:43	LINE CLEAR AVAILED
1160	08-Jul-24	HASSAN	66	TRANSFORMER	HV1	BANDISHETTIHALLI_66	13:10	14:00	00:50	LINE CLEAR AVAILED
1161	08-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	12:20	15:02	02:42	MAIN SUPPLY FAILURE
1162	08-Jul-24	HASSAN	66	TRANSFORMER	HV2	KANDLI_66	12:20	13:57	01:37	LINE CLEAR AVAILED
1163	08-Jul-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	12:20	15:11	02:51	MAIN SUPPLY FAILURE
1164	08-Jul-24	HASSAN	66	LINE	MALALI-HASSAN	MALALI_66	12:20	14:59	02:39	MAIN SUPPLY FAILURE
1165	08-Jul-24	HASSAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	12:37	13:23	00:46	LINE CLEAR AVAILED
1166	08-Jul-24	HASSAN	66	LINE	MNJUPR-L1 CB	MNJUNATHPURA_66	17:40	18:00	00:20	TRIPPED ON FAULT
1167	08-Jul-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	14:49	15:01	00:12	TRIPPED ON FAULT
1168	08-Jul-24	HASSAN	66	LINE	SBELAG-C R PATNA	SBELAGOLA_66	17:40	18:00	00:20	TRIPPED ON FAULT
1169	08-Jul-24	HASSAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	12:20	15:35	03:15	MAIN SUPPLY FAILURE
1170	08-Jul-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	09:35	09:55	00:20	TRIPPED ON FAULT
1171	08-Jul-24	HASSAN	110	LINE	BANTWA-SALATTUR	BANTWALA_110	07:24	12:07	04:43	TRIPPED ON FAULT
1172	08-Jul-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	17:23	17:45	00:22	LINE CLEAR AVAILED
1173	08-Jul-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	17:23	18:25	01:02	LINE CLEAR AVAILED
1174	08-Jul-24	HASSAN	110	TRANSFORMER	HV1 CB	JADE_110	13:50	14:45	00:55	LINE CLEAR AVAILED
1175	08-Jul-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	17:23	18:25	01:02	LINE CLEAR AVAILED
1176	08-Jul-24	HASSAN	110	TRANSFORMER	HV2	NANDIKUR_110	11:51	12:48	00:57	LINE CLEAR AVAILED
1177	08-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	16:30	16:46	00:16	MAIN SUPPLY FAILURE
1178	08-Jul-24	HASSAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	16:30	16:36	00:06	TRIPPED ON FAULT
1179	08-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	16:30	16:40	00:10	MAIN SUPPLY FAILURE
1180	08-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTALA_110	16:30	16:39	00:09	MAIN SUPPLY FAILURE
1181	08-Jul-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	10:27	19:09	08:42	LINE CLEAR AVAILED
1182	08-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharaavthy	21:23(7.7.2024)	10:18(8.7.2024)	12:54 hrs	LINE CLEAR AVAILED
1183	08-Jul-24	HASSAN	220	LINE	SHRAVTY-TALAGUPPA 2	gen_sharaavthy	15:50(7.7.2024)	16:06(08.07.2024)	24:15 hrs	LINE CLEAR AVAILED
1184	08-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	21:23(7.7.2024)	10:18(8.7.2024)	12:54 hrs	LINE CLEAR AVAILED
1185	08-Jul-24	HASSAN	220	LINE	TALAGU-SGS2	TALAGUPPA_400	15:50(07.07.2023)	16:06(08.07.2024)	24:15 hrs	LINE CLEAR AVAILED
1186	08-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
1187	08-Jul-24	MYSORE	66	LINE	HANNUR-ECOREN_WIND	NO STATIONS EFFECTED	12:37 (07/07/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1188	08-Jul-24	MYSORE	66	LINE	HEBBANI-VAJMAGALA	GARGESHWARI_66 THUMBLA_66 VYASARAJAPURA_66	06:24	06:37	00:13	TRIPPED ON FAULT
1189	08-Jul-24	MYSORE	66	LINE	HEBBANI-VAJMAGALA	GARGESHWARI_66 THUMBLA_66 VYASARAJAPURA_66	08:07	08:19	00:12	TRIPPED ON FAULT
1190	08-Jul-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	10:26	10:51	00:24	TRIPPED ON FAULT
1191	08-Jul-24	MYSORE	66	TRANSFORMER	HV1	HADLI_66 KADKOTHNAHALLI_66 MALAVALLI_66	11:06	11:30	00:24	LINE CLEAR AVAILED
1192	08-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	10:56	11:01	00:04	TRIPPED ON FAULT
1193	08-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1194	08-Jul-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	11:00	11:35	00:35	LINE CLEAR AVAILED
1195	08-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	11:36	12:10	00:34	LINE CLEAR AVAILED
1196	08-Jul-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	19:16 (05/07/2024)	11:40:00 (8/7/2024)	64:24 HRs	LINE CLEAR AVAILED
1197	08-Jul-24	MYSORE	66	LINE	JAKKANAHALI-NAGMANGLA	GMALLIGERE_66	19:14	19:23	00:08	TRIPPED ON FAULT
1198	08-Jul-24	MYSORE	66	LINE	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	00:58	01:09	00:11	TRIPPED ON FAULT
1199	08-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (4/7/2024)			LINE CLEAR AVAILED
1200	08-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1201	08-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1202	08-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-BG NAGARA	ADICHUNCHUANGIRI_66 BGNAGARA_66 KADABLLI_66 VADERALLI_66	20:54	21:00	00:06	TRIPPED ON FAULT
1203	08-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
1204	08-Jul-24	MYSORE	66	TRANSFORMER	SFCSIVA-HV3	NO STATIONS EFFECTED	12:26	16:24	03:58	LINE CLEAR AVAILED
1205	08-Jul-24	MYSORE	66	TRANSFORMER	SFCSIVA-HV4	NO STATIONS EFFECTED	12:10	16:24	04:13	LINE CLEAR AVAILED
1206	08-Jul-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	06:22	06:30	00:08	TRIPPED ON FAULT
1207	08-Jul-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	08:06	08:21	00:15	TRIPPED ON FAULT
1208	08-Jul-24	MYSORE	66	TRANSFORMER	YATHAMBADI-HV1	YATHAMBADI_66 KHONALGERE_66	01:03	01:53	00:50	LINE CLEAR AVAILED
1209	08-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (6/7/24)			LINE CLEAR AVAILED
1210	08-Jul-24	MYSORE	220	TRANSFORMER	VAJMANGALA -HV1	JYOTHINAGARA_66 DKMAIDANA_66 DEVNUR(MYS)_66 RAJEEVNAGARA_66	10:20	14:20	04:00	TRIPPED ON FAULT
1211	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV CHALLAKERE LINE	CHALLAKERE_66	13:21	13:46	00:25	TRIPPED ON FAULT
1212	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV CHITRADURGA LINE 1 & 2	CHITRADURGA_66	13:21	13:45	00:24	TRIPPED ON FAULT
1213	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV HIRIYUR LINE	66KV J N KOTE,AIMANGALA,MALLAPPANAHALLI	13:21	13:46	00:25	TRIPPED ON FAULT
1214	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 1	66KV SIRIGERE,BHARAMASAGARA KNNL , VIJAPURA	13:21	13:46	00:25	TRIPPED ON FAULT
1215	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV HIREGUNTUR, PANDARAHALLI	13:21	13:46	00:25	TRIPPED ON FAULT
1216	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	SUZLON1_IPP_66	13:21	LINE NOT YET CHARGED		TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1217	08-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV TURUVANUR LINE	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	13:21	13:46	00:25	TRIPPED ON FAULT
1218	08-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	66KV KUKKAWADA,SHYAGALE	12:39	12:55	00:16	TRIPPED ON FAULT
1219	08-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV BANUVALLI LINE	66KV NANDIGUDI,BANUVALLI,EHT CARGIL	06:03	06:15	00:12	TRIPPED ON FAULT
1220	08-Jul-24	TUMKUR	66	LINE	66KV K R HALLI OUTGOING LINE	66KV BEVINAHALLI,J G HALLI, DASUDI	19:10	19:30	00:20	TRIPPED ON FAULT
1221	08-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	12:25	12:29	00:04	LINE CLEAR AVAILED
1222	08-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	12:35	12:37	00:02	LINE CLEAR AVAILED
1223	08-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	12:19	12:24	00:05	LINE CLEAR AVAILED
1224	08-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	12:22	12:24	00:02	LINE CLEAR AVAILED
1225	08-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:29	12:31	00:02	LINE CLEAR AVAILED
1226	08-Jul-24	TUMKUR	66	LINE	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	20:20	20:45	00:25	TRIPPED ON FAULT
1227	08-Jul-24	TUMKUR	66	LINE	PAVAGADA 220KV- MADHUGIRI	PAVAGADA_66	23:25	23:33	00:08	TRIPPED ON FAULT
1228	08-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	MADHUGIRI_66	14:52	15:02	00:09	TRIPPED ON FAULT
1229	08-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	MATHOD_66	06:55	07:05	00:10	TRIPPED ON FAULT
1230	08-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	RAMPURA_66	12:40	12:46	00:06	TRIPPED ON FAULT
1231	08-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 (8MVA)	CHITRAHALLI_66	21:40	21:45	00:04	TRIPPED ON FAULT
1232	08-Jul-24	TUMKUR	66	TRANSFORMER	TR1(12.5MVA) & TR2 (12.5MVA)	SASLUHALLA_66	11:07	12:26	01:19	LINE CLEAR AVAILED
1233	08-Jul-24	TUMKUR	66	TRANSFORMER	TR1(8MVA) & TR2 (12.5MVA)	SANIKERE_66	11:20	12:20	01:00	LINE CLEAR AVAILED
1234	08-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	ANCHEPALYA_66	19:40	19:45	00:05	TRIPPED ON FAULT
1235	08-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	KADAJJI_66	09:11	09:16	00:04	TRIPPED ON FAULT
1236	08-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	KUKKAWADA_66	10:37	10:41	00:04	TRIPPED ON FAULT
1237	08-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	KUKKAWADA_66	10:41	10:51	00:10	TRIPPED ON FAULT
1238	08-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (8MVA)	PD KOTE_66	02:54	03:03	00:08	TRIPPED ON FAULT
1239	08-Jul-24	TUMKUR	110	LINE	KB CROSS 220KV-HANDANKERE_110	HANDANKERE_110	15:33	15:40	00:07	TRIPPED ON FAULT
1240	08-Jul-24	TUMKUR	110	TRANSFORMER	TR-1 (20MVA)	KBCROSS_110	08:27	15:56	07:29	TRIPPED ON FAULT
1241	08-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 1 & 2-220KV CHITRADURGA	66KV HIREGUNTNR, CHITRADURGA, PANDARAHALLI, H D PURA, CHITRAHALLI, HOLALKERE,CHIKKAJAJUR, SASALUHALLA, TURUVANUR,MADANAYAKANAHALLI, BIDARKERE	13:21	13:44	00:23	TRIPPED ON FAULT
1242	08-Jul-24	TUMKUR	220	LINE	CHITRADURGA 220- GUTTUR 220	GUTTUR 220	05:51	13:40	07:48	LINE CLEAR AVAILED
1243	08-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- 220KV KAIGA LINE 2	GUTUR_400	14:13 (06.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
1244	08-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI LINE 1	HAVERI_220	11:45 (07.07.2024)	18:16 (08.07.2024)	1 DAY 6 Hrs 31 Min	LINE CLEAR AVAILED
1245	09-Jul-24	BAGALKOTE	110	LINE	VAJJARMATTI220-VAJJARMATTI	VAJJARMATTI_220	18:53	18:56	00:03	LINE CLEAR AVAILED
1246	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALGHATAGI_110	06:55	07:00	00:05	TRIPPED ON FAULT
1247	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KULAGERICROSS_110	14:01	15:33	01:32	LINE CLEAR AVAILED
1248	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KULAGERICROSS_110	21:09	21:20	00:11	TRIPPED ON FAULT
1249	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	MUNAVALLI_110	06:30	14:31	08:01	LINE CLEAR AVAILED
1250	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KUDUCHI_220	11:59	14:47	02:48	LINE CLEAR AVAILED
1251	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MUGALKHOD_220	10:10	11:55	01:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1252	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TOLAMATTI_110	16:06	16:11	00:05	LINE CLEAR AVAILED
1253	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UAS_110	16:19	17:08	00:49	TRIPPED ON FAULT
1254	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UAS_110	17:30	17:43	00:13	TRIPPED ON FAULT
1255	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MATTIHAL_110	7:10 (07.07.2024)	19:19 (8.07.2024)	36:09:00	LINE CLEAR AVAILED
1256	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	AMBEWADI_220	18:46	20:02	01:16	TRIPPED ON FAULT
1257	09-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA)	TOLAMATTI_110	15:00	17:11	02:11	LINE CLEAR AVAILED
1258	09-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-SUPA-1	AMBEWADI_220	01:15	15:42	14:27	TRIPPED ON FAULT
1259	09-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-SUPA-2	AMBEWADI_220	12:54	15:43	02:49	LINE CLEAR AVAILED
1260	09-Jul-24	BAGALKOTE	110	LINE	BAGALKOT-F7 RAMDURG	BAGALKOT_220	06:44	08:02	01:18	TRIPPED ON FAULT
1261	09-Jul-24	BAGALKOTE	110	LINE	BIDNAL-P H COMPOUND	BIDNAL_220	15:00	15:03	00:03	LINE CLEAR AVAILED
1262	09-Jul-24	BAGALKOTE	110	LINE	CHIKKODI220- BHOJ	CHIKKODI_220	15:00	16:06	01:06	LINE CLEAR AVAILED
1263	09-Jul-24	BAGALKOTE	110	LINE	DEVANAGAON-AFZALPUR	DEVANAGAON_110	11:31	12:03	00:32	LINE CLEAR AVAILED
1264	09-Jul-24	BAGALKOTE	110	LINE	DEVANAGAON-AFZALPUR	DEVANAGAON_110	13:15	15:59	02:44	LINE CLEAR AVAILED
1265	09-Jul-24	BAGALKOTE	110	LINE	DEVANAGAON-GATTARGI	DEVANAGAON_110	11:31	12:03	00:32	LINE CLEAR AVAILED
1266	09-Jul-24	BAGALKOTE	110	LINE	JAMAKHANDI-PRABHULINGESHWAR(SIDDAPUR)	JAMAKHANDI_110	16:58 (08.07.2024)	10:59 (09.07.2024)	18:01:00	LINE CLEAR AVAILED
1267	09-Jul-24	BAGALKOTE	110	LINE	KULAGERICROSS-MRN SUGARS	KULAGERICROSS_110	06:44	06:47	00:03	TRIPPED ON FAULT
1268	09-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR-BANAHATTI(JAMAKHANDI EXPRESS)	MAHALINGAPUR_220	14:50	15:14	00:24	TRIPPED ON FAULT
1269	09-Jul-24	BAGALKOTE	110	LINE	MAMDAPUR(B)-SHIRBUR	MAMADAPUR(B)_110	19:53	20:02	00:09	TRIPPED ON FAULT
1270	09-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1271	09-Jul-24	BAGALKOTE	110	LINE	NAVALAGI-F2(BANAHATTI)	NAVALAGI_110	12:24 (08.07.2024)	14:38 (09.07.2024)	26:14:00	LINE CLEAR AVAILED
1272	09-Jul-24	BAGALKOTE	110	LINE	NAVALAGI-MAHALINGAPUR	NAVALAGI_110	14:33	14:38	00:05	LINE CLEAR AVAILED
1273	09-Jul-24	BAGALKOTE	110	LINE	RAIBAG-CHIKKODI2	RAIBAG_110	15:23	15:30	00:07	TRIPPED ON FAULT
1274	09-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1275	09-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1276	09-Jul-24	BAGALKOTE	220	LINE	ATHANI - KAKMARI 1	ATHANI_220	18:33	20:08	01:35	LINE CLEAR AVAILED
1277	09-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 2	STATION NOT AFFECTED ATHANI_220	21:12 (07.07.2024)			TRIPPED ON FAULT
1278	09-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1279	09-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2,LV2	HAVERI_220	10:27	13:40	03:13	LINE CLEAR AVAILED
1280	09-Jul-24	BAGALKOTE	220	LINE	KUDACHI220- SHIRAGUPPI	KUDACHI_220	23:30	23:35	00:05	TRIPPED ON FAULT
1281	09-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	05:26	05:44	00:18	TRIPPED ON FAULT
1282	09-Jul-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	05:49	05:58	00:09	TRIPPED ON FAULT
1283	09-Jul-24	BANGALORE	66	LINE	66KV HOODY 220 - BRIGADE METROPOLIS	BRIGADE METROPOLIS	08:38	08:46	00:08	LINE CLEAR AVAILED
1284	09-Jul-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	17:32	17:40	00:08	LINE CLEAR AVAILED
1285	09-Jul-24	BANGALORE	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	KACHAMARANAHALLI	22:18	22:25	00:07	LINE CLEAR AVAILED
1286	09-Jul-24	BANGALORE	66	LINE	66KV KACHAMARANAHALLI - PRESTIGE LAKESIDE HABITAT	KACHAMARANAHALLI	14:08	14:25	00:17	MAIN SUPPLY FAILURE
1287	09-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALI, BIJJAHALLI, HUNASENAHALLI	10:20	17:00	06:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1288	09-Jul-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	SIR MV LAYOUT	13:42	13:47	00:05	LINE CLEAR AVAILED
1289	09-Jul-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	SIR MV LAYOUT	15:45	15:50	00:05	LINE CLEAR AVAILED
1290	09-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	TALAGUNDA	10:00	12:50	02:50	LINE CLEAR AVAILED
1291	09-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	TALAGUNDA	17:20	18:40	01:20	LINE CLEAR AVAILED
1292	09-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALANUR	10:01	10:07	00:06	LINE CLEAR AVAILED
1293	09-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	18:07	18:31	00:24	TRIPPED ON FAULT
1294	09-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	SIR MV LAYOUT	13:52	14:05	00:13	LINE CLEAR AVAILED
1295	09-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	06:31	06:48	00:17	TRIPPED ON FAULT
1296	09-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	VEMGAL, KYALANUR	18:42	18:47	00:05	LINE CLEAR AVAILED
1297	09-Jul-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, RAYALPADU, GOWNIPALLI	05:50	06:04	00:14	TRIPPED ON FAULT
1298	09-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	GUNDAMGERE, SASLU, DODDABELAVANGALA	23:33	23:59	00:26	TRIPPED ON FAULT
1299	09-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	11:20	20:18	08:58	LINE CLEAR AVAILED
1300	09-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	18:21	19:00	00:39	MAIN SUPPLY FAILURE
1301	09-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, BEML, KAMASAMUDRA	18:21	19:07	00:46	MAIN SUPPLY FAILURE
1302	09-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, BEML, KAMASAMUDRA	18:21	19:07	00:46	MAIN SUPPLY FAILURE
1303	09-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	18:21	18:58	00:37	MAIN SUPPLY FAILURE
1304	09-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	14:13	14:18	00:05	LINE CLEAR AVAILED
1305	09-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	09:43	09:48	00:05	LINE CLEAR AVAILED
1306	09-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	13:30	14:20	00:50	LINE CLEAR AVAILED
1307	09-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SIR MV LAYOUT	10:20	10:25	00:05	LINE CLEAR AVAILED
1308	09-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SURYANAGARA	13:35	14:36	01:01	LINE CLEAR AVAILED
1309	09-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	17:00	17:40	00:40	LINE CLEAR AVAILED
1310	09-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YENNIGADALE	11:15	11:20	00:05	LINE CLEAR AVAILED
1311	09-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 1	NO STATION AFFECTED	16:00	16:12	00:12	TRIPPED ON FAULT
1312	09-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2	NO STATION AFFECTED	00:00	00:54	00:54	TRIPPED ON FAULT
1313	09-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	16:50	17:21	00:31	LINE CLEAR AVAILED
1314	09-Jul-24	BANGALORE	220	TRANSFORMER	HV1	T GOLLAHALLI 220	18:21	18:58	00:37	TRIPPED ON FAULT
1315	09-Jul-24	GULBARGA	66	LINE	NEELGUNDA-TELGI	TELGI_66, KURUBANAHALLI_66, OBBAJIHALLI_66	11:38	12:10	00:32	LINE CLEAR AVAILED
1316	09-Jul-24	GULBARGA	110	LINE	ADAVI AMARAESHWARA-JAVALGERA	JAVALAGERA_110	09:20	14:05	04:45	LINE CLEAR AVAILED
1317	09-Jul-24	GULBARGA	110	LINE	ADAVI AMARAESHWARA-MALLAT	ADAVI-AMARASHWARA_110	19:14	19:24	00:10	MAIN SUPPLY FAILURE
1318	09-Jul-24	GULBARGA	110	LINE	AFZALPUR-DEVANGOAN	AFZALPUR_110,KARAJAGI_110	11:58	12:53	00:55	MAIN SUPPLY FAILURE
1319	09-Jul-24	GULBARGA	110	LINE	ALAND-MADIYAL	ALAND_110, MADIYAL_110, KADAGANCHI_110, RUDRAWADI_110	23:15	23:25	00:10	MAIN SUPPLY FAILURE
1320	09-Jul-24	GULBARGA	110	LINE	ALIPUR-BELLARYSOUTH	BELLARYSOUTH_110	03:54	04:05	00:11	TRIPPED ON FAULT
1321	09-Jul-24	GULBARGA	110	LINE	BYGWAT-WALKAMDINI	WALKAMDINI_110	09:15	11:40	02:25	LINE CLEAR AVAILED
1322	09-Jul-24	GULBARGA	110	LINE	CHICKSUGUR-APMC	APMC_110	18:17	18:40	00:23	LINE CLEAR AVAILED
1323	09-Jul-24	GULBARGA	110	LINE	CHITAPUR-SHAHABAD	CHITAPUR_110	00:29	00:36	00:07	TRIPPED ON FAULT
1324	09-Jul-24	GULBARGA	110	LINE	CHOWDAPUR-DEVANGOAN	AFZALPUR_110,KARAJAGI_110	11:58	12:53	00:55	MAIN SUPPLY FAILURE
1325	09-Jul-24	GULBARGA	110	LINE	GHATTARGA-DEVANGOAN	AFZALPUR_110,KARAJAGI_110	11:58	12:53	00:55	MAIN SUPPLY FAILURE
1326	09-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-SHAHPUR-2	SHAHPUR-2_110	01:01	01:09	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1327	09-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-SHAHPUR-2	SHAHPUR_2_110	03:14	03:23	00:09	TRIPPED ON FAULT
1328	09-Jul-24	GULBARGA	110	TRANSFORMER	HV1	KOGALI_66	07:25	07:35	00:10	TRIPPED ON FAULT
1329	09-Jul-24	GULBARGA	110	TRANSFORMER	HV1	SHAHPUR_110	12:16	15:08	02:52	LINE CLEAR AVAILED
1330	09-Jul-24	GULBARGA	110	TRANSFORMER	HV1	YADRAMI_110	21:00	21:30	00:30	TRIPPED ON FAULT
1331	09-Jul-24	GULBARGA	110	TRANSFORMER	HV2	SHAHPUR_110	12:16	15:08	02:52	LINE CLEAR AVAILED
1332	09-Jul-24	GULBARGA	110	LINE	KAPNOOR-GANAGAPUR	GANAGAPUR_110	11:47	18:55	07:08	LINE CLEAR AVAILED
1333	09-Jul-24	GULBARGA	110	LINE	KARAJAGI-DEVANGOAN	AFZALPUR_110,KARAJAGI_110	11:58	12:53	00:55	MAIN SUPPLY FAILURE
1334	09-Jul-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	KHANAPUR_110	20:05	20:20	00:15	TRIPPED ON FAULT
1335	09-Jul-24	GULBARGA	110	LINE	LINGASUGUR-KAREPOWER	LINGASUGUR_220	00:33	00:41	00:08	TRIPPED ON FAULT
1336	09-Jul-24	GULBARGA	110	LINE	NALWAR-SHAHPUR	NALWAR_110	23:15	23:25	00:10	MAIN SUPPLY FAILURE
1337	09-Jul-24	GULBARGA	110	LINE	RAICHUR-MALIYABAD	MALIYABAD_110	07:53	08:22	00:29	LINE CLEAR AVAILED
1338	09-Jul-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR 1&2	GUGAL_110, GABUR_110	07:09	15:25	08:16	LINE CLEAR AVAILED
1339	09-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	20:55	21:10	00:15	TRIPPED ON FAULT
1340	09-Jul-24	GULBARGA	220	LINE	ALIPURA-RAGALPADU	ALIPUR_220	00:00	22:00	22:00	LINE CLEAR AVAILED
1341	09-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-RTPS-2	HATTIGUDUR_220	21:30	21:53	00:23	TRIPPED ON FAULT
1342	09-Jul-24	GULBARGA	220	TRANSFORMER	HV1	ALIPUR_220	11:44	16:13	04:29	LINE CLEAR AVAILED
1343	09-Jul-24	GULBARGA	220	TRANSFORMER	HV1	ITTAGI_220	18:05	20:20	02:15	LINE CLEAR AVAILED
1344	09-Jul-24	GULBARGA	220	TRANSFORMER	HV2	ALIPUR_220	06:07	06:17	00:10	TRIPPED ON FAULT
1345	09-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1346	09-Jul-24	HASSAN	66	LINE	DUDDA-BASAVAGHATTA	DUDDA_66	18:17	19:01	00:44	TRIPPED ON FAULT
1347	09-Jul-24	HASSAN	66	TRANSFORMER	HV1	BALLUPETE_66	10:26	11:46	01:20	LINE CLEAR AVAILED
1348	09-Jul-24	HASSAN	66	TRANSFORMER	HV1	HOLALUR_66	10:32	11:02	00:30	TRIPPED ON FAULT
1349	09-Jul-24	HASSAN	66	TRANSFORMER	HV1	SBELAGOLA_66	06:36	06:51	00:15	TRIPPED ON FAULT
1350	09-Jul-24	HASSAN	66	TRANSFORMER	HV2	BANDISHETTIHALLI_66	11:19	13:05	01:46	LINE CLEAR AVAILED
1351	09-Jul-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	10:34	13:09	02:35	LINE CLEAR AVAILED
1352	09-Jul-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	10:45	13:00	02:15	LINE CLEAR AVAILED
1353	09-Jul-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:25	13:40	02:15	LINE CLEAR AVAILED
1354	09-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESH PURA_66	08:05	18:42	10:37	LINE CLEAR AVAILED
1355	09-Jul-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	11:20	11:39	00:19	LINE CLEAR AVAILED
1356	09-Jul-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	13:45	13:50	00:05	MAIN SUPPLY FAILURE
1357	09-Jul-24	HASSAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:20	13:54	02:34	LINE CLEAR AVAILED
1358	09-Jul-24	HASSAN	66	LINE	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	11:51	13:54	02:03	LINE CLEAR AVAILED
1359	09-Jul-24	HASSAN	110	LINE	BANTWA-SALATTUR	BANTWAL_110	10:25	13:18	02:53	LINE CLEAR AVAILED
1360	09-Jul-24	HASSAN	110	TRANSFORMER	HV1	ESSUR_110	17:05	17:32	00:27	TRIPPED ON FAULT
1361	09-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	10:47	12:03	01:16	LINE CLEAR AVAILED
1362	09-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	07:37	10:40	03:03	TRIPPED ON FAULT
1363	09-Jul-24	HASSAN	110	TRANSFORMER	HV3	NITTUR_110	12:05	12:50	00:45	LINE CLEAR AVAILED
1364	09-Jul-24	HASSAN	110	TRANSFORMER	HV3	PUTTUR_110	09:15	10:05	00:50	LINE CLEAR AVAILED
1365	09-Jul-24	HASSAN	110	TRANSFORMER	HV4	PUTTUR_110	10:07	11:52	01:45	LINE CLEAR AVAILED
1366	09-Jul-24	HASSAN	110	LINE	KADUR-NGNHL	KADUR_220	16:03	16:10	00:07	LINE CLEAR AVAILED
1367	09-Jul-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	04:56	05:15	00:19	TRIPPED ON FAULT
1368	09-Jul-24	HASSAN	110	LINE	LV1	PUTTUR_220	07:50	12:00	04:10	LINE CLEAR AVAILED
1369	09-Jul-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	15:34	15:43	00:09	TRIPPED ON FAULT
1370	09-Jul-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	16:01	16:11	00:10	TRIPPED ON FAULT
1371	09-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
1372	09-Jul-24	MYSORE	66	LINE	HANNUR-AJJIPURA	AJJIPURA_66 BANDALLI_66 COWDALLI_66 HANNUR_66 MARTAHALLI_66 RAMAPURA_MYS_66	17:24	17:34	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1373	09-Jul-24	MYSORE	66	LINE	HANNUR-ECOREN_WIND	NO STATIONS EFFECTED	12:37 (07/07/2024)	13:45 (09/07/2024)	49:07 HRs	LINE CLEAR AVAILED
1374	09-Jul-24	MYSORE	66	TRANSFORMER	HV1	BEGUR_220	12:35	13:30	00:55	LINE CLEAR AVAILED
1375	09-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	09:00	09:05	00:05	TRIPPED ON FAULT
1376	09-Jul-24	MYSORE	66	TRANSFORMER	HV1	MADDUR_66	11:26	11:57	00:31	LINE CLEAR AVAILED
1377	09-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1378	09-Jul-24	MYSORE	66	TRANSFORMER	HV1	YELANDUR_66	15:26	15:30	00:03	LINE CLEAR AVAILED
1379	09-Jul-24	MYSORE	66	TRANSFORMER	HV2	YELANDUR_66	13:19	15:26	02:07	LINE CLEAR AVAILED
1380	09-Jul-24	MYSORE	66	LINE	KM DODDI-TK HALLI	NO STATIONS EFFECTED	15:59	16:13	00:13	TRIPPED ON FAULT
1381	09-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
1382	09-Jul-24	MYSORE	66	LINE	MADDUR-KIADB MANDYA	NO STATIONS EFFECTED	06:48	08:50	02:02	LINE CLEAR AVAILED
1383	09-Jul-24	MYSORE	66	LINE	MADDUR-KIADB SOMNAHALLI	NO STATIONS EFFECTED	02:21	06:48	04:26	LINE CLEAR AVAILED
1384	09-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1385	09-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1386	09-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	19:04	19:38	00:34	TRIPPED ON FAULT
1387	09-Jul-24	MYSORE	66	LINE	MANDYA-MADDUR	KIADB SOMANAHALLI_66 MADDUR_66	01:48	08:39	06:51	TRIPPED ON FAULT
1388	09-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
1389	09-Jul-24	MYSORE	66	LINE	PANDAVAPURA-G UKKADA	NO STATIONS EFFECTED	12:34	13:01	00:27	TRIPPED ON FAULT
1390	09-Jul-24	MYSORE	66	LINE	VADKEPURA-KIRUGAVLU	KIRUGAVALU_66 MALIYURU_66	02:30	02:40	00:10	TRIPPED ON FAULT
1391	09-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (06/07/2024)			LINE CLEAR AVAILED
1392	09-Jul-24	MYSORE	220	TRANSFORMER	HV1	TUBINAKERE_220	11:37	12:42	01:05	LINE CLEAR AVAILED
1393	09-Jul-24	MYSORE	220	TRANSFORMER	HV2	TUBINAKERE_220	12:34	16:14	03:39	TRIPPED ON FAULT
1394	09-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	SUZLON1_IPP_66	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
1395	09-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV BASAVAPATNA	16:51	17:06	00:15	TRIPPED ON FAULT
1396	09-Jul-24	TUMKUR	66	LINE	HARIYABBE-CHIKKABANAGERE (P D KOTE)	HARIYABBE_66	03:50	05:50	02:00	LINE CLEAR AVAILED
1397	09-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	RANGENAHALLI_66	10:00	18:30	08:30	LINE CLEAR AVAILED
1398	09-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	10:00	18:30	08:30	LINE CLEAR AVAILED
1399	09-Jul-24	TUMKUR	66	LINE	KORATAGERE-HOLAVINAHALLI	HOLAVINAHALLI_66	12:10	14:10	02:00	LINE CLEAR AVAILED
1400	09-Jul-24	TUMKUR	66	LINE	KORATAGERE-MADHUGIRI2	KORATAGERE_66	12:35	13:10	00:35	LINE CLEAR AVAILED
1401	09-Jul-24	TUMKUR	66	LINE	THALLAK 220KV- GOWRASAMUDRA	GOWRASAMUDRA,KONANSAGARA	11:47	11:52	00:05	LINE CLEAR AVAILED
1402	09-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	HALUVAGALU_66	13:32	14:29	00:56	LINE CLEAR AVAILED
1403	09-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (8MVA)	PDKOTE_66	10:10	17:40	07:30	MAIN SUPPLY FAILURE
1404	09-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (8MVA)	THIPPUR_66	14:15	14:20	00:05	LINE CLEAR AVAILED
1405	09-Jul-24	TUMKUR	66	TRANSFORMER	TR1(12.5MVA)	MATHOD_66	12:15	14:35	02:20	LINE CLEAR AVAILED
1406	09-Jul-24	TUMKUR	66	TRANSFORMER	TR1(20MVA)	KORATAGERE_66	11:30	13:10	01:40	LINE CLEAR AVAILED
1407	09-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	MATHOD_66	15:00	17:35	02:35	LINE CLEAR AVAILED
1408	09-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	MAVINAKATTE_66	10:07	10:20	00:13	TRIPPED ON FAULT
1409	09-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (20MVA)	KORATAGERE_66	12:35	13:55	01:20	LINE CLEAR AVAILED
1410	09-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (8MVA)	PDKOTE_66	10:10	17:40	07:30	MAIN SUPPLY FAILURE
1411	09-Jul-24	TUMKUR	110	TRANSFORMER	TR2 (10MVA)	THIMMANAHALLI_110	00:10	11:54	11:44	TRIPPED ON FAULT
1412	09-Jul-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV- K B CROSS_220	ANTHRASANAHALLI 220	12:12	15:10	02:58	LINE CLEAR AVAILED
1413	09-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- 220KV KAIGA LINE 2	GUTUR_400	14:13 (06.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1414	10-Jul-24	BAGALKOTE	110	LINE	GHATAPRABHA- SOEPL	GHATAPRABHA_220	00:10	00:15	00:05	TRIPPED ON FAULT
1415	10-Jul-24	BAGALKOTE	110	LINE	GHATAPRABHA-SOEPL	GHATAPRABHA_220	00:25	00:37	00:12	TRIPPED ON FAULT
1416	10-Jul-24	BAGALKOTE	110	LINE	NIPPANI- FPEL WIND	NIPPANI_110	11:00	11:20	00:20	TRIPPED ON FAULT
1417	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11 KV,HV1(20MVA)	SULTANPUR_110	17:00	17:11	00:11	LINE CLEAR AVAILED
1418	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11 KV,HV2(20MVA)	AMBEWADI_220	10:21	13:04	02:43	LINE CLEAR AVAILED
1419	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11 KV,HV2(20MVA)	AMBEWADI_220	16:21 (10.07.2024)			LINE CLEAR AVAILED
1420	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11 KV,HV2(20MVA)	RAIBAG_110	14:28	15:53	01:25	TRIPPED ON FAULT
1421	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10 MVA)	ALNAVAR_110	11:10	15:41	04:31	LINE CLEAR AVAILED
1422	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20 MVA)	ANKALGI_110	06:59	08:25	01:26	LINE CLEAR AVAILED
1423	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BIDI_110	19:46	20:31	00:45	LINE CLEAR AVAILED
1424	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10 MVA)	ALNAVAR_110	10:30	16:13	05:43	LINE CLEAR AVAILED
1425	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (HV3 20MVA)	BYADAGI_110	09:13	09:22	00:09	TRIPPED ON FAULT
1426	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (HV3 20MVA)	BYADAGI_110	11:11	18:56	07:45	LINE CLEAR AVAILED
1427	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HEBBALLI_110	14:24	17:30	03:06	LINE CLEAR AVAILED
1428	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HONNAVAR_110	14:02	14:48	00:46	LINE CLEAR AVAILED
1429	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	LOKAPUR_110	11:50	12:27	00:37	LINE CLEAR AVAILED
1430	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NARAGAL_110	12:41	13:01	00:20	TRIPPED ON FAULT
1431	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULAGERE CROSS_110	11:12	11:14	00:02	LINE CLEAR AVAILED
1432	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	RATTIHALLI_110	16:45	17:21	00:36	LINE CLEAR AVAILED
1433	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SULTANPUR_110	10:45	11:40	00:55	LINE CLEAR AVAILED
1434	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KULAGERE CROSS_110	12:07	12:17	00:10	LINE CLEAR AVAILED
1435	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	MUNAVALLI_110	22:30	22:34	00:04	TRIPPED ON FAULT
1436	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	PG HUNSHYAL_110	14:44	15:07	00:23	TRIPPED ON FAULT
1437	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	SULTANPUR_110	10:45	11:40	00:55	LINE CLEAR AVAILED
1438	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	SULTANPUR_110	17:00	17:11	00:11	LINE CLEAR AVAILED
1439	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (10MVA)	ANKOLA_110	18:08	18:19	00:11	TRIPPED ON FAULT
1440	10-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10 MVA)	ALNAVAR_110	10:30	16:55	06:25	LINE CLEAR AVAILED
1441	10-Jul-24	BAGALKOTE	110	LINE	ALNAVAR-RAILWAY	ALNAVAR_110	10:10	17:19	07:09	LINE CLEAR AVAILED
1442	10-Jul-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	09:06	11:49	02:43	LINE CLEAR AVAILED
1443	10-Jul-24	BAGALKOTE	110	LINE	ATHARGA-KNISLR	ATHARHGA_110	07:26	11:23	03:57	LINE CLEAR AVAILED
1444	10-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1445	10-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD-SULTANAPUR	MUGALAKHOD_220	11:56	14:00	02:04	LINE CLEAR AVAILED
1446	10-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1447	10-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1448	10-Jul-24	BAGALKOTE	110	LINE	SULTANPUR-MUGALKHOD	SULTANPUR_110	10:45	17:10	06:25	LINE CLEAR AVAILED
1449	10-Jul-24	BAGALKOTE	110	LINE	TAKKALAKI-THORVI(KIADB BIJAPUR)	TAKKALAKI_110	03:10	03:18	00:08	TRIPPED ON FAULT
1450	10-Jul-24	BAGALKOTE	110	LINE	UTTUR-MAHALINGAPUR(RANNABELAGALI)	UTTUR_110	13:48 (10.07.2024)			LINE CLEAR AVAILED
1451	10-Jul-24	BAGALKOTE	220	LINE	ATHANI-KAKMARI 2	STATION NOT AFFECTED ATHANI_220	21:12 (07.07.2024)	14:48 (10.07.2024)	65:36:00	TRIPPED ON FAULT
1452	10-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1453	10-Jul-24	BAGALKOTE	220	LINE	ATHANI - KAKMARI 1	ATHANI_220	10:52	14:47	03:55	LINE CLEAR AVAILED
1454	10-Jul-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BIAL BEGUR 220	NO STATION AFFECTED	19:02	19:40	00:38	TRIPPED ON FAULT
1455	10-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	20:30	20:42	00:12	TRIPPED ON FAULT
1456	10-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	TALAGUNDA	10:00	10:50	00:50	LINE CLEAR AVAILED
1457	10-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	TALAGUNDA	16:50	17:30	00:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1458	10-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALNUR	10:02	10:06	00:04	LINE CLEAR AVAILED
1459	10-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	KYALANUR, VEMGAL	17:40	17:50	00:10	LINE CLEAR AVAILED
1460	10-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	GUNDAMGERE, SASLU, DODDABELAVANGALA	00:00	00:33	00:33	TRIPPED ON FAULT
1461	10-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	07:36	12:26	04:50	TRIPPED ON FAULT
1462	10-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	10:17	12:26	02:09	LINE CLEAR AVAILED
1463	10-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	12:49	12:56	00:07	TRIPPED ON FAULT
1464	10-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	NO STATION AFFECTED	17:52	18:09	00:17	TRIPPED ON FAULT
1465	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1466	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:12	16:23	00:11	MAIN SUPPLY FAILURE
1467	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 1	BWSSB(EHT)	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1468	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 1	BWSSB(EHT)	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1469	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB(EHT)	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1470	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 2	BWSSB(EHT)	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1471	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 3	BWSSB(EHT)	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1472	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 3	BWSSB(EHT)	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1473	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - BWSSB 4	BWSSB(EHT)	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1474	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1475	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	16:12	16:24	00:12	MAIN SUPPLY FAILURE
1476	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU, YATHAMBADI, K HONALGERE	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1477	10-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU, YATHAMBADI, K HONALGERE	16:12	16:23	00:11	MAIN SUPPLY FAILURE
1478	10-Jul-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	16:15	16:30	00:15	TRIPPED ON FAULT
1479	10-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BAGEPALLI	11:10	11:15	00:05	LINE CLEAR AVAILED
1480	10-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	13:15	15:42	02:27	LINE CLEAR AVAILED
1481	10-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TK HALLI 220	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1482	10-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1483	10-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DODDALAHALLI	19:42	19:50	00:08	TRIPPED ON FAULT
1484	10-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TK HALLI 220	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1485	10-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1486	10-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TUBAGERE	22:20	22:24	00:04	TRIPPED ON FAULT
1487	10-Jul-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	17:28	17:33	00:05	TRIPPED ON FAULT
1488	10-Jul-24	BANGALORE	66	LINE	KIADB HARDWARE PARK 220 - BPH	BPH(EHT)	09:35	18:45	09:10	LINE CLEAR AVAILED
1489	10-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 1	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMGERE	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1490	10-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 1	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMGERE	16:12	16:23	00:11	MAIN SUPPLY FAILURE
1491	10-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMGERE	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1492	10-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, THALAGAVADI, KIADB MANDYA, TUMGERE	16:12	16:23	00:11	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1493	10-Jul-24	BANGALORE	220	LINE	220KV TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	08:19	08:29	00:10	TRIPPED ON FAULT
1494	10-Jul-24	BANGALORE	220	LINE	220KV TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1495	10-Jul-24	BANGALORE	220	TRANSFORMER	HV1	TK HALLI 220	08:19	08:31	00:12	MAIN SUPPLY FAILURE
1496	10-Jul-24	BANGALORE	220	TRANSFORMER	HV1	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1497	10-Jul-24	BANGALORE	220	TRANSFORMER	HV2	TK HALLI 220	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1498	10-Jul-24	BANGALORE	220	TRANSFORMER	HV2	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1499	10-Jul-24	BANGALORE	220	TRANSFORMER	HV3	TK HALLI 220	08:19	08:33	00:14	MAIN SUPPLY FAILURE
1500	10-Jul-24	BANGALORE	220	TRANSFORMER	HV3	TK HALLI 220	16:12	16:20	00:08	MAIN SUPPLY FAILURE
1501	10-Jul-24	GULBARGA	66	LINE	BADALADUKU-CJHALLI	CJHALLI_66,HOSAHALLI_66	11:21	11:32	00:11	TRIPPED ON FAULT
1502	10-Jul-24	GULBARGA	66	LINE	BADALADUKU-CJHALLI	CJHALLI_66,HOSAHALLI_66	11:21	11:32	00:11	TRIPPED ON FAULT
1503	10-Jul-24	GULBARGA	66	LINE	BADALADUKU-HUDEM	HUDEM_66,	11:21	11:32	00:11	TRIPPED ON FAULT
1504	10-Jul-24	GULBARGA	66	LINE	BADALADUKU-KOTTUR	KOTTUR_66	11:30	12:30	01:00	LINE CLEAR AVAILED
1505	10-Jul-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	07:10	07:15	00:05	TRIPPED ON FAULT
1506	10-Jul-24	GULBARGA	66	LINE	KUDALGI-HIREHADAGALI1	HIREHADAGALI_66	09:33	09:52	00:19	TRIPPED ON FAULT
1507	10-Jul-24	GULBARGA	110	LINE	BYGWAT-SOLAR_IPP	SOLAR_IPP	18:42	23:10	04:28	LINE CLEAR AVAILED
1508	10-Jul-24	GULBARGA	110	LINE	GABUR-SHAHPUR2	GUGAL_110, GABUR_110	05:42	05:56	00:14	TRIPPED ON FAULT
1509	10-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	23:53	23:58	00:05	TRIPPED ON FAULT
1510	10-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	23:53	23:59	00:06	TRIPPED ON FAULT
1511	10-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	00:00	00:03	00:03	TRIPPED ON FAULT
1512	10-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-SHAHPUR-1	SHAHPUR-1_110	11:06	11:08	00:02	LINE CLEAR AVAILED
1513	10-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	10:11	16:05	05:54	LINE CLEAR AVAILED
1514	10-Jul-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	11:50	12:06	00:16	TRIPPED ON FAULT
1515	10-Jul-24	GULBARGA	110	TRANSFORMER	HV1	WALKAMDINI_110	11:30	11:35	00:05	TRIPPED ON FAULT
1516	10-Jul-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	KADAGANCHI_110	16:20	18:00	01:40	LINE CLEAR AVAILED
1517	10-Jul-24	GULBARGA	110	TRANSFORMER	HV3	MUNIRABAD_220	10:37	12:46	02:09	LINE CLEAR AVAILED
1518	10-Jul-24	GULBARGA	110	LINE	KAMPLI-MALLAPURA	KAMPLI_110	08:05	08:11	00:06	LINE CLEAR AVAILED
1519	10-Jul-24	GULBARGA	110	LINE	SHAHPUR-CHITAPUR	CHITAPUR_110,KORWARTEMPLE_110	00:29	00:36	00:07	TRIPPED ON FAULT
1520	10-Jul-24	GULBARGA	110	LINE	SHAHPUR-KORWARTEMPLE	KORWARTEMPLE_110	00:29	00:36	00:07	TRIPPED ON FAULT
1521	10-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-LINGASUGUR	HATTIGUDUR_110	11:41	11:47	00:06	LINE CLEAR AVAILED
1522	10-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-RTPS1	HATTIGUDUR_220	11:55	11:59	00:04	LINE CLEAR AVAILED
1523	10-Jul-24	GULBARGA	220	LINE	HATTIGUDUR-RTPS2	HATTIGUDUR_220	11:50	11:54	00:04	LINE CLEAR AVAILED
1524	10-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	22:07	22:22	00:15	TRIPPED ON FAULT
1525	10-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1526	10-Jul-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	10:40	13:00	02:20	LINE CLEAR AVAILED
1527	10-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	14:45	15:25	00:40	TRIPPED ON FAULT
1528	10-Jul-24	HASSAN	66	LINE	BYARAPU-BAGUR	K BYARAPURA_66	10:43	13:05	02:22	LINE CLEAR AVAILED
1529	10-Jul-24	HASSAN	66	TRANSFORMER	HV1	DODDAMAGGE_66	13:20	14:04	00:44	LINE CLEAR AVAILED
1530	10-Jul-24	HASSAN	66	TRANSFORMER	HV1	K BYARAPURA_66	10:43	13:05	02:22	LINE CLEAR AVAILED
1531	10-Jul-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	12:41	13:41	01:00	TRIPPED ON FAULT
1532	10-Jul-24	HASSAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	12:17	13:23	01:06	LINE CLEAR AVAILED
1533	10-Jul-24	HASSAN	66	LINE	LV3	MRSMG_220	09:07	14:24	05:17	LINE CLEAR AVAILED
1534	10-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPUA_66	07:55	18:40	10:45	LINE CLEAR AVAILED
1535	10-Jul-24	HASSAN	66	LINE	SATHENA-UDAY	SATHENAHALLI_66	06:00	06:10	00:10	LINE CLEAR AVAILED
1536	10-Jul-24	HASSAN	110	LINE	ARSK2-GANDASI	ARSIKERE_220	10:50	14:18	03:28	LINE CLEAR AVAILED
1537	10-Jul-24	HASSAN	110	LINE	BLGMBA-AFT CB	BELAGUMBA_110	10:50	14:22	03:32	LINE CLEAR AVAILED
1538	10-Jul-24	HASSAN	110	LINE	GANDAS-KADUR	GANDASI_110	10:50	16:40	05:50	LINE CLEAR AVAILED
1539	10-Jul-24	HASSAN	110	LINE	GURUPUR-MDBDRE	GURUPURA_110	10:40	14:13	03:33	LINE CLEAR AVAILED
1540	10-Jul-24	HASSAN	110	TRANSFORMER	HV1	GANDASI_110	12:09	18:07	05:58	LINE CLEAR AVAILED
1541	10-Jul-24	HASSAN	110	TRANSFORMER	HV1	GURUVAYANKERE_110	10:57	16:56	05:59	LINE CLEAR AVAILED
1542	10-Jul-24	HASSAN	110	TRANSFORMER	HV1	KONDENALU_110	10:10	16:50	06:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1543	10-Jul-24	HASSAN	110	TRANSFORMER	HV1	KULASHEKARA_110	13:03	14:09	01:06	LINE CLEAR AVAILED
1544	10-Jul-24	HASSAN	110	TRANSFORMER	HV1 CB	BELAGUMBA_110	10:05	15:30	05:25	LINE CLEAR AVAILED
1545	10-Jul-24	HASSAN	110	TRANSFORMER	HV2	ARASIKERE_110	14:41	14:59	00:18	LINE CLEAR AVAILED
1546	10-Jul-24	HASSAN	110	TRANSFORMER	HV2	GANDASI_110	10:30	16:40	06:10	LINE CLEAR AVAILED
1547	10-Jul-24	HASSAN	110	TRANSFORMER	HV2	KONDENALU_110	10:10	16:50	06:40	LINE CLEAR AVAILED
1548	10-Jul-24	HASSAN	110	TRANSFORMER	HV2 CB	BELAGUMBA_110	10:05	15:30	05:25	LINE CLEAR AVAILED
1549	10-Jul-24	HASSAN	110	TRANSFORMER	HV3	ALKOLA_110	12:30	12:50	00:20	TRIPPED ON FAULT
1550	10-Jul-24	HASSAN	110	TRANSFORMER	HV3	MRSMSG_220	09:07	14:24	05:17	LINE CLEAR AVAILED
1551	10-Jul-24	HASSAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	12:07	12:16	00:09	TRIPPED ON FAULT
1552	10-Jul-24	HASSAN	110	LINE	KONAJE-BCROAD	KONAJE_110	11:33	13:00	01:27	LINE CLEAR AVAILED
1553	10-Jul-24	HASSAN	110	LINE	KONAJE-JAPPU	KONAJE_110	10:12	11:33	01:21	LINE CLEAR AVAILED
1554	10-Jul-24	HASSAN	110	LINE	KONDENA-KADUR-ARSIKERE	KONDENALU_110	10:10	16:50	06:40	LINE CLEAR AVAILED
1555	10-Jul-24	HASSAN	110	LINE	MOODAB-GURUPURA	MOODABIDRE-110	10:40	14:13	03:33	LINE CLEAR AVAILED
1556	10-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	12:07	12:25	00:18	TRIPPED ON FAULT
1557	10-Jul-24	MYSORE	66	LINE	BANNIMANTAP-FTS 1	NO STATIONS EFFECTED	13:32	13:44	00:12	LINE CLEAR AVAILED
1558	10-Jul-24	MYSORE	66	LINE	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	01:18	01:24	00:05	TRIPPED ON FAULT
1559	10-Jul-24	MYSORE	66	LINE	CR NAGARA-KOLLEGALA	MUGUR_66JANNUR_66THAYUR_66 TNARASIPURA_66	05:54	06:02	00:07	TRIPPED ON FAULT
1560	10-Jul-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)	16:23 (10/07/2024)	365:34 HRs	LINE CLEAR AVAILED
1561	10-Jul-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	13:10	14:30	01:20	LINE CLEAR AVAILED
1562	10-Jul-24	MYSORE	66	TRANSFORMER	HV1	KIADBMANDYA_66	08:27	08:35	00:07	MAIN SUPPLY FAILURE
1563	10-Jul-24	MYSORE	66	TRANSFORMER	HV1	KIADBMANDYA_66	16:12	16:23	00:10	MAIN SUPPLY FAILURE
1564	10-Jul-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	10:22	18:10	07:48	LINE CLEAR AVAILED
1565	10-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1566	10-Jul-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	11:32	13:19	01:46	LINE CLEAR AVAILED
1567	10-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	16:53	17:02	00:08	LINE CLEAR AVAILED
1568	10-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
1569	10-Jul-24	MYSORE	66	LINE	KR PETE-AKKIHEBBAL 1	AKKIHEBBAL_66	10:03	18:52	08:49	LINE CLEAR AVAILED
1570	10-Jul-24	MYSORE	66	LINE	KR PETE-AKKIHEBBAL 2	AKKIHEBBAL_66	10:03	18:52	08:49	LINE CLEAR AVAILED
1571	10-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1572	10-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1573	10-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
1574	10-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANGODU	NO STATIONS EFFECTED	11:10	15:24	04:13	LINE CLEAR AVAILED
1575	10-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (06/07/2024)			LINE CLEAR AVAILED
1576	10-Jul-24	MYSORE	220	TRANSFORMER	HV1	MADHUVANAHALLI_220	11:50	11:52	00:01	LINE CLEAR AVAILED
1577	10-Jul-24	MYSORE	220	TRANSFORMER	HV1	VAJMANGALA_220	16:12	16:23	00:11	TRIPPED ON FAULT
1578	10-Jul-24	MYSORE	220	TRANSFORMER	HV2	MADHUVANAHALLI_220	11:52	13:43	01:50	LINE CLEAR AVAILED
1579	10-Jul-24	MYSORE	220	LINE	KADAKOLA-HOOTAGALLI	NO STATIONS EFFECTED	11:44	12:10	00:26	TRIPPED ON FAULT
1580	10-Jul-24	MYSORE	220	LINE	VAJAMANGALA -TK HALLI	NO STATIONS EFFECTED	08:15	08:29	00:14	TRIPPED ON FAULT
1581	10-Jul-24	MYSORE	220	LINE	VAJAMANGALA -TK HALLI	NO STATIONS EFFECTED	16:12	16:19	00:07	TRIPPED ON FAULT
1582	10-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	SUZLON1_IPP_66	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
1583	10-Jul-24	TUMKUR	66	LINE	220KV GUTTUR-66KV HALASABALU LINE	66KV GUTTUR,HARIHAR HOSPETE POLY FIBER	15:46	15:56	00:10	TRIPPED ON FAULT
1584	10-Jul-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE 2	66 KV CHALLAKERE MUSS	00:00	00:10	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1585	10-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI, HDPURA	16:10	16:44	00:34	TRIPPED ON FAULT
1586	10-Jul-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	RAMAGIRI_66, ENERCON_IPP_66	06:15	06:25	00:10	TRIPPED ON FAULT
1587	10-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	16:08	16:42	00:33	MAIN SUPPLY FAILURE
1588	10-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:32	13:32	03:00	LINE CLEAR AVAILED
1589	10-Jul-24	TUMKUR	66	LINE	HARIYABBE-HIRIYUR	HARIYABBE_66	08:05	08:10	00:05	LINE CLEAR AVAILED
1590	10-Jul-24	TUMKUR	66	LINE	HARIYABBE-HIRIYUR	HARIYABBE_66	08:00	08:10	00:10	LINE CLEAR AVAILED
1591	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	HALUMAMESHWARA_66	09:35	13:45	04:10	LINE CLEAR AVAILED
1592	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	HALUMAMESHWARA_66	13:50	15:50	02:00	LINE CLEAR AVAILED
1593	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	MADHUGIRI_66	15:00	15:17	00:17	TRIPPED ON FAULT
1594	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	RAMPURA_66	16:35	16:40	00:05	TRIPPED ON FAULT
1595	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (20MVA)	CHANNAGIRI_66	12:56	13:12	00:15	LINE CLEAR AVAILED
1596	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (20MVA)	PAVAGADA_66	13:37	13:45	00:08	TRIPPED ON FAULT
1597	10-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (8MVA)	TAVAREKERE_66	11:10	11:14	00:04	TRIPPED ON FAULT
1598	10-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (20MVA)	ANTHARASANAHALLI_66	15:03	LINE NOT YET CHARGED		TRIPPED ON FAULT
1599	10-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (20MVA)	CHANNAGIRI_66	13:08	13:12	00:04	LINE CLEAR AVAILED
1600	10-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2KV	GUTUR_400	14:13 (06.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
1601	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11 KV,HV2(20MVA)	AMBEWADI_220	16:21 (10.07.2024)	12:29 (11.07.2024)	20:08	LINE CLEAR AVAILED
1602	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BJCTY(THORVI)_110	12:15	13:00	00:45	LINE CLEAR AVAILED
1603	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	INDI_220	08:16	10:27	02:11	LINE CLEAR AVAILED
1604	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	INDI_220	10:52	11:04	00:12	LINE CLEAR AVAILED
1605	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	INDI_220	11:47	12:27	00:40	LINE CLEAR AVAILED
1606	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	INDI_220	16:19	17:30	01:11	LINE CLEAR AVAILED
1607	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULAGETRE CROSS_110	11:15	11:20	00:05	TRIPPED ON FAULT
1608	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	UCHAGOAN_110	06:34	13:58	07:24	LINE CLEAR AVAILED
1609	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	SINDAGI_110	12:35	12:51	00:16	TRIPPED ON FAULT
1610	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA-HV2)	RANEENNUR_220	15:42	16:27	00:45	LINE CLEAR AVAILED
1611	11-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA-HV1)	RANEENNUR_220	16:28	17:02	00:34	LINE CLEAR AVAILED
1612	11-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,HV1	MUGALKHOD_220	10:16	11:50	01:34	LINE CLEAR AVAILED
1613	11-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	MUGALKHOD_220	10:16	11:52	01:36	LINE CLEAR AVAILED
1614	11-Jul-24	BAGALKOTE	110	LINE	BAGAKOT-F2 BAGALKOT-2	BAGAKOT_220	03:51	03:57	00:06	TRIPPED ON FAULT
1615	11-Jul-24	BAGALKOTE	110	LINE	KAMBAGI-F2 (TODALBAGI)	KAMBAGI_110	12:48	18:08	05:20	LINE CLEAR AVAILED
1616	11-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	05:45	12:27	06:42	TRIPPED ON FAULT
1617	11-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR-HIDIKAL	MAHALINGAPUR_220	20:48	21:27	00:39	TRIPPED ON FAULT
1618	11-Jul-24	BAGALKOTE	110	LINE	MK HUBLI220-BAILHONGAL	MK HUBLI_220	19:46	19:52	00:06	LINE CLEAR AVAILED
1619	11-Jul-24	BAGALKOTE	110	LINE	MK HUBLI220-BIDI	MK HUBLI_220	19:46	19:50	00:04	LINE CLEAR AVAILED
1620	11-Jul-24	BAGALKOTE	110	LINE	MK HUBLI220-HIREBAGEWADI	MK HUBLI_220	19:46	21:19	01:33	LINE CLEAR AVAILED
1621	11-Jul-24	BAGALKOTE	110	LINE	MK HUBLI220-KHANAPUR	MK HUBLI_220	19:46	19:48	00:02	LINE CLEAR AVAILED
1622	11-Jul-24	BAGALKOTE	110	LINE	MK HUBLI-MACHE	MK HUBLI_110	19:35	19:44	00:09	LINE CLEAR AVAILED
1623	11-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1624	11-Jul-24	BAGALKOTE	110	LINE	RANEENNUR-HIREKERUR	RANEENNUR_220	03:50	04:01	00:11	TRIPPED ON FAULT
1625	11-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1626	11-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1627	11-Jul-24	BAGALKOTE	110	LINE	UTTUR-MAHALINGAPUR(RANNABELAGALI)	UTTUR_110	13:48 (10.07.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1628	11-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1629	11-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	MK HUBLI_220	19:46	20:34	00:48	TRIPPED ON FAULT
1630	11-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	MK HUBLI_220	19:46	20:35	00:49	TRIPPED ON FAULT
1631	11-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV1	MK HUBLI_220	19:46	21:03	01:17	LINE CLEAR AVAILED
1632	11-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV2	MK HUBLI_220	19:46	21:05	01:19	LINE CLEAR AVAILED
1633	11-Jul-24	BAGALKOTE	220	LINE	HAVERI220-GUTTUR1	HAVERI_220	12:40	18:19	05:39	LINE CLEAR AVAILED
1634	11-Jul-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA-2	HUBLI_220	07:24	14:34	07:10	TRIPPED ON FAULT
1635	11-Jul-24	BAGALKOTE	220	LINE	NARENDRA-HUBLI	NARENDRA_220	07:24	14:34	07:10	TRIPPED ON FAULT
1636	11-Jul-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST STEEL	18:24	18:40	00:16	TRIPPED ON FAULT
1637	11-Jul-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	15:08	15:12	00:04	LINE CLEAR AVAILED
1638	11-Jul-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	17:10	17:15	00:05	LINE CLEAR AVAILED
1639	11-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	VEMGAL, KYALANUR AND TALGUNDA	10:02	10:06	00:04	LINE CLEAR AVAILED
1640	11-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	07:19	07:23	00:04	LINE CLEAR AVAILED
1641	11-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	VEMGAL, KYALANUR AND TALGUNDA	17:51	18:00	00:09	LINE CLEAR AVAILED
1642	11-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	SARJAPURA 220	15:22	15:28	00:06	LINE CLEAR AVAILED
1643	11-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	SARJAPURA 220	19:00	19:05	00:05	LINE CLEAR AVAILED
1644	11-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	ABBIGERE, WELCAST STEEL	21:12	21:16	00:04	LINE CLEAR AVAILED
1645	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ALLIMARANAHALLI	13:35	14:20	00:45	LINE CLEAR AVAILED
1646	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ALLIMARANAHALLI	14:25	15:10	00:45	LINE CLEAR AVAILED
1647	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ALLIMARANAHALLI	15:15	15:50	00:35	LINE CLEAR AVAILED
1648	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	12:00	14:20	02:20	LINE CLEAR AVAILED
1649	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAASTHI	17:45	18:05	00:20	LINE CLEAR AVAILED
1650	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	11:08	16:48	05:40	LINE CLEAR AVAILED
1651	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 220	16:59	18:42	01:43	LINE CLEAR AVAILED
1652	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	09:12	09:20	00:08	TRIPPED ON FAULT
1653	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MATHIKERE RAMANAGARA	09:05	10:25	01:20	LINE CLEAR AVAILED
1654	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	08:48	09:04	00:16	LINE CLEAR AVAILED
1655	11-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	15:22	15:26	00:04	LINE CLEAR AVAILED
1656	11-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	15:22	15:26	00:04	LINE CLEAR AVAILED
1657	11-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	19:00	19:07	00:07	LINE CLEAR AVAILED
1658	11-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TUBAGERE	00:02	00:30	00:28	TRIPPED ON FAULT
1659	11-Jul-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NO STATION AFFECTED	12:09	13:59	01:50	LINE CLEAR AVAILED
1660	11-Jul-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	08:09	10:33	02:24	LINE CLEAR AVAILED
1661	11-Jul-24	GULBARGA	66	LINE	ACME_IPP-BADALADUKU	ACME_IPP	21:05	23:59	02:54	LINE CLEAR AVAILED
1662	11-Jul-24	GULBARGA	66	LINE	BANAVIKAL-ABRSL WIND_IPP	ABRSL WIND_IPP	15:00	15:50	00:50	TRIPPED ON FAULT
1663	11-Jul-24	GULBARGA	66	LINE	BANAVIKAL-ABRSL WIND_IPP	ABRSL WIND_IPP	16:01	16:45	00:44	TRIPPED ON FAULT
1664	11-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HUDEM	08:30	08:45	00:15	LINE CLEAR AVAILED
1665	11-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HUDEM	17:43	18:03	00:20	LINE CLEAR AVAILED
1666	11-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66	05:20	05:30	00:10	TRIPPED ON FAULT
1667	11-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HARAPPANAHALLI	HARAPPANAHALLI_66	14:19	14:30	00:11	TRIPPED ON FAULT
1668	11-Jul-24	GULBARGA	110	TRANSFORMER	HV2	MANVI_110	18:42	18:48	00:06	TRIPPED ON FAULT
1669	11-Jul-24	GULBARGA	110	LINE	KAMPLI-MALLAPURA	MALLAPURA_110	07:48	08:00	00:12	LINE CLEAR AVAILED
1670	11-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	22:13	22:26	00:13	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1671	11-Jul-24	GULBARGA	110	LINE	KHANAPUR-WADAGERA	KHANAPUR_110	10:12	16:28	06:16	LINE CLEAR AVAILED
1672	11-Jul-24	GULBARGA	110	LINE	TEKKALKOTE-SIRGUPPA	SIRGUPPA_110	03:30	03:40	00:10	MAIN SUPPLY FAILURE
1673	11-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	19:19	20:10	00:51	TRIPPED ON FAULT
1674	11-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC_IPP	BADALADUKU_220	10:50	11:45	00:55	TRIPPED ON FAULT
1675	11-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC_IPP	BADALADUKU_220	12:25	13:00	00:35	TRIPPED ON FAULT
1676	11-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC_IPP	BADALADUKU_220	14:45	15:10	00:25	LINE CLEAR AVAILED
1677	11-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1678	11-Jul-24	HASSAN	66	LINE	SAKSHI-HANBAL1	SAKSHIPURA_66	11:09	17:50	06:41	LINE CLEAR AVAILED
1679	11-Jul-24	HASSAN	66	LINE	SAKSHI-HANBAL2	SAKSHIPURA_66	16:05	17:10	01:05	LINE CLEAR AVAILED
1680	11-Jul-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	01:33	01:41	00:08	TRIPPED ON FAULT
1681	11-Jul-24	HASSAN	110	TRANSFORMER	HV1	ANAVATTI_110	11:10	15:01	03:51	LINE CLEAR AVAILED
1682	11-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	14:48	18:15	03:27	TRIPPED ON FAULT
1683	11-Jul-24	HASSAN	110	TRANSFORMER	HV1	VITTALA_110	10:19	13:08	02:49	LINE CLEAR AVAILED
1684	11-Jul-24	HASSAN	110	TRANSFORMER	HV2	ANAVATTI_110	15:15	17:48	02:33	LINE CLEAR AVAILED
1685	11-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	03:12	14:33	11:21	TRIPPED ON FAULT
1686	11-Jul-24	HASSAN	110	TRANSFORMER	HV3	PUTTUR_110	10:01	12:46	02:45	LINE CLEAR AVAILED
1687	11-Jul-24	HASSAN	110	LINE	KAVOOR-BAIKAMPADI	KAVOOR_220	12:16	12:21	00:05	TRIPPED ON FAULT
1688	11-Jul-24	HASSAN	110	LINE	NDKR-SUZLON	NANDIKUR_110	06:15	06:27	00:12	TRIPPED ON FAULT
1689	11-Jul-24	HASSAN	220	LINE	KEMAR-KAVR3	KEMAR_220	12:16	16:16	04:00	TRIPPED ON FAULT
1690	11-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMG_220	10:45	14:55	04:10	LINE CLEAR AVAILED
1691	11-Jul-24	HASSAN	220	LINE	VARAH1-SHIMOGA2	gen_varah1	10:45	14:55	04:10	LINE CLEAR AVAILED
1692	11-Jul-24	MYSORE	66	LINE	BEGUR 220-BEGUR-1	NO STATIONS EFFECTED	17:49	17:52	00:03	LINE CLEAR AVAILED
1693	11-Jul-24	MYSORE	66	LINE	BEGUR 220-GUNDLUPETE-2	NO STATIONS EFFECTED	18:05	18:18	00:13	LINE CLEAR AVAILED
1694	11-Jul-24	MYSORE	66	LINE	CHIKKAMANDYA-MANDYA	NO STATIONS EFFECTED	11:26	18:06	06:39	LINE CLEAR AVAILED
1695	11-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1696	11-Jul-24	MYSORE	66	TRANSFORMER	HV2	BILIKERE_66	12:52	13:25	00:33	LINE CLEAR AVAILED
1697	11-Jul-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	11:01	12:08	01:06	LINE CLEAR AVAILED
1698	11-Jul-24	MYSORE	66	TRANSFORMER	HV2	KIRUGAVALU_66	13:02	13:47	00:44	LINE CLEAR AVAILED
1699	11-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
1700	11-Jul-24	MYSORE	66	LINE	KR PETE 220-SHEELUNERE	BOOKANAKERE_66 GANJIGERE_66 SHEELUNERE_66	10:27	17:31	07:04	LINE CLEAR AVAILED
1701	11-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1702	11-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1703	11-Jul-24	MYSORE	66	LINE	NAGAMANGALA-TUBINAKERE 1	NO STATIONS EFFECTED	11:52 (11/07/2024)			LINE CLEAR AVAILED
1704	11-Jul-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)	10:24 (11/07/2024)	503:10 HRs	LINE CLEAR AVAILED
1705	11-Jul-24	MYSORE	66	LINE	SANTHE SARAGURU-KABINI-2	NO STATIONS EFFECTED	06:12	06:26	00:14	TRIPPED ON FAULT
1706	11-Jul-24	MYSORE	66	LINE	SINDHUVALLI-BEGUR	SINDHUVALLI_66	11:30	11:45	00:15	TRIPPED ON FAULT
1707	11-Jul-24	MYSORE	220	LINE	BEGUR 220-ADAKANAHALLI-2	NO STATIONS EFFECTED	16:12	16:24	00:12	LINE CLEAR AVAILED
1708	11-Jul-24	MYSORE	220	LINE	BEGUR 220-CR NAGARA-2	NO STATIONS EFFECTED	16:14	16:24	00:10	LINE CLEAR AVAILED
1709	11-Jul-24	MYSORE	220	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	9:25:00 (06/07/2024)	10:07 (11/07/2024)	129:50 hrs	LINE CLEAR AVAILED
1710	11-Jul-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_220	17:43	18:04	00:21	LINE CLEAR AVAILED
1711	11-Jul-24	MYSORE	220	TRANSFORMER	HV2	BEGUR_220	16:10	16:36	00:26	LINE CLEAR AVAILED
1712	11-Jul-24	MYSORE	220	TRANSFORMER	HV2	BEGUR_220	16:10	16:36	00:26	LINE CLEAR AVAILED
1713	11-Jul-24	MYSORE	220	TRANSFORMER	HV2	TUBINAKERE_220	12:23	17:43	05:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1714	11-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	SUZLON1_IPP_66	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
1715	11-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA AND SASALUHALLA	06:01	06:15	00:14	TRIPPED ON FAULT
1716	11-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRAHALLI,H D PURA	16:15	16:43	00:28	TRIPPED ON FAULT
1717	11-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	10:30	15:53	05:23	LINE CLEAR AVAILED
1718	11-Jul-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE	PDKOTE_66	09:22	09:27	00:05	MAIN SUPPLY FAILURE
1719	11-Jul-24	TUMKUR	66	LINE	PDKOTE-HARIYABBE	PDKOTE_66	10:18	20:20	10:02	LINE CLEAR AVAILED
1720	11-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	BILCHODE_66	07:50	08:00	00:09	TRIPPED ON FAULT
1721	11-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	GUTTUR_66	14:47	16:16	01:29	TRIPPED ON FAULT
1722	11-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (12.5MVA)	HARIYABBE_66	10:20	20:25	10:05	LINE CLEAR AVAILED
1723	11-Jul-24	TUMKUR	66	TRANSFORMER	TR1 (8MVA)	CHITRAHALLI_66	11:45	12:04	00:19	LINE CLEAR AVAILED
1724	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	CHITRAHALLI_66	11:50	12:04	00:14	LINE CLEAR AVAILED
1725	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	KUKKAWADA_66	14:28	14:36	00:07	TRIPPED ON FAULT
1726	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	MADADKERE_66	10:09	10:14	00:04	TRIPPED ON FAULT
1727	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	MAVINAKATTE_66	12:44	13:22	00:37	LINE CLEAR AVAILED
1728	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (12.5MVA)	MELLEKATTE_66	06:20	06:25	00:04	TRIPPED ON FAULT
1729	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (20MVA)	ANTHARASANAHALLI_66	(open on 10.7.24) 15:03	(CHARGED on 11.7.24) 15:00	24:10 hrs	TRIPPED ON FAULT
1730	11-Jul-24	TUMKUR	66	TRANSFORMER	TR2 (8MVA)	HARIYABBE_66	10:20	20:25	10:05	LINE CLEAR AVAILED
1731	11-Jul-24	TUMKUR	66	TRANSFORMER	TR3 (12.5MVA)	HARIYABBE_66	10:20	20:25	10:05	LINE CLEAR AVAILED
1732	11-Jul-24	TUMKUR	110	LINE	KB CROSS 220KV- MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	06:12	06:24	00:12	TRIPPED ON FAULT
1733	11-Jul-24	TUMKUR	110	LINE	KB CROSS 220KV-THIMMANAHALLI_110	C N HALLI_110, THIMMANAHALLI_110	06:07	06:23	00:16	TRIPPED ON FAULT
1734	11-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-3-220KV CHITRADURGA	66KV AIMANGALA,MALLAPANAHALLI, SIRIGERE, BHARAMSAGARA,KNNL,VIJAPURA	03:26	05:07	01:41	TRIPPED ON FAULT
1735	11-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-220KV PGCIL LINE	CHITRADURGA_220	03:26	13:15	09:49	TRIPPED ON FAULT
1736	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV BARC LINE-1	220KV BARC	11:18	11:45	00:27	TRIPPED ON FAULT
1737	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV BARC LINE-1	220KV BARC	11:49	12:39	00:50	TRIPPED ON FAULT
1738	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV CHITRADURGA LINE	CHITRADURGA_220	11:18	15:57	04:39	TRIPPED ON FAULT
1739	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV H.M HOLE LINE 1	HIEMALLANAHOLE	11:18	11:38	00:20	TRIPPED ON FAULT
1740	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV H.M HOLE LINE 1	HIEMALLANAHOLE 1	11:49	12:11	00:22	TRIPPED ON FAULT
1741	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV HIRIYUR LINE	HIRIYUR_220	11:18	11:33	00:15	TRIPPED ON FAULT
1742	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV HIRIYUR LINE	SANEKERE_66, THALLAKK_220	11:49	12:02	00:13	TRIPPED ON FAULT
1743	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITUR LINE-1	220KV SAGITUR	11:18	11:41	00:23	TRIPPED ON FAULT
1744	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITUR LINE-1	220KV SAGITUR	11:49	12:45	00:56	TRIPPED ON FAULT
1745	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITUR LINE-2	220KV SAGITUR	11:18	11:41	00:23	TRIPPED ON FAULT
1746	11-Jul-24	TUMKUR	220	LINE	220KV THALLAK-220KV SAGITUR LINE-2	220KV SAGITUR	11:49	12:45	00:56	TRIPPED ON FAULT
1747	11-Jul-24	TUMKUR	220	LINE	400KV GUTTUR - 220KVCHITRADURGA LINE	CHITRADURGA_220	11:21	15:31	04:10	TRIPPED ON FAULT
1748	11-Jul-24	TUMKUR	220	LINE	JAGALURU_66-CHITRADURGA_220-	JAGALURU_66, SOKKE_66	12:43	16:43	04:00	LINE CLEAR AVAILED
1749	11-Jul-24	TUMKUR	220	LINE	NITTUR 220KV- ARASIKERE	NITTUR_220	16:15	17:29	01:14	LINE CLEAR AVAILED
1750	11-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2KV	GUTUR_400	(open on 7.7.24) 2:13:00	(CHARGED on 11.7.24) 15:20	113:33 Hrs	LINE CLEAR AVAILED
1751	12-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	21:27	21:37	00:10	TRIPPED ON FAULT
1752	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	HUDLI_110	10:25	14:35	04:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1753	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	UTTUR_110	12:13	12:20	00:07	TRIPPED ON FAULT
1754	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	HUDLI_110	10:25	14:35	04:10	LINE CLEAR AVAILED
1755	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MALGHAN(B)_110	15:25	15:30	00:05	TRIPPED ON FAULT
1756	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	HIDIKAL_110	15:08	15:10	00:02	TRIPPED ON FAULT
1757	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	HIDIKAL_110	15:34	16:17	00:43	LINE CLEAR AVAILED
1758	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	UTTUR_110	12:13	12:22	00:09	TRIPPED ON FAULT
1759	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIRSI_110	12:11	12:29	00:18	LINE CLEAR AVAILED
1760	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1(20MVA)	SINDAGI_110	16:50	17:07	00:17	TRIPPED ON FAULT
1761	12-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA-HV2)	RANEENNUR_220	13:14	14:06	00:52	LINE CLEAR AVAILED
1762	12-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-KAVALWADA(NK-2)	AMBEWADI_220	18:53	18:56	00:03	LINE CLEAR AVAILED
1763	12-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-KAVALWADA(NK-2)	AMBEWADI_220	18:56	18:58	00:02	TRIPPED ON FAULT
1764	12-Jul-24	BAGALKOTE	110	LINE	ANKALAGI- BELGAUM220 (HUDLI)	ANKALAGI_110	10:03	14:35	04:32	LINE CLEAR AVAILED
1765	12-Jul-24	BAGALKOTE	110	LINE	BELGAUM- ANKALAGI(HUDALI)	BELGAUM_220	10:20	14:13	03:53	LINE CLEAR AVAILED
1766	12-Jul-24	BAGALKOTE	110	LINE	HUDLI- ANKALAGI	HUDLI_110	09:56	14:30	04:34	LINE CLEAR AVAILED
1767	12-Jul-24	BAGALKOTE	110	LINE	HUDLI- BELGAUM	HUDLI_110	10:20	14:15	03:55	LINE CLEAR AVAILED
1768	12-Jul-24	BAGALKOTE	110	LINE	HUDLI- BSPL1&2	HUDLI_110	10:15	14:35	04:20	LINE CLEAR AVAILED
1769	12-Jul-24	BAGALKOTE	110	LINE	HUNGUND- JINDAL	HUNGUND_110	14:29	15:17	00:48	LINE CLEAR AVAILED
1770	12-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR-DAVALESHWAR	MAHALINGAPUR_220	12:28	13:38	01:10	LINE CLEAR AVAILED
1771	12-Jul-24	BAGALKOTE	110	LINE	MK HUBLI-BIDI	MK HUBLI_220	06:06	06:33	00:27	TRIPPED ON FAULT
1772	12-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1773	12-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1774	12-Jul-24	BAGALKOTE	110	LINE	SIRSI220-SIRSI2	SIRSI_220	14:48	15:10	00:22	TRIPPED ON FAULT
1775	12-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1776	12-Jul-24	BAGALKOTE	110	LINE	UTTUR-MAHALINGAPUR(RANNABELAGALI)	UTTUR_110	13:48 (10.07.2024)	12:19 (12.07.2024)	46:31:00	LINE CLEAR AVAILED
1777	12-Jul-24	BAGALKOTE	110	LINE	YADWAD-UTTUR	YADWAD_110	12:13	12:19	00:06	LINE CLEAR AVAILED
1778	12-Jul-24	BAGALKOTE	110	LINE	YADWAD-UTTUR	YADWAD_110	13:02	13:18	00:16	LINE CLEAR AVAILED
1779	12-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1780	12-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,LV1	SIRSI_220	14:48	15:10	00:22	TRIPPED ON FAULT
1781	12-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA-1	AMBEWADI_220	06:08	13:18	07:10	TRIPPED ON FAULT
1782	12-Jul-24	BAGALKOTE	220	LINE	BAGALKOT220 - VAJARAMATTI-1	BAGAKOT_220	11:44	19:19	07:35	LINE CLEAR AVAILED
1783	12-Jul-24	BAGALKOTE	220	LINE	NARENDRA-AMBEWADI1	NARENDRA_220	06:08	13:18	07:10	TRIPPED ON FAULT
1784	12-Jul-24	BAGALKOTE	220	LINE	NARENDRA-SHIGGOAN	NARENDRA_220	13:02	15:17	02:15	LINE CLEAR AVAILED
1785	12-Jul-24	BAGALKOTE	220	LINE	SHIGGOAN-NARENDRA	SHIGGOAN_220	13:02	15:17	02:15	LINE CLEAR AVAILED
1786	12-Jul-24	BANGALORE	66	LINE	220KV HBR LAYOUT 220 - HBR LAYOUT 66	BANASWADI, HBR LAYOUT 66	11:55	12:26	00:31	MAIN SUPPLY FAILURE
1787	12-Jul-24	BANGALORE	66	LINE	66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4	ATTUR YELAHANKA	11:24	11:53	00:29	TRIPPED ON FAULT
1788	12-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:53	06:06	00:13	TRIPPED ON FAULT
1789	12-Jul-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	66KV HEJJALA	05:52	06:05	00:13	TRIPPED ON FAULT
1790	12-Jul-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	T BEGUR	23:55	23:59	00:04	LINE CLEAR AVAILED
1791	12-Jul-24	BANGALORE	66	LINE	66KV DOMMASANDRA - WIPRO EHT	WIPRO EHT	20:18	23:59	03:41	LINE CLEAR AVAILED
1792	12-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - POTTERY ROAD	POTTERY ROAD	11:54	12:40	00:46	MAIN SUPPLY FAILURE
1793	12-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	HENNUR CROSS, PURAVANKARA PALM BEACH	11:55	12:20	00:25	MAIN SUPPLY FAILURE
1794	12-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL)_DG3	KONDASPURA	11:56	12:26	00:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1795	12-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	66/11KV BANASWADI MUSS	16:57	17:05	00:08	TRIPPED ON FAULT
1796	12-Jul-24	BANGALORE	66	LINE	66KV ITI 220 - DRDO (EHT)	DRDO(EHT)	11:54	12:35	00:41	MAIN SUPPLY FAILURE
1797	12-Jul-24	BANGALORE	66	LINE	66KV ITI 220 - NGEF	NGEF	11:54	12:35	00:41	MAIN SUPPLY FAILURE
1798	12-Jul-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	10:03	15:22	05:19	LINE CLEAR AVAILED
1799	12-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	21:35	22:00	00:25	LINE CLEAR AVAILED
1800	12-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	KYALANUR,VEMAGAL, TALGUNDA	10:02	10:07	00:05	LINE CLEAR AVAILED
1801	12-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	KYALANUR,VEMAGAL, TALGUNDA	17:56	18:00	00:04	LINE CLEAR AVAILED
1802	12-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - BYATARAYANAPURA (L&T) _DG4	BYTARAYANAPURA	11:55	12:10	00:15	MAIN SUPPLY FAILURE
1803	12-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - MANYATA 66 _DG3	MANYATHA 66	11:55	12:19	00:24	MAIN SUPPLY FAILURE
1804	12-Jul-24	BANGALORE	66	LINE	66KV MANYATA 220 - SHOBHA CITY _DG3	SHOBHA CITY	11:55	12:20	00:25	MAIN SUPPLY FAILURE
1805	12-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - VIJAYANAGAR	VIJAYNAGAR	10:03	17:12	07:09	LINE CLEAR AVAILED
1806	12-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDDABELAVANGALA,GUNDAMG ERRE ABD SASLU	16:45	17:03	00:18	TRIPPED ON FAULT
1807	12-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KHB DC_SC _DG1	KHB	11:52	12:24	00:32	MAIN SUPPLY FAILURE
1808	12-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAILWHEEL AND AXLE SECORTES - ATTURU DG4	RAILWHEEL AND AXLE SECORTES (EHT)	11:52	12:24	00:32	MAIN SUPPLY FAILURE
1809	12-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SANJEEVANADODDI	66KV SANJEEVAYYANADODDI	18:35	18:55	00:20	TRIPPED ON FAULT
1810	12-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST STEEL DG-3	WELL CAST STEEL	06:03	06:06	00:03	LINE CLEAR AVAILED
1811	12-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	18:25	19:00	00:35	MAIN SUPPLY FAILURE
1812	12-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR - AREHALLI	AREHALLI	18:26	19:05	00:39	MAIN SUPPLY FAILURE
1813	12-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO GIS (TR-1)), GLOBAL EHT	18:26	19:06	00:40	MAIN SUPPLY FAILURE
1814	12-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	18:25	19:06	00:41	MAIN SUPPLY FAILURE
1815	12-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMNAYAPURA 66	18:26	18:58	00:32	MAIN SUPPLY FAILURE
1816	12-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI	14:49	17:32	02:43	LINE CLEAR AVAILED
1817	12-Jul-24	BANGALORE	66	LINE	66KV WELCAST STEEL - ABBIGERE	WELL CAST STEEL	11:51	11:54	00:03	LINE CLEAR AVAILED
1818	12-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HOSKOTE 66	19:00	19:55	00:55	LINE CLEAR AVAILED
1819	12-Jul-24	BANGALORE	66	TRANSFORMER	HV1	K RAGHUTTAHALLI	12:40	13:35	00:55	LINE CLEAR AVAILED
1820	12-Jul-24	BANGALORE	66	TRANSFORMER	HV1	T G HALLI	14:25	14:35	00:10	TRIPPED ON FAULT
1821	12-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	08:53	08:59	00:06	TRIPPED ON FAULT
1822	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	D CROSS	17:03	17:40	00:37	TRIPPED ON FAULT
1823	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GUNDLU KOTHUR	10:25	10:55	00:30	LINE CLEAR AVAILED
1824	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	JAYADEVA	05:41	08:57	03:16	TRIPPED ON FAULT
1825	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	K RAGHUTTAHALLI	13:35	14:30	00:55	LINE CLEAR AVAILED
1826	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	S M MANGALA	12:23	12:40	00:17	LINE CLEAR AVAILED
1827	12-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	10:21	10:30	00:09	TRIPPED ON FAULT
1828	12-Jul-24	BANGALORE	66	TRANSFORMER	HV3	KGF	11:20	13:15	01:55	LINE CLEAR AVAILED
1829	12-Jul-24	BANGALORE	220	LINE	220KV A STATION 220 - NRS 220	NO STATION AFFECTED	20:19	23:59	03:40	LINE CLEAR AVAILED
1830	12-Jul-24	BANGALORE	220	LINE	220KV HOODY 220 - HBR LAYOUT 220	HBR LAYOUT 220	11:54	12:40	00:46	TRIPPED ON FAULT
1831	12-Jul-24	BANGALORE	220	LINE	220KV HOODY 220 - ITI 220	ITI 220	11:54	12:37	00:43	TRIPPED ON FAULT
1832	12-Jul-24	BANGALORE	220	LINE	220KV KHODAYS 220 - SUBRAMANYAPURA 220	SUBRAMNAYAPURA 220	18:26	18:52	00:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1833	12-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	MANYATHA 220	11:52	12:15	00:23	TRIPPED ON FAULT
1834	12-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - SAHAKARNAGAR 220	MANYATHA 220	11:52	12:14	00:22	TRIPPED ON FAULT
1835	12-Jul-24	BANGALORE	220	LINE	220KV PUTTENAHALLI 220 - SAHAKARNAGAR 2	NO STATION AFFECTED	11:52	12:09	00:17	TRIPPED ON FAULT
1836	12-Jul-24	BANGALORE	220	LINE	220KV SINGANAYAKANAHALLI PGCIL 400 - PUTTENAHALLI 2	YELAHANKA 220	11:52	12:03	00:11	TRIPPED ON FAULT
1837	12-Jul-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	220KV SUBRAMANYAPURA	18:22	18:52	00:30	TRIPPED ON FAULT
1838	12-Jul-24	BANGALORE	220	TRANSFORMER	HV2	HBR LAYOUT 220	11:55	12:25	00:30	TRIPPED ON FAULT
1839	12-Jul-24	GULBARGA	66	LINE	CHILAKANAHATTI-HANASI	CHILAKANAHATTI_66	10:30	13:30	03:00	LINE CLEAR AVAILED
1840	12-Jul-24	GULBARGA	66	LINE	HALAVAGALU-KNNL	KNNL NITTUR_IPP	09:00	09:15	00:15	TRIPPED ON FAULT
1841	12-Jul-24	GULBARGA	66	LINE	MUNIRABAD-TIELINE	TIELINE_66	08:13	11:47	03:34	LINE CLEAR AVAILED
1842	12-Jul-24	GULBARGA	66	LINE	TELGI-NEELGUNDA	TELGI_66, OBJ HALLI_66, KURUBANAHALLI_66	15:05	15:50	00:45	LINE CLEAR AVAILED
1843	12-Jul-24	GULBARGA	110	LINE	ALLIPUR-MUNIRABAD	TORANGALU_110, KURGOD_110, KUPTINI_110, KIADB_110, METRI_110, SIRIGERI CROSS_110	15:50	16:04	00:14	TRIPPED ON FAULT
1844	12-Jul-24	GULBARGA	110	LINE	CHITAPUR-SAHAHABAD	CHITAPUR_110	19:36	19:50	00:14	TRIPPED ON FAULT
1845	12-Jul-24	GULBARGA	110	LINE	CHITAPUR-SAHAHABAD	CHITAPUR_110	19:55	20:40	00:45	TRIPPED ON FAULT
1846	12-Jul-24	GULBARGA	110	TRANSFORMER	HV1	APMC_110	16:43	17:20	00:37	LINE CLEAR AVAILED
1847	12-Jul-24	GULBARGA	110	TRANSFORMER	HV1	HALAVARTHI_220	15:40	15:44	00:04	TRIPPED ON FAULT
1848	12-Jul-24	GULBARGA	110	TRANSFORMER	HV1	KHANAPUR_110	12:32	23:59	11:27	LINE CLEAR AVAILED
1849	12-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	14:08	14:20	00:12	TRIPPED ON FAULT
1850	12-Jul-24	GULBARGA	110	LINE	KHANAPUR-WADAGERA	KHANAPUR_110	23:30	23:40	00:10	TRIPPED ON FAULT
1851	12-Jul-24	GULBARGA	110	LINE	KORWARTEMPLE-SHAHABAD	KORWARTEMPLE_110	19:36	19:50	00:14	TRIPPED ON FAULT
1852	12-Jul-24	GULBARGA	110	LINE	KORWARTEMPLE-SHAHABAD	KORWARTEMPLE_110	19:55	20:40	00:45	TRIPPED ON FAULT
1853	12-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	04:40	04:50	00:10	TRIPPED ON FAULT
1854	12-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:35	05:50	00:15	TRIPPED ON FAULT
1855	12-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:50	17:30	11:40	LINE CLEAR AVAILED
1856	12-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	20:10	20:25	00:15	TRIPPED ON FAULT
1857	12-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	04:43	04:50	00:07	TRIPPED ON FAULT
1858	12-Jul-24	GULBARGA	220	TRANSFORMER	HV1	SHAHABAD_220	17:47	18:52	01:05	TRIPPED ON FAULT
1859	12-Jul-24	GULBARGA	220	TRANSFORMER	HV1	SHAHABAD_220	20:54	21:27	00:33	TRIPPED ON FAULT
1860	12-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1861	12-Jul-24	GULBARGA	220	LINE	RTPS2-RAMASAMUDRA	RAMASAMUDRA_220	20:47	23:59	03:13	LINE CLEAR AVAILED
1862	12-Jul-24	HASSAN	66	LINE	HASSN22-MALLALI	HASSAN_220	23:03 (12.7.2024)			TRIPPED ON FAULT
1863	12-Jul-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	23:03 (12.7.2024)			TRIPPED ON FAULT
1864	12-Jul-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	11:17	13:15	01:58	LINE CLEAR AVAILED
1865	12-Jul-24	HASSAN	66	LINE	LV2	HASSAN_220	23:03	23:13	00:10	TRIPPED ON FAULT
1866	12-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	23:02(12.07.2024)			MAIN SUPPLY FAILURE
1867	12-Jul-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	11:55	15:35	03:40	LINE CLEAR AVAILED
1868	12-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	04:54	06:46	01:52	LINE CLEAR AVAILED
1869	12-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	14:10	15:20	01:10	LINE CLEAR AVAILED
1870	12-Jul-24	HASSAN	110	TRANSFORMER	HV2	NANDIKUR_110	23:31(12.07.2024)			TRIPPED ON FAULT
1871	12-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	11:50	12:01	00:11	LINE CLEAR AVAILED
1872	12-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	15:27	15:32	00:05	LINE CLEAR AVAILED
1873	12-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	11:58	15:21	03:23	LINE CLEAR AVAILED
1874	12-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	11:03	11:12	00:09	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1875	12-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	13:19	13:26	00:07	LINE CLEAR AVAILED
1876	12-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	11:09	11:15	00:06	MAIN SUPPLY FAILURE
1877	12-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	13:07	13:11	00:04	LINE CLEAR AVAILED
1878	12-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	11:09	11:15	00:06	MAIN SUPPLY FAILURE
1879	12-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	13:07	13:10	00:03	MAIN SUPPLY FAILURE
1880	12-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTALA_110	13:06	13:08	00:02	LINE CLEAR AVAILED
1881	12-Jul-24	HASSAN	220	TRANSFORMER	HV2	HASSAN_220	23:03	23:13	00:10	TRIPPED ON FAULT
1882	12-Jul-24	HASSAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	11:40	14:38	02:58	LINE CLEAR AVAILED
1883	12-Jul-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	11:40	14:38	02:58	LINE CLEAR AVAILED
1884	12-Jul-24	HASSAN	220	LINE	PUTTUR-VITTALA	PUTTUR_220	11:08	13:07	01:59	LINE CLEAR AVAILED
1885	12-Jul-24	MYSORE	66	LINE	BEGUR 220-BEGUR-1	NO STATIONS EFFECTED	12:58	13:08	00:10	LINE CLEAR AVAILED
1886	12-Jul-24	MYSORE	66	LINE	CHIKKMANDYA-MANDYA	NO STATIONS EFFECTED	10:35	21:53	11:18	LINE CLEAR AVAILED
1887	12-Jul-24	MYSORE	66	LINE	CR NAGARA-HONNALLI	ATTIGULIPURA_66 ARKALVADI_66 HONNALLY_MYS_66	00:20	00:31	00:11	LINE CLEAR AVAILED
1888	12-Jul-24	MYSORE	66	TRANSFORMER	HV1	BEGUR_66	12:00	13:25	01:25	LINE CLEAR AVAILED
1889	12-Jul-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORNGUDU_66	12:31	13:55	01:23	LINE CLEAR AVAILED
1890	12-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1891	12-Jul-24	MYSORE	66	TRANSFORMER	HV2	BEGUR_66	13:20	14:25	01:05	LINE CLEAR AVAILED
1892	12-Jul-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	12:44	12:52	00:08	LINE CLEAR AVAILED
1893	12-Jul-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	12:54	14:30	01:35	LINE CLEAR AVAILED
1894	12-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
1895	12-Jul-24	MYSORE	66	LINE	KR PETE -AKKIHEBBAL-1	AKKIHEBBAL_66	09:02	17:27	08:25	LINE CLEAR AVAILED
1896	12-Jul-24	MYSORE	66	LINE	KR PETE -AKKIHEBBAL-2	AKKIHEBBAL_66	09:02	17:28	08:25	LINE CLEAR AVAILED
1897	12-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1898	12-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
1899	12-Jul-24	MYSORE	66	LINE	NAGAMANGALA-TUBINAKERE 1	NO STATIONS EFFECTED	11:52 (11/07/2024)	22:11 (12/07/2024)	34:18 HRs	LINE CLEAR AVAILED
1900	12-Jul-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_220	14:00	17:45	03:45	LINE CLEAR AVAILED
1901	12-Jul-24	MYSORE	220	TRANSFORMER	HV1	TUBINAKERE_220	11:56	17:24	05:28	LINE CLEAR AVAILED
1902	12-Jul-24	MYSORE	220	TRANSFORMER	HV2	TUBINAKERE_220	11:17	11:55	00:38	LINE CLEAR AVAILED
1903	12-Jul-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	09:27	15:16	05:49	LINE CLEAR AVAILED
1904	12-Jul-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV B G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIYUR	06:49	06:59	00:10	TRIPPED ON FAULT
1905	12-Jul-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI-66KV CHELUR LINE	66KV CHELUR,NANDHI HALI CROSS,HOSKERE,HAGALWADI	18:30	18:49	00:19	TRIPPED ON FAULT
1906	12-Jul-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI-66KV KORA LINE	66KV KORA	07:01	07:27	00:26	TRIPPED ON FAULT
1907	12-Jul-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV GOPPENAHALLI LINE	66KV GOPPENAHALLI,TAVAREKERE	14:10	14:15	00:05	TRIPPED ON FAULT
1908	12-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
1909	12-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA	07:01	07:18	00:17	TRIPPED ON FAULT
1910	12-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV MATHOD LINE 1	66KV MATHOD,KANCHIPURA, GARAGA,PANCHANAHALLI	05:45	05:58	00:13	TRIPPED ON FAULT
1911	12-Jul-24	TUMKUR	66	LINE	66KV BHARAMGIRI-66KV MATHOD LINE 2	BHARAMAGIRI_66	05:45	06:00	00:15	TRIPPED ON FAULT
1912	12-Jul-24	TUMKUR	66	LINE	66KV HOLALKERE-66KV PANDARAHALLI LINE 2	66KV CHIKKAJAJUR,SASALUHALLA	17:40	17:55	00:15	TRIPPED ON FAULT
1913	12-Jul-24	TUMKUR	66	LINE	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	11:38	11:57	00:19	LINE CLEAR AVAILED
1914	12-Jul-24	TUMKUR	66	LINE	NYAMATHI-HONNALLI-220	NYAMATHI_66	12:45	13:45	01:00	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1915	12-Jul-24	TUMKUR	66	LINE	PAVAGADA 220KV- MADHUGIRI 66	PAVAGADA_66	15:40	15:50	00:15	TRIPPED ON FAULT
1916	12-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-8MVA	CHITRAHALLI_66	15:00	15:15	00:06	TRIPPED ON FAULT
1917	12-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	KADAJI_66	06:52	07:01	00:09	TRIPPED ON FAULT
1918	12-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MADHUGIRI_66	16:50	17:10	00:20	TRIPPED ON FAULT
1919	12-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	THOVINAKERE_66	04:15	10:00	05:45	TRIPPED ON FAULT
1920	12-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS	GUTUR_400	10:23	13:15	02:52	LINE CLEAR AVAILED
1921	13-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD 220- NAGANUR	MUGALAKHOD_220	06:32	06:44	00:12	TRIPPED ON FAULT
1922	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	DAVALESHWAR_110	12:06	12:26	00:20	LINE CLEAR AVAILED
1923	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MALGHAN(B)_110	12:05	12:14	00:09	TRIPPED ON FAULT
1924	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MALGHAN(B)_110	13:47	13:50	00:03	TRIPPED ON FAULT
1925	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	MUNDARAGI_110	16:09	16:29	00:20	TRIPPED ON FAULT
1926	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	AMBEWADI_220	19:10	21:00	01:50	TRIPPED ON FAULT
1927	13-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	KULIGOD_110	15:00	15:37	00:37	LINE CLEAR AVAILED
1928	13-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	CHIKKODI_220	18:25	19:00	00:35	TRIPPED ON FAULT
1929	13-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV3	CHIKKODI_220	18:25	19:07	00:42	TRIPPED ON FAULT
1930	13-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	13:39	13:43	00:04	LINE CLEAR AVAILED
1931	13-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	13:43	13:48	00:05	TRIPPED ON FAULT
1932	13-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
1933	13-Jul-24	BAGALKOTE	110	LINE	BELGAUM 220-MACHE EXP LINE	BELGAUM_220	08:37	08:51	00:14	TRIPPED ON FAULT
1934	13-Jul-24	BAGALKOTE	110	LINE	BELGAUM 220-MACHE EXP LINE	BELGAUM_220	08:37	08:51	00:14	TRIPPED ON FAULT
1935	13-Jul-24	BAGALKOTE	110	LINE	BIJAPUR-KIADB BIJAPUR1	BIJAPUR_220	16:18	17:32	01:14	LINE CLEAR AVAILED
1936	13-Jul-24	BAGALKOTE	110	LINE	HIDIKAL DAM- ANKALGI	HIDIKAL DAM_110	00:55	06:07	05:12	LINE CLEAR AVAILED
1937	13-Jul-24	BAGALKOTE	110	LINE	KHADAKALAT- F1(CHIKKODI220)	KHADAKLAT_110	18:25 (13.07.2024)			TRIPPED ON FAULT
1938	13-Jul-24	BAGALKOTE	110	LINE	KHADAKALAT- F2(NIPPANI)	KHADAKLAT_110	18:27 (13.07.2024)			TRIPPED ON FAULT
1939	13-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1940	13-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1941	13-Jul-24	BAGALKOTE	110	LINE	SIRSI220-SIRSI1	SIRSI_220	16:04	16:21	00:17	TRIPPED ON FAULT
1942	13-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	16:04 (13.07.2024)			TRIPPED ON FAULT
1943	13-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1944	13-Jul-24	BAGALKOTE	110	LINE	SUVARNA SOUDA-MACHE	SUVARNA SOUDA_110	04:55	05:12	00:17	TRIPPED ON FAULT
1945	13-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI-KATARAKI	VAJRAMATTI_220	06:02	08:56	02:54	TRIPPED ON FAULT
1946	13-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
1947	13-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	CHIKKODI_220	18:25	18:57	00:32	TRIPPED ON FAULT
1948	13-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	CHIKKODI_220	18:25	19:08	00:43	TRIPPED ON FAULT
1949	13-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR--NARENDRA2	MAHALINGAPUR_220	06:00	06:16	00:16	TRIPPED ON FAULT
1950	13-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	09:19	09:35	00:16	TRIPPED ON FAULT
1951	13-Jul-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	T BEGUR	00:00	00:20	00:20	LINE CLEAR AVAILED
1952	13-Jul-24	BANGALORE	66	LINE	66KV DOMMASANDRA - WIPRO EHT	WIPRO EHT	00:00	11:57	11:57	LINE CLEAR AVAILED
1953	13-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	YELLARBANDE	14:00	14:30	00:30	LINE CLEAR AVAILED
1954	13-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	KYALANUR,VEMAGAL, TALGUNDA	10:05	10:07	00:02	LINE CLEAR AVAILED
1955	13-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TAMAKA - DRDO	DRDO, MALLASANDRA	11:10	11:17	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1956	13-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	KYALANUR,VEMAGAL, TALGUNDA	18:40	18:44	00:04	LINE CLEAR AVAILED
1957	13-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	07:22	07:33	00:11	TRIPPED ON FAULT
1958	13-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDDABELAVANGALA,GUNDAMGERRE ABD SASLU	14:25	14:32	00:07	LINE CLEAR AVAILED
1959	13-Jul-24	BANGALORE	66	LINE	66kV SRS Peenya 220 - Welcast Steel DG-3	WELCAST STEEL	14:08	14:10	00:02	LINE CLEAR AVAILED
1960	13-Jul-24	BANGALORE	66	LINE	66KV T D HALLI (MALLASANDRA) - DALASANUR	DRDO, MALLASANDRA	13:15	13:30	00:15	LINE CLEAR AVAILED
1961	13-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGALI AND BYRAKUR	15:16	16:05	00:49	LINE CLEAR AVAILED
1962	13-Jul-24	BANGALORE	66	TRANSFORMER	HV1	H.GOLLAHALLI	17:50	18:50	01:00	TRIPPED ON FAULT
1963	13-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HOSKOTE 66	16:30	17:15	00:45	LINE CLEAR AVAILED
1964	13-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KANAKAPURA 66	07:42	08:18	00:36	LINE CLEAR AVAILED
1965	13-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAXMI LAYOUT	12:30	12:35	00:05	LINE CLEAR AVAILED
1966	13-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANAKAPURA 66	00:15	00:23	00:08	LINE CLEAR AVAILED
1967	13-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAXMI LAYOUT	12:30	12:35	00:05	LINE CLEAR AVAILED
1968	13-Jul-24	BANGALORE	66	TRANSFORMER	HV2	T BEGUR	00:25	13:15	12:50	LINE CLEAR AVAILED
1969	13-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YELLARBANDE	02:40	03:15	00:35	LINE CLEAR AVAILED
1970	13-Jul-24	BANGALORE	220	LINE	220KV A STATION 220 - NRS 220	NO STATION AFFECTED	00:00	00:47	00:47	LINE CLEAR AVAILED
1971	13-Jul-24	GULBARGA	66	TRANSFORMER	HV3	NEELGUNDA_220	01:45	01:50	00:05	TRIPPED ON FAULT
1972	13-Jul-24	GULBARGA	110	LINE	BISILHALLI-HALAKUNDI	BISILHALLI_110	22:07	22:42	00:35	TRIPPED ON FAULT
1973	13-Jul-24	GULBARGA	110	TRANSFORMER	HV1	WALKAMDINI_110	15:30	15:40	00:10	TRIPPED ON FAULT
1974	13-Jul-24	GULBARGA	110	TRANSFORMER	HV2	GULBARGA UNIVERSITY_110	19:20	22:00	02:40	TRIPPED ON FAULT
1975	13-Jul-24	GULBARGA	110	LINE	RAMASAMUDRAYADGIR	RAMASAMUDRA_220	10:36	19:46	09:10	LINE CLEAR AVAILED
1976	13-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	16:11	16:23	00:12	TRIPPED ON FAULT
1977	13-Jul-24	GULBARGA	220	LINE	ALLIPUR-BTPS	ALLIPUR_220	22:06	23:59	01:53	TRIPPED ON FAULT
1978	13-Jul-24	GULBARGA	220	TRANSFORMER	HV1	MUNIRABAD_220	09:24	17:50	08:26	LINE CLEAR AVAILED
1979	13-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1980	13-Jul-24	GULBARGA	220	LINE	RAMASAMUDRA-RTPS-1	RAMASAMUDRA_220	11:23	13:53	02:30	LINE CLEAR AVAILED
1981	13-Jul-24	GULBARGA	220	LINE	RAMASAMUDRA-RTPS2	RAMASAMUDRA_220	00:00	13:53	13:53	LINE CLEAR AVAILED
1982	13-Jul-24	HASSAN	66	LINE	HASSN22-MALLALI	HASSAN_220	23:03 (12.7.2024)	8:11(13.07.2024)	9:07 hrs	LINE CLEAR AVAILED
1983	13-Jul-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	23:03 (12.7.2024)	8:11(13.07.2024)	9:07 hrs	LINE CLEAR AVAILED
1984	13-Jul-24	HASSAN	66	LINE	HNPR2-HASS2	HNPURA_220	06:52	07:08	00:16	TRIPPED ON FAULT
1985	13-Jul-24	HASSAN	66	LINE	HNPR2-HASS2	HNPURA_220	07:38	10:50	03:12	LINE CLEAR AVAILED
1986	13-Jul-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	06:13	06:23	00:10	TRIPPED ON FAULT
1987	13-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	06:50	07:05	00:15	MAIN SUPPLY FAILURE
1988	13-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	07:40	08:50	01:10	MAIN SUPPLY FAILURE
1989	13-Jul-24	HASSAN	66	TRANSFORMER	HV1	RAMESHWARNAGARA_66	07:40	08:15	00:35	MAIN SUPPLY FAILURE
1990	13-Jul-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	07:40	08:15	00:35	MAIN SUPPLY FAILURE
1991	13-Jul-24	HASSAN	66	LINE	KIADB H-RAMESWARNAGAR	KIADB_HASSAN_66	10:10	10:20	00:10	TRIPPED ON FAULT
1992	13-Jul-24	HASSAN	66	LINE	KIADB H-RAMESWARNAGAR	KIADB_HASSAN_66	10:45	12:35	01:50	LINE CLEAR AVAILED
1993	13-Jul-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	06:50	07:05	00:15	MAIN SUPPLY FAILURE
1994	13-Jul-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	07:40	08:50	01:10	MAIN SUPPLY FAILURE
1995	13-Jul-24	HASSAN	66	LINE	MALALI-HASSAN	MALALI_66	06:50	07:05	00:15	MAIN SUPPLY FAILURE
1996	13-Jul-24	HASSAN	66	LINE	MALALI-HASSAN	MALALI_66	07:40	08:50	01:10	MAIN SUPPLY FAILURE
1997	13-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	23:03 (12.7.2024)	00:15(13.04.2024)	1:11 hrs	MAIN SUPPLY FAILURE
1998	13-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	09:55	10:15	00:20	MAIN SUPPLY FAILURE
1999	13-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	06:52	07:07	00:15	MAIN SUPPLY FAILURE
2000	13-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:50	11:50	01:00	LINE CLEAR AVAILED
2001	13-Jul-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	12:25	12:35	00:10	LINE CLEAR AVAILED
2002	13-Jul-24	HASSAN	66	LINE	RMWNGR-SHANTI	RAMESHWARNAGARA_66	07:40	08:15	00:35	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2003	13-Jul-24	HASSAN	66	LINE	SHANTHI-MALALI	SHANTHIGRAMA_66	06:50	07:10	00:20	MAIN SUPPLY FAILURE
2004	13-Jul-24	HASSAN	66	LINE	SHANTHI-MALALI	SHANTHIGRAMA_66	07:40	08:25	00:45	MAIN SUPPLY FAILURE
2005	13-Jul-24	HASSAN	66	LINE	SHANTHI-MALALI	SHANTHIGRAMA_66	08:25	08:50	00:25	LINE CLEAR AVAILED
2006	13-Jul-24	HASSAN	66	LINE	SHANTHI-MALALI	SHANTHIGRAMA_66	10:00	10:20	00:20	MAIN SUPPLY FAILURE
2007	13-Jul-24	HASSAN	66	LINE	SHANTHI-MALALI	SHANTHIGRAMA_66	10:40	11:50	01:10	MAIN SUPPLY FAILURE
2008	13-Jul-24	HASSAN	110	TRANSFORMER	HV1	NANDIKUR_110	12:12	12:43	00:31	LINE CLEAR AVAILED
2009	13-Jul-24	HASSAN	110	TRANSFORMER	HV2	NANDIKUR_110	23:31(12.07.2024)	12:11(13.07.2024)	12:39 hrs	LINE CLEAR AVAILED
2010	13-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	03:31	03:55	00:24	TRIPPED ON FAULT
2011	13-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	10:00	19:00	09:00	LINE CLEAR AVAILED
2012	13-Jul-24	HASSAN	110	LINE	MRSSHM-TRKER	MRSMG_220	08:53	11:12	02:19	TRIPPED ON FAULT
2013	13-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMG_220	15:04	18:02	02:58	TRIPPED ON FAULT
2014	13-Jul-24	HASSAN	220	LINE	VARAH1-SHIMOGA1	gen_varahi	15:04	18:04	03:00	TRIPPED ON FAULT
2015	13-Jul-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	13:19	14:56	01:36	LINE CLEAR AVAILED
2016	13-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2017	13-Jul-24	MYSORE	66	TRANSFORMER	HV2	KIKKERI_66	13:19	14:52	01:33	LINE CLEAR AVAILED
2018	13-Jul-24	MYSORE	66	TRANSFORMER	HV2	KIKKERI_66	14:59	15:16	00:17	LINE CLEAR AVAILED
2019	13-Jul-24	MYSORE	66	LINE	KHB STATION-BILIKERE	DMG_HALLI_66	09:38	09:58	00:20	TRIPPED ON FAULT
2020	13-Jul-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	05:45	05:51	00:05	TRIPPED ON FAULT
2021	13-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2022	13-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	09:28	09:47	00:19	TRIPPED ON FAULT
2023	13-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2024	13-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2025	13-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	18:54	18:59	00:05	TRIPPED ON FAULT
2026	13-Jul-24	MYSORE	66	LINE	SANTHESARGUR-KALSON	NO STATIONS EFFECTED	14:47	15:54	01:07	LINE CLEAR AVAILED
2027	13-Jul-24	MYSORE	66	LINE	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:48	19:04	00:16	TRIPPED ON FAULT
2028	13-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2029	13-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV BEVINAHALLI LINE	66KV KRHHALLY, JG HALLY, DASUDI, BEVINAHALLI	20:17	20:30	00:13	TRIPPED ON FAULT
2030	13-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV MATHOD LINE 1	66KV HINDUSGHATTA	02:05	02:20	00:15	TRIPPED ON FAULT
2031	13-Jul-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA	66KV MYLANAHALLI, VV PURA, DYAVARANAHALLI	08:08	08:20	00:12	TRIPPED ON FAULT
2032	13-Jul-24	TUMKUR	66	LINE	66HIRIYUR-JAVAGONDANAHALLY	66KV BEVINAHALLI	19:00	19:20	00:20	TRIPPED ON FAULT
2033	13-Jul-24	TUMKUR	66	LINE	66HIRIYUR-JAVAGONDANAHALLY	66KV BEVINAHALLI	20:20	20:40	00:20	TRIPPED ON FAULT
2034	13-Jul-24	TUMKUR	66	LINE	BRAHMASANDRA_66-ANKASANDRA_66	66KV ANKASANDRA	08:45	09:00	00:15	TRIPPED ON FAULT
2035	13-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	18:21	19:00	00:39	LINE CLEAR AVAILED
2036	13-Jul-24	TUMKUR	66	LINE	NAYAKANAHATTI66-HIREMALLANHOLE	NAYAKANAHATTI_66	02:55	03:10	00:15	TRIPPED ON FAULT
2037	13-Jul-24	TUMKUR	66	LINE	NYAMATHI-HONNALLI-220	NYAMATHI_66	02:35	02:45	00:10	MAIN SUPPLY FAILURE
2038	13-Jul-24	TUMKUR	66	LINE	SHYLAPURA-MAGALAWADA_66	MAGALAWADA_66	19:35	19:40	00:05	TRIPPED ON FAULT
2039	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5MVA	HOSADURGA_66	08:25	08:35	00:10	TRIPPED ON FAULT
2040	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-20MVA	CHANNAGIRI_66	11:06	11:12	00:06	TRIPPED ON FAULT
2041	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-8MVA	NYAMATHI_66	09:50	09:55	00:05	TRIPPED ON FAULT
2042	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-12.5MVA	HALURAMESHWARA_66	08:25	08:35	00:10	TRIPPED ON FAULT
2043	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-12.5MVA	HALURAMESHWARA_66	10:15	10:25	00:10	TRIPPED ON FAULT
2044	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-12.5MVA	SHYLAPURA_66	19:35	19:40	00:05	TRIPPED ON FAULT
2045	13-Jul-24	TUMKUR	66	TRANSFORMER	TR-2-8MVA	HARIYABBE_66	17:25	17:45	00:20	LINE CLEAR AVAILED
2046	13-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV-PAVAGADA_220 1	MADHUGIRI_220	20:04	22:30	02:26	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2047	13-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV-PAVAGADA_220 2	MADHUGIRI_220	20:04	22:30	02:26	LINE CLEAR AVAILED
2048	13-Jul-24	TUMKUR	220	LINE	PAVAGADA 220KV- MADHUGIRI 1	PAVAGADA_220	14:10	19:35	00:15	TRIPPED ON FAULT
2049	13-Jul-24	TUMKUR	220	LINE	PAVAGADA 220KV- MADHUGIRI 2	PAVAGADA_220	19:35	22:35	00:15	LINE CLEAR AVAILED
2050	14-Jul-24	BAGALKOTE	110	LINE	ATHANI220-BALIGERI	ATHANI_220	06:10	06:17	00:07	TRIPPED ON FAULT
2051	14-Jul-24	BAGALKOTE	110	LINE	UCHGAON-UDYAMBAG	BELAGAVI_220	22:35	22:43	00:08	TRIPPED ON FAULT
2052	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	GAJENDRAGAD_110	22:11	23:45	01:34	TRIPPED ON FAULT
2053	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KULIGOD_110	7:10 (14.07.2024)			LINE CLEAR AVAILED
2054	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MAMADAPUR(G)_110	10:04	11:07	01:03	LINE CLEAR AVAILED
2055	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KUDACHI_110	11:20	11:32	00:12	TRIPPED ON FAULT
2056	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KUDACHI_110	11:59	12:13	00:14	TRIPPED ON FAULT
2057	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	LAXMESHVAR_110	16:23	16:54	00:31	TRIPPED ON FAULT
2058	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MAMADAPUR(B)_110	07:27	07:34	00:07	TRIPPED ON FAULT
2059	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIDDAPUR_110	14:30	14:59	00:29	TRIPPED ON FAULT
2060	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	UCHAGOAN_110	18:25 (14.7.2024)			TRIPPED ON FAULT
2061	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	ANKOLA_110	11:58	12:13	00:15	TRIPPED ON FAULT
2062	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	ANKOLA_110	12:14	12:23	00:09	TRIPPED ON FAULT
2063	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	ANKOLA_110	12:25	12:35	00:10	TRIPPED ON FAULT
2064	14-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GAJENDRAGAD_110	13:21	14:11	00:50	TRIPPED ON FAULT
2065	14-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2066	14-Jul-24	BAGALKOTE	110	LINE	BELGAUM220-HUKKERI	BELAGAVI_220	20:39	20:54	00:15	TRIPPED ON FAULT
2067	14-Jul-24	BAGALKOTE	110	LINE	HUNGUND- ILKAL1&2	HUNGUND_110	10:07	10:11	00:04	LINE CLEAR AVAILED
2068	14-Jul-24	BAGALKOTE	110	LINE	HUNGUND- ILKAL1&2	HUNGUND_110	15:47	16:44	00:57	LINE CLEAR AVAILED
2069	14-Jul-24	BAGALKOTE	110	LINE	KHADAKALAT- F1(CHIKKODI220)	KHADAKLAT_110	18:25 (13.07.2024)	3:22 (14.07.2024)	8:57:00	TRIPPED ON FAULT
2070	14-Jul-24	BAGALKOTE	110	LINE	KHADAKALAT- F2(NIPPANI)	KHADAKLAT_110	18:27 (13.07.2024)	3:26 (14.07.2024)	8:59:00	TRIPPED ON FAULT
2071	14-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2072	14-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD220-LN10(KULAGOD)	MUGALAKHOD_220	05:55	06:09	00:14	TRIPPED ON FAULT
2073	14-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	01:36	01:45	00:09	TRIPPED ON FAULT
2074	14-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	02:55	03:04	00:09	TRIPPED ON FAULT
2075	14-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	04:20	10:19	05:59	TRIPPED ON FAULT
2076	14-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2077	14-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	16:04 (13.07.2024)	11:01 (14.07.2024)	18:57:00	TRIPPED ON FAULT
2078	14-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2079	14-Jul-24	BAGALKOTE	220	LINE	HUBLI- NAGAJHARI -2	HUBLI_220	12:46	15:23	02:37	LINE CLEAR AVAILED
2080	14-Jul-24	BAGALKOTE	220	LINE	HUBLI-NAGAJHARI -1	HUBLI_220	05:19	15:21	10:02	TRIPPED ON FAULT
2081	14-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2082	14-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI_220	14:01	16:03	02:02	TRIPPED ON FAULT
2083	14-Jul-24	BANGALORE	66	LINE	220kV JIGANI 220 - JIGANI OLD STATION	JIGANI OLD STATION, JIGANI LINK ROAD	07:18	07:25	00:07	MAIN SUPPLY FAILURE
2084	14-Jul-24	BANGALORE	66	LINE	220kV JIGANI 220 - JIGANI OLD STATION	JIGANI OLD STATION, JIGANI LINK ROAD	13:06	13:14	00:08	MAIN SUPPLY FAILURE
2085	14-Jul-24	BANGALORE	66	LINE	66KV BOMMEPALLI - YENNIGADALE	YENIGADALE	13:00	13:06	00:06	LINE CLEAR AVAILED
2086	14-Jul-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	12:45	13:00	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2087	14-Jul-24	BANGALORE	66	LINE	66KV K RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI CROSS	13:10	14:50	01:40	LINE CLEAR AVAILED
2088	14-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	10:10	16:30	06:20	LINE CLEAR AVAILED
2089	14-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	KYALANUR,VEMAGAL, TALGUNDA	10:03	10:07	00:04	LINE CLEAR AVAILED
2090	14-Jul-24	BANGALORE	66	LINE	66KV KYALANUR - TALAGAWARA	KYALANUR,VEMAGAL, TALGUNDA	19:20	19:23	00:03	LINE CLEAR AVAILED
2091	14-Jul-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHAPURA ,CHELUR AND CHAKAVELU	18:13	18:23	00:10	TRIPPED ON FAULT
2092	14-Jul-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 220	13:04	13:14	00:10	LINE CLEAR AVAILED
2093	14-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KEMBODI	11:35	12:05	00:30	LINE CLEAR AVAILED
2094	14-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NANDAGUDI	09:07	09:40	00:33	TRIPPED ON FAULT
2095	14-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	10:15	10:25	00:10	TRIPPED ON FAULT
2096	14-Jul-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	14:25	14:38	00:13	TRIPPED ON FAULT
2097	14-Jul-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 220	07:53	08:09	00:16	LINE CLEAR AVAILED
2098	14-Jul-24	BANGALORE	66	TRANSFORMER	HV2	THIMMAMPALLI	08:15	08:17	00:02	LINE CLEAR AVAILED
2099	14-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YELDUR	19:55	20:20	00:25	TRIPPED ON FAULT
2100	14-Jul-24	BANGALORE	220	TRANSFORMER	HV1	JIGANI 220	13:04	13:11	00:07	LINE CLEAR AVAILED
2101	14-Jul-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	07:13	07:20	00:07	LINE CLEAR AVAILED
2102	14-Jul-24	GULBARGA	110	TRANSFORMER	HV1	HALAVARTHI_220	04:20	04:27	00:07	TRIPPED ON FAULT
2103	14-Jul-24	GULBARGA	110	TRANSFORMER	HV1	MAGLA_66	14:50	15:05	00:15	TRIPPED ON FAULT
2104	14-Jul-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	03:34	04:12	00:38	TRIPPED ON FAULT
2105	14-Jul-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	22:25	22:38	00:13	TRIPPED ON FAULT
2106	14-Jul-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	SONATHI_110	22:05	22:13	00:08	TRIPPED ON FAULT
2107	14-Jul-24	GULBARGA	110	LINE	KHANAPUR-WADAGERA	KHANAPUR_110	19:23	19:43	00:20	TRIPPED ON FAULT
2108	14-Jul-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	KEREHALLI_110	05:39	06:01	00:22	TRIPPED ON FAULT
2109	14-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	20:55	21:00	00:05	TRIPPED ON FAULT
2110	14-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	20:55	21:00	00:05	TRIPPED ON FAULT
2111	14-Jul-24	GULBARGA	110	LINE	SIRAGUPPA-TEKKALKOTE	TEKKALKOTE_110	05:41	06:26	00:45	TRIPPED ON FAULT
2112	14-Jul-24	GULBARGA	110	LINE	WADI-SHAHABAD	WADI_110	13:00	13:05	00:05	TRIPPED ON FAULT
2113	14-Jul-24	GULBARGA	220	LINE	ALLIPUR-BTPS	ALLIPUR_220	00:00	04:25	04:25	LINE CLEAR AVAILED
2114	14-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2115	14-Jul-24	HASSAN	66	TRANSFORMER	HV2	BELUR_66	13:14	13:25	00:11	TRIPPED ON FAULT
2116	14-Jul-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	21:15	21:26	00:11	TRIPPED ON FAULT
2117	14-Jul-24	HASSAN	110	LINE	GURUVA-SLPWR	GURUVAYANKERE_110	04:54	06:46	01:52	LINE CLEAR AVAILED
2118	14-Jul-24	HASSAN	110	TRANSFORMER	HV2	KADUR_220	11:19	11:31	00:12	TRIPPED ON FAULT
2119	14-Jul-24	HASSAN	110	TRANSFORMER	HV2	MOODABIDRE_110	11:11	11:17	00:06	TRIPPED ON FAULT
2120	14-Jul-24	MYSORE	66	TRANSFORMER	HV1	BYLUKUPPE_66	13:45	13:50	00:05	TRIPPED ON FAULT
2121	14-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2122	14-Jul-24	MYSORE	66	TRANSFORMER	HV2	HANGLA_66	12:08	12:15	00:06	TRIPPED ON FAULT
2123	14-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2124	14-Jul-24	MYSORE	66	LINE	KR PETE-AKKIHEBBAL-1	AKKIHEBBAL_66	09:04	17:18	08:14	LINE CLEAR AVAILED
2125	14-Jul-24	MYSORE	66	LINE	KR PETE-AKKIHEBBAL-2	AKKIHEBBAL_66	09:04	17:18	08:14	LINE CLEAR AVAILED
2126	14-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2127	14-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2128	14-Jul-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	VIRAJPET_66	20:28	20:39	00:11	TRIPPED ON FAULT
2129	14-Jul-24	MYSORE	66	LINE	MADIKERI-VIRAJPETE	VIRAJPET_66	21:03	21:10	00:07	TRIPPED ON FAULT
2130	14-Jul-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	19:06	19:11	00:05	TRIPPED ON FAULT
2131	14-Jul-24	MYSORE	66	LINE	PERIYAPATNA-PONNAMPETE	PONNAMPET_66 SRIMANGALA_66	19:57	20:03	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2132	14-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	19:47	19:58	00:10	TRIPPED ON FAULT
2133	14-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	20:03 (14/07/2024)			TRIPPED ON FAULT
2134	14-Jul-24	MYSORE	66	LINE	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	14:45	14:56	00:11	TRIPPED ON FAULT
2135	14-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2136	14-Jul-24	TUMKUR	66	LINE	220KV MADHUGIRI-66KV KORATAGERE LINE 2	66KV KORATAGERE	08:27	08:40	00:13	TRIPPED ON FAULT
2137	14-Jul-24	TUMKUR	66	LINE	66KV BEVINAHALLI -220KV HIRIYUR LINE	66KV KRHHALLY, JG HALLY, DASUDI, BEVINAHALLI	15:02	15:47	00:45	MAIN SUPPLY FAILURE
2138	14-Jul-24	TUMKUR	66	LINE	66KV HANGAL-66KV THALLAK LINE 1	66KV HANGAL,NAGASAMUDRA,RAMPUR A	05:50	06:06	00:16	TRIPPED ON FAULT
2139	14-Jul-24	TUMKUR	66	LINE	66KV HANGAL-66KV THALLAK LINE 2	66KV HANGAL,NAGASAMUDRA,RAMPUR A	05:50	06:06	00:16	TRIPPED ON FAULT
2140	14-Jul-24	TUMKUR	66	LINE	66KV MATHOD -66KV KANCHIPURA LINE	66KV KANCHIPURA	06:20	06:30	00:10	TRIPPED ON FAULT
2141	14-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66	13:18 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2142	14-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2143	14-Jul-24	TUMKUR	66	LINE	THALLAK 220KV - BGKERE 2	66KV HANGAL,NAGASAMUDRA,RAMPUR A	05:50	06:10	00:10	TRIPPED ON FAULT
2144	14-Jul-24	TUMKUR	66	TRANSFORMER	TR-1-12.5MVA	SHYLAPURA_66	13:05	13:10	00:05	TRIPPED ON FAULT
2145	14-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	KADAJI_66	07:45	07:50	00:05	TRIPPED ON FAULT
2146	14-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MADHUGIRI_66	18:15	21:25	03:10	TRIPPED ON FAULT
2147	14-Jul-24	TUMKUR	66	TRANSFORMER	TR-3-8MVA	HARIYABBE_66	12:30	12:35	00:05	TRIPPED ON FAULT
2148	14-Jul-24	TUMKUR	66	TRANSFORMER	TR-3-8MVA	HARIYABBE_66	13:35	13:40	00:05	TRIPPED ON FAULT
2149	14-Jul-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	BENKIKERE_220	16:14 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2150	15-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	02:52	03:05	00:13	TRIPPED ON FAULT
2151	15-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	06:00	06:10	00:10	TRIPPED ON FAULT
2152	15-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	20:08 (15.07.2024)			LINE CLEAR AVAILED
2153	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	ANANDANAGAR_110	13:29	13:38	00:09	LINE CLEAR AVAILED
2154	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	DAVALESHWAR_110	10:10	15:20	05:10	LINE CLEAR AVAILED
2155	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	ANANDANAGAR_110	13:18	13:28	00:10	LINE CLEAR AVAILED
2156	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	DAVALESHWAR_110	10:10	17:07	06:57	LINE CLEAR AVAILED
2157	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KADANKOPPA_110	11:08	14:06	02:58	LINE CLEAR AVAILED
2158	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KADANKOPPA_110	15:47	15:57	00:10	LINE CLEAR AVAILED
2159	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KULIGOD_110	7:10 (14.07.2024)			LINE CLEAR AVAILED
2160	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MAMADAPUR(B)_110	11:11	11:32	00:21	LINE CLEAR AVAILED
2161	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KUDUCHI_220	12:55	16:15	03:20	LINE CLEAR AVAILED
2162	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	UMMACHAGI_110	04:05	04:10	00:05	TRIPPED ON FAULT
2163	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KHADAKLAT_110	12:05	12:30	00:25	LINE CLEAR AVAILED
2164	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	BHOJ_110	11:15	15:45	04:30	LINE CLEAR AVAILED
2165	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	RAIBAG_110	17:30	17:43	00:13	LINE CLEAR AVAILED
2166	15-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	UCHAGOAN_110	18:25 (14.7.2024)	13:57 (15.07.2024)	19:32:00	TRIPPED ON FAULT
2167	15-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV3	INDI_220	13:47	14:50	01:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2168	15-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2169	15-Jul-24	BAGALKOTE	110	LINE	ANKALAGI- BELGAUM220 (HUDLI)	ANKALAGI_110	06:38	06:54	00:16	LINE CLEAR AVAILED
2170	15-Jul-24	BAGALKOTE	110	LINE	DAVALESHWAR- SAIDAPUR	DAVALESHWAR_110	10:54	16:15	05:21	LINE CLEAR AVAILED
2171	15-Jul-24	BAGALKOTE	110	LINE	HAVERI-BASAVANAKATTI	HAVERI_220	12:15 (15.07.2024)			LINE CLEAR AVAILED
2172	15-Jul-24	BAGALKOTE	110	LINE	HONNAVAR- MURDESHWAR	HONNAVAR_110	01:07	01:26	00:19	TRIPPED ON FAULT
2173	15-Jul-24	BAGALKOTE	110	LINE	HUNGUND- JINDAL	HUNGUND_110	07:35	08:16	00:41	TRIPPED ON FAULT
2174	15-Jul-24	BAGALKOTE	110	LINE	INDI-ZALKI1	INDI_220	13:25	13:38	00:13	LINE CLEAR AVAILED
2175	15-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	00:14	00:42	00:28	TRIPPED ON FAULT
2176	15-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	05:16	05:28	00:12	TRIPPED ON FAULT
2177	15-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	06:11	15:07	08:56	TRIPPED ON FAULT
2178	15-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	21:45 (15.07.2024)			TRIPPED ON FAULT
2179	15-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	04:51	05:07	00:16	TRIPPED ON FAULT
2180	15-Jul-24	BAGALKOTE	110	LINE	KUDUCHI22-SHIRAGUPPI	KUDUCHI_220	04:50	05:05	00:15	TRIPPED ON FAULT
2181	15-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2182	15-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR- HONNAVAR (RAILWAY LINE)	MURDESHWAR_110	01:10	01:26	00:16	LINE CLEAR AVAILED
2183	15-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2184	15-Jul-24	BAGALKOTE	110	LINE	SOUNDATTI- SOUNDATTI 1	SOUNDATTI_220	17:16	17:23	00:07	LINE CLEAR AVAILED
2185	15-Jul-24	BAGALKOTE	110	LINE	SOUNDATTI- SOUNDATTI 2	SOUNDATTI_220	17:16	17:23	00:07	LINE CLEAR AVAILED
2186	15-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2187	15-Jul-24	BAGALKOTE	110	LINE	YADWAD-IZARA	YADWAD_110	18:00	18:02	00:02	LINE CLEAR AVAILED
2188	15-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2189	15-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3	INDI_220	13:47	14:50	01:03	LINE CLEAR AVAILED
2190	15-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NAGZHARI-2	AMBEWADI_220	23:31 (15.07.2024)			TRIPPED ON FAULT
2191	15-Jul-24	BAGALKOTE	220	LINE	VAJRAMATTI-BAGALKOT1	VAJRAMATTI_220	11:37	19:19	07:42	LINE CLEAR AVAILED
2192	15-Jul-24	BANGALORE	66	LINE	66KV ACHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALGURU	02:22	02:27	00:05	TRIPPED ON FAULT
2193	15-Jul-24	BANGALORE	66	LINE	66KV ACHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALGURU	12:08	12:18	00:10	TRIPPED ON FAULT
2194	15-Jul-24	BANGALORE	66	LINE	66KV BOMMEPALLI - YENNIGADALE	YENIGADALE	11:21	11:22	00:01	LINE CLEAR AVAILED
2195	15-Jul-24	BANGALORE	66	LINE	66KV K RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI CROSS	11:21	11:22	00:01	LINE CLEAR AVAILED
2196	15-Jul-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP)	KC VALLEY	19:03	19:38	00:35	TRIPPED ON FAULT
2197	15-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - KUMBALAGODU 220	NO STATION AFFECTED	11:35	23:59	12:24	LINE CLEAR AVAILED
2198	15-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SANJEEVANADODDI	NO STATION AFFECTED	12:00	16:30	04:30	LINE CLEAR AVAILED
2199	15-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRKUR	15:40	17:07	01:27	LINE CLEAR AVAILED
2200	15-Jul-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	RAILWAY TRACTION DODDABELE (EHT)	15:30	23:59	08:29	LINE CLEAR AVAILED
2201	15-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	KUMARANAHALI, BAGGANADODDI	06:33	06:43	00:10	LINE CLEAR AVAILED
2202	15-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HONNIGANAHALLI	02:22	02:27	00:05	TRIPPED ON FAULT
2203	15-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HONNIGANAHALLI	12:08	15:40	03:32	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2204	15-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAXMI LAYOUT	06:12	06:17	00:05	LINE CLEAR AVAILED
2205	15-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	10:30	10:45	00:15	LINE CLEAR AVAILED
2206	15-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HONNIGANAHALLI	01:20	02:27	01:07	TRIPPED ON FAULT
2207	15-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAXMI LAYOUT	06:12	06:17	00:05	LINE CLEAR AVAILED
2208	15-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TK HALLI 220	16:57	17:02	00:05	TRIPPED ON FAULT
2209	15-Jul-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	11:20	17:27	06:07	LINE CLEAR AVAILED
2210	15-Jul-24	BANGALORE	220	TRANSFORMER	HV2	KIADB DB PURA 220	21:24	22:15	00:51	TRIPPED ON FAULT
2211	15-Jul-24	BANGALORE	220	TRANSFORMER	HV2	KIADB DB PURA 220	22:41	23:59	01:18	TRIPPED ON FAULT
2212	15-Jul-24	BANGALORE	220	TRANSFORMER	HV2	NRS 220	10:30	11:14	00:44	TRIPPED ON FAULT
2213	15-Jul-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-MALLAT	ADAVIAMARESHWAR_110	21:36	21:55	00:19	LINE CLEAR AVAILED
2214	15-Jul-24	GULBARGA	110	LINE	ALKOD-MALLAT	ALKOD_110,GALAG_110	21:39	21:52	00:13	TRIPPED ON FAULT
2215	15-Jul-24	GULBARGA	110	LINE	ALKOD-MALLAT	ALKOD_110,GALAG_110	22:50	23:10	00:20	TRIPPED ON FAULT
2216	15-Jul-24	GULBARGA	110	LINE	BYGWAT-MALLAT	BYGWAT_110	20:18	20:24	00:06	MAIN SUPPLY FAILURE
2217	15-Jul-24	GULBARGA	110	LINE	BYGWAT-MALLAT	BYGWAT_110	21:36	21:41	00:05	MAIN SUPPLY FAILURE
2218	15-Jul-24	GULBARGA	110	LINE	HANAWALA-MARALIHALLA	YARADONA_110,BENNUR_110	01:45	01:55	00:10	TRIPPED ON FAULT
2219	15-Jul-24	GULBARGA	110	LINE	HANAWALA-MARALIHALLA	YARADONA_110,BENNUR_110	01:45	01:50	00:05	TRIPPED ON FAULT
2220	15-Jul-24	GULBARGA	110	TRANSFORMER	HV2	KURDICROSS_110	07:30	07:40	00:10	TRIPPED ON FAULT
2221	15-Jul-24	GULBARGA	110	TRANSFORMER	HV2	VADAVATTI_110	17:50	18:15	00:25	TRIPPED ON FAULT
2222	15-Jul-24	GULBARGA	110	TRANSFORMER	HV2	VADAVATTI_110	20:00	20:05	00:05	TRIPPED ON FAULT
2223	15-Jul-24	GULBARGA	110	TRANSFORMER	HV2	VALKAMDINI_110	03:25	03:30	00:05	TRIPPED ON FAULT
2224	15-Jul-24	GULBARGA	110	TRANSFORMER	HV4	ALLIPUR_220	00:38	00:48	00:10	TRIPPED ON FAULT
2225	15-Jul-24	GULBARGA	110	LINE	ITTIGI-HIREHADAGALI-1	HIREHADAGALI_66	19:03	19:12	00:09	TRIPPED ON FAULT
2226	15-Jul-24	GULBARGA	110	LINE	ITTIGI-HIREHADAGALI-2	SOVENHALLI_66	04:48	05:00	00:12	TRIPPED ON FAULT
2227	15-Jul-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	19:15	19:30	00:15	MAIN SUPPLY FAILURE
2228	15-Jul-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	19:15	19:30	00:15	TRIPPED ON FAULT
2229	15-Jul-24	GULBARGA	110	LINE	LINGASUGUR-KPRL_IPP	LINGASUGUR_220	08:32	13:15	04:43	LINE CLEAR AVAILED
2230	15-Jul-24	GULBARGA	110	LINE	LV2	ALLIPUR_220	12:48	13:52	01:04	LINE CLEAR AVAILED
2231	15-Jul-24	GULBARGA	110	LINE	MALLAPURA-KAMPLI	KAMPLI_110	09:20	09:30	00:10	LINE CLEAR AVAILED
2232	15-Jul-24	GULBARGA	110	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66	00:14	00:30	00:16	TRIPPED ON FAULT
2233	15-Jul-24	GULBARGA	110	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66	01:35	01:43	00:08	TRIPPED ON FAULT
2234	15-Jul-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	20:13	20:26	00:13	TRIPPED ON FAULT
2235	15-Jul-24	GULBARGA	110	LINE	SHAHAPUR-KHANAPUR1	KHANAPUR_110	12:18	18:12	05:54	LINE CLEAR AVAILED
2236	15-Jul-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	SHAHAPUR_110	12:35	18:07	05:32	LINE CLEAR AVAILED
2237	15-Jul-24	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	12:18	18:12	05:54	LINE CLEAR AVAILED
2238	15-Jul-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	12:18	18:15	05:57	LINE CLEAR AVAILED
2239	15-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SR.NAGAR	KARATAGI_110	19:30	19:40	00:10	TRIPPED ON FAULT
2240	15-Jul-24	GULBARGA	110	LINE	SIRAGUPPA-TEKKALKOTE	TEKKALKOTE_110	10:15	10:40	00:25	MAIN SUPPLY FAILURE
2241	15-Jul-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGERICROSS	TEKKALKOTE_110	15:20	16:02	00:42	MAIN SUPPLY FAILURE
2242	15-Jul-24	GULBARGA	110	LINE	VAJRABANDI-KUSHTAGI	VAJRABANDI_110	14:35	14:57	00:22	TRIPPED ON FAULT
2243	15-Jul-24	GULBARGA	220	TRANSFORMER	HV2	ALLIPUR_220	13:45	13:52	00:07	LINE CLEAR AVAILED
2244	15-Jul-24	GULBARGA	220	TRANSFORMER	HV2	ALLIPUR_220	13:53	14:21	00:28	LINE CLEAR AVAILED
2245	15-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	02:04	02:24	00:20	TRIPPED ON FAULT
2246	15-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	02:46	03:21	00:35	TRIPPED ON FAULT
2247	15-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	03:21	11:40	08:19	LINE CLEAR AVAILED
2248	15-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	01:10	01:29	00:19	TRIPPED ON FAULT
2249	15-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2250	15-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	00:24	08:03	07:39	TRIPPED ON FAULT
2251	15-Jul-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONUR_66	20:48(15.07.2024)			TRIPPED ON FAULT
2252	15-Jul-24	HASSAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	05:20	05:30	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2253	15-Jul-24	HASSAN	66	LINE	BELUR66-HASSAN	BELUR_66	20:28	20:50	00:22	TRIPPED ON FAULT
2254	15-Jul-24	HASSAN	66	LINE	BELUR66-HASSAN	BELUR_66	21:02	21:11	00:09	TRIPPED ON FAULT
2255	15-Jul-24	HASSAN	66	LINE	BELUR66-HASSAN	BELUR_66	21:35	22:00	00:25	MAIN SUPPLY FAILURE
2256	15-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	20:50	20:55	00:05	LINE CLEAR AVAILED
2257	15-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	21:05	21:12	00:07	MAIN SUPPLY FAILURE
2258	15-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	21:19	21:31	00:12	MAIN SUPPLY FAILURE
2259	15-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	21:33	22:07	00:34	LINE CLEAR AVAILED
2260	15-Jul-24	HASSAN	66	LINE	GENDEHA-HASSAN	GENDEHALLI_66	21:15(15.07.2024)			MAIN SUPPLY FAILURE
2261	15-Jul-24	HASSAN	66	LINE	GENDEHA-HASSAN	GENDEHALLI_66	20:25	21:15	00:50	TRIPPED ON FAULT
2262	15-Jul-24	HASSAN	66	TRANSFORMER	HV1	HALEBEEDU_66	13:23	14:19	00:56	LINE CLEAR AVAILED
2263	15-Jul-24	HASSAN	66	TRANSFORMER	HV2	CHIKKABOMMENAHALLI_66	06:50	07:12	00:22	TRIPPED ON FAULT
2264	15-Jul-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	23:17	23:36	00:19	TRIPPED ON FAULT
2265	15-Jul-24	HASSAN	66	LINE	MALALI-SHANTHIGRAMA	MALALI_66	12:35	12:55	00:20	TRIPPED ON FAULT
2266	15-Jul-24	HASSAN	110	TRANSFORMER	HV1	GERUMARA_110	14:35	15:10	00:35	LINE CLEAR AVAILED
2267	15-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	10:20	10:42	00:22	LINE CLEAR AVAILED
2268	15-Jul-24	HASSAN	110	TRANSFORMER	HV1	NANDIKUR_110	10:02	10:31	00:29	LINE CLEAR AVAILED
2269	15-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	05:33	12:41	07:08	LINE CLEAR AVAILED
2270	15-Jul-24	HASSAN	110	TRANSFORMER	HV2	BEJAI_110	11:30	11:40	00:10	TRIPPED ON FAULT
2271	15-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	16:55	18:18	01:23	LINE CLEAR AVAILED
2272	15-Jul-24	HASSAN	110	TRANSFORMER	HV4	BEJAI_110	11:30	11:46	00:16	TRIPPED ON FAULT
2273	15-Jul-24	HASSAN	110	LINE	KADUR-AJAMPURA	KADUR_220	13:44	14:32	00:48	LINE CLEAR AVAILED
2274	15-Jul-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	23:22	23:35	00:13	TRIPPED ON FAULT
2275	15-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMG_220	23:30(15.7.2024)			TRIPPED ON FAULT
2276	15-Jul-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	23:00	23:22	00:22	TRIPPED ON FAULT
2277	15-Jul-24	MYSORE	66	LINE	BETTADAPURA-KITTUR-CHUNCHUNKATTE	KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66	05:56	06:05	00:09	TRIPPED ON FAULT
2278	15-Jul-24	MYSORE	66	LINE	COWDALLI-RAMAPURA	RAMAPURA_66 MARTHALLI_66	06:00	06:05	00:05	TRIPPED ON FAULT
2279	15-Jul-24	MYSORE	66	LINE	HARADANHALLI (JAK)-LAXJEET	NO STATIONS EFFECTED	06:25	06:30	00:05	TRIPPED ON FAULT
2280	15-Jul-24	MYSORE	66	LINE	HEBBANI-SFC1	NO STATIONS EFFECTED	10:05	13:17	03:12	LINE CLEAR AVAILED
2281	15-Jul-24	MYSORE	66	LINE	HEBBANI-SFC2	NO STATIONS EFFECTED	10:05	13:17	03:12	LINE CLEAR AVAILED
2282	15-Jul-24	MYSORE	66	LINE	HEBBANI-SIMSHA	NO STATIONS EFFECTED	11:20	11:20	00:00	LINE CLEAR AVAILED
2283	15-Jul-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	03:38	03:52	00:14	TRIPPED ON FAULT
2284	15-Jul-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	03:52	13:15	09:23	TRIPPED ON FAULT
2285	15-Jul-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR 1	NO STATIONS EFFECTED	06:23	07:06	00:43	TRIPPED ON FAULT
2286	15-Jul-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR 2	NO STATIONS EFFECTED	06:33	07:06	00:33	TRIPPED ON FAULT
2287	15-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGURU_66	02:20	02:30	00:10	MAIN SUPPLY FAILURE
2288	15-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGURU_66	12:05	12:20	00:15	MAIN SUPPLY FAILURE
2289	15-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2290	15-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	11:25	19:02	07:37	LINE CLEAR AVAILED
2291	15-Jul-24	MYSORE	66	TRANSFORMER	HV3	POONAMPETE_66	18:50	19:45	00:54	LINE CLEAR AVAILED
2292	15-Jul-24	MYSORE	66	LINE	KOLLEGALA-PARINAMIPURA	NO STATIONS EFFECTED	07:24	07:48	00:24	TRIPPED ON FAULT
2293	15-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2294	15-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2295	15-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2296	15-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	15:28	15:38	00:09	TRIPPED ON FAULT
2297	15-Jul-24	MYSORE	66	LINE	MALLAVALLI-SIMSHA	NO STATIONS EFFECTED	10:21	11:03	00:42	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2298	15-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	20:03 (14/07/2024)	15:07:06 (15/7/2024)	19:04:06	TRIPPED ON FAULT
2299	15-Jul-24	MYSORE	66	LINE	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	03:39	06:13	02:33	TRIPPED ON FAULT
2300	15-Jul-24	MYSORE	66	LINE	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	03:39	06:10	02:30	TRIPPED ON FAULT
2301	15-Jul-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	03:39	03:44	00:05	TRIPPED ON FAULT
2302	15-Jul-24	TUMKUR	66	TRANSFORMER	100MVA TRANSFORMER 2 LV SIDE-220KV BENKIKERE	66KV BENKIKERE, MALLADIHALLI,DEVARAHALLI, SANTHEBENNUR,KEREBILACHI, NALLUR, LINGADAHALLI,CHANNAGIRI,GOPPENAHALLI, TAVAREKERE	02:12	02:41	00:29	TRIPPED ON FAULT
2303	15-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV HIREGUNTNR	13:07	13:28	00:21	TRIPPED ON FAULT
2304	15-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2305	15-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV HARIHAR HOSPET LINE	66KV HARIHARA NEW	08:45	08:56	00:11	TRIPPED ON FAULT
2306	15-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	15:11	15:23	00:12	TRIPPED ON FAULT
2307	15-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 1	66KV PANDARAHALLI,HOLALKERE,CHIKKAJJUR, SASALUHALLA	13:11	13:20	00:09	TRIPPED ON FAULT
2308	15-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-CHANNAGIRI	LINGADAHALLI_66, CHANNAGIRI_66	15:36	16:15	00:39	LINE CLEAR AVAILED
2309	15-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	15:36	16:15	00:39	LINE CLEAR AVAILED
2310	15-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	15:36	16:25	00:49	LINE CLEAR AVAILED
2311	15-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-MALLADIHALLI	MALLADIHALLI_66	15:36	16:20	00:44	LINE CLEAR AVAILED
2312	15-Jul-24	TUMKUR	66	LINE	BENKIKERE 220KV-NALLUR	NALLUR_66	15:36	16:20	00:44	LINE CLEAR AVAILED
2313	15-Jul-24	TUMKUR	66	LINE	BENKIKERE-220KV-BENKIKERE_66	BENKIKERE_66	15:36	16:21	00:45	LINE CLEAR AVAILED
2314	15-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66	13:18 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2315	15-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2316	15-Jul-24	TUMKUR	66	LINE	KEREBILACHI66-SANTEBENNUR66	KEREBILACHI_66	10:40	17:00	06:20	LINE CLEAR AVAILED
2317	15-Jul-24	TUMKUR	66	LINE	SHYLAPURA_66-PAVAGADA R/S 220KV	SHYLAPURA_66	17:15	18:00	00:45	MAIN SUPPLY FAILURE
2318	15-Jul-24	TUMKUR	66	LINE	TMTP_66-KIADB VN .PURA_220KV	TMTP_66	15:05	16:05	01:00	MAIN SUPPLY FAILURE
2319	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	CHITRAHALLI_66	02:40	02:45	00:05	TRIPPED ON FAULT
2320	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	KADAJI_66	14:00	14:05	00:05	TRIPPED ON FAULT
2321	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	MADHUGIRI_66	09:00	09:05	00:05	TRIPPED ON FAULT
2322	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	HOSADURGA_66	09:20	09:25	00:05	TRIPPED ON FAULT
2323	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	HOSADURGA_66	10:00	10:05	00:05	TRIPPED ON FAULT
2324	15-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	KADAJI_66	06:55	07:00	00:05	TRIPPED ON FAULT
2325	15-Jul-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	BENKIKERE_220	16:14 (14.07.2024)	16:14 (15.07.2024)	00:00	LINE CLEAR AVAILED
2326	15-Jul-24	TUMKUR	220	TRANSFORMER	TR-2(HV SIDE)	BENKIKERE_220	15:35 (15.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2327	16-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	20:08 (15.07.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2328	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADANAKOPPA_110	12:10	12:11	00:01	LINE CLEAR AVAILED
2329	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	DAVALESHWAR_110	16:35	16:52	00:17	LINE CLEAR AVAILED
2330	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KADANAKOPPA_110	12:05	12:08	00:03	LINE CLEAR AVAILED
2331	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KULIGOD_110	7:10 (14.07.2024)	18:09 (16.07.2024)	58:59:00	LINE CLEAR AVAILED
2332	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (10MVA)	GAJENDRAGAD_110	10:37	11:44	01:07	LINE CLEAR AVAILED
2333	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULIGERE CROSS_110	09:19	14:11	04:52	LINE CLEAR AVAILED
2334	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KULIGOD_110	09:23	11:53	02:30	LINE CLEAR AVAILED
2335	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULIGERE CROSS_110	14:05	15:02	00:57	LINE CLEAR AVAILED
2336	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	13:41	14:19	00:38	LINE CLEAR AVAILED
2337	16-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	CHIKKODI_110	13:06	13:15	00:09	TRIPPED ON FAULT
2338	16-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2339	16-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA2	ANKOLA_110	10:29	11:47	01:18	LINE CLEAR AVAILED
2340	16-Jul-24	BAGALKOTE	110	LINE	BABALESHWAR-VSE IPP	VSE IPP_110 STATION NOT AFFECTED BABALESHWAR_110	19:48 (16.07.2024)			LINE CLEAR AVAILED
2341	16-Jul-24	BAGALKOTE	110	LINE	HAVERI-BASAVANAKATTI	HAVERI_220	12:15 (15.07.2024)	19:40 (16.07.2024)	31:25:00	LINE CLEAR AVAILED
2342	16-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA(KUMTA)	KARWAR_220	21:45 (15.07.2024)	5:08 (16.07.2024)	7:23:00	TRIPPED ON FAULT
2343	16-Jul-24	BAGALKOTE	110	LINE	KUDDHARWAD-NARENDRA	KUDDHARWAD_110	10:55	15:50	04:55	LINE CLEAR AVAILED
2344	16-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2345	16-Jul-24	BAGALKOTE	110	LINE	MUGALKHOD220- HALLUR	MUGALKHOD_220	08:25	08:38	00:13	TRIPPED ON FAULT
2346	16-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2347	16-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA1	SIRSI_110	05:00	17:15	12:15	TRIPPED ON FAULT
2348	16-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	04:42	17:17	12:35	TRIPPED ON FAULT
2349	16-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2350	16-Jul-24	BAGALKOTE	110	LINE	TODALBAGI-JAMAKHANDI SUGARS	TODALBAGI_110	20:22	20:29	00:07	TRIPPED ON FAULT
2351	16-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2352	16-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	AMBEWADI_220	06:10	12:43	06:33	LINE CLEAR AVAILED
2353	16-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-NAGZHARI-2	AMBEWADI_220	23:31 (15.07.2024)	12:40 (16.07.2024)	13:09:00	TRIPPED ON FAULT
2354	16-Jul-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	AGALAKOTE	16:38	16:42	00:04	LINE CLEAR AVAILED
2355	16-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	DODDALAHALLI, SHIVANAHALLI DAIRY	10:44	16:33	05:49	LINE CLEAR AVAILED
2356	16-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	DODDALAHALLI, SHIVANAHALLI DAIRY	21:06	21:13	00:07	TRIPPED ON FAULT
2357	16-Jul-24	BANGALORE	66	LINE	66KV KEMPANAHALLI - AGALAKOTE	AGALAKOTE	12:44	12:47	00:03	LINE CLEAR AVAILED
2358	16-Jul-24	BANGALORE	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	12:27	13:01	00:34	LINE CLEAR AVAILED
2359	16-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	09:40	09:45	00:05	LINE CLEAR AVAILED
2360	16-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SAINT GOBIN - BHURUKA GAS - ORCHID LAMINTES 1 - AO SMITH - ORCHID LAMINATES-2	BHORUKA(EHT), SAINT GOBAIN, AO SMITH, ORCHID LAMINATE	11:06	11:32	00:26	TRIPPED ON FAULT
2361	16-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	12:12	12:41	00:29	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2362	16-Jul-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	RAILWAY TRACTION DODDABELE (EHT)	00:00	23:59	23:59	LINE CLEAR AVAILED
2363	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BUDIKOTE	13:30	13:55	00:25	LINE CLEAR AVAILED
2364	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HAROBEL	13:40	16:05	02:25	LINE CLEAR AVAILED
2365	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KAMBIPURA	16:05	16:07	00:02	LINE CLEAR AVAILED
2366	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MANDIKAL	09:45	10:00	00:15	LINE CLEAR AVAILED
2367	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SOMANATHPURA	10:25	10:35	00:10	TRIPPED ON FAULT
2368	16-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	08:20	08:24	00:04	TRIPPED ON FAULT
2369	16-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ADDAGAL	13:35	14:15	00:40	TRIPPED ON FAULT
2370	16-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BUDIKOTE	13:05	13:30	00:25	LINE CLEAR AVAILED
2371	16-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DODDALAHALLI	21:38	21:45	00:07	TRIPPED ON FAULT
2372	16-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HAROBEL	17:00	18:00	01:00	LINE CLEAR AVAILED
2373	16-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KAMBIPURA	16:40	16:42	00:02	LINE CLEAR AVAILED
2374	16-Jul-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	14:00	14:35	00:35	LINE CLEAR AVAILED
2375	16-Jul-24	BANGALORE	66	LINE	VIDURASHWATHA - GREENENERGY SOLAR(IPP)	VIDURASHWATHA	15:05	15:15	00:10	LINE CLEAR AVAILED
2376	16-Jul-24	BANGALORE	220	LINE	220KV BIDADI 220 - TOYOTA 1	TOYOTA(EHT)	16:15	17:05	00:50	TRIPPED ON FAULT
2377	16-Jul-24	BANGALORE	220	LINE	220KV BIDADI 220 - TOYOTA 2	TOYOTA(EHT)	16:15	17:05	00:50	TRIPPED ON FAULT
2378	16-Jul-24	BANGALORE	220	TRANSFORMER	HV2	KIADB DB PURA 220	00:00	08:30	08:30	TRIPPED ON FAULT
2379	16-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	07:25	07:30	00:05	TRIPPED ON FAULT
2380	16-Jul-24	GULBARGA	66	TRANSFORMER	HV2	GUDEKOTE_66	12:50	13:00	00:10	TRIPPED ON FAULT
2381	16-Jul-24	GULBARGA	110	LINE	HALBARGA-CHIDRI	CHIDRI_110	03:20	03:40	00:20	TRIPPED ON FAULT
2382	16-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	03:10	03:20	00:10	TRIPPED ON FAULT
2383	16-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	03:10	03:15	00:05	TRIPPED ON FAULT
2384	16-Jul-24	GULBARGA	110	TRANSFORMER	HV1	YADRAMI_110	00:00	24:00:00	00:00	LINE CLEAR AVAILED
2385	16-Jul-24	GULBARGA	110	TRANSFORMER	HV2	SHAKTINAGAR_110	10:12	12:04	01:52	LINE CLEAR AVAILED
2386	16-Jul-24	GULBARGA	110	LINE	KAPNOOR-GULBARGA WEST 1	GULBARGA WEST_110	05:39	06:01	00:22	TRIPPED ON FAULT
2387	16-Jul-24	GULBARGA	110	LINE	LINGASUGUR-CHAYADEVI	LINGASUGUR_220	10:56	15:53	04:57	LINE CLEAR AVAILED
2388	16-Jul-24	GULBARGA	110	LINE	LINGASUGUR-KAREPOWER	LINGASUGUR_220	08:12	12:20	04:08	LINE CLEAR AVAILED
2389	16-Jul-24	GULBARGA	110	LINE	SANTHAPUR-JANAWADA	JANAWADA_110	05:40	06:00	00:20	TRIPPED ON FAULT
2390	16-Jul-24	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR	SHAHAPUR_110	20:06	20:41	00:35	LINE CLEAR AVAILED
2391	16-Jul-24	GULBARGA	110	LINE	SHAHBAD-JEEWARGI	JEEWARGI_110	00:17	00:22	00:05	TRIPPED ON FAULT
2392	16-Jul-24	GULBARGA	110	LINE	SHAHBAD-NALWAR	NALWAR_110	02:09	02:18	00:09	TRIPPED ON FAULT
2393	16-Jul-24	GULBARGA	110	LINE	SHAKTINAGAR-RAICHUR	SHAKTINAGAR_110	11:11	12:04	00:53	LINE CLEAR AVAILED
2394	16-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	11:12	17:13	06:01	LINE CLEAR AVAILED
2395	16-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	18:23	18:42	00:19	TRIPPED ON FAULT
2396	16-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	11:12	17:13	06:01	LINE CLEAR AVAILED
2397	16-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2398	16-Jul-24	GULBARGA	220	LINE	SHAHAPUR-SHAHBAD	SHAHAPUR_220	06:22	07:05	00:43	TRIPPED ON FAULT
2399	16-Jul-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONUR_66	20:48(15.07.2024)			TRIPPED ON FAULT
2400	16-Jul-24	HASSAN	66	LINE	BALLUPE-KANDLI	BALLUPETE_66	12:17	13:58	01:41	LINE CLEAR AVAILED
2401	16-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	00:00	07:55	07:55	LINE CLEAR AVAILED
2402	16-Jul-24	HASSAN	66	LINE	BHADRA-LINGADAHALLI	gen_bhadra	14:36	14:48	00:12	TRIPPED ON FAULT
2403	16-Jul-24	HASSAN	66	LINE	GENDEHA-HASSAN	GENDEHALLI_66	21:15(15.07.2024)	8:30(16.07.2024)	11:14 hrs	MAIN SUPPLY FAILURE
2404	16-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	08:40	19:40	11:00	LINE CLEAR AVAILED
2405	16-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	08:20	08:40	00:20	LINE CLEAR AVAILED
2406	16-Jul-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	03:49	03:57	00:08	TRIPPED ON FAULT
2407	16-Jul-24	HASSAN	66	LINE	HNPR2-RNPR1	HNPURA_220	11:52	12:04	00:12	TRIPPED ON FAULT
2408	16-Jul-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	03:56	04:03	00:07	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2409	16-Jul-24	HASSAN	66	TRANSFORMER	HV1	DUDDA_66	13:07	13:30	00:23	LINE CLEAR AVAILED
2410	16-Jul-24	HASSAN	66	TRANSFORMER	HV1	HNPURA_66	13:29	13:57	00:28	TRIPPED ON FAULT
2411	16-Jul-24	HASSAN	66	TRANSFORMER	HV1	HOLALUR_66	12:38	13:39	01:01	LINE CLEAR AVAILED
2412	16-Jul-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	12:23	14:00	01:37	MAIN SUPPLY FAILURE
2413	16-Jul-24	HASSAN	66	TRANSFORMER	HV1	SAKALESH PURA_66	12:15	14:00	01:45	LINE CLEAR AVAILED
2414	16-Jul-24	HASSAN	66	TRANSFORMER	HV2	MAGGE_66	12:23	14:00	01:37	MAIN SUPPLY FAILURE
2415	16-Jul-24	HASSAN	66	TRANSFORMER	HV2	SAKALESH PURA_66	12:15	14:00	01:45	LINE CLEAR AVAILED
2416	16-Jul-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	04:45	05:05	00:20	TRIPPED ON FAULT
2417	16-Jul-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	12:20	13:55	01:35	LINE CLEAR AVAILED
2418	16-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESH PURA_66	03:35	15:39	12:04	TRIPPED ON FAULT
2419	16-Jul-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESH PURA_66	12:15	14:00	01:45	LINE CLEAR AVAILED
2420	16-Jul-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESH PURA_66	04:40	05:00	00:20	TRIPPED ON FAULT
2421	16-Jul-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESH PURA_66	12:09	14:00	01:51	LINE CLEAR AVAILED
2422	16-Jul-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESH PURA_66	12:15	14:05	01:50	LINE CLEAR AVAILED
2423	16-Jul-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESH PURA_66	12:15	14:05	01:50	LINE CLEAR AVAILED
2424	16-Jul-24	HASSAN	110	LINE	ALKOLA-MRS	ALKOLA_110	05:55	06:20	00:25	TRIPPED ON FAULT
2425	16-Jul-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	05:30	05:55	00:25	TRIPPED ON FAULT
2426	16-Jul-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	06:13	10:49	04:36	TRIPPED ON FAULT
2427	16-Jul-24	HASSAN	110	LINE	ANANDA-LPH(LST-4)	ANANDAPURA_110	14:31	16:20	01:49	TRIPPED ON FAULT
2428	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	ANANDAPURA_110	00:02	11:50	11:48	TRIPPED ON FAULT
2429	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	ANANDAPURA_110	14:31	14:40	00:09	TRIPPED ON FAULT
2430	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	HOSANGADI_110	11:20	12:10	00:50	LINE CLEAR AVAILED
2431	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	HOSANGADI_110	14:00	16:29	02:29	LINE CLEAR AVAILED
2432	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	KITTADAHALLI_110	11:10	12:30	01:20	LINE CLEAR AVAILED
2433	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	22:30(16.07.2024)			TRIPPED ON FAULT
2434	16-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	11:22	11:30	00:08	LINE CLEAR AVAILED
2435	16-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	12:40	13:22	00:42	LINE CLEAR AVAILED
2436	16-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	08:59	09:11	00:12	TRIPPED ON FAULT
2437	16-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	03:34	03:42	00:08	TRIPPED ON FAULT
2438	16-Jul-24	HASSAN	110	LINE	LV1	PUTTUR_220	09:52	12:31	02:39	LINE CLEAR AVAILED
2439	16-Jul-24	HASSAN	110	LINE	SAGARA-ALKLA	SAGARA_110	05:28	10:30	05:02	TRIPPED ON FAULT
2440	16-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	07:30	11:20	03:50	LINE CLEAR AVAILED
2441	16-Jul-24	HASSAN	220	TRANSFORMER	HV1	PUTTUR_220	09:52	12:29	02:37	LINE CLEAR AVAILED
2442	16-Jul-24	HASSAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	12:35	14:18	01:43	LINE CLEAR AVAILED
2443	16-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMG_220	23:30(15.7.2024)			LINE CLEAR AVAILED
2444	16-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMG_220	23:30(15.7.2024)	8:18(16.07.2024)	8:47 hrs	LINE CLEAR AVAILED
2445	16-Jul-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:19	12:00	01:41	LINE CLEAR AVAILED
2446	16-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	23:30(15.7.2024)	8:25(16.07.2024)	8:54 hrs	LINE CLEAR AVAILED
2447	16-Jul-24	MYSORE	66	LINE	CHUNCHANAKATTE-GAVADGERE	NO STATIONS EFFECTED	10:10	12:05	01:55	LINE CLEAR AVAILED
2448	16-Jul-24	MYSORE	66	LINE	HAMPAPURA-SANTHESARGUR	HDKOTE_66 YEREHALLI HANDPOST_66ANTHARSANTHE_66	05:53	06:05	00:12	TRIPPED ON FAULT
2449	16-Jul-24	MYSORE	66	LINE	HEBBANI-BG PURA	BGPURA_66CHIDRAVALLI_66	06:02	06:17	00:15	TRIPPED ON FAULT
2450	16-Jul-24	MYSORE	66	LINE	HUNSUR-HUNSUR 1	NO STATIONS EFFECTED	13:12	14:52	01:39	LINE CLEAR AVAILED
2451	16-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2452	16-Jul-24	MYSORE	66	TRANSFORMER	HV1	THUMBLA_66	15:55	16:05	00:10	LINE CLEAR AVAILED
2453	16-Jul-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_220	08:22	12:32	04:09	TRIPPED ON FAULT
2454	16-Jul-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	15:55	16:05	00:10	LINE CLEAR AVAILED
2455	16-Jul-24	MYSORE	66	TRANSFORMER	HV2	TUBINAKERE_220	10:35	19:08	08:33	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2456	16-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2457	16-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2458	16-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2459	16-Jul-24	MYSORE	66	LINE	MUGUR -THAYUR	TNARASIPURA_66THAYUR_66	19:06	19:11	00:05	TRIPPED ON FAULT
2460	16-Jul-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_220	10:32	13:15	02:43	LINE CLEAR AVAILED
2461	16-Jul-24	MYSORE	220	TRANSFORMER	HV2	BEGUR_220	10:07	10:24	00:17	LINE CLEAR AVAILED
2462	16-Jul-24	MYSORE	220	TRANSFORMER	HV2	BEGUR_220	13:19	15:24	02:05	LINE CLEAR AVAILED
2463	16-Jul-24	MYSORE	220	TRANSFORMER	HV2	TUBINAKERE_220	10:25	13:24	02:58	LINE CLEAR AVAILED
2464	16-Jul-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	14:08	18:37	04:28	LINE CLEAR AVAILED
2465	16-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2466	16-Jul-24	TUMKUR	66	LINE	220KV GUTTUR-66KV DITTUR LINE	66KV KNNL DITTUR KNNL HALASABALU	02:05	02:23	00:18	TRIPPED ON FAULT
2467	16-Jul-24	TUMKUR	66	LINE	220KV MADHUGIRI-66KV KORATAGERE LINE 1	66KV HOLAVANAHALLI	17:16	17:26	00:10	TRIPPED ON FAULT
2468	16-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66	13:18 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2469	16-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2470	16-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 20 MVA	DAVANAGERE_66	08:54	09:50	00:56	TRIPPED ON FAULT
2471	16-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MADHUGIRI_66	04:31	04:51	00:20	TRIPPED ON FAULT
2472	16-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 20 MVA	KIADB_220	08:15	09:30	01:15	LINE CLEAR AVAILED
2473	16-Jul-24	TUMKUR	110	TRANSFORMER	TR-2 20 MVA	NITTUR_220	17:10	17:40	00:30	LINE CLEAR AVAILED
2474	16-Jul-24	TUMKUR	220	LINE	HIRIYUR 220KV- PGCIL	HIRIYUR_220	16:33	17:00	00:27	LINE CLEAR AVAILED
2475	16-Jul-24	TUMKUR	220	TRANSFORMER	TR-2(HV SIDE)	BENKIKERE_220	15:35 (15.07.2024)	16:32 (16.07.2024)	1DAY 57MIN	LINE CLEAR AVAILED
2476	16-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- BEERANAHALLI2	BEERANAHALLI2	12:45	16:06	03:21	LINE CLEAR AVAILED
2477	17-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	20:08 (15.07.2024)			LINE CLEAR AVAILED
2478	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BIDI_110	13:40	14:40	01:00	LINE CLEAR AVAILED
2479	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BIDI_110	12:14	13:17	01:03	LINE CLEAR AVAILED
2480	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	NIDAGUNDI_110	01:38	02:46	01:08	LINE CLEAR AVAILED
2481	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	RAMANAKOPPA_110	09:40	12:55	03:15	LINE CLEAR AVAILED
2482	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULIGERE CROSS_110	14:01	17:34	03:33	LINE CLEAR AVAILED
2483	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULIGOD_110	09:23	14:21	04:58	LINE CLEAR AVAILED
2484	17-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	SINDAGI_110	17:00	18:02	01:02	LINE CLEAR AVAILED
2485	17-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-NK1	AMBEWADI_220	18:45	20:43	01:58	TRIPPED ON FAULT
2486	17-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2487	17-Jul-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	17:28	17:37	00:09	LINE CLEAR AVAILED
2488	17-Jul-24	BAGALKOTE	110	LINE	ATHANI220-KARIMASUTTI	KARIMASUTTI LIS_110	06:06	06:20	00:14	TRIPPED ON FAULT
2489	17-Jul-24	BAGALKOTE	110	LINE	BABALESHWAR-VSE IPP	VSE IPP_110 STATION NOT AFFECTED BABALESHWAR_110	19:48 (16.07.2024)	02:41 (17.07.2024)	06:53	LINE CLEAR AVAILED
2490	17-Jul-24	BAGALKOTE	110	LINE	BELLATTI-ADITYA BIRLA SOLAR	ADITYA BIRLA SOLAR_110 STATION NOT AFFECTED BELLATTI_110	14:17	16:48	02:31	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2491	17-Jul-24	BAGALKOTE	110	LINE	BELLATTI-ENERCON2	ENERCON_110 STATION NOT AFFECTED BELLATTI_110	14:17	16:48	02:31	LINE CLEAR AVAILED
2492	17-Jul-24	BAGALKOTE	110	LINE	GADAG220- BETAGERI(ROn)	GADAG_220	14:30	16:30	02:00	LINE CLEAR AVAILED
2493	17-Jul-24	BAGALKOTE	110	LINE	GADAG220- DAMBAL1(SAMBAPUR)	GADAG_220	14:30	16:23	1:53	LINE CLEAR AVAILED
2494	17-Jul-24	BAGALKOTE	110	LINE	GADAG220- DAMBAL2(DAMBAL)	GADAG_220	14:30	16:26	1:56	LINE CLEAR AVAILED
2495	17-Jul-24	BAGALKOTE	110	LINE	GADAG220- GADAG1(BETAGERI)	GADAG_221	14:30	16:28	01:58	LINE CLEAR AVAILED
2496	17-Jul-24	BAGALKOTE	110	LINE	GADAG220- LAXMESHWAR	GADAG_220	14:30	16:29	1:59	LINE CLEAR AVAILED
2497	17-Jul-24	BAGALKOTE	110	LINE	GADAG220-SHIRHATTI	GADAG_220	14:10	21:12	07:02	TRIPPED ON FAULT
2498	17-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	11:04	15:19	04:15	LINE CLEAR AVAILED
2499	17-Jul-24	BAGALKOTE	110	LINE	HIREHAL-ROn	HIREHAL_110	14:20	15:29	01:09	LINE CLEAR AVAILED
2500	17-Jul-24	BAGALKOTE	110	LINE	JAMBAGI KD-VAJJRAMATTI	JAMBAGI KD_110	05:39	05:41	00:02	TRIPPED ON FAULT
2501	17-Jul-24	BAGALKOTE	110	LINE	KARWAR220-ARGA(KUMATA)	KARWAR_220	10:29	17:10	06:41	TRIPPED ON FAULT
2502	17-Jul-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	15:29	16:18	00:49	LINE CLEAR AVAILED
2503	17-Jul-24	BAGALKOTE	110	LINE	LAXMESHWAR-GADAG1	LAXMESHWAR_110	14:11	16:30	02:19	TRIPPED ON FAULT
2504	17-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2505	17-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR(BAGALKHOT1)	NAVANAGAR(B)_110	12:25 (6.07.2024)	10:51 (17.07.2024)	262:26:00	LINE CLEAR AVAILED
2506	17-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR(BAGALKHOT2)	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
2507	17-Jul-24	BAGALKOTE	110	LINE	RAMANAKOPPA-DUNDASHI	RAMANAKOPPA_110	12:31	12:55	00:24	LINE CLEAR AVAILED
2508	17-Jul-24	BAGALKOTE	110	LINE	RAMANAKOPPA-HUBLI	RAMANAKOPPA_110	12:31	12:55	00:24	LINE CLEAR AVAILED
2509	17-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2510	17-Jul-24	BAGALKOTE	110	LINE	ROn-GAMESH	ROn_110	16:35	16:39	00:04	LINE CLEAR AVAILED
2511	17-Jul-24	BAGALKOTE	110	LINE	SAMBAPUR ROAD-DAMBAL	SAMBAPUR ROAD_110	14:25	16:39	02:14	LINE CLEAR AVAILED
2512	17-Jul-24	BAGALKOTE	110	LINE	SAMBAPUR ROAD-RAILWAY LINE(RVNL)	SAMBAPUR ROAD_110	14:25	16:40	02:15	LINE CLEAR AVAILED
2513	17-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2514	17-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2515	17-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1(HV2)	GADAG_220	14:19	16:39	02:10	LINE CLEAR AVAILED
2516	17-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2(HV1)	GADAG_220	14:19	16:18	01:48	LINE CLEAR AVAILED
2517	17-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3&LV3	GADAG_220	14:10	16:19	02:09	TRIPPED ON FAULT
2518	17-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV4&LV4	GADAG_220	14:13	16:19	02:09	TRIPPED ON FAULT
2519	17-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI(HV1 & HV3)	22:26	22:34	00:08	TRIPPED ON FAULT
2520	17-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	13:51	15:30	01:39	TRIPPED ON FAULT
2521	17-Jul-24	BANGALORE	66	LINE	66KV KEMPANAHALLI - AGALAKOTE	AGALAKOTE	04:10	04:35	00:25	TRIPPED ON FAULT
2522	17-Jul-24	BANGALORE	66	LINE	66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA	DRDO, MALLASANDRA, SUGUTUR	08:50	09:21	00:31	TRIPPED ON FAULT
2523	17-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASWADI	08:03	08:15	00:12	TRIPPED ON FAULT
2524	17-Jul-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	RAILWAY TRACTION DODDABELE (EHT)	00:00	23:59	23:59	LINE CLEAR AVAILED
2525	17-Jul-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	23:00	23:05	00:05	TRIPPED ON FAULT
2526	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GULUR	04:10	04:55	00:45	TRIPPED ON FAULT
2527	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HOSAPALYA CIRLCE	03:08	03:15	00:07	TRIPPED ON FAULT
2528	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	09:15	09:17	00:02	LINE CLEAR AVAILED
2529	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KODIHALLI	08:45	09:05	00:20	TRIPPED ON FAULT
2530	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	13:12	13:32	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2531	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	15:15	15:30	00:15	TRIPPED ON FAULT
2532	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	11:20	11:45	00:25	LINE CLEAR AVAILED
2533	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	PALLADIUM	11:20	13:00	01:40	LINE CLEAR AVAILED
2534	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	PERESANDRA	13:00	13:35	00:35	LINE CLEAR AVAILED
2535	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	THAYALUR	11:25	11:45	00:20	LINE CLEAR AVAILED
2536	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	THONDEBHAVI	15:25	15:50	00:25	LINE CLEAR AVAILED
2537	17-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	08:40	08:49	00:09	LINE CLEAR AVAILED
2538	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	09:15	09:17	00:02	LINE CLEAR AVAILED
2539	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	11:56	11:58	00:02	LINE CLEAR AVAILED
2540	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	PALLADIUM	13:10	13:55	00:45	LINE CLEAR AVAILED
2541	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	REMCO	08:47	08:54	00:07	LINE CLEAR AVAILED
2542	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	REMCO	22:02	22:04	00:02	LINE CLEAR AVAILED
2543	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	THONDEBHAVI	15:25	15:50	00:25	LINE CLEAR AVAILED
2544	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TUBAGERE	11:05	11:30	00:25	LINE CLEAR AVAILED
2545	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TYAMAGONDLU	13:55	14:55	01:00	TRIPPED ON FAULT
2546	17-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	08:40	08:49	00:09	LINE CLEAR AVAILED
2547	17-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 1	NO STATION AFFECTED	10:54	17:56	07:02	TRIPPED ON FAULT
2548	17-Jul-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	NO STATION AFFECTED	15:01	23:59	08:58	TRIPPED ON FAULT
2549	17-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	20:32	23:59	03:27	LINE CLEAR AVAILED
2550	17-Jul-24	GULBARGA	110	LINE	GABUR-RAICHUR	GUGAL_110, GABUR_110	19:36	19:43	02:10	TRIPPED ON FAULT
2551	17-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	00:04	00:09	00:10	TRIPPED ON FAULT
2552	17-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110,BENNUR_110	00:04	00:12	00:10	TRIPPED ON FAULT
2553	17-Jul-24	GULBARGA	110	TRANSFORMER	HV1	VALKAMDINI_110	20:50	20:55	00:10	TRIPPED ON FAULT
2554	17-Jul-24	GULBARGA	110	LINE	JAWALGERA-VALABALLARI	JAWALGERA_110	05:06	05:16	01:10	TRIPPED ON FAULT
2555	17-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	04:20	04:30	00:10	TRIPPED ON FAULT
2556	17-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	04:50	05:35	00:10	TRIPPED ON FAULT
2557	17-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	00:53	07:33	00:10	LINE CLEAR AVAILED
2558	17-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	10:34	17:40	00:10	LINE CLEAR AVAILED
2559	17-Jul-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	23:01	23:30	00:29	TRIPPED ON FAULT
2560	17-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2561	17-Jul-24	HASSAN	66	LINE	BALEHN-JENUGADDE1	BALEHONUR_66	14:54	15:45	00:51	TRIPPED ON FAULT
2562	17-Jul-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONUR_66	20:48(15.07.2024)	10:35(17.07.2024)	37:46 hrs	TRIPPED ON FAULT
2563	17-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	11:30	11:45	00:15	TRIPPED ON FAULT
2564	17-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	14:45	15:55	01:10	MAIN SUPPLY FAILURE
2565	17-Jul-24	HASSAN	66	LINE	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	14:55	15:43	00:48	MAIN SUPPLY FAILURE
2566	17-Jul-24	HASSAN	66	LINE	HIREMAN-RDL	HIREMANGALUR_66	14:55	15:43	00:48	MAIN SUPPLY FAILURE
2567	17-Jul-24	HASSAN	66	TRANSFORMER	HV1	GORUR_66	09:06	15:25	06:19	LINE CLEAR AVAILED
2568	17-Jul-24	HASSAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	14:55	15:43	00:48	MAIN SUPPLY FAILURE
2569	17-Jul-24	HASSAN	66	TRANSFORMER	HV1	KALASAPURA_66	19:35	20:39	01:04	LINE CLEAR AVAILED
2570	17-Jul-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	13:51	15:25	01:34	LINE CLEAR AVAILED
2571	17-Jul-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	10:50	11:23	00:33	LINE CLEAR AVAILED
2572	17-Jul-24	HASSAN	66	LINE	LV2	MRSMG_220	09:16	13:05	03:49	LINE CLEAR AVAILED
2573	17-Jul-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPUA_66	02:47	03:16	00:29	TRIPPED ON FAULT
2574	17-Jul-24	HASSAN	110	LINE	ANANDA-LPH(LST-4)	ANANDAPURA_110	10:30	15:15	04:45	LINE CLEAR AVAILED
2575	17-Jul-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	10:18	10:21	00:03	TRIPPED ON FAULT
2576	17-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	14:46	14:49	00:03	LINE CLEAR AVAILED
2577	17-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKRE_110	09:24	13:22	03:58	TRIPPED ON FAULT
2578	17-Jul-24	HASSAN	110	TRANSFORMER	HV1	HOSANGADI_110	14:57	15:16	00:19	TRIPPED ON FAULT
2579	17-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTUR_110	22:30(16.07.2024)	13:11(17.07.2024)	14:40 hrs	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2580	17-Jul-24	HASSAN	110	TRANSFORMER	HV1	PUTTUR_110	09:37	12:00	02:23	LINE CLEAR AVAILED
2581	17-Jul-24	HASSAN	110	TRANSFORMER	HV2	MRSMSG_220	09:16	13:05	03:49	LINE CLEAR AVAILED
2582	17-Jul-24	HASSAN	110	TRANSFORMER	HV3	ALKOLA_110	04:18	05:36	01:18	LINE CLEAR AVAILED
2583	17-Jul-24	HASSAN	110	TRANSFORMER	HV3	PUTTUR_110	12:05	13:12	01:07	LINE CLEAR AVAILED
2584	17-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	10:25	15:30	05:05	LINE CLEAR AVAILED
2585	17-Jul-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	17:05	19:07	02:02	LINE CLEAR AVAILED
2586	17-Jul-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	14:55	19:02	04:07	TRIPPED ON FAULT
2587	17-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	12:57	13:55	00:58	LINE CLEAR AVAILED
2588	17-Jul-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	10:18	10:34	00:16	TRIPPED ON FAULT
2589	17-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2590	17-Jul-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	12:02	12:29	00:26	LINE CLEAR AVAILED
2591	17-Jul-24	MYSORE	66	TRANSFORMER	HV2	TUBINKERE_66	13:01	14:45	01:44	LINE CLEAR AVAILED
2592	17-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2593	17-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2594	17-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2595	17-Jul-24	MYSORE	66	LINE	TUBINKERE-KOTHIPURA	NO STATIONS EFFECTED	19:05:00 (17/7/24)			TRIPPED ON FAULT
2596	17-Jul-24	MYSORE	220	TRANSFORMER	HV1	TUBINKERE_220	10:35	12:46	02:11	LINE CLEAR AVAILED
2597	17-Jul-24	MYSORE	220	TRANSFORMER	HV2	TUBINKERE_220	12:52	12:54	00:02	LINE CLEAR AVAILED
2598	17-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2599	17-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LLINE 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	09:53	10:16	00:23	TRIPPED ON FAULT
2600	17-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	10:57	11:07	00:10	TRIPPED ON FAULT
2601	17-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALURAMESHWARA MADADKERE LINE	66KV HALRAMESHWARA, MADADAKERE	07:35	07:45	00:10	TRIPPED ON FAULT
2602	17-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66	13:18 (14.07.2024)	19:17 (17.07.2024)	3DAY, 6HR, 01MIN	LINE CLEAR AVAILED
2603	17-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2604	17-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 20 MVA	DAVANAGERE_66	08:51	09:00	00:09	TRIPPED ON FAULT
2605	17-Jul-24	TUMKUR	110	TRANSFORMER	TR-1 20MVA K.B.CROSS_220	K.B.CROSS_220	22:36 (17.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2606	17-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-220KV H M HOLE LINE 2	CHITRADURGA-220KV	14:12	14:24	00:12	TRIPPED ON FAULT
2607	17-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-220KV H M HOLE LINE 2	CHITRADURGA-220KV	14:32 (17.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2608	17-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV- HIRIYUR	MADHUGIRI_220	10:48	17:04	06:16	LINE CLEAR AVAILED
2609	18-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	20:08 (15.07.2024)	19:36 (18.07.2024)	71:28:00	LINE CLEAR AVAILED
2610	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	UGARKHUD_110	12:40	13:19	00:39	LINE CLEAR AVAILED
2611	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	HATTARAGI_110	11:45	12:30	00:45	LINE CLEAR AVAILED
2612	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	BEDI_110	12:22	14:45	02:23	LINE CLEAR AVAILED
2613	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	BIJAPUR CITY_110	13:12	13:15	00:03	LINE CLEAR AVAILED
2614	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	HATTARAGI_110	12:40	13:22	00:42	LINE CLEAR AVAILED
2615	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	MUNAVALLI_110	17:40	18:31	0:51	LINE CLEAR AVAILED
2616	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	ZALKI_110	16:09	17:11	01:02	LINE CLEAR AVAILED
2617	18-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4(20MVA)	KANABARGI LAYOUT_110	16:09	16:51	0:42	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2618	18-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220- NK1	AMBEWADI_220	12:10	12:14	00:04	LINE CLEAR AVAILED
2619	18-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2620	18-Jul-24	BAGALKOTE	110	LINE	ATHANI220-ATHANI2	ATHANI_220	12:51	13:10	00:19	TRIPPED ON FAULT
2621	18-Jul-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR CITY	BIJAPUR_220	12:49	13:07	00:18	TRIPPED ON FAULT
2622	18-Jul-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR CITY	BIJAPUR_220	13:42	14:32	00:50	TRIPPED ON FAULT
2623	18-Jul-24	BAGALKOTE	110	LINE	CHIKKODI220-DKSS COGEN	CHIKKODI_220	11:34	11:36	00:02	LINE CLEAR AVAILED
2624	18-Jul-24	BAGALKOTE	110	LINE	HAVERI220- BYADAGI	HAVERI_220	13:31	17:10	03:39	LINE CLEAR AVAILED
2625	18-Jul-24	BAGALKOTE	110	LINE	HIDIKAL DAM-GHATAPRABHA	HIDIKAL DAM_110	11:03	11:37	00:34	LINE CLEAR AVAILED
2626	18-Jul-24	BAGALKOTE	110	LINE	JAMAKHNDI-MAHALINGAPUR	JAMAKHNDI_110	13:07	14:01	00:54	LINE CLEAR AVAILED
2627	18-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2628	18-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKHOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
2629	18-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2630	18-Jul-24	BAGALKOTE	110	LINE	SIRSI220- SIRSI2	SIRSI_220	20:48	21:05	00:17	TRIPPED ON FAULT
2631	18-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2632	18-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-BILAGI	VAJRAMATTI_220	10:25	10:46	00:21	TRIPPED ON FAULT
2633	18-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-BILAGI	VAJRAMATTI_220	12:26	12:40	00:14	TRIPPED ON FAULT
2634	18-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-KATARKI	VAJRAMATTI_220	10:10	13:29	03:19	LINE CLEAR AVAILED
2635	18-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2636	18-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	SIRSI_220	11:22	17:53	06:31	LINE CLEAR AVAILED
2637	18-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1&2	AMBEWADI_220	7:06	14:12	7:06	LINE CLEAR AVAILED
2638	18-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHI2	SIRSI_220	05:41	16:40	10:59	TRIPPED ON FAULT
2639	18-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	02:02	02:23	00:21	TRIPPED ON FAULT
2640	18-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASWADI(HV1 & HV3)	08:02	08:37	00:35	TRIPPED ON FAULT
2641	18-Jul-24	BANGALORE	66	LINE	66KV ITI 220 - POTTERY ROAD	POTTERY ROAD	09:58	10:22	00:24	LINE CLEAR AVAILED
2642	18-Jul-24	BANGALORE	66	LINE	66KV KEMPAHALI - AGALAKOTE	AGALAKOTE	05:52	06:00	00:08	TRIPPED ON FAULT
2643	18-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66	14:25	14:40	00:15	TRIPPED ON FAULT
2644	18-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA, DEVANAHALLI 66, BRIGADE ORCHIDS	14:25	14:37	00:12	TRIPPED ON FAULT
2645	18-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALI 220 - ANDERSONPET	ANDERSONPET	15:15	15:31	00:16	TRIPPED ON FAULT
2646	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BRIGADE MEADOWS	16:45	16:47	00:02	LINE CLEAR AVAILED
2647	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	12:26	12:36	00:10	TRIPPED ON FAULT
2648	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DOMMASANDRA	15:30	16:30	01:00	LINE CLEAR AVAILED
2649	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GUNDAMGERE	02:40	02:45	00:05	TRIPPED ON FAULT
2650	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	15:20	15:30	00:10	TRIPPED ON FAULT
2651	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	LEELA VENTURE	12:12	15:22	03:10	LINE CLEAR AVAILED
2652	18-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MALLANAYAKANAHALLI	13:10	13:12	00:02	LINE CLEAR AVAILED
2653	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BRIGADE MEADOWS	11:15	11:17	00:02	LINE CLEAR AVAILED
2654	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	16:43	16:53	00:10	TRIPPED ON FAULT
2655	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	14:28	14:35	00:07	TRIPPED ON FAULT
2656	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	LEELA VENTURE	09:30	13:07	03:37	LINE CLEAR AVAILED
2657	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MALLANAYAKANAHALLI	12:35	13:10	00:35	LINE CLEAR AVAILED
2658	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANDINI LAYOUT	08:08	08:19	00:11	TRIPPED ON FAULT
2659	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	08:23	08:28	00:05	LINE CLEAR AVAILED
2660	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	04:18	04:38	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2661	18-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TYAMAGONDLU	14:00	16:30	02:30	LINE CLEAR AVAILED
2662	18-Jul-24	BANGALORE	66	LINE	LV1	SARJAPURA 220	11:00	11:14	00:14	MAIN SUPPLY FAILURE
2663	18-Jul-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	NO STATION AFFECTED	00:00	06:40	06:40	TRIPPED ON FAULT
2664	18-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	00:00	06:40	06:40	LINE CLEAR AVAILED
2665	18-Jul-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	11:00	11:14	00:14	LINE CLEAR AVAILED
2666	18-Jul-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	00:40	00:52	00:12	TRIPPED ON FAULT
2667	18-Jul-24	GULBARGA	110	TRANSFORMER	HV1	SHAHAPUR_110	09:52	09:58	00:06	TRIPPED ON FAULT
2668	18-Jul-24	GULBARGA	110	TRANSFORMER	HV1	YADRAMI_110	11:55	14:35	02:40	LINE CLEAR AVAILED
2669	18-Jul-24	GULBARGA	110	TRANSFORMER	HV2	YADRAMI_110	08:55	12:40	03:45	LINE CLEAR AVAILED
2670	18-Jul-24	GULBARGA	110	LINE	ITTAGI-TBH LINE	HP SGAR_66, TB HALLI_66, HB HALLI_66, BG HALLI_66	19:00	19:10	00:10	TRIPPED ON FAULT
2671	18-Jul-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	10:23	17:07	06:44	LINE CLEAR AVAILED
2672	18-Jul-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	10:30	16:53	06:23	LINE CLEAR AVAILED
2673	18-Jul-24	GULBARGA	110	LINE	RENEWSLR-SANTHAPUR	SANTHAPUR_110	18:55	19:30	00:35	TRIPPED ON FAULT
2674	18-Jul-24	GULBARGA	110	LINE	YADGIR-RMASAMUDRA	YADGIR_110	05:37	05:53	00:16	TRIPPED ON FAULT
2675	18-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	01:00	05:35	04:35	LINE CLEAR AVAILED
2676	18-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	00:40	00:55	00:15	TRIPPED ON FAULT
2677	18-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	11:59	23:59	12:00	LINE CLEAR AVAILED
2678	18-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	11:59	23:59	12:00	LINE CLEAR AVAILED
2679	18-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2680	18-Jul-24	GULBARGA	220	LINE	NEELGUNDA-ITTAGI	NEELGUNDA_220	19:00	19:36	00:36	MAIN SUPPLY FAILURE
2681	18-Jul-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	12:50	12:52	00:02	LINE CLEAR AVAILED
2682	18-Jul-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONNUR_66	09:02	14:58	05:56	TRIPPED ON FAULT
2683	18-Jul-24	HASSAN	66	TRANSFORMER	HV1	KALASAPURA_66	12:23	12:42	00:19	LINE CLEAR AVAILED
2684	18-Jul-24	HASSAN	66	TRANSFORMER	HV1	SATHENAHALLI_66	13:00	13:25	00:25	LINE CLEAR AVAILED
2685	18-Jul-24	HASSAN	66	TRANSFORMER	HV1	SINGAPURA_66	12:16	12:42	00:26	LINE CLEAR AVAILED
2686	18-Jul-24	HASSAN	66	TRANSFORMER	HV1	UDAYAPURA_66	11:01	11:40	00:39	LINE CLEAR AVAILED
2687	18-Jul-24	HASSAN	66	TRANSFORMER	HV2	AREHALLI_66	13:20	15:05	01:45	TRIPPED ON FAULT
2688	18-Jul-24	HASSAN	66	TRANSFORMER	HV2	HNPURA_66	18:08	18:16	00:08	TRIPPED ON FAULT
2689	18-Jul-24	HASSAN	66	TRANSFORMER	HV2	HOLEHAONNUR_66	23:50(18.07.2024)			TRIPPED ON FAULT
2690	18-Jul-24	HASSAN	66	TRANSFORMER	HV2	SATHENAHALLI_66	12:35	13:25	00:50	LINE CLEAR AVAILED
2691	18-Jul-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	21:18	21:28	00:10	TRIPPED ON FAULT
2692	18-Jul-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	17:00	17:18	00:18	MAIN SUPPLY FAILURE
2693	18-Jul-24	HASSAN	66	LINE	SATHENA-UDAY	SATHENAHALLI_66	13:00	13:25	00:25	LINE CLEAR AVAILED
2694	18-Jul-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	12:52	13:01	00:09	MAIN SUPPLY FAILURE
2695	18-Jul-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	16:15	16:18	00:03	LINE CLEAR AVAILED
2696	18-Jul-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	12:52	16:18	03:26	MAIN SUPPLY FAILURE
2697	18-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	12:52	13:01	00:09	MAIN SUPPLY FAILURE
2698	18-Jul-24	HASSAN	110	LINE	GURUVA-SLVPWR	GURUVAYANKERE_110	16:15	16:18	00:03	MAIN SUPPLY FAILURE
2699	18-Jul-24	HASSAN	110	TRANSFORMER	HV1	BHADRAVATHY_110	8:20(18.07.2024)			TRIPPED ON FAULT
2700	18-Jul-24	HASSAN	110	TRANSFORMER	HV1	MANIPAL_110	02:01	04:22	02:21	TRIPPED ON FAULT
2701	18-Jul-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	13:28(18.07.2024)			TRIPPED ON FAULT
2702	18-Jul-24	HASSAN	110	TRANSFORMER	HV4	MRSMSG_220	16:58(18.07.2024)			LINE CLEAR AVAILED
2703	18-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	12:53	13:01	00:08	LINE CLEAR AVAILED
2704	18-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	16:16	16:20	00:04	LINE CLEAR AVAILED
2705	18-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	12:52	16:13	03:21	LINE CLEAR AVAILED
2706	18-Jul-24	HASSAN	110	LINE	LV3	KEMAR_220	12:24	13:33	01:09	LINE CLEAR AVAILED
2707	18-Jul-24	HASSAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	18:16	18:32	00:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2708	18-Jul-24	HASSAN	110	LINE	NANDIKU-MULKY	NANDIKUR_110	05:19	05:34	00:15	TRIPPED ON FAULT
2709	18-Jul-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	19:36	19:43	00:07	LINE CLEAR AVAILED
2710	18-Jul-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	19:36	19:42	00:06	LINE CLEAR AVAILED
2711	18-Jul-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	19:36	19:46	00:10	LINE CLEAR AVAILED
2712	18-Jul-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:36	19:43	00:07	LINE CLEAR AVAILED
2713	18-Jul-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	19:36	19:57	00:21	LINE CLEAR AVAILED
2714	18-Jul-24	HASSAN	220	TRANSFORMER	HV3	KEMAR_220	12:24	13:33	01:09	LINE CLEAR AVAILED
2715	18-Jul-24	HASSAN	220	LINE	KAVOOR-BAJPE1	KAVOOR_220	10:39	14:34	03:55	LINE CLEAR AVAILED
2716	18-Jul-24	HASSAN	220	LINE	KAVOOR-BAJPE1	KAVOOR_220	15:09	16:03	00:54	LINE CLEAR AVAILED
2717	18-Jul-24	HASSAN	220	LINE	KAVOOR-BAJPE2	KAVOOR_220	14:02	14:57	00:55	LINE CLEAR AVAILED
2718	18-Jul-24	HASSAN	220	LINE	KEMAR-BAJPE1	KEMAR_220	12:16	13:44	01:28	LINE CLEAR AVAILED
2719	18-Jul-24	HASSAN	220	LINE	KEMAR-BAJPE2	KEMAR_220	10:19	12:16	01:57	LINE CLEAR AVAILED
2720	18-Jul-24	HASSAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	15:20	15:53	00:33	LINE CLEAR AVAILED
2721	18-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	20:00(18.07.2024)			TRIPPED ON FAULT
2722	18-Jul-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	12:09	13:45	01:36	LINE CLEAR AVAILED
2723	18-Jul-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	14:02	14:57	00:55	LINE CLEAR AVAILED
2724	18-Jul-24	HASSAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	15:03	16:04	01:01	LINE CLEAR AVAILED
2725	18-Jul-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	15:21	15:53	00:32	LINE CLEAR AVAILED
2726	18-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA3	gen_sharavathy	20:00(18.07.2024)			TRIPPED ON FAULT
2727	18-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	19:36(18.07.2024)			TRIPPED ON FAULT
2728	18-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	19:36(18.07.2024)			LINE CLEAR AVAILED
2729	18-Jul-24	MYSORE	66	LINE	CHUNCHANAKATTE- GRAPHITE INDIA IPP-GAVADGERE LINE	NO STATIONS EFFECTED	12:25	14:45	02:20	LINE CLEAR AVAILED
2730	18-Jul-24	MYSORE	66	LINE	GOLUR-DEVANUR NANJANGUDU	DEVANOORNGUDU_66SUTTUR_66	11:41	12:01	00:20	TRIPPED ON FAULT
2731	18-Jul-24	MYSORE	66	TRANSFORMER	HV1	BEGUR_66	14:40	15:05	00:25	LINE CLEAR AVAILED
2732	18-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2733	18-Jul-24	MYSORE	66	TRANSFORMER	HV2	BEGUR_66	11:40	13:05	01:25	LINE CLEAR AVAILED
2734	18-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	10:45	12:50	02:05	LINE CLEAR AVAILED
2735	18-Jul-24	MYSORE	66	TRANSFORMER	HV2	RAVANDUR_66	18:20	18:30	00:10	TRIPPED ON FAULT
2736	18-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2737	18-Jul-24	MYSORE	66	LINE	KR PETE 220-NARAYANAPURA	NO STATIONS EFFECTED	13:30	15:15	01:45	LINE CLEAR AVAILED
2738	18-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MIRLE-GRAPHITE IPP-KR NAGARA	NO STATIONS EFFECTED	17:19	17:33	00:14	TRIPPED ON FAULT
2739	18-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
2740	18-Jul-24	MYSORE	66	LINE	MADESHWARAPURA-NARAYANAPURA	NO STATIONS EFFECTED	13:30	15:15	01:45	LINE CLEAR AVAILED
2741	18-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2742	18-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2743	18-Jul-24	MYSORE	66	LINE	MUGUR-THAYURU	NO STATIONS EFFECTED	10:35	15:22	04:47	LINE CLEAR AVAILED
2744	18-Jul-24	MYSORE	66	LINE	PANYADAHUNDI-KEREHALLI LIS	NO STATIONS EFFECTED	06:15	06:20	00:05	TRIPPED ON FAULT
2745	18-Jul-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	YESSLU_66HETHUR_66	17:00	17:27	00:26	TRIPPED ON FAULT
2746	18-Jul-24	MYSORE	66	LINE	TUBINKERE-KOTHIPURA	NO STATIONS EFFECTED	19:05:00 (17/7/24)	18:01 (18/07/2024)	22:56 HRs	TRIPPED ON FAULT
2747	18-Jul-24	MYSORE	220	LINE	KADAKOLA-BASTIPURA1	NO STATIONS EFFECTED	10:47	17:36	06:49	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2748	18-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2749	18-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	15:35	15:45	00:10	TRIPPED ON FAULT
2750	18-Jul-24	TUMKUR	66	LINE	BALENAHALLI-CHALKERE	CHALKERE_66	14:45	16:05	01:20	TRIPPED ON FAULT
2751	18-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220KV- HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	13:55	14:30	00:35	LINE CLEAR AVAILED
2752	18-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2753	18-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MADHUGIRI_66	13:20	15:10	01:50	LINE CLEAR AVAILED
2754	18-Jul-24	TUMKUR	110	TRANSFORMER	TR-1 20MVA K.B.CROSS _220	K.B.CROSS _220	22:36 (17.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2755	18-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-220KV H M HOLE LINE 2	CHITRADURGA-220KV	14:32 (17.07.2024)	13:38 (18.07.2024)	23:06	TRIPPED ON FAULT
2756	18-Jul-24	TUMKUR	220	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	08:04	08:14	00:10	TRIPPED ON FAULT
2757	18-Jul-24	TUMKUR	220	LINE	220KV MADHURE-66KV HALURAMESHWARA MADADKERE LINE	66KV HALRAMESHWARA, MADADAKERE	17:40	17:55	00:15	TRIPPED ON FAULT
2758	18-Jul-24	TUMKUR	220	LINE	HOSADURGA220-BENKIKERE 2	HOSADURGA_220	17:40	17:55	00:15	TRIPPED ON FAULT
2759	18-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- BEERANAHALLI1	BEERANAHALLI1	11:00	19:08	08:08	LINE CLEAR AVAILED
2760	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	KANABARAGI_110	11:29	11:49	00:20	LINE CLEAR AVAILED
2761	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MUNDUGANUR_110	16:26	16:32	00:06	LINE CLEAR AVAILED
2762	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIRSI_110	21:44	21:55	00:11	TRIPPED ON FAULT
2763	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TUMMINAKATTI_110	19:01 (19.07.2024)			TRIPPED ON FAULT
2764	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SIRSI_110	07:24	07:48	00:24	LINE CLEAR AVAILED
2765	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SULTANPUR_110	14:30	17:40	03:10	LINE CLEAR AVAILED
2766	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	MACHE_110	09:52	11:09	01:17	TRIPPED ON FAULT
2767	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	KANABARAGI_110	11:50	11:53	00:03	LINE CLEAR AVAILED
2768	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	HIDIKAL_110	11:33	11:48	00:15	TRIPPED ON FAULT
2769	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULIGERE CROSS_110	14:57	17:56	02:59	LINE CLEAR AVAILED
2770	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	12:32	12:41	00:09	TRIPPED ON FAULT
2771	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	KANABARAGI_110	11:56	11:59	00:03	LINE CLEAR AVAILED
2772	19-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3(20MVA)	KANABARAGI_110	16:49	16:52	00:03	LINE CLEAR AVAILED
2773	19-Jul-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	SIRSI_220	14:14	14:57	00:43	TRIPPED ON FAULT
2774	19-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2775	19-Jul-24	BAGALKOTE	110	LINE	HAVERI220-BYADAGI	HAVERI_220	11:35	12:47	01:12	LINE CLEAR AVAILED
2776	19-Jul-24	BAGALKOTE	110	LINE	HIREHAL-IDLE(BADAMI)	HIREHAL_110	10:56	10:57	00:01	LINE CLEAR AVAILED
2777	19-Jul-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	11:03	14:13	03:10	LINE CLEAR AVAILED
2778	19-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-BISNAL	MAHALINGAPUR_220	16:46	19:02	02:16	LINE CLEAR AVAILED
2779	19-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2780	19-Jul-24	BAGALKOTE	110	LINE	MURUDESHWAR-HONNAVAR(KRCL RAILWAY)	MURUDESHWAR_110	16:56	17:02	00:06	LINE CLEAR AVAILED
2781	19-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKHOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
2782	19-Jul-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)	8:04 (19.07.2024)	2034:24:00	LINE CLEAR AVAILED
2783	19-Jul-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	10:44	10:52	00:08	LINE CLEAR AVAILED
2784	19-Jul-24	BAGALKOTE	110	LINE	SIRSI-JOG2	SIRSI_110	14:25	19:26	05:01	TRIPPED ON FAULT
2785	19-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	16:55	17:41	00:46	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2786	19-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2787	19-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2788	19-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	05:34	13:26	07:52	TRIPPED ON FAULT
2789	19-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	15:29	16:47	01:18	TRIPPED ON FAULT
2790	19-Jul-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI3	HUBLI_220	20:17 (19.07.2024)			TRIPPED ON FAULT
2791	19-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	12:18	14:10	01:52	LINE CLEAR AVAILED
2792	19-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	16:51 (19.07.2024)			LINE CLEAR AVAILED
2793	19-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	09:48	15:40	05:52	TRIPPED ON FAULT
2794	19-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	15:47	19:18	03:31	TRIPPED ON FAULT
2795	19-Jul-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA HOSPITAL	VICTORIA	09:26	09:41	00:15	LINE CLEAR AVAILED
2796	19-Jul-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	NO STATION AFFECTED	15:14	17:37	02:23	MAIN SUPPLY FAILURE
2797	19-Jul-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	12:19	12:24	00:05	LINE CLEAR AVAILED
2798	19-Jul-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTINIKETHAN	22:50	22:55	00:05	LINE CLEAR AVAILED
2799	19-Jul-24	BANGALORE	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SOUDELA, ANNABEL(DLF)	12:10	12:32	00:22	TRIPPED ON FAULT
2800	19-Jul-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - SANJEEVANADODDI	SANJEEVANADODDI, RANGANADODDI	12:31	12:58	00:27	TRIPPED ON FAULT
2801	19-Jul-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, RAYALPADU, GOWNIPALLI	18:52	19:03	00:11	TRIPPED ON FAULT
2802	19-Jul-24	BANGALORE	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	12:00	12:10	00:10	TRIPPED ON FAULT
2803	19-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66	13:12	13:26	00:14	TRIPPED ON FAULT
2804	19-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI, KUNDANA, BRIGADE ORCHARD	13:12	13:26	00:14	TRIPPED ON FAULT
2805	19-Jul-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANUKUNTE	16:15	16:30	00:15	TRIPPED ON FAULT
2806	19-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR, MN HALLI	06:41	07:06	00:25	TRIPPED ON FAULT
2807	19-Jul-24	BANGALORE	66	LINE	AVANI - ADITHYA BIRLA(SOLAR IPP)	ADITHYA BIRLA(SOLAR IPP)	13:55	14:25	00:30	LINE CLEAR AVAILED
2808	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BEVOOR	15:39	15:48	00:09	TRIPPED ON FAULT
2809	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	08:12	08:20	00:08	TRIPPED ON FAULT
2810	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	19:25	19:40	00:15	TRIPPED ON FAULT
2811	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	19:40	19:42	00:02	LINE CLEAR AVAILED
2812	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	H GOLLAHALLI	01:27	01:45	00:18	TRIPPED ON FAULT
2813	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	15:40	15:45	00:05	TRIPPED ON FAULT
2814	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MANCHENAHALLI	14:40	14:55	00:15	TRIPPED ON FAULT
2815	19-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MUDIYANUR	14:00	14:10	00:10	LINE CLEAR AVAILED
2816	19-Jul-24	BANGALORE	66	TRANSFORMER	HV2	JULUPALYA	19:20	20:25	01:05	TRIPPED ON FAULT
2817	19-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KGF	12:55	13:40	00:45	LINE CLEAR AVAILED
2818	19-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SOMENAHALLI	11:35	11:40	00:05	LINE CLEAR AVAILED
2819	19-Jul-2024	GULBARGA	66	TRANSFORMER	HV1	HARAPPANAHALLI_66	14:00	14:05	00:05	TRIPPED ON FAULT
2820	19-Jul-2024	GULBARGA	66	TRANSFORMER	HV3	MUNIRABAD_220	10:30	13:25	02:55	LINE CLEAR AVAILED
2821	19-Jul-2024	GULBARGA	66	LINE	MUNIRABAD-UP HALLI	VENKATAPUR_66	09:06	15:33	06:27	LINE CLEAR AVAILED
2822	19-Jul-2024	GULBARGA	66	LINE	UJJINI-BADALADUKU	UJJINI_66	19:00	19:10	00:10	LINE CLEAR AVAILED
2823	19-Jul-2024	GULBARGA	110	LINE	CHITAPUR-SEDAM	KORWARTEMPLE_110,CHITAPUR_110	03:58	04:15	00:17	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2824	19-Jul-2024	GULBARGA	110	LINE	CHITAPUR-SEDAM	KORWARTEMPLE_110,CHITAPUR_110	19:36	19:48	00:12	TRIPPED ON FAULT
2825	19-Jul-2024	GULBARGA	110	LINE	CHITAPUR-SEDAM	KORWARTEMPLE_110,CHITAPUR_110	03:58	04:15	00:17	LINE CLEAR AVAILED
2826	19-Jul-2024	GULBARGA	110	LINE	CHITAPUR-SEDAM	KORWARTEMPLE_110,CHITAPUR_110	19:36	19:48	00:12	TRIPPED ON FAULT
2827	19-Jul-2024	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALKI_110	04:00	04:15	00:15	TRIPPED ON FAULT
2828	19-Jul-2024	GULBARGA	110	LINE	HALBARGA-CHIDRI	CHIDRI_110	03:06	03:14	00:08	TRIPPED ON FAULT
2829	19-Jul-2024	GULBARGA	110	LINE	HALBARGA-HALLIKHED	HALLIKHED_110	05:21	05:26	00:05	TRIPPED ON FAULT
2830	19-Jul-2024	GULBARGA	110	TRANSFORMER	HV1	HALAVARTHI_220	10:39	13:53	03:14	LINE CLEAR AVAILED
2831	19-Jul-2024	GULBARGA	110	TRANSFORMER	HV1	MANDEWAL_110	11:40	17:53	06:13	LINE CLEAR AVAILED
2832	19-Jul-2024	GULBARGA	110	LINE	KAPNOOR-GANAGAPUR	GANAGAPUR_110	15:08	18:15	03:07	LINE CLEAR AVAILED
2833	19-Jul-2024	GULBARGA	110	LINE	RAICHUR-SINDHANOOR2	KURDICROSS_110	21:30	21:35	00:05	TRIPPED ON FAULT
2834	19-Jul-2024	GULBARGA	110	LINE	SINDHANOOR-JAWALGERA	JAWALGERA_110	10:10	15:27	05:17	LINE CLEAR AVAILED
2835	19-Jul-2024	GULBARGA	110	LINE	SIRGUPPA-TEKKALKOTE	SIRGUPPA_110	13:30	13:38	00:08	MAIN SUPPLY FAILURE
2836	19-Jul-2024	GULBARGA	110	LINE	VALKAMDINI-SINDHANOOR	SINDHANOOR_110	09:45	09:50	00:05	LINE CLEAR AVAILED
2837	19-Jul-2024	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2838	19-Jul-2024	GULBARGA	220	LINE	SHAHABAD-SHAHAPUR	SHAHAPUR_220	03:58	04:32	00:34	TRIPPED ON FAULT
2839	19-Jul-2024	GULBARGA	220	LINE	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	13:31	13:45	00:14	TRIPPED ON FAULT
2840	19-Jul-2024	GULBARGA	220	LINE	SINDHANOOR-SULEKAL	SINDHANOOR_220	13:31	13:45	00:14	TRIPPED ON FAULT
2841	19-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	11:43	13:28	01:45	TRIPPED ON FAULT
2842	19-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:43	13:07	01:24	TRIPPED ON FAULT
2843	19-Jul-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_66	12:14	12:25	00:11	TRIPPED ON FAULT
2844	19-Jul-24	HASSAN	66	LINE	GORUR-HASSAN	GORUR_66	10:25	10:55	00:30	MAIN SUPPLY FAILURE
2845	19-Jul-24	HASSAN	66	LINE	HASSN22-ARAKALGUD2	HASSAN_220	10:24	10:54	00:30	TRIPPED ON FAULT
2846	19-Jul-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	11:25	13:10	01:45	LINE CLEAR AVAILED
2847	19-Jul-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	14:00	14:07	00:07	TRIPPED ON FAULT
2848	19-Jul-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	15:52	16:07	00:15	TRIPPED ON FAULT
2849	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	18:39(19.07.2024)	13:30(20.07.2024)		TRIPPED ON FAULT
2850	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	14:39	15:00	00:21	TRIPPED ON FAULT
2851	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	BALEHONNUR_66	20:35	20:43	00:08	TRIPPED ON FAULT
2852	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	HANGARAHALLI_66	02:31	03:00	00:29	TRIPPED ON FAULT
2853	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	HOLEHONNUR_66	23:50(18.07.2024)	00:36(19.07.2024)	0:45 hrs	TRIPPED ON FAULT
2854	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	13:00	13:10	00:10	LINE CLEAR AVAILED
2855	19-Jul-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	15:50	16:24	00:34	LINE CLEAR AVAILED
2856	19-Jul-24	HASSAN	66	LINE	KIADB H-RAMESWARNAGAR	KIADB HASSAN_66	10:50	13:45	02:55	LINE CLEAR AVAILED
2857	19-Jul-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	15:51	16:09	00:18	TRIPPED ON FAULT
2858	19-Jul-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	13:00	13:10	00:10	LINE CLEAR AVAILED
2859	19-Jul-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	13:00	13:10	00:10	LINE CLEAR AVAILED
2860	19-Jul-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:54	13:46	02:52	LINE CLEAR AVAILED
2861	19-Jul-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	11:35	11:55	00:20	TRIPPED ON FAULT
2862	19-Jul-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	14:10	14:30	00:20	TRIPPED ON FAULT
2863	19-Jul-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	11:50	12:25	00:35	MAIN SUPPLY FAILURE
2864	19-Jul-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	17:45	17:51	00:06	TRIPPED ON FAULT
2865	19-Jul-24	HASSAN	110	LINE	HALADY1-HEGGUNJE	HALADY_110	15:13	17:15	02:02	MAIN SUPPLY FAILURE
2866	19-Jul-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	15:13	17:16	02:03	MAIN SUPPLY FAILURE
2867	19-Jul-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	17:16	17:19	00:03	LINE CLEAR AVAILED
2868	19-Jul-24	HASSAN	110	LINE	HIRIYA-HALADY	HIRIYADKA_110	12:03	12:12	00:09	LINE CLEAR AVAILED
2869	19-Jul-24	HASSAN	110	LINE	HULICA-KVR	HULICAL_110	15:15	15:45	00:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2870	19-Jul-24	HASSAN	110	TRANSFORMER	HV1	BHADRAVATHY_110	8:20(18.07.2024)			TRIPPED ON FAULT
2871	19-Jul-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	11:50	12:25	00:35	MAIN SUPPLY FAILURE
2872	19-Jul-24	HASSAN	110	TRANSFORMER	HV1	HIRENALLUR_110	07:50	15:00	07:10	LINE CLEAR AVAILED
2873	19-Jul-24	HASSAN	110	TRANSFORMER	HV1	SAGARA_110	16:05	16:57	00:52	LINE CLEAR AVAILED
2874	19-Jul-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	11:50	12:25	00:35	MAIN SUPPLY FAILURE
2875	19-Jul-24	HASSAN	110	TRANSFORMER	HV2	JOG_110	12:10	13:50	01:40	LINE CLEAR AVAILED
2876	19-Jul-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	00:00	14:43	14:43	TRIPPED ON FAULT
2877	19-Jul-24	HASSAN	110	TRANSFORMER	HV4	MRSMSG_220	16:58(18.07.2024)			LINE CLEAR AVAILED
2878	19-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA_110	12:03	12:12	00:09	LINE CLEAR AVAILED
2879	19-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA_110	13:52	14:09	00:17	LINE CLEAR AVAILED
2880	19-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	16:41	18:32	01:51	LINE CLEAR AVAILED
2881	19-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	19:00	19:25	00:25	LINE CLEAR AVAILED
2882	19-Jul-24	HASSAN	220	LINE	CRPATNA-HUYGNH	CRPATNA_220	08:04	08:24	00:20	TRIPPED ON FAULT
2883	19-Jul-24	HASSAN	220	LINE	HGUNJE-HALADY	HEGGUNJE_220	15:13	15:28	00:15	TRIPPED ON FAULT
2884	19-Jul-24	HASSAN	220	LINE	HGUNJE-HALADY	HEGGUNJE_220	15:28	15:49	00:21	TRIPPED ON FAULT
2885	19-Jul-24	HASSAN	220	LINE	HGUNJE-HALADY	HEGGUNJE_220	15:49	17:00	01:11	LINE CLEAR AVAILED
2886	19-Jul-24	HASSAN	220	LINE	HGUNJE-HALADY	HEGGUNJE_220	17:11	17:14	00:03	LINE CLEAR AVAILED
2887	19-Jul-24	HASSAN	220	LINE	HGUNJE-HIRIYADKA	HEGGUNJE_220	12:16	13:51	01:35	LINE CLEAR AVAILED
2888	19-Jul-24	HASSAN	220	TRANSFORMER	HV2	HEGGUNJE_220	10:16	15:54	05:38	TRIPPED ON FAULT
2889	19-Jul-24	HASSAN	220	LINE	MRSSHM-ARSIKERE	MRSMSG_220	15:52	18:26	02:34	TRIPPED ON FAULT
2890	19-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	20:00(18.07.2024)	14:08(19.07.2024)	18:07 hrs	TRIPPED ON FAULT
2891	19-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMSG_220	15:43	19:02	03:19	TRIPPED ON FAULT
2892	19-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA3	gen_sharavathy	20:00(18.07.2024)	14:08(19.07.2024)	18:07 hrs	TRIPPED ON FAULT
2893	19-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	19:36(18.07.2024)	13:35(19.07.2024)	17:58 hrs	TRIPPED ON FAULT
2894	19-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	19:36(18.07.2024)	13:35(19.07.2024)	17:58 hrs	TRIPPED ON FAULT
2895	19-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	15:44	19:02	03:18	TRIPPED ON FAULT
2896	19-Jul-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	17:45	18:00	00:15	TRIPPED ON FAULT
2897	19-Jul-24	MYSORE	66	LINE	BILIKERE-GV GUDI	GVGUDI_66	13:46	13:57	00:10	TRIPPED ON FAULT
2898	19-Jul-24	MYSORE	66	LINE	HUNSUR-HOSURGATE-BANNIKUPPE	BANNIKUPPE_66	13:46	14:03	00:16	TRIPPED ON FAULT
2899	19-Jul-24	MYSORE	66	TRANSFORMER	HV1	KRPET_66	18:23	18:58	00:35	LINE CLEAR AVAILED
2900	19-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2901	19-Jul-24	MYSORE	66	LINE	KK DODDI-TALAGAVADI-KIADB	KIADBMANDYA_66 TUMBEKERE_66	10:14	11:17	01:02	LINE CLEAR AVAILED
2902	19-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
2903	19-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
2904	19-Jul-24	MYSORE	66	LINE	MADDUR-KIADB-MANDYA	NO STATIONS EFFECTED	10:00	11:24	01:24	LINE CLEAR AVAILED
2905	19-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2906	19-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
2907	19-Jul-24	MYSORE	66	LINE	MANDYA-KIADB-MADDUR	NO STATIONS EFFECTED	10:12	11:19	01:07	LINE CLEAR AVAILED
2908	19-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	14:25	17:39	03:13	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2909	19-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV HIREGUTNUR,PANDARAHALLI,HOLALKERE, CHIKKAJAJUR,SASALUHALLA	16:28	16:37	00:09	TRIPPED ON FAULT
2910	19-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
2911	19-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR, MALEBENNUR,DEVARBELAKERE	15:08	15:19	00:11	TRIPPED ON FAULT
2912	19-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	11:03	11:14	00:11	TRIPPED ON FAULT
2913	19-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV SASVEHALLI LINE	66KV SASVEHALLI	17:14	17:24	00:10	TRIPPED ON FAULT
2914	19-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALURAMESHWARA MADADKERE LINE	66KV HALURAMESHWARA,MADADAKERE	17:15	17:25	00:10	TRIPPED ON FAULT
2915	19-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 1	Station not affected	16:30	16:40	00:10	TRIPPED ON FAULT
2916	19-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRAHALLI, HD PURA,	16:30	16:40	00:10	TRIPPED ON FAULT
2917	19-Jul-24	TUMKUR	66	LINE	66KV GARAGA-66KV PANCHANAHALLI LINE	66KV PANCHANAHALLI	19:00	19:20	00:20	TRIPPED ON FAULT
2918	19-Jul-24	TUMKUR	66	LINE	66KV KEREILACHI-66KV SHYGALE LINE	WATER SUPPLY	15:50	16:05	00:15	TRIPPED ON FAULT
2919	19-Jul-24	TUMKUR	66	LINE	66KV PANDARAHALLI-66KV HOLALKERE LINE	66KV HOLALKERE,CHIKKAJAJUR,SASALUHALLA	12:28	12:38	00:10	TRIPPED ON FAULT
2920	19-Jul-24	TUMKUR	66	LINE	66KV SANTEBENNUR-66KV KEREILACHI LINE	66KV KEREILACHI,SHYGALE	15:50	16:05	00:15	TRIPPED ON FAULT
2921	19-Jul-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI LINE	66KV SOKKE ,JAGALUR	17:00	17:10	00:10	MAIN SUPPLY FAILURE
2922	19-Jul-24	TUMKUR	66	LINE	BUKKAPATNA-SIRA	BUKKAPATNA_66	10:10	17:17	07:07	LINE CLEAR AVAILED
2923	19-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	16:30	16:45	00:15	TRIPPED ON FAULT
2924	19-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	16:45	18:17	01:32	TRIPPED ON FAULT
2925	19-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	18:17 (19.07.24)	10:51 (20.07.24)	16:34	TRIPPED ON FAULT
2926	19-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2927	19-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	15:50	15:55	00:05	TRIPPED ON FAULT
2928	19-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
2929	19-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15	16:15	06:00	LINE CLEAR AVAILED
2930	19-Jul-24	TUMKUR	110	TRANSFORMER	TR-1 20MVA K.B.CROSS _220	K.B.CROSS _220	22:36 (17.07.2024)	17:41 (19.07.24)	1DAY 19HRS 05MIN	TRIPPED ON FAULT
2931	19-Jul-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA ANTHARASANAHALLI_220	ANTHARASANAHALLI_220	12:06	12:55	00:49	LINE CLEAR AVAILED
2932	19-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS LINE	GUTTUR_400	00:41	16:07	15:26	LINE CLEAR AVAILED
2933	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	ALNAVAR_110	03:50	03:55	00:05	TRIPPED ON FAULT
2934	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	11:09	19:11	08:02	LINE CLEAR AVAILED
2935	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	MAMADAPUR(B)	16:01	17:48	01:47	LINE CLEAR AVAILED
2936	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KULAGERICROSS_110	14:24	18:14	03:50	LINE CLEAR AVAILED
2937	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	NAVANAGAR(H)_110	10:28	11:29	01:01	LINE CLEAR AVAILED
2938	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	SIDDAPUR_110	12:34	14:17	01:43	LINE CLEAR AVAILED
2939	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TADASINAKOPPA_110	00:14	11:23	11:09	LINE CLEAR AVAILED
2940	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	UDYAMBAG_110	11:10	15:11	04:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2941	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	DAVALESHWAR_110	11:15	12:44	01:29	LINE CLEAR AVAILED
2942	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KULAGERICROSS_110	14:24	18:14	03:50	LINE CLEAR AVAILED
2943	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MALGHAN(S)_110	10:02	10:11	00:09	TRIPPED ON FAULT
2944	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MURDESHWAR_110	11:06	12:09	01:03	LINE CLEAR AVAILED
2945	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	UDYAMBAG_110	15:18	18:33	03:15	LINE CLEAR AVAILED
2946	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	TUMMINAKATTI_110	19:01 (19.07.2024)	12:53 (20.07.2024)	17:52:00	TRIPPED ON FAULT
2947	20-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(20MVA)	ANKALI_110	11:45	11:55	00:10	TRIPPED ON FAULT
2948	20-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
2949	20-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2950	20-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
2951	20-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2952	20-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
2953	20-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - KOPPAL LIS	BAGALKOT_220	01:27	01:39	00:12	TRIPPED ON FAULT
2954	20-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - KOPPAL LIS	BAGALKOT_220	01:49	01:54	00:05	TRIPPED ON FAULT
2955	20-Jul-24	BAGALKOTE	220	LINE	BIDNAL-NAGJHARI2(NAGJHARI)	BIDNAL_220	11:56	14:09	02:13	LINE CLEAR AVAILED
2956	20-Jul-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI3	HUBLI_220	20:17 (19.07.2024)	14:14 (20.07.2024)	17:57:00	TRIPPED ON FAULT
2957	20-Jul-24	BAGALKOTE	220	LINE	HUBLI-SIRSI 1	HUBLI_220	09:39	13:42	04:03	LINE CLEAR AVAILED
2958	20-Jul-24	BAGALKOTE	220	LINE	HUBLI-SIRSI 2	HUBLI_220	09:40	13:42	04:02	LINE CLEAR AVAILED
2959	20-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	16:51 (19.07.2024)	22:41 (20.07.2024)	29:50:00	LINE CLEAR AVAILED
2960	20-Jul-24	BAGALKOTE	220	LINE	SAVADATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
2961	20-Jul-24	BAGALKOTE	220	LINE	SIRSI-HUBLI1	SIRSI_220	09:39	13:42	04:03	LINE CLEAR AVAILED
2962	20-Jul-24	BAGALKOTE	220	LINE	SIRSI-HUBLI2	SIRSI_220	09:39	13:42	04:03	LINE CLEAR AVAILED
2963	20-Jul-24	BAGALKOTE	220	LINE	VAJJARMATTI-BAGALKOT 1	VAJJARAMATTI_220	18:42	20:35	01:53	TRIPPED ON FAULT
2964	20-Jul-24	BAGALKOTE	220	LINE	VAJJARMATTI-ENERCON SOLAR	VAJJARAMATTI_220	17:26	19:35	02:09	LINE CLEAR AVAILED
2965	20-Jul-24	BAGALKOTE	220	LINE	VAJJARMATTI-MAHALINGAPUR 2	VAJJARAMATTI_220	16:45 (19.07.24)	22:38 (20.07.2024)	29:53:00	LINE CLEAR AVAILED
2966	20-Jul-24	BANGALORE	66	LINE	66KV EDC 220 - AUSTIN TOWN	AUSTIN TOWN	08:41	08:46	00:05	LINE CLEAR AVAILED
2967	20-Jul-24	BANGALORE	66	LINE	66KV GOKULA - BEL EHT	BEL(EHT)	10:08	14:50	04:42	LINE CLEAR AVAILED
2968	20-Jul-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	10:08	14:56	04:48	LINE CLEAR AVAILED
2969	20-Jul-24	BANGALORE	66	LINE	66KV GOKULA - MATHIKERE	MATHIKERE	10:00	10:04	00:04	LINE CLEAR AVAILED
2970	20-Jul-24	BANGALORE	66	LINE	66KV GOKULA - RMV	RMV, IISc(EHT)	09:30	09:37	00:07	LINE CLEAR AVAILED
2971	20-Jul-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE TECH PARK (TAPPED TO ADE/GTRE)	BAGHMANE TECH PARK	09:25	14:40:00	05:15	LINE CLEAR AVAILED
2972	20-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	LR BANDE	15:15	15:20	00:05	LINE CLEAR AVAILED
2973	20-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4	SHOBHA CITY	11:00	14:42	03:42	LINE CLEAR AVAILED
2974	20-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	LR BANDE	09:20	09:25	00:05	LINE CLEAR AVAILED
2975	20-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - MATHIKERE	MATHIKERE	15:13	15:19	00:06	LINE CLEAR AVAILED
2976	20-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - RMV	RMV, IISc(EHT)	15:01	15:05	00:04	LINE CLEAR AVAILED
2977	20-Jul-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	AUSTIN TOWN	18:16	18:20	00:04	LINE CLEAR AVAILED
2978	20-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	10:13	10:16	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2979	20-Jul-24	BANGALORE	66	LINE	66KV NIMHANS 220 - ADUGODI	ADUGODI	08:32	08:45	00:13	LINE CLEAR AVAILED
2980	20-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	21:45	21:50	00:05	LINE CLEAR AVAILED
2981	20-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66	14:30	14:50	00:20	TRIPPED ON FAULT
2982	20-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI, KUNDANA, BRIGADE ORCHARDS	14:30	14:52	00:22	TRIPPED ON FAULT
2983	20-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	12:34	12:47	00:13	TRIPPED ON FAULT
2984	20-Jul-24	BANGALORE	66	LINE	66KV PRESTIGE SHANTHINIKETHAN - DARSHITHA EHT	PRESTIGE SHANTINIKETHAN	10:50	11:00	00:10	LINE CLEAR AVAILED
2985	20-Jul-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - GOKULA	GOKULA	10:22	14:49	04:27	LINE CLEAR AVAILED
2986	20-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:12	10:20	00:08	LINE CLEAR AVAILED
2987	20-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	09:53	10:02	00:09	LINE CLEAR AVAILED
2988	20-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	10:05	17:20	07:15	LINE CLEAR AVAILED
2989	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BEVOOR	12:04	12:38	00:34	LINE CLEAR AVAILED
2990	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	11:23	11:28	00:05	LINE CLEAR AVAILED
2991	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GOKULA	10:21	15:06	04:45	LINE CLEAR AVAILED
2992	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	07:16	07:20	00:04	LINE CLEAR AVAILED
2993	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SURYANAGAR	20:26	20:36	00:10	TRIPPED ON FAULT
2994	20-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VRISHABHAVATHI 220	10:17	17:20	07:03	LINE CLEAR AVAILED
2995	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	AGALAKOTE	11:12	11:17	00:05	TRIPPED ON FAULT
2996	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	AGALAKOTE	16:09	16:14	00:05	TRIPPED ON FAULT
2997	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BEVOOR	11:36	11:59	00:23	LINE CLEAR AVAILED
2998	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GOKULA	10:21	15:06	04:45	LINE CLEAR AVAILED
2999	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HOSKOTE 66	11:55	12:30	00:35	LINE CLEAR AVAILED
3000	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	07:16	07:20	00:04	LINE CLEAR AVAILED
3001	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	LR BANDE	09:25	09:27	00:02	LINE CLEAR AVAILED
3002	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	03:03	04:03	01:00	TRIPPED ON FAULT
3003	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VRISHABHAVATHI 220	10:17	17:20	07:03	LINE CLEAR AVAILED
3004	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	09:02	09:17	00:15	TRIPPED ON FAULT
3005	20-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	09:17	11:17	02:00	LINE CLEAR AVAILED
3006	20-Jul-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	18:45	23:59	05:14	LINE CLEAR AVAILED
3007	20-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HARAPPANAHALLI1	HARAPPANAHALLI_66	06:20	06:26	00:06	TRIPPED ON FAULT
3008	20-Jul-24	GULBARGA	110	LINE	BISILHALLI-NORTH	BISILHALLI_110, MOKA_110, PD HALLI_110	15:55	16:59	01:04	LINE CLEAR AVAILED
3009	20-Jul-24	GULBARGA	110	TRANSFORMER	HV1	HALAVARTHI_220	11:52	13:31	01:39	LINE CLEAR AVAILED
3010	20-Jul-24	GULBARGA	110	TRANSFORMER	HV1	WALKAMDINI_110	09:10	09:20	00:10	TRIPPED ON FAULT
3011	20-Jul-24	GULBARGA	110	TRANSFORMER	HV2	KALBURGI NORTH_110	11:20	13:22	02:02	LINE CLEAR AVAILED
3012	20-Jul-24	GULBARGA	110	TRANSFORMER	HV2	KANAKAGIRI_110	15:15	16:00	00:45	TRIPPED ON FAULT
3013	20-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	21:40	21:53	00:13	TRIPPED ON FAULT
3014	20-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	05:00	05:10	00:10	TRIPPED ON FAULT
3015	20-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	05:50	06:00	00:10	TRIPPED ON FAULT
3016	20-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	06:05	08:15	02:10	TRIPPED ON FAULT
3017	20-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	20:06	21:11	01:05	TRIPPED ON FAULT
3018	20-Jul-24	GULBARGA	110	LINE	MOKA-NORTH	MOKA_110	16:00	16:30	00:30	LINE CLEAR AVAILED
3019	20-Jul-24	GULBARGA	110	LINE	MOKA-NORTH	MOKA_110	16:30	16:55	00:25	MAIN SUPPLY FAILURE
3020	20-Jul-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	09:03	09:45	00:42	TRIPPED ON FAULT
3021	20-Jul-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	09:45	11:20	01:35	LINE CLEAR AVAILED
3022	20-Jul-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERICROSS_110	01:15	01:25	00:10	MAIN SUPPLY FAILURE
3023	20-Jul-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERICROSS_110	01:28	01:38	00:10	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3024	20-Jul-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERICROSS_110	02:18	02:30	00:12	MAIN SUPPLY FAILURE
3025	20-Jul-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERICROSS_110	04:23	04:33	00:10	MAIN SUPPLY FAILURE
3026	20-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:35	05:45	00:10	TRIPPED ON FAULT
3027	20-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	21:20	21:30	00:10	TRIPPED ON FAULT
3028	20-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:37	17:26	11:49	TRIPPED ON FAULT
3029	20-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	21:23	21:28	00:05	TRIPPED ON FAULT
3030	20-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	05:12	05:20	00:08	TRIPPED ON FAULT
3031	20-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3032	20-Jul-24	GULBARGA	220	LINE	SHAHAPUR-FIROZABAD2	SHAHAPUR_220	21:41	21:54	00:13	TRIPPED ON FAULT
3033	20-Jul-24	GULBARGA	220	LINE	SHAHAPUR-SHAHABAD	SHAHAPUR_220	20:51	21:16	00:25	TRIPPED ON FAULT
3034	20-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	10:25	10:30	00:05	MAIN SUPPLY FAILURE
3035	20-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	07:25	10:25	03:00	TRIPPED ON FAULT
3036	20-Jul-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	15:14	15:20	00:06	LINE CLEAR AVAILED
3037	20-Jul-24	HASSAN	66	LINE	BAGUR-UDAYAPUR	BAGUR_66	15:14	15:20	00:06	LINE CLEAR AVAILED
3038	20-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	07:24	10:32	03:08	MAIN SUPPLY FAILURE
3039	20-Jul-24	HASSAN	66	TRANSFORMER	HV1	BAGUR_66	15:14	15:20	00:06	LINE CLEAR AVAILED
3040	20-Jul-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	13:49	14:24	00:35	MAIN SUPPLY FAILURE
3041	20-Jul-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	23:05	23:12	00:07	TRIPPED ON FAULT
3042	20-Jul-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	18:39(19.07.2024)	13:30(20.07.2024)	18:50 hrs	TRIPPED ON FAULT
3043	20-Jul-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	15:14	15:20	00:06	LINE CLEAR AVAILED
3044	20-Jul-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	10:15	10:35	00:20	MAIN SUPPLY FAILURE
3045	20-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	13:15	13:25	00:10	TRIPPED ON FAULT
3046	20-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	18:50	21:10	02:20	LINE CLEAR AVAILED
3047	20-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	21:50	22:15	00:25	TRIPPED ON FAULT
3048	20-Jul-24	HASSAN	66	LINE	SAKALE-HASSAN	SAKALESHPURA_66	13:48	14:17	00:29	LINE CLEAR AVAILED
3049	20-Jul-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	13:22	14:00	00:38	LINE CLEAR AVAILED
3050	20-Jul-24	HASSAN	110	TRANSFORMER	HV1	NITTU_110	12:10	12:42	00:32	LINE CLEAR AVAILED
3051	20-Jul-24	HASSAN	110	TRANSFORMER	HV1	SHIVAPURA_110	14:35	17:05	02:30	TRIPPED ON FAULT
3052	20-Jul-24	HASSAN	110	TRANSFORMER	HV2	BHADRAVATHY_110	8:20(18.07.2024)	13:00(20.07.2024)	55:39 hrs	LINE CLEAR AVAILED
3053	20-Jul-24	HASSAN	110	TRANSFORMER	HV2	HALADY_110	07:24	07:30	00:06	TRIPPED ON FAULT
3054	20-Jul-24	HASSAN	110	TRANSFORMER	HV2	MOODABIDRE_110	12:18	12:39	00:21	LINE CLEAR AVAILED
3055	20-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	23:23	23:32	00:09	TRIPPED ON FAULT
3056	20-Jul-24	HASSAN	110	TRANSFORMER	HV4	MRSMG_220	16:58(18.07.2024)	13:39 (20.07.2024)	44:40 hrs	LINE CLEAR AVAILED
3057	20-Jul-24	HASSAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	15:31	15:36	00:05	TRIPPED ON FAULT
3058	20-Jul-24	HASSAN	110	LINE	LV2	PUTTUR_220	09:50	12:35	02:45	LINE CLEAR AVAILED
3059	20-Jul-24	HASSAN	110	LINE	MADHUV-BRK_HRD CBreaker	MADHUVANA_110	13:22	14:00	00:38	LINE CLEAR AVAILED
3060	20-Jul-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	09:50	12:35	02:45	LINE CLEAR AVAILED
3061	20-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	03:48	04:37	00:49	TRIPPED ON FAULT
3062	20-Jul-24	MYSORE	66	LINE	BEGUR220-SINDUVALLIPURA	SINDHUVALI_66	18:10	18:15	00:05	TRIPPED ON FAULT
3063	20-Jul-24	MYSORE	66	LINE	CHUNCHUNKATTE-GAVADGERE	NO STATIONS EFFECTED	10:45	10:50	00:05	TRIPPED ON FAULT
3064	20-Jul-24	MYSORE	66	LINE	DKMAIDANA-KADAKOLA	NO STATIONS EFFECTED	12:08	12:47	00:38	LINE CLEAR AVAILED
3065	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	GUNDLUPETE_66	14:05	15:08	01:03	LINE CLEAR AVAILED
3066	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	HURA_66	12:10	12:45	00:35	LINE CLEAR AVAILED
3067	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	09:58	14:29	04:31	LINE CLEAR AVAILED
3068	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	MUGUR_66	12:15	13:22	01:06	LINE CLEAR AVAILED
3069	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3070	20-Jul-24	MYSORE	66	TRANSFORMER	HV1	SRIRANGAPATNA_66	11:03	15:40	04:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3071	20-Jul-24	MYSORE	66	LINE	JYOTHINAGAR-DK MAIDANA	NO STATIONS EFFECTED	12:24	12:48	00:23	LINE CLEAR AVAILED
3072	20-Jul-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	02:57	03:00	00:03	TRIPPED ON FAULT
3073	20-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
3074	20-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
3075	20-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3076	20-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
3077	20-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1 & TR-2 HONNALLI_220	HONNALLI_220	07:21	08:02	00:41	MAIN SUPPLY FAILURE
3078	20-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	ANCHEPALYA 66	08:00	08:50	00:50	LINE CLEAR AVAILED
3079	20-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3080	20-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	16:01	16:04	00:03	LINE CLEAR AVAILED
3081	20-Jul-24	TUMKUR	66	LINE	BUKKAPATNA-SIRA	BUKKAPATNA_66	08:55	19:04	10:09	LINE CLEAR AVAILED
3082	20-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	11:10	11:17	00:07	LINE CLEAR AVAILED
3083	20-Jul-24	TUMKUR	66	LINE	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66	13:01	14:12	01:11	LINE CLEAR AVAILED
3084	20-Jul-24	TUMKUR	66	LINE	DEVARAHALLI- SANTHEBENNUR	SANTHEBENNUR_66,KEREBILCHI_66	19:00	19:10	00:10	TRIPPED ON FAULT
3085	20-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	P R PURA_66	9:24 (14.07.2024)	15:30 (19.07.24)	5days 6hrs 6min	LINE CLEAR AVAILED
3086	20-Jul-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	07:21	08:01	00:40	MAIN SUPPLY FAILURE
3087	20-Jul-24	TUMKUR	66	LINE	HONNALLI 220kV- NALLUR_66	NALLUR_66	07:21	08:01	00:40	MAIN SUPPLY FAILURE
3088	20-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	08:16	08:28	00:12	TRIPPED ON FAULT
3089	20-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	10:52	11:02	00:10	TRIPPED ON FAULT
3090	20-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	07:19	08:03	00:44	MAIN SUPPLY FAILURE
3091	20-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	08:16	14:51	06:35	TRIPPED ON FAULT
3092	20-Jul-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	21:30	21:40	00:10	TRIPPED ON FAULT
3093	20-Jul-24	TUMKUR	66	LINE	MALLADIHALLI_66-BENKIKERE_220	MALLADIHALLI_66	10:00	16:55	06:55	LINE CLEAR AVAILED
3094	20-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA MADHUGIRI_220	MADHUGIRI_220	19:42	20:00	00:18	TRIPPED ON FAULT
3095	20-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
3096	20-Jul-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA HONNALLI_220	HONNALLI_220	07:19	07:58	00:39	TRIPPED ON FAULT
3097	21-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	ATHARGA_110	12:29	13:27	00:58	LINE CLEAR AVAILED
3098	21-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	09:06	09:16	00:10	TRIPPED ON FAULT
3099	21-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ALBAL_110	08:37	09:06	00:29	LINE CLEAR AVAILED
3100	21-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	TALIKOT_110	07:41	07:49	00:08	TRIPPED ON FAULT
3101	21-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)			TRIPPED ON FAULT
3102	21-Jul-24	BAGALKOTE	110	LINE	KARWAR-ARGA	KARWAR_220	04:36	14:53	10:17	TRIPPED ON FAULT
3103	21-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3104	21-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR- HONNAVAR	MURDESHWAR_110	16:21	16:23	00:02	LINE CLEAR AVAILED
3105	21-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
3106	21-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMATA2	SIRSI_110	10:33	12:11	01:38	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3107	21-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMATA2	SIRSI_110	12:13	17:45	05:32	TRIPPED ON FAULT
3108	21-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3109	21-Jul-24	BAGALKOTE	110	LINE	VAJJARAMATTI-BAGALKOT1	VAJJARAMATTI_220	07:26	07:41	00:15	TRIPPED ON FAULT
3110	21-Jul-24	BAGALKOTE	110	LINE	VAJJARAMATTI-BAGALKOT1	VAJJARAMATTI_220	09:05	15:20	06:15	TRIPPED ON FAULT
3111	21-Jul-24	BAGALKOTE	110	LINE	VAJJARAMATTI-BAGALKOT1	VAJJARAMATTI_220	16:27 (21.07.2024)			TRIPPED ON FAULT
3112	21-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1(XELDOM-1)	AMBEWADI_220	14:15 (21.07.2024)			TRIPPED ON FAULT
3113	21-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
3114	21-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI-1	BAGALKOT_220	11:17	15:25	04:08	LINE CLEAR AVAILED
3115	21-Jul-24	BAGALKOTE	220	LINE	KANAGALA-CHIKKODI2	KANAGALA_220	04:00	08:54	04:54	TRIPPED ON FAULT
3116	21-Jul-24	BAGALKOTE	220	LINE	KANAGALA-CHIKKODI2	KANAGALA_220	09:00	09:08	00:08	TRIPPED ON FAULT
3117	21-Jul-24	BAGALKOTE	220	LINE	SAVADATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
3118	21-Jul-24	BAGALKOTE	220	LINE	SIRSI220-SIRSI2	SIRS_220	13:03	13:11	00:08	TRIPPED ON FAULT
3119	21-Jul-24	BAGALKOTE	220	LINE	VAJJARAMATTI-MANTUR1	VAJJARAMATTI_220	06:13	06:30	00:17	TRIPPED ON FAULT
3120	21-Jul-24	BAGALKOTE	220	LINE	VAJJARAMATTI-MANTUR2	VAJJARAMATTI_220	06:13	06:30	00:17	TRIPPED ON FAULT
3121	21-Jul-24	BAGALKOTE	220	LINE	VAJJARMATTI-ENERCON SOLAR	VAJJARAMATTI_220	18:30	19:07	00:37	TRIPPED ON FAULT
3122	21-Jul-24	BANGALORE	66	LINE	66KV BIDADI 220 - TTIPL (EHT)	TTIPL(EHT)	09:56	18:44	08:48	LINE CLEAR AVAILED
3123	21-Jul-24	BANGALORE	66	LINE	66KV BIDADI 220 - TTIPL (EHT)	TTIPL(EHT)	18:47	18:59	00:12	TRIPPED ON FAULT
3124	21-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	14:52	15:23	00:31	MAIN SUPPLY FAILURE
3125	21-Jul-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	10:11	10:16	00:05	TRIPPED ON FAULT
3126	21-Jul-24	BANGALORE	66	LINE	66KV KGF - BEML (EHT)	BEML(EHT)	11:52	14:38	02:46	LINE CLEAR AVAILED
3127	21-Jul-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4	GRIDWELL NORTON	07:36	07:57	00:21	TRIPPED ON FAULT
3128	21-Jul-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA	12:28	12:38	00:10	LINE CLEAR AVAILED
3129	21-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, KUNDANA, BRIGADE ORCHIDS	10:30	11:40	01:10	LINE CLEAR AVAILED
3130	21-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI, KUNDANA, BRIGADE ORCHIDS	10:30	11:40	01:10	LINE CLEAR AVAILED
3131	21-Jul-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 1	SARAKKI	12:07	12:13	00:06	LINE CLEAR AVAILED
3132	21-Jul-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 2	SARAKKI	12:07	12:13	00:06	LINE CLEAR AVAILED
3133	21-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BUDIGERE	10:20	10:25	00:05	LINE CLEAR AVAILED
3134	21-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	14:52	15:30	00:38	MAIN SUPPLY FAILURE
3135	21-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GUDIBANDE	06:30	07:15	00:45	TRIPPED ON FAULT
3136	21-Jul-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	12:18	14:40	02:22	LINE CLEAR AVAILED
3137	21-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	14:52	15:30	00:38	MAIN SUPPLY FAILURE
3138	21-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HAROHALLI I/A 220	08:55	08:57	00:02	LINE CLEAR AVAILED
3139	21-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	17:15	17:40	00:25	LINE CLEAR AVAILED
3140	21-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	12:58	14:10	01:12	LINE CLEAR AVAILED
3141	21-Jul-24	BANGALORE	66	TRANSFORMER	HV3	ELECTRONIC CITY	11:00	11:03	00:03	LINE CLEAR AVAILED
3142	21-Jul-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	14:52	16:45	01:53	TRIPPED ON FAULT
3143	21-Jul-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	00:00	14:52	14:52	LINE CLEAR AVAILED
3144	21-Jul-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	CHANNAPATNA 220	14:47	15:18	00:31	TRIPPED ON FAULT
3145	21-Jul-24	BANGALORE	220	TRANSFORMER	HV1	CHANNAPATNA 220	14:52	15:25	00:33	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3146	21-Jul-24	GULBARGA	66	LINE	KUDALGI-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66, HUDEM_66	22:05	22:15	00:10	TRIPPED ON FAULT
3147	21-Jul-24	GULBARGA	110	TRANSFORMER	HV1	PD_HALLI_110	06:45	08:30	01:45	LINE CLEAR AVAILED
3148	21-Jul-24	GULBARGA	110	TRANSFORMER	HV1	WALKAMDINI_110	12:50	12:55	00:05	TRIPPED ON FAULT
3149	21-Jul-24	GULBARGA	110	LINE	KALBURGI SOUTH-FATHABAD	FARTHABAD_110	12:50	13:00	00:10	TRIPPED ON FAULT
3150	21-Jul-24	GULBARGA	110	LINE	KALBURGI SOUTH-FATHABAD	FARTHABAD_110	02:15	02:30	00:15	TRIPPED ON FAULT
3151	21-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANATHI	SANOTHI_110	03:27	03:47	00:20	TRIPPED ON FAULT
3152	21-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANATHI	SANOTHI_110	05:30	07:00	01:30	TRIPPED ON FAULT
3153	21-Jul-24	GULBARGA	110	LINE	KHANAPUR-WADAGERA	WADAGERA_110	02:05	02:17	00:12	TRIPPED ON FAULT
3154	21-Jul-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	04:48	04:56	00:08	TRIPPED ON FAULT
3155	21-Jul-24	GULBARGA	110	LINE	LINGASUGUR-KRPL_IPP	LINGASUGUR_220	04:59	05:18	00:19	TRIPPED ON FAULT
3156	21-Jul-24	GULBARGA	110	LINE	MALIYABAD-YEREGERA	YERAGERA_110	16:55	17:10	00:15	TRIPPED ON FAULT
3157	21-Jul-24	GULBARGA	110	LINE	MALLAT-ADAVIAMARESHWAR	ADAVIAMARESHWAR_110	21:34	21:40	00:06	MAIN SUPPLY FAILURE
3158	21-Jul-24	GULBARGA	110	LINE	MALLAT-ADAVIAMARESHWAR	ADAVIAMARESHWAR_110	23:33	23:38	00:05	MAIN SUPPLY FAILURE
3159	21-Jul-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110, GABUR_110	04:30	04:35	00:05	TRIPPED ON FAULT
3160	21-Jul-24	GULBARGA	110	LINE	YADGIR-KBJNL	YADGIR_110	05:30	08:00	02:30	TRIPPED ON FAULT
3161	21-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	04:50	04:55	00:05	TRIPPED ON FAULT
3162	21-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	04:50	05:00	00:10	TRIPPED ON FAULT
3163	21-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	09:14	17:30	08:16	LINE CLEAR AVAILED
3164	21-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
3165	21-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
3166	21-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3167	21-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:19	15:46	04:27	TRIPPED ON FAULT
3168	21-Jul-24	HASSAN	66	LINE	ALDUR-JENIGADDDE	ALDUR_66	11:20	15:48	04:28	MAIN SUPPLY FAILURE
3169	21-Jul-24	HASSAN	66	LINE	ALDUR-JENIGADDDE	ALDUR_66	17:20	19:41	02:21	TRIPPED ON FAULT
3170	21-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	11:20	15:44	04:24	MAIN SUPPLY FAILURE
3171	21-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	17:21	19:44	02:23	MAIN SUPPLY FAILURE
3172	21-Jul-24	HASSAN	66	LINE	BELUR66-HASSAN	BELUR_66	19:00	19:30	00:30	MAIN SUPPLY FAILURE
3173	21-Jul-24	HASSAN	66	LINE	BELUR66-MUDIGERE	BELUR_66	19:00	19:30	00:30	MAIN SUPPLY FAILURE
3174	21-Jul-24	HASSAN	66	LINE	GENDEHA-HASSAN	GENDEHALLI_66	19:00	19:35	00:35	MAIN SUPPLY FAILURE
3175	21-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	12:35	13:21	00:46	LINE CLEAR AVAILED
3176	21-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	19:00	19:35	00:35	MAIN SUPPLY FAILURE
3177	21-Jul-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	10:14	10:32	00:18	TRIPPED ON FAULT
3178	21-Jul-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPURA_220	07:13	07:23	00:10	TRIPPED ON FAULT
3179	21-Jul-24	HASSAN	66	TRANSFORMER	HV1	HADAVANAHALLI_66	13:12	13:32	00:20	LINE CLEAR AVAILED
3180	21-Jul-24	HASSAN	66	TRANSFORMER	HV2	HANGARAHALLI_66	02:42	03:00	00:18	TRIPPED ON FAULT
3181	21-Jul-24	HASSAN	66	LINE	LV1	HASSAN_220	00:37	03:37	03:00	TRIPPED ON FAULT
3182	21-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESH PURA_66	10:21	12:25	02:04	LINE CLEAR AVAILED
3183	21-Jul-24	HASSAN	66	LINE	UGANE-L2 CB	UGANE_66	19:00	19:20	00:20	MAIN SUPPLY FAILURE
3184	21-Jul-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	03:27	17:57	14:30	TRIPPED ON FAULT
3185	21-Jul-24	HASSAN	220	TRANSFORMER	HV1	HASSAN_220	00:37	03:37	03:00	TRIPPED ON FAULT
3186	21-Jul-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	13:50	14:10	00:20	TRIPPED ON FAULT
3187	21-Jul-24	MYSORE	66	TRANSFORMER	HV1	KITTUR_66	9:30 (21/07/2024)			TRIPPED ON FAULT
3188	21-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3189	21-Jul-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	07:25	07:46	00:20	TRIPPED ON FAULT
3190	21-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	20:01	20:17	00:15	TRIPPED ON FAULT
3191	21-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
3192	21-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220-EDCL IPP	NO STATIONS EFFECTED	11:36	13:35	01:59	TRIPPED ON FAULT
3193	21-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220-EDCL IPP	NO STATIONS EFFECTED	17:49	18:30	00:41	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3194	21-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
3195	21-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3196	21-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
3197	21-Jul-24	MYSORE	220	LINE	TUBINAKERE-BASTIPURA	NO STATIONS EFFECTED	10:26	20:45	10:19	LINE CLEAR AVAILED
3198	21-Jul-24	MYSORE	220	LINE	TUBINAKERE-CHANNAPATNA	NO STATIONS EFFECTED	08:47	20:26	11:39	TRIPPED ON FAULT
3199	21-Jul-24	MYSORE	220	LINE	TUBINAKERE-KOTHIPURA	NO STATIONS EFFECTED	16:29	20:22	03:53	LINE CLEAR AVAILED
3200	21-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3201	21-Jul-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV- WIPRO1	WIPRO_EHT	08:44	09:07	00:23	TRIPPED ON FAULT
3202	21-Jul-24	TUMKUR	66	LINE	BUKKAPATNA-SIRA	BUKKAPATNA_66	09:37	18:49	09:12	LINE CLEAR AVAILED
3203	21-Jul-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	00:48	00:54	00:06	TRIPPED ON FAULT
3204	21-Jul-24	TUMKUR	66	LINE	KEREBILCHE-SHYGALE	KEREBILCHI_66, SANTHEBENNUR_66	08:30	08:35	00:05	TRIPPED ON FAULT
3205	21-Jul-24	TUMKUR	66	LINE	SANTEBENNUR_66-KEREBILCHI LINE	KEREBILCHI_66,SHYGALE_66	08:30	08:35	00:05	TRIPPED ON FAULT
3206	21-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 & TR-2 ,12.5MVA ANCHEPALYA_66	ANCHEPALYA_66	15:05	15:40	00:35	LINE CLEAR AVAILED
3207	21-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
3208	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	11:10	11:35	00:25	LINE CLEAR AVAILED
3209	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	PH COMPOUND_110	13:57	15:36	01:39	TRIPPED ON FAULT
3210	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SULTANPUR_110	14:01	15:00	00:59	LINE CLEAR AVAILED
3211	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YELPHARATTI_110	16:30	17:05	00:35	LINE CLEAR AVAILED
3212	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	13:00	13:02	00:02	TRIPPED ON FAULT
3213	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	PG HUNSHYAL_110	14:25	16:05	01:40	LINE CLEAR AVAILED
3214	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	YELPHARATTI_110	11:08	12:11	01:03	LINE CLEAR AVAILED
3215	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA-HV1)	UCHAGOAN_110	16:35	17:31	00:56	LINE CLEAR AVAILED
3216	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2A(10MVA)	JAMAKHANDI_110	10:45	11:35	00:50	LINE CLEAR AVAILED
3217	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	CHIKKODI_110	21:45	22:01	00:16	TRIPPED ON FAULT
3218	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	CHIKKODI_110	22:04	22:17	00:13	TRIPPED ON FAULT
3219	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GAJENDRAGAD_110	14:38	14:51	00:13	TRIPPED ON FAULT
3220	22-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GAJENDRAGAD_110	17:34	17:42	00:08	TRIPPED ON FAULT
3221	22-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK 2(KAVALWADA)	AMBEWADI_220	18:30 (13.07.2024)	21:02 (22.07.2024)	218:32:00	TRIPPED ON FAULT
3222	22-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA1	AMBEWADI_220	12:17	13:45	01:28	TRIPPED ON FAULT
3223	22-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	11:43	12:47	01:04	TRIPPED ON FAULT
3224	22-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	18:36	20:43	02:07	TRIPPED ON FAULT
3225	22-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	20:57 (22.07.2024)			TRIPPED ON FAULT
3226	22-Jul-24	BAGALKOTE	110	LINE	BAGALKOT220-F1-BAGALKOT1	BAGALKOT_220	13:10	16:00	02:50	LINE CLEAR AVAILED
3227	22-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3228	22-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
3229	22-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR220- HIREKERUR	RANEBENNUR_220	21:19	21:28	00:09	TRIPPED ON FAULT
3230	22-Jul-24	BAGALKOTE	110	LINE	SIRSI220- SIRSI2	SIRSI_220	12:38	12:45	00:07	TRIPPED ON FAULT
3231	22-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3232	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1(XELDOM-1)	AMBEWADI_220	14:15 (21.07.2024)	16:14 (22.07.2024)	25:59:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3233	22-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
3234	22-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
3235	22-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	AMBEWADI_220	12:12	12:52	00:40	LINE CLEAR AVAILED
3236	22-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KUDACHI_220	13:30	14:15	00:45	LINE CLEAR AVAILED
3237	22-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	SIRSI_220	12:38	12:45	00:07	TRIPPED ON FAULT
3238	22-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	AMBEWADI_220	08:13	08:15:00	00:02	LINE CLEAR AVAILED
3239	22-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	AMBEWADI_220	11:04	11:59	00:55	LINE CLEAR AVAILED
3240	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	AMBEWADI_220	12:25	14:11	01:46	TRIPPED ON FAULT
3241	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	AMBEWADI_220	10:43	14:14	03:31	LINE CLEAR AVAILED
3242	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA1	AMBEWADI_220	12:12	12:51	00:39	LINE CLEAR AVAILED
3243	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA2	AMBEWADI_220	08:10	08:19	00:09	LINE CLEAR AVAILED
3244	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA2	AMBEWADI_220	11:10	11:50	00:40	LINE CLEAR AVAILED
3245	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA2	AMBEWADI_220	11:08	12:54	01:46	LINE CLEAR AVAILED
3246	22-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA2	AMBEWADI_220	11:09	12:54	01:45	LINE CLEAR AVAILED
3247	22-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI1	BAGALKOT_220	11:52	20:02	08:10	LINE CLEAR AVAILED
3248	22-Jul-24	BAGALKOTE	220	LINE	BELGAUM220- KANABARGI2	BELGAUM_220	11:39	17:57	06:18	LINE CLEAR AVAILED
3249	22-Jul-24	BAGALKOTE	220	LINE	BELGAUM220- KANABARGI2	BELGAUM_220	18:22	19:07	00:45	LINE CLEAR AVAILED
3250	22-Jul-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI1	HUBLI_220	16:04	18:46	02:42	LINE CLEAR AVAILED
3251	22-Jul-24	BAGALKOTE	220	LINE	HUBLI- NAGJHARI2	HUBLI_220	13:05	18:46	05:41	LINE CLEAR AVAILED
3252	22-Jul-24	BAGALKOTE	220	LINE	HUBLI- SIRSI1	HUBLI_220	12:56	19:42	06:46	TRIPPED ON FAULT
3253	22-Jul-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	HUBLI_220	09:52	16:58	07:06	LINE CLEAR AVAILED
3254	22-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	13:02	16:46	03:44	TRIPPED ON FAULT
3255	22-Jul-24	BAGALKOTE	220	LINE	VAJJARAMATTI-BAGALKOT1	VAJJARAMATTI_220	16:27 (21.07.2024)	20:10 (22.07.2024)	27:43:00	TRIPPED ON FAULT
3256	22-Jul-24	BANGALORE	66	LINE	66KV ADUGODI - JAKKASANDRA	ADUGODI	18:04	18:08	00:04	LINE CLEAR AVAILED
3257	22-Jul-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	05:45	06:58	01:13	MAIN SUPPLY FAILURE
3258	22-Jul-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	13:19	13:33	00:14	LINE CLEAR AVAILED
3259	22-Jul-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGAR	VIDYANAGARA	09:10	09:15	00:05	LINE CLEAR AVAILED
3260	22-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, Y HUNSENAHALLI	05:50	06:00	00:10	TRIPPED ON FAULT
3261	22-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	08:49	08:57	00:08	TRIPPED ON FAULT
3262	22-Jul-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	04:43	06:00	01:17	TRIPPED ON FAULT
3263	22-Jul-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	ADUGODI	11:23	11:31	00:08	LINE CLEAR AVAILED
3264	22-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - RANGANADODDI - SOMANAHALLI	NO STATION AFFECTED	15:00	15:20	00:20	TRIPPED ON FAULT
3265	22-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE, DODDERI	10:25	11:05	00:40	MAIN SUPPLY FAILURE
3266	22-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	10:23	11:05	00:42	TRIPPED ON FAULT
3267	22-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	10:55	10:59	00:04	LINE CLEAR AVAILED
3268	22-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PADMANABHANAGAR - AREHALLI	AREHALLI, BANASHANKARI	11:02	11:09	00:07	TRIPPED ON FAULT
3269	22-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	10:22	10:40	00:18	TRIPPED ON FAULT
3270	22-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	10:23	11:10	00:47	TRIPPED ON FAULT
3271	22-Jul-24	BANGALORE	66	LINE	66KV YENNIGADALE - SOMANATHAPURA - CHELUR	CHELUR, CHAKAVELU	05:48	06:03	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3272	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BAGGANADODDI	11:55	14:55	03:00	LINE CLEAR AVAILED
3273	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GOLLAHALLI	11:15	11:51	00:36	LINE CLEAR AVAILED
3274	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HEJJALA	22:20	22:25	00:05	TRIPPED ON FAULT
3275	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HEJJALA	22:50	22:55	00:05	TRIPPED ON FAULT
3276	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	08:30	08:45	00:15	TRIPPED ON FAULT
3277	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TYAMAGONDLU	12:52	13:02	00:10	TRIPPED ON FAULT
3278	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TYAMAGONDLU	18:32	18:42	00:10	TRIPPED ON FAULT
3279	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIDURASHWATHA	14:30	14:35	00:05	TRIPPED ON FAULT
3280	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIDURASHWATHA	15:40	15:50	00:10	TRIPPED ON FAULT
3281	22-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIDURASHWATHA	23:00	23:10	00:10	TRIPPED ON FAULT
3282	22-Jul-24	BANGALORE	66	TRANSFORMER	HV2	K & C VALLEY	15:01	15:04	00:03	LINE CLEAR AVAILED
3283	22-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANASAWADI	12:45	12:50	00:05	LINE CLEAR AVAILED
3284	22-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	19:48	20:00	00:12	TRIPPED ON FAULT
3285	22-Jul-24	BANGALORE	66	TRANSFORMER	HV2	THAYALUR	07:20	08:14	00:54	TRIPPED ON FAULT
3286	22-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	00:57	01:05	00:08	LINE CLEAR AVAILED
3287	22-Jul-24	BANGALORE	220	LINE	220KV HOODY 220 - BIAL BEGUR 220	NO STATION AFFECTED	12:01	12:53	00:52	TRIPPED ON FAULT
3288	22-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	NO STATION AFFECTED	04:52	23:59	19:07	TRIPPED ON FAULT
3289	22-Jul-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGI	BENNEHALLI_66	11:50	12:05	00:15	MAIN SUPPLY FAILURE
3290	22-Jul-24	GULBARGA	66	LINE	CJ.HAHALLI-HOSAHALLI	HOSAHALLI_66,HUDEM	11:50	12:05	00:15	TRIPPED ON FAULT
3291	22-Jul-24	GULBARGA	66	LINE	CJ.HALLI-BADALADUKU	CJ.HALLI_66,HOSAHALLI_66 AND HUDEM	11:50	12:05	00:15	TRIPPED ON FAULT
3292	22-Jul-24	GULBARGA	66	LINE	CJ.HALLI-BADALADUKU	CJ.HALLI_66,HOSAHALLI_66 AND HUDEM	12:20	13:20	01:00	TRIPPED ON FAULT
3293	22-Jul-24	GULBARGA	66	LINE	CJ.HALLI-BANAVIKAL	BANVEKAL_66	11:50	12:05	00:15	TRIPPED ON FAULT
3294	22-Jul-24	GULBARGA	66	LINE	CJ.HALLI-HUDEM	HUDEM	11:50	12:05	00:15	TRIPPED ON FAULT
3295	22-Jul-24	GULBARGA	66	TRANSFORMER	HV1	TELGI_66	15:30	15:35	00:05	TRIPPED ON FAULT
3296	22-Jul-24	GULBARGA	66	LINE	MUNIRABAD-CHILAKANAHATTI	CHILAKNAHATTI_66,HANASI_66	14:08	15:30	01:22	TRIPPED ON FAULT
3297	22-Jul-24	GULBARGA	66	LINE	NEELGUNDA-H P HALLI	H P HALLI_66	12:22	12:39	00:17	MAIN SUPPLY FAILURE
3298	22-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66, KNNL NITTUR WATER LINE	12:22	12:39	00:17	MAIN SUPPLY FAILURE
3299	22-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66, KNNL NITTUR WATER LINE	14:10	14:18	00:08	TRIPPED ON FAULT
3300	22-Jul-24	GULBARGA	66	LINE	NEELGUNDA-HALAVAGALU	HALAVAGALU_66, HARVI_66, KNNL NITTUR WATER LINE	14:18	21:45	07:27	LINE CLEAR AVAILED
3301	22-Jul-24	GULBARGA	66	LINE	NEELGUNDA-TELGI	TELGI_66, OBJ HALLI_66, KURUBANAHALLI_66	12:22	12:39	00:17	MAIN SUPPLY FAILURE
3302	22-Jul-24	GULBARGA	66	LINE	UJJINI-BADALADUKU	UJJINI_66	11:50	12:05	00:15	MAIN SUPPLY FAILURE
3303	22-Jul-24	GULBARGA	110	LINE	BIDWAL WIND_IPP-MALIYABAD	MALIYABAD_110	02:55	03:05	00:10	TRIPPED ON FAULT
3304	22-Jul-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	05:38	05:43	00:05	TRIPPED ON FAULT
3305	22-Jul-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	MANVI_110	12:00	12:16	00:16	TRIPPED ON FAULT
3306	22-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	03:26	03:34	00:08	TRIPPED ON FAULT
3307	22-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	05:35	05:50	00:15	TRIPPED ON FAULT
3308	22-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	23:55	23:59	00:04	TRIPPED ON FAULT
3309	22-Jul-24	GULBARGA	110	LINE	MALLAT-ADAVI AMARESHWAR	ADAVI ADAVAIAMARESHWAR_110	11:10	11:26	00:16	MAIN SUPPLY FAILURE
3310	22-Jul-24	GULBARGA	110	LINE	MALLAT-BYGWAT	BYGWAT_110,WALKAMDINI_110	11:10	11:45	00:35	MAIN SUPPLY FAILURE
3311	22-Jul-24	GULBARGA	110	LINE	MALLAT-WALKAMDINI	WALKAMDINI_110	11:10	11:40	00:30	MAIN SUPPLY FAILURE
3312	22-Jul-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI-2	CHINCHOLI_110	04:03	04:35	00:32	TRIPPED ON FAULT
3313	22-Jul-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI-2	CHINCHOLI_110	05:34	06:30	00:56	TRIPPED ON FAULT
3314	22-Jul-24	GULBARGA	110	LINE	SEDAM-MRT	MRT	15:40	17:14	01:34	LINE CLEAR AVAILED
3315	22-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR3	SINDHANOOR_110	11:00	13:35	02:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3316	22-Jul-24	GULBARGA	220	TRANSFORMER	HV1 & HV2	ITTAGI_220	11:53	12:04	00:11	TRIPPED ON FAULT
3317	22-Jul-24	GULBARGA	220	LINE	ITTAGI-LINGAPUR	ITTAGI_220	12:22	12:35	00:13	TRIPPED ON FAULT
3318	22-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
3319	22-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
3320	22-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3321	22-Jul-24	GULBARGA	220	LINE	SINDHANOOR-SULEKAL	SINDHANOOR_220	16:38	18:10	01:32	LINE CLEAR AVAILED
3322	22-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	13:45	16:15	02:30	LINE CLEAR AVAILED
3323	22-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:24(22.07.2024)			TRIPPED ON FAULT
3324	22-Jul-24	HASSAN	66	LINE	BALEHNR-ALDUR	BALEHONNUR_66	9:24(22.07.2024)			MAIN SUPPLY FAILURE
3325	22-Jul-24	HASSAN	66	LINE	BELUR66-HASSAN	BELUR_66	12:25	12:45	00:20	MAIN SUPPLY FAILURE
3326	22-Jul-24	HASSAN	66	LINE	GENDEHA-MUDIGERE	GENDEHALLI_66	12:22	14:30	02:08	TRIPPED ON FAULT
3327	22-Jul-24	HASSAN	66	LINE	HASSN22-SKPURA	HASSAN_220	14:59	17:06	02:07	LINE CLEAR AVAILED
3328	22-Jul-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	13:45	18:02	04:17	MAIN SUPPLY FAILURE
3329	22-Jul-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	11:55	14:20	02:25	LINE CLEAR AVAILED
3330	22-Jul-24	HASSAN	66	TRANSFORMER	HV1 CB	UGANE_66	12:25	12:55	00:30	MAIN SUPPLY FAILURE
3331	22-Jul-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	11:55	14:20	02:25	LINE CLEAR AVAILED
3332	22-Jul-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	14:30	15:37	01:07	LINE CLEAR AVAILED
3333	22-Jul-24	HASSAN	66	LINE	LV1	HASSAN_220	20:43	22:02	01:19	TRIPPED ON FAULT
3334	22-Jul-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	16:40	18:01	01:21	LINE CLEAR AVAILED
3335	22-Jul-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	11:55	14:20	02:25	LINE CLEAR AVAILED
3336	22-Jul-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	11:55	14:20	02:25	LINE CLEAR AVAILED
3337	22-Jul-24	HASSAN	66	LINE	UGANE-L2 CB	UGANE_66	12:25	12:55	00:30	MAIN SUPPLY FAILURE
3338	22-Jul-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	18:19	18:30	00:11	TRIPPED ON FAULT
3339	22-Jul-24	HASSAN	110	TRANSFORMER	HV1	SHIVAPURA_66	13:15	14:35	01:20	LINE CLEAR AVAILED
3340	22-Jul-24	HASSAN	110	TRANSFORMER	HV2	GANDASI_110	11:03	11:18	00:15	LINE CLEAR AVAILED
3341	22-Jul-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	05:58	15:51	09:53	TRIPPED ON FAULT
3342	22-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	12:17	13:03	00:46	LINE CLEAR AVAILED
3343	22-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	15:09	15:25	00:16	TRIPPED ON FAULT
3344	22-Jul-24	HASSAN	110	LINE	JOG-NK1	ggen_mghe	12:32	12:51	00:19	TRIPPED ON FAULT
3345	22-Jul-24	HASSAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	12:35	12:44	00:09	TRIPPED ON FAULT
3346	22-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA-110	10:12	13:58	03:46	LINE CLEAR AVAILED
3347	22-Jul-24	HASSAN	110	LINE	LV1	KEMAR_220	15:17	16:23	01:06	TRIPPED ON FAULT
3348	22-Jul-24	HASSAN	220	LINE	CKAVR3	KEMAR_220	11:00	13:17	02:17	LINE CLEAR AVAILED
3349	22-Jul-24	HASSAN	220	TRANSFORMER	HV1	HASSAN_220	20:43	22:02	01:19	TRIPPED ON FAULT
3350	22-Jul-24	HASSAN	220	TRANSFORMER	HV1	KEMAR_220	15:17	16:23	01:06	TRIPPED ON FAULT
3351	22-Jul-24	HASSAN	220	LINE	KAVOOR-KEMAR3	KAVOOR_220	10:59	13:17	02:18	LINE CLEAR AVAILED
3352	22-Jul-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	15:21	17:27	02:06	TRIPPED ON FAULT
3353	22-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	15:21	17:27	02:06	TRIPPED ON FAULT
3354	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	CHIKKA_MANDYA_66	10:37	12:45	02:08	LINE CLEAR AVAILED
3355	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	KALAMANDIRA_66	10:30	12:59	02:29	LINE CLEAR AVAILED
3356	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	KITTUR_66	9:30 (21/07/2024)	16:49 (22/07/2024)	31:19 HRs	TRIPPED ON FAULT
3357	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	KUSHALNAGARA_220	01:28	02:58	01:30	LINE CLEAR AVAILED
3358	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3359	22-Jul-24	MYSORE	66	TRANSFORMER	HV1	SINDHUVALLI_66	11:05	11:15	00:10	TRIPPED ON FAULT
3360	22-Jul-24	MYSORE	66	TRANSFORMER	HV2	CHIKKA_MANDYA_66	12:42	15:40	02:58	LINE CLEAR AVAILED
3361	22-Jul-24	MYSORE	66	TRANSFORMER	HV2	KALAMANDIRA_66	13:11	14:47	01:36	LINE CLEAR AVAILED
3362	22-Jul-24	MYSORE	66	TRANSFORMER	HV2	KITTUR_66	14:00	14:16	00:16	LINE CLEAR AVAILED
3363	22-Jul-24	MYSORE	66	LINE	KADAKOLA-DOORA	DOORA_66	13:37	16:45	03:08	LINE CLEAR AVAILED
3364	22-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3365	22-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
3366	22-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	12:14	13:10	00:56	LINE CLEAR AVAILED
3367	22-Jul-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	01:10	01:15	00:05	TRIPPED ON FAULT
3368	22-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-DODDINADUWADI	NO STATIONS EFFECTED	10:29	13:20	02:51	LINE CLEAR AVAILED
3369	22-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3370	22-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
3371	22-Jul-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	18:34 (22/07/2024)			TRIPPED ON FAULT
3372	22-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	GUDDENAHALLI_66	10:20	14:45	04:25	LINE CLEAR AVAILED
3373	22-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-NAGAMANGALA 2	NO STATIONS EFFECTED	10:15	14:45	04:30	LINE CLEAR AVAILED
3374	22-Jul-24	MYSORE	220	LINE	HUNSUR 220-BASTIPURA 2	NO STATIONS EFFECTED	09:19	20:12	10:53	LINE CLEAR AVAILED
3375	22-Jul-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	08:57	20:37	11:39	LINE CLEAR AVAILED
3376	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR2	CHITRAHALLI_66	10:25	10:32	0:07	TRIPPED ON FAULT
3377	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1	HALURAMESWARA_66	14:30	14:40	0:10	TRIPPED ON FAULT
3378	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1	MYLANAHALLI_66	13:40	13:56	0:16	TRIPPED ON FAULT
3379	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1	TYAVANAGI_66	15:06	15:33	0:27	LINE CLEAR AVAILED
3380	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1 & TR-2 ANCHEPALYA_66	ANCHEPALYA_66	11:05	13:20	2:15	LINE CLEAR AVAILED
3381	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	HALURAMESWARA_66	12:30	13:55	1:25	LINE CLEAR AVAILED
3382	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	KUKKAWADA_66	21:04	21:08	0:04	TRIPPED ON FAULT
3383	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	KUKKAWADA_66	21:50	21:55	0:05	TRIPPED ON FAULT
3384	22-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	TMTP_66	12:25	15:15	2:50	TRIPPED ON FAULT
3385	22-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3386	22-Jul-24	TUMKUR	66	TRANSFORMER	8MVA TR-1	CHITRAHALLI_66	12:21	12:36	0:15	TRIPPED ON FAULT
3387	22-Jul-24	TUMKUR	66	TRANSFORMER	8MVA TR-1	KATTIGE_66	12:34	13:00	0:26	LINE CLEAR AVAILED
3388	22-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220- HEBBUR	HEBBUR_66, HONNENAHALLI_66, THIMMASANDRA_66	07:45	16:39	8:54	LINE CLEAR AVAILED
3389	22-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220kv- KUNIGAL	KUNIGAL_66	11:28	13:32	2:04	LINE CLEAR AVAILED
3390	22-Jul-24	TUMKUR	66	LINE	ANCHEPALYA_66-BHAKTRAHALLI	BHAKTRAHALLI_66	07:55	14:40	6:45	LINE CLEAR AVAILED
3391	22-Jul-24	TUMKUR	66	LINE	BRAMASANDRA_66-SIRA_66	BRAMASANDRA_66	12:02	12:41	0:39	LINE CLEAR AVAILED
3392	22-Jul-24	TUMKUR	66	LINE	BRAMASANDRA_66-SIRA_66	BRAMASANDRA_66	17:43	17:50	0:07	LINE CLEAR AVAILED
3393	22-Jul-24	TUMKUR	66	LINE	CHITRADURGA 220kv- PANDARAHALLI 2	CHITRAHALLI_66, H D PURA_66	14:34	15:01	0:27	TRIPPED ON FAULT
3394	22-Jul-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	20:18	20:27	0:09	TRIPPED ON FAULT
3395	22-Jul-24	TUMKUR	66	LINE	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASUDI,K.R.HALLI	14:42 (22.07.24)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3396	22-Jul-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	14:13	14:23	0:10	TRIPPED ON FAULT
3397	22-Jul-24	TUMKUR	66	LINE	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	14:09	14:19	0:10	TRIPPED ON FAULT
3398	22-Jul-24	TUMKUR	66	LINE	MELEKOTE-BADDIHALLI	BADDIHALLI_66	11:54	12:10	0:16	TRIPPED ON FAULT
3399	22-Jul-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	09:00	18:39	9:39	LINE CLEAR AVAILED
3400	22-Jul-24	TUMKUR	66	LINE	SIRA220-SIRA 1, 2 & 3	SIRA_66,KALLAMBELLA_66	11:47	17:30	5:43	LINE CLEAR AVAILED
3401	22-Jul-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	11:50	12:05	0:15	MAIN SUPPLY FAILURE
3402	22-Jul-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	12:20	14:15	1:55	MAIN SUPPLY FAILURE
3403	22-Jul-24	TUMKUR	66	LINE	THALLAK 220kv - BARC 1	BARC 1	12:04	12:23	0:19	LINE CLEAR AVAILED
3404	22-Jul-24	TUMKUR	66	LINE	THALLAK 220kv -HIRIYUR	THALLAKK_220	12:30	12:37	0:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3405	22-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
3406	22-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-1	THALLAK_220	11:46	12:40	0:54	MAIN SUPPLY FAILURE
3407	22-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-2	ANCHEPALYA_220	05:44	06:53	1:09	TRIPPED ON FAULT
3408	22-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-2	ANCHEPALYA_220	13:12	13:32	0:20	TRIPPED ON FAULT
3409	22-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-2	THALLAK_220	11:46	12:38	0:52	MAIN SUPPLY FAILURE
3410	22-Jul-24	TUMKUR	220	LINE	CHITRADURGA_220-PGCL LINE	J N KOTE,H D PURA, HOLALKERE,CHIKKAJAJUR,CHITRA HALLI,PANDARAHALLI,MALLAPANA HALLI,AIMANGALA,JAGALUR,BIDAR KERE,TURUVANUR,SIRIGERE,BHA RAMSAGERA,HIREGUNTANUR,MAD ANAYAKANAHALLI,VIJAPURA	11:47	13:18	1:31	TRIPPED ON FAULT
3411	22-Jul-24	TUMKUR	220	LINE	GUTTUR 400- CHITRADURGA 220	J N KOTE,H D PURA, HOLALKERE,CHIKKAJAJUR,CHITRA HALLI,PANDARAHALLI,MALLAPANA HALLI,AIMANGALA,JAGALUR,BIDAR KERE,TURUVANUR,SIRIGERE,BHA RAMSAGERA,HIREGUNTANUR,MAD ANAYAKANAHALLI,VIJAPURA	11:49	12:09	0:20	TRIPPED ON FAULT
3412	22-Jul-24	TUMKUR	220	LINE	GUTTUR 400- CHITRADURGA 220	J N KOTE,H D PURA, HOLALKERE,CHIKKAJAJUR,CHITRA HALLI,PANDARAHALLI,MALLAPANA HALLI,AIMANGALA,JAGALUR,BIDAR KERE,TURUVANUR,SIRIGERE,BHA RAMSAGERA,HIREGUNTANUR,MAD ANAYAKANAHALLI,VIJAPURA	12:20	12:38	0:18	TRIPPED ON FAULT
3413	22-Jul-24	TUMKUR	220	LINE	THALLAK 220kV -HIRIYUR	SAGITAU,SEI VENUS,IMOND_66, CHALLAKERE,MYLANAHALLI, VV PURA, DYAVARANAHALLI, THALLAK, GOWRASAMUDRA, KONASAGARA ,B G KERE, HANGAL,NAGASAMUDRA, RAMPURA,NAYAKANAHATTI, NERLAGUNTE,HM HOLE, WELSPUN	11:46	12:19	0:33	TRIPPED ON FAULT
3414	22-Jul-24	TUMKUR	220	LINE	THALLAK 220kV-CHITRADURGA _220	SAGITAU,SEI VENUS,IMOND_66, CHALLAKERE,MYLANAHALLI, VV PURA, DYAVARANAHALLI, THALLAK, GOWRASAMUDRA, KONASAGARA ,B G KERE, HANGAL,NAGASAMUDRA, RAMPURA,NAYAKANAHATTI, NERLAGUNTE,HM HOLE, WELSPUN	11:46	13:14	1:28	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3415	22-Jul-24	TUMKUR	220	LINE	THALLAK_220-SAGITAU LINE 1 & 2	SAGITAU,SEI VENUS,IMOND_66, CHALLAKERE,MYLANAHALLI, VV PURA, DYAVARANAHALLI, THALLAK, GOWRASAMUDRA, KONASAGARA ,B G KERE, HANGAL,NAGASAMUDRA, RAMPURA,NAYAKANAHATTI, NERLAGUNTE,HM HOLE, WELSPUN	11:46	13:01	1:15	TRIPPED ON FAULT
3416	22-Jul-24	TUMKUR	400	LINE	500MVA ICT 1 & 2	JAGALUR_400	11:45	12:59	1:14	TRIPPED ON FAULT
3417	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV1(10MVA)	GANESHGUDI_110	12:29	12:35	0:06	TRIPPED ON FAULT
3418	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV1(10MVA)	GANESHGUDI_110	12:35	13:36	1:01	LINE CLEAR AVAILED
3419	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV1(20MVA)	RAIBAG_110	7:13	7:30	0:17	TRIPPED ON FAULT
3420	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV2(10MVA)	KUDUCHI_220	05:20	06:45	1:25	TRIPPED ON FAULT
3421	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV2(10MVA)	KUDUCHI_220	08:20	08:35	0:15	TRIPPED ON FAULT
3422	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV2(10MVA)	KUDUCHI_220	08:45	13:25	4:40	TRIPPED ON FAULT
3423	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV ,HV2(10MVA)	KUDUCHI_220	13:50	18:10	4:20	TRIPPED ON FAULT
3424	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	RAIBAG_110	07:13	07:30	00:17	TRIPPED ON FAULT
3425	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	AMBEWADI_220	09:39	09:46	0:07	TRIPPED ON FAULT
3426	23-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	AMBEWADI_220	09:39	09:46	0:07	TRIPPED ON FAULT
3427	23-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	20:57 (22.07.2024)	15:16 (23.07.2024)	18:19:00	TRIPPED ON FAULT
3428	23-Jul-24	BAGALKOTE	110	LINE	ANMOD-SUPA2	ANMOD_110	23:40	00:05	0:05	TRIPPED ON FAULT
3429	23-Jul-24	BAGALKOTE	110	LINE	ITNAL-HIDKAL(MUGALKHOD3)	ITNAL_110	02:26	02:42	00:16	TRIPPED ON FAULT
3430	23-Jul-24	BAGALKOTE	110	LINE	KUDUCHI220-SHIRAGUPPI	KUDUCHI_220	20:15	20:35	0:20	TRIPPED ON FAULT
3431	23-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3432	23-Jul-24	BAGALKOTE	110	LINE	MRUTYUNJAYNAGAR-NARENDRA	MRUTYUNJAYNAGAR_110	10:57	14:35	03:38	LINE CLEAR AVAILED
3433	23-Jul-24	BAGALKOTE	110	LINE	MUGALAKHOD- ITNAL-3	MUGALAKHOD_220	02:26	02:42	0:16	TRIPPED ON FAULT
3434	23-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
3435	23-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMATA 2	KUMATA_110	07:41	07:56	00:15	TRIPPED ON FAULT
3436	23-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3437	23-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
3438	23-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
3439	23-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI_220	18:23 (23.07.2024)			TRIPPED ON FAULT
3440	23-Jul-24	BAGALKOTE	220	LINE	AMBEWAD-NAGJHARI2	AMBEWADI_220	9:28	14:14	4:46	LINE CLEAR AVAILED
3441	23-Jul-24	BAGALKOTE	220	LINE	KANAGALA-CHIKKODI2	KANAGALA_220	04:37	06:02	1:25	TRIPPED ON FAULT
3442	23-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	13:17	13:39	00:22	MAIN SUPPLY FAILURE
3443	23-Jul-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	CHIKKENAHALLI, SHIVANAHALLI, ALLIMARADANAHALLI	10:16	10:26	00:10	TRIPPED ON FAULT
3444	23-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA	10:00	10:15	00:15	LINE CLEAR AVAILED
3445	23-Jul-24	BANGALORE	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY, HULIMANGALA	15:10	15:35	00:25	MAIN SUPPLY FAILURE
3446	23-Jul-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGEHALLI, ID HALLI	11:25	11:35	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3447	23-Jul-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4	VIDYANAGARA	16:00	16:03	00:03	LINE CLEAR AVAILED
3448	23-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	06:15	06:19	00:04	LINE CLEAR AVAILED
3449	23-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO	10:40	10:44	00:04	LINE CLEAR AVAILED
3450	23-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO	15:06	15:10	00:04	LINE CLEAR AVAILED
3451	23-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	05:49	06:09	00:20	TRIPPED ON FAULT
3452	23-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	18:11	18:17	00:06	LINE CLEAR AVAILED
3453	23-Jul-24	BANGALORE	66	LINE	66KV VIJAYAPURA - JANGAMKOTE - MELUR	JANGAMKOTE	13:05	13:17	00:12	LINE CLEAR AVAILED
3454	23-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON, BOMMASANDRA	09:40	10:10	00:30	TRIPPED ON FAULT
3455	23-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BIOCON, BOMMASANDRA, ELECTRONIC CITY, HULIMANGALA	15:56	16:18	00:22	TRIPPED ON FAULT
3456	23-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	BIOCON, BOMMASANDRA,	13:05	14:42	01:37	LINE CLEAR AVAILED
3457	23-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA	12:28	13:36	01:08	LINE CLEAR AVAILED
3458	23-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA	15:54	16:19	00:25	MAIN SUPPLY FAILURE
3459	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHAKAVELU	14:00	14:02	00:02	LINE CLEAR AVAILED
3460	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	13:17	13:40	00:23	MAIN SUPPLY FAILURE
3461	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDAKARI	16:40	16:45	00:05	LINE CLEAR AVAILED
3462	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	16:14	16:34	00:20	TRIPPED ON FAULT
3463	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SADALI	09:40	09:50	00:10	TRIPPED ON FAULT
3464	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	12:05	12:09	00:04	LINE CLEAR AVAILED
3465	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	14:50	15:09	00:19	TRIPPED ON FAULT
3466	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	12:18	12:48	00:30	LINE CLEAR AVAILED
3467	23-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	12:18	12:48	00:30	LINE CLEAR AVAILED
3468	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHAKAVELU	14:30	14:32	00:02	LINE CLEAR AVAILED
3469	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	13:17	13:40	00:23	MAIN SUPPLY FAILURE
3470	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DODDAKARI	15:40	16:40	01:00	LINE CLEAR AVAILED
3471	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	11:05	12:15	01:10	LINE CLEAR AVAILED
3472	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANDAGUDI	01:32	01:42	00:10	TRIPPED ON FAULT
3473	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANDAGUDI	11:47	11:57	00:10	TRIPPED ON FAULT
3474	23-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	15:14	15:15	00:01	LINE CLEAR AVAILED
3475	23-Jul-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	CHANNAPATNA 220	13:17	13:34	00:17	TRIPPED ON FAULT
3476	23-Jul-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - EKARAJPURA 1	NO STATION AFFECTED	16:28	16:50	00:22	MAIN SUPPLY FAILURE
3477	23-Jul-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	CHANNAPATNA 220	13:12	13:33	00:21	TRIPPED ON FAULT
3478	23-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3479	23-Jul-24	BANGALORE	220	TRANSFORMER	HV1	CHANNAPATNA 220	13:17	13:38	00:21	MAIN SUPPLY FAILURE
3480	23-Jul-24	BANGALORE	220	TRANSFORMER	HV1	MITTEMARI 220	13:28	13:38	00:10	TRIPPED ON FAULT
3481	23-Jul-24	GULBARGA	66	TRANSFORMER	HV1	H P HALLI_66	22:30	22:35	00:05	TRIPPED ON FAULT
3482	23-Jul-24	GULBARGA	66	TRANSFORMER	HV3	HALAVAGALU_66	11:05	11:10	00:05	TRIPPED ON FAULT
3483	23-Jul-24	GULBARGA	66	TRANSFORMER	HV3	HALAVAGALU_66	13:25	13:30	00:05	TRIPPED ON FAULT
3484	23-Jul-24	GULBARGA	110	LINE	HALBARGA-CHIDRI	CHIDRI_110	23:40	23:50	00:10	TRIPPED ON FAULT
3485	23-Jul-24	GULBARGA	110	TRANSFORMER	HV3	CHICKSUGUR_110	16:05	16:11	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3486	23-Jul-24	GULBARGA	110	LINE	JAWALGERA-VALABALLARI	VALABALLARY_110	09:02	13:31	04:29	LINE CLEAR AVAILED
3487	23-Jul-24	GULBARGA	110	LINE	KADECHUR-SANOTHI	KADECHUR_110	16:11	17:07	00:56	LINE CLEAR AVAILED
3488	23-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KAHANAPUR_110	03:48	03:58	00:10	TRIPPED ON FAULT
3489	23-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR3	SINDHANOOR_110	11:10	13:31	02:21	LINE CLEAR AVAILED
3490	23-Jul-24	GULBARGA	110	LINE	WALKAMDINI-SINDHANUR	WALKAMDINI_110	09:25	13:35	04:10	LINE CLEAR AVAILED
3491	23-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:50	23:59	18:09	TRIPPED ON FAULT
3492	23-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:52	06:02	00:10	TRIPPED ON FAULT
3493	23-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	11:18	18:40	07:22	TRIPPED ON FAULT
3494	23-Jul-24	GULBARGA	220	TRANSFORMER	HV1	SHAHAPUR_220	12:18	17:43	05:25	LINE CLEAR AVAILED
3495	23-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3496	23-Jul-24	GULBARGA	220	LINE	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	14:37	16:56	02:19	LINE CLEAR AVAILED
3497	23-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:24(22.07.2024)			TRIPPED ON FAULT
3498	23-Jul-24	HASSAN	66	LINE	BALEHNR-ALDUR	BALEHONNUR_66	9:24(22.07.2024)			MAIN SUPPLY FAILURE
3499	23-Jul-24	HASSAN	66	LINE	HASSN22-HN PURA	HASSAN_220	17:05	19:07	02:02	LINE CLEAR AVAILED
3500	23-Jul-24	HASSAN	66	LINE	HNPR2-HASS3	HNPURA_220	03:51	04:21	00:30	TRIPPED ON FAULT
3501	23-Jul-24	HASSAN	66	TRANSFORMER	HV1	BELUR_66	12:25	14:20	01:55	LINE CLEAR AVAILED
3502	23-Jul-24	HASSAN	66	TRANSFORMER	HV1	BELUR_66	19:00	19:17	00:17	LINE CLEAR AVAILED
3503	23-Jul-24	HASSAN	66	TRANSFORMER	HV1	HETTUR_66	11:07	12:37	01:30	MAIN SUPPLY FAILURE
3504	23-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	03:40	03:45	00:05	TRIPPED ON FAULT
3505	23-Jul-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	11:03	12:44	01:41	MAIN SUPPLY FAILURE
3506	23-Jul-24	HASSAN	66	TRANSFORMER	HV2	BELUR_66	12:25	14:20	01:55	LINE CLEAR AVAILED
3507	23-Jul-24	HASSAN	66	TRANSFORMER	HV2	BELUR_66	19:00	19:17	00:17	LINE CLEAR AVAILED
3508	23-Jul-24	HASSAN	66	TRANSFORMER	HV2	HALEBEEDU_66	12:48	13:51	01:03	LINE CLEAR AVAILED
3509	23-Jul-24	HASSAN	66	TRANSFORMER	HV2	MALLIPATNA_66	03:40	03:45	00:05	TRIPPED ON FAULT
3510	23-Jul-24	HASSAN	66	TRANSFORMER	HV2	SAKALESH PURA_66	06:15	13:20	07:05	TRIPPED ON FAULT
3511	23-Jul-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	02:25	03:30	01:05	TRIPPED ON FAULT
3512	23-Jul-24	HASSAN	66	LINE	MALLIPA-ARAKALGUD	MALLIPATNA_66	04:10	04:20	00:10	TRIPPED ON FAULT
3513	23-Jul-24	HASSAN	66	LINE	YESLUR-SNVRSNT	YESLUR_66	11:03	12:41	01:38	MAIN SUPPLY FAILURE
3514	23-Jul-24	HASSAN	110	LINE	HGUNJE-hiriyadka	HEGGUNJ_220	10:07	14:26	04:19	LINE CLEAR AVAILED
3515	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	15:30	16:28	00:58	LINE CLEAR AVAILED
3516	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	BIRUR_110	16:20	19:47	03:27	TRIPPED ON FAULT
3517	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	GURUPURA_110	21:25	21:40	00:15	TRIPPED ON FAULT
3518	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	GURUPURA_110	22:26	22:47	00:21	TRIPPED ON FAULT
3519	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	17:05	17:53	00:48	LINE CLEAR AVAILED
3520	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	13:01	14:00	00:59	LINE CLEAR AVAILED
3521	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	KUNDAPURA_110	12:09	14:25	02:16	LINE CLEAR AVAILED
3522	23-Jul-24	HASSAN	110	TRANSFORMER	HV1	NERALEKERE_110	14:10	16:31	02:21	LINE CLEAR AVAILED
3523	23-Jul-24	HASSAN	110	TRANSFORMER	HV2	HALADY_110	17:52	17:55	00:03	LINE CLEAR AVAILED
3524	23-Jul-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	11:54	12:47	00:53	LINE CLEAR AVAILED
3525	23-Jul-24	HASSAN	110	TRANSFORMER	HV2	MSEZ_220	10:14	12:52	02:38	LINE CLEAR AVAILED
3526	23-Jul-24	HASSAN	110	TRANSFORMER	HV2	NERALEKERE_110	11:42	13:58	02:16	LINE CLEAR AVAILED
3527	23-Jul-24	HASSAN	110	TRANSFORMER	HV2 CB	JADE_110	12:09	13:10	01:01	LINE CLEAR AVAILED
3528	23-Jul-24	HASSAN	110	TRANSFORMER	HV3	BEJAI_110	06:45	07:00	00:15	TRIPPED ON FAULT
3529	23-Jul-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	16:49	17:04	00:15	TRIPPED ON FAULT
3530	23-Jul-24	HASSAN	110	TRANSFORMER	HV4	BEJAI_110	06:45	07:00	00:15	TRIPPED ON FAULT
3531	23-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA_110	09:50	09:52	00:02	LINE CLEAR AVAILED
3532	23-Jul-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKLA_110	14:26	14:28	00:02	LINE CLEAR AVAILED
3533	23-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	09:00	09:37	00:37	LINE CLEAR AVAILED
3534	23-Jul-24	HASSAN	110	LINE	LV2	PUTTUR_110	09:39	12:30	02:51	LINE CLEAR AVAILED
3535	23-Jul-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	00:13	01:10	00:57	TRIPPED ON FAULT
3536	23-Jul-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	09:39	12:29	02:50	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3537	23-Jul-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMSG_220	00:38	11:11	10:33	TRIPPED ON FAULT
3538	23-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	17:42(23.07.2024)			TRIPPED ON FAULT
3539	23-Jul-24	HASSAN	220	LINE	VARAH1-SHIMOGA1	gen_varahi	17:42(23.07.2024)			TRIPPED ON FAULT
3540	23-Jul-24	MYSORE	66	LINE	HEBBANI-MEGALAPURA	BGPURA_66 CHIDRAVALLI_66	03:59	04:11	00:12	TRIPPED ON FAULT
3541	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	DATTAGALLY_66	15:20	18:06	02:45	LINE CLEAR AVAILED
3542	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	ELAVALA_66	13:53	13:58	00:05	TRIPPED ON FAULT
3543	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	12:00	12:32	00:32	LINE CLEAR AVAILED
3544	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	10:50	10:59	00:09	LINE CLEAR AVAILED
3545	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3546	23-Jul-24	MYSORE	66	TRANSFORMER	HV1	SHIVALLY_66	11:00	15:58	04:58	LINE CLEAR AVAILED
3547	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	DATTAGALLY_66	11:23	13:00	01:37	LINE CLEAR AVAILED
3548	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	13:05	15:56	02:50	LINE CLEAR AVAILED
3549	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	GUNDULPET_66	12:00	12:32	00:32	LINE CLEAR AVAILED
3550	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_66	08:05	08:12	00:06	TRIPPED ON FAULT
3551	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADHUVANAHALLI_220	18:42	19:28	00:46	TRIPPED ON FAULT
3552	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADHUVANAHALLI_220	19:30	19:37	00:07	LINE CLEAR AVAILED
3553	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	15:53	16:06	00:12	TRIPPED ON FAULT
3554	23-Jul-24	MYSORE	66	TRANSFORMER	HV2	SHIVALLY_66	16:01	16:45	00:44	LINE CLEAR AVAILED
3555	23-Jul-24	MYSORE	66	TRANSFORMER	HV3	GUNDULPET_66	11:45	12:45	01:00	TRIPPED ON FAULT
3556	23-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
3557	23-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	16:35	16:48	00:13	TRIPPED ON FAULT
3558	23-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MADIKERI	NO STATIONS EFFECTED	11:58	13:51	01:53	LINE CLEAR AVAILED
3559	23-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
3560	23-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-SUNTIKOPPA	SUNTIKOPPA_66	11:58	13:51	01:53	LINE CLEAR AVAILED
3561	23-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3562	23-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
3563	23-Jul-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	18:34 (22/07/2024)	13:55 (23/07/2024)	19:21 HRS	TRIPPED ON FAULT
3564	23-Jul-24	MYSORE	66	LINE	MUGUR -THAYUR	THAYURU_66 TNARASIPURA_66	05:07	05:12	00:05	TRIPPED ON FAULT
3565	23-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-ADDIHALLI	NO STATIONS EFFECTED	11:40	15:00	03:20	LINE CLEAR AVAILED
3566	23-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-NAGAMANGALA 1	NO STATIONS EFFECTED	11:45	15:10	03:25	LINE CLEAR AVAILED
3567	23-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPET	NO STATIONS EFFECTED	04:23	04:34	00:11	TRIPPED ON FAULT
3568	23-Jul-24	MYSORE	66	LINE	SHANIVARSANTHE-YESSLUR	NO STATIONS EFFECTED	02:25	12:43	10:18	TRIPPED ON FAULT
3569	23-Jul-24	MYSORE	66	LINE	SHIVALLI-NAGAMANGALA	NO STATIONS EFFECTED	11:43	16:24	04:40	LINE CLEAR AVAILED
3570	23-Jul-24	MYSORE	220	LINE	CR NAGARA-MADHUVANAHALLI 1	NO STATIONS EFFECTED	11:13	13:01	01:47	LINE CLEAR AVAILED
3571	23-Jul-24	MYSORE	220	LINE	CR NAGARA-MADHUVANAHALLI 2	NO STATIONS EFFECTED	13:45	14:54	01:08	LINE CLEAR AVAILED
3572	23-Jul-24	MYSORE	220	LINE	HEBBANI-MADHUVANAHALLI 1	NO STATIONS EFFECTED	15:08	16:10	01:02	LINE CLEAR AVAILED
3573	23-Jul-24	MYSORE	220	LINE	HUNSUR 220-BASTIPURA 1	NO STATIONS EFFECTED	09:40	18:45	09:05	LINE CLEAR AVAILED
3574	23-Jul-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	09:26	18:53	09:27	LINE CLEAR AVAILED
3575	23-Jul-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	13:17	19:11	05:54	TRIPPED ON FAULT
3576	23-Jul-24	MYSORE	220	LINE	TUBINKERE-KOTTIPURA	NO STATIONS EFFECTED	17:13	19:19	02:06	LINE CLEAR AVAILED
3577	23-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1 HONNALLI_66	HONNALLI_66	15:24	17:32	2:08	LINE CLEAR AVAILED
3578	23-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2	KADAJJI_66	06:02	06:06	0:04	TRIPPED ON FAULT
3579	23-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2 BUKKAPATNA_66	BUKKAPATNA_66	12:39	12:49	0:10	LINE CLEAR AVAILED
3580	23-Jul-24	TUMKUR	66	TRANSFORMER	20MVA TR-2 HOSADURGA_66	HOSADURGA_66	18:37	18:48	0:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3581	23-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3582	23-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV MATHOD LINE 1	66KV HINDUSGHATTA,MATHOD, KANCHIPURA,GARAGA,PANCHANA HALLI	5:24	5:36	0:12	TRIPPED ON FAULT
3583	23-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE-2	66KV CHITRAHLLI, HDPURA	13:44	13:54	0:10	TRIPPED ON FAULT
3584	23-Jul-24	TUMKUR	66	LINE	66KV MATHOD -220KV HIRIYUR LINE 2	66KV HINDUSGHATTA,MATHOD, KANCHIPURA,GARAGA,PANCHANA HALLI	5:22	5:38	0:16	TRIPPED ON FAULT
3585	23-Jul-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	RAMAGIRI_66	15:50	17:35	1:45	LINE CLEAR AVAILED
3586	23-Jul-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV MADHURE LINE	RAMAGIRI_66	15:50	17:35	1:45	LINE CLEAR AVAILED
3587	23-Jul-24	TUMKUR	66	LINE	66KV TURUVANUR-CHITRADURGA	BIDARKERE_66,MARANAYAKANAH ALLI_66,TURUVANUR_66	21:18	21:41	0:23	LINE CLEAR AVAILED
3588	23-Jul-24	TUMKUR	66	LINE	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	5:21	5:32	0:11	TRIPPED ON FAULT
3589	23-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-H D PURA	H D PURA_66	13:42	13:52	0:10	TRIPPED ON FAULT
3590	23-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASUDI,K.R.HALLI	14:42 (22.07.24)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3591	23-Jul-24	TUMKUR	66	LINE	KUKKAWADA -HONNALLI	KUKKAWADA_66	11:44	11:54	0:10	LINE CLEAR AVAILED
3592	23-Jul-24	TUMKUR	66	LINE	RAMAGIRI_66-CHANNAGIRI_66	RAMAGIRI_66	15:13	17:35	2:22	LINE CLEAR AVAILED
3593	23-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
3594	23-Jul-24	TUMKUR	110	TRANSFORMER	10MVA TR-1	AMMASANDRA_110	19:18	19:26	0:08	TRIPPED ON FAULT
3595	23-Jul-24	TUMKUR	220	LINE	220KV HIRIYUR- 220KVTHALLAK	THALLAK_220	16:52	19:30	2:38	LINE CLEAR AVAILED
3596	24-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	AMBEWADI_220	19:46	19:50	0:04	TRIPPED ON FAULT
3597	24-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	HUBLI_220	20:17 (24.07.2024)			TRIPPED ON FAULT
3598	24-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA1	AMBEWADI_220	18:17	18:37	0:20	TRIPPED ON FAULT
3599	24-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA1	AMBEWADI_220	19:12	19:30	0:18	TRIPPED ON FAULT
3600	24-Jul-24	BAGALKOTE	110	LINE	ANMOD-SUPA2	ANMOD_110	23:40 (23.07.2024)	00:05 (24.07.2024)	0:05	TRIPPED ON FAULT
3601	24-Jul-24	BAGALKOTE	110	LINE	ATHANI220- KSSKN	ATHANI_220	06:13	06:23	0:10	TRIPPED ON FAULT
3602	24-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3603	24-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
3604	24-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMATA 2	SIRSI_110	07:40	16:35	8:55	TRIPPED ON FAULT
3605	24-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3606	24-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
3607	24-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
3608	24-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI_220	18:23 (23.07.2024)	13:24 (24.07.2024)	19:01:00	TRIPPED ON FAULT
3609	24-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI_220	16:07 (24.07.2024)			TRIPPED ON FAULT
3610	24-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HARTI1	BIDNAL_220	17:58	18:09	00:11	LINE CLEAR AVAILED
3611	24-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HARTI1	BIDNAL_220	18:10 (24.07.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3612	24-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HARTI2	BIDNAL_220	13:29 (24.07.2024)			LINE CLEAR AVAILED
3613	24-Jul-24	BANGALORE	66	LINE	66KV ANEKAL - ATTIBELE	ATTIBELE	12:52	12:57	00:05	LINE CLEAR AVAILED
3614	24-Jul-24	BANGALORE	66	LINE	66KV ANEKAL - SAMANDURU	SAMANDURU	14:44	15:16	00:32	LINE CLEAR AVAILED
3615	24-Jul-24	BANGALORE	66	LINE	66KV BAGEPALLI - GULUR	NO STATION AFFECTED	07:15	07:30	00:15	TRIPPED ON FAULT
3616	24-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	16:21	16:35	00:14	TRIPPED ON FAULT
3617	24-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA	10:01	10:10	00:09	LINE CLEAR AVAILED
3618	24-Jul-24	BANGALORE	66	LINE	66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	DIVYASHREE TECH PARK	11:32	11:37	00:05	MAIN SUPPLY FAILURE
3619	24-Jul-24	BANGALORE	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, ANNABEL(DLF), SAUDELA	20:12	20:55	00:43	MAIN SUPPLY FAILURE
3620	24-Jul-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ELITA PROMENADE	ELITA PROMENENDE	20:12	20:55	00:43	MAIN SUPPLY FAILURE
3621	24-Jul-24	BANGALORE	66	LINE	66KV KHODAYS 220 - FALCON CITY	PRESTIGE FALCON CITY	20:12	20:55	00:43	MAIN SUPPLY FAILURE
3622	24-Jul-24	BANGALORE	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	20:12	20:55	00:43	MAIN SUPPLY FAILURE
3623	24-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, TORALAKKI	10:50	12:24	01:34	LINE CLEAR AVAILED
3624	24-Jul-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	12:46	13:05	00:19	TRIPPED ON FAULT
3625	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASLU	18:05	18:26	00:21	MAIN SUPPLY FAILURE
3626	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 1	D CROSS	18:05	18:35	00:30	MAIN SUPPLY FAILURE
3627	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	18:05	18:12	00:07	MAIN SUPPLY FAILURE
3628	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHIDS	18:05	18:25	00:20	MAIN SUPPLY FAILURE
3629	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	10:51	14:52	04:01	LINE CLEAR AVAILED
3630	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	10:51	14:52	04:01	LINE CLEAR AVAILED
3631	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	18:05	18:25	00:20	MAIN SUPPLY FAILURE
3632	24-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE	18:05	18:35	00:30	MAIN SUPPLY FAILURE
3633	24-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	19:00	19:05	00:05	LINE CLEAR AVAILED
3634	24-Jul-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	17:50	18:00	00:10	TRIPPED ON FAULT
3635	24-Jul-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	18:55	19:00	00:05	TRIPPED ON FAULT
3636	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ANDERSONPET	09:45	09:48	00:03	LINE CLEAR AVAILED
3637	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	14:35	14:39	00:04	LINE CLEAR AVAILED
3638	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HONNIGANAHALLI	13:37	13:42	00:05	TRIPPED ON FAULT
3639	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KGF	17:30	17:40	00:10	LINE CLEAR AVAILED
3640	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	19:48	19:52	00:04	LINE CLEAR AVAILED
3641	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NIMHANS 220	13:25	13:30	00:05	TRIPPED ON FAULT
3642	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	22:23	22:31	00:08	TRIPPED ON FAULT
3643	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	23:11	23:15	00:04	TRIPPED ON FAULT
3644	24-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	12:15	12:45	00:30	LINE CLEAR AVAILED
3645	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	11:32	11:37	00:05	LINE CLEAR AVAILED
3646	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BOMMEPALLI CROSS	09:30	09:32	00:02	LINE CLEAR AVAILED
3647	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	13:47	14:22	00:35	TRIPPED ON FAULT
3648	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	15:48	16:08	00:20	TRIPPED ON FAULT
3649	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KONDASAPURA	19:48	19:52	00:04	LINE CLEAR AVAILED
3650	24-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YENNIGADALE	12:03	12:25	00:22	LINE CLEAR AVAILED
3651	24-Jul-24	BANGALORE	220	LINE	220KV AERO SPACE 220 - BIAL BEGUR 220	NO STATION AFFECTED	18:05	22:29	04:24	TRIPPED ON FAULT
3652	24-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 1	NO STATION AFFECTED	18:05	21:50	03:45	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3653	24-Jul-24	BANGALORE	220	LINE	220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2	NO STATION AFFECTED	18:05	20:20	02:15	TRIPPED ON FAULT
3654	24-Jul-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 2	NO STATION AFFECTED	18:05	22:29	04:24	TRIPPED ON FAULT
3655	24-Jul-24	BANGALORE	220	LINE	220KV MANYATA 220 - HEBBAL 220 - SAHAKARNAGAR 220	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3656	24-Jul-24	BANGALORE	220	LINE	220KV NRS DB PURA 220 - BIAL BEGUR 220	DB PURA 220	18:05	18:12	00:07	TRIPPED ON FAULT
3657	24-Jul-24	BANGALORE	220	TRANSFORMER	HV1	KHODAYS 220	20:12	20:55	00:43	TRIPPED ON FAULT
3658	24-Jul-24	BANGALORE	220	TRANSFORMER	HV1	NRS DB PURA 220	18:05	18:12	00:07	MAIN SUPPLY FAILURE
3659	24-Jul-24	BANGALORE	220	TRANSFORMER	HV2	KHODAYS 220	20:12	20:55	00:43	TRIPPED ON FAULT
3660	24-Jul-24	BANGALORE	220	TRANSFORMER	HV3	NRS DB PURA 220	18:05	18:12	00:07	MAIN SUPPLY FAILURE
3661	24-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	19:00	19:05	00:05	TRIPPED ON FAULT
3662	24-Jul-24	GULBARGA	66	TRANSFORMER	HV2	TELGI_66	11:20	11:25	00:05	TRIPPED ON FAULT
3663	24-Jul-24	GULBARGA	66	TRANSFORMER	HV3 & HV4	ITTAGI_220	08:49	08:58	00:09	TRIPPED ON FAULT
3664	24-Jul-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	21:22	21:45	00:23	TRIPPED ON FAULT
3665	24-Jul-24	GULBARGA	66	LINE	ITTAGI-RENEW 1& 2	ITTAGI_220	08:26	08:58	00:32	TRIPPED ON FAULT
3666	24-Jul-24	GULBARGA	66	LINE	LV1	ITTAGI_220	08:43	08:55	00:12	TRIPPED ON FAULT
3667	24-Jul-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	00:20	00:25	00:05	TRIPPED ON FAULT
3668	24-Jul-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	BENNUR_110,YARADONA_110	10:45	11:01	00:16	TRIPPED ON FAULT
3669	24-Jul-24	GULBARGA	110	LINE	HUMNABAD-SANTHPUR	SANTHAPUR_110,JANAWADA_110	23:45	23:59	00:14	TRIPPED ON FAULT
3670	24-Jul-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	MANVI_110	10:20	10:38	00:18	TRIPPED ON FAULT
3671	24-Jul-24	GULBARGA	110	TRANSFORMER	HV2	KANAKAGIRI_110	11:35	14:45	03:10	LINE CLEAR AVAILED
3672	24-Jul-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	SONATHI_110	20:05	20:26	00:21	TRIPPED ON FAULT
3673	24-Jul-24	GULBARGA	110	LINE	MALLAPURA-MUNIRABAD	MALLAPURA_110	19:02	19:18	00:16	TRIPPED ON FAULT
3674	24-Jul-24	GULBARGA	110	LINE	MOKA-ALLIPUR	MOKA_110	14:20	14:25	00:05	TRIPPED ON FAULT
3675	24-Jul-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	MALLAPUR_110, KEREHALLI_110	19:02	19:18	00:16	TRIPPED ON FAULT
3676	24-Jul-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI-1	CHINCHOLI_110	12:45	18:26	05:41	LINE CLEAR AVAILED
3677	24-Jul-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI-2	CHINCHOLI_110	12:50	18:27	05:37	LINE CLEAR AVAILED
3678	24-Jul-24	GULBARGA	110	LINE	SEDAM-CHITAPUR	CHITAPUR_110	05:00	23:59	18:59	TRIPPED ON FAULT
3679	24-Jul-24	GULBARGA	110	LINE	SHAHABAD-SAGNOOR	CHOWDAPUR_110	08:45	08:52	00:07	MAIN SUPPLY FAILURE
3680	24-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3681	24-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:24(22.07.2024)			TRIPPED ON FAULT
3682	24-Jul-24	HASSAN	66	LINE	BALEHNR-ALDUR	BALEHONNUR_66	9:24(22.07.2024)			MAIN SUPPLY FAILURE
3683	24-Jul-24	HASSAN	66	TRANSFORMER	HV1	GORUR_66	11:15	13:00	01:45	LINE CLEAR AVAILED
3684	24-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	13:05	13:10	00:05	TRIPPED ON FAULT
3685	24-Jul-24	HASSAN	66	TRANSFORMER	HV1	SATHENAHALLI_66	10:05	15:26	05:21	LINE CLEAR AVAILED
3686	24-Jul-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	10:00	10:09	00:09	TRIPPED ON FAULT
3687	24-Jul-24	HASSAN	66	TRANSFORMER	HV2	SATHENAHALLI_66	10:05	15:26	05:21	LINE CLEAR AVAILED
3688	24-Jul-24	HASSAN	66	TRANSFORMER	HV2	SINGAPURA_66	11:35	12:51	01:16	LINE CLEAR AVAILED
3689	24-Jul-24	HASSAN	66	LINE	SATHEN-UDAY	SATHENAHALLI_66	10:05	15:26	05:21	LINE CLEAR AVAILED
3690	24-Jul-24	HASSAN	66	LINE	TAVAREC-HONNALI	TAVARECHATNAHALLI_66	04:36	08:47	04:11	TRIPPED ON FAULT
3691	24-Jul-24	HASSAN	110	TRANSFORMER	HV1	GURUPURA_110	08:42	08:51	00:09	TRIPPED ON FAULT
3692	24-Jul-24	HASSAN	110	TRANSFORMER	HV1	GURUPURA_110	21:25	21:40	00:15	TRIPPED ON FAULT
3693	24-Jul-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	20:07(24.07.2024)			TRIPPED ON FAULT
3694	24-Jul-24	HASSAN	110	TRANSFORMER	HV1	KONAJE_110	16:08	16:58	00:50	LINE CLEAR AVAILED
3695	24-Jul-24	HASSAN	110	TRANSFORMER	HV1	SAGARA_110	16:06	17:15	01:09	LINE CLEAR AVAILED
3696	24-Jul-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	11:01	12:52	01:51	LINE CLEAR AVAILED
3697	24-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	15:04	16:00	00:56	LINE CLEAR AVAILED
3698	24-Jul-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:05	15:59	05:54	LINE CLEAR AVAILED
3699	24-Jul-24	HASSAN	110	LINE	LV2	MSEZ_220	10:16	14:27	04:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3700	24-Jul-24	HASSAN	110	LINE	MADHUV-KUNDAPURA	MADHUVANA_110	08:54	11:52	02:58	TRIPPED ON FAULT
3701	24-Jul-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	13:12	14:44	01:32	TRIPPED ON FAULT
3702	24-Jul-24	HASSAN	220	TRANSFORMER	HV2	MSEZ_220	10:16	14:27	04:11	LINE CLEAR AVAILED
3703	24-Jul-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMG_220	13:14	14:45	01:31	TRIPPED ON FAULT
3704	24-Jul-24	HASSAN	220	LINE	MRSSHM-DAVANGERE	MRSMG_220	11:49	18:06	06:17	TRIPPED ON FAULT
3705	24-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMG_220	17:42(23.07.2024)	9:39(24.07.2024)	15:56 hrs	LINE CLEAR AVAILED
3706	24-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA3	gen_sharavathy	18:56	20:58	02:02	TRIPPED ON FAULT
3707	24-Jul-24	HASSAN	220	LINE	SHRAVTY-TALGUPPA3	gen_sharavathy	18:47(24.07.2024)			TRIPPED ON FAULT
3708	24-Jul-24	HASSAN	220	LINE	TALGUPPA-SHRAVTY	TALGUPPA_400	18:47(24.07.2024)			TRIPPED ON FAULT
3709	24-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	09:32	09:45	00:13	TRIPPED ON FAULT
3710	24-Jul-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	17:42(23.07.2024)	9:43(24.07.2024)	16:00 hrs	LINE CLEAR AVAILED
3711	24-Jul-24	MYSORE	66	LINE	ELWALA-HOOTAGALLI	ELAVALA_66	12:10	12:32	00:22	LINE CLEAR AVAILED
3712	24-Jul-24	MYSORE	66	LINE	HAMPAPURA-JAYAPURA	NO STATIONS EFFECTED	05:55	06:10	00:15	TRIPPED ON FAULT
3713	24-Jul-24	MYSORE	66	LINE	HUNSUR-ELWALA	NO STATIONS EFFECTED	12:11	15:50	03:38	LINE CLEAR AVAILED
3714	24-Jul-24	MYSORE	66	LINE	HUNSUR-HUNSUR 2	NO STATIONS EFFECTED	10:45	15:45	04:59	LINE CLEAR AVAILED
3715	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORMYS_66	11:06	13:15:00	02:09	LINE CLEAR AVAILED
3716	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	JYOTHINAGARA_66	11:20	11:58	00:37	LINE CLEAR AVAILED
3717	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	11:06	14:24	03:18	LINE CLEAR AVAILED
3718	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	14:49	15:17	00:27	TRIPPED ON FAULT
3719	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	15:31	15:42	00:11	LINE CLEAR AVAILED
3720	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	16:05	16:10	00:04	LINE CLEAR AVAILED
3721	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	K_HONNALGERE_66	16:40	16:45	00:05	TRIPPED ON FAULT
3722	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	11:33	12:22	00:48	LINE CLEAR AVAILED
3723	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	13:09	13:15	00:05	TRIPPED ON FAULT
3724	24-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3725	24-Jul-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORMYS_66	13:20	15:00:25	01:40	LINE CLEAR AVAILED
3726	24-Jul-24	MYSORE	66	TRANSFORMER	HV2	K_HONNALGERE_66	14:30	14:40	00:10	LINE CLEAR AVAILED
3727	24-Jul-24	MYSORE	66	TRANSFORMER	HV2	K_HONNALGERE_66	16:25	18:30	02:05	LINE CLEAR AVAILED
3728	24-Jul-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	10:36	11:51	01:15	LINE CLEAR AVAILED
3729	24-Jul-24	MYSORE	66	TRANSFORMER	HV3	KUSHALNAGARA_220	07:02	07:15	00:12	TRIPPED ON FAULT
3730	24-Jul-24	MYSORE	66	TRANSFORMER	HV3	KUSHALNAGARA_220	00:58	01:10	00:12	TRIPPED ON FAULT
3731	24-Jul-24	MYSORE	66	TRANSFORMER	HV3	KUSHALNAGARA_220	02:04	02:08	00:04	TRIPPED ON FAULT
3732	24-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
3733	24-Jul-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 1	SANTHEBACHALLI_66	11:33	15:43	04:09	LINE CLEAR AVAILED
3734	24-Jul-24	MYSORE	66	LINE	KR PETE 220-SB HALLI 2	SANTHEBACHALLI_66	11:33	15:44	04:11	LINE CLEAR AVAILED
3735	24-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MADIKERI	NO STATIONS EFFECTED	12:28	13:21	00:53	LINE CLEAR AVAILED
3736	24-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
3737	24-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-SUNTIKOPPA	NO STATIONS EFFECTED	10:47	13:19	02:31	TRIPPED ON FAULT
3738	24-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3739	24-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
3740	24-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-ADDIHALLI	ADDIHALLI_66	10:25	14:29	04:04	LINE CLEAR AVAILED
3741	24-Jul-24	MYSORE	66	LINE	SUTTUR-ALAMBURU LIS	NO STATIONS EFFECTED	16:10	16:27	00:17	TRIPPED ON FAULT
3742	24-Jul-24	MYSORE	66	LINE	VADAKEPURA-KIRUGAVALU	KIRUGAVALU_66MALIYURU_66	09:24	09:36	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3743	24-Jul-24	MYSORE	220	TRANSFORMER	HV1	KUSHALNAGARA_220	13:20	14:22	01:02	LINE CLEAR AVAILED
3744	24-Jul-24	MYSORE	220	LINE	KR PETE 220-BASTIPURA	NO STATIONS EFFECTED	08:51	19:04	10:12	LINE CLEAR AVAILED
3745	24-Jul-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	08:44	19:08	10:24	LINE CLEAR AVAILED
3746	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-1	TURUVANUR_66	15:44	15:54	0:10	TRIPPED ON FAULT
3747	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-1	TURUVANUR_66	16:20	16:32	0:12	TRIPPED ON FAULT
3748	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-1	TYAVANAGI_66	14:52	15:22	0:30	LINE CLEAR AVAILED
3749	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-1	TYAVANAGI_66	17:41	17:57	0:16	TRIPPED ON FAULT
3750	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-1 & 2	SHYLAPURA_66	13:04	14:03	0:59	LINE CLEAR AVAILED
3751	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5 MVA TR-2	MELLEKATTEI_66	13:00	13:30	0:30	LINE CLEAR AVAILED
3752	24-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1	HOSADURGA_66	11:15	15:13	3:58	LINE CLEAR AVAILED
3753	24-Jul-24	TUMKUR	66	TRANSFORMER	20 MVA TR-2	KORAI_66	10:25	10:30	0:05	LINE CLEAR AVAILED
3754	24-Jul-24	TUMKUR	66	TRANSFORMER	20 MVA TR-2	KORAI_66	16:09	16:15	0:06	LINE CLEAR AVAILED
3755	24-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3756	24-Jul-24	TUMKUR	66	LINE	66KV CHITRDURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI,HD PURA	11:36	12:07	0:31	TRIPPED ON FAULT
3757	24-Jul-24	TUMKUR	66	LINE	66KV CHITRDURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI,HD PURA	13:20	13:32	0:12	TRIPPED ON FAULT
3758	24-Jul-24	TUMKUR	66	LINE	66KV CHITRDURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI,HD PURA	14:25	14:35	0:10	TRIPPED ON FAULT
3759	24-Jul-24	TUMKUR	66	LINE	66KV CHITRDURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI,HD PURA	16:05	16:15	0:10	TRIPPED ON FAULT
3760	24-Jul-24	TUMKUR	66	LINE	66KV KEREKILACHI-66KV SHYGALE LINE	WATER SUPPLY	10:05	10:10	0:05	TRIPPED ON FAULT
3761	24-Jul-24	TUMKUR	66	LINE	66KV SANTEBENNUR-66KV KEREKILACHI LINE	66KV KEREKILACHI,SHYGALE	10:05	10:10	0:05	TRIPPED ON FAULT
3762	24-Jul-24	TUMKUR	66	TRANSFORMER	8 MVA TR-1	CHITRAHALLI_66	11:01	11:12	0:11	TRIPPED ON FAULT
3763	24-Jul-24	TUMKUR	66	TRANSFORMER	8 MVA TR-2	HARIYABBE_66	14:47	14:55	0:08	TRIPPED ON FAULT
3764	24-Jul-24	TUMKUR	66	TRANSFORMER	8 MVA TR-2	HONNALLI_66	12:36	13:10	0:34	LINE CLEAR AVAILED
3765	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	10:42	11:01	0:19	MAIN SUPPLY FAILURE
3766	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-CHITRADURGA	CHITRAHALLI_66	13:21	13:31	0:10	MAIN SUPPLY FAILURE
3767	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-H D PURA	H D PURA_66	11:34	11:48	0:14	TRIPPED ON FAULT
3768	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-H D PURA	H D PURA_66	12:00	13:01	1:01	TRIPPED ON FAULT
3769	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-H D PURA	H D PURA_66	13:21	13:58	0:37	TRIPPED ON FAULT
3770	24-Jul-24	TUMKUR	66	LINE	CHITRAHALLI-H D PURA	H D PURA_66	14:05	16:57	2:52	TRIPPED ON FAULT
3771	24-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASUDI,K.R.HALLI	14:42 (22.07.24)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3772	24-Jul-24	TUMKUR	66	LINE	KEREKILCHE-SHAGLE	KEREKILCHE_66, SANTEBENNUR_66	10:06	10:10	0:04	TRIPPED ON FAULT
3773	24-Jul-24	TUMKUR	66	LINE	SHYLAPURA-PR PURA	P R PURA_66	13:04	13:11	0:07	LINE CLEAR AVAILED
3774	24-Jul-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	10:17	12:25	2:08	LINE CLEAR AVAILED
3775	24-Jul-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	10:50	12:25	1:35	LINE CLEAR AVAILED
3776	24-Jul-24	TUMKUR	66	LINE	TMTP66-KORA	KORA_66	5:57	6:13	0:16	TRIPPED ON FAULT
3777	24-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
3778	24-Jul-24	TUMKUR	110	TRANSFORMER	10 MVA TR-1	SOMALAPURA_110KV	6:08	6:25	0:17	TRIPPED ON FAULT
3779	24-Jul-24	TUMKUR	110	TRANSFORMER	10 MVA TR-1	TALKERE_110KV	12:20	14:00	1:40	LINE CLEAR AVAILED
3780	24-Jul-24	TUMKUR	110	TRANSFORMER	10 MVA TR-2	THIMMANAHALLI_110KV	16:39	16:50	0:11	TRIPPED ON FAULT
3781	24-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-1 ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	10:57	16:32	5:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3782	24-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-1-220KV KIADB	KIADB_220KV	20:11 (24.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3783	24-Jul-24	TUMKUR	220	LINE	220KV HONNALI-220KV SHIVAMOGGA LINE 2	SHIMOGA_220KV	11:49	18:06	6:17	TRIPPED ON FAULT
3784	24-Jul-24	TUMKUR	220	LINE	220KV SIRA-220KV HIRIYUR LINE 1	SIRA_220KV	18:52 (24.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
3785	24-Jul-24	TUMKUR	400	LINE	315 MVA TR-2 GUTTUR-400KV	GUTTUR_400KV	10:30	21:48	11:18	LINE CLEAR AVAILED
3786	24-Jul-24	TUMKUR	400	LINE	400KV GUTTUR-400KV KAIGA LINE 2	GUTTUR_400KV	13:57	15:09	1:12	TRIPPED ON FAULT
3787	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BJCTY(THORVI_110)	13:10	13:46	00:36	LINE CLEAR AVAILED
3788	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALAGHATAGI_110	00:02	00:10	00:08	TRIPPED ON FAULT
3789	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALAGHATAGI_110	00:50	00:55	00:05	TRIPPED ON FAULT
3790	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALAGHATAGI_110	07:45	07:50	00:05	TRIPPED ON FAULT
3791	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	SADALAGA_110	10:50	11:15	00:25	LINE CLEAR AVAILED
3792	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	13:22	14:21	00:59	LINE CLEAR AVAILED
3793	25-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	HUBLI_220	20:17 (24.07.2024)	13:45 (25.07.2024)	17:28:00	TRIPPED ON FAULT
3794	25-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220- SUPA1	AMBEWADI_220	02:08	02:33	00:25	TRIPPED ON FAULT
3795	25-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220- SUPA1	AMBEWADI_220	20:16	20:29	00:13	TRIPPED ON FAULT
3796	25-Jul-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	10:11	10:26	00:15	LINE CLEAR AVAILED
3797	25-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	10:11	14:20	04:09	TRIPPED ON FAULT
3798	25-Jul-24	BAGALKOTE	110	LINE	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	03:29	07:27	03:58	TRIPPED ON FAULT
3799	25-Jul-24	BAGALKOTE	110	LINE	BELGAUM220- VADAGOAN	BELGAUM_220	10:54	11:23	00:29	TRIPPED ON FAULT
3800	25-Jul-24	BAGALKOTE	110	LINE	BELGAUM220- VADAGOAN	BELGAUM_220	11:26	13:46	02:20	LINE CLEAR AVAILED
3801	25-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3802	25-Jul-24	BAGALKOTE	110	LINE	NAREGAL-BETAGERI	NAREGAL_110	16:47	16:49	00:02	LINE CLEAR AVAILED
3803	25-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
3804	25-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR- RATTIHALLI (TUMMINKATTE)	RANEBENNUR_220	20:31 (25.07.2024)			LINE CLEAR AVAILED
3805	25-Jul-24	BAGALKOTE	110	LINE	RON-NAREGAL	STATION NOT AFFECTED RON_110	16:44 (25.07.2024)			LINE CLEAR AVAILED
3806	25-Jul-24	BAGALKOTE	110	LINE	SIRSI-JOGA1 (SIDDAPUR)	SIRSI_110	11:59	23:43	11:44	LINE CLEAR AVAILED
3807	25-Jul-24	BAGALKOTE	110	LINE	SIRSI-JOGA2 (NK2)	SIRSI_110	10:51	12:12	01:21	TRIPPED ON FAULT
3808	25-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA1	SIRSI_110	03:10	05:10	02:00	TRIPPED ON FAULT
3809	25-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA1	SIRSI_110	19:05	19:30	00:25	TRIPPED ON FAULT
3810	25-Jul-24	BAGALKOTE	110	LINE	SIRSI-KUMTA2	SIRSI_110	19:31	22:16	02:45	TRIPPED ON FAULT
3811	25-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3812	25-Jul-24	BAGALKOTE	110	LINE	TODALBAGI-JAMAKHANDI SUGARS	TODALBAGI_110	13:37	13:45	00:08	TRIPPED ON FAULT
3813	25-Jul-24	BAGALKOTE	110	LINE	VADAGAON-BELAGAVI	VADAGAON_110	11:23	13:45	02:22	LINE CLEAR AVAILED
3814	25-Jul-24	BAGALKOTE	110	LINE	VADAGAON-MACHE	VADAGAON_110	10:54	14:00	03:06	TRIPPED ON FAULT
3815	25-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
3816	25-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
3817	25-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	MKHUBLI_220	13:00 (25.07.2024)			TRIPPED ON FAULT
3818	25-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	AMBEWADI_220	01:20	16:49	15:29	LINE CLEAR AVAILED
3819	25-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	AMBEWADI_220	01:11	16:48	15:37	TRIPPED ON FAULT
3820	25-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	07:34	08:13	00:39	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3821	25-Jul-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI_220	16:07 (24.07.2024)	13:50 (25.07.2024)	21:43:00	TRIPPED ON FAULT
3822	25-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI1(ALAMATTI2)	BAGALKOT_220	11:25	14:49	03:24	LINE CLEAR AVAILED
3823	25-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HARTI1	BIDNAL_220	18:10 (24.07.2024)	12:16 (25.07.2024)	18:06:00	LINE CLEAR AVAILED
3824	25-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HARTI2	BIDNAL_220	13:29 (24.07.2024)	12:17 (25.07.2024)	22:48:00	LINE CLEAR AVAILED
3825	25-Jul-24	BAGALKOTE	220	LINE	CHIKKODI- KUDACHI1	CHIKKODI_220	01:50	02:19	00:29	TRIPPED ON FAULT
3826	25-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	04:27	13:04	08:37	TRIPPED ON FAULT
3827	25-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	13:04	16:11	03:07	TRIPPED ON FAULT
3828	25-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	16:11 (25.07.2024)			TRIPPED ON FAULT
3829	25-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	13:12	16:35	03:23	TRIPPED ON FAULT
3830	25-Jul-24	BAGALKOTE	220	LINE	NARENDRA- KANABARGI2	NARENDRA_220	11:03	11:20	00:17	TRIPPED ON FAULT
3831	25-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	19:33 (25.07.2024)			TRIPPED ON FAULT
3832	25-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:48	06:34	00:46	TRIPPED ON FAULT
3833	25-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	10:01	10:36	00:35	LINE CLEAR AVAILED
3834	25-Jul-24	BANGALORE	66	LINE	66KV D CROSS - DODDABELAVANGALA - THONDEBHAVI - ALIPURA	THONDEBHAVI	11:05	11:25	00:20	LINE CLEAR AVAILED
3835	25-Jul-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, MANDIKAL, GUDIBANDE	18:00	18:20	00:20	TRIPPED ON FAULT
3836	25-Jul-24	BANGALORE	66	LINE	66KV ITI 220 - NGEF	NGEF	10:08	15:28	05:20	LINE CLEAR AVAILED
3837	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACHALU	ACHALU, HONNIGANAHALLI	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3838	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	ALLIMARADANAHALLI, CHIKKENAHALLI	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3839	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	HANUMANTHANAGARA, CHATRA, MARALAVADI, GODUR	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3840	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3841	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - KUNUR	KUNUR, HAROBELE, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNASENAHALLI	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3842	25-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI DAIRY, DODDALAHALLI	19:40	19:41	00:01	MAIN SUPPLY FAILURE
3843	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - KEMBODI	KEMBODI	11:20	11:47	00:27	MAIN SUPPLY FAILURE
3844	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA, WISTRON, KC VALLEY	11:20	11:45	00:25	MAIN SUPPLY FAILURE
3845	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA, WISTRON, KC VALLEY	15:48	16:05	00:17	TRIPPED ON FAULT
3846	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	11:20	23:59	12:39	TRIPPED ON FAULT
3847	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - TALAGUNDA	TALAGUNDA, VEMGAL, KYALANUR, CHEEMANGALA, TALAGAWARA	11:20	11:47	00:27	MAIN SUPPLY FAILURE
3848	25-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - VOKKALERI	VOKKAERI, KC VALLEY(EHT)	11:20	11:47	00:27	MAIN SUPPLY FAILURE
3849	25-Jul-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUDUGODI-1	NO STATION AFFECTED	15:43	17:07	01:24	TRIPPED ON FAULT
3850	25-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE, DODDERI	07:40	08:05	00:25	TRIPPED ON FAULT
3851	25-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	07:40	08:05	00:25	TRIPPED ON FAULT
3852	25-Jul-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, RAYALPADU, GOWNIPALLI	19:00	19:09	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3853	25-Jul-24	BANGALORE	66	LINE	66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA	SUGUTUR, PGCIL AUX	11:20	11:47	00:27	MAIN SUPPLY FAILURE
3854	25-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPET	16:38	16:49	00:11	TRIPPED ON FAULT
3855	25-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	18:31	18:41	00:10	LINE CLEAR AVAILED
3856	25-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR	18:16	18:30	00:14	TRIPPED ON FAULT
3857	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	CESSNA	13:55	14:20	00:25	MAIN SUPPLY FAILURE
3858	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	CESSNA	19:35	19:40	00:05	LINE CLEAR AVAILED
3859	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	CESSNA	13:55	14:20	00:25	MAIN SUPPLY FAILURE
3860	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	CESSNA	19:35	19:40	00:05	LINE CLEAR AVAILED
3861	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	13:55	14:20	00:25	MAIN SUPPLY FAILURE
3862	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	19:35	19:40	00:05	LINE CLEAR AVAILED
3863	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	13:55	14:33	00:38	MAIN SUPPLY FAILURE
3864	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	19:35	19:40	00:05	LINE CLEAR AVAILED
3865	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	13:55	14:20	00:25	MAIN SUPPLY FAILURE
3866	25-Jul-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	19:35	19:40	00:05	LINE CLEAR AVAILED
3867	25-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	07:40	08:04	00:24	TRIPPED ON FAULT
3868	25-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	07:40	08:02	00:22	TRIPPED ON FAULT
3869	25-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - BOMMASANDRA I/A-BIOCON (ELECTRONIC CITY 2)	BOMMASANDRA, BIOCON	15:23	15:46	00:23	MAIN SUPPLY FAILURE
3870	25-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	15:23	15:56	00:33	MAIN SUPPLY FAILURE
3871	25-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA	15:16	15:56	00:40	MAIN SUPPLY FAILURE
3872	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BANASAWADI	07:08	07:18	00:10	TRIPPED ON FAULT
3873	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKABALLAPURA I/A	22:07	22:19	00:12	TRIPPED ON FAULT
3874	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	03:55	04:00	00:05	TRIPPED ON FAULT
3875	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	03:55	04:00	00:05	TRIPPED ON FAULT
3876	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	11:15	11:23	00:08	TRIPPED ON FAULT
3877	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	10:50	10:55	00:05	TRIPPED ON FAULT
3878	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	18:56	19:00	00:04	LINE CLEAR AVAILED
3879	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	14:15	14:20	00:05	TRIPPED ON FAULT
3880	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	14:20	14:35	00:15	LINE CLEAR AVAILED
3881	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	16:50	17:00	00:10	TRIPPED ON FAULT
3882	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MITTEMARI 220	04:45	04:50	00:05	TRIPPED ON FAULT
3883	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MITTEMARI 220	04:50	09:00	04:10	LINE CLEAR AVAILED
3884	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SULIBELE	16:47	16:56	00:09	TRIPPED ON FAULT
3885	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	13:55	14:33	00:38	MAIN SUPPLY FAILURE
3886	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	19:35	19:40	00:05	LINE CLEAR AVAILED
3887	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	15:23	15:35	00:12	MAIN SUPPLY FAILURE
3888	25-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	09:21	09:29	00:08	TRIPPED ON FAULT
3889	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	00:48	00:56	00:08	TRIPPED ON FAULT
3890	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	09:18	09:50	00:32	TRIPPED ON FAULT
3891	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	13:14	13:25	00:11	TRIPPED ON FAULT
3892	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	13:25	13:26	00:01	LINE CLEAR AVAILED
3893	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	DEVANAHALLI 66	07:39	07:49	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3894	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 220	13:46	15:06	01:20	LINE CLEAR AVAILED
3895	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	11:20	11:48	00:28	MAIN SUPPLY FAILURE
3896	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KONDASAPURA	18:56	19:00	00:04	LINE CLEAR AVAILED
3897	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SOMAYAJANAHALLI	13:54	14:10	00:16	TRIPPED ON FAULT
3898	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	13:55	14:20	00:25	MAIN SUPPLY FAILURE
3899	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	19:35	19:40	00:05	LINE CLEAR AVAILED
3900	25-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	14:46	14:50	00:04	TRIPPED ON FAULT
3901	25-Jul-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	15:23	15:35	00:12	MAIN SUPPLY FAILURE
3902	25-Jul-24	BANGALORE	220	LINE	220KV CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	09:38	12:27	02:49	TRIPPED ON FAULT
3903	25-Jul-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 3	NO STATION AFFECTED	11:20	12:10	00:50	TRIPPED ON FAULT
3904	25-Jul-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - KHODAYS 220	NO STATION AFFECTED	07:40	08:17	00:37	TRIPPED ON FAULT
3905	25-Jul-24	BANGALORE	220	TRANSFORMER	HV1	KANAKAPURA 220	19:40	19:41	00:01	LINE CLEAR AVAILED
3906	25-Jul-24	BANGALORE	220	TRANSFORMER	HV1	YARANDANAHALLI 220	15:23	15:35	00:12	TRIPPED ON FAULT
3907	25-Jul-24	BANGALORE	220	TRANSFORMER	HV2	KOLAR 220	11:20	11:43	00:23	TRIPPED ON FAULT
3908	25-Jul-24	BANGALORE	220	TRANSFORMER	HV2	VIKAS TECH PARK 220	13:55	14:20	00:25	TRIPPED ON FAULT
3909	25-Jul-24	BANGALORE	220	TRANSFORMER	HV2	YARANDANAHALLI 220	15:23	15:54	00:31	TRIPPED ON FAULT
3910	25-Jul-24	BANGALORE	220	TRANSFORMER	HV3	KOLAR 220	11:20	11:43	00:23	TRIPPED ON FAULT
3911	25-Jul-24	GULBARGA	66	LINE	NEELGUNDA-PUNABGHATTA	PUNABGHATTA_66, UCCHANGIDURGA_66, PALLAGATTE_66, BILCHOD_66	10:53	11:01	00:08	TRIPPED ON FAULT
3912	25-Jul-24	GULBARGA	110	LINE	HALIKHAED-HUMNABAD	HALIKHED_110	04:20	05:10	00:50	TRIPPED ON FAULT
3913	25-Jul-24	GULBARGA	110	TRANSFORMER	HV1	KANAKAGIRI_110	09:05	09:40	00:35	LINE CLEAR AVAILED
3914	25-Jul-24	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUDRA_110	19:40	19:55	00:15	LINE CLEAR AVAILED
3915	25-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	12:52	13:01	00:09	TRIPPED ON FAULT
3916	25-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	04:08	04:16	00:08	TRIPPED ON FAULT
3917	25-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	04:43	04:57	00:14	TRIPPED ON FAULT
3918	25-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	11:20	14:50	03:30	LINE CLEAR AVAILED
3919	25-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	21:17	21:24	00:07	TRIPPED ON FAULT
3920	25-Jul-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	03:37	03:49	00:12	TRIPPED ON FAULT
3921	25-Jul-24	GULBARGA	110	LINE	LINGASUGUR-KRPL	LINGASUGUR_220	04:12	04:18	00:06	TRIPPED ON FAULT
3922	25-Jul-24	GULBARGA	110	LINE	SEDAM-CHINCHOLI-2	CHINCHOLI_110	23:46	23:59	00:13	TRIPPED ON FAULT
3923	25-Jul-24	GULBARGA	110	LINE	SEDAM-HUMNABAD-2	HUMNABAD_110	04:40	04:55	00:15	TRIPPED ON FAULT
3924	25-Jul-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	10:30	14:45	04:15	LINE CLEAR AVAILED
3925	25-Jul-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	10:30	14:45	04:15	LINE CLEAR AVAILED
3926	25-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	13:43	17:45	04:02	LINE CLEAR AVAILED
3927	25-Jul-24	GULBARGA	110	LINE	YADRAMI-MANDEWAL	BAGEWADI_110	18:34	18:48	00:14	TRIPPED ON FAULT
3928	25-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC ENERGY_IPP	BADALADUKU_220	10:40	11:10	00:30	LINE CLEAR AVAILED
3929	25-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC ENERGY_IPP	BADALADUKU_220	16:25	16:40	00:15	TRIPPED ON FAULT
3930	25-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
3931	25-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
3932	25-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3933	25-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	9:24(22.07.2024)	18:17(25.07.2024)	80:52 hrs	LINE CLEAR AVAILED
3934	25-Jul-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	10:26	10:35	00:09	TRIPPED ON FAULT
3935	25-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	9:24(22.07.2024)	18:17(25.07.2024)	80:52 hrs	MAIN SUPPLY FAILURE
3936	25-Jul-24	HASSAN	66	LINE	BANDISH-RAMNATHPURA	BANDISHETTIHALLI_66	11:13	11:28	00:15	LINE CLEAR AVAILED
3937	25-Jul-24	HASSAN	66	LINE	BHADRA-SHMGA 2	bhadara_gen	07:17	07:35	00:18	TRIPPED ON FAULT
3938	25-Jul-24	HASSAN	66	LINE	HNPR2-MYSOR1	HOLENARASIPURA_220	19:05	19:15	00:10	TRIPPED ON FAULT
3939	25-Jul-24	HASSAN	66	TRANSFORMER	HV1	HNPURA_66	14:30	14:55	00:25	LINE CLEAR AVAILED
3940	25-Jul-24	HASSAN	66	TRANSFORMER	HV2	HNPURA_66	12:57	14:55	01:58	LINE CLEAR AVAILED
3941	25-Jul-24	HASSAN	66	TRANSFORMER	HV2	SAKALE	09:25	10:10	00:45	TRIPPED ON FAULT
3942	25-Jul-24	HASSAN	66	LINE	TAVAREC-MRS	TAVARECHATNAHALLI_66	12:25	12:45	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3943	25-Jul-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	23:20(25.07.2024)			TRIPPED ON FAULT
3944	25-Jul-24	HASSAN	110	LINE	ANANDA-LPH(LST-4)	ANANDAPURA_110	23:36(25.07.2024)			LINE CLEAR AVAILED
3945	25-Jul-24	HASSAN	110	LINE	ANANDA-LPH(LST-4)	ANANDAPURA_110	22:15	23:16	01:01	TRIPPED ON FAULT
3946	25-Jul-24	HASSAN	110	LINE	HALADY1-HIRIYADKA	HALADY_110	11:48	12:25	00:37	TRIPPED ON FAULT
3947	25-Jul-24	HASSAN	110	LINE	HGUNJE-HALADY	HGGUNJE_220	11:48	15:46	03:58	TRIPPED ON FAULT
3948	25-Jul-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	06:19	09:12	02:53	TRIPPED ON FAULT
3949	25-Jul-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	11:48	12:24	00:36	MAIN SUPPLY FAILURE
3950	25-Jul-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	11:10	13:30	02:20	LINE CLEAR AVAILED
3951	25-Jul-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	20:07(24.07.2024)	13:08(25.07.2024)	17:00 hrs	LINE CLEAR AVAILED
3952	25-Jul-24	HASSAN	110	TRANSFORMER	HV1	NAVUNDA_110	10:29	10:40	00:11	TRIPPED ON FAULT
3953	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	HALADY_110	11:10	13:30	02:20	LINE CLEAR AVAILED
3954	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	KARKALA_110	06:45	06:54	00:09	TRIPPED ON FAULT
3955	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	NAVUNDA_110	06:08	09:31	03:23	TRIPPED ON FAULT
3956	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	09:51	16:49	06:58	TRIPPED ON FAULT
3957	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	16:49	19:26	02:37	TRIPPED ON FAULT
3958	25-Jul-24	HASSAN	110	TRANSFORMER	HV2	NITTUR_110	12:08	12:42	00:34	LINE CLEAR AVAILED
3959	25-Jul-24	HASSAN	110	TRANSFORMER	HV3	ANAVATTI_110	20:10	20:14	00:04	LINE CLEAR AVAILED
3960	25-Jul-24	HASSAN	110	LINE	JOG-JLT3	mghejog_gen	10:53	11:26	00:33	TRIPPED ON FAULT
3961	25-Jul-24	HASSAN	110	LINE	JOG-JLT4	mghejog_gen	10:53	11:26	00:33	TRIPPED ON FAULT
3962	25-Jul-24	HASSAN	110	LINE	JOG-JST2	mghejog_gen	23:17(25.02.2024)			TRIPPED ON FAULT
3963	25-Jul-24	HASSAN	110	LINE	JOG-JST2	mghejog_gen	10:53	11:24	00:31	TRIPPED ON FAULT
3964	25-Jul-24	HASSAN	110	LINE	JOG-NK1	mghejog_gen	10:55	11:58	01:03	LINE CLEAR AVAILED
3965	25-Jul-24	HASSAN	110	LINE	LPH-MGHE 1	LPH_GEN	23:17(25.07.2024)			TRIPPED ON FAULT
3966	25-Jul-24	HASSAN	110	LINE	MADHUVBRK_HRD	MADHUVANA_110	06:20	09:15	02:55	MAIN SUPPLY FAILURE
3967	25-Jul-24	HASSAN	110	LINE	SAGARA-ALKLA	SAGARA_110	22:20(25.07.2024)			LINE CLEAR AVAILED
3968	25-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	22:20(25.07.2024)			MAIN SUPPLY FAILURE
3969	25-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	22:15	22:18	00:03	TRIPPED ON FAULT
3970	25-Jul-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	03:28	03:39	00:11	MAIN SUPPLY FAILURE
3971	25-Jul-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	03:28	03:39	00:11	MAIN SUPPLY FAILURE
3972	25-Jul-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	03:28	03:39	00:11	MAIN SUPPLY FAILURE
3973	25-Jul-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	03:28	03:39	00:11	MAIN SUPPLY FAILURE
3974	25-Jul-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	15:54	16:42	00:48	LINE CLEAR AVAILED
3975	25-Jul-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	03:28	07:02	03:34	MAIN SUPPLY FAILURE
3976	25-Jul-24	HASSAN	220	LINE	HBNHL-LINE1	HEBBANAHALLI_400.	07:29	10:45	03:16	TRIPPED ON FAULT
3977	25-Jul-24	HASSAN	220	LINE	HGUNJE-LINE2	HGGUNJE_220	11:48	15:38	03:50	TRIPPED ON FAULT
3978	25-Jul-24	HASSAN	220	LINE	SHRAVITY-SHIRALKOPPA	sharavathy_gen	03:28	16:32	13:04	TRIPPED ON FAULT
3979	25-Jul-24	HASSAN	220	LINE	SHRAVITY-TALAGUPPA1	sharavathy_gen	10:33	14:27	03:54	LINE CLEAR AVAILED
3980	25-Jul-24	HASSAN	220	LINE	SHRAVITY-TALAGUPPA2	sharavathy_gen	12:26	12:36	00:10	LINE CLEAR AVAILED
3981	25-Jul-24	HASSAN	220	LINE	SHRAVITY-TALAGUPPA3	sharavathy_gen	18:47(24.07.2024)	13:33(25.07.2024)	18:45 hrs	LINE CLEAR AVAILED
3982	25-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	03:35	16:30	12:55	MAIN SUPPLY FAILURE
3983	25-Jul-24	HASSAN	220	LINE	TALAGU-SGS1	TALAGUPPA_400	10:33	14:27	03:54	LINE CLEAR AVAILED
3984	25-Jul-24	HASSAN	220	LINE	TALAGU-SGS2	TALAGUPPA_400	12:26	12:36	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3985	25-Jul-24	HASSAN	220	LINE	TALAGU-SGS3	TALAGUPPA_400	18:47(24.07.2024)	13:33(25.07.2024)	18:45 hrs	LINE CLEAR AVAILED
3986	25-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR3	varahi_gen	11:48	15:38	03:50	TRIPPED ON FAULT
3987	25-Jul-24	MYSORE	66	LINE	C R NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	07:53	07:58	00:04	TRIPPED ON FAULT
3988	25-Jul-24	MYSORE	66	LINE	C R NAGARA-HONGANURU	HONGANURU_66	06:57	07:06	00:09	TRIPPED ON FAULT
3989	25-Jul-24	MYSORE	66	LINE	HANNUR-AMPS_SOLAR	NO STATIONS EFFECTED	14:56	15:22	00:25	LINE CLEAR AVAILED
3990	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	12:02	14:09	02:07	LINE CLEAR AVAILED
3991	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA(K)_66	18:00	18:15	00:15	TRIPPED ON FAULT
3992	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOPPA_66	10:40	11:15	00:35	LINE CLEAR AVAILED
3993	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	KUSHALANAGARA_66	15:07	15:52	00:45	LINE CLEAR AVAILED
3994	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3995	25-Jul-24	MYSORE	66	TRANSFORMER	HV1	YERALLI HAND POST_66	07:30	07:35	00:05	TRIPPED ON FAULT
3996	25-Jul-24	MYSORE	66	TRANSFORMER	HV2	DUNDANAHALLI_66	11:08	16:55	05:46	LINE CLEAR AVAILED
3997	25-Jul-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	14:10	15:32	01:22	LINE CLEAR AVAILED
3998	25-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOPPA_66	11:20	11:50	00:30	LINE CLEAR AVAILED
3999	25-Jul-24	MYSORE	66	TRANSFORMER	HV2	SUNTIKOPPA_66	00:25	00:35	00:10	TRIPPED ON FAULT
4000	25-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4001	25-Jul-24	MYSORE	66	LINE	KOPPA -KASALAGERE	NO STATIONS EFFECTED	00:30	00:43	00:13	TRIPPED ON FAULT
4002	25-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220-PERIYAPATNA-1	NO STATIONS EFFECTED	01:04	01:17	00:13	TRIPPED ON FAULT
4003	25-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4004	25-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4005	25-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4006	25-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU-PONNAMPETE	NO STATIONS EFFECTED	01:40	01:47	00:06	TRIPPED ON FAULT
4007	25-Jul-24	MYSORE	66	LINE	SUTTUR-ALAMBUR LIS (EHT)	NO STATIONS EFFECTED	12:59	13:16	00:17	TRIPPED ON FAULT
4008	25-Jul-24	MYSORE	66	LINE	VAJAMANGALA-KADAKOLA-2	NO STATIONS EFFECTED	19:01	19:10	00:09	TRIPPED ON FAULT
4009	25-Jul-24	MYSORE	220	LINE	HOOTAGALLI-BASTHIPURA- 2	NO STATIONS EFFECTED	10:46	18:34	07:48	LINE CLEAR AVAILED
4010	25-Jul-24	MYSORE	220	LINE	HOOTAGALLI-VAJAMANGALA	NO STATIONS EFFECTED	12:14	13:28	01:14	LINE CLEAR AVAILED
4011	25-Jul-24	MYSORE	220	LINE	TUBINAKERE-BASTHIPURA	NO STATIONS EFFECTED	10:34	18:29	07:54	LINE CLEAR AVAILED
4012	25-Jul-24	MYSORE	220	LINE	TUBINAKERE-CHANNAPATNA	NO STATIONS EFFECTED	09:54	15:01	05:07	LINE CLEAR AVAILED
4013	25-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-1	MYLANAHALLI_66	17:05	17:59	00:54	LINE CLEAR AVAILED
4014	25-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2 KADAJJI_66	KADAJJI_66	06:31	06:40	00:09	TRIPPED ON FAULT
4015	25-Jul-24	TUMKUR	66	TRANSFORMER	12.5MVA TR-2 KUKKAWADA_66	KUKKAWADA_66	02:07	02:13	00:06	TRIPPED ON FAULT
4016	25-Jul-24	TUMKUR	66	TRANSFORMER	20MVA TR-2 HOSADURGA_66	HOSADURGA_66	23:00	23:11	00:11	TRIPPED ON FAULT
4017	25-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4018	25-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA,SASALUHALLA	18:57	19:22	00:25	TRIPPED ON FAULT
4019	25-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR,MALEBENNUR,DEVARBEL AKERE	23:52 (25.07.2024)	00:03 (26.07.2024)	00:11	TRIPPED ON FAULT
4020	25-Jul-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66,DASUDI,K.R.HALLI	14:42 (22.07.24)	21:52 (25.07.2024)	3days 7 hrs 10Min	TRIPPED ON FAULT
4021	25-Jul-24	TUMKUR	66	LINE	SIRA220-HIRIYUR2 220 LINE 2	SIRA_220	16:22	19:32	03:10	LINE CLEAR AVAILED
4022	25-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4023	25-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TR-1 (HV & LV SIDE)DAVANGERE_220	DAVANGERE_220	10:35	14:42	04:07	LINE CLEAR AVAILED
4024	25-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-1-220KV KIADB (HV & LV SIDE)	KIADB_220KV	20:11 (24.07.2024)	14:17 (25.07.2024)	18:06	TRIPPED ON FAULT
4025	25-Jul-24	TUMKUR	220	LINE	220KV SIRA-220KV HIRIYUR LINE 1	SIRA_220KV	18:52 (24.07.2024)	19:44 (25.07.2024)	1 Day 52 Min	TRIPPED ON FAULT
4026	25-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2 LINE	GUTUR_400KV	09:54	15:46	05:52	LINE CLEAR AVAILED
4027	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	AKSHYCOLONY_110	13:20	14:15	00:55	LINE CLEAR AVAILED
4028	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	14:50	15:06	00:16	LINE CLEAR AVAILED
4029	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	AKSHYCOLONY_110	13:20	14:15	00:55	LINE CLEAR AVAILED
4030	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	GOKAK_110	06:53	10:07	03:14	TRIPPED ON FAULT
4031	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KULAGERICROSS_110	14:21	15:49	01:28	LINE CLEAR AVAILED
4032	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	UCHAGOAN_110	12:56	13:38	00:42	LINE CLEAR AVAILED
4033	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	RANEBENNUR_220	13:30	15:03	01:33	LINE CLEAR AVAILED
4034	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	HUKKERI_110	08:30	08:40	00:10	TRIPPED ON FAULT
4035	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(10MVA)	SHIGGOAN_110	14:30	14:44	00:14	TRIPPED ON FAULT
4036	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (20MVA)	KULIGOD_110	15:07	16:20	01:13	LINE CLEAR AVAILED
4037	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (10MVA)	TUMMINAKATTI_110	15:17	15:50	00:33	LINE CLEAR AVAILED
4038	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA HV1)	ZALKI_110	17:03	17:12	00:09	LINE CLEAR AVAILED
4039	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	GOKAK_110	13:00	13:10	00:10	TRIPPED ON FAULT
4040	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	RANEBENNUR_220	13:32	16:25	02:53	LINE CLEAR AVAILED
4041	26-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA HV2)	ZALKI_110	17:03	17:12	00:09	LINE CLEAR AVAILED
4042	26-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-SUPA-1	AMBEWADI_220	22:17	22:34	00:17	TRIPPED ON FAULT
4043	26-Jul-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	23:18	23:31	00:13	TRIPPED ON FAULT
4044	26-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	08:50	14:43	05:53	LINE CLEAR AVAILED
4045	26-Jul-24	BAGALKOTE	110	LINE	HONNAVAR-MURDESHWAR	HONNAVAR_110	21:01	21:20	00:19	TRIPPED ON FAULT
4046	26-Jul-24	BAGALKOTE	110	LINE	KARWAR220- ARGA(KUMTA)	KARWAR_220	11:11 (26.07.2024)			TRIPPED ON FAULT
4047	26-Jul-24	BAGALKOTE	110	LINE	KERUR-BADAMI	KERUR_110	14:07	16:10	02:03	LINE CLEAR AVAILED
4048	26-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	02:20	04:54	02:34	TRIPPED ON FAULT
4049	26-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	21:19 (25.07.2024)	11:10 (26.07.2024)	13:51	TRIPPED ON FAULT
4050	26-Jul-24	BAGALKOTE	110	LINE	KUMTA-SIRSI2	KUMTA_110	00:17	13:30	13:13	LINE CLEAR AVAILED
4051	26-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- GSML1	MAHALINGAPUR_220	6:13	6:21	00:08	LINE CLEAR AVAILED
4052	26-Jul-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- GSML2	MAHALINGAPUR_220	5:57	6:22	00:25	LINE CLEAR AVAILED
4053	26-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4054	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	00:01	00:16	00:15	LINE CLEAR AVAILED
4055	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	01:10	01:16	00:06	LINE CLEAR AVAILED
4056	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	01:26	01:30	00:04	LINE CLEAR AVAILED
4057	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	11:32	11:58	00:26	LINE CLEAR AVAILED
4058	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	12:08	12:16	00:08	LINE CLEAR AVAILED
4059	26-Jul-24	BAGALKOTE	110	LINE	MURDESHWAR-RAILWAY	MURDESHWAR_110	21:01	21:23	00:22	LINE CLEAR AVAILED
4060	26-Jul-24	BAGALKOTE	110	LINE	NARENDRA220-BELUR1	NARENDRA_220	13:17	13:27	00:10	LINE CLEAR AVAILED
4061	26-Jul-24	BAGALKOTE	110	LINE	NARENDRA220-BELUR2	NARENDRA_220	12:52	13:13	00:21	LINE CLEAR AVAILED
4062	26-Jul-24	BAGALKOTE	110	LINE	NAVALAGUND-BIDNAL	NAVALAGUND_110	08:24	08:58	00:34	LINE CLEAR AVAILED
4063	26-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4064	26-Jul-24	BAGALKOTE	110	LINE	RANEBENNUR- RATTIHALLI (TUMMINKATTE)	RANEBENNUR_220	20:31 (25.07.2024)	17:03 (26.07.2024)	20:36:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4065	26-Jul-24	BAGALKOTE	110	LINE	RON-NAREGAL	STATION NOT AFFECTED RON_110	16:44 (25.07.2024)			LINE CLEAR AVAILED
4066	26-Jul-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	00:02	13:37	13:35	TRIPPED ON FAULT
4067	26-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-BENAKATTI	SOUDATTI_220	8:51	9:11	00:20	TRIPPED ON FAULT
4068	26-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4069	26-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_220	6:29	7:04	00:35	LINE CLEAR AVAILED
4070	26-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-BILAGI	VAJRAMATTI_220	6:30	7:07	00:37	LINE CLEAR AVAILED
4071	26-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-MANTUR(MUDHOL)	VAJRAMATTI_220	6:29	6:58	00:29	LINE CLEAR AVAILED
4072	26-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220-MANTUR1&2	VAJRAMATTI_220	6:29	7:04	00:35	LINE CLEAR AVAILED
4073	26-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
4074	26-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
4075	26-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	NARENDRA_220	12:20	12:29	00:09	LINE CLEAR AVAILED
4076	26-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	VAJRAMATTI_220	6:14	6:51	00:37	TRIPPED ON FAULT
4077	26-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	MKHUBLI_220	13:00 (25.07.2024)	17:04 (26.07.2024)	28:04:00	TRIPPED ON FAULT
4078	26-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	NARENDRA_220	13:26	13:31	00:05	LINE CLEAR AVAILED
4079	26-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	AMBEWADI_220	04:48	15:30	10:42	TRIPPED ON FAULT
4080	26-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI2	AMBEWADI_220	10:33	15:31	04:58	LINE CLEAR AVAILED
4081	26-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	05:13	15:11	09:58	TRIPPED ON FAULT
4082	26-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	19:47	20:40	00:53	TRIPPED ON FAULT
4083	26-Jul-24	BAGALKOTE	220	LINE	ATHANI- MAHALINGPUR	ATHANI_220	6:13	6:29	00:16	TRIPPED ON FAULT
4084	26-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI2(ALAMATTI1)	BAGALKOT_220	7:40	7:46	00:06	LINE CLEAR AVAILED
4085	26-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATI2	BAGALKOT_220	6:13	7:03	00:50	TRIPPED ON FAULT
4086	26-Jul-24	BAGALKOTE	220	LINE	CHIKKODI-KUDACHI1	CHIKKODI_220	1:53	2:19	00:26	TRIPPED ON FAULT
4087	26-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	16:11 (25.07.2024)			TRIPPED ON FAULT
4088	26-Jul-24	BAGALKOTE	220	LINE	KUDACHI- CHIKKODI1	KUDACHI_220	01:53	02:18	00:25	TRIPPED ON FAULT
4089	26-Jul-24	BAGALKOTE	220	LINE	KUDACHI- MAHALINGAPUR	KUDACHI_220	15:06	16:31	01:25	LINE CLEAR AVAILED
4090	26-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI1	MAHALINGAPUR_220	6:13	6:55	00:42	TRIPPED ON FAULT
4091	26-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	6:13	9:50	03:37	TRIPPED ON FAULT
4092	26-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI2	MAHALINGAPUR_220	10:45	12:57	02:12	LINE CLEAR AVAILED
4093	26-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	19:33 (25.07.2024)	16:47 (26.07.2024)	21:14:00	TRIPPED ON FAULT
4094	26-Jul-24	BAGALKOTE	220	LINE	SIRSI220- SHARAVATHY2	SIRSI_220	17:08	21:40	04:32	LINE CLEAR AVAILED
4095	26-Jul-24	BAGALKOTE	220	LINE	VAJRAMATTI-ENERGON	VAJRAMATTI_220	19:20	23:14	03:54	LINE CLEAR AVAILED
4096	26-Jul-24	BAGALKOTE	220	LINE	VAJRAMATTI-MAHALINGPUR2	VAJRAMATTI_220	6:13	17:35	11:22	TRIPPED ON FAULT
4097	26-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 1	NO STATION AFFECTED	17:16	17:30	00:14	TRIPPED ON FAULT
4098	26-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	10:08	10:31	00:23	LINE CLEAR AVAILED
4099	26-Jul-24	BANGALORE	66	LINE	66KV DRDO - T D HALLI (MALLASANDRA)	MALLASANDRA	10:35	10:40	00:05	LINE CLEAR AVAILED
4100	26-Jul-24	BANGALORE	66	LINE	66KV GANJIGUNTE - PALLICHERLU	PALLICHERLU	17:16	17:28	00:12	TRIPPED ON FAULT
4101	26-Jul-24	BANGALORE	66	LINE	66KV GANJIGUNTE - PALLICHERLU	PALLICHERLU	20:30	20:56	00:26	TRIPPED ON FAULT
4102	26-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	22:15	22:20	00:05	LINE CLEAR AVAILED
4103	26-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	MARALAVADI, CHATRA, GODUR	12:50	15:25	02:35	LINE CLEAR AVAILED
4104	26-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - KEMBODI	KEMBODI	12:00	12:05	00:05	LINE CLEAR AVAILED
4105	26-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4106	26-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	DODDERI, CHANDRAPPA CIRCLE	07:28	08:09	00:41	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4107	26-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	07:28	08:35	01:07	TRIPPED ON FAULT
4108	26-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	14:14	14:28	00:14	TRIPPED ON FAULT
4109	26-Jul-24	BANGALORE	66	LINE	66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA	PGCIL, SUGUTUR	12:00	12:05	00:05	LINE CLEAR AVAILED
4110	26-Jul-24	BANGALORE	66	LINE	66KV T D HALLI (MALLASANDRA) - DALASANUR	MALLASANDRA	16:55	16:58	00:03	LINE CLEAR AVAILED
4111	26-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	17:55	18:00	00:05	LINE CLEAR AVAILED
4112	26-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - BANASHANKARI	BANASHANKARI	07:29	07:40	00:11	TRIPPED ON FAULT
4113	26-Jul-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT	SIR MV LAYOUT	07:28	07:40	00:12	TRIPPED ON FAULT
4114	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHAKAVELU	10:30	10:32	00:02	LINE CLEAR AVAILED
4115	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	13:47	13:54	00:07	TRIPPED ON FAULT
4116	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NG HULKUR	14:15	14:25	00:10	MAIN SUPPLY FAILURE
4117	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SAMANDURU	13:25	13:55	00:30	LINE CLEAR AVAILED
4118	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	Y HUNSENAHALLI	12:50	12:55	00:05	LINE CLEAR AVAILED
4119	26-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	14:05	14:30	00:25	LINE CLEAR AVAILED
4120	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	13:34	13:42	00:08	TRIPPED ON FAULT
4121	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	15:28	15:37	00:09	TRIPPED ON FAULT
4122	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BTM 4TH PHASE	06:20	06:35	00:15	TRIPPED ON FAULT
4123	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHAKAVELU	11:00	11:15	00:15	LINE CLEAR AVAILED
4124	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KANAKAPURA 66	09:00	09:05	00:05	TRIPPED ON FAULT
4125	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	12:06	12:09	00:03	LINE CLEAR AVAILED
4126	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NG HULKUR	14:05	14:15	00:10	MAIN SUPPLY FAILURE
4127	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SAMANDURU	14:05	17:35	03:30	LINE CLEAR AVAILED
4128	26-Jul-24	BANGALORE	66	TRANSFORMER	HV2	SHOBHA CITY	20:56	21:04	00:08	TRIPPED ON FAULT
4129	26-Jul-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	06:47	07:17	00:30	LINE CLEAR AVAILED
4130	26-Jul-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - MAGADI CKT 2	NO STATION AFFECTED	18:55	19:30	00:35	TRIPPED ON FAULT
4131	26-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	08:34	23:59	15:25	LOAD CURTAILMENT
4132	26-Jul-24	GULBARGA	66	LINE	BADALADUKU-BANVEKAL	ABRSL_IPP	11:35	13:00	01:25	LINE CLEAR AVAILED
4133	26-Jul-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	BANVEKAL_66,ABRSL_IPP	11:22	11:35	00:13	TRIPPED ON FAULT
4134	26-Jul-24	GULBARGA	66	TRANSFORMER	HV2	BENNEHALLI_66	10:40	13:00	02:20	LINE CLEAR AVAILED
4135	26-Jul-24	GULBARGA	66	TRANSFORMER	HV3 & HV4	ITTAGI_220	10:37	16:45	06:08	LINE CLEAR AVAILED
4136	26-Jul-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66	19:05	19:25	00:20	TRIPPED ON FAULT
4137	26-Jul-24	GULBARGA	110	LINE	GUGAL-RAICHUR	GUGAL_110, GABUR_110	05:00	05:15	00:15	TRIPPED ON FAULT
4138	26-Jul-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	MALLAPUR_110	16:50	17:03	00:13	TRIPPED ON FAULT
4139	26-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	01:30	05:48	04:18	LINE CLEAR AVAILED
4140	26-Jul-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	09:27	11:06	01:39	LINE CLEAR AVAILED
4141	26-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	11:05	20:20	09:15	LINE CLEAR AVAILED
4142	26-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
4143	26-Jul-24	GULBARGA	220	LINE	LINGASUGUR-KUSHTAGI	LINGASUGUR_220	13:40	17:27	03:47	TRIPPED ON FAULT
4144	26-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
4145	26-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4146	26-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	03:47	11:05	07:18	TRIPPED ON FAULT
4147	26-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	15:37	15:40	00:03	LINE CLEAR AVAILED
4148	26-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	15:37	15:40	00:03	LINE CLEAR AVAILED
4149	26-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	03:52	10:01	06:09	MAIN SUPPLY FAILURE
4150	26-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	10:46	11:05	00:19	MAIN SUPPLY FAILURE
4151	26-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	21:47	22:16	00:29	MAIN SUPPLY FAILURE
4152	26-Jul-24	HASSAN	66	LINE	BALEHN-L2	BALEHONNUR_66	03:52	10:01	06:09	MAIN SUPPLY FAILURE
4153	26-Jul-24	HASSAN	66	LINE	BALEHN-L2	BALEHONNUR_66	10:46	11:05	00:19	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4154	26-Jul-24	HASSAN	66	LINE	CRPATNA-HNPURA	CRPATNA_220	12:13	12:56	00:43	LINE CLEAR AVAILED
4155	26-Jul-24	HASSAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_66	15:30	15:51	00:21	LINE CLEAR AVAILED
4156	26-Jul-24	HASSAN	66	LINE	HNPURA	SINGAPURA_66	11:23	12:10	00:47	MAIN SUPPLY FAILURE
4157	26-Jul-24	HASSAN	66	TRANSFORMER	HV1	ALDUR_66	10:48	15:40	04:52	LINE CLEAR AVAILED
4158	26-Jul-24	HASSAN	66	TRANSFORMER	HV1	ALDUR_66	15:54	15:56	00:02	LINE CLEAR AVAILED
4159	26-Jul-24	HASSAN	66	TRANSFORMER	HV1	ARAKALGUD_66	15:20	15:41	00:21	TRIPPED ON FAULT
4160	26-Jul-24	HASSAN	66	TRANSFORMER	HV1	GORUR_66	16:43	16:50	00:07	LINE CLEAR AVAILED
4161	26-Jul-24	HASSAN	66	TRANSFORMER	HV1 CB	NAGARTHI_66	13:21	14:23	01:02	LINE CLEAR AVAILED
4162	26-Jul-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	23:20(25.07.2024)	0:08(26.07.2024)	0:47 hrs	LINE CLEAR AVAILED
4163	26-Jul-24	HASSAN	110	LINE	ANANDA-LPH(LST-4)	ANANDAPURA_110	23:17(25.07.2024)	10:04(26.07.20024)	10:46 hrs	MAIN SUPPLY FAILURE
4164	26-Jul-24	HASSAN	110	LINE	HIRIYA-MADHUVANA	HIRIYADKA_110	10:05	10:13	00:08	LINE CLEAR AVAILED
4165	26-Jul-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	22:02(26.07.2024)			LINE CLEAR AVAILED
4166	26-Jul-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	11:11	11:25	00:14	TRIPPED ON FAULT
4167	26-Jul-24	HASSAN	110	TRANSFORMER	HV1	KUNDAPURA_110	18:55	19:15	00:20	TRIPPED ON FAULT
4168	26-Jul-24	HASSAN	110	TRANSFORMER	HV1	NAVUNDA_110	11:33	11:41	00:08	TRIPPED ON FAULT
4169	26-Jul-24	HASSAN	110	TRANSFORMER	HV2	ESSUR_110	09:36	10:45	01:09	LINE CLEAR AVAILED
4170	26-Jul-24	HASSAN	110	TRANSFORMER	HV2 CBreaker	KARKLA_110	08:18	08:29	00:11	TRIPPED ON FAULT
4171	26-Jul-24	HASSAN	110	LINE	JOG-JLT3	gen_mghe	12:42	13:52	01:10	TRIPPED ON FAULT
4172	26-Jul-24	HASSAN	110	LINE	JOG-JLT4	gen_mghe	01:36	02:16	00:40	TRIPPED ON FAULT
4173	26-Jul-24	HASSAN	110	LINE	JOG-JLT4	gen_mghe	12:42	14:56	02:14	TRIPPED ON FAULT
4174	26-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	23:17(25.02.2024)	0:20 (26.07.2024)	1:02 hrs	TRIPPED ON FAULT
4175	26-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	20:23(26.07.2024)			LINE CLEAR AVAILED
4176	26-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	01:36	02:30	00:54	TRIPPED ON FAULT
4177	26-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	12:42	15:01	02:19	TRIPPED ON FAULT
4178	26-Jul-24	HASSAN	110	LINE	JOG-NK1	gen_mghe	12:42	15:28	02:46	LINE CLEAR AVAILED
4179	26-Jul-24	HASSAN	110	LINE	KARKLA-L1 CBreaker	KARKLA_110	11:11	11:30	00:19	MAIN SUPPLY FAILURE
4180	26-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	11:11	11:31	00:20	TRIPPED ON FAULT
4181	26-Jul-24	HASSAN	110	LINE	KEMAR-KARKALA	KEMAR_220	11:11	19:12	08:01	TRIPPED ON FAULT
4182	26-Jul-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	11:11	11:30	00:19	TRIPPED ON FAULT
4183	26-Jul-24	HASSAN	110	LINE	KEMARManipal2	KEMAR_220	11:11	11:30	00:19	TRIPPED ON FAULT
4184	26-Jul-24	HASSAN	110	LINE	KEMARNANDHIKUR1	KEMAR_220	11:11	11:32	00:21	TRIPPED ON FAULT
4185	26-Jul-24	HASSAN	110	LINE	KEMARNANDHIKUR2	KEMAR_220	11:11	11:33	00:22	TRIPPED ON FAULT
4186	26-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	23:01	23:45	00:44	MAIN SUPPLY FAILURE
4187	26-Jul-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	23:01	23:48	00:47	MAIN SUPPLY FAILURE
4188	26-Jul-24	HASSAN	110	LINE	LPH-MGHE 1	gen_lph	23:17(25.07.2024)	13:35(26.07.2024)	14:17 hrs	LINE CLEAR AVAILED
4189	26-Jul-24	HASSAN	110	LINE	LPH-MGHE 2	gen_lph	01:35	02:17	00:42	TRIPPED ON FAULT
4190	26-Jul-24	HASSAN	110	LINE	LV1	KEMAR_220	11:13	11:28	00:15	TRIPPED ON FAULT
4191	26-Jul-24	HASSAN	110	LINE	LV1	KEMAR_220	16:09	16:20	00:11	LINE CLEAR AVAILED
4192	26-Jul-24	HASSAN	110	LINE	LV2	KEMAR_220	11:11	11:22	00:11	TRIPPED ON FAULT
4193	26-Jul-24	HASSAN	110	LINE	LV2	KEMAR_220	16:22	16:28	00:06	LINE CLEAR AVAILED
4194	26-Jul-24	HASSAN	110	LINE	LV3	KEMAR_220	11:11	11:35	00:24	TRIPPED ON FAULT
4195	26-Jul-24	HASSAN	110	LINE	LV3	KEMAR_220	16:35	16:40	00:05	LINE CLEAR AVAILED
4196	26-Jul-24	HASSAN	110	LINE	MADHUV-BRK_HRD CBrea	MADHUVANA_110	10:06	10:14	00:08	LINE CLEAR AVAILED
4197	26-Jul-24	HASSAN	110	LINE	MADHUV-KUNDAPURA	MADHUVANA_110	10:06	10:14	00:08	MAIN SUPPLY FAILURE
4198	26-Jul-24	HASSAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	11:11	11:33	00:22	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4199	26-Jul-24	HASSAN	110	LINE	MANIPAL-KEMAR1	MANIPAL_110	11:11	11:30	00:19	MAIN SUPPLY FAILURE
4200	26-Jul-24	HASSAN	110	LINE	SAGARA-ALKLA	SAGARA_110	22:20(25.07.2024)	12:12(26.07.2024)	12:54 hrs	LINE CLEAR AVAILED
4201	26-Jul-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	20:23(26.07.2024)			LINE CLEAR AVAILED
4202	26-Jul-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	01:37	02:24	00:47	MAIN SUPPLY FAILURE
4203	26-Jul-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	12:42	15:01	02:19	TRIPPED ON FAULT
4204	26-Jul-24	HASSAN	110	LINE	SAGARA-SORABA	SAGARA_110	22:20(25.07.2024)	0:10(26.07.2024)	0:49 hrs	MAIN SUPPLY FAILURE
4205	26-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	23:01	23:48	00:47	MAIN SUPPLY FAILURE
4206	26-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	23:01 (26.04.2024)			MAIN SUPPLY FAILURE
4207	26-Jul-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	01:35	01:46	00:11	MAIN SUPPLY FAILURE
4208	26-Jul-24	HASSAN	110	LINE	SHRLKP-BARANG	SHIRALKOPPA_220	18:45	18:53	00:08	MAIN SUPPLY FAILURE
4209	26-Jul-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	01:35	01:46	00:11	MAIN SUPPLY FAILURE
4210	26-Jul-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	01:35	01:46	00:11	MAIN SUPPLY FAILURE
4211	26-Jul-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	01:35	01:46	00:11	MAIN SUPPLY FAILURE
4212	26-Jul-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	01:35	01:46	00:11	MAIN SUPPLY FAILURE
4213	26-Jul-24	HASSAN	220	TRANSFORMER	HV1	KEMAR_220	11:13	11:28	00:15	TRIPPED ON FAULT
4214	26-Jul-24	HASSAN	220	TRANSFORMER	HV1	KEMAR_220	16:09	16:20	00:11	LINE CLEAR AVAILED
4215	26-Jul-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	11:11	11:22	00:11	TRIPPED ON FAULT
4216	26-Jul-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	16:22	16:28	00:06	LINE CLEAR AVAILED
4217	26-Jul-24	HASSAN	220	TRANSFORMER	HV3	KEMAR_220	11:11	11:35	00:24	TRIPPED ON FAULT
4218	26-Jul-24	HASSAN	220	TRANSFORMER	HV3	KEMAR_220	16:35	16:40	00:05	LINE CLEAR AVAILED
4219	26-Jul-24	HASSAN	220	LINE	KEMAR-UPCL2	KEMAR_220	11:11	11:19	00:08	TRIPPED ON FAULT
4220	26-Jul-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	12:51	13:34	00:43	LINE CLEAR AVAILED
4221	26-Jul-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	21:42(26.07.2024)			TRIPPED ON FAULT
4222	26-Jul-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	09:09	18:04	08:55	LINE CLEAR AVAILED
4223	26-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH1	MRSMSG_220	02:38	10:37	07:59	TRIPPED ON FAULT
4224	26-Jul-24	HASSAN	220	LINE	MRSSHM-VARAH2	MRSMSG_220	02:37	10:37	08:00	TRIPPED ON FAULT
4225	26-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	18:43(26.07.2024)			TRIPPED ON FAULT
4226	26-Jul-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	01:35	15:04	13:29	TRIPPED ON FAULT
4227	26-Jul-24	HASSAN	220	LINE	SHRAVTY-SIRISI 1	gen_sharavathy	17:08	21:40	04:32	LINE CLEAR AVAILED
4228	26-Jul-24	HASSAN	220	LINE	SHRAVTY-SIRISI 2	gen_sharavathy	01:25	16:48	15:23	TRIPPED ON FAULT
4229	26-Jul-24	HASSAN	220	LINE	SHRAVTY-ST3	gen_sharavathy	07:19	14:33	07:14	TRIPPED ON FAULT
4230	26-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	18:43(26.07.2024)			MAIN SUPPLY FAILURE
4231	26-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	01:35	15:04	13:29	TRIPPED ON FAULT
4232	26-Jul-24	HASSAN	220	LINE	TALAGU-ST3	TALAGUPPA_400	07:18	14:33	07:15	TRIPPED ON FAULT
4233	26-Jul-24	HASSAN	220	LINE	VARAH1-KEMAR1	gen_varahi	12:51	13:34	00:43	LINE CLEAR AVAILED
4234	26-Jul-24	HASSAN	220	LINE	VARAH1-KEMAR2	gen_varahi	21:42(26.07.2024)			TRIPPED ON FAULT
4235	26-Jul-24	HASSAN	220	LINE	VARAH1-SHIMOGA1	gen_varahi	02:38	10:37	07:59	TRIPPED ON FAULT
4236	26-Jul-24	HASSAN	220	LINE	VARAH1-SHIMOGA2	gen_varahi	02:37	10:37	08:00	TRIPPED ON FAULT
4237	26-Jul-24	MYSORE	66	LINE	ATTAGOLIPURA-HONNAHALLI	ATTIGULIPURA_66	08:33	08:40	00:07	LINE CLEAR AVAILED
4238	26-Jul-24	MYSORE	66	LINE	CHAMARAJANAGARA 220-CHANDAKAVADI	CHANDAKAVADI_66	12:51	15:09	02:17	LINE CLEAR AVAILED
4239	26-Jul-24	MYSORE	66	LINE	DK MAIDANA-JYOTINAGARA	NO STATIONS EFFECTED	10:35	11:00	00:24	LINE CLEAR AVAILED
4240	26-Jul-24	MYSORE	66	LINE	DK MAIDANA-JYOTINAGARA	NO STATIONS EFFECTED	14:52	15:12	00:20	LINE CLEAR AVAILED
4241	26-Jul-24	MYSORE	66	LINE	HOOTAGALLI 220KV-BELAGOLA	NO STATIONS EFFECTED	10:01	15:29	05:27	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4242	26-Jul-24	MYSORE	66	LINE	HOOTAGALLI 220KV-FTS1	NO STATIONS EFFECTED	10:50	10:55	00:05	LINE CLEAR AVAILED
4243	26-Jul-24	MYSORE	66	LINE	HOOTAGALLI 220KV-FTS2	NO STATIONS EFFECTED	10:50	10:55	00:05	LINE CLEAR AVAILED
4244	26-Jul-24	MYSORE	66	LINE	HOOTAGALLI 220KV-KHB COLONY	NO STATIONS EFFECTED	09:58	15:11	05:13	LINE CLEAR AVAILED
4245	26-Jul-24	MYSORE	66	LINE	HOOTAGALLI 220KV-VIJAYANAGARA	NO STATIONS EFFECTED	10:14	10:16	00:02	LINE CLEAR AVAILED
4246	26-Jul-24	MYSORE	66	TRANSFORMER	HV1	CHIKKA_MANDYA_66	11:15	14:10	02:54	LINE CLEAR AVAILED
4247	26-Jul-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	10:45	12:50	02:05	LINE CLEAR AVAILED
4248	26-Jul-24	MYSORE	66	TRANSFORMER	HV1	HOOTAGALLY_220	11:06	11:10	00:04	LINE CLEAR AVAILED
4249	26-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4250	26-Jul-24	MYSORE	66	TRANSFORMER	HV1	THUMBLA_66	11:43	11:50	00:07	LINE CLEAR AVAILED
4251	26-Jul-24	MYSORE	66	TRANSFORMER	HV2	HAMPAPURA_66	12:50	14:25	01:35	LINE CLEAR AVAILED
4252	26-Jul-24	MYSORE	66	TRANSFORMER	HV2	HOOTAGALLY_220	11:06	11:11	00:04	LINE CLEAR AVAILED
4253	26-Jul-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_220	00:45	00:56	00:11	TRIPPED ON FAULT
4254	26-Jul-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_220	11:44	13:16	01:31	LINE CLEAR AVAILED
4255	26-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4256	26-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220KV-PERIYAPATNA 1	NO STATIONS EFFECTED	22:03	22:19	00:16	TRIPPED ON FAULT
4257	26-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220KV-RAMANATHAPURA 1	ALUR SIDDAPURA_66 KANAGAL_66 CHIKKABOMMANAHALLI_66, RUDRAPATNA_66	17:50	18:10	00:20	TRIPPED ON FAULT
4258	26-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4259	26-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4260	26-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4261	26-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	06:11	14:34	08:22	TRIPPED ON FAULT
4262	26-Jul-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	18:15	18:22	00:07	TRIPPED ON FAULT
4263	26-Jul-24	MYSORE	66	LINE	PONNAMPETE-HANAGODU	NO STATIONS EFFECTED	06:11	14:34	08:22	TRIPPED ON FAULT
4264	26-Jul-24	MYSORE	66	LINE	PONNAMPETE-HANAGODU	NO STATIONS EFFECTED	18:14	18:26	00:11	TRIPPED ON FAULT
4265	26-Jul-24	MYSORE	66	TRANSFORMER	THUMBLA-HV2	THUMBLA_66	11:43	11:50	00:07	LINE CLEAR AVAILED
4266	26-Jul-24	MYSORE	220	TRANSFORMER	HV2	HOOTAGALLY_220	11:17	13:45	02:27	LINE CLEAR AVAILED
4267	26-Jul-24	MYSORE	220	LINE	KADAKOLA 220KV-BASTIPURA1	NO STATIONS EFFECTED	09:58	14:31	04:33	LINE CLEAR AVAILED
4268	26-Jul-24	MYSORE	220	LINE	KADAKOLA 220KV-BASTIPURA2	NO STATIONS EFFECTED	14:39	19:09	04:29	LINE CLEAR AVAILED
4269	26-Jul-24	MYSORE	220	LINE	TUBINAKERE 220KV-BASTIPURA 220KV	NO STATIONS EFFECTED	09:31	19:55	10:24	LINE CLEAR AVAILED
4270	26-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4271	26-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV ANAGODU LINE	66KV ANAGODU,ATTTIGERE	00:14	00:49	00:35	TRIPPED ON FAULT
4272	26-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV ANAGODU LINE	66KV ANAGODU,ATTTIGERE	01:18	01:28	00:10	TRIPPED ON FAULT
4273	26-Jul-24	TUMKUR	66	LINE	66KV PANDARAHALLI-66KV HOLALKERE LINE	66KV HOLALKERE,CHIKKAJAJUR,SASAL UHALLA	01:45	01:54	00:09	TRIPPED ON FAULT
4274	26-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	02:40	07:15	03:09	MAIN SUPPLY FAILURE
4275	26-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	11:05	13:30	04:09	MAIN SUPPLY FAILURE
4276	26-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	14:45	15:05	05:09	MAIN SUPPLY FAILURE
4277	26-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66	15:08	17:25	06:09	MAIN SUPPLY FAILURE
4278	26-Jul-24	TUMKUR	66	LINE	MALEBENNUR_66-HONNALLI_220KV	MALEBENNUR_66	00:00	00:05	01:09	MAIN SUPPLY FAILURE
4279	26-Jul-24	TUMKUR	66	LINE	MALEBENNUR_66-HONNALLI_220KV	MALEBENNUR_66	00:50	01:00	01:09	MAIN SUPPLY FAILURE
4280	26-Jul-24	TUMKUR	66	LINE	MALEBENNUR_66-HONNALLI_220KV	MALEBENNUR_66	10:30	18:00	02:09	LINE CLEAR AVAILED
4281	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-1	BELLAVI_66	11:21	11:26	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4282	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4283	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	MADHUGIRI_220KV	16:13	16:18	00:05	TRIPPED ON FAULT
4284	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	MADHUGIRI_66	16:28	16:40	00:12	TRIPPED ON FAULT
4285	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	SHYLAPURA_66	16:45	16:55	00:10	TRIPPED ON FAULT
4286	26-Jul-24	TUMKUR	66	TRANSFORMER	TR-2,12.5MVA	MALEBENNUR_66	18:15	18:50	00:35	TRIPPED ON FAULT
4287	26-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 1 -220KV	ANTHRASANAHALLI 220KV	12:21	12:46	00:25	LINE CLEAR AVAILED
4288	26-Jul-24	TUMKUR	220	LINE	GUTUR_400-BEERANAHALLI-1	GUTUR_400	17:02	18:30	01:28	LINE CLEAR AVAILED
4289	26-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS LINE	GUTTUR_400	10:50	23:48	12:58	LINE CLEAR AVAILED
4290	26-Jul-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 1KV	GUTUR_400	10:39	22:57	12:18	LINE CLEAR AVAILED
4291	26-Jul-24	TUMKUR	400	LINE	ICT-1	GUTUR_400	15:38	22:39	07:01	LINE CLEAR AVAILED
4292	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	SULTANPUR_110	15:09	16:44	01:35	LINE CLEAR AVAILED
4293	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BIDI_110	10:51	12:12	01:21	LINE CLEAR AVAILED
4294	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	10:09	10:22	00:13	LINE CLEAR AVAILED
4295	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	TALIKOTI_110	09:48	09:55	00:07	TRIPPED ON FAULT
4296	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	GOKAK_110	00:15	00:26	00:11	TRIPPED ON FAULT
4297	27-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	KULIGOD_110	13:13	15:35	02:22	TRIPPED ON FAULT
4298	27-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-SUPA-1	AMBEWADI_220	00:27	00:58	00:31	TRIPPED ON FAULT
4299	27-Jul-24	BAGALKOTE	110	LINE	KARWAR220- ARGA(KUMTA)	KARWAR_220	11:11 (26.07.2024)	19:18 (27.07.2024)	32:07:00	TRIPPED ON FAULT
4300	27-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4301	27-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4302	27-Jul-24	BAGALKOTE	110	LINE	RON-NAREGAL	STATION NOT AFFECTED RON_110	16:44 (25.07.2024)	16:20(27.7.24)	68:32:00	LINE CLEAR AVAILED
4303	27-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA1	SOUDATTI_220	15:10	17:55	02:45	LINE CLEAR AVAILED
4304	27-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA2	SOUDATTI_220	15:10	17:55	02:45	LINE CLEAR AVAILED
4305	27-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4306	27-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
4307	27-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
4308	27-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	08:02	13:10	05:08	LINE CLEAR AVAILED
4309	27-Jul-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	16:11 (25.07.2024)	13:10 (27.07.2024)	44:59:00	TRIPPED ON FAULT
4310	27-Jul-24	BANGALORE	66	LINE	66KV A STATION 220 - C STATION	C STATION	12:56	12:58	00:02	LINE CLEAR AVAILED
4311	27-Jul-24	BANGALORE	66	LINE	66KV ACHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGUR	13:10	13:21	00:11	TRIPPED ON FAULT
4312	27-Jul-24	BANGALORE	66	LINE	66KV ACHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGUR	14:05	14:15	00:10	TRIPPED ON FAULT
4313	27-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	09:57	10:06	00:09	TRIPPED ON FAULT
4314	27-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	10:00	10:12	00:12	LINE CLEAR AVAILED
4315	27-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - LR BANDE	LR BANDE	08:15	08:23	00:08	LINE CLEAR AVAILED
4316	27-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	05:44	06:04	00:20	LINE CLEAR AVAILED
4317	27-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	05:44	06:04	00:20	LINE CLEAR AVAILED
4318	27-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	LR BANDE	05:50	05:58	00:08	LINE CLEAR AVAILED
4319	27-Jul-24	BANGALORE	66	LINE	66KV ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	13:13	13:42	00:29	TRIPPED ON FAULT
4320	27-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - KEMBODI	KEMBODI	06:47	06:53	00:06	LINE CLEAR AVAILED
4321	27-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4322	27-Jul-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, GOWNIPALLI, RAYALPAD	11:58	12:15	00:17	TRIPPED ON FAULT
4323	27-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	11:49	13:30	01:41	TRIPPED ON FAULT
4324	27-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	13:30	15:12	01:42	LINE CLEAR AVAILED
4325	27-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	11:49	13:30	01:41	TRIPPED ON FAULT
4326	27-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	13:30	15:07	01:37	LINE CLEAR AVAILED
4327	27-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	NO STATION AFFECTED	10:15	11:59	01:44	TRIPPED ON FAULT
4328	27-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - VICTORIA HOSPITAL	VICTORIA	10:07	10:13	00:06	LINE CLEAR AVAILED
4329	27-Jul-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - VICTORIA HOSPITAL	VICTORIA	10:16	10:27	00:11	LINE CLEAR AVAILED
4330	27-Jul-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI	10:06	10:21	00:15	TRIPPED ON FAULT
4331	27-Jul-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGAR, NATIONAL COLLEGE	10:06	10:12	00:06	TRIPPED ON FAULT
4332	27-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISc	16:20	16:24	00:04	LINE CLEAR AVAILED
4333	27-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 2	TELECOM LAYOUT	13:25	13:28	00:03	LINE CLEAR AVAILED
4334	27-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	14:35	15:38	01:03	LINE CLEAR AVAILED
4335	27-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	13:19	13:46	00:27	TRIPPED ON FAULT
4336	27-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	14:19	15:38	01:19	TRIPPED ON FAULT
4337	27-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA, DEVANAHALLI, BRIGADE ORCHIDS	11:42	11:53	00:11	TRIPPED ON FAULT
4338	27-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA, DEVANAHALLI, BRIGADE ORCHIDS	12:04	12:38	00:34	TRIPPED ON FAULT
4339	27-Jul-24	BANGALORE	66	LINE	66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA	PGCIL, SUGUTUR	06:47	06:49	00:02	LINE CLEAR AVAILED
4340	27-Jul-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 1	SARAKKI	10:06	10:32	00:26	TRIPPED ON FAULT
4341	27-Jul-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 1	SARAKKI	11:57	12:00	00:03	LINE CLEAR AVAILED
4342	27-Jul-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL, GOWNIPALLI, RAYALPADU	11:58	12:14	00:16	TRIPPED ON FAULT
4343	27-Jul-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	LAKSHMIPURA, SOMAYAJANAHALLI, ADDAGAL, GOWNIPALLI, RAYALPADU	15:25	15:32	00:07	TRIPPED ON FAULT
4344	27-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPET	11:39	11:52	00:13	TRIPPED ON FAULT
4345	27-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPET	18:01	19:28	01:27	TRIPPED ON FAULT
4346	27-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	18:40	18:45	00:05	LINE CLEAR AVAILED
4347	27-Jul-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	16:20	16:21	00:01	LINE CLEAR AVAILED
4348	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	14:53	15:09	00:16	TRIPPED ON FAULT
4349	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	15:14	16:43	01:29	TRIPPED ON FAULT
4350	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	16:43	19:15	02:32	LINE CLEAR AVAILED
4351	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4352	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETHAMBADI	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4353	27-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETHAMBADI	18:02	18:09	00:07	TRIPPED ON FAULT
4354	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ADDAGAL	15:25	18:45	03:20	TRIPPED ON FAULT
4355	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BYRAKUR	14:00	14:55	00:55	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4356	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	BYRAKUR	14:55	16:16	01:21	LINE CLEAR AVAILED
4357	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	12:04	12:10	00:06	TRIPPED ON FAULT
4358	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	13:39	13:47	00:08	TRIPPED ON FAULT
4359	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	15:31	15:38	00:07	TRIPPED ON FAULT
4360	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HEJJALA	18:40	19:30	00:50	LINE CLEAR AVAILED
4361	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KADUBISANAHALLI	10:05	13:20	03:15	LINE CLEAR AVAILED
4362	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	23:27	23:57	00:30	TRIPPED ON FAULT
4363	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KUDUR	12:03	12:13	00:10	TRIPPED ON FAULT
4364	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MELUR	02:03	02:12	00:09	TRIPPED ON FAULT
4365	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MELUR	11:15	11:27	00:12	TRIPPED ON FAULT
4366	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	15:05	15:15	00:10	TRIPPED ON FAULT
4367	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TG HALLI	09:35	09:45	00:10	TRIPPED ON FAULT
4368	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TG HALLI	18:05	18:30	00:25	TRIPPED ON FAULT
4369	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TG HALLI	19:10	21:10	02:00	LINE CLEAR AVAILED
4370	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	18:45	18:47	00:02	TRIPPED ON FAULT
4371	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	20:05	20:10	00:05	TRIPPED ON FAULT
4372	27-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	13:35	14:10	00:35	LINE CLEAR AVAILED
4373	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	09:18	09:27	00:09	TRIPPED ON FAULT
4374	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	11:53	12:03	00:10	TRIPPED ON FAULT
4375	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	14:55	16:16	01:21	LINE CLEAR AVAILED
4376	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HOSKOTE 220	11:50	11:55	00:05	TRIPPED ON FAULT
4377	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KADUBISANAHALLI	13:28	13:31	00:03	LINE CLEAR AVAILED
4378	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	06:55	06:57	00:02	LINE CLEAR AVAILED
4379	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KUDUR	08:59	09:09	00:10	TRIPPED ON FAULT
4380	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	21:40	21:50	00:10	TRIPPED ON FAULT
4381	27-Jul-24	BANGALORE	66	TRANSFORMER	HV2	TK HALLI 220	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4382	27-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 1	KK DODDI, KM DODDI, TALAGAWADI, KIADB MANDYA, TUMBGERE	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4383	27-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	KK DODDI, KM DODDI, TALAGAWADI, KIADB MANDYA, TUMBGERE	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4384	27-Jul-24	BANGALORE	220	LINE	220KV SAHAKARNAGAR 220 - HEBBAL 220 - CPRI	HEBBALA 220, CPRI 220	06:10	07:28	01:18	LINE CLEAR AVAILED
4385	27-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	00:00	09:10	09:10	LOAD CURTAILMENT
4386	27-Jul-24	BANGALORE	220	TRANSFORMER	HV2	TK HALLI 220	15:17	15:28	00:11	TRIPPED ON FAULT
4387	27-Jul-24	BANGALORE	220	TRANSFORMER	HV3	TK HALLI 220	15:17	15:28	00:11	TRIPPED ON FAULT
4388	27-Jul-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66, SOVENHALLI_66	08:28	09:53	01:25	TRIPPED ON FAULT
4389	27-Jul-24	GULBARGA	110	LINE	BHALKI-HUMNABAD	BHALKI_110	18:55	24:00:00	05:05	TRIPPED ON FAULT
4390	27-Jul-24	GULBARGA	110	LINE	CHIDRI-HALBARGA	CHIDRI_110	19:15	19:20	00:05	TRIPPED ON FAULT
4391	27-Jul-24	GULBARGA	110	TRANSFORMER	HV1	KURDI CROSS_110	17:00	17:30	00:30	LINE CLEAR AVAILED
4392	27-Jul-24	GULBARGA	110	LINE	TEKKALKOTE-SIRGUPPA	SIRGUPPA_110	17:04	17:45	00:41	MAIN SUPPLY FAILURE
4393	27-Jul-24	GULBARGA	110	LINE	VALABALLARI-SINDHANOOR	VALABALLARI_110, JAWALGERA_110	14:20	14:52	00:32	TRIPPED ON FAULT
4394	27-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	09:30	18:35	09:05	LINE CLEAR AVAILED
4395	27-Jul-24	GULBARGA	220	LINE	BADALADUKU-CYCLIC ENERGY_IPP	BADALADUKU_220	13:10	13:45	00:35	LINE CLEAR AVAILED
4396	27-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
4397	27-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
4398	27-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4399	27-Jul-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	14:00	17:05	03:05	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4400	27-Jul-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	14:00	17:00	03:00	TRIPPED ON FAULT
4401	27-Jul-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	14:05	17:00	02:55	MAIN SUPPLY FAILURE
4402	27-Jul-24	HASSAN	66	LINE	BALEHN-L2	BALEHONNUR_66	21:47	22:16	00:29	MAIN SUPPLY FAILURE
4403	27-Jul-24	HASSAN	66	LINE	BALEHN-L2	BALEHONNUR_66	14:05	17:00	02:55	MAIN SUPPLY FAILURE
4404	27-Jul-24	HASSAN	66	LINE	BHADRA-SHMGA 2	gen_bhadra	13:30	13:57	00:27	TRIPPED ON FAULT
4405	27-Jul-24	HASSAN	66	TRANSFORMER	HV1	HIEMANGALUR_66	11:05	12:42	01:37	LINE CLEAR AVAILED
4406	27-Jul-24	HASSAN	66	TRANSFORMER	HV1	HIEMANGALUR_66	11:50	12:50	01:00	LINE CLEAR AVAILED
4407	27-Jul-24	HASSAN	66	TRANSFORMER	HV1	HNPUA_66	11:18	11:28	00:10	TRIPPED ON FAULT
4408	27-Jul-24	HASSAN	66	TRANSFORMER	HV1	HNPUA_66	14:16	14:25	00:09	TRIPPED ON FAULT
4409	27-Jul-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPUA_66	09:24	12:59	03:35	LINE CLEAR AVAILED
4410	27-Jul-24	HASSAN	66	LINE	UDDURKO-HASSAN1	UDDURKOPPLU_66	12:42	13:30	00:48	TRIPPED ON FAULT
4411	27-Jul-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	22:02(26.07.2024)	8:58(27.07.2024)	10:55 hrs	LINE CLEAR AVAILED
4412	27-Jul-24	HASSAN	110	TRANSFORMER	HV1	MOODABIDRE_110	09:43	10:27	00:44	LINE CLEAR AVAILED
4413	27-Jul-24	HASSAN	110	TRANSFORMER	HV1	NANDIKUR_110	11:58	13:02	01:04	LINE CLEAR AVAILED
4414	27-Jul-24	HASSAN	110	TRANSFORMER	HV1	NAVUNDA_110	06:08	06:15	00:07	TRIPPED ON FAULT
4415	27-Jul-24	HASSAN	110	TRANSFORMER	HV2 CBreaker	KARKLA_110	02:28	02:35	00:07	TRIPPED ON FAULT
4416	27-Jul-24	HASSAN	110	TRANSFORMER	HV2 CBreaker	KARKLA_110	12:28	12:35	00:07	TRIPPED ON FAULT
4417	27-Jul-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	20:23(26.07.2024)	13:31(27.07.2024)	17:07 hrs	LINE CLEAR AVAILED
4418	27-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	09:33	09:37	00:04	LINE CLEAR AVAILED
4419	27-Jul-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	08:37	09:36	00:59	LINE CLEAR AVAILED
4420	27-Jul-24	HASSAN	110	LINE	LPH-LST3	gen_lph	10:10	13:13	03:03	LINE CLEAR AVAILED
4421	27-Jul-24	HASSAN	110	LINE	LV1	PUTTUR_220	10:34	12:01	01:27	LINE CLEAR AVAILED
4422	27-Jul-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	20:23(26.07.2024)	13:31(27.07.2024)	17:07 hrs	LINE CLEAR AVAILED
4423	27-Jul-24	HASSAN	110	LINE	SAGARA-LST4	SAGARA_110	10:14	13:10	02:56	LINE CLEAR AVAILED
4424	27-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	08:35	08:54	00:19	MAIN SUPPLY FAILURE
4425	27-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	23:01 (26.04.2024)	8:36(27.07.2024)	9:34 hrs	MAIN SUPPLY FAILURE
4426	27-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_110	23:01	23:48	00:47	TRIPPED ON FAULT
4427	27-Jul-24	HASSAN	220	TRANSFORMER	HV1	PUTTUR_220	11:03	11:58	00:55	LINE CLEAR AVAILED
4428	27-Jul-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	21:42(26.07.2024)	13:46(27.07.2024)	16:03 hrs	LINE CLEAR AVAILED
4429	27-Jul-24	HASSAN	220	LINE	MRSSHM-HASSAN	MRSMSG_220	16:18(27.07.2024)			TRIPPED ON FAULT
4430	27-Jul-24	HASSAN	220	LINE	SHRAVITY-SHIRALKOPPA	gen_sharavathy	18:43(26.07.2024)	11:32(27.07.2024)	16:48 hrs	LINE CLEAR AVAILED
4431	27-Jul-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	18:43(26.07.2024)	11:32(27.07.2024)	16:47 hrs	MAIN SUPPLY FAILURE
4432	27-Jul-24	HASSAN	220	LINE	VARAHI-KEMAR2	gen_varahi	21:42(26.07.2024)	13:46(27.07.2024)	16:03 hrs	LINE CLEAR AVAILED
4433	27-Jul-24	MYSORE	66	LINE	CR NAGARA-HONNALLI	ATTIGULIPURA_66 ARKALVADI_66 HONNALLY_MYS_66	07:34	15:37	08:03	LINE CLEAR AVAILED
4434	27-Jul-24	MYSORE	66	LINE	HARADANAHALLI(JAK)-LAXJEET IPP	NO STATIONS EFFECTED	16:59	17:07	00:08	TRIPPED ON FAULT
4435	27-Jul-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	15:40	16:24	00:44	LINE CLEAR AVAILED
4436	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	13:04	13:22	00:18	MAIN SUPPLY FAILURE
4437	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	14:05	14:20	00:15	MAIN SUPPLY FAILURE
4438	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	KIADBMANDYA_66	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4439	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	15:16	15:28	00:12	MAIN SUPPLY FAILURE
4440	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	SANIVARASANTHE_66	10:53	11:19	00:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4441	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4442	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	17:45	17:58	00:13	TRIPPED ON FAULT
4443	27-Jul-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	15:17	15:36	00:19	MAIN SUPPLY FAILURE
4444	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	BESAGARAHALLI_66	14:50	15:10	00:20	TRIPPED ON FAULT
4445	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	13:04	13:22	00:18	MAIN SUPPLY FAILURE
4446	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	14:05	14:20	00:15	MAIN SUPPLY FAILURE
4447	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	KIADBMANDYA_66	15:17	15:28	00:11	MAIN SUPPLY FAILURE
4448	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	15:16	15:28	00:12	MAIN SUPPLY FAILURE
4449	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	04:36	06:39	02:02	TRIPPED ON FAULT
4450	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	YETHAMBADI_66	18:01	18:20	00:18	TRIPPED ON FAULT
4451	27-Jul-24	MYSORE	66	TRANSFORMER	HV2	YETHAMBADI_66	15:17	15:36	00:19	MAIN SUPPLY FAILURE
4452	27-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4453	27-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220-MADIKERI-1	NO STATIONS EFFECTED	05:30	10:06	04:36	TRIPPED ON FAULT
4454	27-Jul-24	MYSORE	66	LINE	KUSHALANAGARA 220-MADIKERI-1	NO STATIONS EFFECTED	12:51	19:48	06:57	LINE CLEAR AVAILED
4455	27-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4456	27-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4457	27-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4458	27-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	18:57	19:17	00:19	TRIPPED ON FAULT
4459	27-Jul-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	5:31 (27/07/2024)			TRIPPED ON FAULT
4460	27-Jul-24	MYSORE	66	LINE	TALAGAVADI-KIADB-K.K DODDI	NO STATIONS EFFECTED	16:35	16:40	00:05	LINE CLEAR AVAILED
4461	27-Jul-24	MYSORE	66	LINE	TALAGAVADI-TK HALLI	NO STATIONS EFFECTED	16:40	19:35	02:55	LINE CLEAR AVAILED
4462	27-Jul-24	MYSORE	66	LINE	YATHAMBADI-TK HALLI	YETHAMBADI_66	18:03	18:10	00:06	TRIPPED ON FAULT
4463	27-Jul-24	MYSORE	220	LINE	TUBINAKERE-BASTHIPURA	NO STATIONS EFFECTED	10:03	20:09	10:06	LINE CLEAR AVAILED
4464	27-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 1	66KV SIRIGERE,BHARAMSAGARA,VIJAPURA	22:30	23:24	00:54	TRIPPED ON FAULT
4465	27-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 1	66KV SIRIGERE,BHARAMSAGARA,VIJAPURA	17:48	18:37	00:49	LINE CLEAR AVAILED
4466	27-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4467	27-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV P R PURA LINE	66KV HARIAYBBE,PD KOTE	11:26	14:34	03:08	TRIPPED ON FAULT
4468	27-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV THALLAK LINE	66KV RANGENAHALLY	11:26	11:56	00:30	TRIPPED ON FAULT
4469	27-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV BASAVAPATNA	14:16	14:26	00:10	TRIPPED ON FAULT
4470	27-Jul-24	TUMKUR	66	LINE	66KV CHALLAKERE LINE-66KV BALENAHALLI	BALENAHALLI_66	12:22	18:15	05:53	TRIPPED ON FAULT
4471	27-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI, HDPURA	07:58	08:08	00:10	TRIPPED ON FAULT
4472	27-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI, HDPURA	14:04	14:24	00:20	TRIPPED ON FAULT
4473	27-Jul-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRALLI, HDPURA	16:25	18:43	02:18	LINE CLEAR AVAILED
4474	27-Jul-24	TUMKUR	66	LINE	66KV PANDARAHALLI-66KV HOLALKERE LINE	66KV HOLALKERE,SASALUHALLA,CHIKK AJAJUR	08:00	08:10	00:10	TRIPPED ON FAULT
4475	27-Jul-24	TUMKUR	66	LINE	BALENAHALLI-CHALKERE	BALENAHALLI_66	13:30	13:38	00:08	LINE CLEAR AVAILED
4476	27-Jul-24	TUMKUR	66	LINE	BALENAHALLI-CHITRADURGA	BALENAHALLI_66	18:15	18:20	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4477	27-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	11:25	11:55	00:30	MAIN SUPPLY FAILURE
4478	27-Jul-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	12:10	12:25	00:15	MAIN SUPPLY FAILURE
4479	27-Jul-24	TUMKUR	66	LINE	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	08:00	08:10	00:10	LINE CLEAR AVAILED
4480	27-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66,	18:45	19:40	05:09	MAIN SUPPLY FAILURE
4481	27-Jul-24	TUMKUR	66	LINE	PAVAGADA 220KV- MADHUGIRI	PAVAGADA_220	12:06	12:12	07:09	TRIPPED ON FAULT
4482	27-Jul-24	TUMKUR	66	LINE	PAVAGADA 220KV- PAVAGADA LINE-1	PAVAGADA_220	12:00	12:12	06:09	TRIPPED ON FAULT
4483	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-1	CHANNAGIRI_66	16:04	16:12	00:08	TRIPPED ON FAULT
4484	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4485	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	MADHUGIRI_66	10:15	10:30	00:15	TRIPPED ON FAULT
4486	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,8MVA	GARAGA_66	11:45	12:05	00:20	LINE CLEAR AVAILED
4487	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-2,12.5MVA	KUKKAWADA_66	14:10	14:15	00:05	TRIPPED ON FAULT
4488	27-Jul-24	TUMKUR	66	TRANSFORMER	TR-2,12.5MVA	KUKKAWADA_66	00:15	00:20	00:05	TRIPPED ON FAULT
4489	27-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 1 & 3-220KV HIRIYUR	66KV MATHOD,GARGA,PANCHANAHALLI, KANCHIPURA,BEVINAHALLI, J G HALLI, K R HALLI,RANGANATHAPURA,HIRIYUR	11:26	11:49	00:23	TRIPPED ON FAULT
4490	27-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 1 & 3-220KV HIRIYUR	66KV MATHOD,GARGA,PANCHANAHALLI, KANCHIPURA,BEVINAHALLI, J G HALLI, K R HALLI,RANGANATHAPURA,HIRIYUR	12:07	12:24	00:17	TRIPPED ON FAULT
4491	27-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 1 -220KV DAVANGERE	AVARGERE,MELLEKATTE,KADAJJI, MAYAKONDA,SASALUHALLA,ANAG ODU,ATTIGERE,DAVANGERE,KUKK AWADA,SHYGALE,HARIHAR NEW, YARAGUNTA,CHIKKAJAJUR, SASALUHALLA	18:43	19:16	00:33	TRIPPED ON FAULT
4492	27-Jul-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER 2-220KV DAVANGERE	DAVANGERE_220KV	18:43	19:24	00:41	TRIPPED ON FAULT
4493	27-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV- VASANTANARASAPURA 1	VASANTANARASAPURA	13:30 (27.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4494	28-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA HV1)	UGARKHUD_110	08:42	08:57	00:15	TRIPPED ON FAULT
4495	28-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALGHATAGI_110	09:52	09:57	00:05	TRIPPED ON FAULT
4496	28-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	BIJAPUR_220	11:26	17:28	06:02	LINE CLEAR AVAILED
4497	28-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	SINDAGI_110	12:30	13:00	00:30	LINE CLEAR AVAILED
4498	28-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	GOKAK_110	15:30	16:10	00:40	TRIPPED ON FAULT
4499	28-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	13:13 (28.07.2024)			LINE CLEAR AVAILED
4500	28-Jul-24	BAGALKOTE	110	LINE	JAMAKHANDI-MAHALINGAPUR	JAMAKHANDI_110	17:18	17:27	00:09	LINE CLEAR AVAILED
4501	28-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4502	28-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4503	28-Jul-24	BAGALKOTE	110	LINE	NIPPANI-FPEL IPP	FPEL IPP_110 NIPPANI_110	15:31	18:40	03:09	LINE CLEAR AVAILED
4504	28-Jul-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD1	RON_110	12:58	13:04	00:06	LINE CLEAR AVAILED
4505	28-Jul-24	BAGALKOTE	110	LINE	RON-GAJENDRAGAD2	RON_110	12:58	13:04	00:06	LINE CLEAR AVAILED
4506	28-Jul-24	BAGALKOTE	110	LINE	RON-GAMESH	RON_110	12:58	13:23	00:25	LINE CLEAR AVAILED
4507	28-Jul-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON_110	12:58	13:37	00:39	LINE CLEAR AVAILED
4508	28-Jul-24	BAGALKOTE	110	LINE	RON-NAREGAL	STATION NOT AFFECTED RON_110	16:44 (25.07.2024)	13:16 (28.07.2024)	68:32:00	LINE CLEAR AVAILED
4509	28-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4510	28-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
4511	28-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
4512	28-Jul-24	BANGALORE	66	LINE	66KV ACHALU - HONNIGANAHALLI	HONNAGANAHALLI, HALAGUR S /S	12:33	12:35	00:02	TRIPPED ON FAULT
4513	28-Jul-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR AND SRIGIRUPURA	16:37	16:46	00:09	TRIPPED ON FAULT
4514	28-Jul-24	BANGALORE	66	LINE	66KV ARMY WELFARE HOUSING ORGANISATION - KONDASAPURA (SAFAL)	ARMY WELFARE ORGANISATION	13:03	13:05	00:02	LINE CLEAR AVAILED
4515	28-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR,DASHAVARA, SANKALAGERE, VANDARAGUPPE.	11:48	11:53	00:05	TRIPPED ON FAULT
4516	28-Jul-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA (SAFAL)	KONADASAPURA	09:28	09:32	00:04	LINE CLEAR AVAILED
4517	28-Jul-24	BANGALORE	66	LINE	66KV EPIP 220 - KADUGODI	KADUGODI	13:01	13:05	00:04	LINE CLEAR AVAILED
4518	28-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 66 - MANYATA 66 - KONDASPURA (SAFAL) _DG3	KONADASAPURA	17:28	17:32	00:04	LINE CLEAR AVAILED
4519	28-Jul-24	BANGALORE	66	LINE	66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)	L R BANDE	09:24	09:28	00:04	LINE CLEAR AVAILED
4520	28-Jul-24	BANGALORE	66	LINE	66KV JIGANI 220 - JIGANI OLD STATION	JIGANI OLD STATION	13:11	13:13	00:02	MAIN SUPPLY FAILURE
4521	28-Jul-24	BANGALORE	66	LINE	66KV JIGANI 220 - JIGANI OLD STATION	JIGANI OLD STATION	15:38	15:42	00:04	LINE CLEAR AVAILED
4522	28-Jul-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	13:14	15:32	02:18	MAIN SUPPLY FAILURE
4523	28-Jul-24	BANGALORE	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD, KTTM(EHT)	11:50	11:54	00:04	LINE CLEAR AVAILED
4524	28-Jul-24	BANGALORE	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	ARMY WELFARE ORGANISATION	09:50	09:55	00:05	LINE CLEAR AVAILED
4525	28-Jul-24	BANGALORE	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	KADUGODI	10:01	10:07	00:06	LINE CLEAR AVAILED
4526	28-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59:00	23:59	TRIPPED ON FAULT
4527	28-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4528	28-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	04:49	05:26:00	00:37	TRIPPED ON FAULT
4529	28-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANHALLI AND BRIGADE ORCHADE	10:30	14:55	04:25	LINE CLEAR AVAILED
4530	28-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	10:30	14:55	04:25	LINE CLEAR AVAILED
4531	28-Jul-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:12	14:13	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4532	28-Jul-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	11:20	11:25	00:05	LINE CLEAR AVAILED
4533	28-Jul-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - BMRCL PUTTENAHALLI EHT 66/33KV	BMRCL, PUTTENALLI	00:35	00:40	00:05	LINE CLEAR AVAILED
4534	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU, ATTIBELE	12:23	12:30	00:07	LINE CLEAR AVAILED
4535	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU, ATTIBELE	13:40	13:45	00:05	LINE CLEAR AVAILED
4536	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	11:18	11:20	00:02	LINE CLEAR AVAILED
4537	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT	TIMES OF INDIA EHT	12:23	12:30	00:07	LINE CLEAR AVAILED
4538	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT	TIMES OF INDIA EHT	13:40	13:45	00:05	LINE CLEAR AVAILED
4539	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYA CITY	12:23	12:30	00:07	LINE CLEAR AVAILED
4540	28-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYA CITY	13:40	13:45	00:05	LINE CLEAR AVAILED
4541	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDHA	14:50	15:00	00:10	TRIPPED ON FAULT
4542	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NANGALI	12:45	13:00	00:15	LINE CLEAR AVAILED
4543	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	T G HALLY	17:30	18:10	00:40	LINE CLEAR AVAILED
4544	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	09:52	10:00	00:08	LINE CLEAR AVAILED
4545	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	12:23	12:29	00:06	LINE CLEAR AVAILED
4546	28-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	13:40	13:52	00:12	LINE CLEAR AVAILED
4547	28-Jul-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	11:53	12:03	00:10	TRIPPED ON FAULT
4548	28-Jul-24	BANGALORE	66	TRANSFORMER	HV2	HONNIGANAHALLY	12:15	14:15	02:00	LINE CLEAR AVAILED
4549	28-Jul-24	BANGALORE	66	TRANSFORMER	HV2	L R BANDE	09:28	09:32	00:04	LINE CLEAR AVAILED
4550	28-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	12:24	12:27	00:03	LINE CLEAR AVAILED
4551	28-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	13:41	13:43	00:02	LINE CLEAR AVAILED
4552	28-Jul-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	09:52	10:00	00:08	LINE CLEAR AVAILED
4553	28-Jul-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	12:23	12:28	00:05	LINE CLEAR AVAILED
4554	28-Jul-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	13:40	13:52	00:12	LINE CLEAR AVAILED
4555	28-Jul-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - JIGANI 220	JIGANI 220	13:25	15:29	02:04	LINE CLEAR AVAILED
4556	28-Jul-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NO LOAD AFFECTED	12:23	12:38	00:15	LINE CLEAR AVAILED
4557	28-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	00:00	09:10:00	09:10	LOAD CURTAILMENT
4558	28-Jul-24	BANGALORE	220	TRANSFORMER	HV1	JIGANI 220	13:22	15:30	02:08	LINE CLEAR AVAILED
4559	28-Jul-24	BANGALORE	220	TRANSFORMER	HV1	YARANDANAHALLI 220	10:00	11:40	01:40	LINE CLEAR AVAILED
4560	28-Jul-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	13:11	15:35	02:24	LINE CLEAR AVAILED
4561	28-Jul-24	BANGALORE	220	TRANSFORMER	HV2	YARANDANAHALLI 220	11:40	12:26	00:46	LINE CLEAR AVAILED
4562	28-Jul-24	BANGALORE	220	TRANSFORMER	HV2	YARANDANAHALLI 220	13:41	13:51	00:10	LINE CLEAR AVAILED
4563	28-Jul-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	12:25	13:42	01:17	LINE CLEAR AVAILED
4564	28-Jul-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	ABSRL_IPP,BANVEKAL_66	10:05	10:25	00:20	TRIPPED ON FAULT
4565	28-Jul-24	GULBARGA	66	TRANSFORMER	HV1	CJ.HALLI_66	14:00	14:10	00:10	TRIPPED ON FAULT
4566	28-Jul-24	GULBARGA	66	TRANSFORMER	HV1	CJ.HALLI_66	15:15	15:25	00:10	TRIPPED ON FAULT
4567	28-Jul-24	GULBARGA	110	LINE	MUKUNDA-SINDHANOOR	MUKUNDA_110	01:15	01:25	00:10	MAIN SUPPLY FAILURE
4568	28-Jul-24	GULBARGA	110	LINE	SR NAGAR-SINDHANOOR	KARATAGI_110	03:10	03:20	00:10	MAIN SUPPLY FAILURE
4569	28-Jul-24	GULBARGA	110	LINE	YADGIR-HATTIGUDUR	YADGIR_110	02:58	11:44	08:46	TRIPPED ON FAULT
4570	28-Jul-24	GULBARGA	110	LINE	YADGIR-SHAHAPUR	YADGIR_110	03:45	17:25	13:40	LINE CLEAR AVAILED
4571	28-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
4572	28-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
4573	28-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4574	28-Jul-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	18:56	19:20	00:24	TRIPPED ON FAULT
4575	28-Jul-24	HASSAN	66	TRANSFORMER	HV2	MALLAPURA_66	07:29	10:08	02:39	TRIPPED ON FAULT
4576	28-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESH PURA_66	21:01 (28.07.2024)			TRIPPED ON FAULT
4577	28-Jul-24	HASSAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPPLU_66	18:55	19:14	00:19	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4578	28-Jul-24	HASSAN	110	TRANSFORMER	HV3	BAIKAMPADI_110	10:03	13:04	03:01	LINE CLEAR AVAILED
4579	28-Jul-24	HASSAN	220	TRANSFORMER	HV5	PUTTUR_220	20:49	22:18	01:29	TRIPPED ON FAULT
4580	28-Jul-24	HASSAN	220	LINE	MRSSHM-HASSAN	MRSMSG_220	16:18(27.07.2024)	9:23(28.07.2024)	17:4 hrs	TRIPPED ON FAULT
4581	28-Jul-24	HASSAN	220	LINE	SHRAVTY-SIRISI 1	gen_sharavathy	21:38(28.07.2024)			TRIPPED ON FAULT
4582	28-Jul-24	MYSORE	66	LINE	CRNAGARA-KOLLEGALA	KOLLEGALA_66	13:25	17:41	04:16	LINE CLEAR AVAILED
4583	28-Jul-24	MYSORE	66	LINE	HUNSUR 220-KAMPALAPURA	NO STATIONS EFFECTED	11:33	11:39	00:06	TRIPPED ON FAULT
4584	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	12:31	12:33	00:02	MAIN SUPPLY FAILURE
4585	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	HANAGODU_66	19:48	20:17	00:28	LINE CLEAR AVAILED
4586	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	10:00	17:27	07:27	LINE CLEAR AVAILED
4587	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	MADIKERI_66	11:03	11:06	00:03	TRIPPED ON FAULT
4588	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	14:24	14:33	00:08	TRIPPED ON FAULT
4589	28-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4590	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	HALAGUR_66	12:31	12:33	00:02	MAIN SUPPLY FAILURE
4591	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	HANAGODU_66	11:45	11:49	00:04	TRIPPED ON FAULT
4592	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	10:00	17:27	07:27	LINE CLEAR AVAILED
4593	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	11:03	11:06	00:03	TRIPPED ON FAULT
4594	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	12:52	13:07	00:15	TRIPPED ON FAULT
4595	28-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	16:10	16:58	00:48	TRIPPED ON FAULT
4596	28-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4597	28-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4598	28-Jul-24	MYSORE	66	LINE	LOKKANAHALLI-P G PALYA	PGPALYA_66	17:25	17:30	00:05	TRIPPED ON FAULT
4599	28-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4600	28-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4601	28-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA	NO STATIONS EFFECTED	13:09	17:34	04:25	LINE CLEAR AVAILED
4602	28-Jul-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	5:31 (27/07/2024)			TRIPPED ON FAULT
4603	28-Jul-24	MYSORE	66	LINE	PARINAMIPURA-KOLLEGALA	KOLLEGALA_66	13:11	17:26	04:15	LINE CLEAR AVAILED
4604	28-Jul-24	MYSORE	220	LINE	TUBINKERE-BASTHIPURA	NO STATIONS EFFECTED	09:54	19:15	09:21	LINE CLEAR AVAILED
4605	28-Jul-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2	66KV HULLENAHALLI,KUDUR,SRIGIRIPURA	16:36	16:46	00:10	TRIPPED ON FAULT
4606	28-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4607	28-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA AND SHYAGALE MUSS	04:03	04:12	00:09	TRIPPED ON FAULT
4608	28-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 2	KUKKAWADA AND SHYAGALE MUSS	04:03	04:11	00:08	TRIPPED ON FAULT
4609	28-Jul-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV BEVINAHALLI LINE	DASUDI, JG HALLI, BEVINAHALLI, KRHALLY	09:08	09:49	00:41	TRIPPED ON FAULT
4610	28-Jul-24	TUMKUR	66	LINE	KUKKAWADA-BASAVAPATNA_66	BASAVAPATNA_66, TYVANAGI_66,	04:05	04:10	05:09	MAIN SUPPLY FAILURE
4611	28-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4612	28-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	BALENAHALLI_66	15:50	16:05	00:15	TRIPPED ON FAULT
4613	28-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	BALENAHALLI_66	19:08	19:13	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4614	28-Jul-24	TUMKUR	220	LINE	CHITRADURGA _220-PGCIL _220	CHITRADURGA_220	20:36 (27.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4615	28-Jul-24	TUMKUR	220	LINE	HIREMALLANAHOLE-CHITRADURGA 220KV LINE 1	CHITRADURGA_220	07:04	10:41	03:37	LINE CLEAR AVAILED
4616	28-Jul-24	TUMKUR	220	LINE	HIREMALLANAHOLE-CHITRADURGA 220KV LINE 1	CHITRADURGA_220	16:20 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4617	28-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV- VASANTANARASAPURA 1	VASANTANARASAPURA	13:33 (27.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4618	28-Jul-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA _220	CHITRADURGA_220	07:12	10:32	03:20	LINE CLEAR AVAILED
4619	28-Jul-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA _220	CHITRADURGA_220	16:23 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4620	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	UCHAGOAN_110	12:39	15:08	02:29	LINE CLEAR AVAILED
4621	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	UCHAGOAN_110	16:22	17:42	01:20	LINE CLEAR AVAILED
4622	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	NARAGAL_110	17:00	17:19	00:19	TRIPPED ON FAULT
4623	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA-HV2)	MUDDEBIHAL_110	08:55	10:53	01:58	LINE CLEAR AVAILED
4624	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	HUDALI_110	14:31	15:11	00:40	LINE CLEAR AVAILED
4625	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KALADAGI_110	14:35	14:55	00:20	LINE CLEAR AVAILED
4626	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULAGERE CROSS_110	11:56	14:39	02:43	LINE CLEAR AVAILED
4627	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	KULIGOD_110	13:00	13:49	00:49	LINE CLEAR AVAILED
4628	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	ANKALAGI_110	08:37	09:58	01:21	LINE CLEAR AVAILED
4629	29-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(20MVA)	ANKALAGI_110	10:06	10:20	00:14	LINE CLEAR AVAILED
4630	29-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK1(HALIYAL)	AMBEWADI_220	04:11	17:22	13:11	TRIPPED ON FAULT
4631	29-Jul-24	BAGALKOTE	110	LINE	AMBEWADI-NK1(HALIYAL)	AMBEWADI_220	17:37	17:40	00:03	LINE CLEAR AVAILED
4632	29-Jul-24	BAGALKOTE	110	LINE	BIDNAL220- NAVALGUND	BIDNAL_220	06:08	09:32	03:24	TRIPPED ON FAULT
4633	29-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	13:13 (28.07.2024)			LINE CLEAR AVAILED
4634	29-Jul-24	BAGALKOTE	110	LINE	HUBLI220- KADANKOPPA	HUBLI_220	17:58	18:01	00:03	LINE CLEAR AVAILED
4635	29-Jul-24	BAGALKOTE	110	LINE	KUDACHI220- TERDAL(MORAB)	KUDACHI_220	3:35	3:49	00:14	TRIPPED ON FAULT
4636	29-Jul-24	BAGALKOTE	110	LINE	KUDACHI220- TERDAL(MORAB)	KUDACHI_220	4:04	4:16	00:12	TRIPPED ON FAULT
4637	29-Jul-24	BAGALKOTE	110	LINE	KULAGERE CROSS-MRN	KULAGERE CROSS_110	06:10	06:15	00:05	TRIPPED ON FAULT
4638	29-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220- BAILHONGAL	MKHUBLI_220	5:40	6:22	00:42	TRIPPED ON FAULT
4639	29-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4640	29-Jul-24	BAGALKOTE	110	LINE	MUDDEBIHAL-KNM SOLAR	MUDDEBIHAL_110	08:55	10:54	01:59	LINE CLEAR AVAILED
4641	29-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4642	29-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4643	29-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
4644	29-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
4645	29-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	HAVERI_220	04:24	16:29	12:05	TRIPPED ON FAULT
4646	29-Jul-24	BAGALKOTE	220	LINE	AEQUS -BELGAUM-2	AEQUS_220	12:05	15:22	03:17	LINE CLEAR AVAILED
4647	29-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - KOPPAL LIS	BAGAKOT_220	17:17	17:36	00:19	TRIPPED ON FAULT
4648	29-Jul-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI-1	BAGAKOT_220	15:10	16:53	01:43	LINE CLEAR AVAILED
4649	29-Jul-24	BAGALKOTE	220	LINE	BELGAUM-AEQUS2	BELGAUM_220	12:03	15:22	03:19	LINE CLEAR AVAILED
4650	29-Jul-24	BAGALKOTE	220	LINE	SHIGGOAN- HAVERI1	SHIGGOAN_220	04:23	07:02	02:39	TRIPPED ON FAULT
4651	29-Jul-24	BAGALKOTE	220	LINE	SHIGGOAN- HAVERI2	SHIGGOAN_220	04:23	07:02	02:39	TRIPPED ON FAULT
4652	29-Jul-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	21:15 (28.07.2024)	16:30 (29.07.2024)	19:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4653	29-Jul-24	BAGALKOTE	220	LINE	VALRAMATTI-BAGALKOT1	VAJRAMATTI_220	15:10	16:52	01:42	LINE CLEAR AVAILED
4654	29-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:10	06:02	00:52	TRIPPED ON FAULT
4655	29-Jul-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	16:36	16:43	00:07	MAIN SUPPLY FAILURE
4656	29-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	10:30	10:42	00:12	LINE CLEAR AVAILED
4657	29-Jul-24	BANGALORE	66	LINE	66KV DABASPETE 220 - AVERAHALLI	AVERAHALLI, T BEGUR	19:20	19:24	00:04	LINE CLEAR AVAILED
4658	29-Jul-24	BANGALORE	66	LINE	66KV KACHAMARANAHALLI - DOMMASANDRA	DOMMASANDRA	20:32	21:00	00:28	TRIPPED ON FAULT
4659	29-Jul-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	CHATRA, MARALAWADI, GODUR	16:40	16:54	00:14	TRIPPED ON FAULT
4660	29-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4661	29-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	10:10	15:00	04:50	LINE CLEAR AVAILED
4662	29-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	10:46	15:36	04:50	LINE CLEAR AVAILED
4663	29-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	10:46	15:36	04:50	LINE CLEAR AVAILED
4664	29-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	19:17	19:25	00:08	LINE CLEAR AVAILED
4665	29-Jul-24	BANGALORE	66	LINE	66KV TEKAL - BUDIKOTE	BUDIKOTE	15:25	16:00	00:35	LINE CLEAR AVAILED
4666	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ALLIMARADANAHALLI	11:30	16:00	04:30	LINE CLEAR AVAILED
4667	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	16:36	16:47	00:11	MAIN SUPPLY FAILURE
4668	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	CHELUR	12:45	13:00	00:15	TRIPPED ON FAULT
4669	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DEVANAHALLI 66	15:45	15:55	00:10	LINE CLEAR AVAILED
4670	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	GOWNIPALLI	14:30	15:20	00:50	LINE CLEAR AVAILED
4671	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	14:14	14:16	00:02	LINE CLEAR AVAILED
4672	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	15:50	15:55	00:05	LINE CLEAR AVAILED
4673	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	16:00	16:10	00:10	TRIPPED ON FAULT
4674	29-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	17:18	17:23	00:05	TRIPPED ON FAULT
4675	29-Jul-24	BANGALORE	66	TRANSFORMER	HV2	AGALAKOTE	12:20	12:45	00:25	LINE CLEAR AVAILED
4676	29-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	16:36	16:47	00:11	MAIN SUPPLY FAILURE
4677	29-Jul-24	BANGALORE	66	TRANSFORMER	HV2	VOLVO	11:10	11:15	00:05	LINE CLEAR AVAILED
4678	29-Jul-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	16:00	16:05	00:05	TRIPPED ON FAULT
4679	29-Jul-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	20:10	23:59	03:49	TRIPPED ON FAULT
4680	29-Jul-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - CHANNAPATNA 220	CHANNAPATNA 220	16:36	16:40	00:04	TRIPPED ON FAULT
4681	29-Jul-24	BANGALORE	220	LINE	220KV TUBINAKERE 220 - KOTHIPURA 2	NO STATION AFFECTED	07:31	23:59	16:28	LOAD CURTAILMENT
4682	29-Jul-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	16:40	16:45	00:05	TRIPPED ON FAULT
4683	29-Jul-24	GULBARGA	66	TRANSFORMER	HV3	HALAVAGALU_66	08:55	09:05	00:10	TRIPPED ON FAULT
4684	29-Jul-24	GULBARGA	66	TRANSFORMER	HV3	NEELGUNDA_220	07:15	07:25	00:10	TRIPPED ON FAULT
4685	29-Jul-24	GULBARGA	66	TRANSFORMER	HV3	NEELGUNDA_220	18:15	18:35	00:20	LINE CLEAR AVAILED
4686	29-Jul-24	GULBARGA	110	LINE	BHALKI-DUBALGUNDI	BHALKI_110	10:10	17:10	07:00	LINE CLEAR AVAILED
4687	29-Jul-24	GULBARGA	110	LINE	BYGWAT-MALLAT	BYGWAT_110,WALKAMDINI_110	13:25	13:35	00:10	LINE CLEAR AVAILED
4688	29-Jul-24	GULBARGA	110	LINE	HALBARGA-CHIDRI	CHIDRI_110	10:00	12:35	02:35	LINE CLEAR AVAILED
4689	29-Jul-24	GULBARGA	110	TRANSFORMER	HV1	DONIMALAI_110	12:03	12:18	00:15	LINE CLEAR AVAILED
4690	29-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	04:54	05:01	00:07	TRIPPED ON FAULT
4691	29-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	04:15	04:45	00:30	TRIPPED ON FAULT
4692	29-Jul-24	GULBARGA	110	LINE	KHANAPUR-SANOTHI	KHANAPUR_110	05:00	08:00	03:00	LINE CLEAR AVAILED
4693	29-Jul-24	GULBARGA	110	LINE	NALWAR-SHAHABAD	NALWAR_110	03:10	03:17	00:07	TRIPPED ON FAULT
4694	29-Jul-24	GULBARGA	110	LINE	NALWAR-SHAHABAD	NALWAR_110	19:10	19:19	00:09	TRIPPED ON FAULT
4695	29-Jul-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110, GABUR_110	05:11	05:17	00:06	TRIPPED ON FAULT
4696	29-Jul-24	GULBARGA	110	LINE	SHAHABAD-GHATTARGA	KARAJAGI-GHATTARGA_110	20:48	20:58	00:10	MAIN SUPPLY FAILURE
4697	29-Jul-24	GULBARGA	110	LINE	SHAHABAD-JEWARGI	JEWARGI_110	03:21	03:25	00:04	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSIO N ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4698	29-Jul-24	GULBARGA	110	LINE	SHAHABAD-MORATAGI	KARAJAGI-GHATTARGA_110	20:48	20:58	00:10	MAIN SUPPLY FAILURE
4699	29-Jul-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	01:46	02:06	00:20	TRIPPED ON FAULT
4700	29-Jul-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	05:08	05:18	00:10	TRIPPED ON FAULT
4701	29-Jul-24	GULBARGA	110	LINE	WALKAMDINI-BYGWAT	WALKAMDINI_110	13:25	13:35	00:10	MAIN SUPPLY FAILURE
4702	29-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:00	22:10	17:10	TRIPPED ON FAULT
4703	29-Jul-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	05:04	05:15	00:11	TRIPPED ON FAULT
4704	29-Jul-24	GULBARGA	220	LINE	ALLIPUR-BTPS	ALLIPUR_220	14:34	14:50:00	00:16	TRIPPED ON FAULT
4705	29-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
4706	29-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
4707	29-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4708	29-Jul-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	19:08	19:20	00:12	TRIPPED ON FAULT
4709	29-Jul-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPURA_220	10:10	10:18	00:08	LINE CLEAR AVAILED
4710	29-Jul-24	HASSAN	66	TRANSFORMER	HV	CHIKABOMMENAHALLI_66	22:10	22:25	00:15	TRIPPED ON FAULT
4711	29-Jul-24	HASSAN	66	TRANSFORMER	HV1	BYACHANAHALLI_66	12:35	14:45	02:10	LINE CLEAR AVAILED
4712	29-Jul-24	HASSAN	66	TRANSFORMER	HV1	HADAVANAHALLI_66	12:14	12:48	00:34	LINE CLEAR AVAILED
4713	29-Jul-24	HASSAN	66	TRANSFORMER	HV1	UDAYAPURA_66	15:18	15:32	00:14	LINE CLEAR AVAILED
4714	29-Jul-24	HASSAN	66	TRANSFORMER	HV2	BYACHANAHALLI_66	10:20	11:50	01:30	LINE CLEAR AVAILED
4715	29-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPUA_66	21:01 (28.07.2024)	19:57(29.07.2024)	22:55 hrs	LINE CLEAR AVAILED
4716	29-Jul-24	HASSAN	110	LINE	ANANDA-SHIMOGA	ANANDAPURA_110	17:39	19:10	01:31	TRIPPED ON FAULT
4717	29-Jul-24	HASSAN	110	LINE	BANTWA-KAVOOR	BANTWAL_110	16:32	18:12	01:40	LINE CLEAR AVAILED
4718	29-Jul-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	10:25	11:25	01:00	MAIN SUPPLY FAILURE
4719	29-Jul-24	HASSAN	110	TRANSFORMER	HV1	HIRIYADKA_110	10:35	12:22	01:47	LINE CLEAR AVAILED
4720	29-Jul-24	HASSAN	110	TRANSFORMER	HV2	KADUR_220	13:00	13:35	00:35	LINE CLEAR AVAILED
4721	29-Jul-24	HASSAN	110	TRANSFORMER	HV5	MRSMSG_220	10:24	16:46	06:22	LINE CLEAR AVAILED
4722	29-Jul-24	HASSAN	110	TRANSFORMER	HV5	PUTTUR_220	11:13	13:25	02:12	LINE CLEAR AVAILED
4723	29-Jul-24	HASSAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	06:05	06:11	00:06	TRIPPED ON FAULT
4724	29-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	19:13(29.07.2024)			LINE CLEAR AVAILED
4725	29-Jul-24	HASSAN	110	LINE	KMS110-MRS-ANDPR	KUMSI_110	17:40	19:11	01:31	TRIPPED ON FAULT
4726	29-Jul-24	HASSAN	110	LINE	LV2	MRSMSG_220	10:24	16:43	06:19	TRIPPED ON FAULT
4727	29-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY1	MRSMSG_220	7:58(29.07.2024)			TRIPPED ON FAULT
4728	29-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY2	MRSMSG_220	8:12(29.07.2024)			TRIPPED ON FAULT
4729	29-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY3	MRSMSG_220	10:24	11:13	00:49	LINE CLEAR AVAILED
4730	29-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY3	MRSMSG_220	17:06	17:09	00:03	LINE CLEAR AVAILED
4731	29-Jul-24	HASSAN	110	LINE	MRSSHM-GAJNUR	MRSMSG_220	10:24	11:12	00:48	LINE CLEAR AVAILED
4732	29-Jul-24	HASSAN	110	LINE	MRSSHM-GAJNUR	MRSMSG_220	16:50	16:57	00:07	LINE CLEAR AVAILED
4733	29-Jul-24	HASSAN	110	LINE	MRSSHM-MPM	MRSMSG_220	09:27	15:03	05:36	LINE CLEAR AVAILED
4734	29-Jul-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	14:26	14:32	00:06	TRIPPED ON FAULT
4735	29-Jul-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	14:45	15:26	00:41	TRIPPED ON FAULT
4736	29-Jul-24	HASSAN	110	LINE	MRSSHM-RLW CBreaker	MRSMSG_220	10:24	11:18	00:54	LINE CLEAR AVAILED
4737	29-Jul-24	HASSAN	110	LINE	MRSSHM-RLW CBreaker	MRSMSG_220	17:30	17:32	00:02	LINE CLEAR AVAILED
4738	29-Jul-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMSG_220	14:29	14:31	00:02	TRIPPED ON FAULT
4739	29-Jul-24	HASSAN	110	LINE	MRSSHM-TRKER	MRSMSG_220	10:24	11:13	00:49	LINE CLEAR AVAILED
4740	29-Jul-24	HASSAN	220	TRANSFORMER	HV2	MRSMSG_220	10:24	13:55:00	03:31	TRIPPED ON FAULT
4741	29-Jul-24	HASSAN	220	LINE	KEMAR-Kavoor1	KEMAR_220	09:33	18:33	09:00	LINE CLEAR AVAILED
4742	29-Jul-24	HASSAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	12:15	12:56	00:41	LINE CLEAR AVAILED
4743	29-Jul-24	HASSAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	09:33	18:36	09:03	LINE CLEAR AVAILED
4744	29-Jul-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	12:15	12:56	00:41	LINE CLEAR AVAILED
4745	29-Jul-24	HASSAN	220	LINE	SHRAVITY-SIRISI 1	gen_sharavathy	21:38(28.07.2024)	16:31(29.07.2024)	18:52 hrs	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4746	29-Jul-24	MYSORE	66	LINE	B G NAGARA-AC GIRI - VADERALLI	ADICHUNCHANAGIRI_66 VADERALLI_66	07:33	07:53	00:19	TRIPPED ON FAULT
4747	29-Jul-24	MYSORE	66	LINE	CR NAGARA-HARVEY	HARVEY_66	18:35	19:49	01:14	LINE CLEAR AVAILED
4748	29-Jul-24	MYSORE	66	LINE	CR NAGARA-HARVEY	NO STATIONS EFFECTED	14:31	16:58	02:27	LINE CLEAR AVAILED
4749	29-Jul-24	MYSORE	66	LINE	CR NAGARA-TERAKANAMBI - GUNDLUPETE	TERAKANAMBE_66	14:33	16:55	02:21	LINE CLEAR AVAILED
4750	29-Jul-24	MYSORE	66	LINE	GUNDLUPETE-CR NAGARA - TERAKANAMBI	TERAKANAMBE_66	14:33	16:56	02:23	LINE CLEAR AVAILED
4751	29-Jul-24	MYSORE	66	TRANSFORMER	HARADANAHALLI-HV2	HARADANAHALLI_66	19:10	19:20	00:10	MAIN SUPPLY FAILURE
4752	29-Jul-24	MYSORE	66	LINE	HARVEY-BEGUR 220	HARVEY_66	16:50	19:10	02:20	LINE CLEAR AVAILED
4753	29-Jul-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	14:31	17:57	03:26	LINE CLEAR AVAILED
4754	29-Jul-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	18:32 (29/07/2024)			LINE CLEAR AVAILED
4755	29-Jul-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	18:01	18:04	00:03	TRIPPED ON FAULT
4756	29-Jul-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI_66	19:10	19:20	00:10	MAIN SUPPLY FAILURE
4757	29-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4758	29-Jul-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	12:00	12:15	00:15	TRIPPED ON FAULT
4759	29-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	12:11	12:57	00:46	LINE CLEAR AVAILED
4760	29-Jul-24	MYSORE	66	TRANSFORMER	HV2	MADIKERI_66	17:26	18:35	01:08	LINE CLEAR AVAILED
4761	29-Jul-24	MYSORE	66	TRANSFORMER	HV2	MYSORESOUTH_66	11:54	12:04	00:10	TRIPPED ON FAULT
4762	29-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4763	29-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4764	29-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4765	29-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4766	29-Jul-24	MYSORE	66	LINE	MADIKERI-KUSHALANAGARA	MADIKERI_66 VIRAJPET_66	09:34	12:56	03:22	LINE CLEAR AVAILED
4767	29-Jul-24	MYSORE	66	LINE	MADIKERI-KUSHALANAGARA	NO STATIONS EFFECTED	16:19	19:04	02:45	LINE CLEAR AVAILED
4768	29-Jul-24	MYSORE	66	LINE	MADIKERI-SUNTIKOPPA	NO STATIONS EFFECTED	5:31 (27/07/2024)	19:26 (29/07/2024)	61:55 HRs	TRIPPED ON FAULT
4769	29-Jul-24	MYSORE	66	LINE	NAGAMANGALA 220-B G NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	07:33	07:46	00:13	TRIPPED ON FAULT
4770	29-Jul-24	MYSORE	66	LINE	PANNIYADHUNDI-KEREHALLI LIS (EHT)	NO STATIONS EFFECTED	06:00	06:05	00:05	TRIPPED ON FAULT
4771	29-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	MADIKERI_66 VIRAJPET_66	12:01	16:12	04:11	TRIPPED ON FAULT
4772	29-Jul-24	MYSORE	220	TRANSFORMER	HV1	MADHUVANAHALLI_220	14:58	15:19	00:20	LINE CLEAR AVAILED
4773	29-Jul-24	MYSORE	220	TRANSFORMER	HV2	MADHUVANAHALLI_220	13:43	14:44	01:00	LINE CLEAR AVAILED
4774	29-Jul-24	MYSORE	220	LINE	MADHUVANAHALLI-CR NAGARA-2	NO STATIONS EFFECTED	15:30	16:06	00:36	LINE CLEAR AVAILED
4775	29-Jul-24	MYSORE	220	LINE	MADHUVANAHALLI-HEBBANI-2	NO STATIONS EFFECTED	10:30	13:32	03:01	LINE CLEAR AVAILED
4776	29-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4777	29-Jul-24	TUMKUR	66	LINE	LOKIKERE-KEREBILCHI_66	KEREBILCHI_66, SANTHEBENNURU_66	11:50	12:10	00:20	LINE CLEAR AVAILED
4778	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4779	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,12.5MVA	HARIYABBE_66	17:30	17:35	00:05	LINE CLEAR AVAILED
4780	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,20MVA	KUNIGAL_66	09:50	13:45	03:55	LINE CLEAR AVAILED
4781	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,8MVA	KATTIGE_66	10:35	10:40	00:05	TRIPPED ON FAULT
4782	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-1,8MVA	P.D,KOTE_66	10:00	10:05	00:05	TRIPPED ON FAULT
4783	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-2,12.5MVA	HALURAMESWARA_66	13:40	13:56	00:16	TRIPPED ON FAULT
4784	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-2,8MVA	HARIYABBE_66	17:40	17:45	00:05	LINE CLEAR AVAILED
4785	29-Jul-24	TUMKUR	66	TRANSFORMER	TR-3,12.5MVA	HARIYABBE_66	17:35	17:40	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4786	29-Jul-24	TUMKUR	110	LINE	110KV TURUVEKERE-220KV K B CROSS	TURUVEKERE_110	13:25	13:55	00:30	LINE CLEAR AVAILED
4787	29-Jul-24	TUMKUR	110	TRANSFORMER	TR-1,20MVA	TURUVEKERE_110	13:25	13:55	00:30	LINE CLEAR AVAILED
4788	29-Jul-24	TUMKUR	110	TRANSFORMER	TR-2,20MVA	TURUVEKERE_110	13:25	13:55	00:30	LINE CLEAR AVAILED
4789	29-Jul-24	TUMKUR	220	LINE	CHITRADURGA _220-PGCIL _220	CHITRADURGA_220	20:36 (27.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4790	29-Jul-24	TUMKUR	220	LINE	CHITRADURGA 220KV-HIREMALLANAHOLE 1_220	CHITRADURGA_220	16:20 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4791	29-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV- VASANTANARASAPURA 1	VASANTANARASAPURA	13:33 (27.07.2024)	12:01 (29.07.2024)	1 DAY 22HRS 28MIN	TRIPPED ON FAULT
4792	29-Jul-24	TUMKUR	220	LINE	MADHUGIRI 220KV- VASANTANARASAPURA 2	VASANTANARASAPURA	07:45	11:33	03:48	LINE CLEAR AVAILED
4793	29-Jul-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA _220	CHITRADURGA_220	16:23 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4794	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	CHIKKODI_220	16:18	17:40	01:22	LINE CLEAR AVAILED
4795	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	ATHANI_220	19:25	19:48	00:23	LINE CLEAR AVAILED
4796	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	DADDI_110	15:17	16:23	01:06	LINE CLEAR AVAILED
4797	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	DEVANGOAN_110	15:33	17:36	02:03	LINE CLEAR AVAILED
4798	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MACHE_110	16:02	16:36	00:34	LINE CLEAR AVAILED
4799	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	DEVANGOAN_110	17:36	19:00	01:24	LINE CLEAR AVAILED
4800	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KAGAWADA_110	10:15	12:15	02:00	LINE CLEAR AVAILED
4801	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALADAGI_110	3:19	3:57	00:38	TRIPPED ON FAULT
4802	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALADAGI_110	14:07	14:57	00:50	LINE CLEAR AVAILED
4803	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALADAGI_110	15:10	15:15	00:05	LINE CLEAR AVAILED
4804	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	NAVALAGI_110	14:12	18:44	04:32	LINE CLEAR AVAILED
4805	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YADWAD_110	10:23	15:55	05:32	LINE CLEAR AVAILED
4806	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	YADWAD_110	18:06	18:32	00:26	LINE CLEAR AVAILED
4807	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(10MVA)	YADWAD_110	15:55	17:05	01:10	TRIPPED ON FAULT
4808	30-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	KANABARGI LAYOUT_110	22:57	23:17	00:20	TRIPPED ON FAULT
4809	30-Jul-24	BAGALKOTE	110	LINE	AHERI220- ALMEL	AHERI_220	16:06	16:46	00:40	LINE CLEAR AVAILED
4810	30-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-SUPA-1	AMBEWADI_220	12:42	14:56	02:14	TRIPPED ON FAULT
4811	30-Jul-24	BAGALKOTE	110	LINE	ANNIGERI- GADAG	ANNIGERI_110	14:40	16:50	02:10	LINE CLEAR AVAILED
4812	30-Jul-24	BAGALKOTE	110	LINE	BIDNAL220- ANNIGERI	BIDNAL_220	14:42	16:36	01:54	LINE CLEAR AVAILED
4813	30-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	13:13 (28.07.2024)			LINE CLEAR AVAILED
4814	30-Jul-24	BAGALKOTE	110	LINE	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	05:51	06:02	00:11	TRIPPED ON FAULT
4815	30-Jul-24	BAGALKOTE	110	LINE	MAMADAPUR(B)- BELGAUM SOLAR	MAMADAPUR_110	06:03	06:33	00:30	TRIPPED ON FAULT
4816	30-Jul-24	BAGALKOTE	110	LINE	MAMADAPUR(B)- TODALBAGI (SAVALAGI)	MAMADAPUR_110	06:03	06:14	00:11	TRIPPED ON FAULT
4817	30-Jul-24	BAGALKOTE	110	LINE	MAMADAPUR-SB LAKMI	MAMADAPUR(G)_110	06:19	06:34	00:15	TRIPPED ON FAULT
4818	30-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4819	30-Jul-24	BAGALKOTE	110	LINE	NAREGAL-RON	NAREGAL_110	11:51	11:55	00:04	LINE CLEAR AVAILED
4820	30-Jul-24	BAGALKOTE	110	LINE	NAVALGUND-BIDNAL	NAVALGUND_110	6:07 (29.07.2024)	8:31 (30.07.2024)	26:24:00	TRIPPED ON FAULT
4821	30-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4822	30-Jul-24	BAGALKOTE	110	LINE	RON-NAREGAL	RON_110	11:31	11:57	00:26	LINE CLEAR AVAILED
4823	30-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4824	30-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL II	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4825	30-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
4826	30-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	AMBEWADI_220	12:43	14:57	02:14	TRIPPED ON FAULT
4827	30-Jul-24	BAGALKOTE	220	LINE	BIDNAL- HUBLI2	BIDNAL_220	12:01	17:48	05:47	TRIPPED ON FAULT
4828	30-Jul-24	BAGALKOTE	220	LINE	DHONI- GADAG1	DHONI_400	10:54	13:44	02:50	LINE CLEAR AVAILED
4829	30-Jul-24	BAGALKOTE	220	LINE	GADAG- LINGAPUR1(GADAG1)	GADAG_220	10:54	13:44	02:50	LINE CLEAR AVAILED
4830	30-Jul-24	BAGALKOTE	220	LINE	HUBLI- BIDNAL2	HUBLI_220	12:01	17:48	05:47	TRIPPED ON FAULT
4831	30-Jul-24	BAGALKOTE	220	LINE	MAHALINGAPUR- VAJRAMATTI	MAHALINGAPUR_220	12:03	13:34	01:31	LINE CLEAR AVAILED
4832	30-Jul-24	BAGALKOTE	220	LINE	VAJRAMATTI-MAHALINGPUR1	VAJRAMATTI_220	12:05	13:35	01:30	LINE CLEAR AVAILED
4833	30-Jul-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:34	05:48	00:14	TRIPPED ON FAULT
4834	30-Jul-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - KALYANI TECH PARK	KALYANI TECH PARK	12:35	12:37	00:02	LINE CLEAR AVAILED
4835	30-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	10:04	10:16	00:12	LINE CLEAR AVAILED
4836	30-Jul-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	22:18	22:28	00:10	TRIPPED ON FAULT
4837	30-Jul-24	BANGALORE	66	LINE	66KV HBR LAYOUT 220 - POTTERY ROAD	POTTERY ROAD	13:12	13:15	00:03	LINE CLEAR AVAILED
4838	30-Jul-24	BANGALORE	66	LINE	66KV KALYANI TECH PARK - EXORA BUSINESS PARK	EXORA 66(EHT)	10:40	10:42	00:02	LINE CLEAR AVAILED
4839	30-Jul-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	11:05	14:10	03:05	LINE CLEAR AVAILED
4840	30-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4841	30-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHIDS	10:58	15:14	04:16	LINE CLEAR AVAILED
4842	30-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	10:58	15:14	04:16	LINE CLEAR AVAILED
4843	30-Jul-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	10:05	17:05	07:00	LINE CLEAR AVAILED
4844	30-Jul-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	08:17	08:30	00:13	TRIPPED ON FAULT
4845	30-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	19:14	19:19	00:05	LINE CLEAR AVAILED
4846	30-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	GURUVINAPURA, BV HALLI	12:04	14:04	02:00	LINE CLEAR AVAILED
4847	30-Jul-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	16:07	16:15	00:08	LINE CLEAR AVAILED
4848	30-Jul-24	BANGALORE	66	TRANSFORMER	HV1	ADDAGAL	16:20	17:05	00:45	LINE CLEAR AVAILED
4849	30-Jul-24	BANGALORE	66	TRANSFORMER	HV1	DEVANAHALLI 66	07:40	07:50	00:10	TRIPPED ON FAULT
4850	30-Jul-24	BANGALORE	66	TRANSFORMER	HV1	KALYANI TECH PARK	12:30	12:32	00:02	LINE CLEAR AVAILED
4851	30-Jul-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	10:05	17:08	07:03	LINE CLEAR AVAILED
4852	30-Jul-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	11:48	12:01	00:13	TRIPPED ON FAULT
4853	30-Jul-24	BANGALORE	66	TRANSFORMER	HV2	K&C VALLEY	10:39	10:45	00:06	LINE CLEAR AVAILED
4854	30-Jul-24	BANGALORE	66	TRANSFORMER	HV2	KALYANI TECH PARK	10:40	10:42	00:02	LINE CLEAR AVAILED
4855	30-Jul-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	10:05	18:02	07:57	LINE CLEAR AVAILED
4856	30-Jul-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	NO STATION AFFECTED	19:10	19:33	00:23	TRIPPED ON FAULT
4857	30-Jul-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	11:51	14:05	02:14	TRIPPED ON FAULT
4858	30-Jul-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASAPURA 1	NO STATION AFFECTED	11:51	14:10	02:19	TRIPPED ON FAULT
4859	30-Jul-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4860	30-Jul-24	BANGALORE	220	TRANSFORMER	HV2	EXORA 220	13:57	14:13	00:16	TRIPPED ON FAULT
4861	30-Jul-24	GULBARGA	66	LINE	BADALADUKU-BANVEKAL	BANVEKAL_66	19:15	19:35	00:20	TRIPPED ON FAULT
4862	30-Jul-24	GULBARGA	66	LINE	CHORNOOR-BADALADUKU	CHORNOOR_66	06:15	06:35	00:20	TRIPPED ON FAULT
4863	30-Jul-24	GULBARGA	66	LINE	CHORNOOR-BADALADUKU	CHORNOOR_66	06:15	06:35	00:20	TRIPPED ON FAULT
4864	30-Jul-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	10:55	11:05	00:10	TRIPPED ON FAULT
4865	30-Jul-24	GULBARGA	66	LINE	KUDLIGI-BADALADUKU	KUDILIGI_66,HANASI_66,KOGALI_66	06:15	06:40	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4866	30-Jul-24	GULBARGA	110	LINE	ALIPUR-DHADESUGUR	TEKKALKOTE_110,SIRIGIRICROSS_110	03:15	03:25	00:10	MAIN SUPPLY FAILURE
4867	30-Jul-24	GULBARGA	110	LINE	ALIPUR-SOUTHLINE	HALKUNDI_110,SOUTH_110	06:24	06:44	00:20	TRIPPED ON FAULT
4868	30-Jul-24	GULBARGA	110	LINE	BISILHALLI-HALAKUNDI	BISILHALLI_110	06:24	06:48	00:24	TRIPPED ON FAULT
4869	30-Jul-24	GULBARGA	110	LINE	FARTHABAD-SHAHABAD	FARTHABAD_110, MARTOOR RAILWAY TRACTION	21:54	22:03	00:09	TRIPPED ON FAULT
4870	30-Jul-24	GULBARGA	110	LINE	GABUR-RAICHUR	GUGAL_110, GABUR_110	21:05	22:00	00:55	TRIPPED ON FAULT
4871	30-Jul-24	GULBARGA	110	LINE	HALBARGA-SANTHPUR	SANTHPUR_110	10:50	11:06	00:16	TRIPPED ON FAULT
4872	30-Jul-24	GULBARGA	110	TRANSFORMER	HV2	APMC_110	13:15	13:30	00:15	LINE CLEAR AVAILED
4873	30-Jul-24	GULBARGA	110	TRANSFORMER	HV3	APMC_110	13:50	14:00	00:10	LINE CLEAR AVAILED
4874	30-Jul-24	GULBARGA	110	LINE	KAMPLI-MALLAPURA	MALLAPURA_110	09:30	09:40	00:10	LINE CLEAR AVAILED
4875	30-Jul-24	GULBARGA	110	LINE	KAMPLI-MALLAPURA	MALLAPURA_110	13:15	13:20	00:05	LINE CLEAR AVAILED
4876	30-Jul-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KHANAPUR_110	23:48	23:58	00:10	TRIPPED ON FAULT
4877	30-Jul-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	00:20	00:27	00:07	TRIPPED ON FAULT
4878	30-Jul-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	22:01	22:12	00:11	TRIPPED ON FAULT
4879	30-Jul-24	GULBARGA	110	LINE	LINGASUGUR-MUDGAL	MUDGAL_110	13:40	13:52	00:12	TRIPPED ON FAULT
4880	30-Jul-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	06:35	21:25	14:50	LINE CLEAR AVAILED
4881	30-Jul-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERI CROSS_110	03:15	03:25	00:10	MAIN SUPPLY FAILURE
4882	30-Jul-24	GULBARGA	220	TRANSFORMER	HV2	ALIPUR_220	02:48	03:13	00:25	MAIN SUPPLY FAILURE
4883	30-Jul-24	GULBARGA	220	TRANSFORMER	HV2	ALIPUR_220	03:16	03:33	00:17	TRIPPED ON FAULT
4884	30-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
4885	30-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
4886	30-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4887	30-Jul-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	19:03	19:14	00:11	TRIPPED ON FAULT
4888	30-Jul-24	HASSAN	66	TRANSFORMER	HV1	DODDAMAGGE_66	10:52	12:04	01:12	LINE CLEAR AVAILED
4889	30-Jul-24	HASSAN	66	TRANSFORMER	HV1	DUDDA_66	13:39	14:07	00:28	LINE CLEAR AVAILED
4890	30-Jul-24	HASSAN	66	TRANSFORMER	HV1 CB	MNJUNATHPURA_66	11:08	11:57	00:49	LINE CLEAR AVAILED
4891	30-Jul-24	HASSAN	66	TRANSFORMER	HV2	DIDIGA_66	05:30	05:56	00:26	TRIPPED ON FAULT
4892	30-Jul-24	HASSAN	66	TRANSFORMER	HV2	DIDIGA_66	09:36	09:43	00:07	TRIPPED ON FAULT
4893	30-Jul-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	07:30	16:19	08:49	LINE CLEAR AVAILED
4894	30-Jul-24	HASSAN	110	TRANSFORMER	HV3	PUTTUR_110	15:47	17:29	01:42	LINE CLEAR AVAILED
4895	30-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	19:13(29.07.2024)	1:09 (30.07.2024)	5:58 hrs	LINE CLEAR AVAILED
4896	30-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	07:01	07:13	00:12	TRIPPED ON FAULT
4897	30-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	07:15	12:58	05:43	LINE CLEAR AVAILED
4898	30-Jul-24	HASSAN	110	LINE	KEMAR-NANDHIKUR2	KEMAR_220	06:56	07:18	00:22	TRIPPED ON FAULT
4899	30-Jul-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	03:51	12:08	08:17	TRIPPED ON FAULT
4900	30-Jul-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	06:12	13:53	07:41	TRIPPED ON FAULT
4901	30-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY1	MRSMG_220	7:58(29.07.2024)	19:20(30.07.2024)	88:21 hrs	LINE CLEAR AVAILED
4902	30-Jul-24	HASSAN	110	LINE	MRSSHM-BADRAVATY2	MRSMG_220	8:12(29.07.2024)	19:21(30.07.2024)	35:8 hrs	LINE CLEAR AVAILED
4903	30-Jul-24	HASSAN	110	TRANSFORMER	MSEZ-HV1	MSEZ_220	11:22	12:34	01:12	LINE CLEAR AVAILED
4904	30-Jul-24	HASSAN	110	LINE	NANDIK-ISTR	NANDIKUR_110	07:00	07:23	00:23	MAIN SUPPLY FAILURE
4905	30-Jul-24	HASSAN	110	LINE	NANDIKU-KEMAR2	NANDIKUR_110	06:56	07:19	00:23	TRIPPED ON FAULT
4906	30-Jul-24	HASSAN	110	LINE	NANDIKU-NDKR-SUZLON	NANDIKUR_110	07:00	07:24	00:24	MAIN SUPPLY FAILURE
4907	30-Jul-24	HASSAN	110	LINE	PUTTUR-PUTUR 2	PUTTUR_220	06:11	13:52	07:41	TRIPPED ON FAULT
4908	30-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	06:16	06:42	00:26	MAIN SUPPLY FAILURE
4909	30-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	13:59	14:01	00:02	MAIN SUPPLY FAILURE
4910	30-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	06:41	06:43	00:02	MAIN SUPPLY FAILURE
4911	30-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTALA_110	06:12	06:43	00:31	MAIN SUPPLY FAILURE
4912	30-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTALA_110	13:59	14:01	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4913	30-Jul-24	HASSAN	220	TRANSFORMER	HV2	AREHALLI_66	22:50(30.07.2024)			TRIPPED ON FAULT
4914	30-Jul-24	HASSAN	220	LINE	KAVOOR-KEMR1	KAVOOR_220	09:27	10:31	01:04	LINE CLEAR AVAILED
4915	30-Jul-24	HASSAN	220	LINE	KAVOOR-KEMR2	KAVOOR_220	10:34	11:16	00:42	LINE CLEAR AVAILED
4916	30-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	21:39(30.07.2024)			LINE CLEAR AVAILED
4917	30-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	16:39	21:36	04:57	LINE CLEAR AVAILED
4918	30-Jul-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	10:34	11:16	00:42	LINE CLEAR AVAILED
4919	30-Jul-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	09:28	10:31	01:03	LINE CLEAR AVAILED
4920	30-Jul-24	MYSORE	66	LINE	BOOKANAKERE-CHINAKURALI	BANANGADI_66 CHIDRAVALLI_66	08:09	08:17	00:07	TRIPPED ON FAULT
4921	30-Jul-24	MYSORE	66	LINE	CR NAGARA-HARVEY	NO STATIONS EFFECTED	06:52	09:13	02:21	LINE CLEAR AVAILED
4922	30-Jul-24	MYSORE	66	LINE	DEVNUR(N'GUD)-BAS1	NO STATIONS EFFECTED	13:39	13:53	00:14	TRIPPED ON FAULT
4923	30-Jul-24	MYSORE	66	LINE	HARVEY-BEGUR 220	HARVEY_66	09:25	10:40	01:15	LINE CLEAR AVAILED
4924	30-Jul-24	MYSORE	66	LINE	HARVEY-CR NAGARA	NO STATIONS EFFECTED	18:32 (29/07/2024)	11:01 (30/07/2024)	16:28 HRs	LINE CLEAR AVAILED
4925	30-Jul-24	MYSORE	66	LINE	HARVEY-KABBALLI	NO STATIONS EFFECTED	06:50	09:15	02:25	LINE CLEAR AVAILED
4926	30-Jul-24	MYSORE	66	LINE	HEBBANI-BG PURA-CHIDRAVALLI	CHIDRAVALLI_66 BGPURA_66	02:06	02:19	00:13	TRIPPED ON FAULT
4927	30-Jul-24	MYSORE	66	TRANSFORMER	HV1	HARVEY_66	18:02	18:10	00:07	TRIPPED ON FAULT
4928	30-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	02:13	09:15	07:01	TRIPPED ON FAULT
4929	30-Jul-24	MYSORE	66	TRANSFORMER	HV1	PONNAMPET_66	17:55	18:30	00:35	TRIPPED ON FAULT
4930	30-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4931	30-Jul-24	MYSORE	66	TRANSFORMER	HV2	HARADANAHALLI_66	12:25	13:20	00:55	LINE CLEAR AVAILED
4932	30-Jul-24	MYSORE	66	TRANSFORMER	HV2	PONNAMPET_66	17:55	18:30	00:35	TRIPPED ON FAULT
4933	30-Jul-24	MYSORE	66	TRANSFORMER	HV3	PONNAMPET_66	17:55	18:30	00:35	TRIPPED ON FAULT
4934	30-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
4935	30-Jul-24	MYSORE	66	LINE	KUSHALNAGARA 220-MIRLE -GRAPHITE INDIA IPP- KR NAGARA	MIRLE_66	05:22	05:35	00:13	TRIPPED ON FAULT
4936	30-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
4937	30-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4938	30-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4939	30-Jul-24	MYSORE	66	LINE	MADHUVANALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	00:25	00:40	00:14	TRIPPED ON FAULT
4940	30-Jul-24	MYSORE	66	LINE	PONNAMPETE-HANAGODU- PERIYAPATNA	PONNAMPET_66	10:18	11:57	01:38	LINE CLEAR AVAILED
4941	30-Jul-24	MYSORE	66	LINE	PONNAMPETE-HANAGODU- PERIYAPATNA	PONNAMPET_66	12:47	14:51	02:03	LINE CLEAR AVAILED
4942	30-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	10:18	11:57	01:39	LINE CLEAR AVAILED
4943	30-Jul-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	12:47	14:52	02:05	LINE CLEAR AVAILED
4944	30-Jul-24	MYSORE	66	LINE	THALAGAVADI-T K HALLI	NO STATIONS EFFECTED	19:10	19:35	00:25	TRIPPED ON FAULT
4945	30-Jul-24	MYSORE	220	TRANSFORMER	HV2	MADHUVANAHALLI_220	12:05	13:07	01:01	LINE CLEAR AVAILED
4946	30-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
4947	30-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	13:15	13:34	00:19	TRIPPED ON FAULT
4948	30-Jul-24	TUMKUR	66	LINE	220KV MADHUGIRI-66KV KORATAGERE LINE 1	66KV HOLAVANAHALLI	18:28	18:48	00:20	TRIPPED ON FAULT
4949	30-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALRAMESHWARA MADADKERE LINE	66KV HALRAMESHWARA MADADKERE	08:10	08:30	00:20	TRIPPED ON FAULT
4950	30-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALRAMESHWARA MADADKERE LINE	66KV HALRAMESHWARA MADADKERE	11:15	11:20	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4951	30-Jul-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALRAMESHWARA MADADKERE LINE	66KV HALRAMESHWARA MADADKERE	16:15	16:20	00:05	LINE CLEAR AVAILED
4952	30-Jul-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	66KV RAMAGIRI	11:30	11:55	00:25	TRIPPED ON FAULT
4953	30-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	12:42	13:42	01:00	LINE CLEAR AVAILED
4954	30-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	15:08	15:54	00:46	LINE CLEAR AVAILED
4955	30-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:31	14:33	01:02	LINE CLEAR AVAILED
4956	30-Jul-24	TUMKUR	66	LINE	BILCHODU66-NEELAGUNDA_220	PALLAGATTE_66, BILCHODE_66	21:00	21:15	00:15	MAIN SUPPLY FAILURE
4957	30-Jul-24	TUMKUR	66	LINE	BILCHODU66-NEELAGUNDA_220	PALLAGATTE_66, BILCHODE_66	23:00	23:15	00:15	MAIN SUPPLY FAILURE
4958	30-Jul-24	TUMKUR	66	LINE	BILCHODU-PALLAGATTE	BILCHODU_66	06:10	06:15	00:05	TRIPPED ON FAULT
4959	30-Jul-24	TUMKUR	66	LINE	KEREBILCHE-SHAGLE	KEREBILCHE_66, SANTHEBENNUR_66	13:50	14:30	00:40	LINE CLEAR AVAILED
4960	30-Jul-24	TUMKUR	66	LINE	MADHUGIRI 220KV- KORATAGERE 1	KORATAGERE_66	18:20	18:40	00:20	TRIPPED ON FAULT
4961	30-Jul-24	TUMKUR	66	LINE	THIPPUR-ANCHEPALYA220	THIPPUR_66	15:05	15:50	00:45	MAIN SUPPLY FAILURE
4962	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1	THIPPUR_66	15:55	16:06	00:11	LINE CLEAR AVAILED
4963	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	ANCHEPALYA_66	12:45	12:50	00:05	TRIPPED ON FAULT
4964	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	HANGAL_66	17:25	17:35	00:10	LINE CLEAR AVAILED
4965	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	KOLALA_66	14:00	15:00	01:00	LINE CLEAR AVAILED
4966	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	NAGALAMADIKE_66	13:10	14:10	01:00	LINE CLEAR AVAILED
4967	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4968	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 20 MVA	CHANNAGIRI_66	12:57	14:30	01:33	LINE CLEAR AVAILED
4969	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 8MVA.	LOKIKERE_66	16:40	16:45	00:05	TRIPPED ON FAULT
4970	30-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	KUKKAWADA_66	13:16	13:29	00:13	TRIPPED ON FAULT
4971	30-Jul-24	TUMKUR	66	LINE	TURUVANUR66-JAGALUR	TURUVANUR_66	15:20	15:53	00:33	LINE CLEAR AVAILED
4972	30-Jul-24	TUMKUR	110	LINE	NITTUR 220KV- KALLUR	KALLUR_110	12:35	15:56	03:21	LINE CLEAR AVAILED
4973	30-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-PGCL_220KV	220KV CHITRADURGA	20:36 (27.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4974	30-Jul-24	TUMKUR	220	LINE	400KV HIREMALLANAHOLE 1-CHITRADURGA 220KV	CHITRADURGA_220	16:20 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4975	30-Jul-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA_220	CHITRADURGA_220	16:23 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
4976	30-Jul-24	TUMKUR	400	LINE	ICT-1	GUTTUR_400KV	12:36	15:33	02:57	LINE CLEAR AVAILED
4977	30-Jul-24	TUMKUR	400	LINE	ICT-2	GUTTUR_400KV	17:06	18:28	01:22	LINE CLEAR AVAILED
4978	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(5MVA)	ANMOD_110	9:55	10:20	00:25	LINE CLEAR AVAILED
4979	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BAGALKOT_110	11:08	11:51	00:43	LINE CLEAR AVAILED
4980	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	KALAGATAGI_110	13:00	13:45	00:45	LINE CLEAR AVAILED
4981	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	MATTIHAL_110	11:34	21:45	10:11	LINE CLEAR AVAILED
4982	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	AINAPUR_110	17:03	17:34	00:31	LINE CLEAR AVAILED
4983	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MATTIHAL_110	11:34	18:10	06:36	LINE CLEAR AVAILED
4984	31-Jul-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4(20MVA)	MACHE_110	10:30	18:13	07:43	LINE CLEAR AVAILED
4985	31-Jul-24	BAGALKOTE	110	LINE	AMBEWADI220-NK1(HALIYAL)	AMBEWADI_220	15:05	16:38	01:33	LINE CLEAR AVAILED
4986	31-Jul-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA2	ANKOLA_110	10:45	12:14	01:29	LINE CLEAR AVAILED
4987	31-Jul-24	BAGALKOTE	110	LINE	ATHANI220-AIGALI	ATHANI_220	21:35	22:15	00:40	TRIPPED ON FAULT
4988	31-Jul-24	BAGALKOTE	110	LINE	ATHANI220-ATHANI	ATHANI_220	21:36 (31.07.2024)			TRIPPED ON FAULT
4989	31-Jul-24	BAGALKOTE	110	LINE	BENAKATTI-F1(SOUDATTI)	BENAKATTI_110	21:58	22:14	00:16	LINE CLEAR AVAILED
4990	31-Jul-24	BAGALKOTE	110	LINE	BENAKATTI-F2(YARAGATTI)	BENAKATTI_110	22:01	22:14	00:13	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4991	31-Jul-24	BAGALKOTE	110	LINE	GAJENDRAGAD-KUSHTAGI	GAJENDRAGAD_110	13:13 (28.07.2024)			LINE CLEAR AVAILED
4992	31-Jul-24	BAGALKOTE	110	LINE	KIRUVATTI-SIRSI(AMBEWADI)	KIRUVATTI_110	20:25 (23.07.2023)	15:06 (31.07.2024)	186:41:00	LINE CLEAR AVAILED
4993	31-Jul-24	BAGALKOTE	110	LINE	MATTIHAL-MK HUBLI(BAGEWADI)	MATTIHAL_110	11:33	13:00	01:27	LINE CLEAR AVAILED
4994	31-Jul-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4995	31-Jul-24	BAGALKOTE	110	LINE	NAVANAGAR-BAGALKOT2	NAVANAGAR(B)_110	10:51 (17.07.2024)			LINE CLEAR AVAILED
4996	31-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220- MUNAVALLI	SOUDATTI_220	18:52 (31.07.2024)			TRIPPED ON FAULT
4997	31-Jul-24	BAGALKOTE	110	LINE	SOUDATTI220-BENAKATTI	SOUDATTI_220	21:55 (31.07.2024)			TRIPPED ON FAULT
4998	31-Jul-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4999	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- BILAGI	VAJRAMATTI_220	14:24	14:32	00:08	TRIPPED ON FAULT
5000	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- JK CEMENT	VAJRAMATTI_220	14:24	14:45	00:21	TRIPPED ON FAULT
5001	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- LOKAPUR	VAJRAMATTI_220	14:24	14:50	00:26	TRIPPED ON FAULT
5002	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR(MUDHOL)	VAJRAMATTI_220	14:24	14:47	00:23	TRIPPED ON FAULT
5003	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR1&2	VAJRAMATTI_220	14:24	14:47	00:23	TRIPPED ON FAULT
5004	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MELLIGERI	VAJRAMATTI_220	14:24	14:48	00:24	TRIPPED ON FAULT
5005	31-Jul-24	BAGALKOTE	110	LINE	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI_220	14:24	14:45	00:21	TRIPPED ON FAULT
5006	31-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-BIDNAL 2	SOUDATTI_220	10:49 (18.07.2024)			LINE CLEAR AVAILED
5007	31-Jul-24	BAGALKOTE	220	LINE	SOUNDATTI-MAHALINGAPURA-2	STATION NOT AFFECTED SOUNDATTI_220	11:47 (06.07.2024)			LINE CLEAR AVAILED
5008	31-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	VAJRAMATTI_220	14:24	14:29	00:05	TRIPPED ON FAULT
5009	31-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	VAJRAMATTI_220	14:24	14:39	00:15	TRIPPED ON FAULT
5010	31-Jul-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	ATHANI_220	21:36	22:05	00:29	TRIPPED ON FAULT
5011	31-Jul-24	BAGALKOTE	220	LINE	AMBEWADI- NAGJHARI1	AMBEWADI_220	12:36	17:45	05:09	LINE CLEAR AVAILED
5012	31-Jul-24	BAGALKOTE	220	LINE	VAJRAMATTI- KAVATAGI LIS	VAJRAMATTI_220	14:24	14:44	00:20	TRIPPED ON FAULT
5013	31-Jul-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	11:14	19:24	08:10	LINE CLEAR AVAILED
5014	31-Jul-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	18:28	18:50	00:22	TRIPPED ON FAULT
5015	31-Jul-24	BANGALORE	66	LINE	66KV BRIGADE UTOPIA - PRESTIGE LAKE SIDE HABITAT	PRESTIGE LAKE SIDE HABITAT, KACHAMARANAHALLI, DOMMASANDRA	20:57	21:25	00:28	TRIPPED ON FAULT
5016	31-Jul-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	07:08	07:18	00:10	LINE CLEAR AVAILED
5017	31-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - G KODIHALLI	G KODIHALLI	07:35	07:45	00:10	LINE CLEAR AVAILED
5018	31-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - K RAGHUTTAHALLI	RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	09:01	09:13	00:12	LINE CLEAR AVAILED
5019	31-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	09:01	09:13	00:12	LINE CLEAR AVAILED
5020	31-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	CHEEMANGALA, TALAGAWARA	09:01	09:13	00:12	LINE CLEAR AVAILED
5021	31-Jul-24	BANGALORE	66	LINE	66KV CHINTAMANI 66 - SM MANGALA	SM MANGALA	08:00	08:07	00:07	LINE CLEAR AVAILED
5022	31-Jul-24	BANGALORE	66	LINE	66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	DIVYASHREE TECH PARK, MINOR IRRIGATION, KACHAMARANAHALLI, DOMMASANDRA	21:45	22:05	00:20	TRIPPED ON FAULT
5023	31-Jul-24	BANGALORE	66	LINE	66KV KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5024	31-Jul-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	DODDERI, CHANDRAPPA CIRCLE	18:48	19:56	01:08	TRIPPED ON FAULT
5025	31-Jul-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, ASSOCIATE DÉCOR LTD (EHT), BEST STEEL(EHT)	19:31	20:10	00:39	TRIPPED ON FAULT
5026	31-Jul-24	BANGALORE	66	LINE	66KV MARALAVADI - GODUR	GODUR	18:58	19:08	00:10	TRIPPED ON FAULT
5027	31-Jul-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	NO STATION AFFECTED	09:49	23:59	14:10	TRIPPED ON FAULT
5028	31-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHIDS	10:53	15:31	04:38	LINE CLEAR AVAILED
5029	31-Jul-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	10:53	15:31	04:38	LINE CLEAR AVAILED
5030	31-Jul-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - THAYALUR	THAYALUR, NG HULKUR	16:37	16:51	00:14	TRIPPED ON FAULT
5031	31-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	10:02	10:08	00:06	LINE CLEAR AVAILED
5032	31-Jul-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	18:17	18:31	00:14	LINE CLEAR AVAILED
5033	31-Jul-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V R DODDI	BV HALLI, GURUVINAPURA	18:14	18:40	00:26	LINE CLEAR AVAILED
5034	31-Jul-24	BANGALORE	66	TRANSFORMER	HV1	AGALAKOTE	12:00	12:10	00:10	TRIPPED ON FAULT
5035	31-Jul-24	BANGALORE	66	TRANSFORMER	HV1	HEBBALA 220	00:28	01:25	00:57	TRIPPED ON FAULT
5036	31-Jul-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	02:20	02:35	00:15	TRIPPED ON FAULT
5037	31-Jul-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE LAKE SIDE HABITAT	20:57	23:20	02:23	TRIPPED ON FAULT
5038	31-Jul-24	BANGALORE	66	TRANSFORMER	HV1	TK HALLI 220	18:00	18:03	00:03	TRIPPED ON FAULT
5039	31-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	18:30	18:40	00:10	TRIPPED ON FAULT
5040	31-Jul-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKENAHALLI	18:47	19:12	00:25	TRIPPED ON FAULT
5041	31-Jul-24	BANGALORE	66	TRANSFORMER	HV2	NG HULKUR	12:05	12:50	00:45	LINE CLEAR AVAILED
5042	31-Jul-24	BANGALORE	66	TRANSFORMER	HV3	B STATION	07:15	07:20	00:05	LINE CLEAR AVAILED
5043	31-Jul-24	BANGALORE	220	LINE	220KV DABASPETE 220 - KADUR 220	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
5044	31-Jul-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	06:55	07:00	00:05	TRIPPED ON FAULT
5045	31-Jul-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI 1	HIREHADAGALI_66	19:04	19:17	00:13	TRIPPED ON FAULT
5046	31-Jul-24	GULBARGA	110	LINE	GUGAL-RAICHUR	GUGAL_110, GABUR_110	15:00	15:20	00:20	TRIPPED ON FAULT
5047	31-Jul-24	GULBARGA	110	LINE	MALLATADAVIAMARESHWAR	ADAVIAMARESHWAR_110	03:20	03:25	00:05	MAIN SUPPLY FAILURE
5048	31-Jul-24	GULBARGA	110	LINE	MALLATADAVIAMARESHWAR	ADAVIAMARESHWAR_110	22:22	22:25	00:03	MAIN SUPPLY FAILURE
5049	31-Jul-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	KEREHALLI_110	20:01	20:38	00:37	TRIPPED ON FAULT
5050	31-Jul-24	GULBARGA	110	LINE	SHAHAPUR-KHANAPUR1	KHANAPUR_110	21:02	21:19	00:17	TRIPPED ON FAULT
5051	31-Jul-24	GULBARGA	110	LINE	VEKATGIRI-MUNIRABAD	VENKATAGIRI_110	09:20	09:25	00:05	MAIN SUPPLY FAILURE
5052	31-Jul-24	GULBARGA	110	LINE	VEKATGIRI-MUNIRABAD	VENKATAGIRI_110	11:10	11:20	00:10	MAIN SUPPLY FAILURE
5053	31-Jul-24	GULBARGA	110	LINE	YADGIR-KHANAPUR	YADGIR_110	21:02	21:19	00:17	TRIPPED ON FAULT
5054	31-Jul-24	GULBARGA	220	TRANSFORMER	HV1	KUSHTAGI_220	10:40	14:05	03:25	LINE CLEAR AVAILED
5055	31-Jul-24	GULBARGA	220	LINE	LINGASUGUR-B BAGEWADI 2	LINGASUGUR_220	00:00	24:00:00	24:00:00	TRIPPED ON FAULT
5056	31-Jul-24	GULBARGA	220	LINE	LINGASUGUR-NAGABENAL	LINGASUGUR_220	00:00	24:00:00	24:00:00	LINE CLEAR AVAILED
5057	31-Jul-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
5058	31-Jul-24	HASSAN	66	TRANSFORMER	HV1	MALLIPATNA_66	12:10	13:20	01:10	LINE CLEAR AVAILED
5059	31-Jul-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	11:40	14:20	02:40	MAIN SUPPLY FAILURE
5060	31-Jul-24	HASSAN	66	TRANSFORMER	HV2	AREHALLI_66	22:50(30.07.2024)	0:55(31.07.2024)	2:04 hrs	LINE CLEAR AVAILED
5061	31-Jul-24	HASSAN	66	TRANSFORMER	HV2	AREHALLI_66	04:20	14:25	10:05	TRIPPED ON FAULT
5062	31-Jul-24	HASSAN	66	LINE	MALLIPA-SANIVARSANTE	MALLIPATNA_66	11:40	12:10	00:30	LINE CLEAR AVAILED
5063	31-Jul-24	HASSAN	66	LINE	YESLUR-SNVRST	YESLUR_66	11:58	14:20	02:22	MAIN SUPPLY FAILURE
5064	31-Jul-24	HASSAN	110	LINE	ARSK2-BANAVARA	ARSIKERE_220	12:25	12:50	00:25	LINE CLEAR AVAILED
5065	31-Jul-24	HASSAN	110	LINE	ARSK2-BANAVARA	ARSIKERE_220	19:17	19:35	00:18	LINE CLEAR AVAILED
5066	31-Jul-24	HASSAN	110	LINE	HALADY1-HIRIYADKA	HALADY_110	11:31	14:05	02:34	LINE CLEAR AVAILED
5067	31-Jul-24	HASSAN	110	LINE	HGUNJE-HALADY	HEGGUNJE_220	11:31	14:05	02:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5068	31-Jul-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADI_110	10:25	17:00	06:35	LINE CLEAR AVAILED
5069	31-Jul-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	11:20	12:06	00:46	LINE CLEAR AVAILED
5070	31-Jul-24	HASSAN	110	TRANSFORMER	HV1	SALATHUR_110	10:52	14:29	03:37	LINE CLEAR AVAILED
5071	31-Jul-24	HASSAN	110	LINE	JST1	gen_mghe	10:41	15:05	04:24	LINE CLEAR AVAILED
5072	31-Jul-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	03:22	03:30	00:08	TRIPPED ON FAULT
5073	31-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	11:05	12:51	01:46	LINE CLEAR AVAILED
5074	31-Jul-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	14:25	14:28	00:03	MAIN SUPPLY FAILURE
5075	31-Jul-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	11:05	14:26	03:21	LINE CLEAR AVAILED
5076	31-Jul-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	15:52	17:00	01:08	TRIPPED ON FAULT
5077	31-Jul-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_110	11:05	14:26	03:21	LINE CLEAR AVAILED
5078	31-Jul-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	21:39(30.07.2024)			LINE CLEAR AVAILED
5079	31-Jul-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	16:47	19:06	02:19	LINE CLEAR AVAILED
5080	31-Jul-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	03:22	06:33	03:11	TRIPPED ON FAULT
5081	31-Jul-24	MYSORE	66	LINE	BOOKANAKERE-CHINKURALI	BANANGADI_66CHINAKURALI_66	02:03	08:24	06:21	TRIPPED ON FAULT
5082	31-Jul-24	MYSORE	66	TRANSFORMER	HV1	KOLLEGALA_66	19:40	19:48	00:08	TRIPPED ON FAULT
5083	31-Jul-24	MYSORE	66	TRANSFORMER	HV1	PERIYAPATNA_66	14:57	18:04	03:06	TRIPPED ON FAULT
5084	31-Jul-24	MYSORE	66	TRANSFORMER	HV1	PERIYAPATNA_66	10:04	10:10	00:06	LINE CLEAR AVAILED
5085	31-Jul-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5086	31-Jul-24	MYSORE	66	TRANSFORMER	HV2	PERIYAPATNA_66	10:14	10:20	00:06	LINE CLEAR AVAILED
5087	31-Jul-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	9:00:00 (04/07/2024)			LINE CLEAR AVAILED
5088	31-Jul-24	MYSORE	66	LINE	KOTTANUR-HANNUR	NO STATIONS EFFECTED	18:50	18:55	00:05	TRIPPED ON FAULT
5089	31-Jul-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULLUSOGGE LIS	NO STATIONS EFFECTED	17:29 (18/07/2024)			TRIPPED ON FAULT
5090	31-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5091	31-Jul-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
5092	31-Jul-24	MYSORE	220	TRANSFORMER	HV1	NAGAMANGALA_220	18:49	22:02	03:13	LINE CLEAR AVAILED
5093	31-Jul-24	MYSORE	220	TRANSFORMER	HV2	NAGAMANGALA_220	18:49	22:02	03:13	LINE CLEAR AVAILED
5094	31-Jul-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 1	NO STATIONS EFFECTED	18:55	22:00	03:05	LINE CLEAR AVAILED
5095	31-Jul-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	18:55	22:00	03:05	LINE CLEAR AVAILED
5096	31-Jul-24	MYSORE	220	LINE	TUBINKERE-KOTHIPURA	NO STATIONS EFFECTED	16:00	17:06	01:06	TRIPPED ON FAULT
5097	31-Jul-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2	66KV HULLENAHALLI,KUDUR,SRIGIRIPURA	18:28	18:50	00:22	TRIPPED ON FAULT
5098	31-Jul-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV B G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIYUR	15:02	22:12	07:10	TRIPPED ON FAULT
5099	31-Jul-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV DEVARAHALLI LINE	66KV DEVARAHALLI,SANTHEBENNUR,KE REBILACHI	15:35	15:54	00:19	TRIPPED ON FAULT
5100	31-Jul-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV SUZLON LINE 1	220KV CHITRADURGA	13:21 (08.07.2024)	LINE NOT YET CHARGED		TRIPPED ON FAULT
5101	31-Jul-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV ANAGODU LINE	66KV ANAGODU,ATTIGERE	15:31	15:39	00:08	TRIPPED ON FAULT
5102	31-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV BANUVALLI LINE	66KV NANDIGUDI,BANUVALLI,EHT CARGIL	16:12	16:25	00:13	TRIPPED ON FAULT
5103	31-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR,MALEBENNUR, DEVARBELAKERE	15:48	15:58	00:10	TRIPPED ON FAULT
5104	31-Jul-24	TUMKUR	66	LINE	220KV HONNALI-66KV SASVEHALLI LINE	66KV SASVEHALLI	13:31	LINE NOT YET CHARGED		TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5105	31-Jul-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE 1	BG.KERE	06:11	06:29	00:18	TRIPPED ON FAULT
5106	31-Jul-24	TUMKUR	66	LINE	66KV GARAGA-66KV PANCHANAHALLI LINE	66KV PANCHANAHALLI	18:55	19:10	00:15	TRIPPED ON FAULT
5107	31-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:14	11:24	00:10	LINE CLEAR AVAILED
5108	31-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	11:14	14:18	03:04	LINE CLEAR AVAILED
5109	31-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- ANCHEPALYA-2	ANCHEPALYA 66KV	11:14	11:24	00:10	LINE CLEAR AVAILED
5110	31-Jul-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- HEBBUR	HEBBUR_66	11:14	11:24	00:10	LINE CLEAR AVAILED
5111	31-Jul-24	TUMKUR	66	LINE	CHITRADURGA 66KV- PANDARAHALLI 2 LINE	PANDARAHALLI_66	15:16	15:31	00:15	LINE CLEAR AVAILED
5112	31-Jul-24	TUMKUR	66	LINE	HANAGAL-GUDEKOTE(THALLAK)-1	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	06:11	06:30	00:19	TRIPPED ON FAULT
5113	31-Jul-24	TUMKUR	66	LINE	HANAGAL-GUDEKOTE(THALLAK)-2	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	06:11	06:25	00:14	TRIPPED ON FAULT
5114	31-Jul-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	14:35	LINE NOT YET CHARGED		LINE CLEAR AVAILED
5115	31-Jul-24	TUMKUR	66	LINE	KATTIGE- BEDRUKATTE	KATTIGE_66	20:57	21:05	00:08	TRIPPED ON FAULT
5116	31-Jul-24	TUMKUR	66	LINE	MADHUGIRI 220KV- NITRAHALLI	NITRAHALLI_66	09:04	09:36	00:32	TRIPPED ON FAULT
5117	31-Jul-24	TUMKUR	66	LINE	MALEEBENUR_66-KUNDUR_66	MALEEBENUR_66	15:50	16:00	00:10	MAIN SUPPLY FAILURE
5118	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	BHARAMAGIRI_66	11:25	11:30	00:05	LINE CLEAR AVAILED
5119	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	BHARAMAGIRI_66	11:55	12:05	00:10	LINE CLEAR AVAILED
5120	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	CHITRAHALLI_66	12:40	12:45	00:05	TRIPPED ON FAULT
5121	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA	MELLEKATTE_66	08:55	10:15	01:20	LINE CLEAR AVAILED
5122	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-1 12.5MVA SANTEBENNUR_66	SANTEBENNUR_66	10:15 (19.07.24)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
5123	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MALEEBENUR_66	10:10	10:50	00:40	TRIPPED ON FAULT
5124	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MALEEBENUR_66	11:05	11:45	00:40	TRIPPED ON FAULT
5125	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 12.5MVA	MALEEBENUR_66	23:37	23:57	00:20	TRIPPED ON FAULT
5126	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA	GOPPENAHALLI_66	11:30	11:40	00:10	TRIPPED ON FAULT
5127	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 20MVA	GOPPENAHALLI_66	11:45	11:50	00:05	TRIPPED ON FAULT
5128	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 8 MVA	BHARAMAGIRI_66	11:40	11:50	00:10	LINE CLEAR AVAILED
5129	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 8 MVA	HANGAL_66	06:42	07:12	00:30	LINE CLEAR AVAILED
5130	31-Jul-24	TUMKUR	66	TRANSFORMER	TR-2 8 MVA	MELLEKATTE_66	08:55	10:15	01:20	LINE CLEAR AVAILED
5131	31-Jul-24	TUMKUR	220	TRANSFORMER	100 MVA TRANSFORMER-2 (LV SIDE)	ANCHEPALYA 220KV	11:14	11:22	00:08	LINE CLEAR AVAILED
5132	31-Jul-24	TUMKUR	220	LINE	220KV CHITRADURGA-PGCL_220KV	220KV CHITRADURGA	20:36 (27.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
5133	31-Jul-24	TUMKUR	220	LINE	400KV HIREMALLANAHOLE 1-CHITRADURGA 220KV	CHITRADURGA_220	16:20 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED
5134	31-Jul-24	TUMKUR	220	LINE	THALLAK 220KV-CHITRADURGA _220	CHITRADURGA_220	16:23 (28.07.2024)	LINE NOT YET CHARGED		LINE CLEAR AVAILED