

400/220/110/66 kV TRANSMISSION OUTAGES FOR THE MONTH OF JUNE-2024

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	07:25	07:37	00:12	TRIPPED ON FAULT
2	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	09:43	09:47	00:04	TRIPPED ON FAULT
3	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MANTUR(G)_110	19:08	19:16	00:08	TRIPPED ON FAULT
4	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MAMADAPUR(G)_110	11:15	17:07	05:52	LINE CLEAR AVAILED
5	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	NAVALAGI_110	10:53	17:03	06:10	LINE CLEAR AVAILED
6	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	GOKOK_110	10:32	10:38	00:06	TRIPPED ON FAULT
7	01-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	GHATAPRABHA_110	10:30	10:35	00:05	TRIPPED ON FAULT
8	01-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
9	01-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR-VIVASAUT SOLAR	BABALESHWAR_110	19:13	19:20	00:07	LINE CLEAR AVAILED
10	01-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
11	01-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
12	01-Jun-24	BAGALKOTE	110	LINE	JAMAKHANDI-PRABHU SUGARS	JAMAKHANDI_1100	17:20 (09.05.2024)	17:46 (01.06.2024)	552:26:00	LINE CLEAR AVAILED
13	01-Jun-24	BAGALKOTE	110	LINE	KARWAR220-ARGA(KUMTA)	KARWAR_220	11:42	19:52	08:10	LINE CLEAR AVAILED
14	01-Jun-24	BAGALKOTE	110	LINE	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
15	01-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
16	01-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(GOK)- SOUBHAGYA LAXMI IPP	SOUBHAGYA LAXMI IPP_110 STATION NOT AFFECTED MAMADAPUR(GOK)_110	02:29 (26.05.2024)	15:05 (01.06.2024)	156:36:00	LINE CLEAR AVAILED
17	01-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
18	01-Jun-24	BAGALKOTE	110	LINE	NAVALK-BIDNAL(F1 NOKR CB)	STATION NOT AFFECTED NAVALGUND_110	16:10	16:16	00:06	LINE CLEAR AVAILED
19	01-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
20	01-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
21	01-Jun-24	BAGALKOTE	110	LINE	SANKS110-CHIKKODI	SANKESHWAR_110	08:27	11:50	03:23	TRIPPED ON FAULT
22	01-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
23	01-Jun-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON2	STATION NOT AFFECTED SOUDATTI_110	11:38	12:37	00:59	LINE CLEAR AVAILED
24	01-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
25	01-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
26	01-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
27	01-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
28	01-Jun-24	BAGALKOTE	220	LINE	HUBLI- SIRSI1	HUBLI_220	15:52	17:53	02:01	LINE CLEAR AVAILED
29	01-Jun-24	BAGALKOTE	220	LINE	HUBLI- SIRSI2	HUBLI_220	15:53	17:54	02:01	LINE CLEAR AVAILED
30	01-Jun-24	BAGALKOTE	220	LINE	SIRSI- HUBLI1	SIRSI_220	15:43	17:54	02:11	LINE CLEAR AVAILED
31	01-Jun-24	BAGALKOTE	220	LINE	SIRSI- HUBLI2	SIRSI_220	15:43	17:58	02:15	LINE CLEAR AVAILED
32	01-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
33	01-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- KUDAGI1(KUDAGI2)	VAJRAMATTI_220	11:13	19:57	08:44	LINE CLEAR AVAILED
34	01-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- KUDAGI2(KUDAGI1)	VAJRAMATTI_220	11:13	19:34	08:21	LINE CLEAR AVAILED
35	01-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - C STATION	C STATION	13:50	13:55	00:05	LINE CLEAR AVAILED
36	01-Jun-24	BANGALORE	66	LINE	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGUR	22:50	22:55	00:05	TRIPPED ON FAULT
37	01-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	HEJJALA	15:50	16:05	00:15	LINE CLEAR AVAILED
38	01-Jun-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	10:22	10:26	00:04	LINE CLEAR AVAILED
39	01-Jun-24	BANGALORE	66	LINE	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	MANYATHA 66	16:59	17:23	00:24	LINE CLEAR AVAILED
40	01-Jun-24	BANGALORE	66	LINE	66KV DG3_ MANYATA 220 - SHOBHA CITY	SHOBHA CITY	14:55	17:17	02:22	TRIPPED ON FAULT
41	01-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL NORTON	11:08	13:24	02:16	LINE CLEAR AVAILED
42	01-Jun-24	BANGALORE	66	LINE	66KV EDC 220 - BMTC	BMTC, NATIONAL COLLEGE	20:18	20:49	00:31	TRIPPED ON FAULT
43	01-Jun-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	15:10	16:54	01:44	TRIPPED ON FAULT
44	01-Jun-24	BANGALORE	66	LINE	66KV GOKULA - MATHIKERE	MATHIKERE	15:10	15:32	00:22	TRIPPED ON FAULT
45	01-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	10:40	10:44	00:04	LINE CLEAR AVAILED
46	01-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	10:40	10:44	00:04	LINE CLEAR AVAILED
47	01-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	10:04	10:06	00:02	LINE CLEAR AVAILED
48	01-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - MATHIKERE	MATHIKERE	17:08	17:13	00:05	LINE CLEAR AVAILED
49	01-Jun-24	BANGALORE	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	20:25	20:50	00:25	TRIPPED ON FAULT
50	01-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 1	NARASAPURA, HONDA, WISTRON, KC VALLEY	20:39	20:58	00:19	TRIPPED ON FAULT
51	01-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 2	NARASAPURA, HONDA, WISTRON, KC VALLEY	20:39	20:53	00:14	TRIPPED ON FAULT
52	01-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	TALAGUNDA, KYALANUR, VEMGAL	16:55	17:04	00:09	TRIPPED ON FAULT
53	01-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA	TAMAKA	20:27	20:58	00:31	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
54	01-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	DODDERI, CHANDRAPPA CIRCLE	10:56	12:14	01:18	TRIPPED ON FAULT
55	01-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	06:49	07:01	00:12	TRIPPED ON FAULT
56	01-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, THIMMAMPALLI, GULUR	22:50	23:04	00:14	TRIPPED ON FAULT
57	01-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 1	NO STATION AFFECTED	22:30	00:50(02/06/2024)	02:20	TRIPPED ON FAULT
58	01-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	NO STATION AFFECTED	13:44	13:57	00:13	TRIPPED ON FAULT
59	01-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	SOMENAHALLI, PERESANDRA, NALLIMARADANAHALLI	22:30	23:20	00:50	TRIPPED ON FAULT
60	01-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISc	22:17	22:18	00:01	LINE CLEAR AVAILED
61	01-Jun-24	BANGALORE	66	LINE	66KV PATHPALYA - THIMMAMPALLI	THIMMAMPALLI	22:30	22:50	00:20	TRIPPED ON FAULT
62	01-Jun-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - GOKULA	GOKULA, MATHIKERE, RMV, BEL(EHT)	15:09	15:22	00:13	TRIPPED ON FAULT
63	01-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	SOMAYAJANAHALLI, LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI	21:02	21:10	00:08	TRIPPED ON FAULT
64	01-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	05:36	09:20	03:44	TRIPPED ON FAULT
65	01-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	15:36	15:48	00:12	TRIPPED ON FAULT
66	01-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	21:27	21:35	00:08	TRIPPED ON FAULT
67	01-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	21:37	22:18	00:41	TRIPPED ON FAULT
68	01-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	22:18	23:59	01:41	TRIPPED ON FAULT
69	01-Jun-24	BANGALORE	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	15:02	15:15	00:13	TRIPPED ON FAULT
70	01-Jun-24	BANGALORE	66	LINE	GOWRIBIDANUR 220 - AFTL(EHT)	AFTL(EHT)	15:45	17:18	01:33	LINE CLEAR AVAILED
71	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	18:28	18:38	00:10	LINE CLEAR AVAILED
72	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	19:45	19:55	00:10	TRIPPED ON FAULT
73	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	21:52	22:05	00:13	TRIPPED ON FAULT
74	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VR DODDI	02:20	02:25	00:05	TRIPPED ON FAULT
75	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KEMPANAHALLI	20:40	21:15	00:35	TRIPPED ON FAULT
76	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	14:46	15:33	00:47	TRIPPED ON FAULT
77	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	18:02	18:10	00:08	TRIPPED ON FAULT
78	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	16:56	17:03	00:07	TRIPPED ON FAULT
79	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	17:34	17:41	00:07	TRIPPED ON FAULT
80	01-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	22:50	23:03	00:13	TRIPPED ON FAULT
81	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PLATINUM CITY	23:28	23:42:00	00:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
82	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KADUBISANAHALLI	23:00	23:10	00:10	TRIPPED ON FAULT
83	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SOMANAHALLI 220	15:35	15:43	00:08	TRIPPED ON FAULT
84	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DODDABELAVANGALA	13:10	13:25	00:15	TRIPPED ON FAULT
85	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GUDIBANDE	10:45	12:15	01:30	TRIPPED ON FAULT
86	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SOMENAHALLI	23:45	23:59	00:14	TRIPPED ON FAULT
87	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ADDAGAL	07:20	07:35	00:15	TRIPPED ON FAULT
88	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ADDAGAL	13:00	13:35	00:35	TRIPPED ON FAULT
89	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SANJEEVANADODDI	05:08	05:15	00:07	TRIPPED ON FAULT
90	01-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GUDEMARANAHALLI	08:26	08:50	00:24	LINE CLEAR AVAILED
91	01-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66	13:04	13:11	00:07	TRIPPED ON FAULT
92	01-Jun-24	GULBARGA	66	TRANSFORMER	HV3 & HV4	ITTAGI_220	05:25	05:45	00:20	TRIPPED ON FAULT
93	01-Jun-24	GULBARGA	66	LINE	ITTAGI-HB HALLI	H B HALLI_66	05:25	05:58	00:33	TRIPPED ON FAULT
94	01-Jun-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	05:25	05:48	00:23	TRIPPED ON FAULT
95	01-Jun-24	GULBARGA	66	LINE	KUDALGI-KOTTUR	KOTTUR_66, UJJINI_66, SOKKE_66, NIMBALGERI_66	10:35	19:10	08:35	LINE CLEAR AVAILED
96	01-Jun-24	GULBARGA	66	TRANSFORMER	LV1 AND LV2	KUDALGI_220	13:05	13:15	00:10	TRIPPED ON FAULT
97	01-Jun-24	GULBARGA	110	LINE	CHITAPUR-SHAHBAD	CHITAPUR_110,KORWAR TEMPLE_110	16:00	16:20	00:20	MAIN SUPPLY FAILURE
98	01-Jun-24	GULBARGA	110	LINE	MANDEWAL-SHAHBAD	CHITAPUR_110,KORWAR TEMPLE_110	16:00	16:20	00:20	MAIN SUPPLY FAILURE
99	01-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	21:45	22:20	00:35	MAIN SUPPLY FAILURE
100	01-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	23:59	00:00	00:01	LINE CLEAR AVAILED
101	01-Jun-24	GULBARGA	110	LINE	SHAHAPUR-DEVAPUR	SHORAPUR_110,DEVAPUR_11 0	04:46	16:34	11:48	TRIPPED ON FAULT
102	01-Jun-24	GULBARGA	110	LINE	YEDRAMI-SHAHBAD	YEDRAMI_110,MANDEWAL_110	16:11	16:20	00:09	MAIN SUPPLY FAILURE
103	01-Jun-24	GULBARGA	220	LINE	KAPNOOR-FEROZABAD	KAPNOOR_220	15:58	16:19	00:21	MAIN SUPPLY FAILURE
104	01-Jun-24	GULBARGA	220	LINE	LINGASUGUR-CMHS	LINGASUGUR_220	20:20	21:01	00:41	TRIPPED ON FAULT
105	01-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
106	01-Jun-24	GULBARGA	220	LINE	NEELGUNDA-ITTAGI	NEELGUNDA_220	05:25	06:13	00:48	MAIN SUPPLY FAILURE
107	01-Jun-24	GULBARGA	220	LINE	SEDAM-HUMNABAD1	HUMNABAD_220	16:00	17:00	01:00	TRIPPED ON FAULT
108	01-Jun-24	GULBARGA	220	LINE	SEDAM-HUMNABAD1	HUMNABAD_220	16:00	18:10	02:10	TRIPPED ON FAULT
109	01-Jun-24	GULBARGA	220	LINE	SEDAM-HUMNABAD1	SEDAM_220	16:00	17:00	01:00	TRIPPED ON FAULT
110	01-Jun-24	GULBARGA	220	LINE	SEDAM-HUMNABAD2	SEDAM_220	16:00	18:10	02:10	TRIPPED ON FAULT
111	01-Jun-24	GULBARGA	220	LINE	SHAHABAD-SHAHAPUR	SHAHAPUR_220	11:04	16:27	05:23	LINE CLEAR AVAILED
112	01-Jun-24	GULBARGA	220	LINE	SHAHABAD-SHAHAPUR	SHAHAPUR_220	16:44	18:01	01:17	LINE CLEAR AVAILED
113	01-Jun-24	GULBARGA	220	LINE	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	10:49	16:34	05:45	LINE CLEAR AVAILED
114	01-Jun-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	03:40	04:01	00:21	TRIPPED ON FAULT
115	01-Jun-24	HASSAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	11:35	11:40	00:05	MAIN SUPPLY FAILURE
116	01-Jun-24	HASSAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	12:35	12:45	00:10	MAIN SUPPLY FAILURE
117	01-Jun-24	HASSAN	66	LINE	HASSN22-MALLALI	HASSAN_220	11:10	12:29	01:19	LINE CLEAR AVAILED
118	01-Jun-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	11:09	11:24	00:15	LINE CLEAR AVAILED
119	01-Jun-24	HASSAN	66	LINE	HASSN22-R R NAGAR	HASSAN_220	12:26	12:29	00:03	LINE CLEAR AVAILED
120	01-Jun-24	HASSAN	66	LINE	HASSN22-SKPURA	HASSAN_220	11:28	12:44	01:16	LINE CLEAR AVAILED
121	01-Jun-24	HASSAN	66	LINE	HASSN22-SKPURA1	HASSAN_220	11:27	11:45	00:18	LINE CLEAR AVAILED
122	01-Jun-24	HASSAN	66	LINE	HASSN22-SKPURA1	HASSAN_220	12:31	12:40	00:09	LINE CLEAR AVAILED
123	01-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPR2_220	18:01	18:13	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
124	01-Jun-24	HASSAN	66	LINE	HNPURA-KADVINKOTE	HNPURA_66	18:05	18:15	00:10	MAIN SUPPLY FAILURE
125	01-Jun-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	18:05	18:25	00:20	MAIN SUPPLY FAILURE
126	01-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
127	01-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
128	01-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
129	01-Jun-24	HASSAN	66	TRANSFORMER	HV1	UDAYAPURA_66	13:10	13:59	00:49	LINE CLEAR AVAIED
130	01-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
131	01-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
132	01-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
133	01-Jun-24	HASSAN	66	TRANSFORMER	LV1	HASSAN_220	11:36	12:25	00:49	LINE CLEAR AVAIED
134	01-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
135	01-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
136	01-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
137	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
138	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
139	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
140	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
141	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
142	01-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
143	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
144	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
145	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
146	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	11:30	11:35	00:05	MAIN SUPPLY FAILURE
147	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	11:40	11:45	00:05	MAIN SUPPLY FAILURE
148	01-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	12:30	12:40	00:10	MAIN SUPPLY FAILURE
149	01-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	21:25	21:31	00:06	TRIPPED ON FAULT
150	01-Jun-24	HASSAN	110	LINE	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	21:25	21:30	00:05	TRIPPED ON FAULT
151	01-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	11:01	14:53	03:52	LINE CLEAR AVAIED
152	01-Jun-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADI_110	10:35	11:43	01:08	LINE CLEAR AVAIED
153	01-Jun-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADI_110	12:31	15:36	03:05	LINE CLEAR AVAIED
154	01-Jun-24	HASSAN	110	TRANSFORMER	HV1	SALATHUR_110	10:13	15:38	05:25	LINE CLEAR AVAIED
155	01-Jun-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADI_110	10:19	10:34	00:15	LINE CLEAR AVAIED
156	01-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	11:01	14:53	03:52	LINE CLEAR AVAIED
157	01-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	09:03	12:28	03:25	TRIPPED ON FAULT
158	01-Jun-24	HASSAN	110	LINE	MRSSHM-GAJNUR	MRSMSG_220	09:57	13:25	03:28	LINE CLEAR AVAIED
159	01-Jun-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	10:50	12:00	01:10	LINE CLEAR AVAIED
160	01-Jun-24	HASSAN	110	LINE	VITTAL-PUTR_SLTUR	VITTAL_110	10:42	11:53	01:11	LINE CLEAR AVAIED
161	01-Jun-24	HASSAN	220	TRANSFORMER	HV1	HASSAN_220	11:37	12:25	00:48	LINE CLEAR AVAIED
162	01-Jun-24	HASSAN	220	LINE	MRSSHM-DVG-1	MRSMSG_220	02:27	02:47	00:20	TRIPPED ON FAULT
163	01-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMSG_220	21:25	21:54	00:29	TRIPPED ON FAULT
164	01-Jun-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	14:08	14:09	00:01	LINE CLEAR AVAIED
165	01-Jun-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	14:10	14:11	00:01	LINE CLEAR AVAIED
166	01-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	21:25	21:54	00:29	TRIPPED ON FAULT
167	01-Jun-24	MYSORE	66	LINE	BANNIMANTAPA -FTS 2	NO STATIONS EFFECTED	12:56	13:09	00:13	TRIPPED ON FAULT
168	01-Jun-24	MYSORE	66	LINE	BANNIMANTAPA -HOOTGALLY2	NO STATIONS EFFECTED	12:56	13:07	00:11	TRIPPED ON FAULT
169	01-Jun-24	MYSORE	66	LINE	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66 NIDSALE_66	18:40	18:52	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
170	01-Jun-24	MYSORE	66	LINE	BESAGARAHALLI-DUNDANAHALLI	DUNDANAHALLI_66 NIDSALE_66 BESAGARAHALLI_66	18:58	19:15	00:17	TRIPPED ON FAULT
171	01-Jun-24	MYSORE	66	LINE	CR NAGARA-GUNDLUPETE	TERAKANAMBI_66	17:41	17:48	00:07	TRIPPED ON FAULT
172	01-Jun-24	MYSORE	66	LINE	HOOTGALLY-BANNIKUPPE	GVGUDI_66	05:47	05:53	00:06	TRIPPED ON FAULT
173	01-Jun-24	MYSORE	66	LINE	HUNSUR-HOSURGATE	GVGUDI_66 BANNIKUPPE_66	23:54:00 (1/6/2024)			TRIPPED ON FAULT
174	01-Jun-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	22:40	22:55	00:15	TRIPPED ON FAULT
175	01-Jun-24	MYSORE	66	TRANSFORMER	HV1	KHONALAGERE_66	10:10	10:40	00:29	LINE CLEAR AVAILED
176	01-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
177	01-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
178	01-Jun-24	MYSORE	66	LINE	KADAKOLA-DEVNUR(N'GUD)	DEVNUR(N'GUD)_66 SUTTUR_66	18:08	18:11	00:03	TRIPPED ON FAULT
179	01-Jun-24	MYSORE	66	LINE	KHB-DMG HALLI	DMGHALLI_66	17:09	17:27	00:18	TRIPPED ON FAULT
180	01-Jun-24	MYSORE	66	LINE	KIRUGAVALU-MALIYUR	NO STATIONS EFFECTED	10:07	17:50	07:43	LINE CLEAR AVAILED
181	01-Jun-24	MYSORE	66	LINE	KIRUGAVALU-VADKEPURA	NO STATIONS EFFECTED	10:28	17:48	07:20	LINE CLEAR AVAILED
182	01-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
183	01-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
184	01-Jun-24	MYSORE	66	LINE	MUGUR-THAYUR	THAYUR_66 TNARSIPURA_66	17:57	18:02	00:05	TRIPPED ON FAULT
185	01-Jun-24	MYSORE	66	LINE	PANYADUNDI -KARYA	KARYA_66 HEMARGALA_66	21:30	21:40	00:10	TRIPPED ON FAULT
186	01-Jun-24	MYSORE	66	LINE	THANDYA-KADAKOLA	THANDYA_66	12:39	12:45	00:06	TRIPPED ON FAULT
187	01-Jun-24	MYSORE	66	LINE	THANDYA-KADAKOLA	THANDYA_66	13:40	13:44	00:04	TRIPPED ON FAULT
188	01-Jun-24	MYSORE	66	LINE	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 DKMAIDANA_66	02:52	03:00	00:08	TRIPPED ON FAULT
189	01-Jun-24	MYSORE	220	TRANSFORMER	HV1	K R PETE_220	14:52	15:35	00:43	LINE CLEAR AVAILED
190	01-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV-ANCHEPALYA-1	ANCHEPALYA 66KV	19:01	19:24	00:23	TRIPPED ON FAULT
191	01-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- HEBBUR	HEBBUR_66	19:01	19:41	00:40	TRIPPED ON FAULT
192	01-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	19:09	19:27	00:18	TRIPPED ON FAULT
193	01-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORATAGERE-1	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	20:00	20:27	00:27	TRIPPED ON FAULT
194	01-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	22:35	23:17	00:42	TRIPPED ON FAULT
195	01-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	22:57	23:17	00:20	TRIPPED ON FAULT
196	01-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-CHITRADURGA2	CHITRADURGA_220	22:57	23:19	00:22	TRIPPED ON FAULT
197	01-Jun-24	TUMKUR	66	LINE	CHITRADURGA 66KV-CHITRADURGA 3	CHITRADURGA_66	22:57	23:17	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
198	01-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	05:55	06:10	00:15	TRIPPED ON FAULT
199	01-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	18:55	19:30	00:35	TRIPPED ON FAULT
200	01-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-2	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	05:55	06:10	00:15	TRIPPED ON FAULT
201	01-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-2	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	18:55	19:30	00:35	TRIPPED ON FAULT
202	01-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK_66	THALLAK_66, RANGENAHALLI_66	08:05	18:10	10:05	LINE CLEAR AVAILED
203	01-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66, PDKOTE_66	08:05	18:10	10:05	LINE CLEAR AVAILED
204	01-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66, PDKOTE_66	21:01 (01.06.2024)	7:03 (02.06.2024)	10:02	TRIPPED ON FAULT
205	01-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	13:32	13:42	00:10	TRIPPED ON FAULT
206	01-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	14:59	15:11	00:12	TRIPPED ON FAULT
207	01-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	19:20	19:50	00:30	TRIPPED ON FAULT
208	01-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV- MEDIGESHI	MEDIGESHI_66	05:22	06:06	00:44	TRIPPED ON FAULT
209	01-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV- GOWRIBIDANUR220	MADHUGIRI_220	13:00	14:12	01:12	LINE CLEAR AVAILED
210	01-Jun-24	TUMKUR	66	TRANSFORMER	TR-1	HIRIYUR 220KV-	21:01	21:17	00:16	TRIPPED ON FAULT
211	01-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(LV SIDE)	MADHUGIRI_220	15:05	18:10	03:05	LINE CLEAR AVAILED
212	01-Jun-24	TUMKUR	110	LINE	NITTUR 220KV- KADABA	KADABA_110	23:54 (01.06.2024)	00:02 (02.06.2024)	00:08	TRIPPED ON FAULT
213	01-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	20:43 (01.06.2024)			TRIPPED ON FAULT
214	01-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI- 2	HAVERI_220	18:59 (01.06.2024)			TRIPPED ON FAULT
215	01-Jun-24	TUMKUR	220	LINE	MADHUGIRI 220KV- GOWRIBIDANUR220	MADHUGIRI_220	13:00	14:12	01:12	LINE CLEAR AVAILED
216	01-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(HV SIDE)	MADHUGIRI_220	15:05	18:10	03:05	LINE CLEAR AVAILED
217	01-Jun-24	TUMKUR	220	TRANSFORMER	TR-2 (HVSIDE)	DAVANGERE_SRS_220	19:01	19:15	00:14	TRIPPED ON FAULT
218	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	TOLAMATTI_110	09:07	20:06	10:59	LINE CLEAR AVAILED
219	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	YADWAD_110	08:47	08:50	00:03	MAIN SUPPLY FAILURE
220	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BAILHONGAL_110	09:55	19:50	09:55	LINE CLEAR AVAILED
221	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HEBBALLI_110	11:53	12:01	00:08	TRIPPED ON FAULT
222	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	21:19	21:29	00:10	LINE CLEAR AVAILED
223	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	LAXMESHWAR_110	18:50	19:28	00:38	TRIPPED ON FAULT
224	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	KANABARGI LAYOUT_110	09:17	14:41	05:24	LINE CLEAR AVAILED
225	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BAILHONGAL_110	09:55	19:50	09:55	LINE CLEAR AVAILED
226	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	BILAGI_110	09:18	20:04	10:46	LINE CLEAR AVAILED
227	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KAGAWAD_110	11:56	12:08	00:12	TRIPPED ON FAULT
228	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KANABARGI LAYOUT_110	09:17	14:40	05:23	LINE CLEAR AVAILED
229	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	12:57	12:59	00:02	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
230	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MAMADAPUR(B)_110	13:53	14:02	00:09	TRIPPED ON FAULT
231	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	LAXMESHWAR_110	19:03	22:51	03:48	TRIPPED ON FAULT
232	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	BILAGI_110	09:18	20:04	10:46	LINE CLEAR AVAILED
233	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	19:08	19:12	00:04	TRIPPED ON FAULT
234	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA)	UTTUR_110	08:35	08:51	00:16	TRIPPED ON FAULT
235	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	UTTUR_110	08:35	08:51	00:16	TRIPPED ON FAULT
236	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (10MVA)	TOLAMATTI_110	09:08	20:09	11:01	LINE CLEAR AVAILED
237	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	BILAGI_110	09:18	20:04	10:46	LINE CLEAR AVAILED
238	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	GOKOK_110	16:09	16:28	00:19	TRIPPED ON FAULT
239	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	BAILHONGAL_110	09:55	19:50	09:55	LINE CLEAR AVAILED
240	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	KANABARGI LAYOUT_110	09:40	14:51	05:11	LINE CLEAR AVAILED
241	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	KANABARGI LAYOUT_110	18:53	19:23	00:30	TRIPPED ON FAULT
242	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	BAILHONGAL_110	09:55	19:50	09:55	LINE CLEAR AVAILED
243	02-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4(20MVA)	KANABARGI LAYOUT_110	09:41	14:51	05:10	LINE CLEAR AVAILED
244	02-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	KARWAR_220	09:26	13:23	03:57	LINE CLEAR AVAILED
245	02-Jun-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	14:25	14:38	00:13	LINE CLEAR AVAILED
246	02-Jun-24	BAGALKOTE	110	LINE	ATHANI220-GHATANATTI	ATHANI_220	10:19	17:23	07:04	LINE CLEAR AVAILED
247	02-Jun-24	BAGALKOTE	110	LINE	ATHARGA-BAGEWADI	ATHARGA_110	22:48	23:02	00:14	TRIPPED ON FAULT
248	02-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
249	02-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- ANKALAGI(HUDLI)	BELGAUM_220	05:06	05:43	00:37	TRIPPED ON FAULT
250	02-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- KANABARGI LAYOUT	BELGAUM_220	09:51	14:06	04:15	LINE CLEAR AVAILED
251	02-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- NEHRU NAGRA	BELGAUM_220	09:41	14:35	04:54	LINE CLEAR AVAILED
252	02-Jun-24	BAGALKOTE	110	LINE	BIDNAL220-ANNIGERI	BIDNAL_220	18:07 (02.06.2024)			TRIPPED ON FAULT
253	02-Jun-24	BAGALKOTE	110	LINE	BILAGI-KATARKI (SHIRGUPPI)	BILAGI_110	09:18	20:04	10:46	LINE CLEAR AVAILED
254	02-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG1	CHIKKODI_220	10:33	13:05	02:32	LINE CLEAR AVAILED
255	02-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
256	02-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
257	02-Jun-24	BAGALKOTE	110	LINE	KANABARGI LAYOUT- BELGAUM220	KANABARGI LAYOUT_110	09:50	14:06	04:16	LINE CLEAR AVAILED
258	02-Jun-24	BAGALKOTE	110	LINE	KANABARGI LAYOUT- NEHRU NAGAR	KANABARGI LAYOUT_110	09:04	14:33	05:29	LINE CLEAR AVAILED
259	02-Jun-24	BAGALKOTE	110	LINE	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)			LINE CLEAR AVAILED
260	02-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
261	02-Jun-24	BAGALKOTE	110	LINE	MK HUBLI220-BAILHONGAL	MK HUBLI_220	10:03	15:17	05:14	LINE CLEAR AVAILED
262	02-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
263	02-Jun-24	BAGALKOTE	110	LINE	RAIBAG-CHIKKODI1	STATION NOT AFFECTED RAIBAG_110	10:33	13:04	02:31	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
264	02-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
265	02-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
266	02-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
267	02-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
268	02-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
269	02-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
270	02-Jun-24	BAGALKOTE	110	LINE	UTTUR-F1 JAMB CB	UTTUR_110	20:48	21:00	00:12	LINE CLEAR AVAILED
271	02-Jun-24	BAGALKOTE	110	LINE	UTTUR-M L PURA (RANNABELAGALI)	UTTUR_110	16:50	20:57	04:07	LINE CLEAR AVAILED
272	02-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- BILAGI	VAJRMATTI_220	09:22	19:59	10:37	LINE CLEAR AVAILED
273	02-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- KATARAKI	VAJRAMATTI_220	09:23	20:00	10:37	LINE CLEAR AVAILED
274	02-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
275	02-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR1	VAJRMATTI_220	04:25	04:36	00:11	LINE CLEAR AVAILED
276	02-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR2	VAJRMATTI_220	03:40	05:50	02:10	LINE CLEAR AVAILED
277	02-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KARWAR_220	09:31	13:23	03:52	LINE CLEAR AVAILED
278	02-Jun-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA1	AMBEWADI_220	12:14	13:27	01:13	TRIPPED ON FAULT
279	02-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	20:43 (02.06.2024)			LINE CLEAR AVAILED
280	02-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	19:00 (02.06.2024)			TRIPPED ON FAULT
281	02-Jun-24	BAGALKOTE	220	LINE	HUBLI- SIRSI1	HUBLI_220	13:39	14:50	01:11	LINE CLEAR AVAILED
282	02-Jun-24	BAGALKOTE	220	LINE	KARWAR-KADRA1	KARWAR_220	09:07	09:17	00:10	LINE CLEAR AVAILED
283	02-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
284	02-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
285	02-Jun-24	BAGALKOTE	220	LINE	SIRSI- HUBLI1	SIRSI_220	13:32	14:50	01:18	LINE CLEAR AVAILED
286	02-Jun-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY1	SIRSI_220	11:05	13:26	02:21	LINE CLEAR AVAILED
287	02-Jun-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHY2	SIRSI_220	11:04	13:26	02:22	LINE CLEAR AVAILED
288	02-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
289	02-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- KAVATAGI LIS	VAJRAMATTI_220	18:12	20:30	02:18	LINE CLEAR AVAILED
290	02-Jun-24	BANGALORE	66	LINE	220KV SHOBHA DREAMS 220 - SOMANAHALLI 220	SHOBHA DREAMS 220	17:50	18:33	00:43	TRIPPED ON FAULT
291	02-Jun-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE, WELCAST, ATTUR YELAHANKA	18:44	19:07	00:23	TRIPPED ON FAULT
292	02-Jun-24	BANGALORE	66	LINE	66KV ACCHALU - HONNIGANAHALLI	HONNIGANAHALLI, HALAGURU	00:50	00:55	00:05	TRIPPED ON FAULT
293	02-Jun-24	BANGALORE	66	LINE	66KV AREHALLI - BANASHANKARI	AREHALLI	23:10	23:15	00:05	LINE CLEAR AVAILED
294	02-Jun-24	BANGALORE	66	LINE	66KV AUDUGODI - JAKKASANDRA	JAKKASANDRA	15:53	15:56	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
295	02-Jun-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	13:10	13:16	00:06	LINE CLEAR AVAILED
296	02-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - SK STEEL	SK STEEL	20:26	20:42	00:16	TRIPPED ON FAULT
297	02-Jun-24	BANGALORE	66	LINE	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	00:10	23:59	23:49	TRIPPED ON FAULT
298	02-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL(EHT)	09:12	15:46	06:34	LINE CLEAR AVAILED
299	02-Jun-24	BANGALORE	66	LINE	66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	DIVYASHREE TECH PARK, KACHAMARANAHALLI, MINOR IRRIGATION, PRESTIGE LAKESIDE HABITAT	17:50	18:40	00:50	MAIN SUPPLY FAILURE
300	02-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	18:40	18:56	00:16	TRIPPED ON FAULT
301	02-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BHORUKA - GRAPHITE INDIA	NO STATION AFFECTED	12:57	13:06	00:09	LINE CLEAR AVAILED
302	02-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHIKETHAN	PRESTIGE SHANTHIKETHAN	12:54	13:05	00:11	LINE CLEAR AVAILED
303	02-Jun-24	BANGALORE	66	LINE	66KV HULLENAHALLI - KUDURU	HULLENAHALLI, KUDUR, SRIGIRIPURA	19:39	19:55	00:16	TRIPPED ON FAULT
304	02-Jun-24	BANGALORE	66	LINE	66KV ITI 220 - NGEF	NGEF	18:25	18:42	00:17	TRIPPED ON FAULT
305	02-Jun-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	10:35	11:20	00:45	TRIPPED ON FAULT
306	02-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACCHALU	ACCHALU, HONNIGANAHALLI, HALAGURU	22:34	22:50	00:16	TRIPPED ON FAULT
307	02-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	CHATRA, MARALAWADI, GODUR	06:35	06:48	00:13	TRIPPED ON FAULT
308	02-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	SHIVANAHALLI DAIRY, DODDALAHALLI	22:34	22:50	00:16	TRIPPED ON FAULT
309	02-Jun-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUDUGODI-2	NO STATION AFFECTED	18:21	20:22	02:01	TRIPPED ON FAULT
310	02-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA	19:28	23:59	04:31	TRIPPED ON FAULT
311	02-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	03:56	04:06	00:10	TRIPPED ON FAULT
312	02-Jun-24	BANGALORE	66	LINE	66KV MARALAVADI - GODUR	GODUR	05:20	05:25	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
313	02-Jun-24	BANGALORE	66	LINE	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	ELECTRONIC CITY PH2 SEC 2, TAT BP SOLAR, HUSKUR, BIOCON(EHT)	20:14	20:27	00:13	MAIN SUPPLY FAILURE
314	02-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	22:55	23:20	00:25	TRIPPED ON FAULT
315	02-Jun-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - GOKULA	GOKULA, MATHIKERE, RMV,BEL(EHT), HMT(EHT)	18:54	19:07	00:13	TRIPPED ON FAULT
316	02-Jun-24	BANGALORE	66	LINE	66KV SHOBHA DREAMS 220 - BRIGADE UTOPIA GIS	BRIGADE UTOPIA	17:50	18:33	00:43	MAIN SUPPLY FAILURE
317	02-Jun-24	BANGALORE	66	LINE	66KV SHOBHA DREAMS 220 - SORAHUNASE	SHOBHA DREAMS 66, SORAHUNASE	17:50	18:33	00:43	MAIN SUPPLY FAILURE
318	02-Jun-24	BANGALORE	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	21:25	21:45	00:20	TRIPPED ON FAULT
319	02-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA - BMRCL PEENYA EHT 66/33KV	BMRCL	18:55	19:00	00:05	TRIPPED ON FAULT
320	02-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BRINDAVAN HTLS	NANDINI LAYOUT, MAHALAKSHMI LAYOUT	18:46	19:21	00:35	TRIPPED ON FAULT
321	02-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	09:03	09:18	00:15	MAIN SUPPLY FAILURE
322	02-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	18:46	19:15	00:29	LINE CLEAR AVAILED
323	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	18:52	19:14	00:22	MAIN SUPPLY FAILURE
324	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR	PADMANABHANAGARA	14:00	14:18	00:18	TRIPPED ON FAULT
325	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	18:52	19:13	00:21	MAIN SUPPLY FAILURE
326	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	21:38	22:05	00:27	TRIPPED ON FAULT
327	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL(EHT)	18:51	19:05	00:14	TRIPPED ON FAULT
328	02-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	18:52	19:09	00:17	MAIN SUPPLY FAILURE
329	02-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	23:59	09:18	09:19	TRIPPED ON FAULT
330	02-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	09:18	10:18	01:00	LINE CLEAR AVAILED
331	02-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	22:43	23:59	01:16	TRIPPED ON FAULT
332	02-Jun-24	BANGALORE	66	LINE	66KV WELCAST - ABBIGERE	ABBIGERE	22:04	22:07	00:03	LINE CLEAR AVAILED
333	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NAGANATHPURA 220	09:23	09:39	00:16	TRIPPED ON FAULT
334	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	03:11	03:20	00:09	TRIPPED ON FAULT
335	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	18:25	18:30	00:05	TRIPPED ON FAULT
336	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SM MANGALA	07:25	07:40	00:15	TRIPPED ON FAULT
337	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIJJAHALLI	08:35	08:55	00:20	LINE CLEAR AVAILED
338	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VR DODDI	23:59	00:05	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
339	02-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	10:47	11:20	00:33	LINE CLEAR AVAIED
340	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HAL 220	16:30	17:40	01:10	TRIPPED ON FAULT
341	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOODY 220	12:53	13:09	00:16	LINE CLEAR AVAIED
342	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	03:30	03:36	00:06	TRIPPED ON FAULT
343	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	08:00	08:11	00:11	TRIPPED ON FAULT
344	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	08:35	08:40	00:05	TRIPPED ON FAULT
345	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	LAKSHMIPURA	18:30	18:45	00:15	LINE CLEAR AVAIED
346	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MUDIYANUR	13:25	13:45	00:20	LINE CLEAR AVAIED
347	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	LAKKUR	21:10	22:00	00:50	LINE CLEAR AVAIED
348	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DODDALAHALLI	11:00	11:17	00:17	TRIPPED ON FAULT
349	02-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DASHAVARA	10:00	10:06	00:06	TRIPPED ON FAULT
350	02-Jun-24	BANGALORE	66	TRANSFORMER	HV3	BANASAWADI	13:05	13:30	00:25	LINE CLEAR AVAIED
351	02-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KIADB DB PURA 220	10:22	12:20	01:58	LINE CLEAR AVAIED
352	02-Jun-24	BANGALORE	220	LINE	220KV HOODY 400 - SHOBHA DREAMS 220	SHOBHA DREAMS 220	17:50	19:46	01:56	TRIPPED ON FAULT
353	02-Jun-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	18:52	19:08	00:16	TRIPPED ON FAULT
354	02-Jun-24	BANGALORE	220	TRANSFORMER	HV2	BRINDAVANA 220	09:05	09:15	00:10	LINE CLEAR AVAIED
355	02-Jun-24	BANGALORE	220	TRANSFORMER	HV2	NAGANATHPURA 220	20:14	20:27	00:13	TRIPPED ON FAULT
356	02-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66	19:10	19:20	00:10	TRIPPED ON FAULT
357	02-Jun-24	GULBARGA	66	TRANSFORMER	HV3	HALUVAGALU_66	20:30	21:15	00:45	TRIPPED ON FAULT
358	02-Jun-24	GULBARGA	66	LINE	KUDALGI-BANAVEKAL	BANAVEKAL_66	20:35	21:45	01:10	TRIPPED ON FAULT
359	02-Jun-24	GULBARGA	66	LINE	KUDALGI-CHORNUR	CHORNUR_66	20:50	21:45	00:55	TRIPPED ON FAULT
360	02-Jun-24	GULBARGA	110	LINE	AFZALPUR-RENUKASUGUR	CHOWDAPUR_110,SAGNOOR_110	16:49	17:13	00:24	MAIN SUPPLY FAILURE
361	02-Jun-24	GULBARGA	110	LINE	CHOWDAPUR-RENUKASUGUR	CHOWDAPUR_110,SAGNOOR_110	15:58	16:32	00:34	MAIN SUPPLY FAILURE
362	02-Jun-24	GULBARGA	110	LINE	GANGAVATHI-MUNIRABAD1	VENKATGIRI_110	02:47	04:20	01:33	TRIPPED ON FAULT
363	02-Jun-24	GULBARGA	110	LINE	GANGAVATHI-VENKATGIRI	VENKATGIRI_110	02:47	04:20	01:33	MAIN SUPPLY FAILURE
364	02-Jun-24	GULBARGA	110	LINE	GANGAVATI-MUNIRABAD	VENKATAGIRI_110	02:47	04:20	01:33	TRIPPED ON FAULT
365	02-Jun-24	GULBARGA	110	TRANSFORMER	HV1	GUGAL_110	21:35	22:00	00:25	TRIPPED ON FAULT
366	02-Jun-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	22:22	22:28	00:06	TRIPPED ON FAULT
367	02-Jun-24	GULBARGA	110	TRANSFORMER	HV3	KURUGODU_110	01:55	02:45	00:50	TRIPPED ON FAULT
368	02-Jun-24	GULBARGA	110	TRANSFORMER	HV3	SOMASAMUDRA_110	00:49	01:00	00:11	TRIPPED ON FAULT
369	02-Jun-24	GULBARGA	110	TRANSFORMER	HV3	ALLIPUR_220	04:14	04:24	00:10	TRIPPED ON FAULT
370	02-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	23:15	23:30	00:15	TRIPPED ON FAULT
371	02-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	23:15	23:30	00:15	MAIN SUPPLY FAILURE
372	02-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	21:54	08:32	10:38HRS	LINE CLEAR AVAIED
373	02-Jun-24	GULBARGA	110	LINE	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	21:58	22:14	00:16	TRIPPED ON FAULT
374	02-Jun-24	GULBARGA	110	LINE	KARAJAGI-RENUKASUGUR	CHOWDAPUR_110,SAGNOOR_110	16:49	17:13	00:24	MAIN SUPPLY FAILURE
375	02-Jun-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR1	SINDHANOOR_110	20:22	20:29	00:07	TRIPPED ON FAULT
376	02-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-KONKAL	KONKAL_110	09:44	15:51	06:07	LINE CLEAR AVAIED
377	02-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	14:31	15:07	00:36	LINE CLEAR AVAIED
378	02-Jun-24	GULBARGA	110	LINE	SAGNOOR-CHOWDAPUR	CHOWDAPUR_110,SAGNOOR_110	15:58	16:32	00:34	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
379	02-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	23:59	00:00	00:01	LINE CLEAR AVAILED
380	02-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	SR NAGAR_110, KARATAGI_110	01:50	12:55	11:05	TRIPPED ON FAULT
381	02-Jun-24	GULBARGA	110	LINE	SIRGUPPA-DHADESUGUR	TEKKALKOTE_110, SIRIGERI CROSS_110	01:49	02:19	00:30	MAIN SUPPLY FAILURE
382	02-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	14:10	15:05	00:55	LINE CLEAR AVAILED
383	02-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	09:50	10:15	00:25	LINE CLEAR AVAILED
384	02-Jun-24	GULBARGA	220	LINE	HUMNABAD-HALBARGA	HALBARGA_220	08:45	08:58	00:13	TRIPPED ON FAULT
385	02-Jun-24	GULBARGA	220	LINE	HUMNABAD-HALBARGA	HALBARGA_220	08:45	08:58	00:13	TRIPPED ON FAULT
386	02-Jun-24	GULBARGA	220	TRANSFORMER	HV1,HV2	RAMASAMUDRA_220	14:31	15:06	00:35	LINE CLEAR AVAILED
387	02-Jun-24	GULBARGA	220	TRANSFORMER	HV2	ITTAGI_220	21:01	21:25	00:24	TRIPPED ON FAULT
388	02-Jun-24	GULBARGA	220	LINE	KUDALGI-ITTAGI2	ITTAGI_220	21:05	21:55	00:50	TRIPPED ON FAULT
389	02-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
390	02-Jun-24	GULBARGA	220	LINE	SHAHAPUR-RTPS1	RTPS_220	21:35	22:00	00:25	TRIPPED ON FAULT
391	02-Jun-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	12:15	12:25	00:10	LINE CLEAR AVAILED
392	02-Jun-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	14:05	14:10	00:05	LINE CLEAR AVAILED
393	02-Jun-24	HASSAN	66	TRANSFORMER	HV1	HNPUA_220	15:52	16:17	00:25	TRIPPED ON FAULT
394	02-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	17:55	18:15	00:20	TRIPPED ON FAULT
395	02-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPUA_66	08:05	17:16	09:11	LINE CLEAR AVAILED
396	02-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPUA_66	08:05	17:16	09:11	LINE CLEAR AVAILED
397	02-Jun-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	07:40	08:20	00:40	TRIPPED ON FAULT
398	02-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	19:57	20:02	00:05	TRIPPED ON FAULT
399	02-Jun-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	09:05	13:15	04:10	LINE CLEAR AVAILED
400	02-Jun-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	13:24	17:50	04:26	LINE CLEAR AVAILED
401	02-Jun-24	HASSAN	220	LINE	CRPATNA-HSN400	CRPATNA_220	09:15	12:30	03:15	LINE CLEAR AVAILED
402	2-Jun-24	MYSORE	66	LINE	220 NAGAMANGALA - BASARALU	BASARALU_66HAMPAPURA_66	18:56	19:07	00:11	TRIPPED ON FAULT
403	2-Jun-24	MYSORE	66	LINE	220 NAGAMANGALA -BG NAGARA	ADICHUNCHANAGIRI_66BGNA GARA_66VADERALLI_66KADABALLI_66	05:47	05:57	00:10	TRIPPED ON FAULT
404	2-Jun-24	MYSORE	66	LINE	220 NAGAMANGALA -KOPPA	NO STATIONS EFFECTED	18:56	19:08	00:12	TRIPPED ON FAULT
405	2-Jun-24	MYSORE	66	LINE	DOORA-HULLAHALLI	NO STATIONS EFFECTED	01:52	01:59	00:07	TRIPPED ON FAULT
406	2-Jun-24	MYSORE	66	LINE	DOORA-HULLAHALLI	NO STATIONS EFFECTED	03:05	06:17	03:12	TRIPPED ON FAULT
407	2-Jun-24	MYSORE	66	LINE	HOOTAGALLI-BANNIKUPPE	GVGUDI_66	05:47	05:53	00:06	TRIPPED ON FAULT
408	2-Jun-24	MYSORE	66	LINE	HUNSUR -HOSURGATE	BANNIKUPPE_66GVGUDI_66	02:50	02:57	00:07	TRIPPED ON FAULT
409	2-Jun-24	MYSORE	66	LINE	HUNSUR-HOSURGATE	GVGUDI_66 BANNIKUPPE_66	23:54:00 (1/6/2024)	0:02 (2/06/2024)	00:08	TRIPPED ON FAULT
410	2-Jun-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	00:50	00:53	00:03	LINE CLEAR AVAILED
411	2-Jun-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	22:34	22:51	00:17	LINE CLEAR AVAILED
412	2-Jun-24	MYSORE	66	TRANSFORMER	HV1	SINDHUVALI_66	10:00	10:30	00:30	LINE CLEAR AVAILED
413	2-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
414	2-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
415	2-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
416	2-Jun-24	MYSORE	66	LINE	KOTTANUR-HANNUR	NO STATIONS EFFECTED	21:30	21:40	00:10	TRIPPED ON FAULT
417	2-Jun-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINAMULSOGE	NO STATIONS EFFECTED	16:39 (2/06/2024)			LINE CLEAR AVAILED
418	2-Jun-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	11:25	15:25	04:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
419	2-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
420	2-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANUR 2	NO STATIONS EFFECTED	12:05	12:10	00:05	TRIPPED ON FAULT
421	2-Jun-24	MYSORE	66	LINE	SANTHEMARALLI-DR PETE	NO STATIONS EFFECTED	18:12	18:20	00:08	TRIPPED ON FAULT
422	2-Jun-24	MYSORE	66	LINE	SB HALLI-220 KR PETE 1	ADDIHALLI_66HARIYALDAMMA TEMPLE_66	19:00	19:09	00:09	TRIPPED ON FAULT
423	2-Jun-24	MYSORE	66	LINE	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	18:50	19:00	00:10	TRIPPED ON FAULT
424	2-Jun-24	MYSORE	66	LINE	VAJMANGALA -KADAKOLA 1	AYRALLI_66MARADIHUNDI_66	06:20	06:30	00:10	TRIPPED ON FAULT
425	02-Jun-24	TUMKUR	66	TRANSFORMER	100MVA TR-1(LV SIDE)	ANTHRASANAHALLI -220KV	01:45	02:47	01:02	LINE CLEAR AVAILED
426	02-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- HEBBUR	HEBBUR_66	07:50	09:12	01:22	LINE CLEAR AVAILED
427	02-Jun-24	TUMKUR	66	LINE	BRAHMASANDRA-ANKASANDRA	ANKASANDRA_66	00:30	00:50	00:20	TRIPPED ON FAULT
428	02-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	01:56	05:52	03:56	TRIPPED ON FAULT
429	02-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	13:08	13:17	00:09	TRIPPED ON FAULT
430	02-Jun-24	TUMKUR	66	LINE	GARAGA- PANCHANAHALLI_66	PANCHANAHALLI_66	23:45	00:00	00:15	TRIPPED ON FAULT
431	02-Jun-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66,POLYFIBER_66	12:36	12:46	00:10	TRIPPED ON FAULT
432	02-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK_66	THALLAK_66, RANGENAHALLI_66	23:05 (02.06.2024)	7:39 (03.06.2024)	08:34	TRIPPED ON FAULT
433	02-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	23:05 (02.06.2024)	7:39 (03.06.2024)	08:34	TRIPPED ON FAULT
434	02-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	23:05 (02.06.2024)	7:52 (03.06.2024)	08:37	TRIPPED ON FAULT
435	02-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	00:24	00:34	00:10	TRIPPED ON FAULT
436	02-Jun-24	TUMKUR	66	LINE	HOSADURGA_220KV-BAGUR_66KV	HOSADURGA_220KV	06:45	07:20	00:35	TRIPPED ON FAULT
437	02-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(LV SIDE)	ANTHRASANAHALLI -220KV	01:09	09:45	08:36	TRIPPED ON FAULT
438	02-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(LV SIDE)	ANTHRASANAHALLI -220KV	09:45	15:35	05:50	LINE CLEAR AVAILED
439	02-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	20:43 (01.06.2024)			TRIPPED ON FAULT
440	02-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI- 2	HAVERI_220	18:59 (01.06.2024)			TRIPPED ON FAULT
441	02-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2 KV	GUTTUR_400	22:54 (02.06.2024)			TRIPPED ON FAULT
442	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HEBBALLI_110	14:36	14:45	00:09	TRIPPED ON FAULT
443	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADAKALAT_110	11:28	11:40	00:12	TRIPPED ON FAULT
444	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	LAKSHMESHVAR_110	04:42	05:11	00:29	TRIPPED ON FAULT
445	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	MALAGHAN(B)_110	12:54	17:15	04:21	TRIPPED ON FAULT
446	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	MALAGHAN(B)_110	12:54	17:15	04:21	LINE CLEAR AVAILED
447	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA-2)	UAS DHARWAD_110	20:51	20:55	00:04	TRIPPED ON FAULT
448	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	AINAPUR_110	19:31	20:10	00:39	TRIPPED ON FAULT
449	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	12:18	15:43	03:25	LINE CLEAR AVAILED
450	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	KAGAWAD_110	12:10	12:25	00:15	TRIPPED ON FAULT
451	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	NAVALGUND_110	10:05	17:46	07:41	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
452	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MANTUR(G)_110	18:40	18:49	00:09	TRIPPED ON FAULT
453	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	05:27	05:30	00:03	TRIPPED ON FAULT
454	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	BIJAPUR CITY_110	10:42	10:43	00:01	TRIPPED ON FAULT
455	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	BAGALKOT_220	09:32	10:49	01:17	LINE CLEAR AVAILED
456	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,,HV2 (10MVA)	GULEDAGUDDA_110	15:52	16:29	00:37	LINE CLEAR AVAILED
457	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3 (20MVA)	BILAGI_110	03:31	03:36	00:05	TRIPPED ON FAULT
458	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3 (20MVA)	BILAGI_110	12:39	12:46	00:07	TRIPPED ON FAULT
459	03-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1 (20MVA)	GULEDAGUDDA_110	15:52	16:29	00:37	TRIPPED ON FAULT
460	03-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2	SHIGGOAN_220	11:30	14:15	02:45	LINE CLEAR AVAILED
461	03-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
462	03-Jun-24	BAGALKOTE	110	LINE	ANKALAGI-BELAGAVI (HUDLI)	ANKALAGI_110	08:35	09:36	01:01	LINE CLEAR AVAILED
463	03-Jun-24	BAGALKOTE	110	LINE	ANKALAGI-HIDAKAL (ISLAMPUR)	ANKALAGI_110	02:57	09:42	06:45	TRIPPED ON FAULT
464	03-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
465	03-Jun-24	BAGALKOTE	110	LINE	BELLATTI-ENERCON2	BELLATTI_110	18:56	21:44	02:48	TRIPPED ON FAULT
466	03-Jun-24	BAGALKOTE	110	LINE	BIDNAL220- NAVALGUND	BIDNAL_220	11:07	17:14	06:07	LINE CLEAR AVAILED
467	03-Jun-24	BAGALKOTE	110	LINE	BIDNAL220-ANNIGERI	BIDNAL_220	18:07 (02.06.2024)	12:40 (03.06.2024)	18:33	TRIPPED ON FAULT
468	03-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
469	03-Jun-24	BAGALKOTE	110	LINE	GADAG220- LAXMESHWAR	GADAG_220	06:13	11:07	04:54	TRIPPED ON FAULT
470	03-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
471	03-Jun-24	BAGALKOTE	110	LINE	HUNAGUND-ILKAL2	HUNAGUND_110	20:08	20:23	00:15	TRIPPED ON FAULT
472	03-Jun-24	BAGALKOTE	110	LINE	KUDALASANGAM-HUNAGUND	KUDALASANGAM_110	20:08	20:28	00:20	LINE CLEAR AVAILED
473	03-Jun-24	BAGALKOTE	110	LINE	KULAGERICROSS- KONNUR	STATION NOT AFFECTED KULAGERI CROSS_110	8:06 (19.04.2024)	11:18 (03.06.2024)	1083:12:00	LINE CLEAR AVAILED
474	03-Jun-24	BAGALKOTE	110	LINE	KUMTA-SIRSI1	KUMTA_110	14:06	14:40	00:34	TRIPPED ON FAULT
475	03-Jun-24	BAGALKOTE	110	LINE	LAKSHMESHWAR-GADAG	LAKSHMESHWAR_110	06:16	11:11	04:55	TRIPPED ON FAULT
476	03-Jun-24	BAGALKOTE	110	LINE	LAKSHMESHWAR-SHIRHATTI	LAKSHMESHWAR_110	19:50	20:39	00:49	TRIPPED ON FAULT
477	03-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- TERDAL	MAHALINGAPUR_220	15:39	16:00	00:21	TRIPPED ON FAULT
478	03-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(B)-BABALKESHWAR	MAMADAPUR(B)_110	06:37	06:58	00:21	TRIPPED ON FAULT
479	03-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
480	03-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-HIREBAGEWADI	MK HUBLI_220	17:10	21:06	03:56	TRIPPED ON FAULT
481	03-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
482	03-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL220	NAVALGUND_110	11:04 (03.06.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
483	03-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
484	03-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
485	03-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	13:56	14:29	00:33	TRIPPED ON FAULT
486	03-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
487	03-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
488	03-Jun-24	BAGALKOTE	110	LINE	SUARNASOUDA-HIREBAGEWADI1	SUARNASOUDA_110	17:24	17:38	00:14	LINE CLEAR AVAILED
489	03-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
490	03-Jun-24	BAGALKOTE	110	LINE	TERDAL-ML PURA	TERDAL_110	22:24 (03.06.2024)			LINE CLEAR AVAILED
491	03-Jun-24	BAGALKOTE	110	LINE	TODALB-JAMKHANDI SUGARS	STATION NOT AFFECTED TODALBAGI_110	10:44	11:28	00:44	LINE CLEAR AVAILED
492	03-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
493	03-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
494	03-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	AMBEWADI_220	12:12	13:29	01:17	TRIPPED ON FAULT
495	03-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	SHIGGOAN_220	11:31	14:14	02:43	LINE CLEAR AVAILED
496	03-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	09:19	10:25	01:06	LINE CLEAR AVAILED
497	03-Jun-24	BAGALKOTE	220	LINE	DHONI- GADAG1	DHONI_400	17:10	20:31	03:21	TRIPPED ON FAULT
498	03-Jun-24	BAGALKOTE	220	TRANSFORMER	DHONI- LINGAPUR2(HALVARTHY1)	DHONI_400	03:21	16:23	13:02	TRIPPED ON FAULT
499	03-Jun-24	BAGALKOTE	220	LINE	GADAG- DHONI1	GADAG_220	17:07	20:27	03:20	TRIPPED ON FAULT
500	03-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	20:43 (02.06.2024)	13:27 (03.06.2024)	16:44	LINE CLEAR AVAILED
501	03-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	19:00 (02.06.2024)	16:09 (03.06.2024)	21:09	TRIPPED ON FAULT
502	03-Jun-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	12:13	17:10	04:57	TRIPPED ON FAULT
503	03-Jun-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	21:16 (03.06.2024)			TRIPPED ON FAULT
504	03-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
505	03-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
506	03-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
507	03-Jun-24	BANGALORE	66	LINE	66KV ABBIGERE - ATTURU - MANYATA DG-3	ABBIGERE	14:50	14:54	00:04	LINE CLEAR AVAILED
508	03-Jun-24	BANGALORE	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	RAGHUTTAHALL, BOMMEPALI, YENNIGADALE	16:18	17:03	00:45	TRIPPED ON FAULT
509	03-Jun-24	BANGALORE	66	LINE	66KV D CROSS - DODDABELAVANGALA - THONDEBHAVI - ALIPURA	ALIPURA, THONDEBHAVI	19:52	20:38	00:46	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
510	03-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	THYAMAGONDLU	11:12	11:31	00:19	TRIPPED ON FAULT
511	03-Jun-24	BANGALORE	66	LINE	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	00:10	12:15	12:05	TRIPPED ON FAULT
512	03-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWILL	08:56	09:06	00:10	LINE CLEAR AVAILED
513	03-Jun-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	20:36	22:45	02:09	TRIPPED ON FAULT
514	03-Jun-24	BANGALORE	66	LINE	66KV GOKULA - MATHIKERE	MATHIKERE	20:36	20:45	00:09	TRIPPED ON FAULT
515	03-Jun-24	BANGALORE	66	LINE	66KV GOKULA - RMV	RMV, IISc(EHT)	22:19	22:24	00:05	LINE CLEAR AVAILED
516	03-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - RAMAPURA	HOSUR RAMAPURA	19:15	19:30	00:15	TRIPPED ON FAULT
517	03-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - IISC	IISc	22:04	22:06	00:02	LINE CLEAR AVAILED
518	03-Jun-24	BANGALORE	66	LINE	66KV JADIGENAHALLI - HOSKOTE	NO STATION AFFECTED	10:25	13:25	03:00	TRIPPED ON FAULT
519	03-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI	19:16	20:46	01:30	TRIPPED ON FAULT
520	03-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA	TAMAKA	23:52	23:59	00:07	TRIPPED ON FAULT
521	03-Jun-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	AUSTIN TOWN	15:14	15:17	00:03	LINE CLEAR AVAILED
522	03-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	10:25	10:36	00:11	TRIPPED ON FAULT
523	03-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - PATHPALYA - GULUR	GULUR, PATHPALYA, THIMAMPALLI	08:12	08:23	00:11	TRIPPED ON FAULT
524	03-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASALU	08:22	08:42	00:20	TRIPPED ON FAULT
525	03-Jun-24	BANGALORE	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENNIGADALE	16:18	17:03	00:45	TRIPPED ON FAULT
526	03-Jun-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - GOKULA	GOKULA, MATHIKERE, RMV, HMT(EHT), BEL(EHT)	16:48	16:53	00:05	TRIPPED ON FAULT
527	03-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	06:05	06:12	00:07	LINE CLEAR AVAILED
528	03-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	06:12	06:16	00:04	LINE CLEAR AVAILED
529	03-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - WELCAST DG-3	WELCAST	18:01	18:03	00:02	LINE CLEAR AVAILED
530	03-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	15:15	15:20	00:05	LINE CLEAR AVAILED
531	03-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL	10:48	11:01	00:13	LINE CLEAR AVAILED
532	03-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL	15:08	15:14	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
533	03-Jun-24	BANGALORE	66	LINE	66KV SUGUTUR - KC VALLEY	NO STATION AFFECTED	05:00	23:59	18:59	TRIPPED ON FAULT
534	03-Jun-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	11:14	11:33	00:19	TRIPPED ON FAULT
535	03-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	23:59	07:33	07:34	TRIPPED ON FAULT
536	03-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	07:33	08:08	00:35	LINE CLEAR AVAIED
537	03-Jun-24	BANGALORE	66	LINE	66KV WELCAST - ABBIGERE	ABBIGERE	16:54	16:58	00:04	LINE CLEAR AVAIED
538	03-Jun-24	BANGALORE	66	LINE	66KV WELCAST - ABBIGERE	WELCAST	14:38	14:45	00:07	LINE CLEAR AVAIED
539	03-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA	06:20	06:21	00:01	LINE CLEAR AVAIED
540	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ATTUR YELAHANKA	00:02	01:04	01:02	TRIPPED ON FAULT
541	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	15:30	17:19	01:49	TRIPPED ON FAULT
542	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	12:52	12:58	00:06	LINE CLEAR AVAIED
543	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	13:25	13:30	00:05	LINE CLEAR AVAIED
544	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	08:50	09:10	00:20	TRIPPED ON FAULT
545	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	13:50	13:55	00:05	LINE CLEAR AVAIED
546	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIJJAHALLI	12:30	13:10	00:40	LINE CLEAR AVAIED
547	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	17:23	17:33	00:10	TRIPPED ON FAULT
548	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	19:15	19:19	00:04	TRIPPED ON FAULT
549	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MARALAWADI	03:45	04:36	00:51	TRIPPED ON FAULT
550	03-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KUDUR	12:07	12:15	00:08	TRIPPED ON FAULT
551	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	12:52	12:58	00:06	LINE CLEAR AVAIED
552	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	13:25	13:30	00:05	LINE CLEAR AVAIED
553	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	03:19	03:29	00:10	TRIPPED ON FAULT
554	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	Y HUNSENAHALLI	18:15	18:25	00:10	LINE CLEAR AVAIED
555	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	THIMAMPALLI	17:23	17:25	00:02	LINE CLEAR AVAIED
556	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	13:45	13:50	00:05	LINE CLEAR AVAIED
557	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	LAKKUR	15:05	18:10	03:05	LINE CLEAR AVAIED
558	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANAKAPURA 66	11:13	11:26	00:13	TRIPPED ON FAULT
559	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KEMPANAHALLI	12:05	12:07	00:02	LINE CLEAR AVAIED
560	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	16:06	16:23	00:17	TRIPPED ON FAULT
561	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	13:39	14:00	00:21	LINE CLEAR AVAIED
562	03-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	06:07	06:14	00:07	LINE CLEAR AVAIED
563	03-Jun-24	GULBARGA	66	LINE	BENNEHALLI-ITTAGI	BENNEHALLI_66, KOTTUR_66	03:20	04:10	00:50	TRIPPED ON FAULT
564	03-Jun-24	GULBARGA	110	LINE	ALIPUR-PDHALLI	PDHALLI_110	06:35	06:57	00:22	MAIN SUPPLY FAILURE
565	03-Jun-24	GULBARGA	110	LINE	ALLIPUR-NORTH	NORTH_110	06:35	06:54	00:19	TRIPPED ON FAULT
566	03-Jun-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	22:22	22:28	00:06	TRIPPED ON FAULT
567	03-Jun-24	GULBARGA	110	TRANSFORMER	HV1	MANVI_110	22:52	22:58	00:06	TRIPPED ON FAULT
568	03-Jun-24	GULBARGA	110	LINE	JAWALGERA-VALABALLARI	JAWALGERA_110	03:10	03:20	00:10	TRIPPED ON FAULT
569	03-Jun-24	GULBARGA	110	LINE	LINGASUGUR-KAREPOWER	LINGASUGUR_220	01:05	01:10	00:05	TRIPPED ON FAULT
570	03-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	23:13	23:20	00:07	TRIPPED ON FAULT
571	03-Jun-24	GULBARGA	110	LINE	SANTHPUR-HALBARGA	SANTHPUR_110	13:40	13:47	00:07	TRIPPED ON FAULT
572	03-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	23:59	00:00	00:01	LINE CLEAR AVAIED
573	03-Jun-24	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DADESUGUR_110	04:30	04:40	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
574	03-Jun-24	GULBARGA	110	LINE	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110	04:20	04:30	00:10	TRIPPED ON FAULT
575	03-Jun-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	01:05	01:15	00:10	TRIPPED ON FAULT
576	03-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	02:10	02:20	00:10	TRIPPED ON FAULT
577	03-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	03:10	03:20	00:10	TRIPPED ON FAULT
578	03-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRUGUPPA	DHADESUGUR_110, TEKKALKOTE_110, SIRIGERICROSS_110	01:09	01:23	00:14	MAIN SUPPLY FAILURE
579	03-Jun-24	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	16:15	17:27	01:12	LINE CLEAR AVAILED
580	03-Jun-24	GULBARGA	220	LINE	KAPNOOR-FEROZABAD	KAPNOOR_220	03:52	09:02	05:10	TRIPPED ON FAULT
581	03-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
582	03-Jun-24	GULBARGA	220	LINE	SEDAM-HUMNABAD1	HUMNABAD_220	03:40	06:35	02:55	TRIPPED ON FAULT
583	03-Jun-24	HASSAN	66	LINE	CRPATNA-HNPURA	CRPATNA_220	10:00	16:14	06:14	LINE CLEAR AVAILED
584	03-Jun-24	HASSAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	10:00	13:35	03:35	MAIN SUPPLY FAILURE
585	03-Jun-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	10:00	16:29	06:29	MAIN SUPPLY FAILURE
586	03-Jun-24	HASSAN	66	LINE	HNPR2-SINGAPURA	HNPURA_220	10:01	17:38	07:37	LINE CLEAR AVAILED
587	03-Jun-24	HASSAN	66	TRANSFORMER	HV1	HANUBAL_66	10:41	11:10	00:29	LINE CLEAR AVAILED
588	03-Jun-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	10:00	16:29	06:29	MAIN SUPPLY FAILURE
589	03-Jun-24	HASSAN	66	TRANSFORMER	HV1	HNPURA_220	17:15	17:35	00:20	TRIPPED ON FAULT
590	03-Jun-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	18:32	18:47	00:15	TRIPPED ON FAULT
591	03-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESH PURA_66	8:00(3.05.2024)			LINE CLEAR AVAILED
592	03-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESH PURA_66	08:00	18:29	10:29	LINE CLEAR AVAILED
593	03-Jun-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	16:25	19:55	03:30	MAIN SUPPLY FAILURE
594	03-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	01:12	01:16	00:04	TRIPPED ON FAULT
595	03-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	02:17	02:20	00:03	TRIPPED ON FAULT
596	03-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	15:00(3.06.2024)			TRIPPED ON FAULT
597	03-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	10:34	13:41	03:07	LINE CLEAR AVAILED
598	03-Jun-24	HASSAN	110	TRANSFORMER	HV1	TOGARSI_110	15:15	15:20	00:05	TRIPPED ON FAULT
599	03-Jun-24	HASSAN	110	TRANSFORMER	HV1	TOGARSI_110	15:40	15:45	00:05	TRIPPED ON FAULT
600	03-Jun-24	HASSAN	110	TRANSFORMER	HV5	BAIKAMPADI_110	10:13	13:07	02:54	LINE CLEAR AVAILED
601	03-Jun-24	HASSAN	110	LINE	KADUR-AJAMPURA	KADUR_220	10:34	11:06	00:32	LINE CLEAR AVAILED
602	03-Jun-24	HASSAN	110	LINE	KADUR-NAGENAHALLI	KADUR_220	17:39	18:39	01:00	TRIPPED ON FAULT
603	03-Jun-24	HASSAN	110	LINE	KARAYA-PUTTUR	KARAYA_110	15:57	16:53	00:56	MAIN SUPPLY FAILURE
604	03-Jun-24	HASSAN	110	LINE	KAVOOR-BAIKAMPADI	KAVOOR_220	16:24	19:55	03:31	TRIPPED ON FAULT
605	03-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	15:00(3.06.2024)			TRIPPED ON FAULT
606	03-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	10:34	13:41	03:07	LINE CLEAR AVAILED
607	03-Jun-24	HASSAN	110	LINE	PUTTUR-MADAVU	PUTTUR_220	15:45	16:52	01:07	TRIPPED ON FAULT
608	03-Jun-24	HASSAN	110	LINE	PUTTUR-PUTUR 1	PUTTUR_220	15:57	16:53	00:56	TRIPPED ON FAULT
609	03-Jun-24	HASSAN	220	LINE	KAVOOR-KEMR1	KAVOOR_220	10:04	15:56	05:52	LINE CLEAR AVAILED
610	03-Jun-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	15:00(3.06.2024)			TRIPPED ON FAULT
611	03-Jun-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	10:00	15:00	05:00	LINE CLEAR AVAILED
612	03-Jun-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	15:28	15:49	00:21	TRIPPED ON FAULT
613	03-Jun-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	15:28	15:52	00:24	TRIPPED ON FAULT
614	03-Jun-24	HASSAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	11:24	14:24	03:00	LINE CLEAR AVAILED
615	03-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	14:38	17:35	02:57	TRIPPED ON FAULT
616	03-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	10:04	15:56	05:52	LINE CLEAR AVAILED
617	03-Jun-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	14:59 (3.06.2024)			TRIPPED ON FAULT
618	03-Jun-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA3	gen_sharavathy	14:38	17:37	02:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
619	03-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	15:28	15:49	00:21	TRIPPED ON FAULT
620	03-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR2	gen_varahi	15:28	15:52	00:24	TRIPPED ON FAULT
621	3-Jun-24	MYSORE	66	LINE	CRNAGAR-KOLLEGALA 1	MUGUR_66 JANNUR_66 THAYUR_66 TNARSIPURA_66	11:11	11:17	00:05	TRIPPED ON FAULT
622	3-Jun-24	MYSORE	66	LINE	DODDINDUVADI-KOTHANURU 1	NO STATIONS EFFECTED	06:35	06:45	00:10	TRIPPED ON FAULT
623	3-Jun-24	MYSORE	66	TRANSFORMER	HV1	DODDARAYAPET_66	15:28	15:34	00:06	TRIPPED ON FAULT
624	3-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	12:54	13:24	00:30	LINE CLEAR AVAILED
625	3-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
626	3-Jun-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	05:12	05:51	00:38	TRIPPED ON FAULT
627	3-Jun-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	12:25	12:51	00:26	LINE CLEAR AVAILED
628	3-Jun-24	MYSORE	66	TRANSFORMER	HV2	SUTTUR_66	11:35	12:45	01:09	LINE CLEAR AVAILED
629	3-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
630	3-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
631	3-Jun-24	MYSORE	66	LINE	KUSHALNAGARA -MYSORE 1	MIRLE_66	08:17	08:29	00:12	TRIPPED ON FAULT
632	3-Jun-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINAMULSOGE	NO STATIONS EFFECTED	16:39 (2/06/2024)			LINE CLEAR AVAILED
633	3-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
634	3-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66 YELANDUR_66	23:42	23:47	00:05	TRIPPED ON FAULT
635	3-Jun-24	MYSORE	66	LINE	MADIKERI-KUSHLANAGARA	NO STATIONS EFFECTED	10:04	17:37	07:33	LINE CLEAR AVAILED
636	3-Jun-24	MYSORE	66	LINE	MADIKERI-SUNTHIKOPA	SUNTIKOPPA_66	10:02	17:36	07:34	LINE CLEAR AVAILED
637	3-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-KESALGERE	NO STATIONS EFFECTED	18:48	19:00	00:12	TRIPPED ON FAULT
638	3-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:33	12:38	00:05	TRIPPED ON FAULT
639	3-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	12:38	16:06	03:28	TRIPPED ON FAULT
640	3-Jun-24	MYSORE	66	LINE	SFCSIVA-PGL	NO STATIONS EFFECTED	11:15	11:42	00:27	LINE CLEAR AVAILED
641	3-Jun-24	MYSORE	66	LINE	SFCSIVA-PPCL	NO STATIONS EFFECTED	11:15	11:42	00:26	LINE CLEAR AVAILED
642	3-Jun-24	MYSORE	66	LINE	THAYUR-TNARSIPURA	TNARSIPURA_66	16:32	16:39	00:07	TRIPPED ON FAULT
643	03-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	21:38	21:50	00:12	TRIPPED ON FAULT
644	03-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	23:33	23:53	00:20	TRIPPED ON FAULT
645	03-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	07:45	08:18	00:33	LINE CLEAR AVAILED
646	03-Jun-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KERECHILCHI_66	16:32	16:42	00:10	TRIPPED ON FAULT
647	03-Jun-24	TUMKUR	66	LINE	GARAGA- PANCHANAHALLI_66	PANCHANAHALLI_66	23:59	00:50	00:50	TRIPPED ON FAULT
648	03-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	11:10	14:55	03:45	LINE CLEAR AVAILED
649	03-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66,DEVARABELKERE_66	22:31	22:41	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
650	03-Jun-24	TUMKUR	66	LINE	MADANAYAKANAHALLI-TURUVANUR	TURUVANUR_66,JAGALUR_66, BIDARKERE_66	00:56	01:09	00:13	TRIPPED ON FAULT
651	03-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV- PULLAMAGATTA	PULLAMGATTA_66	05:36	05:46	00:10	TRIPPED ON FAULT
652	03-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV- PULLAMAGATTA	PULLAMGATTA_66	17:02	17:08	00:06	TRIPPED ON FAULT
653	03-Jun-24	TUMKUR	66	LINE	RAMAGIRI-BAGUR LINE	RAMAGIRI_66, CHIKJAJUR_66,SASALUHALLA_66	05:30	05:50	00:20	TRIPPED ON FAULT
654	03-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- DAVANAGERE 2	DAVANGERE_SRS_220	15:21	17:37	02:16	LINE CLEAR AVAILED
655	03-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 1	HAVERI_220	20:43 (01.06.2024)	16:03 (03.06.2024)	1DAY,19HR,20MINTS.	TRIPPED ON FAULT
656	03-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI- 2	HAVERI_220	18:59 (01.06.2024)	13:27 (03.06.2024)	1DAY,18HR,28MINTS	TRIPPED ON FAULT
657	03-Jun-24	TUMKUR	220	LINE	KB CROSS 220KV- SHIMOGA1	KBCROSS_220	10:41	14:24	03:43	LINE CLEAR AVAILED
658	03-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2KV	GUTUR_400	22:54 (02.06.2024)			TRIPPED ON FAULT
659	03-Jun-24	TUMKUR	400	LINE	JAGALUR 400KV- BPS2(BALLARI400KV)	JAGALUR 400KV	14:40	15:39	00:59	LINE CLEAR AVAILED
660	04-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADAKLAT_110	11:06	11:34	00:28	LINE CLEAR AVAILED
661	04-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	LAKSHMESHWAR_110	09:23	09:55	00:32	TRIPPED ON FAULT
662	04-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	UAS DHARWAD_110	10:30	10:34	00:04	TRIPPED ON FAULT
663	04-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KHADAKALAT_110	11:05	11:35	00:30	LINE CLEAR AVAILED
664	04-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	SULTANPUR_110	11:05	11:25	00:20	LINE CLEAR AVAILED
665	04-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
666	04-Jun-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-1 (104)	AHERI_220	11:45	11:55	00:10	TRIPPED ON FAULT
667	04-Jun-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	15:21	21:20	05:59	TRIPPED ON FAULT
668	04-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
669	04-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- DODDANNAVAR	CHIKKODI_220	17:10	18:10	01:00	TRIPPED ON FAULT
670	04-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)	8:00 (04.06.2024)	12:06	TRIPPED ON FAULT
671	04-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
672	04-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
673	04-Jun-24	BAGALKOTE	110	LINE	KUDACHI220- KUDACHI(AINAPUR)	KUDACHI_220	14:37	16:05	01:28	TRIPPED ON FAULT
674	04-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
675	04-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
676	04-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- NAGNUR	MUGALKHOD_220	19:24	19:37	00:13	TRIPPED ON FAULT
677	04-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL220	NAVALGUND_110	11:04 (03.06.2024)	7:09 (04.06.2024)	20:05:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
678	04-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
679	04-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
680	04-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
681	04-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-MMCL	SOUDATTI_220	09:45	09:55	00:10	LINE CLEAR AVAILED
682	04-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
683	04-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
684	04-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
685	04-Jun-24	BAGALKOTE	110	LINE	TERDAL-ML PURA	TERDAL_110	22:24 (03.06.2024)	8:01 (04.06.2024)	9:37:00	LINE CLEAR AVAILED
686	04-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
687	04-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
688	04-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	11:16	12:26		TRIPPED ON FAULT
689	04-Jun-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	21:16 (03.06.2024)	15:03 (04.06.2024)	17:47	TRIPPED ON FAULT
690	04-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
691	04-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
692	04-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
693	04-Jun-24	BANGALORE	66	LINE	66KV AVANI - KC VALLEY	KC VALLEY PUMP HOUSE	04:53	05:07	00:14	TRIPPED ON FAULT
694	04-Jun-24	BANGALORE	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	18:00	18:05	00:05	LINE CLEAR AVAILED
695	04-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - MATHIKERE	MATHIKERE	06:26	06:31	00:05	LINE CLEAR AVAILED
696	04-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - RMV	RMV, IISc(EHT)	00:30	00:35	00:05	LINE CLEAR AVAILED
697	04-Jun-24	BANGALORE	66	LINE	66KV ITI 220 - POTTERY ROAD MUSS	POTTERY ROAD	05:54	06:32	00:38	TRIPPED ON FAULT
698	04-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	10:20	10:30	00:10	TRIPPED ON FAULT
699	04-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA	TAMAKA	23:59	00:08	00:09	TRIPPED ON FAULT
700	04-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR INDA REA	06:20	06:50	00:30	MAIN SUPPLY FAILURE
701	04-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	NO STATION AFFECTED	06:20	11:40	05:20	TRIPPED ON FAULT
702	04-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	06:20	06:48	00:28	MAIN SUPPLY FAILURE
703	04-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - IISC	IISc	06:05	06:08	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
704	04-Jun-24	BANGALORE	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENNIGADALE	22:33	22:55	00:22	TRIPPED ON FAULT
705	04-Jun-24	BANGALORE	66	LINE	66KV SOMENAHALLI - NALLIMARADANAHALLI	NALLIMARADANAHALLI	11:45	11:50	00:05	LINE CLEAR AVAILED
706	04-Jun-24	BANGALORE	66	LINE	66KV SOMENAHALLI - PERESANDRA	PERESANDRA	17:05	17:10	00:05	LINE CLEAR AVAILED
707	04-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	11:24	11:37	00:13	LINE CLEAR AVAILED
708	04-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	13:47	13:51	00:04	LINE CLEAR AVAILED
709	04-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - AVANI	MULBAGAL, KC VALLEY, SOLAR(EHT)	04:53	05:09	00:16	TRIPPED ON FAULT
710	04-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIAL BEGUR 220	15:45	15:50	00:05	MAIN SUPPLY FAILURE
711	04-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHINTAMANI 66	21:09	21:22	00:13	TRIPPED ON FAULT
712	04-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	23:40	23:50	00:10	TRIPPED ON FAULT
713	04-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	14:15	14:21	00:06	TRIPPED ON FAULT
714	04-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	08:56	08:59	00:03	TRIPPED ON FAULT
715	04-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHINTAMANI 66	21:45	21:49	00:04	LINE CLEAR AVAILED
716	04-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NANGLI	11:20	11:40	00:20	LINE CLEAR AVAILED
717	04-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MALUR 220	06:20	06:46	00:26	TRIPPED ON FAULT
718	04-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66	18:55	19:00	00:05	TRIPPED ON FAULT
719	04-Jun-24	GULBARGA	66	LINE	TELAGI-YERAGUNTA	OBJ HALLI_110	14:40	14:45	00:05	TRIPPED ON FAULT
720	04-Jun-24	GULBARGA	110	LINE	ALAND-KADAGANCHI	ALAND_110, KADAGANCHI_110	18:11	18:34	00:23	TRIPPED ON FAULT
721	04-Jun-24	GULBARGA	110	LINE	ALAND-KADAGANCHI	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	19:49	20:10	00:21	TRIPPED ON FAULT
722	04-Jun-24	GULBARGA	110	LINE	ALLIPUR-MUNIRABAD	KIDB KUDTINI_110, KUDTINI_110, TORANGALU_110, KURGOD_110	05:45	06:09	00:24	TRIPPED ON FAULT
723	04-Jun-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	05:10	05:15	00:05	MAIN SUPPLY FAILURE
724	04-Jun-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	17:13	17:38	00:25	MAIN SUPPLY FAILURE
725	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	01:55	02:05	00:10	TRIPPED ON FAULT
726	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	02:18	02:28	00:10	TRIPPED ON FAULT
727	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	02:44	02:54	00:10	TRIPPED ON FAULT
728	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	03:55	04:20	00:25	TRIPPED ON FAULT
729	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	01:55	02:05	00:10	TRIPPED ON FAULT
730	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	02:18	02:28	00:10	TRIPPED ON FAULT
731	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	02:44	02:54	00:10	TRIPPED ON FAULT
732	04-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	HANAWAL_110	03:35	04:20	00:45	TRIPPED ON FAULT
733	04-Jun-24	GULBARGA	110	LINE	HUMNABAD-MANNEKHELLI	MANNEKHELLI_110	23:59	18:00	18:01	TRIPPED ON FAULT
734	04-Jun-24	GULBARGA	110	TRANSFORMER	HV2	GANGAVATHI_110	16:00	16:45	00:45	TRIPPED ON FAULT
735	04-Jun-24	GULBARGA	110	LINE	KURUGODU-ALIPUR	KURUGODU_110	04:45	06:15	01:30	MAIN SUPPLY FAILURE
736	04-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	23:59	19:30	19:31	LINE CLEAR AVAILED
737	04-Jun-24	GULBARGA	110	LINE	SINDHANUR-SR.NAGAR	KARATAGI_110	08:50	09:25	00:35	MAIN SUPPLY FAILURE
738	04-Jun-24	GULBARGA	110	LINE	SOMASAMUDRA-NORTH	NORTH_110	05:45	05:55	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
739	04-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
740	04-Jun-24	HASSAN	66	LINE	HIEMANGLUR	SALAGAME_66	11:44	12:05	00:21	LINE CLEAR AVAILED
741	04-Jun-24	HASSAN	66	TRANSFORMER	HV1	ALDUR_66	13:10	13:28	00:18	LINE CLEAR AVAILED
742	04-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPUA_66	8:00(3.06.2024)	16:58(4.06.2024)	32:58HRS	LINE CLEAR AVAILED
743	04-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPUA_66	08:19	16:59	08:40	LINE CLEAR AVAILED
744	04-Jun-24	HASSAN	66	LINE	UDURKOPPLU	SALAGAME_66	11:44	12:05	00:21	LINE CLEAR AVAILED
745	04-Jun-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	01:16	14:24	13:08	MAIN SUPPLY FAILURE
746	04-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	22:08	22:13	00:05	TRIPPED ON FAULT
747	04-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	15:00(3.06.2024)	13:25(4.06.2024)	22:25HRS	LINE CLEAR AVAILED
748	04-Jun-24	HASSAN	110	TRANSFORMER	HV2	GURUPURA_110	13:15	16:05	02:50	LINE CLEAR AVAILED
749	04-Jun-24	HASSAN	110	LINE	KAVOOR-BAIKAMPADI	KAVOOR_220	14:16	14:22	00:06	TRIPPED ON FAULT
750	04-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	15:00(3.06.2024)	13:25(4.06.2024)	22:25HRS	LINE CLEAR AVAILED
751	04-Jun-24	HASSAN	110	LINE	KEMAR-Manipal2	KEMAR_220	16:39	17:25	00:46	LINE CLEAR AVAILED
752	04-Jun-24	HASSAN	110	LINE	KEMAR-MOODABIDRE	KEMAR_220	12:00	12:07	00:07	TRIPPED ON FAULT
753	04-Jun-24	HASSAN	110	TRANSFORMER	LV2	SHIRALKOPPA_220	11:02	17:25	06:23	LINE CLEAR AVAILED
754	04-Jun-24	HASSAN	220	TRANSFORMER	HV2	SHIRALKOPPA_220	11:02	17:22	06:20	LINE CLEAR AVAILED
755	04-Jun-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	15:00(3.06.2024)	13:02 (4.062024)	22:02HRS	LINE CLEAR AVAILED
756	04-Jun-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	14:59 (3.06.2024)	13:02(4.06.2024)	22:01HRS	LINE CLEAR AVAILED
757	4-Jun-24	MYSORE	66	LINE	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	16:10	16:22	00:12	LINE CLEAR AVAILED
758	4-Jun-24	MYSORE	66	LINE	GUNDLUPETE-HANGLA	BHARGI_66 HANGLA_66	15:50	16:08	00:18	LINE CLEAR AVAILED
759	4-Jun-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	06:15	06:26	00:11	TRIPPED ON FAULT
760	4-Jun-24	MYSORE	66	LINE	HEBBANI-SHIMSHA	HADLI_66 KADKOTHANAHALLI_66 MALAVALLI_66	14:55	15:09	00:14	TRIPPED ON FAULT
761	4-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
762	4-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	11:17	11:29	00:11	LINE CLEAR AVAILED
763	4-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
764	4-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
765	4-Jun-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINAMULSOGE	NO STATIONS EFFECTED	16:39 (2/06/2024)	12:44 (03/06/2024)	20:05 HRs	LINE CLEAR AVAILED
766	4-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
767	4-Jun-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPETE	NO STATIONS EFFECTED	22:12	22:22	00:10	TRIPPED ON FAULT
768	4-Jun-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	14:56	14:58	00:02	TRIPPED ON FAULT
769	04-Jun-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	14:38	14:45	00:07	TRIPPED ON FAULT
770	04-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	15:17	17:12	01:55	LINE CLEAR AVAILED
771	04-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:23	17:15	01:52	TRIPPED ON FAULT
772	04-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:23	15:35	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
773	04-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-SIRA(RANGANATHAPURA)	SIRA_66	15:17	15:30	00:13	LINE CLEAR AVAILED
774	04-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	15:18	15:30	00:12	LINE CLEAR AVAILED
775	04-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	15:19	15:40	00:21	LINE CLEAR AVAILED
776	04-Jun-24	TUMKUR	66	LINE	J N KOTE_66-MALLAPPANAHALLI	AIMANGALA_66, MALLAPPANAHALLI_66	19:22	19:32	00:10	TRIPPED ON FAULT
777	04-Jun-24	TUMKUR	66	LINE	RAMAGIRI-BAGUR LINE	RAMAGIRI_66, CHIKJAJUR_66,SASALUHALLA_66	18:40	18:55	00:15	TRIPPED ON FAULT
778	04-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	SOKKE_66	05:45	06:00	00:15	TRIPPED ON FAULT
779	04-Jun-24	TUMKUR	66	LINE	THALLAK 220KV - BGKERE 1	BGKERE_66, HANGAL,NAGASAMUDRA, RAMPURA_66,	13:16	13:26	00:10	TRIPPED ON FAULT
780	04-Jun-24	TUMKUR	66	LINE	THALLAK 220KV - BGKERE 2	BGKERE_66, HANGAL,NAGASAMUDRA, RAMPURA_66,	13:16	13:28	00:12	TRIPPED ON FAULT
781	04-Jun-24	TUMKUR	220	TRANSFORMER	100MVA HIRIYUR TR-1&TR-3 (HV SIDE)	HIRIYUR_220KV	15:17	15:36	00:19	TRIPPED ON FAULT
782	04-Jun-24	TUMKUR	220	LINE	CHITRADURGA 220KV--THALLAK_220KV	CHITRADURGA 220KV	14:01	14:15	00:14	TRIPPED ON FAULT
783	04-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	11:15	12:36	01:21	TRIPPED ON FAULT
784	04-Jun-24	TUMKUR	220	LINE	HIRIYUR 220KV-THALLAK_220KV	HIRIYUR_220KV	14:01	14:15	00:14	TRIPPED ON FAULT
785	04-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2KV	GUTTUR_400	22:54 (02.06.2024)			TRIPPED ON FAULT
786	05-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	BYADAGI_110	15:20 (05.06.2024)			TRIPPED ON FAULT
787	05-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
788	05-Jun-24	BAGALKOTE	110	LINE	AHERI220- CHANDAKAVATE	AHERI_220	00:10	00:15	00:05	TRIPPED ON FAULT
789	05-Jun-24	BAGALKOTE	110	LINE	ATHANI220-HALYAL	ATHANI_220	10:36	17:07	06:31	LINE CLEAR AVAILED
790	05-Jun-24	BAGALKOTE	110	LINE	ATHANI220-KSSKN	ATHANI_220	13:20	13:40	00:20	TRIPPED ON FAULT
791	05-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
792	05-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- SADALAGA	CHIKKODI_220	21:29	22:03	00:34	TRIPPED ON FAULT
793	05-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
794	05-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KV/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
795	05-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA- NARENDRA2	GHATAPRABHA_220	20:32	22:42	02:10	TRIPPED ON FAULT
796	05-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
797	05-Jun-24	BAGALKOTE	110	LINE	INDI220- ZALKI1	INDI_220	15:20	15:55	00:35	TRIPPED ON FAULT
798	05-Jun-24	BAGALKOTE	110	LINE	INDI220- ZALKI2	INDI_220	15:20	15:55	00:35	TRIPPED ON FAULT
799	05-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
800	05-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
801	05-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
802	05-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220- BYADAGI	RANEBENNUR_220	19:20	19:23	00:03	LINE CLEAR AVAILED
803	05-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220- BYADAGI	RANEBENNUR_220	19:31	19:49	00:18	LINE CLEAR AVAILED
804	05-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
805	05-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
806	05-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
807	05-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
808	05-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
809	05-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
810	05-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
811	05-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	SIRSI_220	10:47	14:58	04:11	LINE CLEAR AVAILED
812	05-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	12:02	14:24	02:22	LINE CLEAR AVAILED
813	05-Jun-24	BAGALKOTE	220	LINE	KARWAD- KADRA2	KARWAR_220	12:04	14:21	02:17	LINE CLEAR AVAILED
814	05-Jun-24	BAGALKOTE	220	LINE	KUDACHI- MAHALINGAPUR	KUDACHI_220	12:32	15:04	02:32	LINE CLEAR AVAILED
815	05-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
816	05-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
817	05-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
818	05-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENHALLI	HULLENHALLI, KUDUR, SRIGIRIPURA	05:43	05:53	00:10	TRIPPED ON FAULT
819	05-Jun-24	BANGALORE	66	LINE	66KV AVANI - KC VALLEY	KC VALLEY	17:10	17:25	00:15	TRIPPED ON FAULT
820	05-Jun-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURHALLI	08:16	08:22	00:06	LINE CLEAR AVAILED
821	05-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGNAHALLI	10:28	10:39	00:11	MAIN SUPPLY FAILURE
822	05-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGNAHALLI	18:12	18:20	00:08	LINE CLEAR AVAILED
823	05-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:28	10:39	00:11	MAIN SUPPLY FAILURE
824	05-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	18:12	18:19	00:07	LINE CLEAR AVAILED
825	05-Jun-24	BANGALORE	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	10:28	10:39	00:11	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
826	05-Jun-24	BANGALORE	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	18:12	18:22	00:10	LINE CLEAR AVAILED
827	05-Jun-24	BANGALORE	66	LINE	66KV DG3_ MANYATA 220 - SHOBHA CITY	SHOBHA CITY	19:08	19:33	00:25	TRIPPED ON FAULT
828	05-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	19:08	19:29	00:21	TRIPPED ON FAULT
829	05-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	19:54	20:13	00:19	TRIPPED ON FAULT
830	05-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	21:10	21:14	00:04	LINE CLEAR AVAILED
831	05-Jun-24	BANGALORE	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	20:53	20:56	00:03	LINE CLEAR AVAILED
832	05-Jun-24	BANGALORE	66	LINE	66KV KENGERI SATELLITE TOWN - SIR. M.V. LAYOUT	KENGERI SATELLITE TOWN	14:24	14:28	00:04	LINE CLEAR AVAILED
833	05-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALI 220 - SANJEEVANADODDI	RANGANADODDI, SANJEEVANADODDI	16:30	16:40	00:10	TRIPPED ON FAULT
834	05-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA - DRDO	DRDO, MALLASANDRA	19:28	19:36	00:08	LINE CLEAR AVAILED
835	05-Jun-24	BANGALORE	66	LINE	66KV KUDUMULAKUNTE - THERIYUR	THERIYUR, VENKATAPURA	20:05	20:35	00:30	TRIPPED ON FAULT
836	05-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, ADDAGAL, RAYALPADU	06:45	06:55	00:10	TRIPPED ON FAULT
837	05-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, ADDAGAL, RAYALPADU	17:10	17:20	00:10	TRIPPED ON FAULT
838	05-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, ADDAGAL, RAYALPADU	18:50	19:34	00:44	TRIPPED ON FAULT
839	05-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARANAHALLI	11:50	14:15	02:25	LINE CLEAR AVAILED
840	05-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	HANUMANTHANAGARA, YEDAMADU	10:50	11:06	00:16	LINE CLEAR AVAILED
841	05-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	10:48	11:00	00:12	TRIPPED ON FAULT
842	05-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	10:37	10:50	00:13	TRIPPED ON FAULT
843	05-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	10:59	12:39	01:40	LINE CLEAR AVAILED
844	05-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	10:37	10:55	00:18	TRIPPED ON FAULT
845	05-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKENAHALLI	03:49	04:40	00:51	TRIPPED ON FAULT
846	05-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	09:35	10:22	00:47	LINE CLEAR AVAILED
847	05-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	18:47	18:54	00:07	TRIPPED ON FAULT
848	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	K&C VALLEY	11:44	11:46	00:02	LINE CLEAR AVAILED
849	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHINTAMANI 66	11:25	11:42	00:17	LINE CLEAR AVAILED
850	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHINTAMANI 66	11:42	12:22	00:40	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
851	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHINTAMANI 66	16:47	16:56	00:09	LINE CLEAR AVAILED
852	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KIADB DB PURA 220	03:42	04:00	00:18	TRIPPED ON FAULT
853	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KIADB DB PURA 220	04:00	05:11	01:11	LINE CLEAR AVAILED
854	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TAMAKA	13:10	14:10	01:00	LINE CLEAR AVAILED
855	05-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHANDAPURA	16:16	16:20	00:04	LINE CLEAR AVAILED
856	05-Jun-24	BANGALORE	220	TRANSFORMER	HV1	CHINTAMANI 220	10:28	10:38	00:10	LINE CLEAR AVAILED
857	05-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66	14:35	14:40	00:05	TRIPPED ON FAULT
858	05-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR- JAWALGERA	ADAVIAMARESHWAR_110	16:35	18:20	01:45	LINE CLEAR AVAILED
859	05-Jun-24	GULBARGA	110	LINE	ALAND-KADAGANCHI	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	01:26	01:42	00:16	TRIPPED ON FAULT
860	05-Jun-24	GULBARGA	110	LINE	ALAND-KADAGANCHI	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	18:52	19:11	00:19	TRIPPED ON FAULT
861	05-Jun-24	GULBARGA	110	TRANSFORMER	HV1,HV2	VENKATAGIRI_110	11:40	13:45	02:05	LINE CLEAR AVAILED
862	05-Jun-24	GULBARGA	110	TRANSFORMER	HV2	VALKAMDINI_110	10:50	10:55	00:05	TRIPPED ON FAULT
863	05-Jun-24	GULBARGA	110	TRANSFORMER	HV2	VALKAMDINI_110	14:15	14:20	00:05	TRIPPED ON FAULT
864	05-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	22:07	22:25	00:18	TRIPPED ON FAULT
865	05-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	SONNATHI_110	03:20	03:30	00:10	TRIPPED ON FAULT
866	05-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-KONKAL	KONKAL_110	11:04	14:45	03:41	LINE CLEAR AVAILED
867	05-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	18:51	18:54	00:03	TRIPPED ON FAULT
868	05-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	11:02	14:55	03:53	LINE CLEAR AVAILED
869	05-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	KONKAL_110	10:23	10:47	00:24	LINE CLEAR AVAILED
870	05-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	11:00	14:55	03:55	LINE CLEAR AVAILED
871	05-Jun-24	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	04:49	04:59	00:10	TRIPPED ON FAULT
872	05-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	10:23	10:49	00:26	TRIPPED ON FAULT
873	05-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	23:12	23:18	00:06	TRIPPED ON FAULT
874	05-Jun-24	GULBARGA	110	LINE	VALKAMDINI-SINDHANOOR	VALKAMDINI_110	16:40	18:05	01:25	LINE CLEAR AVAILED
875	05-Jun-24	GULBARGA	220	TRANSFORMER	HV1 & HV2	LINGASUGUR_220	14:44	15:45	01:01	TRIPPED ON FAULT
876	05-Jun-24	GULBARGA	220	TRANSFORMER	HV1,HV2	RAMASAMUDRA_220	11:06	14:29	03:23	LINE CLEAR AVAILED
877	05-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
878	05-Jun-24	HASSAN	66	LINE	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	15:30	16:15	00:45	LINE CLEAR AVAILED
879	05-Jun-24	HASSAN	66	LINE	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	11:48	12:58	01:10	LINE CLEAR AVAILED
880	05-Jun-24	HASSAN	66	LINE	CRPATNA-HDAVAN	CRPATNA_220	18:27	20:27	02:00	TRIPPED ON FAULT
881	05-Jun-24	HASSAN	66	LINE	DUDDA-CKNDGL	DUDDA_66	11:45	12:55	01:10	LINE CLEAR AVAILED
882	05-Jun-24	HASSAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	18:25	19:10	00:45	MAIN SUPPLY FAILURE
883	05-Jun-24	HASSAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	20:40	20:55	00:15	MAIN SUPPLY FAILURE
884	05-Jun-24	HASSAN	66	LINE	HAGARE-HASSAN	HAGARE_66	10:45	11:00	00:15	MAIN SUPPLY FAILURE
885	05-Jun-24	HASSAN	66	LINE	HANUBAL-SAKLESPUR	HANUBAL_66	06:50	12:57	06:07	LINE CLEAR AVAILED
886	05-Jun-24	HASSAN	66	LINE	HASSN22-MALLALI	HASSAN_220	11:15	11:27	00:12	LINE CLEAR AVAILED
887	05-Jun-24	HASSAN	66	LINE	HNPR2-CRPTN	HNPUA_220	08:41	15:15	06:34	TRIPPED ON FAULT
888	05-Jun-24	HASSAN	66	TRANSFORMER	LV1	HASSAN_220	11:11	11:18	00:07	LINE CLEAR AVAILED
889	05-Jun-24	HASSAN	66	TRANSFORMER	LV1	HASSAN_220	18:16	18:22	00:06	LINE CLEAR AVAILED
890	05-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPUA_66	06:49	12:39	05:50	LINE CLEAR AVAILED
891	05-Jun-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	11:07	11:18	00:11	LINE CLEAR AVAILED
892	05-Jun-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	10:40	11:20	00:40	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
893	05-Jun-24	HASSAN	110	TRANSFORMER	HV2	KUNDAPURA_110	12:07	12:47	00:40	LINE CLEAR AVAILED
894	05-Jun-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	17:05	18:35	01:30	TRIPPED ON FAULT
895	05-Jun-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	12:16	12:36	00:20	LINE CLEAR AVAILED
896	05-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	10:59	11:03	00:04	LINE CLEAR AVAILED
897	05-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	05:02	15:09	10:07	LINE CLEAR AVAILED
898	05-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:59	14:23	03:24	LINE CLEAR AVAILED
899	05-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	10:59	14:23	03:24	LINE CLEAR AVAILED
900	05-Jun-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRRALKOPPA_220	15:52	16:51	00:59	TRIPPED ON FAULT
901	05-Jun-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	10:44	18:40	07:56	LINE CLEAR AVAILED
902	05-Jun-24	HASSAN	220	TRANSFORMER	HV1	HASSAN_220	11:11	11:12	00:01	LINE CLEAR AVAILED
903	05-Jun-24	HASSAN	220	TRANSFORMER	HV1	HASSAN_220	18:16	18:21	00:05	LINE CLEAR AVAILED
904	05-Jun-24	HASSAN	220	TRANSFORMER	HV1 CBreaker	HEGGUNJE_220	10:11	13:15	03:04	LINE CLEAR AVAILED
905	05-Jun-24	HASSAN	220	LINE	KAVOOR-KEMAR3	KAVOOR_220	19:07	19:14	00:07	TRIPPED ON FAULT
906	05-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	19:07	19:46	00:39	TRIPPED ON FAULT
907	05-Jun-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	09:12	14:15	05:03	LINE CLEAR AVAILED
908	05-Jun-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMG_220	10:44	18:40	07:56	LINE CLEAR AVAILED
909	05-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMG_220	11:23	14:48	03:25	LINE CLEAR AVAILED
910	05-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMG_220	03:38	04:11	00:33	TRIPPED ON FAULT
911	05-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	19:08	19:28	00:20	MAIN SUPPLY FAILURE
912	05-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	19:08	19:28	00:20	MAIN SUPPLY FAILURE
913	05-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	19:07	19:35	00:28	TRIPPED ON FAULT
914	05-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	19:07	19:34	00:27	TRIPPED ON FAULT
915	05-Jun-24	HASSAN	220	LINE	SHRAVTY-SHIMOGA3	gen_sharavathy	11:23	14:48	03:25	LINE CLEAR AVAILED
916	05-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR2	gen_varahi	09:12	14:15	05:03	LINE CLEAR AVAILED
917	05-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	03:38	04:11	00:33	TRIPPED ON FAULT
918	05-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	11:48	15:22	03:34	LINE CLEAR AVAILED
919	5-Jun-24	MYSORE	66	LINE	BEGUR 220-SINDHUVALIPURA	SINDHUVALI_66	13:35	16:54	03:19	LINE CLEAR AVAILED
920	5-Jun-24	MYSORE	66	LINE	G UKKADA-PANDAVAPURA	GARUDANAUKADDA_66	10:55	13:37	02:41	LINE CLEAR AVAILED
921	5-Jun-24	MYSORE	66	LINE	G UKKADA-TUBINAKERE	GARUDANAUKADDA_66	10:55	13:37	02:41	LINE CLEAR AVAILED
922	5-Jun-24	MYSORE	66	LINE	GAVADAGERE-KR NAGARA	KRNAGARA_66BILIKERE_66DM G_HALLI_66	12:33	12:55	00:22	TRIPPED ON FAULT
923	5-Jun-24	MYSORE	66	LINE	HONGANUR-YELANDUR	NO STATIONS EFFECTED	18:45	18:50	00:05	TRIPPED ON FAULT
924	5-Jun-24	MYSORE	66	TRANSFORMER	HV1	HDKOTE_66	10:10	16:30	06:20	LINE CLEAR AVAILED
925	5-Jun-24	MYSORE	66	TRANSFORMER	HV1	KADABALLI_66	14:56	16:15	01:18	LINE CLEAR AVAILED
926	5-Jun-24	MYSORE	66	TRANSFORMER	HV1	MYSORESOUTH_66	00:04	00:11	00:07	TRIPPED ON FAULT
927	5-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
928	5-Jun-24	MYSORE	66	TRANSFORMER	HV2	HDKOTE_66	10:11	16:33	06:21	LINE CLEAR AVAILED
929	5-Jun-24	MYSORE	66	TRANSFORMER	HV2	KADABALLI_66	16:15	16:50	00:35	LINE CLEAR AVAILED
930	5-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
931	5-Jun-24	MYSORE	66	LINE	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	10:22	17:47	07:25	LINE CLEAR AVAILED
932	5-Jun-24	MYSORE	66	LINE	JAIPURA-KADAKOLA	JAIPUR_66	10:40	17:52	07:12	LINE CLEAR AVAILED
933	5-Jun-24	MYSORE	66	LINE	KADABALLI-BG NAGARA	NO STATIONS EFFECTED	15:40	17:35	01:55	LINE CLEAR AVAILED
934	5-Jun-24	MYSORE	66	LINE	KADABALLI-HIRISAVE	NO STATIONS EFFECTED	14:00	15:30	01:30	LINE CLEAR AVAILED
935	5-Jun-24	MYSORE	66	LINE	KADAKOLA-SARGUR 2	NO STATIONS EFFECTED	11:24	13:13	01:49	LINE CLEAR AVAILED
936	5-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
937	5-Jun-24	MYSORE	66	LINE	KR NAGARA-KUSHALNAGARA	KRNAGARA_66BILIKERE_66DM G_HALLI_66	12:35	13:05	00:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
938	5-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
939	5-Jun-24	MYSORE	66	LINE	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	20:09	20:18	00:09	TRIPPED ON FAULT
940	05-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-ANCHEPALYA-2	ANCHEPALYA 66KV	05:43	05:53	00:10	TRIPPED ON FAULT
941	05-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	00:42	00:53	00:11	TRIPPED ON FAULT
942	05-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	16:41	17:28	00:47	TRIPPED ON FAULT
943	05-Jun-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	15:01	15:36	00:35	LINE CLEAR AVAILED
944	05-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	15:01	15:29	00:28	LINE CLEAR AVAILED
945	05-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:01	15:36	00:35	LINE CLEAR AVAILED
946	05-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:01	15:29	00:28	LINE CLEAR AVAILED
947	05-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:01	15:36	00:35	LINE CLEAR AVAILED
948	05-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:17	12:17	01:00	LINE CLEAR AVAILED
949	05-Jun-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	14:06	14:31	00:25	TRIPPED ON FAULT
950	05-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-2	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	12:58	13:48	00:50	LINE CLEAR AVAILED
951	05-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	09:06	09:45	00:39	LINE CLEAR AVAILED
952	05-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK_66	THALLAK_66, RANGENAHALLI_66	09:06	09:45	00:39	LINE CLEAR AVAILED
953	05-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	09:06	09:45	00:39	LINE CLEAR AVAILED
954	05-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	09:30	09:45	00:15	LINE CLEAR AVAILED
955	05-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PKOTE_66	11:06	19:03	07:57	LINE CLEAR AVAILED
956	05-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	14:02	15:56	01:54	TRIPPED ON FAULT
957	05-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	18:48	18:58	00:10	TRIPPED ON FAULT
958	05-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	14:02	15:01	00:59	TRIPPED ON FAULT
959	05-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	14:18	15:56	01:38	TRIPPED ON FAULT
960	05-Jun-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	14:02	15:01	00:59	TRIPPED ON FAULT
961	05-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV-PULLAMAGATTA	PULLAMGATTA_66	18:36	18:44	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
962	05-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	SOKKE_66	21:45	22:00	00:15	TRIPPED ON FAULT
963	05-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	SOKKE_66	23:50	24:00	0:10	TRIPPED ON FAULT
964	05-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(LV SIDE)	DAVANGERE_220	15:01	15:36	00:35	LINE CLEAR AVAILED
965	05-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(LV SIDE)	DAVANGERE_220	15:01	15:36	00:35	LINE CLEAR AVAILED
966	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110	13:01	13:18	00:17	LINE CLEAR AVAILED
967	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	14:30	14:45	00:15	LINE CLEAR AVAILED
968	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV- TIPTUR	TIPTUR_110	13:15	13:29	00:14	LINE CLEAR AVAILED
969	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	14:42	15:59	01:17	LINE CLEAR AVAILED
970	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	14:56	15:21	00:25	LINE CLEAR AVAILED
971	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-HANDANKERE_110	HANDANKERE_110	10:00	11:58	01:58	LINE CLEAR AVAILED
972	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-HANDANKERE_110	HANDANKERE_110	12:48	13:00	00:12	LINE CLEAR AVAILED
973	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-HANDANKERE_110	HANDANKERE_110	16:53	18:32	01:39	LINE CLEAR AVAILED
974	05-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-THIMMANAHALLI_110	THIMMANAHALLI_110	12:20	12:52	00:32	LINE CLEAR AVAILED
975	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA DAVANGERE TR-2(HV SIDE)	DAVANGERE_220KV	11:17	12:13	00:56	TRIPPED ON FAULT
976	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA HIRIYUR TR-2(HV SIDE)	HIRIYUR_220KV	09:25	09:50	00:25	LINE CLEAR AVAILED
977	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA HIRIYUR TR-2(HV SIDE)	HIRIYUR_220KV	12:30	16:02	03:32	LINE CLEAR AVAILED
978	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA K.B.CROSS TR-1(HV SIDE)	K.B.CROSS_220KV	11:05	12:29	01:24	LINE CLEAR AVAILED
979	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA K.B.CROSS TR-2(HV SIDE)	K.B.CROSS_220KV	15:10	15:42	00:32	LINE CLEAR AVAILED
980	05-Jun-24	TUMKUR	220	TRANSFORMER	100MVA K.B.CROSS TR-3(HV SIDE)	K.B.CROSS_220KV	15:37	15:57	00:20	LINE CLEAR AVAILED
981	05-Jun-24	TUMKUR	220	LINE	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	13:13	15:38	02:25	LINE CLEAR AVAILED
982	05-Jun-24	TUMKUR	220	LINE	GUTTUR 400KV- DAVANAGERE 2	DAVANGERE_SRS_220	11:17	16:19	05:02	TRIPPED ON FAULT
983	05-Jun-24	TUMKUR	220	LINE	MADHUGIRI 220KV-VASANTANARASAPURA 1	VASANTANARASAPURA LINE 1	19:18	21:53	02:35	TRIPPED ON FAULT
984	05-Jun-24	TUMKUR	220	LINE	SIRA220-MADHUGIRI 2	MADHUGIRI_220	19:40	19:46	00:06	TRIPPED ON FAULT
985	05-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 220 KV LINE 1	GUTUR_400	11:11	19:11	08:00	TRIPPED ON FAULT
986	05-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 220 KV LINE 2	GUTTUR_400	22:54 (02.06.2024)	19:23 (05.06.2024)	2DAYS20 HR29MINTS	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
987	06-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
988	06-Jun-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	15:21	21:20	05:59	TRIPPED ON FAULT
989	06-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
990	06-Jun-24	BAGALKOTE	110	LINE	BAGEWADI220- MUDDEBIHAL	BAGEWADI_220	23:43	23:51	00:08	TRIPPED ON FAULT
991	06-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
992	06-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
993	06-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220-SOEPL (SOLAR)	GHATAPRABHA_220	06:13	07:11	00:58	TRIPPED ON FAULT
994	06-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
995	06-Jun-24	BAGALKOTE	110	LINE	INDI220- HIREBEVNUR	INDI_220	01:37	01:47	00:10	TRIPPED ON FAULT
996	06-Jun-24	BAGALKOTE	110	LINE	KARWAR220-BINAGA	KARWAR_220	11:37	11:49	00:12	LINE CLEAR AVAILED
997	06-Jun-24	BAGALKOTE	110	LINE	KARWAR220-BINAGA	KARWAR_220	06:01	10:45	04:44	TRIPPED ON FAULT
998	06-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
999	06-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1000	06-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1001	06-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1002	06-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMATA1	SIRSI_110	13:30	14:00	00:30	TRIPPED ON FAULT
1003	06-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	13:30	17:45	04:15	TRIPPED ON FAULT
1004	06-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1005	06-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- BENAKATTI	SOUDATTI_220	20:28	21:30	01:02	TRIPPED ON FAULT
1006	06-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- MUNAVALLI	SOUDATTI_220	20:28	21:39	01:11	TRIPPED ON FAULT
1007	06-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1008	06-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1009	06-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1010	06-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1011	06-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1012	06-Jun-24	BAGALKOTE	220	LINE	AEQUS-KANAGALA1	AEQUS_220	16:21	16:58	00:37	TRIPPED ON FAULT
1013	06-Jun-24	BAGALKOTE	220	LINE	AEQUS-KANAGALA2	AEQUS_220	16:21	17:02	00:41	TRIPPED ON FAULT
1014	06-Jun-24	BAGALKOTE	220	LINE	ATHANI- MAHALINGAPUR	ATHANI_220	11:23	14:25	03:02	LINE CLEAR AVAILED
1015	06-Jun-24	BAGALKOTE	220	LINE	BAGEWADI- MASUTI LIS	BAGEWADI_220	16:05	17:47	01:42	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1016	06-Jun-24	BAGALKOTE	220	LINE	CHIKKODI- KANAGALA1	CHIKKODI_220	16:22	17:05	00:43	TRIPPED ON FAULT
1017	06-Jun-24	BAGALKOTE	220	LINE	CHIKKODI- KANAGALA2	CHIKKODI_220	16:22	17:05	00:43	TRIPPED ON FAULT
1018	06-Jun-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGHOLKOD1	GHATAPRABHA_220	06:13	07:26	01:13	TRIPPED ON FAULT
1019	06-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1020	06-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1021	06-Jun-24	BAGALKOTE	220	LINE	RANEBENNUR- BALLIGAVI	RANEBENNUR_220	10:26	16:55	06:29	LINE CLEAR AVAILED
1022	06-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1023	06-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL2	SOUDATTI_220	18:45	22:30	03:45	TRIPPED ON FAULT
1024	06-Jun-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	AGALAKOTE	20:31	20:35	00:04	LINE CLEAR AVAILED
1025	06-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - CESSNA BUSINESS EHT	CESSNA 66, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	12:19	12:30	00:11	MAIN SUPPLY FAILURE
1026	06-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDLAGHATTA	21:32	21:50	00:18	TRIPPED ON FAULT
1027	06-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	21:37	21:53	00:16	TRIPPED ON FAULT
1028	06-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:10	10:17	00:07	LINE CLEAR AVAILED
1029	06-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - HIREHALLI	HIREHALLI	05:59	06:17	00:18	TRIPPED ON FAULT
1030	06-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	02:30	02:33	00:03	LINE CLEAR AVAILED
1031	06-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	08:10	08:14	00:04	LINE CLEAR AVAILED
1032	06-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	12:45	12:49	00:04	LINE CLEAR AVAILED
1033	06-Jun-24	BANGALORE	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	02:23	02:28	00:05	LINE CLEAR AVAILED
1034	06-Jun-24	BANGALORE	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	17:51	17:54	00:03	LINE CLEAR AVAILED
1035	06-Jun-24	BANGALORE	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	20:10	20:35	00:25	LINE CLEAR AVAILED
1036	06-Jun-24	BANGALORE	66	LINE	66KV JAYADEVA - ADUGODI 1	NO STATION AFFECTED	18:46	23:59	05:13	TRIPPED ON FAULT
1037	06-Jun-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	14:26	14:30	00:04	LINE CLEAR AVAILED
1038	06-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	CHIKKENAHALLI, ALLIMARADANAHALLI, SHIVANAHALLI	11:08	11:18	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1039	06-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	MARALAWADI, CHATRA, GODUR	21:16	21:26	00:10	TRIPPED ON FAULT
1040	06-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA	TAMAKA	20:35	20:48	00:13	TRIPPED ON FAULT
1041	06-Jun-24	BANGALORE	66	LINE	66KV NALLIMARADANAHALLI - DIBBURHALLI - SADLI	DIBBURHALLI	17:24	17:30	00:06	LINE CLEAR AVAILED
1042	06-Jun-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI	18:46	19:00	00:14	TRIPPED ON FAULT
1043	06-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASLU	22:13	22:31	00:18	TRIPPED ON FAULT
1044	06-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - G KODIHALLI	G KODIHALLI	21:36	21:48	00:12	TRIPPED ON FAULT
1045	06-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	14:01	16:10	02:09	TRIPPED ON FAULT
1046	06-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	16:50	16:55	00:05	LINE CLEAR AVAILED
1047	06-Jun-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	18:52	19:57	01:05	LINE CLEAR AVAILED
1048	06-Jun-24	BANGALORE	66	LINE	66KV URAGAHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	19:00	19:50	00:50	TRIPPED ON FAULT
1049	06-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	12:20	12:30	00:10	MAIN SUPPLY FAILURE
1050	06-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	12:20	12:30	00:10	MAIN SUPPLY FAILURE
1051	06-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	12:20	12:35	00:15	MAIN SUPPLY FAILURE
1052	06-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - JIGANI OLD STATION	NO STATION AFFECTED	12:59	17:25	04:26	TRIPPED ON FAULT
1053	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YELAHANKA 220	14:22	14:23	00:01	LINE CLEAR AVAILED
1054	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	11:32	11:43	00:11	TRIPPED ON FAULT
1055	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	23:11	23:59	00:48	TRIPPED ON FAULT
1056	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDABELAVANGALA	22:13	22:31	00:18	TRIPPED ON FAULT
1057	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYAPURA	00:38	00:43	00:05	TRIPPED ON FAULT
1058	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	21:05	21:14	00:09	TRIPPED ON FAULT
1059	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	21:16	21:27	00:11	TRIPPED ON FAULT
1060	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	THIMMAMPALLI	14:50	15:30	00:40	LINE CLEAR AVAILED
1061	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	20:35	22:15	01:40	TRIPPED ON FAULT
1062	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	12:28	12:38	00:10	TRIPPED ON FAULT
1063	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	01:00	01:05	00:05	TRIPPED ON FAULT
1064	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	TG HALLI	18:45	23:20	04:35	TRIPPED ON FAULT
1065	06-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HSR LAYOUT 220	07:50	07:57	00:07	LINE CLEAR AVAILED
1066	06-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YELAHANKA 220	15:28	15:33	00:05	LINE CLEAR AVAILED
1067	06-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ARMY WELFARE ORGANISATION	20:16	20:53	00:37	TRIPPED ON FAULT
1068	06-Jun-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAWADI, KM DODDI, KK DODDI, TUMBERE, KIADB MANDYA	18:30	18:42	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1069	06-Jun-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAWADI, KM DODDI, KK DODDI, TUMBERE, KIADB MANDYA	18:30	18:43	00:13	TRIPPED ON FAULT
1070	06-Jun-24	BANGALORE	220	LINE	220KV HOODY 220 - MALUR 220	EXORA 220, VIKAS TECH PARK 220	12:20	12:29	00:09	TRIPPED ON FAULT
1071	06-Jun-24	BANGALORE	220	LINE	220KV HOODY 220 - RAILWAYS 1	NO STATION AFFECTED	14:11	15:10	00:59	TRIPPED ON FAULT
1072	06-Jun-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	07:25	08:10	00:45	LINE CLEAR AVOIDED
1073	06-Jun-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI2	SOVENHALLI_66	19:04	19:19	00:15	TRIPPED ON FAULT
1074	06-Jun-24	GULBARGA	110	LINE	ALAND-KADAGANCHI	ALAND_110, KADAGANCHI_110	19:10	19:24	00:14	TRIPPED ON FAULT
1075	06-Jun-24	GULBARGA	110	LINE	ALIPUR-MUNIRABAD	KUDTINI_110, TORANGALU_110, KIDB_110, METRI_110	05:34	05:43	00:09	TRIPPED ON FAULT
1076	06-Jun-24	GULBARGA	110	LINE	BHALKI-HALBARGA	BHALKI_110	16:45	24:00:00	07:15	TRIPPED ON FAULT
1077	06-Jun-24	GULBARGA	110	LINE	BHALKI-HALBARGA	BHALKI_110	23:59	17:15	17:16	TRIPPED ON FAULT
1078	06-Jun-24	GULBARGA	110	LINE	BHALKI-HUMNABAD	BHALKI_110	15:00	15:20	00:20	TRIPPED ON FAULT
1079	06-Jun-24	GULBARGA	110	LINE	BHALKI-HUMNABAD	BHALKI_110	15:00	15:20	00:20	TRIPPED ON FAULT
1080	06-Jun-24	GULBARGA	110	LINE	BYAGWAT-MALLAT	BYAGWAT_110, WALKAMDINI_110, ADAVI AMARESHWAR_110	20:24	23:59	03:35	MAIN SUPPLY FAILURE
1081	06-Jun-24	GULBARGA	110	TRANSFORMER	HV3	WALKAMDINI_110	09:10	09:15	00:05	TRIPPED ON FAULT
1082	06-Jun-24	GULBARGA	110	TRANSFORMER	HV3	WALKAMDINI_110	20:10	20:45	00:35	TRIPPED ON FAULT
1083	06-Jun-24	GULBARGA	110	LINE	KALABURGI-NORTH1	NORTH_110	19:30	21:47	02:17	TRIPPED ON FAULT
1084	06-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	KHANAPUR_110	04:20	04:25	00:05	TRIPPED ON FAULT
1085	06-Jun-24	GULBARGA	110	LINE	KHANAPUR-SHAHPUR	KHANAPUR_110	13:55	16:47	02:52	MAIN SUPPLY FAILURE
1086	06-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONNATHI	SONNATHI_110	04:10	04:30	00:20	TRIPPED ON FAULT
1087	06-Jun-24	GULBARGA	110	LINE	KURUGODU-ALIPUR	KURUGODU_110	05:35	05:50	00:15	MAIN SUPPLY FAILURE
1088	06-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMANAL	HIREGONNAGAR_110,HANUMANAL_110	19:39	20:04	00:25	MAIN SUPPLY FAILURE
1089	06-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMANAL	HIREGONNAGAR_110,HANUMANAL_110	19:39	20:05	00:26	MAIN SUPPLY FAILURE
1090	06-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HNUMASAGAR	HANUMASAGAR_110,HIEGONAGAR_110	19:35	20:04	00:29	TRIPPED ON FAULT
1091	06-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HNUMASAGAR	HANUMASAGAR_110,HIEGONAGAR_110	19:39	20:04	00:25	TRIPPED ON FAULT
1092	06-Jun-24	GULBARGA	110	LINE	KUSHTAGI-TAVARGER	TAVARGER_110	17:00	18:04	01:04	TRIPPED ON FAULT
1093	06-Jun-24	GULBARGA	110	LINE	SHAHAPUR-DEVAPUR	DEVAPUR_110	20:03	20:16	00:13	TRIPPED ON FAULT
1094	06-Jun-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:12	05:17	00:05	TRIPPED ON FAULT
1095	06-Jun-24	GULBARGA	110	LINE	SHAHAPUR-KHANAPUR2	KHANAPUR_110	13:10	13:58	00:48	TRIPPED ON FAULT
1096	06-Jun-24	GULBARGA	110	LINE	SHAHAPUR-KHANAPUR2	KHANAPUR_110	13:58	16:48	02:50	LINE CLEAR AVOIDED
1097	06-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	12:20	16:15	03:55	LINE CLEAR AVOIDED
1098	06-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRUGUPPA	SIRIGERICROSS_110	20:32	20:43	00:11	MAIN SUPPLY FAILURE
1099	06-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRUGUPPA	SIRIGERICROSS_110	22:00	22:10	00:10	MAIN SUPPLY FAILURE
1100	06-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	18:50	18:55	00:05	MAIN SUPPLY FAILURE
1101	06-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVOIDED
1102	06-Jun-24	GULBARGA	220	LINE	SINDHANOOR-SULEKAL	SULEKAL_220	16:50	17:06	00:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1103	06-Jun-24	HASSAN	66	LINE	GORUR-ARAKALGUD	GORUR_66	11:10	11:20	00:10	MAIN SUPPLY FAILURE
1104	06-Jun-24	HASSAN	66	LINE	HNPR2-HASS2	HNPUA_220	11:40	13:55	02:15	LINE CLEAR AVOID
1105	06-Jun-24	HASSAN	66	TRANSFORMER	HV1	HNPUA_220	12:16	13:05	00:49	TRIPPED ON FAULT
1106	06-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	11:40	14:00	02:20	MAIN SUPPLY FAILURE
1107	06-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALLAPURA_66	13:20	13:50	00:30	LINE CLEAR AVOID
1108	06-Jun-24	HASSAN	66	TRANSFORMER	HV1	SINGAPURA_66	13:00	14:15	01:15	LINE CLEAR AVOID
1109	06-Jun-24	HASSAN	66	TRANSFORMER	HV2	MALLAPURA_66	13:23	14:08	00:45	LINE CLEAR AVOID
1110	06-Jun-24	HASSAN	66	TRANSFORMER	HV2	SINGAPURA_66	13:00	14:15	01:15	LINE CLEAR AVOID
1111	06-Jun-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:40	14:01	02:21	MAIN SUPPLY FAILURE
1112	06-Jun-24	HASSAN	66	LINE	MALALI-HASSAN	MALALI_66	11:40	13:56	02:16	MAIN SUPPLY FAILURE
1113	06-Jun-24	HASSAN	66	LINE	MALLAPU-SHIMOGA	MALLAPURA_66	13:23	13:48	00:25	LINE CLEAR AVOID
1114	06-Jun-24	HASSAN	66	LINE	MATTNAV-DIDGTHL	MATTNAVILE_66	03:40	03:53	00:13	TRIPPED ON FAULT
1115	06-Jun-24	HASSAN	66	LINE	MATTNAV-DIDGTHL	MATTNAVILE_66	05:11	05:25	00:14	TRIPPED ON FAULT
1116	06-Jun-24	HASSAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	11:40	11:50	00:10	MAIN SUPPLY FAILURE
1117	06-Jun-24	HASSAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	14:10	14:19	00:09	MAIN SUPPLY FAILURE
1118	06-Jun-24	HASSAN	66	LINE	SINGAP-HNPURA	SINGAPURA_66	13:00	14:15	01:15	LINE CLEAR AVOID
1119	06-Jun-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	17:06	17:19	00:13	TRIPPED ON FAULT
1120	06-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	10:35	12:46	02:11	LINE CLEAR AVOID
1121	06-Jun-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY1_110	13:32	14:21	00:49	TRIPPED ON FAULT
1122	06-Jun-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSNGADI_110	13:32	14:13	00:41	TRIPPED ON FAULT
1123	06-Jun-24	HASSAN	110	TRANSFORMER	HV1	MSEZ_220	10:20	13:12	02:52	LINE CLEAR AVOID
1124	06-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	10:35	12:46	02:11	LINE CLEAR AVOID
1125	06-Jun-24	HASSAN	110	LINE	MADHUV-KUNDAPURA	MADHUVana_110	02:24	03:03	00:39	TRIPPED ON FAULT
1126	06-Jun-24	HASSAN	220	TRANSFORMER	HV2 CBreaker	HEGGUNJE_220	10:41	12:49	02:08	LINE CLEAR AVOID
1127	06-Jun-24	HASSAN	220	LINE	MRSSHM-HONNALLI	MRSMSG_220	09:52	18:42	08:50	LINE CLEAR AVOID
1128	06-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH12	MRSMSG_220	10:11	15:54	05:43	LINE CLEAR AVOID
1129	06-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR3	gen_varahi	13:33	13:42	00:09	TRIPPED ON FAULT
1130	06-Jun-24	HASSAN	220	LINE	VARAHI-SHIMOGA2	gen_varahi	10:11	15:54	05:43	LINE CLEAR AVOID
1131	6-Jun-24	MYSORE	66	LINE	HANAGODU-HUNSURU	HANAGODU_66	10:03	19:16	09:12	LINE CLEAR AVOID
1132	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 1	NO STATIONS EFFECTED	10:12	12:18	02:06	LINE CLEAR AVOID
1133	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 2	NO STATIONS EFFECTED	10:12	12:18	02:06	LINE CLEAR AVOID
1134	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 3	NO STATIONS EFFECTED	11:37	12:56	01:19	LINE CLEAR AVOID
1135	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 4	NO STATIONS EFFECTED	11:37	12:56	01:19	LINE CLEAR AVOID
1136	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 5	NO STATIONS EFFECTED	11:37	12:56	01:19	LINE CLEAR AVOID
1137	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 6	NO STATIONS EFFECTED	12:21	13:22	01:01	LINE CLEAR AVOID
1138	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 7	NO STATIONS EFFECTED	12:21	13:22	01:01	LINE CLEAR AVOID
1139	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 8	NO STATIONS EFFECTED	10:12	12:18	02:06	LINE CLEAR AVOID
1140	6-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 9	NO STATIONS EFFECTED	10:12	12:18	02:06	LINE CLEAR AVOID
1141	6-Jun-24	MYSORE	66	LINE	HEBBANI-SHIMSHA	HADLI_66 KADKOTHANAHALLI_66 MALAVALLI_66	10:38	11:27	00:49	LINE CLEAR AVOID
1142	6-Jun-24	MYSORE	66	LINE	HEBBANI-TK HALLI	NO STATIONS EFFECTED	10:27	11:20	00:53	LINE CLEAR AVOID
1143	6-Jun-24	MYSORE	66	LINE	HEBBANI-VAJAMANGALA	NO STATIONS EFFECTED	11:50	13:29	01:39	LINE CLEAR AVOID
1144	6-Jun-24	MYSORE	66	TRANSFORMER	HV1	HANAGODU_66	10:03	19:16	09:12	LINE CLEAR AVOID
1145	6-Jun-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	05:37	06:05	00:28	MAIN SUPPLY FAILURE
1146	6-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1147	6-Jun-24	MYSORE	66	TRANSFORMER	HV2	HANAGODU_66	10:03	19:16	09:13	LINE CLEAR AVOID
1148	6-Jun-24	MYSORE	66	TRANSFORMER	HV2	MALAVALLI_66	05:37	06:05	00:28	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1149	6-Jun-24	MYSORE	66	TRANSFORMER	HV2	MYSORE SOUTH-	16:52	17:13	00:20	TRIPPED ON FAULT
1150	6-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
1151	6-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	07:31	07:38	00:07	TRIPPED ON FAULT
1152	6-Jun-24	MYSORE	66	LINE	KM DODDI-KK DODDI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, TUMBEKERE_66 TALAGAVADI_66	18:30	18:50	00:20	TRIPPED ON FAULT
1153	6-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1154	6-Jun-24	MYSORE	66	LINE	KUSHALANAGARA 220-HARANGI	NO STATIONS EFFECTED	10:42	17:26	06:44	LINE CLEAR AVAILED
1155	6-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1156	6-Jun-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	00:35	00:40	00:05	TRIPPED ON FAULT
1157	6-Jun-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	00:50	00:55	00:05	TRIPPED ON FAULT
1158	6-Jun-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	02:23	02:28	00:05	TRIPPED ON FAULT
1159	6-Jun-24	MYSORE	66	LINE	PANDAVAPURA-ATRIA 2	NO STATIONS EFFECTED	15:48	15:58	00:10	LINE CLEAR AVAILED
1160	6-Jun-24	MYSORE	66	LINE	SANTHE SARAGURU-B MATTGERE	NO STATIONS EFFECTED	12:20	14:02	01:42	LINE CLEAR AVAILED
1161	6-Jun-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	11:35	12:58	01:23	LINE CLEAR AVAILED
1162	6-Jun-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	11:35	12:57	01:22	LINE CLEAR AVAILED
1163	06-Jun-24	TUMKUR	66	TRANSFORMER	20MVA KIADB TR-1(LV SIDE)	VASANTHNARASAPURA KDB_220	16:10	17:12	01:02	LINE CLEAR AVAILED
1164	06-Jun-24	TUMKUR	66	TRANSFORMER	20MVA KIADB TR-1(LV SIDE)	VASANTHNARASAPURA KDB_220	16:10	17:12	01:02	LINE CLEAR AVAILED
1165	06-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	05:45	05:57	00:12	TRIPPED ON FAULT
1166	06-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	05:45	05:57	00:12	TRIPPED ON FAULT
1167	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI, BHARAMGIRI	01:18	01:28	00:10	TRIPPED ON FAULT
1168	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI BHARAMGIRI	02:15	03:45	01:30	TRIPPED ON FAULT
1169	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI	16:55	17:40	00:45	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1170	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI, BHARAMGIRI	01:18	01:28	00:10	TRIPPED ON FAULT
1171	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI BHARAMGIRI	02:15	03:45	01:30	TRIPPED ON FAULT
1172	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR_66KV MATHOD LINE-2	66KV MATHOD KANCHIPURA AND GARAGA PANCHANAHALLI	16:55	17:40	00:45	TRIPPED ON FAULT
1173	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV JAVAGONDANAHALLY-BEVINAHALLY	66KV BEVINAHALLI, J G HALLI, CHANGAVARA	07:05	07:25	00:20	TRIPPED ON FAULT
1174	06-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV JAVAGONDANAHALLY-BEVINAHALLY	66KV BEVINAHALLI, J G HALLI, CHANGAVARA	07:05	07:25	00:20	TRIPPED ON FAULT
1175	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1	66 KV B G KERE MUSS, 66KV NAGASAMUDRA, RAMPURA	18:22	19:17	00:55	TRIPPED ON FAULT
1176	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1	66 KV B G KERE MUSS, 66KV NAGASAMUDRA, RAMPURA	18:22	19:17	00:55	TRIPPED ON FAULT
1177	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	CHALLAKERE_66, SANIKERE_66	18:34	19:44	01:10	TRIPPED ON FAULT
1178	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE-1	CHALLAKERE_66, SANIKERE_66	18:34	19:44	01:10	TRIPPED ON FAULT
1179	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA	66 KV MYLANAHALLI,V V PURA, DYAVARANAHALLI MUSS	18:39	19:37	00:58	TRIPPED ON FAULT
1180	06-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA	66 KV MYLANAHALLI,V V PURA, DYAVARANAHALLI MUSS	18:39	19:37	00:58	TRIPPED ON FAULT
1181	06-Jun-24	TUMKUR	66	LINE	66KV HANGAL-66KV NAGASAMUDRA	66KV NAGASAMUDRA, RAMPURA	11:29	11:42	00:13	TRIPPED ON FAULT
1182	06-Jun-24	TUMKUR	66	LINE	66KV HANGAL-66KV NAGASAMUDRA	66KV NAGASAMUDRA, RAMPURA	11:29	11:42	00:13	TRIPPED ON FAULT
1183	06-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI -66KV HOLALKERE LINE 1	66KV CHIKKAJAJUR	16:20	16:45	00:25	TRIPPED ON FAULT
1184	06-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI -66KV HOLALKERE LINE 1	66KV CHIKKAJAJUR	16:20	16:45	00:25	TRIPPED ON FAULT
1185	06-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	RAMAGIRI_66, CHIKJAJUR_66,SASALUHALLA_66	19:30	19:45	00:15	TRIPPED ON FAULT
1186	06-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	RAMAGIRI_66, CHIKJAJUR_66,SASALUHALLA_66	19:30	19:45	00:15	TRIPPED ON FAULT
1187	06-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV SOKKE	23:59	00:25	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1188	06-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV SOKKE	10:45	10:55	00:10	LINE CLEAR AVAILED
1189	06-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV SOKKE	23:59	00:25	00:25	TRIPPED ON FAULT
1190	06-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV UJJINI	66KV SOKKE	10:45	10:55	00:10	LINE CLEAR AVAILED
1191	06-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	05:52	06:13	00:21	TRIPPED ON FAULT
1192	06-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	05:52	06:13	00:21	TRIPPED ON FAULT
1193	06-Jun-24	TUMKUR	66	LINE	BRAHMASANDRA_66- ANKASANDRA_66	66KV ANKASANDRA	12:37	13:07	00:30	TRIPPED ON FAULT
1194	06-Jun-24	TUMKUR	66	LINE	BRAHMASANDRA_66- ANKASANDRA_66	66KV ANKASANDRA	12:37	13:07	00:30	TRIPPED ON FAULT
1195	06-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:25	18:16	00:51	TRIPPED ON FAULT
1196	06-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	17:25	18:16	00:51	TRIPPED ON FAULT
1197	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	01:20	01:28	00:08	TRIPPED ON FAULT
1198	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	02:10	02:23	00:13	TRIPPED ON FAULT
1199	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	17:21	17:40	00:19	TRIPPED ON FAULT
1200	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	01:20	01:28	00:08	TRIPPED ON FAULT
1201	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	02:10	02:23	00:13	TRIPPED ON FAULT
1202	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD-1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	17:21	17:40	00:19	TRIPPED ON FAULT
1203	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:57	17:12	01:15	LINE CLEAR AVAILED
1204	06-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	15:57	17:12	01:15	LINE CLEAR AVAILED
1205	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	07:05	07:22	00:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1206	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:26	12:39	01:13	LINE CLEAR AVAILED
1207	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	07:05	07:22	00:17	TRIPPED ON FAULT
1208	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:26	12:39	01:13	LINE CLEAR AVAILED
1209	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	09:28	18:37	09:09	LINE CLEAR AVAILED
1210	06-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	09:28	18:37	09:09	LINE CLEAR AVAILED
1211	06-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	09:11	09:26	00:15	TRIPPED ON FAULT
1212	06-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	09:11	09:26	00:15	TRIPPED ON FAULT
1213	06-Jun-24	TUMKUR	220	TRANSFORMER	100MVA HIRIYUR TR-2 (HV SIDE)	HIRIYUR_220KV	17:20	17:26	00:06	LINE CLEAR AVAILED
1214	06-Jun-24	TUMKUR	220	TRANSFORMER	100MVA HIRIYUR TR-2 (HV SIDE)	HIRIYUR_220KV	17:20	17:26	00:06	LINE CLEAR AVAILED
1215	06-Jun-24	TUMKUR	220	LINE	220KV CHITRADURGA-66KV TURUVANUR LINE	66KV JAGALUR, BIDARKERE, TURUVANUR,MADANAYAKANA HALLI	17:25	18:15	00:50	TRIPPED ON FAULT
1216	06-Jun-24	TUMKUR	220	LINE	220KV CHITRADURGA-66KV TURUVANUR LINE	66KV JAGALUR, BIDARKERE, TURUVANUR,MADANAYAKANA HALLI	17:25	18:15	00:50	TRIPPED ON FAULT
1217	06-Jun-24	TUMKUR	220	LINE	HONNALLI 220KV- SHIMOGA 220KV1	MRSMSG_220	09:46	18:46	09:00	LINE CLEAR AVAILED
1218	06-Jun-24	TUMKUR	220	LINE	HONNALLI 220KV- SHIMOGA 220KV1	MRSMSG_220	09:46	18:46	09:00	LINE CLEAR AVAILED
1219	06-Jun-24	TUMKUR	220	LINE	MADHUGIRI 220KV- GOWRIBIDANUR220	MADHUGIRI_220	15:59	21:13	05:14	LINE CLEAR AVAILED
1220	06-Jun-24	TUMKUR	220	LINE	MADHUGIRI 220KV- GOWRIBIDANUR220	MADHUGIRI_220	15:59	21:13	05:14	LINE CLEAR AVAILED
1221	07-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BISNAL_110	23:54 (06.06.2024)			TRIPPED ON FAULT
1222	07-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	BISNAL_110	23:54 (06.06.2024)	12:10 (07.06.2024)	12:16	TRIPPED ON FAULT
1223	07-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	LOKAPUR_110	19:15	23:55	04:40	TRIPPED ON FAULT
1224	07-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
1225	07-Jun-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-1	AHERI_220	05:54	06:15	00:21	TRIPPED ON FAULT
1226	07-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
1227	07-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
1228	07-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
1229	07-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- MANTUR	GHATAPRABHA_220	14:31	16:29	01:58	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1230	07-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	2:36	2:54	00:18	TRIPPED ON FAULT
1231	07-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	05:13	05:18	00:05	TRIPPED ON FAULT
1232	07-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	21:01	21:11	00:10	TRIPPED ON FAULT
1233	07-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
1234	07-Jun-24	BAGALKOTE	110	LINE	KUDACHI220- AINAPUR	KUDACHI_220	10:20	17:45	07:25	LINE CLEAR AVAILED
1235	07-Jun-24	BAGALKOTE	110	LINE	KUDACHI220- UGARKHUD	KUDACHI_220	13:50	14:10	00:20	LINE CLEAR AVAILED
1236	07-Jun-24	BAGALKOTE	110	LINE	KUDACHI220- YELPARAHATTI	KUDACHI_220	13:30	14:15	00:45	LINE CLEAR AVAILED
1237	07-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
1238	07-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-BIDI	MK HUBLI_220	07:43	08:19	00:36	TRIPPED ON FAULT
1239	07-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1240	07-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- BOMMANAL	MUGALKHOD_220	10:08	16:13	06:05	LINE CLEAR AVAILED
1241	07-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- MAHALINGAPUR	MUGALKHOD_220	06:59	07:11	00:12	TRIPPED ON FAULT
1242	07-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1243	07-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR- HIREKERUR	RANEBENNUR_220	14:50	15:02	00:12	TRIPPED ON FAULT
1244	07-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1245	07-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1246	07-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-BENAKATTI	SOUDATTI_220	20:28	21:30	01:02	TRIPPED ON FAULT
1247	07-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-MUNAVALLI	SOUDATTI_220	20:28	21:39	01:11	TRIPPED ON FAULT
1248	07-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA1	SOUDATTI_220	20:45	21:06	00:21	TRIPPED ON FAULT
1249	07-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-RAMADURGA2	SOUDATTI_220	20:45	21:09	00:24	TRIPPED ON FAULT
1250	07-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1251	07-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1252	07-Jun-24	BAGALKOTE	110	LINE	TAKKALAKI- KIADB BIJAPUR	TAKKALAKI_110	5:20	9:50	04:30	TRIPPED ON FAULT
1253	07-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1254	07-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1255	07-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1256	07-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	09:40	13:02	03:22	LINE CLEAR AVAILED
1257	07-Jun-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI1	BAGALKOT_220	00:10	13:33	13:23	TRIPPED ON FAULT
1258	07-Jun-24	BAGALKOTE	220	LINE	BAGALKOT - ALAMATTI2	BAGALKOT_220	10:18	13:34	03:16	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1259	07-Jun-24	BAGALKOTE	220	LINE	CHIKKODI- KANAGALA1	CHIKKODI_220	10:30	12:40	02:10	LINE CLEAR AVAILED
1260	07-Jun-24	BAGALKOTE	220	LINE	KARWAR-KADRA2	KARWAR_220	09:40	13:03	03:23	LINE CLEAR AVAILED
1261	07-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1262	07-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1263	07-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1264	07-Jun-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	11:20	11:46	00:26	MAIN SUPPLY FAILURE
1265	07-Jun-24	BANGALORE	66	LINE	66KV BRIGADE TECH GARDEN - BRIGADE METROPOLIS	BRIGADE METROPOLIS	14:45	15:05	00:20	MAIN SUPPLY FAILURE
1266	07-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:03	10:14	00:11	LINE CLEAR AVAILED
1267	07-Jun-24	BANGALORE	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	12:54	13:01	00:07	TRIPPED ON FAULT
1268	07-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - SK STEEL	SK STEEL	14:09	14:14	00:05	MAIN SUPPLY FAILURE
1269	07-Jun-24	BANGALORE	66	LINE	66KV DG3_ HBR 66 - MANYATA 66 - KONDASPURA (SAFAL)	NO STATION AFFECTED	17:02	17:53	00:51	TRIPPED ON FAULT
1270	07-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL	17:01	17:18	00:17	TRIPPED ON FAULT
1271	07-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGEHALLI	13:03	13:30	00:27	TRIPPED ON FAULT
1272	07-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	08:02	08:13	00:11	TRIPPED ON FAULT
1273	07-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANASAWADI	14:15	14:18	00:03	MAIN SUPPLY FAILURE
1274	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 1	BAGHMANE WTC	15:20	15:25	00:05	LINE CLEAR AVAILED
1275	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 2	BAGHMANE WTC	15:20	15:25	00:05	LINE CLEAR AVAILED
1276	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BHORUKA - GRAPHITE INDIA	GRAPHITE INDIA	11:20	11:44	00:24	MAIN SUPPLY FAILURE
1277	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BHORUKA - GRAPHITE INDIA	GRAPHITE INDIA	14:45	15:05	00:20	MAIN SUPPLY FAILURE
1278	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	11:20	11:44	00:24	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1279	07-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTHINIKETHAN	14:45	15:05	00:20	MAIN SUPPLY FAILURE
1280	07-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - RANGANADODDI - SOMANAHALLI	NO STATION AFFECTED	16:12	16:55	00:43	TRIPPED ON FAULT
1281	07-Jun-24	BANGALORE	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	06:21	06:45	00:24	TRIPPED ON FAULT
1282	07-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 1	NARASAPURA, HONDA, WISTRON, KC VALLEY	07:43	08:59	01:16	LINE CLEAR AVAILED
1283	07-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 2	NARASAPURA, HONDA, WISTRON, KC VALLEY	07:43	08:59	01:16	LINE CLEAR AVAILED
1284	07-Jun-24	BANGALORE	66	LINE	66KV KUMBARANAHALLI - BAGGANADODDI	BAGGANADODDI	21:12	22:09	00:57	TRIPPED ON FAULT
1285	07-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	HOSPALYA CIRCLE, MAGADI 66	05:44	06:09	00:25	TRIPPED ON FAULT
1286	07-Jun-24	BANGALORE	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	06:14	07:04	00:50	TRIPPED ON FAULT
1287	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, BEST STEEL(EHT), ADL(EHT)	06:02	06:31	00:29	MAIN SUPPLY FAILURE
1288	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, BEST STEEL(EHT), ADL(EHT)	08:48	13:16	04:28	LINE CLEAR AVAILED
1289	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	NO STATION AFFECTED	06:02	06:31	00:29	MAIN SUPPLY FAILURE
1290	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	NO STATION AFFECTED	08:48	13:16	04:28	LINE CLEAR AVAILED
1291	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR 66	06:02	06:31	00:29	MAIN SUPPLY FAILURE
1292	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	06:02	06:31	00:29	MAIN SUPPLY FAILURE
1293	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	06:14	06:49	00:35	MAIN SUPPLY FAILURE
1294	07-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	VOKKALERI	06:14	06:49	00:35	MAIN SUPPLY FAILURE
1295	07-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	22:30	22:35	00:05	LINE CLEAR AVAILED
1296	07-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - MUDDENAHALLI (NANDI)	MUDDENAHALLI, CB PURA URBAN, CB PURA I/A	02:18	02:25	00:07	LINE CLEAR AVAILED
1297	07-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	02:18	02:25	00:07	LINE CLEAR AVAILED
1298	07-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANKUNTE	11:00	11:10	00:10	TRIPPED ON FAULT
1299	07-Jun-24	BANGALORE	66	LINE	66KV RAGHUTTAHALLI - BOMMEPALLI	BOMMEPALLI, YENNIGADALE	12:54	13:05	00:11	TRIPPED ON FAULT
1300	07-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	07:47	08:27	00:40	TRIPPED ON FAULT
1301	07-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST VIEW	06:10	06:18	00:08	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1302	07-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	19:10	19:25	00:15	LINE CLEAR AVAILED
1303	07-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	TALAGAWARA, CHEEMANGALA	17:46	17:56	00:10	LINE CLEAR AVAILED
1304	07-Jun-24	BANGALORE	66	LINE	66KV URAGAHALLI - KEMPANAHALLI	URAGAHALLI	12:45	12:50	00:05	MAIN SUPPLY FAILURE
1305	07-Jun-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	15:05	15:15	00:10	TRIPPED ON FAULT
1306	07-Jun-24	BANGALORE	66	LINE	GOWRIBIDANUR 220 - AFTL	NO STATION AFFECTED	13:03	13:25	00:22	TRIPPED ON FAULT
1307	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDINI LAYOUT	09:49	09:52	00:03	LINE CLEAR AVAILED
1308	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOODY 220	14:45	15:05	00:20	MAIN SUPPLY FAILURE
1309	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ISRO LAYOUT	06:02	06:15	00:13	TRIPPED ON FAULT
1310	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BUDIGERE	18:55	19:10	00:15	LINE CLEAR AVAILED
1311	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MELUR	11:40	11:45	00:05	LINE CLEAR AVAILED
1312	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	23:59	00:05	00:06	TRIPPED ON FAULT
1313	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	12:10	12:18	00:08	TRIPPED ON FAULT
1314	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KIADB DB PURA 220	15:39	15:40	00:01	LINE CLEAR AVAILED
1315	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KGF	12:15	13:30	01:15	LINE CLEAR AVAILED
1316	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KYASAMBALLI	16:10	16:12	00:02	LINE CLEAR AVAILED
1317	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	10:21	10:26	00:05	TRIPPED ON FAULT
1318	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	14:20	14:25	00:05	TRIPPED ON FAULT
1319	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	10:55	11:20:00	00:25	LINE CLEAR AVAILED
1320	07-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	19:40	19:52	00:12	TRIPPED ON FAULT
1321	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ARMY WELFARE ORGANISATION	00:10	00:31	00:21	TRIPPED ON FAULT
1322	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOODY 220	11:20	11:44	00:24	MAIN SUPPLY FAILURE
1323	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUMPA	17:30	17:40	00:10	TRIPPED ON FAULT
1324	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	08:40	08:46	00:06	TRIPPED ON FAULT
1325	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	D CROSS	11:10	11:25	00:15	TRIPPED ON FAULT
1326	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KYASAMBALLI	15:25	15:35	00:10	LINE CLEAR AVAILED
1327	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MASTHI	15:45	16:35	00:50	LINE CLEAR AVAILED
1328	07-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 220	04:46	08:02	03:16	TRIPPED ON FAULT
1329	07-Jun-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	16:50	17:20	00:30	TRIPPED ON FAULT
1330	07-Jun-24	BANGALORE	220	TRANSFORMER	HV1	HOODY 220	11:20	11:44	00:24	MAIN SUPPLY FAILURE
1331	07-Jun-24	BANGALORE	220	TRANSFORMER	HV1	HOODY 220	14:45	15:43	00:58	TRIPPED ON FAULT
1332	07-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MALUR 220	06:02	06:31	00:29	TRIPPED ON FAULT
1333	07-Jun-24	BANGALORE	220	TRANSFORMER	LV1	MALUR 220	06:14	06:49	00:35	TRIPPED ON FAULT
1334	07-Jun-24	GULBARGA	66	LINE	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66	09:05	13:10	04:05	LINE CLEAR AVAILED
1335	07-Jun-24	GULBARGA	66	LINE	ITTAGI-HARAPPANALLI	HARAPPANAHALLI_66	10:00	15:30	05:30	LINE CLEAR AVAILED
1336	07-Jun-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	21:33	22:20	00:47	TRIPPED ON FAULT
1337	07-Jun-24	GULBARGA	66	LINE	ITTAGI-KUDALGI1	KUDALAGI_66	10:00	15:35	05:35	LINE CLEAR AVAILED
1338	07-Jun-24	GULBARGA	66	LINE	ITTAGI-KUDALGI2	KUDALAGI_66	10:00	13:10	03:10	LINE CLEAR AVAILED
1339	07-Jun-24	GULBARGA	66	LINE	KUDALGI-UJJINI	UJJINI_66, NIMBALAGERI_66, SOKKE_66	21:30	21:45	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1340	07-Jun-24	GULBARGA	66	LINE	KUDALGI-UJJINI	UJJINI_66, NIMBALAGERI_66, SOKKE_66	23:00	23:15	00:15	TRIPPED ON FAULT
1341	07-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-JAWALGERA	ADAVIAMARESHWAR_110	09:36	10:10	00:34	LINE CLEAR AVAILED
1342	07-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-MALLAT	ADAVIAMARESHWAR_110	18:57	19:03	00:06	MAIN SUPPLY FAILURE
1343	07-Jun-24	GULBARGA	110	LINE	ALLIPUR-NORTH	SOMASAMUDRA_110	05:31	05:39	00:08	TRIPPED ON FAULT
1344	07-Jun-24	GULBARGA	110	LINE	ALLIPUR-SOUTH	SOUTH_110	05:10	05:28	00:18	TRIPPED ON FAULT
1345	07-Jun-24	GULBARGA	110	LINE	BISILHALLI-HALAKUNDI	BISILHALLI_110	05:11	05:34	00:23	TRIPPED ON FAULT
1346	07-Jun-24	GULBARGA	110	LINE	BYAGWAT-MALLAT	BYAGWAT_110	10:45	10:55	00:10	MAIN SUPPLY FAILURE
1347	07-Jun-24	GULBARGA	110	LINE	BYAGWAT-MALLAT	BYAGWAT_110	17:57	18:00	00:03	MAIN SUPPLY FAILURE
1348	07-Jun-24	GULBARGA	110	LINE	BYAGWAT-WALKAMDINI	BYAGWAT_110	05:10	05:20	00:10	LINE CLEAR AVAILED
1349	07-Jun-24	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALKI_110	23:59	14:50	14:51	LINE CLEAR AVAILED
1350	07-Jun-24	GULBARGA	110	LINE	HALBARGA-SANTHAPUR	SANTAPUR_110	14:15	15:35	01:20	LINE CLEAR AVAILED
1351	07-Jun-24	GULBARGA	110	LINE	HALBARGA-SANTPUR	SANTAPUR_110	14:15	15:35	01:20	LINE CLEAR AVAILED
1352	07-Jun-24	GULBARGA	110	TRANSFORMER	HV1	WALKAMDINI_110	09:30	09:40	00:10	TRIPPED ON FAULT
1353	07-Jun-24	GULBARGA	110	TRANSFORMER	HV1	METRI_110	09:00	15:00	06:00	LINE CLEAR AVAILED
1354	07-Jun-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	GANADAL_110	11:00	17:00	06:00	LINE CLEAR AVAILED
1355	07-Jun-24	GULBARGA	110	TRANSFORMER	HV2	MADLAPUR_110	04:01	04:06	00:05	TRIPPED ON FAULT
1356	07-Jun-24	GULBARGA	110	LINE	JAWALGERA-WALABALLARI	JAWALGERA_110	20:20	20:25	00:05	TRIPPED ON FAULT
1357	07-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	03:05	03:50	00:45	TRIPPED ON FAULT
1358	07-Jun-24	GULBARGA	110	LINE	KAPNOOR-NORTH2	KALBURGI NORTH_110	10:55	00:00	13:05	LINE CLEAR AVAILED
1359	07-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	19:43	19:55	00:12	TRIPPED ON FAULT
1360	07-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	20:02	20:23	00:21	TRIPPED ON FAULT
1361	07-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	20:20	21:07	00:47	TRIPPED ON FAULT
1362	07-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	RAILWAY LINE_110	03:25	03:30	00:05	TRIPPED ON FAULT
1363	07-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	RAILWAY LINE_110	12:00	12:58	00:58	LINE CLEAR AVAILED
1364	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-GANADDAL	GANADAL_110,KANAKAGIRI_110	11:40	14:25	02:45	LINE CLEAR AVAILED
1365	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGON NAGAR_110,HANUMANAL_110	15:25	15:40	00:15	TRIPPED ON FAULT
1366	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-ILKAL1&2	ILKAL_110	03:10	03:43	00:33	TRIPPED ON FAULT
1367	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-ILKAL2	ILKAL_110	00:15	00:48	00:33	TRIPPED ON FAULT
1368	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-ILKAL2	ILKAL_110	01:56	02:17	00:21	TRIPPED ON FAULT
1369	07-Jun-24	GULBARGA	110	LINE	KUSHTAGI-TAVARGERA	TAVARGERA_110	05:53	06:38	00:45	TRIPPED ON FAULT
1370	07-Jun-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	10:28	11:28	01:00	LINE CLEAR AVAILED
1371	07-Jun-24	GULBARGA	110	LINE	PDHALLI-ALIPUR	PD_HALLI_110	05:11	05:41	00:30	MAIN SUPPLY FAILURE
1372	07-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110	01:05	01:10	00:05	TRIPPED ON FAULT
1373	07-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110	21:15	21:24	00:09	TRIPPED ON FAULT
1374	07-Jun-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR1	SIRWAR_110	19:05	19:10	00:05	TRIPPED ON FAULT
1375	07-Jun-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR2	KURDICROSS_110	18:56	19:07	00:11	TRIPPED ON FAULT
1376	07-Jun-24	GULBARGA	110	LINE	SHAHAPUR-JEWARGI	JEWARGI_110	04:52	05:11	00:19	TRIPPED ON FAULT
1377	07-Jun-24	GULBARGA	110	LINE	SHAHAPUR-JEWARGI	JEWARGI_110	18:50	19:01	00:11	TRIPPED ON FAULT
1378	07-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	23:20	23:30	00:10	TRIPPED ON FAULT
1379	07-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	23:20	23:30	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1380	07-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	SIRIGERICROSS_110	00:37	00:55	00:18	MAIN SUPPLY FAILURE
1381	07-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGERICROSS	SIRIGERICROSS_110	02:48	03:05	00:17	TRIPPED ON FAULT
1382	07-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGERICROSS	SIRIGERICROSS_110	04:10	05:15	01:05	TRIPPED ON FAULT
1383	07-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGERICROSS	SIRIGERICROSS_110	13:34	14:05	00:31	MAIN SUPPLY FAILURE
1384	07-Jun-24	GULBARGA	220	LINE	ALLIPUR-BTPS	ALLIPUR_220	12:57	14:05	01:08	TRIPPED ON FAULT
1385	07-Jun-24	GULBARGA	220	TRANSFORMER	HV3 & LV3	KUSHTAGI_220	11:20	18:35	07:15	LINE CLEAR AVAIED
1386	07-Jun-24	GULBARGA	220	LINE	LINGASUGUR-MALLAT	LINGASUGUR_220	10:29	12:50	02:21	LINE CLEAR AVAIED
1387	07-Jun-24	GULBARGA	220	LINE	LINGASUGUR-RTPS2	LINGASUGUR_220	13:00	14:48	01:48	LINE CLEAR AVAIED
1388	07-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
1389	07-Jun-24	GULBARGA	220	LINE	SHAHAPUR-RTPS2	SHAHAPUR_220	23:33	23:47	00:14	TRIPPED ON FAULT
1390	07-Jun-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	07:11	07:15	00:04	TRIPPED ON FAULT
1391	07-Jun-24	HASSAN	66	LINE	BALLUPE-KANDLI	BALLUPETE_66	08:55	19:00	10:05	LINE CLEAR AVAIED
1392	07-Jun-24	HASSAN	66	LINE	HANUBAL-SAKLESPUR	HANUBALU_66	07:00	19:04	12:04	LINE CLEAR AVAIED
1393	07-Jun-24	HASSAN	66	LINE	HASSN22-UDDUR	HASSAN_220	06:53	07:08	00:15	TRIPPED ON FAULT
1394	07-Jun-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	06:53	07:08	00:15	TRIPPED ON FAULT
1395	07-Jun-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	10:02	11:41	01:39	LINE CLEAR AVAIED
1396	07-Jun-24	HASSAN	66	TRANSFORMER	HV1	HANUBAL_66	07:00	19:04	12:04	MAIN SUPPLY FAILURE
1397	07-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1398	07-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	19:18	19:25	00:07	TRIPPED ON FAULT
1399	07-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1400	07-Jun-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	11:00	11:20	00:20	TRIPPED ON FAULT
1401	07-Jun-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	22:59	23:17	00:18	TRIPPED ON FAULT
1402	07-Jun-24	HASSAN	66	TRANSFORMER	HV2	TAVARECHATNAHALLI_66	12:00	13:00	01:00	LINE CLEAR AVAIED
1403	07-Jun-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	14:40	19:11	04:31	LINE CLEAR AVAIED
1404	07-Jun-24	HASSAN	66	LINE	MATTNAV-DIDGTHL	MATTNAVILE_66	00:31	00:50	00:19	TRIPPED ON FAULT
1405	07-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	07:00	19:03	12:03	LINE CLEAR AVAIED
1406	07-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1407	07-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1408	07-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1409	07-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	08:30	19:04	10:34	LINE CLEAR AVAIED
1410	07-Jun-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAM_66	11:32	13:57	02:25	LINE CLEAR AVAIED
1411	07-Jun-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAM_66	11:32	12:53	01:21	LINE CLEAR AVAIED
1412	07-Jun-24	HASSAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPPLU_66	11:48	12:52	01:04	LINE CLEAR AVAIED
1413	07-Jun-24	HASSAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPPLU_66	12:55	13:50	00:55	LINE CLEAR AVAIED
1414	07-Jun-24	HASSAN	66	LINE	UDDURKO-HASSAN1	UDDURKOPPLU_66	10:10	11:42	01:32	LINE CLEAR AVAIED
1415	07-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON1	UDDURKOPPLU_66	06:50	09:00	02:10	TRIPPED ON FAULT
1416	07-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON2	UDDURKOPPLU_66	06:50	09:22	02:32	TRIPPED ON FAULT
1417	07-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	10:35	18:30	07:55	LINE CLEAR AVAIED
1418	07-Jun-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	10:35	18:30	07:55	MAIN SUPPLY FAILURE
1419	07-Jun-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	10:35	18:30	07:55	MAIN SUPPLY FAILURE
1420	07-Jun-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	18:50	21:00	02:10	LINE CLEAR AVAIED
1421	07-Jun-24	HASSAN	110	LINE	KADUR-TNGL	KADUR_220	18:44	18:51	00:07	TRIPPED ON FAULT
1422	07-Jun-24	HASSAN	110	LINE	KEMAR-MOODABIDRE	KEMAR_220	04:05	04:39	00:34	TRIPPED ON FAULT
1423	07-Jun-24	HASSAN	110	LINE	KEMAR-MOODABIDRE	KEMAR_220	04:57	12:41	07:44	TRIPPED ON FAULT
1424	07-Jun-24	HASSAN	110	TRANSFORMER	LV2	PUTTUR_220	09:44	16:11	06:27	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1425	07-Jun-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gersoppa	21:37(7.06.2024)			TRIPPED ON FAULT
1426	07-Jun-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	09:44	16:11	06:27	LINE CLEAR AVAILED
1427	07-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	21:37(7.06.2024)			TRIPPED ON FAULT
1428	07-Jun-24	HASSAN	220	LINE	MRSSHM-VARAHI1	MRSMSG_220	09:25	15:21	05:56	LINE CLEAR AVAILED
1429	07-Jun-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	09:25	15:21	05:56	LINE CLEAR AVAILED
1430	7-Jun-24	MYSORE	66	LINE	BESAGARAHALLI-DUNDANAHALLI	NO STATIONS EFFECTED	12:05	12:45	00:40	LINE CLEAR AVAILED
1431	7-Jun-24	MYSORE	66	LINE	BESAGARAHALLI-KOPPA	BESAGARAHALLI_66	10:40	14:25	03:45	LINE CLEAR AVAILED
1432	7-Jun-24	MYSORE	66	LINE	CR NAGARA-HONNAHALLI	ATTIGULIPURA_66HONNALLY_MYS_66ARAKALWADI_66	10:14	16:10	05:55	LINE CLEAR AVAILED
1433	7-Jun-24	MYSORE	66	LINE	CR NAGARA-KOLLEGALA	THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	04:18	04:24	00:05	TRIPPED ON FAULT
1434	7-Jun-24	MYSORE	66	LINE	DODDINADUWADI-KOTHANUR	NO STATIONS EFFECTED	05:30	05:40	00:10	TRIPPED ON FAULT
1435	7-Jun-24	MYSORE	66	LINE	HOOTAGALLI-BOGADHI	BOGADHI_66	10:09	16:11	06:02	LINE CLEAR AVAILED
1436	7-Jun-24	MYSORE	66	LINE	HOOTAGALLI-KHB	NO STATIONS EFFECTED	12:01	13:38	01:37	LINE CLEAR AVAILED
1437	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARVEY_66	05:40	05:59	00:19	TRIPPED ON FAULT
1438	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	KHBCOLONY_66	11:14	13:18	02:03	LINE CLEAR AVAILED
1439	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	KIKKERI_66	10:17	12:15	01:57	LINE CLEAR AVAILED
1440	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	KUNTHUR_66	10:11	16:33	06:22	LINE CLEAR AVAILED
1441	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDAGERE_66	13:00	13:20	00:20	LINE CLEAR AVAILED
1442	7-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1443	7-Jun-24	MYSORE	66	TRANSFORMER	HV2	KHBCOLONY_66	13:18	14:02	00:44	LINE CLEAR AVAILED
1444	7-Jun-24	MYSORE	66	TRANSFORMER	HV2	KUNTHUR_66	10:10	16:35	06:25	LINE CLEAR AVAILED
1445	7-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
1446	7-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	06:52	07:08	00:16	TRIPPED ON FAULT
1447	7-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1448	7-Jun-24	MYSORE	66	LINE	KUNTHUR-BANNARIIPP	NO STATIONS EFFECTED	12:01	15:10	03:09	LINE CLEAR AVAILED
1449	7-Jun-24	MYSORE	66	LINE	KUNTHUR-SANTHEMARALLI	KUNTHUR_66	12:00	15:13	03:13	LINE CLEAR AVAILED
1450	7-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1451	7-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	11:51	15:07	03:15	LINE CLEAR AVAILED
1452	7-Jun-24	MYSORE	66	LINE	MUGUR-JANNUR	JANNUR_66	06:53	06:58	00:05	TRIPPED ON FAULT
1453	7-Jun-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPET	NO STATIONS EFFECTED	10:22	15:45	05:23	LINE CLEAR AVAILED
1454	7-Jun-24	MYSORE	220	LINE	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	10:27	16:47	06:20	LINE CLEAR AVAILED
1455	07-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI-66KV BELLAVI LINE	66KV BELLAVI, MALLASANDRA, HEGGERE,DODDASARANGI	07:25	07:30	00:05	TRIPPED ON FAULT
1456	07-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI-66KV CHELUR LINE	66KV CHELUR, HOSAKERE, HAGALAWADI, NANDIHALLI CROSS	16:22	16:29	00:07	TRIPPED ON FAULT
1457	07-Jun-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV HIREGUNTNR	05:48	05:57	00:09	TRIPPED ON FAULT
1458	07-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV HARIHAR HOSPET LINE	66KV HARIHARA NEW MUSS	07:46	07:51	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1459	07-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR, MALEBENNUR,DEVARBELAKE RE	12:27	12:39	00:12	TRIPPED ON FAULT
1460	07-Jun-24	TUMKUR	66	LINE	220KV SIRA-66KV GULIGENAHALLI LINE	66KV GULIGENAHALLI	14:30	14:56	00:26	TRIPPED ON FAULT
1461	07-Jun-24	TUMKUR	66	LINE	220KV SIRA-66KV GULIGENAHALLI LINE	66KV GULIGENAHALLI	18:38	22:10	03:32	LINE CLEAR AVAILED
1462	07-Jun-24	TUMKUR	66	LINE	66KV HANGAL-66KV NAGASAMUDRA LINE	66KV NAGASAMUDRA,RAMPURA	10:40	10:50	00:10	TRIPPED ON FAULT
1463	07-Jun-24	TUMKUR	66	LINE	66KV KODIGENAHALLI-220KV GOWRIBIDANUR LINE	KODIGENAHALLI_66KV	13:05	13:25	00:20	TRIPPED ON FAULT
1464	07-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV BAGUR LINE	-	19:05	19:15	00:10	TRIPPED ON FAULT
1465	07-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV HOLALKERE LINE 1	66KV CHIKKAJAJUR	14:15	14:35	00:20	TRIPPED ON FAULT
1466	07-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR LINE	SOKKE_66	21:30	21:45	00:15	MAIN SUPPLY FAILURE
1467	07-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR LINE	SOKKE_66	23:00	23:15	00:15	MAIN SUPPLY FAILURE
1468	07-Jun-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	10:15	16:40	06:25	LINE CLEAR AVAILED
1469	07-Jun-24	TUMKUR	66	LINE	MAYAKONDA- SASLUHALLA	SASLUHALLA_66	20:50	21:00	00:10	TRIPPED ON FAULT
1470	07-Jun-24	TUMKUR	110	LINE	AMMASANDRA 110- HEIDELBERG CEMENT INDIA LTD	HEIDELBERG CEMENT INDIA LTD_EHT_110	15:30	16:10	00:40	LINE CLEAR AVAILED
1471	07-Jun-24	TUMKUR	110	LINE	NITTUR 220KV- KALLUR	KALLUR_110	11:54	14:44	02:50	LINE CLEAR AVAILED
1472	07-Jun-24	TUMKUR	220	LINE	220KV ANTHARASANAHALLI- 220KV K B CROSS LINE	ANTHRASANAHALLI 220	05:20	06:33	01:13	TRIPPED ON FAULT
1473	07-Jun-24	TUMKUR	220	LINE	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:38	13:48	02:10	LINE CLEAR AVAILED
1474	07-Jun-24	TUMKUR	220	TRANSFORMER	TR-2 (12.5MVA)	MADHUGIRI_220	10:59	11:03	00:04	TRIPPED ON FAULT
1475	07-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- NARENDRA-2	NARENDRA -2 LINE	02:27	07:29	05:02	LINE CLEAR AVAILED
1476	08-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BISNAL_110	23:54 (06.06.2024)			TRIPPED ON FAULT
1477	08-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	LOKAPUR_110	0:35	13:35	13:00	TRIPPED ON FAULT
1478	08-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
1479	08-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR _110	9:09 (10.05.2024)			LINE CLEAR AVAILED
1480	08-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- BHOJ	CHIKKODI_220	11:09	13:40	02:31	LINE CLEAR AVAILED
1481	08-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG1	CHIKKODI_220	10:05	18:40	08:35	LINE CLEAR AVAILED
1482	08-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- RAIBAG2	CHIKKODI_220	11:05	19:40	08:35	LINE CLEAR AVAILED
1483	08-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
1484	08-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1485	08-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	1:18	1:24	00:06	TRIPPED ON FAULT
1486	08-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GOKAK	GHATAPRABHA_220	22:47	22:57	00:10	TRIPPED ON FAULT
1487	08-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
1488	08-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
1489	08-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-KHANAPUR	MK HUBLI_220	10:15	13:05	02:50	LINE CLEAR AVAILED
1490	08-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1491	08-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- BOMMANAL	MUGALKHOD_220	10:14	19:07	08:53	LINE CLEAR AVAILED
1492	08-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1493	08-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1494	08-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1495	08-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1496	08-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1497	08-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1498	08-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1499	08-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- KATARKI	VAJRAMATTI_220	20:14	20:26	00:12	TRIPPED ON FAULT
1500	08-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1501	08-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1502	08-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1503	08-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1504	08-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA 66, EOXRA 66, KALYANI TECH PARK, ORACLE(EHT)	10:30	10:40	00:10	LINE CLEAR AVAILED
1505	08-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA 66, EOXRA 66, KALYANI TECH PARK, ORACLE(EHT)	17:00	17:10	00:10	LINE CLEAR AVAILED
1506	08-Jun-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE	14:18	14:27	00:09	TRIPPED ON FAULT
1507	08-Jun-24	BANGALORE	66	LINE	66KV GOKULA - RMV	RMV, IISc(EHT)	10:19	10:24	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1508	08-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGEHALLI	10:20	14:51	04:31	LINE CLEAR AVAILED
1509	08-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 1	C STATION	10:01	10:05	00:04	LINE CLEAR AVAILED
1510	08-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - C STATION 2	C STATION	10:01	10:05	00:04	LINE CLEAR AVAILED
1511	08-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - RMV	RMV, IISc(EHT)	14:15	14:20	00:05	LINE CLEAR AVAILED
1512	08-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK, RMZ, PRIMAL, CESSNA	14:30	15:06	00:36	TRIPPED ON FAULT
1513	08-Jun-24	BANGALORE	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	21:35	21:50	00:15	LINE CLEAR AVAILED
1514	08-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	10:55	11:10	00:15	LINE CLEAR AVAILED
1515	08-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANUKUNTE	06:01	06:10	00:09	TRIPPED ON FAULT
1516	08-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANUKUNTE	10:55	11:15	00:20	LINE CLEAR AVAILED
1517	08-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	10:12	10:21	00:09	LINE CLEAR AVAILED
1518	08-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	16:30	16:33	00:03	LINE CLEAR AVAILED
1519	08-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	10:05	15:43	05:38	LINE CLEAR AVAILED
1520	08-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - BYADARAHALLI	BYADRAHALLI, SRIGANDAKAVALLU, KODIGEHALLI	17:12	18:30	01:18	TRIPPED ON FAULT
1521	08-Jun-24	BANGALORE	66	LINE	66KV TAVAREKERE - KODIGEHALLI	KODIGEHALLI	18:32	18:37	00:05	LINE CLEAR AVAILED
1522	08-Jun-24	BANGALORE	66	LINE	66KV URAGAHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	12:45	12:50	00:05	MAIN SUPPLY FAILURE
1523	08-Jun-24	BANGALORE	66	LINE	66KV URAGAHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	14:08	14:13	00:05	MAIN SUPPLY FAILURE
1524	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	10:31	10:40	00:09	LINE CLEAR AVAILED
1525	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	17:01	17:08	00:07	LINE CLEAR AVAILED
1526	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	10:31	10:40	00:09	LINE CLEAR AVAILED
1527	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	17:01	17:08	00:07	LINE CLEAR AVAILED
1528	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	10:31	10:40	00:09	LINE CLEAR AVAILED
1529	08-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	17:01	17:08	00:07	LINE CLEAR AVAILED
1530	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	17:50	18:08	00:18	LINE CLEAR AVAILED
1531	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	02:08	02:18	00:10	TRIPPED ON FAULT
1532	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	APPAREL PARK	11:45	12:20	00:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1533	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KIADB DB PURA 220	12:38	12:59	00:21	LINE CLEAR AVAILED
1534	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	02:40	02:53	00:13	TRIPPED ON FAULT
1535	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	THAYALUR	16:35	17:15	00:40	LINE CLEAR AVAILED
1536	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	06:00	06:05	00:05	TRIPPED ON FAULT
1537	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	09:10	10:15	01:05	LINE CLEAR AVAILED
1538	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DOMMASANDRA	10:05	17:05	07:00	LINE CLEAR AVAILED
1539	08-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	10:23	14:03	03:40	LINE CLEAR AVAILED
1540	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	09:35	09:40	00:05	LINE CLEAR AVAILED
1541	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	21:55	22:10	00:15	LINE CLEAR AVAILED
1542	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	03:12	03:21	00:09	TRIPPED ON FAULT
1543	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KIADB DB PURA 220	13:10	13:50	00:40	LINE CLEAR AVAILED
1544	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	H GOLLAHALLI	13:40	13:42	00:02	LINE CLEAR AVAILED
1545	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KUDUR	13:23	13:28	00:05	TRIPPED ON FAULT
1546	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DOMMASANDRA	10:05	15:43	05:38	LINE CLEAR AVAILED
1547	08-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	10:23	14:11	03:48	LINE CLEAR AVAILED
1548	08-Jun-24	BANGALORE	220	TRANSFORMER	HV2	SARJAPURA 220	10:23	14:08	03:45	LINE CLEAR AVAILED
1549	08-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66, GUDDEKOTE_66	05:55	06:15	00:20	TRIPPED ON FAULT
1550	08-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66, GUDDEKOTE_66	09:15	09:35	00:20	TRIPPED ON FAULT
1551	08-Jun-24	GULBARGA	66	LINE	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	13:00	13:10	00:10	TRIPPED ON FAULT
1552	08-Jun-24	GULBARGA	66	LINE	ITTAGI-TB HALLI	TB HALLI_66	09:40	13:35	03:55	LINE CLEAR AVAILED
1553	08-Jun-24	GULBARGA	110	LINE	BALLARI SOUTH-ALLIPUR	BALLARI SOUTH_110, HALAKUNDI_110	05:11	05:58	00:47	MAIN SUPPLY FAILURE
1554	08-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YERADONA_110	20:50	21:00	00:10	MAIN SUPPLY FAILURE
1555	08-Jun-24	GULBARGA	110	TRANSFORMER	HV1	GANGVATHI_110	08:40	08:50	00:10	LINE CLEAR AVAILED
1556	08-Jun-24	GULBARGA	110	TRANSFORMER	HV1	KURUGODU_110	09:35	09:40	00:05	TRIPPED ON FAULT
1557	08-Jun-24	GULBARGA	110	LINE	KAMALNAGAR-DONGARGOAN	DONGARGOAN_110	15:55	16:55	01:00	TRIPPED ON FAULT
1558	08-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	08:52	17:41	08:49	LINE CLEAR AVAILED
1559	08-Jun-24	GULBARGA	110	LINE	KAPNOOR-NORTH2	KALBURGI NORTH_110	23:59	18:55	18:56	LINE CLEAR AVAILED
1560	08-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	04:29	04:39	00:10	TRIPPED ON FAULT
1561	08-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	20:10	20:11	00:01	TRIPPED ON FAULT
1562	08-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	RAILWAY LINE_110	19:35	19:40	00:05	TRIPPED ON FAULT
1563	08-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATI	SANNATI_110	01:00	01:05	00:05	TRIPPED ON FAULT
1564	08-Jun-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	13:41	14:30	00:49	TRIPPED ON FAULT
1565	08-Jun-24	GULBARGA	110	LINE	SHAHAPUR-NAGANOOR	NAGANOOR_110	13:41	14:14	00:33	TRIPPED ON FAULT
1566	08-Jun-24	GULBARGA	110	LINE	SHAHAPUR-SHAHAPUR2	JEWARGI_110	00:17	00:28	00:11	TRIPPED ON FAULT
1567	08-Jun-24	GULBARGA	110	LINE	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110, TURVIHAL_110	22:03	22:13	00:10	TRIPPED ON FAULT
1568	08-Jun-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	23:39	23:49	00:10	TRIPPED ON FAULT
1569	08-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	19:27	19:37	00:10	TRIPPED ON FAULT
1570	08-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	21:32	21:42	00:10	TRIPPED ON FAULT
1571	08-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1572	08-Jun-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	15:20	15:30	00:10	TRIPPED ON FAULT
1573	08-Jun-24	HASSAN	66	LINE	HIREMAN-CHIKAMANGALUR	HIREMANGALUR_66	10:15	17:40	07:25	LINE CLEAR AVOIDED
1574	08-Jun-24	HASSAN	66	LINE	HIREMAN-CKM220	HIREMANGALUR_66	10:15	13:27	03:12	LINE CLEAR AVOIDED
1575	08-Jun-24	HASSAN	66	LINE	HIREMAN-RDL	HIREMANGALUR_66	10:15	13:30	03:15	LINE CLEAR AVOIDED
1576	08-Jun-24	HASSAN	66	LINE	HNPR2-HASS2	HNPUA_220	13:08	13:25	00:17	TRIPPED ON FAULT
1577	08-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPUA_220	05:05	05:45	00:40	TRIPPED ON FAULT
1578	08-Jun-24	HASSAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	10:15	16:45	06:30	LINE CLEAR AVOIDED
1579	08-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	08:00	13:10	05:10	MAIN SUPPLY FAILURE
1580	08-Jun-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	23:22	23:29	00:07	TRIPPED ON FAULT
1581	08-Jun-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	08:00	13:11	05:11	MAIN SUPPLY FAILURE
1582	08-Jun-24	HASSAN	66	LINE	MATTNAV-DIDGTHL	MATTNAVILE_66	03:19	03:29	00:10	TRIPPED ON FAULT
1583	08-Jun-24	HASSAN	110	LINE	BRAHMAV-MANIPAL	BRAHMAVARA_110	09:41	10:35	00:54	TRIPPED ON FAULT
1584	08-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	03:46	03:51	00:05	TRIPPED ON FAULT
1585	08-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	05:59	06:06	00:07	TRIPPED ON FAULT
1586	08-Jun-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	11:40	11:50	00:10	MAIN SUPPLY FAILURE
1587	08-Jun-24	HASSAN	110	TRANSFORMER	HV3	KADUR_220	12:04	12:20	00:16	TRIPPED ON FAULT
1588	08-Jun-24	HASSAN	110	LINE	KADUR-BANVR	KADUR_220	16:38	16:47	00:09	TRIPPED ON FAULT
1589	08-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	10:38	11:42	01:04	MAIN SUPPLY FAILURE
1590	08-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	15:34	17:28	01:54	MAIN SUPPLY FAILURE
1591	08-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:38	11:07	00:29	MAIN SUPPLY FAILURE
1592	08-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	11:12	11:20	00:08	MAIN SUPPLY FAILURE
1593	08-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	15:34	16:08	00:34	MAIN SUPPLY FAILURE
1594	08-Jun-24	HASSAN	110	LINE	MRSSHM-BADRAVATY3	MRSMSG_220	00:13	02:20	02:07	TRIPPED ON FAULT
1595	08-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	10:38	10:57	00:19	TRIPPED ON FAULT
1596	08-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	11:12	11:20	00:08	TRIPPED ON FAULT
1597	08-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	15:35	16:11	00:36	TRIPPED ON FAULT
1598	08-Jun-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	10:38	10:50	00:12	TRIPPED ON FAULT
1599	08-Jun-24	HASSAN	220	LINE	ARSK2-HSN	ARSIKERE_220	15:50	17:20	01:30	TRIPPED ON FAULT
1600	08-Jun-24	HASSAN	220	LINE	GERSOPA-TALGUPA1	gen_gersoppa	21:37(7.06.2024)	14:31(08.06.2024)	16:06HRS	LINE CLEAR AVOIDED
1601	08-Jun-24	HASSAN	220	LINE	GERSOPA-TALGUPA2	gen_gersoppa	20:20	21:18	00:58	TRIPPED ON FAULT
1602	08-Jun-24	HASSAN	220	LINE	HASSN22-Shomoga	HASSAN_220	10:38	17:37	06:59	LINE CLEAR AVOIDED
1603	08-Jun-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	09:49	13:21	03:32	LINE CLEAR AVOIDED
1604	08-Jun-24	HASSAN	220	LINE	MRSSHM-CHMLR	MRSMSG_220	10:39	17:37	06:58	LINE CLEAR AVOIDED
1605	08-Jun-24	HASSAN	220	LINE	MRSSHM-HSN4001	MRSMSG_220	10:41	17:46	07:05	LINE CLEAR AVOIDED
1606	08-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	21:37(7.06.2024)	14:30(08.06.2024)	16:05HRS	LINE CLEAR AVOIDED
1607	08-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	09:49	13:21	03:32	LINE CLEAR AVOIDED
1608	08-Jun-24	HASSAN	220	LINE	VARAHI-SHIMOGA1	gen_varahi	02:26	02:46	00:20	TRIPPED ON FAULT
1609	08-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	03:46	04:09	00:23	TRIPPED ON FAULT
1610	08-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	05:59	06:21	00:22	TRIPPED ON FAULT
1611	8-Jun-24	MYSORE	66	LINE	CHIKAMANDYA-MANDYA	NO STATIONS EFFECTED	08:36	16:12	07:36	LINE CLEAR AVOIDED
1612	8-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1613	8-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVOIDED
1614	8-Jun-24	MYSORE	66	LINE	KADAKOLA-DKMAIDANA	NO STATIONS EFFECTED	13:57	14:01	00:04	TRIPPED ON FAULT
1615	8-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	06:57	07:05	00:07	TRIPPED ON FAULT
1616	8-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVOIDED
1617	8-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1618	8-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	23:59	00:01	00:02	TRIPPED ON FAULT
1619	8-Jun-24	MYSORE	66	LINE	PANYADUNDI -KEREHALLI	NO STATIONS EFFECTED	05:30	05:35	00:05	TRIPPED ON FAULT
1620	8-Jun-24	MYSORE	66	LINE	PANYADUNDI -KEREHALLI	NO STATIONS EFFECTED	19:12	19:19	00:07	TRIPPED ON FAULT
1621	8-Jun-24	MYSORE	66	LINE	TANDYA-ITC	NO STATIONS EFFECTED	08:50	09:10	00:20	TRIPPED ON FAULT
1622	8-Jun-24	MYSORE	66	LINE	TUBINKERE-MANDYA2	MANDYA_66 MADDUR_66	10:06	16:02	05:56	LINE CLEAR AVAILED
1623	8-Jun-24	MYSORE	66	LINE	TUBINKERE-MANDYA4	MANDYA_66 MADDUR_66	10:06	16:03	05:56	LINE CLEAR AVAILED
1624	08-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV B G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIYUR	06:19	06:30	00:11	TRIPPED ON FAULT
1625	08-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV HEBBUR LINE	66KV HEBBUR, HONNENAHALI,THIMMASANDRA	16:11	16:22	00:11	TRIPPED ON FAULT
1626	08-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALI	12:47	16:45	03:58	TRIPPED ON FAULT
1627	08-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALI	17:04	17:49	00:45	TRIPPED ON FAULT
1628	08-Jun-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV HIREGUTNUR,66KV CHITRAHALI, HD PURA,PANDARAHALLI	05:48	05:57	00:09	TRIPPED ON FAULT
1629	08-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR, MALEBENNUR,DEVARBELAKERE	10:14	10:24	00:10	TRIPPED ON FAULT
1630	08-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV B.G KERE LINE-1	66 KV B.G.KERE MUSS, 66 KV RAMPURA MUSS AND 66 KV NAGASAMUDRA MUSS.	03:17	03:29	00:12	TRIPPED ON FAULT
1631	08-Jun-24	TUMKUR	66	LINE	66KV BYRENAHALI-66KV HOLAVANAHALLI LINE	66KV HOLAVANAHALLI	01:38	01:45	00:07	TRIPPED ON FAULT
1632	08-Jun-24	TUMKUR	66	LINE	66KV DEVARAHALLI-66KV SANTHEBENNUR LINE	66KV SANTEBENNURU,KEREBILACHALI	07:30	07:35	00:05	TRIPPED ON FAULT
1633	08-Jun-24	TUMKUR	66	LINE	66KV MATHOD- 220KV HIRIYUR LINE 1	MATHOD_66	03:30	04:30	01:00	TRIPPED ON FAULT
1634	08-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-220KV MADHURE LINE	66KV RAMAGIRI , CHIKKAJAJUR	13:45	13:55	00:10	TRIPPED ON FAULT
1635	08-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-220KV MADHURE LINE	66KV RAMAGIRI , CHIKKAJAJUR	14:10	14:15	00:05	TRIPPED ON FAULT
1636	08-Jun-24	TUMKUR	66	LINE	66KV RAMAGIRI-66KV HOLALKERE LINE 1	66KV CHIKKAJAJUR	13:00	13:10	00:10	TRIPPED ON FAULT
1637	08-Jun-24	TUMKUR	66	LINE	66KV SIRA-66KV KALLAMBELLA LINE	66KV KALLAMBELLA	06:47	07:00	00:13	TRIPPED ON FAULT
1638	08-Jun-24	TUMKUR	66	LINE	66KV TURUVANUR-220KV CHITRADURGA LINE	66KV BIDARKERE.TURUVANUR	08:25	08:49	00:24	TRIPPED ON FAULT
1639	08-Jun-24	TUMKUR	66	LINE	GULIGENAHALLI- SIRA	SIRA_66	11:32	17:50	06:18	LINE CLEAR AVAILED
1640	08-Jun-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALI1	HOLALKERE_66	02:52	03:08	00:16	MAIN SUPPLY FAILURE
1641	08-Jun-24	TUMKUR	66	LINE	RAMAGIRI_66-HOLALKERE_66	HOLALKERE_66, CHIKKAJAJUR_66	14:55	15:25	00:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1642	08-Jun-24	TUMKUR	110	LINE	220KV K B CROSS-110KV HANDANKERE LINE	110KV HANDANKERE HULIYAR	11:40	17:38	05:58	TRIPPED ON FAULT
1643	08-Jun-24	TUMKUR	220	LINE	100MVA TRANSFORMER-1-220KV K B CROSS	110KV SAMPIGE, AMMASANDRA, HULIYAR,HANDANKERE,BAND HIHALLI,KARADI,KEREGODI,TI PTUR,HUNASEGATTA,HALKUR KETURUVEKERE, NONAVINAKERE, THANDAGA, GUNGURMALE,P N HALLI, THIMMANAHALLI,KATHRIKEHAL, HANDANKERE HULIYAR	08:28	09:46	01:18	TRIPPED ON FAULT
1644	08-Jun-24	TUMKUR	220	LINE	100MVA TRANSFORMER-2-220KV K B CROSS		08:28	09:47	01:19	TRIPPED ON FAULT
1645	08-Jun-24	TUMKUR	220	LINE	BENKIKERE 220KV-BENKIKERE	BENKIKERE_66	12:20	12:25	00:05	LINE CLEAR AVAILED
1646	08-Jun-24	TUMKUR	220	LINE	SIRA220-SIRA 1	SIRA_66	11:00	15:20	04:20	LINE CLEAR AVAILED
1647	09-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BISNAL_110	23:54 (06.06.2024)			TRIPPED ON FAULT
1648	09-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
1649	09-Jun-24	BAGALKOTE	110	LINE	AEQUS220-DADDI	AEQUS_220	09:12	17:29	08:17	LINE CLEAR AVAILED
1650	09-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
1651	09-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- KHADAKALAT	CHIKKODI_220	11:10	13:00	01:50	LINE CLEAR AVAILED
1652	09-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
1653	09-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)			LINE CLEAR AVAILED
1654	09-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
1655	09-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
1656	09-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1657	09-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- KULIGOD	MUGALKHOD_220	10:54	17:13	06:19	LINE CLEAR AVAILED
1658	09-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1659	09-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1660	09-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1661	09-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1662	09-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1663	09-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1664	09-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1665	09-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1666	09-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	BELGAUM_220	10:28	12:05	01:37	LINE CLEAR AVAILED
1667	09-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1668	09-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1669	09-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1670	09-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	05:45	06:21	00:36	TRIPPED ON FAULT
1671	09-Jun-24	BANGALORE	66	LINE	66KV CB PURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	18:55	19:00	00:05	LINE CLEAR AVAILED
1672	09-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	05:32	05:40	00:08	TRIPPED ON FAULT
1673	09-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	12:20	12:52	00:32	TRIPPED ON FAULT
1674	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - ACC PLANT	ACC	10:02	17:32	07:30	LINE CLEAR AVAILED
1675	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - ALLIPURA	ALIPURA, THONDEBHAVI	10:02	17:45	07:43	LINE CLEAR AVAILED
1676	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, MANDIKAL, GUDIBANDE	10:02	17:42	07:40	LINE CLEAR AVAILED
1677	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGEHALLI	10:02	17:42	07:40	LINE CLEAR AVAILED
1678	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	10:02	17:42	07:40	LINE CLEAR AVAILED
1679	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - RAMAPURA	RAMAPURA	10:02	17:32	07:30	LINE CLEAR AVAILED
1680	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	10:02	17:32	07:30	LINE CLEAR AVAILED
1681	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VIDHURASHWATHA	VIDHURASHWATHA, GUNDLU KOTTUR	10:02	17:32	07:30	LINE CLEAR AVAILED
1682	09-Jun-24	BANGALORE	66	LINE	66KV GOWRIDIDANUR 220 - KUDUMULAKUNTE	KUDUMULKUNTE, A1 STEEL	10:02	17:32	07:30	LINE CLEAR AVAILED
1683	09-Jun-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	BAGHMANE WTC	13:15	13:20	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1684	09-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	GLOBAL TECH PARK	20:47	20:50	00:03	LINE CLEAR AVAILED
1685	09-Jun-24	BANGALORE	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	11:05	12:10	01:05	LINE CLEAR AVAILED
1686	09-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	14:44	14:54	00:10	TRIPPED ON FAULT
1687	09-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	CHANDRAPPA CIRCLE, DODDERI	10:35	15:40	05:05	LINE CLEAR AVAILED
1688	09-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	10:00	10:05	00:05	LINE CLEAR AVAILED
1689	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	10:00	18:19	08:19	LINE CLEAR AVAILED
1690	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - JULPALYA	JULUPALYA	10:00	18:20	08:20	LINE CLEAR AVAILED
1691	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHPALYA, GULUR, THIMMAMPALLI	10:00	18:24	08:24	LINE CLEAR AVAILED
1692	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SADHALI	SADALI	10:00	16:40	06:40	LINE CLEAR AVAILED
1693	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SADHALI	SADALI	10:00	18:21	08:21	LINE CLEAR AVAILED
1694	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMANATHAPURA	SOMANATHPURA, CHELUR, CHAKAVELU	10:00	18:22	08:22	LINE CLEAR AVAILED
1695	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 1	SOMENAHALLI, PERESANDRA	10:00	18:19	08:19	LINE CLEAR AVAILED
1696	09-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SOMENAHALLI 2	NALLIMARADANAHALLI	10:00	18:24	08:24	LINE CLEAR AVAILED
1697	09-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	13:07	13:22	00:15	TRIPPED ON FAULT
1698	09-Jun-24	BANGALORE	66	LINE	66KV PRESTIGE SHANTHINIKETHAN - DARSHITHA EHT	PRESTIGE SHANTINIKETHAN	07:58	08:01	00:03	LINE CLEAR AVAILED
1699	09-Jun-24	BANGALORE	66	LINE	66KV SOMENAHALLI - NALLIMARADANAHALLI	NALLIMARADANAHALLI	08:30	08:35	00:05	LINE CLEAR AVAILED
1700	09-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOL CROSS	05:22	05:39	00:17	TRIPPED ON FAULT
1701	09-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - THAYALUR	THAYALUT, MN HALLI, NG HULKUR	22:27	22:57	00:30	LINE CLEAR AVAILED
1702	09-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	15:14	15:36	00:22	TRIPPED ON FAULT
1703	09-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 200 - SURYA CITY	SURYANAGARA	21:15	21:25	00:10	LINE CLEAR AVAILED
1704	09-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	21:15	21:25	00:10	LINE CLEAR AVAILED
1705	09-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA	21:15	21:25	00:10	LINE CLEAR AVAILED
1706	09-Jun-24	BANGALORE	66	LINE	GOWRIBIDANUR 220 - AFTL	AFTL	10:02	17:32	07:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1707	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	08:01	08:03	00:02	LINE CLEAR AVAILED
1708	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	12:20	12:25	00:05	TRIPPED ON FAULT
1709	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SADALI	09:45	10:00	00:15	LINE CLEAR AVAILED
1710	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWRIBIDANUR 220	10:02	17:32	07:30	LINE CLEAR AVAILED
1711	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANGLI	13:30	13:43	00:13	TRIPPED ON FAULT
1712	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KGF	17:20	17:40	00:20	TRIPPED ON FAULT
1713	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	11:45	11:50	00:05	TRIPPED ON FAULT
1714	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	12:35	12:45	00:10	TRIPPED ON FAULT
1715	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	AGALAKOTE	21:58	22:03	00:05	TRIPPED ON FAULT
1716	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SANKALGERE	15:50	16:00	00:10	TRIPPED ON FAULT
1717	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BOMMASANDRA I/A	10:40	10:45	00:05	LINE CLEAR AVAILED
1718	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHANDAPURA	12:40	12:50	00:10	LINE CLEAR AVAILED
1719	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 220	06:22	06:29	00:07	LINE CLEAR AVAILED
1720	09-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	21:01	21:04	00:03	LINE CLEAR AVAILED
1721	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PLATINUM CITY	09:35	13:50	04:15	LINE CLEAR AVAILED
1722	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KADUGODI	22:37	22:47	00:10	TRIPPED ON FAULT
1723	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KADUGODI	22:47	22:57	00:10	LINE CLEAR AVAILED
1724	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	08:40	09:20	00:40	LINE CLEAR AVAILED
1725	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PILLAGUPPA	17:19	17:30	00:11	TRIPPED ON FAULT
1726	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	10:02	17:32	07:30	LINE CLEAR AVAILED
1727	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KYALANUR	14:40	15:00	00:20	TRIPPED ON FAULT
1728	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MALLASANDRA	14:55	15:15	00:20	TRIPPED ON FAULT
1729	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SUGATUR	11:50	12:00	00:10	TRIPPED ON FAULT
1730	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	18:43	18:57	00:14	TRIPPED ON FAULT
1731	09-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	21:15	21:25	00:10	LINE CLEAR AVAILED
1732	09-Jun-24	BANGALORE	66	LINE	KUDUMULKUNTE - A1 STEEL(EHT)	A1 STEEL(EHT)	18:32	19:19	00:47	TRIPPED ON FAULT
1733	09-Jun-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	10:00	18:05	08:05	LINE CLEAR AVAILED
1734	09-Jun-24	BANGALORE	220	LINE	220KV GOWRIBIDANUR 220 - MITTEMARI 2	MITTEMARI 220	10:00	18:05	08:05	LINE CLEAR AVAILED
1735	09-Jun-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - MAGADI CKT 2	NO STATION AFFECTED	13:06	17:02	03:56	TRIPPED ON FAULT
1736	09-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	NO STATION AFFECTED	14:49	16:29	01:40	TRIPPED ON FAULT
1737	09-Jun-24	BANGALORE	220	TRANSFORMER	HV1	GOWRIBIDANUR 220	10:04	17:20	07:16	LINE CLEAR AVAILED
1738	09-Jun-24	BANGALORE	220	TRANSFORMER	HV1	MITTEMARI 220	09:40	18:16	08:36	LINE CLEAR AVAILED
1739	09-Jun-24	BANGALORE	220	TRANSFORMER	HV2	GOWRIBIDANUR 220	10:04	17:20	07:16	LINE CLEAR AVAILED
1740	09-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MITTEMARI 220	10:00	18:17	08:17	LINE CLEAR AVAILED
1741	09-Jun-24	BANGALORE	220	TRANSFORMER	HV3	GOWRIBIDANUR 220	10:04	17:20	07:16	LINE CLEAR AVAILED
1742	09-Jun-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	21:15	21:25	00:10	LINE CLEAR AVAILED
1743	09-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66, GUDDEKOTE_66	13:49	14:27	00:38	LINE CLEAR AVAILED
1744	09-Jun-24	GULBARGA	66	LINE	CJHALLI-ITTAGGI	CJ_HALLI_66,HOSAHALLI_66,H UDEM_66, GUDDEKOTE_66	15:08	15:20	00:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1745	09-Jun-24	GULBARGA	66	LINE	ITTAGI-BENNEHALLI	BENNEHALLI_66, UJJINI_66, KOTTUR_66	18:55	18:59	00:04	TRIPPED ON FAULT
1746	09-Jun-24	GULBARGA	110	LINE	ALLIPUR-SOUTH	SOUTH_110, HALKUNDI_110, MOKA_110, BISILAHALLI_110, P D HALLI_110	21:55	22:07	00:12	TRIPPED ON FAULT
1747	09-Jun-24	GULBARGA	110	TRANSFORMER	HV2	SHAHAPUR_110	12:05	13:21	01:16	LINE CLEAR AVAILED
1748	09-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-GANADAL	GANADAL_110	14:10	14:30	00:20	TRIPPED ON FAULT
1749	09-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-SULEKAL	KANAKAGIRI_110,NAVALI_110	10:55	13:10	02:15	LINE CLEAR AVAILED
1750	09-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	03:47	04:00	00:13	TRIPPED ON FAULT
1751	09-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATI	SANNATI_110	02:15	02:25	00:10	TRIPPED ON FAULT
1752	09-Jun-24	GULBARGA	110	LINE	PDHALLI-ALIPUR	PD_HALLI_110	21:55	22:12	00:17	MAIN SUPPLY FAILURE
1753	09-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110	21:18	21:23	00:05	TRIPPED ON FAULT
1754	09-Jun-24	GULBARGA	110	LINE	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	23:19	23:27	00:08	TRIPPED ON FAULT
1755	09-Jun-24	GULBARGA	110	LINE	SHAHAPUR-NAGANOOR	NAGANOOR_110	20:22	20:30	00:08	TRIPPED ON FAULT
1756	09-Jun-24	GULBARGA	110	LINE	SHAHAPUR-NAGANOOR	NAGANOOR_110	21:02	21:16	00:14	TRIPPED ON FAULT
1757	09-Jun-24	GULBARGA	110	LINE	SHAHAPUR-RAICHUR2	SHAHAPUR_110	05:52	06:18	00:26	TRIPPED ON FAULT
1758	09-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MARALIHALLA_110, MUKUNDA_110	01:40	01:50	00:10	TRIPPED ON FAULT
1759	09-Jun-24	GULBARGA	110	LINE	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	04:55	05:05	00:10	TRIPPED ON FAULT
1760	09-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON_IPP	SINDHANOOR_220	00:46	00:56	00:10	TRIPPED ON FAULT
1761	09-Jun-24	GULBARGA	110	LINE	SIRIGERICROSS-ALIPUR	SIRIGERICROSS_110	04:44	05:01	00:17	MAIN SUPPLY FAILURE
1762	09-Jun-24	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	22:01	23:40	01:39	TRIPPED ON FAULT
1763	09-Jun-24	GULBARGA	220	TRANSFORMER	HV1	RAICHUR_220	22:01	23:40	01:39	TRIPPED ON FAULT
1764	09-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1765	09-Jun-24	GULBARGA	220	LINE	SHAHAPUR-RTPS2	SHAHAPUR_220	21:33	22:07	00:34	TRIPPED ON FAULT
1766	09-Jun-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	11:52	12:02	00:10	TRIPPED ON FAULT
1767	09-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	05:34	05:44	00:10	TRIPPED ON FAULT
1768	09-Jun-24	HASSAN	66	TRANSFORMER	HV1	HANUBALu_66	13:25	13:42	00:17	TRIPPED ON FAULT
1769	09-Jun-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	10:24	12:24	02:00	LINE CLEAR AVAILED
1770	09-Jun-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	10:24	12:24	02:00	LINE CLEAR AVAILED
1771	09-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	12:40	19:30	06:50	TRIPPED ON FAULT
1772	09-Jun-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	10:24	12:24	02:00	LINE CLEAR AVAILED
1773	09-Jun-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAME_66	10:24	12:24	02:00	LINE CLEAR AVAILED
1774	09-Jun-24	HASSAN	66	LINE	UDDURKO-CHIKMANGLUR	UDDURKOPPLU_66	10:25	12:25	02:00	LINE CLEAR AVAILED
1775	09-Jun-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	10:00	13:36	03:36	LINE CLEAR AVAILED
1776	09-Jun-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADI_110	10:00	13:35	03:35	MAIN SUPPLY FAILURE
1777	09-Jun-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADI_110	10:00	13:35	03:35	MAIN SUPPLY FAILURE
1778	09-Jun-24	HASSAN	110	TRANSFORMER	HV3	BAIKAMPADI_110	10:00	13:35	03:35	MAIN SUPPLY FAILURE
1779	09-Jun-24	HASSAN	110	TRANSFORMER	HV3	GURUVAYANKERE_110	12:23	13:04	00:41	TRIPPED ON FAULT
1780	09-Jun-24	HASSAN	110	TRANSFORMER	HV4	BAIKAMPADI_110	10:00	13:35	03:35	MAIN SUPPLY FAILURE
1781	09-Jun-24	HASSAN	110	LINE	KAVOOR-BAIKAMPADI	KAVOOR_220	10:01	13:36	03:35	LINE CLEAR AVAILED
1782	09-Jun-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	06:37	12:50	06:13	LINE CLEAR AVAILED
1783	09-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	21:22(9.06.2024)			TRIPPED ON FAULT
1784	09-Jun-24	HASSAN	220	LINE	CRPATNA-HUYGNH	CRPATNA_220	13:45	14:20	00:35	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1785	09-Jun-24	HASSAN	220	LINE	GERSOPA-TALGUPA1	gen_GERSOPPA	07:18	11:13	03:55	TRIPPED ON FAULT
1786	09-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	07:18	11:13	03:55	TRIPPED ON FAULT
1787	9-Jun-24	MYSORE	66	LINE	G UKKADA-PANDAVAPURA	NO STATIONS EFFECTED	09:42	13:51	04:09	LINE CLEAR AVAIED
1788	9-Jun-24	MYSORE	66	LINE	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	05:37	05:55	00:17	TRIPPED ON FAULT
1789	9-Jun-24	MYSORE	66	LINE	HEBBAL-METAGALLY	NO STATIONS EFFECTED	10:05	13:33	03:27	LINE CLEAR AVAIED
1790	9-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1791	9-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAIED
1792	9-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAIED
1793	9-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	13:29	13:36	00:06	TRIPPED ON FAULT
1794	9-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1795	9-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-KOPPA	NO STATIONS EFFECTED	07:36	07:45	00:09	TRIPPED ON FAULT
1796	9-Jun-24	MYSORE	220	LINE	KR PETE 220-YACHANAHALLI	NO STATIONS EFFECTED	13:45	14:20	00:34	TRIPPED ON FAULT
1797	9-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA-2	NO STATIONS EFFECTED	13:04 (09/06/2024)			TRIPPED ON FAULT
1798	09-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALLI	09:33	15:32	05:59	TRIPPED ON FAULT
1799	09-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	MELKOTE_66, BADDIHALLI_66	15:36	18:30	02:54	TRIPPED ON FAULT
1800	09-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV NALLUR, BASAVAPATNA,TYAVANGI	13:32	13:42	00:10	TRIPPED ON FAULT
1801	09-Jun-24	TUMKUR	66	LINE	220KV MADHUGIRI-66KV PULAMGHATTA LINE	66KV PULAMGHATTA	05:29	06:48	01:19	TRIPPED ON FAULT
1802	09-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	16:45	16:50	00:05	TRIPPED ON FAULT
1803	09-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	18:35	18:45	00:10	TRIPPED ON FAULT
1804	09-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	18:45	19:10	00:25	TRIPPED ON FAULT
1805	09-Jun-24	TUMKUR	66	LINE	66KV SOKKE-66KV JAGALUR LINE	SOKKE_66	05:30	05:40	00:10	TRIPPED ON FAULT
1806	09-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(12.5MVA)	ANCHEPALYA_66	16:20	17:00	00:40	LINE CLEAR AVAIED
1807	09-Jun-24	TUMKUR	220	LINE	100MVA TRANSFORMER-1-220KV MADHUGIRI	66KV KORATAGERE, PULAMGHATTA, THUMBADI, SANKENAHALLI	05:29	06:06	00:37	TRIPPED ON FAULT
1808	09-Jun-24	TUMKUR	220	LINE	220KV ANCHEPALYA-220KV NAGAMANGALA LINE 2	ANCHEPALYA_220	13:05	Line not yet be Charged		TRIPPED ON FAULT
1809	09-Jun-24	TUMKUR	220	LINE	220KV BENKIKERE-220KV HONNALI LINE 1	BENKIKERE_220	21:49	22:19	00:30	TRIPPED ON FAULT
1810	09-Jun-24	TUMKUR	220	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	12:35	12:41	00:06	LINE CLEAR AVAIED
1811	09-Jun-24	TUMKUR	220	LINE	THALLAK 220KV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	12:51	13:00	00:09	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1812	10-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BISNAL_110	23:54 (06.06.2024)			TRIPPED ON FAULT
1813	10-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	NAVANAGAR(B)_110	18:30	20:00	01:30	LINE CLEAR AVAILED
1814	10-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
1815	10-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220-NK1(HALIYAL)	AMBEWADI_220	08:03	15:38	07:35	TRIPPED ON FAULT
1816	10-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2(KAVALWADA)	AMBEWADI_220	10:01 (10.06.2024)			LINE CLEAR AVAILED
1817	10-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
1818	10-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- KANABARGI LAYOUT	BELGAUM_220	12:28	13:31	01:03	LINE CLEAR AVAILED
1819	10-Jun-24	BAGALKOTE	110	LINE	CHIMMAD- TERDAL	CHIMMAD_110	19:54 (03.06.2024)			TRIPPED ON FAULT
1820	10-Jun-24	BAGALKOTE	110	LINE	DAVALESH-110KVI/CMAHALIN (LIN1 MPUR)	STATION NOT AFFECTED DAVALESHWAR_110	10:12 (10.05.2025)	10:05 (10.06.2024)	744:04:00	LINE CLEAR AVAILED
1821	10-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
1822	10-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
1823	10-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1824	10-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- NAGNUR	MUGALKHOD_220	00:27	00:37	00:10	TRIPPED ON FAULT
1825	10-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- PG HUNSHYAL	MUGALKHOD_220	09:48	09:59	00:11	TRIPPED ON FAULT
1826	10-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1827	10-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220-TUMMINKATTE	RANEBENNUR_220	10:44	18:10	07:26	LINE CLEAR AVAILED
1828	10-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1829	10-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1830	10-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1831	10-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1832	10-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1833	10-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1834	10-Jun-24	BAGALKOTE	110	LINE	UGARKHUD- KAGWAD	UGARKHUD_110	20:45	21:00	00:15	TRIPPED ON FAULT
1835	10-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1836	10-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	GADAG_220	11:01	15:26	04:25	LINE CLEAR AVAILED
1837	10-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KARWAR_220	10:22	11:30	01:08	LINE CLEAR AVAILED
1838	10-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	11:33	12:12	00:39	LINE CLEAR AVAILED
1839	10-Jun-24	BAGALKOTE	220	LINE	GADAG-DHONI1	GADAG_220	20:16 (10.06.2024)			TRIPPED ON FAULT
1840	10-Jun-24	BAGALKOTE	220	LINE	GADAG-DHONI2	GADAG_220	20:15 (10.06.2024)			TRIPPED ON FAULT
1841	10-Jun-24	BAGALKOTE	220	LINE	KARWAR- KADRA2	KARWAR_220	12:42	13:55	01:13	LINE CLEAR AVAILED
1842	10-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1843	10-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1844	10-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1845	10-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJ PURA 220	GRINDWELL(EHT)	14:56	16:02	01:06	TRIPPED ON FAULT
1846	10-Jun-24	BANGALORE	66	LINE	66KV HSR 220 - ADUGODI	NO STATION AFFECTED	17:20	19:25	02:05	TRIPPED ON FAULT
1847	10-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	GLOBAL TECH PARK	20:22	20:25	00:03	LINE CLEAR AVAILED
1848	10-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, ANNABEL(DLF), SAUDELA	14:10	14:47	00:37	LINE CLEAR AVAILED
1849	10-Jun-24	BANGALORE	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	09:23	09:50	00:27	LINE CLEAR AVAILED
1850	10-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	08:30	09:15	00:45	LINE CLEAR AVAILED
1851	10-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66	12:52	13:03	00:11	TRIPPED ON FAULT
1852	10-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	12:51	13:17	00:26	TRIPPED ON FAULT
1853	10-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE	06:17	06:27	00:10	LINE CLEAR AVAILED
1854	10-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	INFOSYS, ELECTRONIC CITY, HULIMANGALA	07:56	08:02	00:06	LINE CLEAR AVAILED
1855	10-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYANAGARA, ATTIBELE	06:17	06:27	00:10	LINE CLEAR AVAILED
1856	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BTM 4TH PHASE	10:15	14:55	04:40	LINE CLEAR AVAILED
1857	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	RAJANUKUNTE	10:00	17:10	07:10	LINE CLEAR AVAILED
1858	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	16:20	16:25	00:05	LINE CLEAR AVAILED
1859	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	01:45	01:56	00:11	TRIPPED ON FAULT
1860	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	14:12	14:15	00:03	LINE CLEAR AVAILED
1861	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	23:27	23:46	00:19	TRIPPED ON FAULT
1862	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BRIGADE ORCHIDS	16:51	17:14	00:23	TRIPPED ON FAULT
1863	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DEVANAHALLI 66	12:08	12:18	00:10	LINE CLEAR AVAILED
1864	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHELUR	10:45	10:55	00:10	TRIPPED ON FAULT
1865	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DALASANUR	12:00	13:00	01:00	LINE CLEAR AVAILED
1866	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	13:40	13:50	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1867	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BOMMASANDRA I/A	18:40	19:15	00:35	LINE CLEAR AVAIED
1868	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	01:18	01:30	00:12	TRIPPED ON FAULT
1869	10-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	06:39	06:44	00:05	LINE CLEAR AVAIED
1870	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PRESTIGE SHANTINIKETHAN	10:46	11:03	00:17	TRIPPED ON FAULT
1871	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BTM 4TH PHASE	10:15	14:55	04:40	LINE CLEAR AVAIED
1872	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	RAJANUKUNTE	10:00	17:10	07:10	LINE CLEAR AVAIED
1873	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DIBBURAHALLI	14:45	14:50	00:05	LINE CLEAR AVAIED
1874	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	11:38	11:45	00:07	TRIPPED ON FAULT
1875	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	13:02	13:10	00:08	TRIPPED ON FAULT
1876	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GUNDLU KOTTUR	10:20	10:22	00:02	LINE CLEAR AVAIED
1877	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DALASANUR	13:05	13:30	00:25	LINE CLEAR AVAIED
1878	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR	10:23	10:50	00:27	TRIPPED ON FAULT
1879	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR	12:00	12:55	00:55	LINE CLEAR AVAIED
1880	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANAKAPURA 66	12:37	12:45	00:08	TRIPPED ON FAULT
1881	10-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	06:17	06:27	00:10	LINE CLEAR AVAIED
1882	10-Jun-24	GULBARGA	66	LINE	TELGI-NEELGUNDA	TELGI_66, KURUBANAHALLI_66, OBJ HALLI_66	04:55	05:15	00:20	TRIPPED ON FAULT
1883	10-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-MADLAPUR	ADAVIAMARESHWAR_110	12:06	12:20	00:14	MAIN SUPPLY FAILURE
1884	10-Jun-24	GULBARGA	110	LINE	BISILHALLI-NORTH	BISILAHALLI_110, MOKA_110, HALAKUNDI_110	21:57	22:22	00:25	TRIPPED ON FAULT
1885	10-Jun-24	GULBARGA	110	LINE	DEVAPUR-SHORAPUR	DEVAPUR_110	04:52	05:02	00:10	TRIPPED ON FAULT
1886	10-Jun-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110, GUGAL_110	01:15	01:20	00:05	TRIPPED ON FAULT
1887	10-Jun-24	GULBARGA	110	LINE	HANUMASAGAR-HIREGONNAGAR	HIREGONNAGAR_110	04:30	05:44	01:14	MAIN SUPPLY FAILURE
1888	10-Jun-24	GULBARGA	110	LINE	HANUMASAGAR-HIREGONNAGAR	HIREGONNAGAR_110	10:41	10:54	00:13	MAIN SUPPLY FAILURE
1889	10-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-KEMBHAVI	KEMBHAVI_110	03:15	03:24	00:09	TRIPPED ON FAULT
1890	10-Jun-24	GULBARGA	110	TRANSFORMER	HV2	KALBURGI SOUTH_110	15:00	17:30	02:30	LINE CLEAR AVAIED
1891	10-Jun-24	GULBARGA	110	TRANSFORMER	HV3	KALBURGI SOUTH_110	15:00	17:30	02:30	LINE CLEAR AVAIED
1892	10-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110, RUDRAWADI_110	03:47	04:00	00:13	TRIPPED ON FAULT
1893	10-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGON NAGAR_110	04:32	05:40	01:08	TRIPPED ON FAULT
1894	10-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGON NAGAR_110	05:40	10:33	04:53	LINE CLEAR AVAIED
1895	10-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGON NAGAR_110	04:30	05:40	01:10	TRIPPED ON FAULT
1896	10-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	03:27	04:22	00:55	TRIPPED ON FAULT
1897	10-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	00:26	00:36	00:10	TRIPPED ON FAULT
1898	10-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	03:30	03:35	00:05	TRIPPED ON FAULT
1899	10-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	00:25	00:35	00:10	TRIPPED ON FAULT
1900	10-Jun-24	GULBARGA	220	LINE	HATTIGUGUDUR-RTPS2	HATTIGUDUR_220	03:02	03:18	00:16	TRIPPED ON FAULT
1901	10-Jun-24	GULBARGA	220	TRANSFORMER	HV1	HALVARTHI_220	10:50	14:12	03:22	LINE CLEAR AVAIED
1902	10-Jun-24	GULBARGA	220	LINE	KAPNOOR-SHAHABAD	KAPNOOR_220	12:30	15:18	02:48	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1903	10-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
1904	10-Jun-24	HASSAN	66	LINE	HARIHAR-KADUVINKOTE	HARIHARPURA_66	16:00	16:05	00:05	MAIN SUPPLY FAILURE
1905	10-Jun-24	HASSAN	66	TRANSFORMER	HV1	HARIHARPURA_66	16:00	16:05	00:05	MAIN SUPPLY FAILURE
1906	10-Jun-24	HASSAN	66	LINE	UGANE-L2 CB	UGANE_66	05:56	06:15	00:19	MAIN SUPPLY FAILURE
1907	10-Jun-24	HASSAN	110	LINE	BRAHMAV-MANIPAL	BRAHMAVARA_110	15:18	16:40	01:22	TRIPPED ON FAULT
1908	10-Jun-24	HASSAN	110	LINE	BRAHMAV-NITTUR	BRAHMAVARA_110	15:18	18:55	03:37	TRIPPED ON FAULT
1909	10-Jun-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	09:07	09:12	00:05	LINE CLEAR AVAILED
1910	10-Jun-24	HASSAN	110	TRANSFORMER	HV2	KUNDAPURA_110	10:19	11:14	00:55	TRIPPED ON FAULT
1911	10-Jun-24	HASSAN	110	TRANSFORMER	HV5	MRSMSG_220	09:19	15:18	05:59	LINE CLEAR AVAILED
1912	10-Jun-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	16:32	16:46	00:14	TRIPPED ON FAULT
1913	10-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	21:22(9.06.2024)	11:28(10.06.2024)	14:06HRS	LINE CLEAR AVAILED
1914	10-Jun-24	HASSAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	16:34	16:37	00:03	LINE CLEAR AVAILED
1915	10-Jun-24	HASSAN	110	LINE	NANDIKU-BELAPU	NANDIKUR_110	11:59	12:16	00:17	TRIPPED ON FAULT
1916	10-Jun-24	HASSAN	110	LINE	NANDIKU-BELAPU	NANDIKUR_110	12:16	13:57	01:41	LINE CLEAR AVAILED
1917	10-Jun-24	HASSAN	110	LINE	NANDIKU-BELMAN	NANDIKUR_110	16:32	16:49	00:17	TRIPPED ON FAULT
1918	10-Jun-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR 1	NO STATIONS EFFECTED	23:09	23:24	00:15	TRIPPED ON FAULT
1919	10-Jun-24	MYSORE	66	LINE	HUNSUR-ILAWALA	ELAWALA_66	23:09	23:24	00:15	TRIPPED ON FAULT
1920	10-Jun-24	MYSORE	66	TRANSFORMER	HV1	CHINKURALI_66	11:50	12:10	00:20	LINE CLEAR AVAILED
1921	10-Jun-24	MYSORE	66	TRANSFORMER	HV1	JAIPUR_66	12:50	15:06	02:16	TRIPPED ON FAULT
1922	10-Jun-24	MYSORE	66	TRANSFORMER	HV1	JAIPUR_66	16:55	17:36	00:40	LINE CLEAR AVAILED
1923	10-Jun-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	08:13	11:53	03:40	LINE CLEAR AVAILED
1924	10-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
1925	10-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
1926	10-Jun-24	MYSORE	66	LINE	JAKKANAHALLI-NAGMANGLA	NO STATIONS EFFECTED	17:25	21:15	03:50	TRIPPED ON FAULT
1927	10-Jun-24	MYSORE	66	LINE	JAKKANAHALLI-TUBINKRE	GMALLIGERE_66 MAHADESHWARAPURA_66 GAMANAHALLI_66	17:40	17:50	00:09	TRIPPED ON FAULT
1928	10-Jun-24	MYSORE	66	LINE	KHBSTN-BILIKERE	DMGHALLI_66	05:45	05:57	00:11	TRIPPED ON FAULT
1929	10-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
1930	10-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
1931	10-Jun-24	MYSORE	66	LINE	VAJMANGALA-KADKOLA1	AYRALLI_66MARADIHUNDI_66	05:28	05:35	00:07	TRIPPED ON FAULT
1932	10-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	16:42	19:18	02:36	TRIPPED ON FAULT
1933	10-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA-2	NO STATIONS EFFECTED	13:04 (09/06/2024)	16:42 (10/06/2024)	27:38 HRs	TRIPPED ON FAULT
1934	10-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	MELKOTE_66, BADDIHALLI_66	11:30	Line not yet be Charged		TRIPPED ON FAULT
1935	10-Jun-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV CHANNAGIRI LINE	66KV CHANNAGIRI	15:03	15:29	00:26	TRIPPED ON FAULT
1936	10-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA, SASALUHALLA, CHIKKAJAJUR	14:42	14:49	00:07	TRIPPED ON FAULT
1937	10-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV NALLUR, BASAVAPATNA,TYAVANGI	16:25	16:35	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1938	10-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	22:55	23:05	00:10	TRIPPED ON FAULT
1939	10-Jun-24	TUMKUR	66	LINE	66KV ANCHEPALYA-66KV BHAKTHARAHALLI LINE	66/11 KV BHAKTHARAHALLI	09:40	12:10	02:30	MAIN SUPPLY FAILURE
1940	10-Jun-24	TUMKUR	66	LINE	66KV KURUBARAHALLI-66KV TELGI LINE 2	66KV KURUBARAHALLI,IPP SHAMANUR SUGARS	04:55	05:15	00:20	MAIN SUPPLY FAILURE
1941	10-Jun-24	TUMKUR	66	LINE	66KV TURUVANUR-220KV CHITRADURGA LINE	66KV TURUVANUR	13:03	13:19	00:16	TRIPPED ON FAULT
1942	10-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- HEBBUR	HEBBUR_66, HONNENAHALLI,_66 THIMMASANDRA_66	09:40	15:25	05:45	LINE CLEAR AVAILED
1943	10-Jun-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	10:00	17:16	07:16	LINE CLEAR AVAILED
1944	10-Jun-24	TUMKUR	66	LINE	THALLAK 220KV-GOWRASAMUDRA	GOWRASAMUDRA,KONANSAGARA	10:06	13:26	03:20	LINE CLEAR AVAILED
1945	10-Jun-24	TUMKUR	220	TRANSFORMER	100MVA TRANSFORMER-1 LV SIDE	ANCHEPALYA_220	09:38	09:52	00:14	TRIPPED ON FAULT
1946	10-Jun-24	TUMKUR	220	LINE	100MVA TRANSFORMER-1 MV SIDE	GUTTUR_220	09:57	10:42	00:45	TRIPPED ON FAULT
1947	10-Jun-24	TUMKUR	220	LINE	220KV ANCHEPALYA-220KV NAGAMANGALA LINE 2	ANCHEPALYA_220	13:05 (09.06.2024)	19:22 (10.06.2024)	1 Day 6Hrs 17Min	TRIPPED ON FAULT
1948	10-Jun-24	TUMKUR	220	LINE	220KV HONNALI-220KV BENKIKERE LINE 2	BENKIKERE_220	00:26	08:20	07:54	TRIPPED ON FAULT
1949	11-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BISNAL_110	23:54 (06.06.2024)	16:26 (11.06.2024)		TRIPPED ON FAULT
1950	11-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2	RAIBAG_110	08:50	11:17	02:27	TRIPPED ON FAULT
1951	11-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2	RAIBAG_110	11:34	11:58	00:24	LINE CLEAR AVAILED
1952	11-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2	RAIBAG_110	12:15	12:48	00:33	LINE CLEAR AVAILED
1953	11-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
1954	11-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220-NK2(KAVALWADA)	AMBEWADI_220	10:01 (10.06.2024)	14:07 (11.06.2024)		LINE CLEAR AVAILED
1955	11-Jun-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	10:04	17:30	07:26	LINE CLEAR AVAILED
1956	11-Jun-24	BAGALKOTE	110	LINE	ATHANI220- GHATANATTI	ATHANI_220	00:10	00:17	00:07	TRIPPED ON FAULT
1957	11-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
1958	11-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- NEHRU NAGAR	BELGAUM_220	12:05	13:04	00:59	LINE CLEAR AVAILED
1959	11-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
1960	11-Jun-24	BAGALKOTE	110	LINE	KUDACHI220-HARUGERI	KUDACHI_220	04:20	04:37	00:17	TRIPPED ON FAULT
1961	11-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
1962	11-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1963	11-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- HALLUR	MUGALKHOD_220	10:14	16:40	06:26	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1964	11-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
1965	11-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
1966	11-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
1967	11-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
1968	11-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
1969	11-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
1970	11-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
1971	11-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
1972	11-Jun-24	BAGALKOTE	220	LINE	CHIKKODI-KANAGALA	220KV CHIKODI	10:35	12:20	01:45	LINE CLEAR AVAILED
1973	11-Jun-24	BAGALKOTE	220	LINE	GADAG-DHONI1	GADAG_220	20:16 (10.06.2024)			TRIPPED ON FAULT
1974	11-Jun-24	BAGALKOTE	220	LINE	GADAG-DHONI2	GADAG_220	20:15 (10.06.2024)			TRIPPED ON FAULT
1975	11-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1976	11-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)			LINE CLEAR AVAILED
1977	11-Jun-24	BAGALKOTE	220	LINE	SHIGGOAN- NARENDRA	SHIGGOAN_220	12:23	14:37	02:14	LINE CLEAR AVAILED
1978	11-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
1979	11-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI	DEVARABISANAHALLI, GLOBAL TECH PARK	10:11	10:15	00:04	LINE CLEAR AVAILED
1980	11-Jun-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	10:00	16:30	06:30	LINE CLEAR AVAILED
1981	11-Jun-24	BANGALORE	66	LINE	66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	KACHAMARANAHALLI	10:44	10:56	00:12	TRIPPED ON FAULT
1982	11-Jun-24	BANGALORE	66	LINE	66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION)	KACHAMARANAHALLI	14:30	14:35	00:05	LINE CLEAR AVAILED
1983	11-Jun-24	BANGALORE	66	LINE	66KV HENNUR (GEDDALAHALLI) - PURAVANKARA PALM BEACH	PURAVANKARA PALM BEACH	13:09	14:30	01:21	LINE CLEAR AVAILED
1984	11-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:29	15:42	00:13	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
1985	11-Jun-24	BANGALORE	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	ARMY WELFARE HOUSING ORGANISATION	10:33	10:45	00:12	TRIPPED ON FAULT
1986	11-Jun-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST	10:44	10:48	00:04	LINE CLEAR AVAILED
1987	11-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA	10:15	10:27	00:12	LINE CLEAR AVAILED
1988	11-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	19:27	19:37	00:10	LINE CLEAR AVAILED
1989	11-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SASLU	19:03	19:27	00:24	TRIPPED ON FAULT
1990	11-Jun-24	BANGALORE	66	LINE	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	SUGUTUR, PGCIL	10:15	10:26	00:11	LINE CLEAR AVAILED
1991	11-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	08:45	09:01	00:16	TRIPPED ON FAULT
1992	11-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	YEDAMADU, HANUMANTHNAGARA	13:53	14:18	00:25	TRIPPED ON FAULT
1993	11-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML	18:59	19:26	00:27	TRIPPED ON FAULT
1994	11-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	18:59	19:25	00:26	TRIPPED ON FAULT
1995	11-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	11:49	11:56	00:07	LINE CLEAR AVAILED
1996	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PURAVANKARA PALM BEACH	12:15	17:55	05:40	LINE CLEAR AVAILED
1997	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	14:05	14:15	00:10	LINE CLEAR AVAILED
1998	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	17:36	17:59	00:23	LINE CLEAR AVAILED
1999	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	10:12	10:25	00:13	TRIPPED ON FAULT
2000	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BAGEPALLI	16:20	16:35	00:15	TRIPPED ON FAULT
2001	11-Jun-24	BANGALORE	66	TRANSFORMER	HV1	TEKAL	11:00	12:53	01:53	LINE CLEAR AVAILED
2002	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	PURAVANKARA PALM BEACH	11:06	12:25	01:19	LINE CLEAR AVAILED
2003	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GANJIGUNTE	10:18	18:23	08:05	TRIPPED ON FAULT
2004	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DALASANUR	01:35	01:45	00:10	TRIPPED ON FAULT
2005	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	10:22	10:33	00:11	LINE CLEAR AVAILED
2006	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SUGUTUR	03:00	03:20	00:20	TRIPPED ON FAULT
2007	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VR DODDI	13:45	13:50	00:05	TRIPPED ON FAULT
2008	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VANDARGUPPE	17:14	17:19	00:05	TRIPPED ON FAULT
2009	11-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DOMMASANDRA	13:17	13:50	00:33	TRIPPED ON FAULT
2010	11-Jun-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	15:43	16:08	00:25	LINE CLEAR AVAILED
2011	11-Jun-24	GULBARGA	66	LINE	KUDALGI-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66, HUDEM_66	18:15	18:30	00:15	TRIPPED ON FAULT
2012	11-Jun-24	GULBARGA	66	LINE	KUDALGI-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66, HUDEM_66	18:42	18:52	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2013	11-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-JAWALGERA	JAWALGERA_110	14:30	16:10	01:40	LINE CLEAR AVAIED
2014	11-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-MADLAPUR	ADAVIAMARESHWAR_110	05:35	05:54	00:19	MAIN SUPPLY FAILURE
2015	11-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-MADLAPUR	ADAVIAMARESHWAR_110	20:43	20:55	00:12	MAIN SUPPLY FAILURE
2016	11-Jun-24	GULBARGA	110	LINE	GHATTARGA-MORATAGI	GHATTARGA_110	04:02	04:10	00:08	MAIN SUPPLY FAILURE
2017	11-Jun-24	GULBARGA	110	LINE	HALWARTHY-LINGAPUR1	LINGAPUR_220	09:27	14:39	05:12	LINE CLEAR AVAIED
2018	11-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	21:05	21:15	00:10	MAIN SUPPLY FAILURE
2019	11-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	21:05	21:10	00:05	TRIPPED ON FAULT
2020	11-Jun-24	GULBARGA	110	LINE	KANAKAGIRI-NAVALI	NAVALI_110	05:20	05:40	00:20	TRIPPED ON FAULT
2021	11-Jun-24	GULBARGA	110	LINE	KANAKAGIR-NAVALI	NAVALI_110	05:20	05:40	00:20	MAIN SUPPLY FAILURE
2022	11-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONNATHI	SONNATHI_110	02:27	02:32	00:05	TRIPPED ON FAULT
2023	11-Jun-24	GULBARGA	110	LINE	KORWARTEMPLE-CHITAPUR	CHITAPUR_110	06:00	06:05	00:05	MAIN SUPPLY FAILURE
2024	11-Jun-24	GULBARGA	110	LINE	MUNIRABAD-DONIMALAI	DONIMALAI_110	17:05	17:24	00:19	MAIN SUPPLY FAILURE
2025	11-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GUGAL_110, GABUR_110	22:23	22:28	00:05	TRIPPED ON FAULT
2026	11-Jun-24	GULBARGA	110	LINE	SANTHAPUR-JANAWADA	JANAWADA_110	01:50	02:15	00:25	TRIPPED ON FAULT
2027	11-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SINDHANOOR 1&3	SINDHANOOR_110	10:50	14:30	03:40	LINE CLEAR AVAIED
2028	11-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGER CROSS	SIRIGERI CROSS_110	20:31	20:45	00:14	TRIPPED ON FAULT
2029	11-Jun-24	GULBARGA	110	LINE	WALKAMDINI-SINDHANOOR	WALKAMDINI_110	10:55	11:05	00:10	MAIN SUPPLY FAILURE
2030	11-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	11:07	12:05	00:58	LINE CLEAR AVAIED
2031	11-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	04:50	04:55	00:05	MAIN SUPPLY FAILURE
2032	11-Jun-24	GULBARGA	220	TRANSFORMER	HV1	ITTAGI_220	17:20	18:55	01:35	LINE CLEAR AVAIED
2033	11-Jun-24	GULBARGA	220	TRANSFORMER	HV2	ITTAGI_220	19:00	20:10	01:10	LINE CLEAR AVAIED
2034	11-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
2035	11-Jun-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	10:25	17:40	07:15	LINE CLEAR AVAIED
2036	11-Jun-24	HASSAN	66	LINE	HAGARE-KALSPURA	HAGARE_66	11:45	13:20	01:35	MAIN SUPPLY FAILURE
2037	11-Jun-24	HASSAN	66	LINE	HAGARE-KALSPURA	HAGARE_66	13:35	14:35	01:00	MAIN SUPPLY FAILURE
2038	11-Jun-24	HASSAN	66	LINE	HASSN22-BELUR	HASSN_220	10:54	20:50	09:56	LINE CLEAR AVAIED
2039	11-Jun-24	HASSAN	66	LINE	HASSN22-CHIKAMAGLUR2	HASSN_220	10:54	20:50	09:56	LINE CLEAR AVAIED
2040	11-Jun-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSN_220	10:54	20:50	09:56	LINE CLEAR AVAIED
2041	11-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPUA_220	10:19	16:16	05:57	LINE CLEAR AVAIED
2042	11-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPUA_220	12:52	12:55	00:03	LINE CLEAR AVAIED
2043	11-Jun-24	HASSAN	66	LINE	HNPUA-HASSAN	HNPUA_66	10:18	18:12	07:54	LINE CLEAR AVAIED
2044	11-Jun-24	HASSAN	66	LINE	HNPUA-RAMNATHPURA	HNPUA_66	10:18	18:12	07:54	LINE CLEAR AVAIED
2045	11-Jun-24	HASSAN	66	LINE	HNPUA-SOMANAHALLI	HNPUA_66	10:18	18:12	07:54	LINE CLEAR AVAIED
2046	11-Jun-24	HASSAN	66	TRANSFORMER	HV1	ALDUR_66	10:25	17:40	07:15	LINE CLEAR AVAIED
2047	11-Jun-24	HASSAN	66	TRANSFORMER	HV1	HAGARE_66	11:45	13:20	01:35	MAIN SUPPLY FAILURE
2048	11-Jun-24	HASSAN	66	TRANSFORMER	HV1	HAGARE_66	13:35	14:35	01:00	MAIN SUPPLY FAILURE
2049	11-Jun-24	HASSAN	66	TRANSFORMER	HV1	HNPUA_66	10:18	18:12	07:54	LINE CLEAR AVAIED
2050	11-Jun-24	HASSAN	66	TRANSFORMER	HV2	HAGARE_66	11:45	13:20	01:35	MAIN SUPPLY FAILURE
2051	11-Jun-24	HASSAN	66	TRANSFORMER	HV2	HNPUA_66	10:18	18:12	07:54	LINE CLEAR AVAIED
2052	11-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA-66	11:08	13:10	02:02	LINE CLEAR AVAIED
2053	11-Jun-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	20:32	20:51	00:19	MAIN SUPPLY FAILURE
2054	11-Jun-24	HASSAN	66	LINE	UDDURKO-HASSAN1	UDDURKOPPLU_66	10:55	11:40	00:45	MAIN SUPPLY FAILURE
2055	11-Jun-24	HASSAN	66	LINE	UDDURKO-HASSAN2	UDDURKOPPLU_66	10:55	11:40	00:45	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2056	11-Jun-24	HASSAN	66	LINE	UGANE-L2	UGANE_66	11:05	20:30	09:25	LINE CLEAR AVAIED
2057	11-Jun-24	HASSAN	110	LINE	BANTWA-AMR	BANTWAL-110	05:53	06:11	00:18	MAIN SUPPLY FAILURE
2058	11-Jun-24	HASSAN	110	LINE	BANTWA-KAVOOR	BANTWAL-110	05:53	06:11	00:18	MAIN SUPPLY FAILURE
2059	11-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	12:37	12:44	00:07	TRIPPED ON FAULT
2060	11-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	22:12	22:14	00:02	TRIPPED ON FAULT
2061	11-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	11:52	12:51	00:59	MAIN SUPPLY FAILURE
2062	11-Jun-24	HASSAN	110	TRANSFORMER	HV1	BRAHMAVARA_110	11:11	13:34	02:23	LINE CLEAR AVAIED
2063	11-Jun-24	HASSAN	110	TRANSFORMER	HV1	NAVUNDA_110	15:15	16:39	01:24	LINE CLEAR AVAIED
2064	11-Jun-24	HASSAN	110	TRANSFORMER	HV2	BRAHMAVARA_110	12:42	14:08	01:26	LINE CLEAR AVAIED
2065	11-Jun-24	HASSAN	110	TRANSFORMER	HV2	KARKALA_110	12:17	12:59	00:42	LINE CLEAR AVAIED
2066	11-Jun-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	05:53	06:11	00:18	MAIN SUPPLY FAILURE
2067	11-Jun-24	HASSAN	110	TRANSFORMER	HV2	NAVUNDA_110	12:10	17:00	04:50	LINE CLEAR AVAIED
2068	11-Jun-24	HASSAN	110	TRANSFORMER	HV2	NAVUNDA_110	17:38	17:49	00:11	TRIPPED ON FAULT
2069	11-Jun-24	HASSAN	110	LINE	KAVOOR-AMR	KAVOOR_220	05:52	06:10	00:18	TRIPPED ON FAULT
2070	11-Jun-24	HASSAN	110	LINE	KAVOOR-KONAJE	KAVOOR_220	05:52	06:10	00:18	TRIPPED ON FAULT
2071	11-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	11:52	12:51	00:59	LINE CLEAR AVAIED
2072	11-Jun-24	HASSAN	110	LINE	KONAJE-KAVOOR	KONAJE_110	05:53	06:11	00:18	MAIN SUPPLY FAILURE
2073	11-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	14:18	14:22	00:04	LINE CLEAR AVAIED
2074	11-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	17:40	17:46	00:06	LINE CLEAR AVAIED
2075	11-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	14:18	17:43	03:25	LINE CLEAR AVAIED
2076	11-Jun-24	HASSAN	110	TRANSFORMER	LV1	SHIRALKOPPA_220	15:07	15:41	00:34	LINE CLEAR AVAIED
2077	11-Jun-24	HASSAN	110	LINE	MSEZKAVOOR	MSEZ_220	10:17	14:00	03:43	LINE CLEAR AVAIED
2078	11-Jun-24	HASSAN	110	LINE	NAVUNDA-MADHUVANA	NAVUNDA_110	15:15	16:39	01:24	LINE CLEAR AVAIED
2079	11-Jun-24	HASSAN	110	LINE	SALATHU-KONAJE	SALATHUR-110	14:27	16:56	02:29	LINE CLEAR AVAIED
2080	11-Jun-24	HASSAN	110	LINE	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	04:10	04:28	00:18	LINE CLEAR AVAIED
2081	11-Jun-24	HASSAN	110	LINE	SHRLKP-SORAB	SHIRALKOPPA_220	04:10	04:29	00:19	LINE CLEAR AVAIED
2082	11-Jun-24	HASSAN	220	TRANSFORMER	HV1	SHIRALKOPPA_220	15:07	15:40	00:33	LINE CLEAR AVAIED
2083	11-Jun-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	09:43	14:50	05:07	LINE CLEAR AVAIED
2084	11-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRS_220	13:26	13:28	00:02	LINE CLEAR AVAIED
2085	11-Jun-24	HASSAN	220	LINE	SHRAVTY-SHIRALKOPPA	gen_sharavathy	04:04	11:23	07:19	TRIPPED ON FAULT
2086	11-Jun-24	HASSAN	220	LINE	SHRLKP-SGS	SHIRALKOPPA_220	04:04	11:23	07:19	TRIPPED ON FAULT
2087	11-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	22:12(11.06.2024)			LINE CLEAR AVAIED
2088	11-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	12:37	13:30	00:53	TRIPPED ON FAULT
2089	11-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	20:33	20:50	00:17	TRIPPED ON FAULT
2090	11-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	21:30	21:51	00:21	TRIPPED ON FAULT
2091	11-Jun-24	MYSORE	66	LINE	BEGUR 220-GUNDLUPETE-1	GUNDULPET_66	10:05	16:00	05:55	LINE CLEAR AVAIED
2092	11-Jun-24	MYSORE	66	LINE	BEGUR 220-GUNDLUPETE-2	GUNDULPET_66	10:05	16:00	05:55	LINE CLEAR AVAIED
2093	11-Jun-24	MYSORE	66	LINE	BOMMALAPURA-GUNDLUPETE	BOMMALAPURA_66	09:10	18:50	09:40	LINE CLEAR AVAIED
2094	11-Jun-24	MYSORE	66	LINE	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	13:58	14:03	00:05	TRIPPED ON FAULT
2095	11-Jun-24	MYSORE	66	LINE	CR NAGARA-KABBALLI	KABHALLY_66	10:21	12:51	02:29	LINE CLEAR AVAIED
2096	11-Jun-24	MYSORE	66	LINE	HANGALA-GUNDLUPETE	BHARGI_66 HANGLA_66	10:05	17:06	07:01	LINE CLEAR AVAIED
2097	11-Jun-24	MYSORE	66	LINE	HARVEY-CR NAGARA	KABHALLY_66	10:23	12:40	02:16	LINE CLEAR AVAIED
2098	11-Jun-24	MYSORE	66	LINE	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	05:50	06:01	00:11	TRIPPED ON FAULT
2099	11-Jun-24	MYSORE	66	LINE	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	11:09	13:46	02:37	LINE CLEAR AVAIED
2100	11-Jun-24	MYSORE	66	LINE	HUNSUR-HUNSUR-2	NO STATIONS EFFECTED	05:50	06:01	00:11	TRIPPED ON FAULT
2101	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	BHARGI_66	09:30	16:30	07:00	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2102	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	HADLI_66	15:01	16:06	01:05	LINE CLEAR AVAILED
2103	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	HANGLA_66	10:03	17:06	07:02	LINE CLEAR AVAILED
2104	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	KIRUGAVALU_66	10:07	17:23	07:15	LINE CLEAR AVAILED
2105	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	YELANDUR_66	13:01	14:32	01:30	LINE CLEAR AVAILED
2106	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	13:00	13:03	00:03	LINE CLEAR AVAILED
2107	11-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2108	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	BHARGI_66	09:30	16:30	07:00	LINE CLEAR AVAILED
2109	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	HANGLA_66	10:03	17:06	07:02	LINE CLEAR AVAILED
2110	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	KIRUGAVALU_66	10:07	17:23	07:15	LINE CLEAR AVAILED
2111	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	KOLLEGALA_66	10:27	10:37	00:10	LINE CLEAR AVAILED
2112	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	YELANDUR_66	06:44	14:35	07:50	TRIPPED ON FAULT
2113	11-Jun-24	MYSORE	66	TRANSFORMER	HV2	YETHAMBADI_66	13:00	13:03	00:03	LINE CLEAR AVAILED
2114	11-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
2115	11-Jun-24	MYSORE	66	LINE	KABBALLI-ATRIA SOLAR	NO STATIONS EFFECTED	09:20	09:30	00:10	TRIPPED ON FAULT
2116	11-Jun-24	MYSORE	66	LINE	KABBALLI-ATRIA SOLAR	NO STATIONS EFFECTED	10:20	12:50	02:30	LINE CLEAR AVAILED
2117	11-Jun-24	MYSORE	66	LINE	KABBALLI-CLEAN SOLAR	NO STATIONS EFFECTED	09:20	16:00	06:40	LINE CLEAR AVAILED
2118	11-Jun-24	MYSORE	66	LINE	KABBALLI-GUNDLUPETE	KABHALLY_66	09:20	15:45	06:25	LINE CLEAR AVAILED
2119	11-Jun-24	MYSORE	66	LINE	KIRUGAVLU-MALIYURU	NO STATIONS EFFECTED	13:23	17:20	03:57	LINE CLEAR AVAILED
2120	11-Jun-24	MYSORE	66	LINE	KIRUGAVLU-VADKEPURA	KIRUGAVALU_66	13:18	17:20	04:02	LINE CLEAR AVAILED
2121	11-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2122	11-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2123	11-Jun-24	MYSORE	66	LINE	MAMBALLI-YELANDURU	YELANDUR_66	05:40	05:45	00:05	TRIPPED ON FAULT
2124	11-Jun-24	MYSORE	66	LINE	MUGUR-JANNUR	JANNUR_66	06:02	06:07	00:05	TRIPPED ON FAULT
2125	11-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-BG NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	09:15	09:23	00:08	TRIPPED ON FAULT
2126	11-Jun-24	MYSORE	66	LINE	NANJANAGUDU-THANDYA	NO STATIONS EFFECTED	09:19	09:46	00:26	LINE CLEAR AVAILED
2127	11-Jun-24	MYSORE	66	LINE	TARIPURA-MHS	NO STATIONS EFFECTED	06:15	07:44	01:29	TRIPPED ON FAULT
2128	11-Jun-24	MYSORE	66	LINE	TARIPURA-MHS	NO STATIONS EFFECTED	07:55	08:41	00:46	LINE CLEAR AVAILED
2129	11-Jun-24	MYSORE	66	LINE	TARIPURA-TUBINAKERE	TARIPURA_66	06:15	06:25	00:10	TRIPPED ON FAULT
2130	11-Jun-24	MYSORE	66	LINE	THANDYA-ITC	NO STATIONS EFFECTED	08:44	09:40	00:55	TRIPPED ON FAULT
2131	11-Jun-24	MYSORE	66	LINE	THANDYA-ITC	NO STATIONS EFFECTED	12:25	14:40	02:15	TRIPPED ON FAULT
2132	11-Jun-24	MYSORE	66	LINE	THANDYA-KADAKOLA	THANDYA_66	08:44	09:40	00:55	TRIPPED ON FAULT
2133	11-Jun-24	MYSORE	66	LINE	THANDYA-KADAKOLA	THANDYA_66	14:20	14:40	00:20	TRIPPED ON FAULT
2134	11-Jun-24	MYSORE	66	LINE	THANDYA-NANJANGUDU	THANDYA_66	08:44	09:37	00:52	TRIPPED ON FAULT
2135	11-Jun-24	MYSORE	66	LINE	THANDYA-NANJANGUDU	THANDYA_66	14:20	14:40	00:20	TRIPPED ON FAULT
2136	11-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA- 66KV B G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIYUR	18:57	19:07	00:10	TRIPPED ON FAULT
2137	11-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	MELKOTE_66, BADDIHALLI_66	11:30 (10.06.2024)	13:32 (11.06.2024)	1 Day 2 Hrs 2 Mint	TRIPPED ON FAULT
2138	11-Jun-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV CHANNAGIRI LINE	66KV CHANNAGIRI	11:06	11:16	00:10	TRIPPED ON FAULT
2139	11-Jun-24	TUMKUR	66	LINE	220KV CHITRADURGA - 66KV PANDARAHALLI LINE 2	66KV HIREGUNTANUR	07:11	07:21	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2140	11-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV CHALLAKERE LINE 2	66KV CHALLAKERE	15:35	15:48	00:13	TRIPPED ON FAULT
2141	11-Jun-24	TUMKUR	66	LINE	66KV HANGAL-66KV RAMPURA LINE	66KV RAMPURA, NAGASAMUDRA	12:38	12:48	00:10	TRIPPED ON FAULT
2142	11-Jun-24	TUMKUR	66	LINE	66KV HOLALKERE-66KV PANDARAHALLI LINE 1	66KV CHITRAHALLI,H D PURA	11:02	11:15	00:13	TRIPPED ON FAULT
2143	11-Jun-24	TUMKUR	66	LINE	BHARAMASAGARA-PANDARAHALLI	BHARAMASAGARA_66	10:55	12:05	01:10	LINE CLEAR AVAILED
2144	11-Jun-24	TUMKUR	66	LINE	BUKKAPATNA-SIRA	BUKKAPATNA_66	10:00	17:30	07:30	LINE CLEAR AVAILED
2145	11-Jun-24	TUMKUR	66	LINE	CHIKKAJAJUR_66-HOLALKERE_66 LINE 1	CHIKKAJAJUR_66	10:05	10:15	00:10	LINE CLEAR AVAILED
2146	11-Jun-24	TUMKUR	66	LINE	CHIKKAJAJUR_66-HOLALKERE_66 LINE 1	CHIKKAJAJUR_66	17:00	17:20	00:20	LINE CLEAR AVAILED
2147	11-Jun-24	TUMKUR	66	LINE	J N KOTE_66-MALLAPPANAHALLI	AIMANGALA_66, MALLAPPANAHALLI_66	17:53	18:03	00:10	LINE CLEAR AVAILED
2148	11-Jun-24	TUMKUR	66	LINE	SASALUHALLA-CHIKKAJAJUR	SASALUHALLA_66	14:10	16:25	02:15	LINE CLEAR AVAILED
2149	11-Jun-24	TUMKUR	66	LINE	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	10:25	16:45	06:20	LINE CLEAR AVAILED
2150	11-Jun-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	10:52	14:43	03:51	LINE CLEAR AVAILED
2151	11-Jun-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	10:08	15:30	05:22	LINE CLEAR AVAILED
2152	11-Jun-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	17:26	17:28	00:02	LINE CLEAR AVAILED
2153	11-Jun-24	TUMKUR	220	LINE	CHITRADURGA 220KV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:58	11:37	00:39	LINE CLEAR AVAILED
2154	11-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(100MVA)-KIADB_220 (HV & LV)	KIADB_220	11:02	15:30	04:28	LINE CLEAR AVAILED
2155	11-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2	GUTUR_400	01:57	08:37	06:40	LINE CLEAR AVAILED
2156	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HONNAVAR_110	11:04	12:01	00:57	LINE CLEAR AVAILED
2157	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	15:13	15:25	00:12	TRIPPED ON FAULT
2158	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	UCHAGOAN_110	23:59	06:02	06:03	LINE CLEAR AVAILED
2159	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADAKLAT_110	02:09	02:16	00:07	TRIPPED ON FAULT
2160	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KULIGOD_110	15:40	21:36	05:56	TRIPPED ON FAULT
2161	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	SIRSI_110	15:42	18:31	02:49	LINE CLEAR AVAILED
2162	12-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	SIRSI_110	18:34	18:57	00:23	LINE CLEAR AVAILED
2163	12-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
2164	12-Jun-24	BAGALKOTE	110	LINE	AKSHYACOLONY-HUBLI	AKSHAYCOLONY_110	12:01	16:00	03:59	LINE CLEAR AVAILED
2165	12-Jun-24	BAGALKOTE	110	LINE	AMBEWADI-NK2(KAVALWADA)	AMBEWADI_220	16:21	16:23	00:02	LINE CLEAR AVAILED
2166	12-Jun-24	BAGALKOTE	110	LINE	ATHANI220- HALIYAL	ATHANI_220	07:13	07:32	00:19	TRIPPED ON FAULT
2167	12-Jun-24	BAGALKOTE	110	LINE	ATHANI220-KARIMASUTI	ATHANI_220	00:24	07:56	07:32	TRIPPED ON FAULT
2168	12-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
2169	12-Jun-24	BAGALKOTE	110	LINE	GADAG220- SHIRAHATTI	GADAG_220	10:21	17:01	06:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2170	12-Jun-24	BAGALKOTE	110	LINE	HAVERI220- HANGAL(KULENUR)	HAVERI_220	12:00	14:37	02:37	LINE CLEAR AVAILED
2171	12-Jun-24	BAGALKOTE	110	LINE	HIREBEVANUR-INDI (ROODAGI)	HIREBEVANUR_110	05:27	05:36	00:09	TRIPPED ON FAULT
2172	12-Jun-24	BAGALKOTE	110	LINE	HIREBEVANUR-INDI (ROODAGI)	HIREBEVANUR_110	05:45	06:09	00:24	TRIPPED ON FAULT
2173	12-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
2174	12-Jun-24	BAGALKOTE	110	LINE	HUBLI220-KADANAKOPPA	HUBLI_220	05:31	08:01	02:30	TRIPPED ON FAULT
2175	12-Jun-24	BAGALKOTE	110	LINE	KADANAKOPPA-HUBLI	KADANAKOPPA_110	08:48	09:06	00:18	LINE CLEAR AVAILED
2176	12-Jun-24	BAGALKOTE	110	LINE	KADANAKOPPA-KAVALWADA	KADANAKOPPA_110	05:36	06:16	00:40	LINE CLEAR AVAILED
2177	12-Jun-24	BAGALKOTE	110	LINE	KUMATA- SIRSI1	KUMATA_110	02:13	18:47	16:34	TRIPPED ON FAULT
2178	12-Jun-24	BAGALKOTE	110	LINE	LAXMESHWAR- SHIRAHATTI	LAXMESHWAR_110	10:18	17:03	06:45	LINE CLEAR AVAILED
2179	12-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
2180	12-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2181	12-Jun-24	BAGALKOTE	110	LINE	MRUTHYUNJAY NAGAR- L1 -GOPPANAKOPPA	MRUTHYUNJAY NAGAR_110	11:21	12:23	01:02	LINE CLEAR AVAILED
2182	12-Jun-24	BAGALKOTE	110	LINE	PG HUNSHYAL- SATTISUGARS	PG HUNSHYAL_110	08:19	17:30	09:11	LINE CLEAR AVAILED
2183	12-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
2184	12-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2185	12-Jun-24	BAGALKOTE	110	LINE	SIRSI- JOG2	SIRSI_110	15:42	16:59	01:17	LINE CLEAR AVAILED
2186	12-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMTA2	SIRSI_110	15:42	16:35	00:53	LINE CLEAR AVAILED
2187	12-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
2188	12-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2189	12-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
2190	12-Jun-24	BAGALKOTE	110	LINE	TARIHAL-SRS HUBLI-1	STATION NOT AFFECTED TARIHAL_110	18:37	21:22	02:45	LINE CLEAR AVAILED
2191	12-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
2192	12-Jun-24	BAGALKOTE	110	LINE	THORVI-BHUTNAL	THORVI_110	11:21	12:50	01:29	LINE CLEAR AVAILED
2193	12-Jun-24	BAGALKOTE	110	LINE	THORVI-TIKOTA	THORVI_110	12:50	14:20	01:30	LINE CLEAR AVAILED
2194	12-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
2195	12-Jun-24	BAGALKOTE	110	LINE	UMMACHAG-SIRSI	STATION NOT AFFECTED UMMACHAGI_110	13:13	17:51	04:38	LINE CLEAR AVAILED
2196	12-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2197	12-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220-BILAGI	VAJRAMATTI_220	02:09	02:17	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2198	12-Jun-24	BAGALKOTE	220	TRANSFORMER	220/11KV, LV1	SIRSI_220	03:01	04:03	01:02	TRIPPED ON FAULT
2199	12-Jun-24	BAGALKOTE	220	TRANSFORMER	220/11KV, LV1	SIRSI_220	14:12	14:51	00:39	LINE CLEAR AVAILED
2200	12-Jun-24	BAGALKOTE	220	LINE	AEQUS -BELGAUM1	AEQUS_220	10:45	12:42	01:57	LINE CLEAR AVAILED
2201	12-Jun-24	BAGALKOTE	220	LINE	AEQUS -BELGAUM2	AEQUS_220	15:19	17:10	01:51	LINE CLEAR AVAILED
2202	12-Jun-24	BAGALKOTE	220	LINE	ATHANI-MAHALINGAPUR	ATHANI_220	10:08	16:43	06:35	LINE CLEAR AVAILED
2203	12-Jun-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS1	BELGAUM_220	10:45	12:41	01:56	LINE CLEAR AVAILED
2204	12-Jun-24	BAGALKOTE	220	LINE	BELGAUM- AEQUS2	BELGAUM_220	15:21	17:09	01:48	LINE CLEAR AVAILED
2205	12-Jun-24	BAGALKOTE	220	LINE	DHONI-GADAG1	DHONI_400	20:16 (10.06.2024)	13:39 (12.06.2024)	41:23:00	TRIPPED ON FAULT
2206	12-Jun-24	BAGALKOTE	220	LINE	DHONI-GADAG2	DHONI_400	20:15 (10.06.2024)	13:39 (12.06.2024)	41:24:00	TRIPPED ON FAULT
2207	12-Jun-24	BAGALKOTE	220	LINE	GADAG-LINGAPUR1(DHONI1)	GADAG_220	08:26	13:34	05:08	LINE CLEAR AVAILED
2208	12-Jun-24	BAGALKOTE	220	LINE	GADAG-LINGAPUR2(DHONI2)	GADAG_220	08:26	13:34	05:08	LINE CLEAR AVAILED
2209	12-Jun-24	BAGALKOTE	220	LINE	KUDACHI- MAHALINGAPUR	KUDACHI_220	10:10	18:46	08:36	LINE CLEAR AVAILED
2210	12-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	9:49 (02.06.2024)	15:26 (12.06.2024)	245:37:00	LINE CLEAR AVAILED
2211	12-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA2	MAHALINGAPUR_220	9:49 (02.06.2024)	15:26 (12.06.2024)	245:37:00	LINE CLEAR AVAILED
2212	12-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2213	12-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR AND SRIGIRUPURA	12:30	13:20	00:50	MAIN SUPPLY FAILURE
2214	12-Jun-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR,DASHAVARA,SANKALAGERE,VANDARAGUPPE	10:04	15:10	05:06	LINE CLEAR AVAILED
2215	12-Jun-24	BANGALORE	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANGUDI	15:28	15:53	00:25	LINE CLEAR AVAILED
2216	12-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI 66	10:00	17:20	07:20	LINE CLEAR AVAILED
2217	12-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	NO STATION AFFECTED	18:01	18:26	00:25	TRIPPED ON FAULT
2218	12-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1	DEVANAHALLI 66	10:00	17:20	07:20	LINE CLEAR AVAILED
2219	12-Jun-24	BANGALORE	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	VANADARAGUPPE	12:58	13:10	00:12	TRIPPED ON FAULT
2220	12-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SOBHA FOREST VIEW	17:13	17:17	00:04	LINE CLEAR AVAILED
2221	12-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	22:10	22:15	00:05	LINE CLEAR AVAILED
2222	12-Jun-24	BANGALORE	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	10:21	15:07	04:46	LINE CLEAR AVAILED
2223	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAXMI LAYOUT	11:32	11:37	00:05	LINE CLEAR AVAILED
2224	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAXMI LAYOUT	22:40	22:45	00:05	LINE CLEAR AVAILED
2225	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MEI LAYOUT	10:00	10:05	00:05	LINE CLEAR AVAILED
2226	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SHOBHA DREAMS ACRES 66	10:44	10:46	00:02	LINE CLEAR AVAILED
2227	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BG ROAD	11:21	11:34	00:13	TRIPPED ON FAULT
2228	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SULIBELE	18:10	18:17	00:07	TRIPPED ON FAULT
2229	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	09:12	09:17	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2230	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GANJIGUNTE	10:32	10:37	00:05	TRIPPED ON FAULT
2231	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	H GOLAHALLI	15:50	17:35	01:45	LINE CLEAR AVOIDED
2232	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KYALANUR	14:47	14:55	00:08	LINE CLEAR AVOIDED
2233	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDAHALLI	18:08	18:13	00:05	TRIPPED ON FAULT
2234	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HEJJALA	21:20	21:35	00:15	TRIPPED ON FAULT
2235	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOTHIPURA 220	15:20	15:55	00:35	LINE CLEAR AVOIDED
2236	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	12:00	12:10	00:10	TRIPPED ON FAULT
2237	12-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	16:55	17:05	00:10	TRIPPED ON FAULT
2238	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAXMI LAYOUT	11:32	11:37	00:05	LINE CLEAR AVOIDED
2239	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAXMI LAYOUT	22:40	22:45	00:05	LINE CLEAR AVOIDED
2240	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MEI LAYOUT	10:49	10:52	00:03	LINE CLEAR AVOIDED
2241	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SHOBHA DREAMS ACRES 66	12:24	12:25	00:01	LINE CLEAR AVOIDED
2242	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SATHANUR (ACHALU)	00:33	00:43	00:10	TRIPPED ON FAULT
2243	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANASWADI	12:30	13:20	00:50	LINE CLEAR AVOIDED
2244	12-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VG DODDI	10:40	15:45	05:05	LINE CLEAR AVOIDED
2245	12-Jun-24	GULBARGA	66	TRANSFORMER	HV2	HBHALLI_66	14:20	14:30	00:10	TRIPPED ON FAULT
2246	12-Jun-24	GULBARGA	66	LINE	KUDLGI-GUDEKOTE	GUDEKOTE_110,CJ_HALLI,HOSAHALLI_66,HUDEM_66	00:45	01:05	00:20	TRIPPED ON FAULT
2247	12-Jun-24	GULBARGA	66	LINE	KUDLGI-GUDEKOTE	GUDEKOTE_110,CJ_HALLI,HOSAHALLI_66,HUDEM_66	12:45	14:45	02:00	LINE CLEAR AVOIDED
2248	12-Jun-24	GULBARGA	66	LINE	KUDLGI-BANAVEKAL	BANVEKAL_66	20:10	20:30	00:20	TRIPPED ON FAULT
2249	12-Jun-24	GULBARGA	66	LINE	KUDLGI-UJJANI	UJJANI_66,SOKKE_66,NIMBALGERE_66	18:30	18:45	00:15	TRIPPED ON FAULT
2250	12-Jun-24	GULBARGA	66	LINE	NEELAGUNDA-PUNABGHATA	PUNABGHATA_66,UCHCHANGI DURGA_66,PALAGATTA_66,SUZLON_IPP	19:07	19:14	00:07	TRIPPED ON FAULT
2251	12-Jun-24	GULBARGA	110	TRANSFORMER	HV3	TORANGALU_110	18:40	19:05	00:25	TRIPPED ON FAULT
2252	12-Jun-24	GULBARGA	110	TRANSFORMER	HV3	TORANGALU_110	08:25	10:50	02:25	TRIPPED ON FAULT
2253	12-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATHI	SANNATHI_IPP	04:34	04:55	00:21	TRIPPED ON FAULT
2254	12-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATHI	SANNATHI_IPP	05:26	05:33	00:07	TRIPPED ON FAULT
2255	12-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMSAGAR	HANUMSAGAR_110,HANUMNAL_110,HIREGONNAGAR_110	04:30	14:04	09:34	TRIPPED ON FAULT
2256	12-Jun-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	19:19	19:25	00:06	TRIPPED ON FAULT
2257	12-Jun-24	GULBARGA	110	LINE	MANEKHALLI-CHINCHOLI	CHINCHOLI_110	23:10	23:30	00:20	TRIPPED ON FAULT
2258	12-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110,GUGAL_110	00:28	00:43	00:15	TRIPPED ON FAULT
2259	12-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110,GUGAL_110	03:50	04:02	00:12	TRIPPED ON FAULT
2260	12-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-KONKAL	KONAKAL_110	23:35	23:53	00:18	TRIPPED ON FAULT
2261	12-Jun-24	GULBARGA	110	LINE	SANTHAPUR-AURAD	AURAD_110	21:05	21:15	00:10	TRIPPED ON FAULT
2262	12-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	04:49	04:54	00:05	TRIPPED ON FAULT
2263	12-Jun-24	GULBARGA	110	LINE	SINDHANOOR-GANDHINAGAR	GANDHINAGAR_110,TURVIHAL_110	10:10	13:00	02:50	LINE CLEAR AVOIDED
2264	12-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALL	MUKKUNDA_110	20:40	20:50	00:10	TRIPPED ON FAULT
2265	12-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALL	MUKKUNDA_110	22:55	23:05	00:10	TRIPPED ON FAULT
2266	12-Jun-24	GULBARGA	110	LINE	SOMASAMUNDRA-BELLARY NORTH_110	BELLARY NORTH_110,BISIHALLI_110,PD_HALLI_110	19:24	19:39	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2267	12-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGER CROSS	SIRIGERI CROSS_110	10:20	13:55	03:35	LINE CLEAR AVAILED
2268	12-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2269	12-Jun-24	GULBARGA	220	LINE	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	21:53	22:30	00:37	TRIPPED ON FAULT
2270	12-Jun-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	14:33	15:03	00:30	TRIPPED ON FAULT
2271	12-Jun-24	HASSAN	66	LINE	HASSN22-CHIKAMAGLUR2	HASSAN_220	18:17	18:34	00:17	TRIPPED ON FAULT
2272	12-Jun-24	HASSAN	66	LINE	HNPR2-HASS2	HNPURA_220	10:50	15:13	04:23	LINE CLEAR AVAILED
2273	12-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPURA_220	10:27	10:34	00:07	TRIPPED ON FAULT
2274	12-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHIKABOMMENAHALLI_66	17:03	17:23	00:20	LINE CLEAR AVAILED
2275	12-Jun-24	HASSAN	66	TRANSFORMER	HV1	HASSAN_66	09:11	20:06	10:55	LINE CLEAR AVAILED
2276	12-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALALI_66	11:04	15:18	04:14	LINE CLEAR AVAILED
2277	12-Jun-24	HASSAN	66	TRANSFORMER	HV1	SIGEBAGE_66	16:05	17:36	01:31	LINE CLEAR AVAILED
2278	12-Jun-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	14:23	14:24	00:01	TRIPPED ON FAULT
2279	12-Jun-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	11:04	15:18	04:14	LINE CLEAR AVAILED
2280	12-Jun-24	HASSAN	66	LINE	MALALI-HASSAN	MALALI_66	11:04	15:18	04:14	LINE CLEAR AVAILED
2281	12-Jun-24	HASSAN	66	LINE	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	13:10	13:20	00:10	TRIPPED ON FAULT
2282	12-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON2	UDDURKOPPLU_66	18:20	19:43	01:23	TRIPPED ON FAULT
2283	12-Jun-24	HASSAN	110	TRANSFORMER	HV1	BAIKAMPADI_110	13:32	13:37	00:05	TRIPPED ON FAULT
2284	12-Jun-24	HASSAN	110	TRANSFORMER	HV1	BRAHMAVARA_110	13:32	15:53	02:21	TRIPPED ON FAULT
2285	12-Jun-24	HASSAN	110	TRANSFORMER	HV1	MSEZ_220	10:05	13:22	03:17	LINE CLEAR AVAILED
2286	12-Jun-24	HASSAN	110	TRANSFORMER	HV1	PUTTUR_220	10:03	13:23	03:20	LINE CLEAR AVAILED
2287	12-Jun-24	HASSAN	110	TRANSFORMER	HV2	BAIKAMPADI_110	13:32	13:38	00:06	TRIPPED ON FAULT
2288	12-Jun-24	HASSAN	110	TRANSFORMER	HV2	BARANGI_110	11:05	11:30	00:25	LINE CLEAR AVAILED
2289	12-Jun-24	HASSAN	110	TRANSFORMER	HV2	BRAHMAVARA_110	15:25	15:35	00:10	LINE CLEAR AVAILED
2290	12-Jun-24	HASSAN	110	TRANSFORMER	HV2	MSEZ_220	10:05	13:34	03:29	LINE CLEAR AVAILED
2291	12-Jun-24	HASSAN	110	TRANSFORMER	HV3	ANAVATTI_110	12:25	12:37	00:12	LINE CLEAR AVAILED
2292	12-Jun-24	HASSAN	110	LINE	JOG-JST2	gen_mghe	11:19	12:14	00:55	TRIPPED ON FAULT
2293	12-Jun-24	HASSAN	110	LINE	SAGARA-JST2	SAGARA_110	11:20	12:10	00:50	TRIPPED ON FAULT
2294	12-Jun-24	HASSAN	110	LINE	SHRLKP-BARANGI	SHIRALKOPPA_220	11:30	11:57	00:27	TRIPPED ON FAULT
2295	12-Jun-24	HASSAN	110	LINE	SHRLKP-MAVLI	SHIRALKOPPA_220	10:24	18:10	07:46	LINE CLEAR AVAILED
2296	12-Jun-24	HASSAN	220	LINE	GERSOPA-TALGUPA2	gen_gersoppa	11:20	17:13	05:53	TRIPPED ON FAULT
2297	12-Jun-24	HASSAN	220	LINE	MRSSHM-VARAHI3	MRSMSG_220	08:23	13:44	05:21	LINE CLEAR AVAILED
2298	12-Jun-24	HASSAN	220	LINE	TALAGU-STRP2	TALAGUPPA_400	11:20	17:13	05:53	TRIPPED ON FAULT
2299	12-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	22:12(11.06.2024)	13:43(12.06.2024)	15:31HRS	LINE CLEAR AVAILED
2300	12-Jun-24	MYSORE	66	LINE	BG NAGARA-KADABALLI	KADABALLY_66	05:52	06:03	00:10	TRIPPED ON FAULT
2301	12-Jun-24	MYSORE	66	LINE	BG PURA-CHANDALLI	CHANDALLI_66	14:58	17:07	02:09	LINE CLEAR AVAILED
2302	12-Jun-24	MYSORE	66	LINE	CHANDALLI-THALAKADU	THALAKADU_66	15:02	16:56	01:54	LINE CLEAR AVAILED
2303	12-Jun-24	MYSORE	66	LINE	DATTAGALLI-RK NAGARA	RKNAGARA_66	10:00	13:26	03:25	LINE CLEAR AVAILED
2304	12-Jun-24	MYSORE	66	LINE	GOLURU-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	04:58	05:01	00:03	TRIPPED ON FAULT
2305	12-Jun-24	MYSORE	66	LINE	HANNUR-KOTHANURU	NO STATIONS EFFECTED	07:47	07:55	00:07	TRIPPED ON FAULT
2306	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	DEVANOORNGUDU_66	10:00	17:10	07:10	LINE CLEAR AVAILED
2307	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	LOKKANAHALLI_66	15:25	17:10	01:45	LINE CLEAR AVAILED
2308	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	MADHUVANAHALLI_220	11:20	11:30	00:10	LINE CLEAR AVAILED
2309	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	MEGALAPURA_66	10:10	17:59	07:48	LINE CLEAR AVAILED
2310	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	PGPALYA_66	11:27	13:40	02:12	LINE CLEAR AVAILED
2311	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	SUTTUR_66	10:09	17:20	07:11	LINE CLEAR AVAILED
2312	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	THALAKADU_66	10:00	17:05	07:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2313	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	TUBINAKERE_220	10:14	16:19	06:05	LINE CLEAR AVAILED
2314	12-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2315	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	DEVANOORNGUDU_66	10:00	17:10	07:10	LINE CLEAR AVAILED
2316	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	HOOTAGALLY_220	13:54	14:20	00:25	TRIPPED ON FAULT
2317	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	MEGALAPURA_66	10:10	17:58	07:48	LINE CLEAR AVAILED
2318	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	PGPALYA_66	12:30	16:00	03:30	LINE CLEAR AVAILED
2319	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	SUTTUR_66	10:09	17:20	07:11	LINE CLEAR AVAILED
2320	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	THALAKADU_66	10:00	17:05	07:05	LINE CLEAR AVAILED
2321	12-Jun-24	MYSORE	66	TRANSFORMER	HV2	TUBINAKERE_220	10:14	16:23	06:09	LINE CLEAR AVAILED
2322	12-Jun-24	MYSORE	66	TRANSFORMER	HV3	TUBINAKERE_220	10:16	13:40	03:23	LINE CLEAR AVAILED
2323	12-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
2324	12-Jun-24	MYSORE	66	LINE	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	12:30	12:50	00:20	LINE CLEAR AVAILED
2325	12-Jun-24	MYSORE	66	LINE	KABHALLY-CR NAGARA	KABHALLY_66	12:30	12:41	00:11	TRIPPED ON FAULT
2326	12-Jun-24	MYSORE	66	LINE	KABHALLY-CR NAGARA	KABHALLY_66	13:10	13:15	00:05	TRIPPED ON FAULT
2327	12-Jun-24	MYSORE	66	LINE	KABHALLY-GUNDLUPETE	NO STATIONS EFFECTED	12:00	18:10	06:10	LINE CLEAR AVAILED
2328	12-Jun-24	MYSORE	66	LINE	KADABALLI-HIRISAVE	KADABALLY_66	05:55	13:46	07:51	TRIPPED ON FAULT
2329	12-Jun-24	MYSORE	66	LINE	KADAKOLA-GOLURU	DEVANOORNGUDU_66 GOLURU(GEEKALLI)_66 SUTTUR_66	09:40	09:44	00:03	TRIPPED ON FAULT
2330	12-Jun-24	MYSORE	66	LINE	KADAKOLA-GOLURU	DEVANOORNGUDU_66 GOLURU(GEEKALLI)_66 SUTTUR_66	11:02	12:56	01:53	LINE CLEAR AVAILED
2331	12-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	10:12	16:10	05:57	LINE CLEAR AVAILED
2332	12-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2333	12-Jun-24	MYSORE	66	LINE	KUSHALANAGARA-PERIYAPATNA-2	BYLUKUPPE_66	19:02	19:08	00:06	TRIPPED ON FAULT
2334	12-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2335	12-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	13:07	13:59	00:51	LINE CLEAR AVAILED
2336	12-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	15:40	15:52	00:11	TRIPPED ON FAULT
2337	12-Jun-24	MYSORE	66	LINE	MALLAVALLI-TK HALLI	HADLI_66	10:46	11:25	00:39	LINE CLEAR AVAILED
2338	12-Jun-24	MYSORE	66	LINE	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	10:22	12:24	02:02	LINE CLEAR AVAILED
2339	12-Jun-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	09:01	11:57	02:56	LINE CLEAR AVAILED
2340	12-Jun-24	MYSORE	66	LINE	SFC SIVA-PPCL	NO STATIONS EFFECTED	08:58	11:57	02:58	LINE CLEAR AVAILED
2341	12-Jun-24	MYSORE	66	LINE	THALAKADU-ADANI	NO STATIONS EFFECTED	15:00	16:55	01:55	LINE CLEAR AVAILED
2342	12-Jun-24	MYSORE	66	LINE	THALAKADU-ADANI	NO STATIONS EFFECTED	16:55	17:05	00:10	TRIPPED ON FAULT
2343	12-Jun-24	MYSORE	66	LINE	THALAKADU-ADANI	NO STATIONS EFFECTED	17:05	20:40	03:35	TRIPPED ON FAULT
2344	12-Jun-24	MYSORE	66	LINE	THALAKADU-ADANI	NO STATIONS EFFECTED	20:40	00:00	03:20	TRIPPED ON FAULT
2345	12-Jun-24	MYSORE	66	LINE	THUMBLA-MEGHALAPURA	NO STATIONS EFFECTED	11:50	17:36	05:46	LINE CLEAR AVAILED
2346	12-Jun-24	MYSORE	66	LINE	TUBINAKERE-MANDYA 4	NO STATIONS EFFECTED	11:56	11:58	00:01	LINE CLEAR AVAILED
2347	12-Jun-24	MYSORE	66	LINE	VAJAMANGALA-BANNUR	BANNUR_66	10:16	18:02	07:46	LINE CLEAR AVAILED
2348	12-Jun-24	MYSORE	66	LINE	VAJAMANGALA-MEGHALAPURA	MEGALAPURA_66	11:15	17:37	06:22	LINE CLEAR AVAILED
2349	12-Jun-24	MYSORE	220	LINE	MADHUVANAHALLI-HEBBANI-1	NO STATIONS EFFECTED	10:28	12:12	01:44	LINE CLEAR AVAILED
2350	12-Jun-24	MYSORE	220	LINE	MADHUVANAHALLI-HEBBANI-2	NO STATIONS EFFECTED	12:24	13:05	00:40	LINE CLEAR AVAILED
2351	12-Jun-24	MYSORE	220	LINE	TUBINAKERE-GOPALAPURA	NO STATIONS EFFECTED	13:03	17:33	04:30	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2352	12-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV CHELUR LINE	66KV CHELUR, NANDHIHALLI, HOSAKERE,HAGALWADI	06:05	06:25	00:20	TRIPPED ON FAULT
2353	12-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALLI	12:31	12:35	00:04	TRIPPED ON FAULT
2354	12-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALLI	12:40	12:50	00:10	TRIPPED ON FAULT
2355	12-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALLI	15:05	16:24	01:19	TRIPPED ON FAULT
2356	12-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALLI - 66KV MELEKOTE LINE	66KV MELEKOTE,BADDIHALLI	16:27	20:42	04:15	TRIPPED ON FAULT
2357	12-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV MATHOD LINE 1	66KV HINDUSGHATTA	07:45	07:55	00:10	TRIPPED ON FAULT
2358	12-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR,MALEBENNUR,DEVARBELAKERE	01:57	02:11	00:14	TRIPPED ON FAULT
2359	12-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV BASAVAPATNA	15:13	15:27	00:14	TRIPPED ON FAULT
2360	12-Jun-24	TUMKUR	66	LINE	66KV BHARAMGIRI-66KV MATHOD LINE	66KV MATHOD,KANCHIPURA,GARGA PANCHANALLI	19:30	19:50	00:20	TRIPPED ON FAULT
2361	12-Jun-24	TUMKUR	66	LINE	66KV HOLALKERE-66KV PANDARAHALLI LINE 1	66KV CHITRAHALLI,H D PURA	13:30	13:55	00:25	TRIPPED ON FAULT
2362	12-Jun-24	TUMKUR	66	LINE	66KV HOLALKERE-66KV PANDARAHALLI LINE 1	66KV CHITRAHALLI,H D PURA	15:45	16:30	00:45	TRIPPED ON FAULT
2363	12-Jun-24	TUMKUR	66	LINE	66KV MATHOD-220KV HIRIYUR LINE 1	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	19:30	19:45	00:15	TRIPPED ON FAULT
2364	12-Jun-24	TUMKUR	66	LINE	66KV PANDARAHALLI-66KV HOLALKERE LINE	66KV HOLALKERE,CHITRAHALLI,H D PURA	14:04	14:22	00:18	TRIPPED ON FAULT
2365	12-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220- HEBBUR	HEBBUR_66, HONNENAHALLI_66, THIMMASANDRA_66	15:16	16:02	00:46	LINE CLEAR AVAILED
2366	12-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	16:20	17:09	00:49	LINE CLEAR AVAILED
2367	12-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-KEMPANAHALLI	KEMPANAHALLI_66, HAGALKOTE_66,MATTIKERE_66	16:37	17:16	00:39	LINE CLEAR AVAILED
2368	12-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-ANCHEPALYA 1	ANCHEPALYA_66	15:40	16:34	00:54	LINE CLEAR AVAILED
2369	12-Jun-24	TUMKUR	66	LINE	CHIKKAJAJUR-HOLALKERE-1	CHIKKAJAJUR_66	10:15	16:40	06:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2370	12-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV- PANDARAHALLI 1	66KV GOPPENAHALLI,TAVAREKERE	06:08	06:21	00:13	TRIPPED ON FAULT
2371	12-Jun-24	TUMKUR	66	LINE	DEVARAHALLI- KEREKILCHI	DEVARAHALLI_66	13:45	14:30	00:45	LINE CLEAR AVOIDED
2372	12-Jun-24	TUMKUR	66	TRANSFORMER	TR-&TR-2	THIMMASANDRA_66	09:45	17:25	07:40	LINE CLEAR AVOIDED
2373	12-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(100MVA)	ANCHEPALYA_66	11:37	13:12	01:35	LINE CLEAR AVOIDED
2374	12-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(100MVA)	ANCHEPALYA_66	13:14	14:30	01:16	LINE CLEAR AVOIDED
2375	12-Jun-24	TUMKUR	220	LINE	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:08	13:52	02:44	LINE CLEAR AVOIDED
2376	12-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 1KV	GUTTUR_400	02:18	07:25	05:07	LINE CLEAR AVOIDED
2377	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1&HV2(20MVA)	KULAGERI CROSS_110	14:00	14:52	00:52	LINE CLEAR AVOIDED
2378	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BASAVANAKATTI_110	10:50	16:17	05:27	LINE CLEAR AVOIDED
2379	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MUNDAGOD_110	10:03	17:03	07:00	LINE CLEAR AVOIDED
2380	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	NAVALAGI_110	13:00	13:31	00:31	LINE CLEAR AVOIDED
2381	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	BASAVANAKATTI_110	10:50	16:17	05:27	LINE CLEAR AVOIDED
2382	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	HATTARAGI_110	13:53	15:09	01:16	LINE CLEAR AVOIDED
2383	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	HATTARAGI_110	16:03	17:02	00:59	LINE CLEAR AVOIDED
2384	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MALGHAN(B)_110	10:49	10:51	00:02	TRIPPED ON FAULT
2385	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUNDAGOD_110	10:14	17:49	07:35	LINE CLEAR AVOIDED
2386	13-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4(10MVA)	BAGALKOT_220	14:58	15:03	00:05	TRIPPED ON FAULT
2387	13-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVOIDED
2388	13-Jun-24	BAGALKOTE	110	LINE	AMBEWADI- NK2(KAVALWADA)	AMBEWADI_220	12:38	12:40	00:02	LINE CLEAR AVOIDED
2389	13-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVOIDED
2390	13-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-KATARAKI (NEERABUDIHAI)	BAGALKOT_220	15:28	17:11	01:43	TRIPPED ON FAULT
2391	13-Jun-24	BAGALKOTE	110	LINE	BASAVANAKATTI- F1(HAVERI220)	BASAVANAKATTI_110	13:10	16:06	02:56	LINE CLEAR AVOIDED
2392	13-Jun-24	BAGALKOTE	110	LINE	BASAVANAKATTI- F2(GUTTAL)	BASAVANAKATTI_110	13:10	16:07	02:57	LINE CLEAR AVOIDED
2393	13-Jun-24	BAGALKOTE	110	LINE	BASAVANAKATTI- F3(AFPL SOLAR)	BASAVANAKATTI_110	13:10	16:08	02:58	LINE CLEAR AVOIDED
2394	13-Jun-24	BAGALKOTE	110	LINE	BIDNAL220- ANNIGERI	BIDNAL_220	10:08	16:23	06:15	LINE CLEAR AVOIDED
2395	13-Jun-24	BAGALKOTE	110	LINE	DAMBAL- ASE SOLAR(AKHILAGYA)	DAMBAL_110	15:04	15:11	00:07	TRIPPED ON FAULT
2396	13-Jun-24	BAGALKOTE	110	LINE	DAMBAL- ASE SOLAR(AKHILAGYA)	DAMBAL_110	15:15	15:37	00:22	TRIPPED ON FAULT
2397	13-Jun-24	BAGALKOTE	110	LINE	GADAG220-DAMBAL	GADAG_220	10:21	15:50	05:29	LINE CLEAR AVOIDED
2398	13-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVOIDED
2399	13-Jun-24	BAGALKOTE	110	LINE	KUD DHARWAD- LAKMANAHALLI	KUD DHARWAD_110	10:25	14:05	03:40	LINE CLEAR AVOIDED
2400	13-Jun-24	BAGALKOTE	110	LINE	KUDACHI220-SHIRAGUPPI	KUDACHI_220	05:15	05:30	00:15	TRIPPED ON FAULT
2401	13-Jun-24	BAGALKOTE	110	LINE	KUMATA- SIRSI2	KUMATA_110	09:38	17:19	07:41	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2402	13-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
2403	13-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2404	13-Jun-24	BAGALKOTE	110	LINE	MRUTHYUNJAY NAGAR-NARENDRA (UAS)	MRUTHYUNJAY NAGAR_110	09:55	16:57	07:02	LINE CLEAR AVAILED
2405	13-Jun-24	BAGALKOTE	110	LINE	MUNDAGOD- HUBLI	MUNDAGOD_110	10:15	17:01	06:46	LINE CLEAR AVAILED
2406	13-Jun-24	BAGALKOTE	110	LINE	PG HUNSHYAL- SATTISUGARS	PG HUNSHYAL_110	14:13	16:18	02:05	LINE CLEAR AVAILED
2407	13-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)			LINE CLEAR AVAILED
2408	13-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220- BYADAGI	RANEBENNUR_220	15:26	15:37	00:11	LINE CLEAR AVAILED
2409	13-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220- RATTIHALLI	RANEBENNUR_220	15:26	15:36	00:10	LINE CLEAR AVAILED
2410	13-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2411	13-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN- RAMANKOPPA (MUNDAGOD)	SHIGGOAN_110	10:03	17:11	07:08	LINE CLEAR AVAILED
2412	13-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN220- LN2 (MUNDAGOD)	SHIGGOAN_220	15:25	17:01	01:36	LINE CLEAR AVAILED
2413	13-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	09:37	11:42	02:05	TRIPPED ON FAULT
2414	13-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMATA2	SIRSI_110	12:26	17:10	04:44	LINE CLEAR AVAILED
2415	13-Jun-24	BAGALKOTE	110	LINE	SIRSI220- KAVALWAD	SIRSI_220	12:40	14:16	01:36	LINE CLEAR AVAILED
2416	13-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
2417	13-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2418	13-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
2419	13-Jun-24	BAGALKOTE	110	LINE	TAKLI-TIK Cbreaker	TAKKALAKI_110	06:03	06:14	00:11	TRIPPED ON FAULT
2420	13-Jun-24	BAGALKOTE	110	LINE	TARIHAL-SRS HUBLI-1	STATION NOT AFFECTED TARIHAL_110	12:54	12:59	00:05	LINE CLEAR AVAILED
2421	13-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
2422	13-Jun-24	BAGALKOTE	110	LINE	THORVI- TIKOTA	THORVI_110	06:03	06:14	00:11	TRIPPED ON FAULT
2423	13-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
2424	13-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2425	13-Jun-24	BAGALKOTE	110	LINE	YARAGA-KATAKOL	KATAKOL_110	04:23	05:09	00:46	TRIPPED ON FAULT
2426	13-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	SIRSI_220	13:01	13:53	00:52	LINE CLEAR AVAILED
2427	13-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	GHATAPRABHA_220	14:33	15:28	00:55	LINE CLEAR AVAILED
2428	13-Jun-24	BAGALKOTE	220	LINE	CHIKKODI- KUDACHI1	CHIKKODI_220	10:39	13:45	03:06	LINE CLEAR AVAILED
2429	13-Jun-24	BAGALKOTE	220	LINE	KUDACHI- CHIKKODI1	KUDACHI_220	10:40	13:45	03:05	LINE CLEAR AVAILED
2430	13-Jun-24	BAGALKOTE	220	LINE	RANEBENNUR- BALLIGAVI	RANEBENNUR_220	10:30 (13.06.2024)			TRIPPED ON FAULT
2431	13-Jun-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	15:25	15:35	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2432	13-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2433	13-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	A STATION 66	21:38	21:51	00:13	MAIN SUPPLY FAILURE
2434	13-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A2)	A STATION 66	21:38	21:51	00:13	MAIN SUPPLY FAILURE
2435	13-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - KANTEERAVA GIS	KANTEERAVA	21:38	21:52	00:14	MAIN SUPPLY FAILURE
2436	13-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - SHOBHA INDRAPRASHTA (A1)	SHOBHA INDRAPRASHTA	21:38	21:52	00:14	MAIN SUPPLY FAILURE
2437	13-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - VICTORIA	VICTORIA	21:38	21:49	00:11	MAIN SUPPLY FAILURE
2438	13-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	06:18	06:30	00:12	TRIPPED ON FAULT
2439	13-Jun-24	BANGALORE	66	LINE	66KV GOKULA - BEL EHT	BEL(EHT)	13:58	15:07	01:09	TRIPPED ON FAULT
2440	13-Jun-24	BANGALORE	66	LINE	66KV GOKULA - HMT EHT	HMT(EHT)	21:40	22:43	01:03	TRIPPED ON FAULT
2441	13-Jun-24	BANGALORE	66	LINE	66KV HONNIGANAHALLI - HALAGURU	HALAGURU	09:45	09:47	00:02	LINE CLEAR AVAILED
2442	13-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	13:33	15:10	01:37	LINE CLEAR AVAILED
2443	13-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ACCHALU	ACCHALU, HONNIGANAHALLI, HALAGURU	10:15	14:35	04:20	LINE CLEAR AVAILED
2444	13-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:52	11:03	00:11	MAIN SUPPLY FAILURE
2445	13-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:53	11:03	00:10	LINE CLEAR AVAILED
2446	13-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	15:38	15:42	00:04	LINE CLEAR AVAILED
2447	13-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - SANJEEVANADODDI	RANGANADODDI, SANJEEVANADODDI	16:52	16:57	00:05	TRIPPED ON FAULT
2448	13-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1	NO STATION AFFECTED	15:27	16:38	01:11	TRIPPED ON FAULT
2449	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, ADL(EHT), BEST STEELS(EHT)	14:15	14:25	00:10	LINE CLEAR AVAILED
2450	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, ADL(EHT), BEST STEELS(EHT)	18:15	18:20	00:05	LINE CLEAR AVAILED
2451	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA	14:16	14:25	00:09	MAIN SUPPLY FAILURE
2452	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	14:15	14:25	00:10	LINE CLEAR AVAILED
2453	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	18:15	18:20	00:05	LINE CLEAR AVAILED
2454	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	14:16	14:25	00:09	MAIN SUPPLY FAILURE
2455	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	14:15	14:25	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2456	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	18:15	18:20	00:05	LINE CLEAR AVAILED
2457	13-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	14:16	14:25	00:09	MAIN SUPPLY FAILURE
2458	13-Jun-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	10:30	14:15	03:45	LINE CLEAR AVAILED
2459	13-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - BRIGADE GATEWAY (GIS)	BRIGADE GATEWAY	10:14	15:58	05:44	LINE CLEAR AVAILED
2460	13-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - BRIGADE GATEWAY (GIS)	BRIGADE GATEWAY	21:39	22:40	01:01	MAIN SUPPLY FAILURE
2461	13-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - PALLADIUM	PALLADIUM	10:14	16:00	05:46	LINE CLEAR AVAILED
2462	13-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	10:14	16:15	06:01	LINE CLEAR AVAILED
2463	13-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	21:38	22:37	00:59	MAIN SUPPLY FAILURE
2464	13-Jun-24	BANGALORE	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE	12:57	13:08	00:11	TRIPPED ON FAULT
2465	13-Jun-24	BANGALORE	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALAGERE - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE	17:05	18:10	01:05	LINE CLEAR AVAILED
2466	13-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA	10:52	11:01	00:09	TRIPPED ON FAULT
2467	13-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI	10:32	15:42	05:10	LINE CLEAR AVAILED
2468	13-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	SOUTH CITY	10:26	10:32	00:06	LINE CLEAR AVAILED
2469	13-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	21:37	21:58	00:21	MAIN SUPPLY FAILURE
2470	13-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	21:38	22:16	00:38	MAIN SUPPLY FAILURE
2471	13-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT)	REMCO, GLOBAL(EHT)	21:38	21:51	00:13	MAIN SUPPLY FAILURE
2472	13-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	21:38	21:51	00:13	MAIN SUPPLY FAILURE
2473	13-Jun-24	BANGALORE	66	LINE	66KV VIDHURASHWATHA - GUNDLU KOTHUR	GUNDLU KOTTUR	01:55	02:05	00:10	TRIPPED ON FAULT
2474	13-Jun-24	BANGALORE	66	LINE	HBR LAYOUT 220 - POTTERY ROAD	POTTERY ROAD	12:52	14:50	01:58	LINE CLEAR AVAILED
2475	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	POTTERY ROAD	11:12	14:50	03:38	LINE CLEAR AVAILED
2476	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NRS 220	10:20	15:49	05:29	LINE CLEAR AVAILED
2477	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOKULA	09:42	09:46	00:04	LINE CLEAR AVAILED
2478	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NAGANATHPURA 220	10:05	13:40	03:35	LINE CLEAR AVAILED
2479	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ST JOHN WOOD	13:33	15:10	01:37	LINE CLEAR AVAILED
2480	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWNIPALLI	09:50	10:10	00:20	TRIPPED ON FAULT
2481	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	12:00	12:20	00:20	TRIPPED ON FAULT
2482	13-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	11:11	11:15	00:04	LINE CLEAR AVAILED
2483	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NRS 220	10:20	15:49	05:29	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2484	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GOKULA	11:31	11:36	00:05	LINE CLEAR AVAILED
2485	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NAGANATHPURA 220	13:45	13:53	00:08	LINE CLEAR AVAILED
2486	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ST JOHN WOOD	10:54	11:56	01:02	LINE CLEAR AVAILED
2487	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHIKKABALLAPURA I/A	20:49	21:20	00:31	TRIPPED ON FAULT
2488	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NALLIMARADANAHALLI	17:00	17:10	00:10	TRIPPED ON FAULT
2489	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MALLASANDRA(NO LOAD AFFECTED)	09:50	10:10	00:20	TRIPPED ON FAULT
2490	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ACCHALU	00:11	00:16	00:05	TRIPPED ON FAULT
2491	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DABUSPETE 220	16:05	16:35	00:30	LINE CLEAR AVAILED
2492	13-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KGF	10:02	10:10	00:08	LINE CLEAR AVAILED
2493	13-Jun-24	BANGALORE	66	TRANSFORMER	HV3	NRS 220	10:20	15:49	05:29	LINE CLEAR AVAILED
2494	13-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KGF	15:15	15:30	00:15	LINE CLEAR AVAILED
2495	13-Jun-24	BANGALORE	66	TRANSFORMER	HV4	NRS 220	10:20	15:48	05:28	LINE CLEAR AVAILED
2496	13-Jun-24	BANGALORE	66	TRANSFORMER	HV5	NRS 220	10:20	15:49	05:29	LINE CLEAR AVAILED
2497	13-Jun-24	BANGALORE	220	LINE	220KV A STATION 220 - EDC	A STATION 220	21:38	21:43	00:05	TRIPPED ON FAULT
2498	13-Jun-24	BANGALORE	220	LINE	220KV A STATION 220 - NRS 220	A STATION 220	21:38	21:43	00:05	TRIPPED ON FAULT
2499	13-Jun-24	BANGALORE	220	LINE	220KV MANYATA 220 - ITI 220	NO STATION AFFECTED	21:37	22:15	00:38	TRIPPED ON FAULT
2500	13-Jun-24	BANGALORE	220	LINE	220KV NRS 220 - VRUSHABHAVATI 220	NRS 220	10:21	15:40	05:19	LINE CLEAR AVAILED
2501	13-Jun-24	BANGALORE	220	LINE	220KV NRS 220 - VRUSHABHAVATI 220	NO STATION AFFECTED	21:56	23:59	02:03	LINE CLEAR AVAILED
2502	13-Jun-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - TATHAGUNI 220	NO STATION AFFECTED	21:40	22:05	00:25	TRIPPED ON FAULT
2503	13-Jun-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - NRS 220	NRS 220	10:21	16:47	06:26	LINE CLEAR AVAILED
2504	13-Jun-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SAHAKARNAGAR 220	NRS 220	21:38	22:31	00:53	TRIPPED ON FAULT
2505	13-Jun-24	BANGALORE	220	LINE	220KV SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220	21:38	21:51	00:13	TRIPPED ON FAULT
2506	13-Jun-24	BANGALORE	220	TRANSFORMER	HV1	A STATION 220	21:38	21:43	00:05	MAIN SUPPLY FAILURE
2507	13-Jun-24	BANGALORE	220	TRANSFORMER	HV1	NRS 220	10:14	15:41	05:27	LINE CLEAR AVAILED
2508	13-Jun-24	BANGALORE	220	TRANSFORMER	HV2	A STATION 220	21:38	21:43	00:05	MAIN SUPPLY FAILURE
2509	13-Jun-24	BANGALORE	220	TRANSFORMER	HV2	NRS 220	10:14	15:41	05:27	LINE CLEAR AVAILED
2510	13-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MALUR 220	14:16	14:25	00:09	LINE CLEAR AVAILED
2511	13-Jun-24	GULBARGA	66	TRANSFORMER	HV3	ITTAGI_220	13:25	14:21	00:56	LINE CLEAR AVAILED
2512	13-Jun-24	GULBARGA	66	TRANSFORMER	HV5,HV6	MUNIRABAD_220	08:58	16:52	07:54	LINE CLEAR AVAILED
2513	13-Jun-24	GULBARGA	66	LINE	ITTAGI-HB HALLI	HB HALLI_66, BG HALLI_66	18:57	19:07	00:10	TRIPPED ON FAULT
2514	13-Jun-24	GULBARGA	66	LINE	MUNIRABAD-TIE LINE	TB DAM_66	08:55	16:33	07:38	LINE CLEAR AVAILED
2515	13-Jun-24	GULBARGA	66	LINE	MUNIRABAD-UPHALLI	UPANAYAKANAHALLI_66, VENKATAPUR_66	08:57	16:55	07:58	LINE CLEAR AVAILED
2516	13-Jun-24	GULBARGA	110	LINE	HALAWARTHY-HIRESINDOGI	HIRESINDOGI_110	10:00	14:19	04:19	LINE CLEAR AVAILED
2517	13-Jun-24	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALKI_110	17:20	17:30	00:10	TRIPPED ON FAULT
2518	13-Jun-24	GULBARGA	110	TRANSFORMER	HV1	ALIPUR_220	00:28	00:33	00:05	TRIPPED ON FAULT
2519	13-Jun-24	GULBARGA	110	TRANSFORMER	HV3	SOMASAMUDRA_110	09:28	09:40	00:12	TRIPPED ON FAULT
2520	13-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110, CHOWDAPUR_110, RUDRAWADI_110	20:18	20:33	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2521	13-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,CHOWDAPUR_110, RUDRAWADI_110	23:09	23:21	00:12	TRIPPED ON FAULT
2522	13-Jun-24	GULBARGA	110	LINE	KAPNOOR-MADIYAL	MADIYAL_110	13:12	17:54	04:42	LINE CLEAR AVAILED
2523	13-Jun-24	GULBARGA	110	LINE	KAPNOOR-MADIYAL	MADIYAL_110	18:19	20:19	02:00	LINE CLEAR AVAILED
2524	13-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATHI	SANNATHI_IPP	20:45	21:15	00:30	TRIPPED ON FAULT
2525	13-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATHI	SANNATHI_IPP	21:50	22:05	00:15	TRIPPED ON FAULT
2526	13-Jun-24	GULBARGA	110	LINE	KUSHTAGI-BEVOOR	BEVOOR_110	11:05	15:07	04:02	LINE CLEAR AVAILED
2527	13-Jun-24	GULBARGA	110	LINE	MALIYABAD-YERAGERA	YERAGERA_110	19:50	20:05	00:15	TRIPPED ON FAULT
2528	13-Jun-24	GULBARGA	110	LINE	MALLAT-MADLAPUR	ADVIAMRESHWAR_110, MANVI_110	10:28	10:36	00:08	TRIPPED ON FAULT
2529	13-Jun-24	GULBARGA	110	LINE	MALLAT-MADLAPUR	ADVIAMRESHWAR_110, MANVI_110	18:08	18:15	00:07	TRIPPED ON FAULT
2530	13-Jun-24	GULBARGA	110	LINE	MOKA-BELLARY NORTH	MOKA_110,BISIHALLI_110,PD_HALLI_110	03:09	03:14	00:05	TRIPPED ON FAULT
2531	13-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-KONKAL	KONAKAL_110	21:40	21:50	00:10	TRIPPED ON FAULT
2532	13-Jun-24	GULBARGA	110	LINE	SHAHAPUR-DEVAPUR	DEVAPUR_110, SHORAPUR_110	22:53	23:04	00:11	TRIPPED ON FAULT
2533	13-Jun-24	GULBARGA	110	LINE	SHAHAPUR-RTPS2	RTPS_220	22:23	22:42	00:19	TRIPPED ON FAULT
2534	13-Jun-24	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110,SIRIGERICROSS_110	20:16	20:26	00:10	TRIPPED ON FAULT
2535	13-Jun-24	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110,SIRIGERICROSS_110	20:55	21:05	00:10	TRIPPED ON FAULT
2536	13-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	13:16	13:50	00:34	LINE CLEAR AVAILED
2537	13-Jun-24	GULBARGA	110	LINE	SINDHANOOR-WALABALLARI	WALABALLARI_110	10:25	13:10	02:45	LINE CLEAR AVAILED
2538	13-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110,SIRIGERICROSS_110	01:15	01:42	00:27	MAIN SUPPLY FAILURE
2539	13-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	SIRIGERICROSS_110	07:30	07:53	00:23	TRIPPED ON FAULT
2540	13-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	SIRIGERICROSS_110	12:00	14:05	02:05	TRIPPED ON FAULT
2541	13-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110,SIRIGERICROSS_110	22:45	23:05	00:20	TRIPPED ON FAULT
2542	13-Jun-24	GULBARGA	110	LINE	WALKAMDINI-BYAGWAT	WALKAMDINI_110, BYAGWAT_110	18:30	18:37	00:07	LINE CLEAR AVAILED
2543	13-Jun-24	GULBARGA	110	LINE	YERADONA-HANAWAL	YERADONA_110	00:05	00:15	00:10	MAIN SUPPLY FAILURE
2544	13-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
2545	13-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	10:08	10:19	00:11	LINE CLEAR AVAILED
2546	13-Jun-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	08:22	09:31	01:09	LINE CLEAR AVAILED
2547	13-Jun-24	HASSAN	66	TRANSFORMER	HV1	HASSAN_66	11:02	13:19	02:17	LINE CLEAR AVAILED
2548	13-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALLAPURA_66	10:00	18:00	08:00	LINE CLEAR AVAILED
2549	13-Jun-24	HASSAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	12:59	13:11	00:12	TRIPPED ON FAULT
2550	13-Jun-24	HASSAN	66	TRANSFORMER	HV1	SOMANAHALLI_66	17:10	18:24	01:14	LINE CLEAR AVAILED
2551	13-Jun-24	HASSAN	66	TRANSFORMER	HV2	MALLAPURA_66	10:04	18:00	07:56	LINE CLEAR AVAILED
2552	13-Jun-24	HASSAN	66	TRANSFORMER	HV2	SOMANAHALLI_66	17:10	18:24	01:14	LINE CLEAR AVAILED
2553	13-Jun-24	HASSAN	66	LINE	MALLAPU-SHIMOGA	MALLAPURA_66	10:04	12:29	02:25	LINE CLEAR AVAILED
2554	13-Jun-24	HASSAN	66	LINE	MOSALEH-BIOMASS	MOSALEHOSAHALLI_66	10:37	14:14	03:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2555	13-Jun-24	HASSAN	66	LINE	MRSSHM-DVG2	MRSMSG_220	13:30	14:00	00:30	TRIPPED ON FAULT
2556	13-Jun-24	HASSAN	66	LINE	SIGEBAG-KDLGRE	SIGEBAGE_66	13:30	14:07	00:37	TRIPPED ON FAULT
2557	13-Jun-24	HASSAN	66	LINE	SOMNHL-GDNEHALI	SOMANAHALLI_66	08:11	09:30	01:19	LINE CLEAR AVAIED
2558	13-Jun-24	HASSAN	110	LINE	HALADY1-HEGNJE	HALADY_110	11:03	14:14	03:11	LINE CLEAR AVAIED
2559	13-Jun-24	HASSAN	110	LINE	HGUNJE-HALADY	HEGGUNJE_220	11:00	14:14	03:14	LINE CLEAR AVAIED
2560	13-Jun-24	HASSAN	110	TRANSFORMER	HV1	BRAHMAVARA_110	11:12	12:40	01:28	TRIPPED ON FAULT
2561	13-Jun-24	HASSAN	110	TRANSFORMER	HV1	PUTTUR_110	10:07	12:28	02:21	LINE CLEAR AVAIED
2562	13-Jun-24	HASSAN	110	TRANSFORMER	HV2	PUTTUR_110	10:07	12:28	02:21	LINE CLEAR AVAIED
2563	13-Jun-24	HASSAN	220	LINE	HGUNJE-VRHI	HEGGUNJE_220	09:36	16:00	06:24	LINE CLEAR AVAIED
2564	13-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	10:53	12:32	01:39	LINE CLEAR AVAIED
2565	13-Jun-24	HASSAN	220	LINE	MSEZ-GSS3	MSEZ_220	09:45	17:19	07:34	LINE CLEAR AVAIED
2566	13-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:53	12:32	01:39	LINE CLEAR AVAIED
2567	13-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR3	gen_varahi	09:36	16:00	06:24	LINE CLEAR AVAIED
2568	13-Jun-24	MYSORE	66	LINE	BEGUR-B MATKERE	B MATKERE_66	10:25	17:48	07:23	LINE CLEAR AVAIED
2569	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	10:13	12:37	02:24	LINE CLEAR AVAIED
2570	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	09:40	09:57	00:17	MAIN SUPPLY FAILURE
2571	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	HALAGUR_66	15:40	15:50	00:10	MAIN SUPPLY FAILURE
2572	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	11:39	12:00	00:20	LINE CLEAR AVAIED
2573	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	12:05	12:09	00:04	LINE CLEAR AVAIED
2574	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDYA_66	12:36	13:06	00:29	LINE CLEAR AVAIED
2575	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	THUMBLA_66	15:10	17:15	02:05	LINE CLEAR AVAIED
2576	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI_66	10:00	18:55	08:55	LINE CLEAR AVAIED
2577	13-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2578	13-Jun-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	12:33	14:10	01:37	LINE CLEAR AVAIED
2579	13-Jun-24	MYSORE	66	TRANSFORMER	HV2	MANDYA_66	11:48	12:35	00:46	LINE CLEAR AVAIED
2580	13-Jun-24	MYSORE	66	TRANSFORMER	HV2	THUMBLA_66	15:10	17:15	02:05	LINE CLEAR AVAIED
2581	13-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARADANAHALLI_66	10:00	18:55	08:55	LINE CLEAR AVAIED
2582	13-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAIED
2583	13-Jun-24	MYSORE	66	LINE	KADAKOLA-DEVNUR(N'GUD)/GOLUR	DEVANOORNGUDU_66 GOLURU(GEEKALLI)_66 SUTTUR_66	05:56	06:02	00:05	TRIPPED ON FAULT
2584	13-Jun-24	MYSORE	66	LINE	KADAKOLA-JAYAPURA	JAIPUR_66	05:48	06:03	00:14	TRIPPED ON FAULT
2585	13-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	13:34	13:44	00:10	TRIPPED ON FAULT
2586	13-Jun-24	MYSORE	66	LINE	KIRUGAVLU -VADKEPURA	VADKEPURA_66	15:31	17:17	01:46	LINE CLEAR AVAIED
2587	13-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAIED
2588	13-Jun-24	MYSORE	66	LINE	KRPETE-KIKKERI	NO STATIONS EFFECTED	16:49	17:42	00:53	LINE CLEAR AVAIED
2589	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-HARANGI 1	NO STATIONS EFFECTED	05:30	06:20	00:50	TRIPPED ON FAULT
2590	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-HARANGI 1	NO STATIONS EFFECTED	06:31	07:45	01:14	TRIPPED ON FAULT
2591	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-MADIKERI 1	NO STATIONS EFFECTED	05:30	06:20	00:50	TRIPPED ON FAULT
2592	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-MADIKERI 1	NO STATIONS EFFECTED	06:31	07:45	01:14	TRIPPED ON FAULT
2593	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-MYSORE 1	NO STATIONS EFFECTED	07:20	07:30	00:10	LINE CLEAR AVAIED
2594	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-PERIYAPATNA 1	NO STATIONS EFFECTED	05:30	06:20	00:50	TRIPPED ON FAULT
2595	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-PERIYAPATNA 1	NO STATIONS EFFECTED	06:31	07:45	01:14	TRIPPED ON FAULT
2596	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-RAMANATAPURA	ALUR SIDDAPURA_66 KANAGAL_66	05:30	06:20	00:50	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2597	13-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-RAMANATAPURA	ALUR SIDDAPURA_66 KANAGAL_66	06:31	07:45	01:14	TRIPPED ON FAULT
2598	13-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2599	13-Jun-24	MYSORE	66	LINE	MANDAKALLY -RK NAGARA	NO STATIONS EFFECTED	05:45	05:58	00:13	TRIPPED ON FAULT
2600	13-Jun-24	MYSORE	66	LINE	MANDYA-CHIKKAMANDYA	NO STATIONS EFFECTED	12:05	14:27	02:22	LINE CLEAR AVAILED
2601	13-Jun-24	MYSORE	66	LINE	MANDYA-KK HALLI	NO STATIONS EFFECTED	10:40	11:36	00:56	LINE CLEAR AVAILED
2602	13-Jun-24	MYSORE	66	LINE	MANDYA-MADDUR	NO STATIONS EFFECTED	11:38	12:14	00:36	LINE CLEAR AVAILED
2603	13-Jun-24	MYSORE	66	LINE	MANDYA-MADDUR	MADDUR_66, KIADB SOMANAHALLI_66	12:19	12:22	00:03	LINE CLEAR AVAILED
2604	13-Jun-24	MYSORE	66	LINE	MANDYA-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66	11:57	12:08	00:10	LINE CLEAR AVAILED
2605	13-Jun-24	MYSORE	66	LINE	MANDYA-MANDYA 2	NO STATIONS EFFECTED	13:04	13:58	00:54	LINE CLEAR AVAILED
2606	13-Jun-24	MYSORE	66	LINE	MANDYA-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66	11:57	12:08	00:10	LINE CLEAR AVAILED
2607	13-Jun-24	MYSORE	66	LINE	MANDYA-MANDYA 4	NO STATIONS EFFECTED	13:58	14:25	00:26	LINE CLEAR AVAILED
2608	13-Jun-24	MYSORE	66	LINE	PANYADUNDI-KARYA	HEMMARGALA_66, KARYA_66	05:50	05:56	00:06	TRIPPED ON FAULT
2609	13-Jun-24	MYSORE	66	LINE	SANTESARGUR-BEGUR	NO STATIONS EFFECTED	10:22	17:46	07:24	LINE CLEAR AVAILED
2610	13-Jun-24	MYSORE	66	TRANSFORMER	SANTESARGUR-HV1	NO STATIONS EFFECTED	10:00	16:50	06:50	LINE CLEAR AVAILED
2611	13-Jun-24	MYSORE	66	TRANSFORMER	SANTESARGUR-HV2	NO STATIONS EFFECTED	10:00	16:50	06:50	LINE CLEAR AVAILED
2612	13-Jun-24	MYSORE	66	LINE	SANTESARGUR-SUBASH KABINI 1	NO STATIONS EFFECTED	06:03	06:11	00:08	TRIPPED ON FAULT
2613	13-Jun-24	MYSORE	66	LINE	THUMBLA-MEGHALAPURA	NO STATIONS EFFECTED	10:40	17:15	06:35	LINE CLEAR AVAILED
2614	13-Jun-24	MYSORE	66	LINE	VAJMANGALA-MEGLAPURA	MEGALAPURA_66	11:26	11:29	00:03	TRIPPED ON FAULT
2615	13-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220- ANCHEPALYA 2	NO STATIONS EFFECTED	14:29	15:40	01:11	TRIPPED ON FAULT
2616	13-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220- ANCHEPALYA 2	NO STATIONS EFFECTED	16:39	17:28	00:49	TRIPPED ON FAULT
2617	13-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220- ANCHEPALYA 2	NO STATIONS EFFECTED	17:28 (13/06/2024)			TRIPPED ON FAULT
2618	13-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2	66KV HULLENAHALLI,KUDUR,SRIGIR IPURA	06:18	06:30	00:12	TRIPPED ON FAULT
2619	13-Jun-24	TUMKUR	66	LINE	220KV ANTHARASANAHALI - 66KV BELLAVI LINE	66KV CHELUR, NANDHIHALLI, HOSAKERE,HAGALWADI	05:55	06:11	00:16	TRIPPED ON FAULT
2620	13-Jun-24	TUMKUR	66	LINE	220KV CHITRADURGA-66KV PANDARAHALLI LINE 1	66KV BHARAMSAGARA,SIRIGERE,VI JAPURA	14:30	14:35	00:05	TRIPPED ON FAULT
2621	13-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILU R ,	10:33	12:30	01:57	TRIPPED ON FAULT
2622	13-Jun-24	TUMKUR	66	LINE	66KV DYAVARANAHALLI-66KV P R PURA LINE	66KV RANGENAHALLI,P R PURA,KALAMARANAHALLI	13:50	14:25	00:35	TRIPPED ON FAULT
2623	13-Jun-24	TUMKUR	66	LINE	66KV J N KOTE-66KV MALLAPANAHALLI LINE	66KV AIMANGALA,MALLAPANAHALLI	18:50	18:56	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2624	13-Jun-24	TUMKUR	66	LINE	66KV KEREKILACHI-66KV SHYGALE LINE	66KV SHYGALE	16:30	16:35	00:05	TRIPPED ON FAULT
2625	13-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	12:40	12:50	00:10	TRIPPED ON FAULT
2626	13-Jun-24	TUMKUR	66	LINE	66KV SANTHEBENNUR-66KV KEREKILACHI LINE	66KV KEREKILACHI,SHYGALE	13:05	13:10	00:05	TRIPPED ON FAULT
2627	13-Jun-24	TUMKUR	66	LINE	DAVANGERE 220-ANGODU	ANGODU_66, ATTIGE_66	09:42	19:03	09:21	LINE CLEAR AVAILED
2628	13-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS _ MAYAKONDA	MAYAKONDA_66, SASALUHALLA_66	14:34	15:52	01:18	LINE CLEAR AVAILED
2629	13-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:15	18:49	03:34	LINE CLEAR AVAILED
2630	13-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	10:12	18:50	08:38	LINE CLEAR AVAILED
2631	13-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	09:42	24:00:00	14:18	LINE CLEAR AVAILED
2632	13-Jun-24	TUMKUR	66	LINE	GARAGA-MTHD PANCHLI	GARAGA_66	10:15	17:00	06:45	LINE CLEAR AVAILED
2633	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- ENERCON-1&2	ENERCON1_IPP_66	14:42	16:39	01:57	LINE CLEAR AVAILED
2634	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD 1	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	11:46	16:20	04:34	LINE CLEAR AVAILED
2635	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD 2	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	11:47	17:34	05:47	LINE CLEAR AVAILED
2636	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	14:37	16:40	02:03	LINE CLEAR AVAILED
2637	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- SUZLON 2	SUZLON1_IPP_66	14:35	16:41	02:06	LINE CLEAR AVAILED
2638	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	08:10	17:42	09:32	LINE CLEAR AVAILED
2639	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	14:32	16:44	02:12	LINE CLEAR AVAILED
2640	13-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- SIRA(RANGANATHAPURA)	SIRA_66	11:20	17:31	06:11	LINE CLEAR AVAILED
2641	13-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	10:30	15:46	05:16	LINE CLEAR AVAILED
2642	13-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	16:02	16:25	00:23	LINE CLEAR AVAILED
2643	13-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	16:02	16:25	00:23	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2644	13-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	13:50	16:33	02:43	LINE CLEAR AVAILED
2645	13-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	16:02	16:25	00:23	LINE CLEAR AVAILED
2646	13-Jun-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	14:01	17:25	03:24	LINE CLEAR AVAILED
2647	13-Jun-24	TUMKUR	66	LINE	KURUBARAHALLI- TELAGI	KURUBARAHALLI_66	04:02	04:17	00:15	MAIN SUPPLY FAILURE
2648	13-Jun-24	TUMKUR	220	LINE	220KV ANCHEPALYA- 220KV NAGAMANGALA LINE 2	ANCHEPALYA_220	16:39	Line not yet be Charged		TRIPPED ON FAULT
2649	13-Jun-24	TUMKUR	220	LINE	220KV ANCHEPALYA- 220KV NAGAMANGALA LINE 2	ANCHEPALYA_220	14:29	15:27	00:58	TRIPPED ON FAULT
2650	13-Jun-24	TUMKUR	220	LINE	400KV GUTTUR -220KV RANEBENNUR LINE	RANEBENNUR_220	15:23	15:36	00:13	TRIPPED ON FAULT
2651	13-Jun-24	TUMKUR	220	LINE	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	10:16	13:16	03:00	LINE CLEAR AVAILED
2652	13-Jun-24	TUMKUR	220	LINE	HIRIYUR220- MADHUGIRI(GOWRIBIDANURU)	MADHUGIRI_220	16:57	18:18	01:21	LINE CLEAR AVAILED
2653	13-Jun-24	TUMKUR	220	LINE	THALLAK 220KV -HIRIYUR	SANEKERE_66, THALLAKK_220	09:47	13:18	03:31	LINE CLEAR AVAILED
2654	13-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(100MVA)	HONNALLI_220	16:02	16:22	00:20	LINE CLEAR AVAILED
2655	13-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(100MVA)	ANTHARASANAHALI_220	10:13	19:02	08:49	LINE CLEAR AVAILED
2656	14-Jun-24	BAGALKOTE	66	LINE	HARIHARHOSPET- DAVANGERI(GUTTUR)	HARIHARHOSPET_66	11:56	12:18	00:22	LINE CLEAR AVAILED
2657	14-Jun-24	BAGALKOTE	66	LINE	HARIHARHOSPET- DAVANGERI(GUTTUR)	HARIHARHOSPET_66	16:37	17:26	00:49	LINE CLEAR AVAILED
2658	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	KHADAKLAT_110	13:59	14:35	00:36	LINE CLEAR AVAILED
2659	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	ZALKI_110	06:32	05:30	04:12	LINE CLEAR AVAILED
2660	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ITNAL_110	15:37	16:21	00:44	LINE CLEAR AVAILED
2661	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	HUDLI_110	15:06	15:48	00:42	LINE CLEAR AVAILED
2662	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MAMADAPUR(G)_110	08:57	09:29	00:32	LINE CLEAR AVAILED
2663	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALGHATAGI_110	05:49	05:57	00:08	TRIPPED ON FAULT
2664	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KALGHATAGI_110	11:15	17:02	05:47	LINE CLEAR AVAILED
2665	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KIRUVATTI_110	10:34	16:15	05:41	LINE CLEAR AVAILED
2666	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	TAKKALAKI_110	17:49	18:17	00:28	LINE CLEAR AVAILED
2667	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	ZALKI_110	14:30	14:40	00:10	TRIPPED ON FAULT
2668	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	ZALKI_110	10:37	11:21	00:44	TRIPPED ON FAULT
2669	14-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	GADAG_110	10:31	11:14	00:43	LINE CLEAR AVAILED
2670	14-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
2671	14-Jun-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	08:01	14:13	06:12	TRIPPED ON FAULT
2672	14-Jun-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	15:32	18:45	03:13	TRIPPED ON FAULT
2673	14-Jun-24	BAGALKOTE	110	LINE	ATHARGA- BAGEWADI(HIREMASALI)	ATHARGA_110	15:43	15:49	00:06	LINE CLEAR AVAILED
2674	14-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
2675	14-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	14:34	15:40	01:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2676	14-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
2677	14-Jun-24	BAGALKOTE	110	LINE	HUBLI220-RAMANKOPPA	HUBLI_220	10:14	17:33	07:19	LINE CLEAR AVAILED
2678	14-Jun-24	BAGALKOTE	110	LINE	HUNGUND- ILKAL2	HUNGUND_110	00:01	00:22	00:21	TRIPPED ON FAULT
2679	14-Jun-24	BAGALKOTE	110	LINE	INDI220- LACHYAN	INDI_220	00:10	00:17	00:07	TRIPPED ON FAULT
2680	14-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
2681	14-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2682	14-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN11(NAGNUR)	MUGALKHOD_220	08:09	08:36	00:27	TRIPPED ON FAULT
2683	14-Jun-24	BAGALKOTE	110	LINE	MUNAVALLI- SOUDATTI(ARATAGAL)	MUNAVALLI_110	10:40	17:20	06:40	LINE CLEAR AVAILED
2684	14-Jun-24	BAGALKOTE	110	LINE	PG HUNSHYAL- SATTI SUGARS	PG HUNSHYAL_110	11:22	14:00	02:38	LINE CLEAR AVAILED
2685	14-Jun-24	BAGALKOTE	110	LINE	RAMANKO-DUNDASI	STATION NOT AFFECTED RAMANAKOPPA_110	10:52 (25.04.2024)	17:40 (14.06.2024)		LINE CLEAR AVAILED
2686	14-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2687	14-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN220-LN1(DUNDASI)	SHIGGOAN_220	10:14	15:59	05:45	LINE CLEAR AVAILED
2688	14-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
2689	14-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2690	14-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
2691	14-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
2692	14-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
2693	14-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2694	14-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MELLIGERI	VAJRAMATTI_220	07:28	20:53	13:25	LINE CLEAR AVAILED
2695	14-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV HV1&LV1,HV2&LV2	HAVERI_220	10:27	18:45	08:18	LINE CLEAR AVAILED
2696	14-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	KUDACHI_220	12:17	16:05	03:48	LINE CLEAR AVAILED
2697	14-Jun-24	BAGALKOTE	220	TRANSFORMER	400/220KV,ICT1(LV)	DHONI_400	11:45	17:14	05:29	LINE CLEAR AVAILED
2698	14-Jun-24	BAGALKOTE	220	LINE	AEQUS-KANAGALA1	AEQUS_220	10:55	12:22	01:27	LINE CLEAR AVAILED
2699	14-Jun-24	BAGALKOTE	220	LINE	AEQUS-KANAGALA2	AEQUS_220	12:34	15:30	02:56	LINE CLEAR AVAILED
2700	14-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	10:17	19:19	09:02	LINE CLEAR AVAILED
2701	14-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR1	HAVERI_220	19:49	20:02	00:13	LINE CLEAR AVAILED
2702	14-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	10:17	19:19	09:02	LINE CLEAR AVAILED
2703	14-Jun-24	BAGALKOTE	220	LINE	KANAGALA- AEQUS1	KANAGALA_220	10:57	12:12	01:15	LINE CLEAR AVAILED
2704	14-Jun-24	BAGALKOTE	220	LINE	RANEENNUR- BALLIGAVI	RANEENNUR_220	10:30 (13.06.2024)	15:20 (14.06.2024)	04:50:00	TRIPPED ON FAULT
2705	14-Jun-24	BAGALKOTE	220	LINE	SHIGGOAN- HAVERI	SHIGGOAN_220	10:25	18:48	08:23	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2706	14-Jun-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHI1	SIRSI_220	11:04	14:16	03:12	LINE CLEAR AVAILED
2707	14-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2708	14-Jun-24	BAGALKOTE	400	TRANSFORMER	400/220KV,ICT1(HV)	DHONI_400	11:46	17:14	05:28	LINE CLEAR AVAILED
2709	14-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 1	BAGHMANE WORLD TECH PARK	10:00	10:10	00:10	LINE CLEAR AVAILED
2710	14-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 2	BAGHMANE WORLD TECH PARK	10:00	10:10	00:10	LINE CLEAR AVAILED
2711	14-Jun-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI	11:40	12:30	00:50	MAIN SUPPLY FAILURE
2712	14-Jun-24	BANGALORE	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI 66, JIGANI LINK ROAD	11:40	12:30	00:50	TRIPPED ON FAULT
2713	14-Jun-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST	10:09	13:44	03:35	LINE CLEAR AVAILED
2714	14-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SADHALI	SADALI	05:34	05:46	00:12	TRIPPED ON FAULT
2715	14-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - AKKURMOLE	AKKURMOLE	10:00	15:00	05:00	LINE CLEAR AVAILED
2716	14-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	DEVARABISANAHALLI	13:04	14:06	01:02	LINE CLEAR AVAILED
2717	14-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	GLOBAL TECH PARK	12:54	14:18	01:24	LINE CLEAR AVAILED
2718	14-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	12:52	12:54	00:02	LINE CLEAR AVAILED
2719	14-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	14:09	14:19	00:10	LINE CLEAR AVAILED
2720	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	IIsc	08:58	09:08	00:10	LINE CLEAR AVAILED
2721	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GLOBAL TECH PARK	11:15	14:18	03:03	LINE CLEAR AVAILED
2722	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BUDIGERE	18:54	19:01	00:07	LINE CLEAR AVAILED
2723	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SULIBELE	10:05	10:10	00:05	TRIPPED ON FAULT
2724	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHEEMANGALA	12:35	12:40	00:05	LINE CLEAR AVAILED
2725	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	17:18	17:25	00:07	LINE CLEAR AVAILED
2726	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KEMBODI	07:30	08:30	01:00	LINE CLEAR AVAILED
2727	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	13:15	13:20	00:05	LINE CLEAR AVAILED
2728	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GODUR	12:20	12:25	00:05	TRIPPED ON FAULT
2729	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KANAKAPURA 66	10:30	10:35	00:05	LINE CLEAR AVAILED
2730	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	19:17	19:27	00:10	TRIPPED ON FAULT
2731	14-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	23:03	23:08	00:05	TRIPPED ON FAULT
2732	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	IIsc	11:12	11:17	00:05	LINE CLEAR AVAILED
2733	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOODY 220	14:55	15:56	01:01	TRIPPED ON FAULT
2734	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GLOBAL TECH PARK	10:00	14:18	04:18	LINE CLEAR AVAILED
2735	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHEEMANGALA	15:10	15:15	00:05	LINE CLEAR AVAILED
2736	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	G KODIHALLI	16:01	16:06	00:05	LINE CLEAR AVAILED
2737	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KGF	10:02	10:10	00:08	LINE CLEAR AVAILED
2738	14-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANAKAPURA 66	11:50	13:55	02:05	LINE CLEAR AVAILED
2739	14-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KGF	15:15	15:30	00:15	LINE CLEAR AVAILED
2740	14-Jun-24	BANGALORE	220	TRANSFORMER	HV1	JIGANI 220	11:40	12:15	00:35	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2741	14-Jun-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	11:40	12:30	00:50	TRIPPED ON FAULT
2742	14-Jun-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	11:55	12:05	00:10	TRIPPED ON FAULT
2743	14-Jun-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	18:15	18:20	00:05	TRIPPED ON FAULT
2744	14-Jun-24	GULBARGA	66	LINE	ITTAGGI-HIREHADAGALLI1	HIREHADAGALLI_66,SOVENHALLI_66,GIRIYAPUR_66,MAGALA_66	15:05	15:30	00:25	TRIPPED ON FAULT
2745	14-Jun-24	GULBARGA	110	LINE	ALIPUR-BELLARY NORTH	SOMASAMUNDRA_110,BELLARY NORTH_110,PD_HALLI_110,MOKA_110	05:33	05:46	00:13	TRIPPED ON FAULT
2746	14-Jun-24	GULBARGA	110	LINE	BISIHALLI-BELLARY NORTH	BISIHALLI_110	11:28	12:12	00:44	LINE CLEAR AVAILED
2747	14-Jun-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110,GUGAL_110	05:57	15:01	09:04	TRIPPED ON FAULT
2748	14-Jun-24	GULBARGA	110	LINE	GULBARGA SOUTH-FARTHABAD	FARTHABAD_110	02:30	02:40	00:10	TRIPPED ON FAULT
2749	14-Jun-24	GULBARGA	110	TRANSFORMER	HV1	VENKATAGIRI_110	12:05	12:55	00:50	LINE CLEAR AVAILED
2750	14-Jun-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	SIRIGERICROSS_110	10:15	18:40	08:25	LINE CLEAR AVAILED
2751	14-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110,RUDRAWADI_110	00:22	00:50	00:28	TRIPPED ON FAULT
2752	14-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110,RUDRAWADI_110	01:24	01:48	00:24	TRIPPED ON FAULT
2753	14-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110,RUDRAWADI_110	23:19	23:33	00:14	TRIPPED ON FAULT
2754	14-Jun-24	GULBARGA	110	LINE	KHANAPUR-SANNATHI	SANNATHI_IPP	20:06	20:15	00:09	TRIPPED ON FAULT
2755	14-Jun-24	GULBARGA	110	LINE	KHANAPUR-SIRWAL	SIRWAL_110	01:35	01:45	00:10	TRIPPED ON FAULT
2756	14-Jun-24	GULBARGA	110	LINE	KUSHTAGI-ILKAL2	ILKAL_110	00:02	00:22	00:20	TRIPPED ON FAULT
2757	14-Jun-24	GULBARGA	110	LINE	MALLAT-MADLAPUR	ADVAMRESHWAR_110,MANVI_110	18:10	18:20	00:10	TRIPPED ON FAULT
2758	14-Jun-24	GULBARGA	110	LINE	MALLAT-SIRWAR	SIRWAR_110	22:00	22:05	00:05	TRIPPED ON FAULT
2759	14-Jun-24	GULBARGA	110	LINE	PD_HALLI-ALIPUR	PD_HALLI_110	05:33	05:42	00:09	MAIN SUPPLY FAILURE
2760	14-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-KONKAL	KONKAL_110	19:52	20:10	00:18	TRIPPED ON FAULT
2761	14-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-YADGIR	YADGIR_110	05:00	05:04	00:04	TRIPPED ON FAULT
2762	14-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-YADGIR	YADGIR_110	20:42	21:14	00:32	TRIPPED ON FAULT
2763	14-Jun-24	GULBARGA	110	LINE	RAMASAMUNDRA-YADGIR	YADGIR_110	21:15	22:03	00:48	TRIPPED ON FAULT
2764	14-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	00:34	00:43	00:09	TRIPPED ON FAULT
2765	14-Jun-24	GULBARGA	110	LINE	SOMASAMUNDRA-BELLARY NORTH	SOMASAMUNDRA_110,BELLARY NORTH_110,PD_HALLI_110,MOKA_110	13:03	13:30	00:27	LINE CLEAR AVAILED
2766	14-Jun-24	GULBARGA	110	LINE	SOMASAMUNDRA-BELLARY NORTH	SOMASAMUNDRA_110,BELLARY NORTH_110,PD_HALLI_110,MOKA_110	05:33	05:52	00:19	TRIPPED ON FAULT
2767	14-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110,SIRIGERICROSS_110	10:34	10:45	00:11	MAIN SUPPLY FAILURE
2768	14-Jun-24	GULBARGA	110	LINE	TORANGALU-KIADB	KUDITINI_110,METRI_110,TORANGALU_110	08:25	08:45	00:20	MAIN SUPPLY FAILURE
2769	14-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUNDRA	YADGIR_110	02:10	02:20	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2770	14-Jun-24	GULBARGA	110	LINE	YERADONA-HANAWAL	HANAWAL_110,MARALIHALLI_110	18:45	18:57	00:12	TRIPPED ON FAULT
2771	14-Jun-24	GULBARGA	220	TRANSFORMER	HV1	SHAHAPUR_220	21:45(14.06.2024)			TRIPPED ON FAULT
2772	14-Jun-24	GULBARGA	220	LINE	ITTAGGI-EMBASSY LINE	EMBASSY_IPP	10:11	10:49	00:38	LINE CLEAR AVAIED
2773	14-Jun-24	GULBARGA	220	LINE	ITTAGGI-LINGAPUR	LINGAPUR_220	10:09	10:25	00:16	TRIPPED ON FAULT
2774	14-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
2775	14-Jun-24	GULBARGA	220	LINE	SINDHANOOR-SINDHANOOR2	SINDHANOOR_110	10:15	13:30	03:15	LINE CLEAR AVAIED
2776	14-Jun-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	10:00	10:30	00:30	LINE CLEAR AVAIED
2777	14-Jun-24	HASSAN	66	LINE	HNPURA-SOMANAHALLI	HNPURA_66	11:05	11:25	00:20	LINE CLEAR AVAIED
2778	14-Jun-24	HASSAN	66	TRANSFORMER	HV1	BALLUPETE_66	10:30	11:00	00:30	LINE CLEAR AVAIED
2779	14-Jun-24	HASSAN	66	TRANSFORMER	LV2	MRSMSG_220	09:26	18:00	08:34	LINE CLEAR AVAIED
2780	14-Jun-24	HASSAN	66	TRANSFORMER	LV3	MRSMSG_220	10:00	18:00	08:00	LINE CLEAR AVAIED
2781	14-Jun-24	HASSAN	66	TRANSFORMER	LV4	MRSMSG_220	10:00	18:00	08:00	LINE CLEAR AVAIED
2782	14-Jun-24	HASSAN	66	LINE	SOMNHL-GDNEHALI	SOMANAHALLY-66	11:00	11:32	00:32	LINE CLEAR AVAIED
2783	14-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE-110	14:50	15:20	00:30	MAIN SUPPLY FAILURE
2784	14-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE-110	16:40	17:30	00:50	MAIN SUPPLY FAILURE
2785	14-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR_110	10:45	10:50	00:05	TRIPPED ON FAULT
2786	14-Jun-24	HASSAN	110	TRANSFORMER	GURUVA-SLVPWR	GURUVAYANKERE-110	11:25	12:50	01:25	LINE CLEAR AVAIED
2787	14-Jun-24	HASSAN	110	TRANSFORMER	HV2	MRSMSG_220	09:26	18:00	08:34	LINE CLEAR AVAIED
2788	14-Jun-24	HASSAN	110	TRANSFORMER	HV3	MRSMSG_220	10:00	18:00	08:00	LINE CLEAR AVAIED
2789	14-Jun-24	HASSAN	110	TRANSFORMER	HV4	MRSMSG_220	10:00	18:00	08:00	LINE CLEAR AVAIED
2790	14-Jun-24	HASSAN	110	TRANSFORMER	LV1	MRSMSG_220	09:20	17:02	07:42	LINE CLEAR AVAIED
2791	14-Jun-24	HASSAN	110	LINE	MRSSHM-MYSORE	MRSMSG_220	09:48	17:09	07:21	LINE CLEAR AVAIED
2792	14-Jun-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMSG_220	09:12	09:14	00:02	LINE CLEAR AVAIED
2793	14-Jun-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMSG_220	14:59	15:02	00:03	TRIPPED ON FAULT
2794	14-Jun-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMSG_220	17:21	17:23	00:02	LINE CLEAR AVAIED
2795	14-Jun-24	HASSAN	110	LINE	MRSSHM-SS2	MRSMSG_220	09:15	09:16	00:01	LINE CLEAR AVAIED
2796	14-Jun-24	HASSAN	110	LINE	MRSSHM-SS2	MRSMSG_220	17:19	17:21	00:02	LINE CLEAR AVAIED
2797	14-Jun-24	HASSAN	110	LINE	MSEZ-KAVOOR	MSEZ_220	09:53	13:39	03:46	LINE CLEAR AVAIED
2798	14-Jun-24	HASSAN	220	LINE	HGUNJE-VRH	HEGGUNJE_220	10:22	17:29	07:07	LINE CLEAR AVAIED
2799	14-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	09:20	17:00	07:40	LINE CLEAR AVAIED
2800	14-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR3	gen_varahi	10:20	17:30	07:10	LINE CLEAR AVAIED
2801	14-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	10:47	13:11	02:24	TRIPPED ON FAULT
2802	14-Jun-24	HASSAN	400	LINE	HBNHL-UP1	HEBBANAHALLY_220	09:51	15:37	05:46	LINE CLEAR AVAIED
2803	14-Jun-24	HASSAN	400	LINE	HBNHL-UP2	HEBBANAHALLY_220	15:45	18:54	03:09	LINE CLEAR AVAIED
2804	14-Jun-24	HASSAN	400	LINE	UPCL-HASSAN1	gen_upcl	09:51	15:38	05:47	LINE CLEAR AVAIED
2805	14-Jun-24	HASSAN	400	LINE	UPCL-HASSAN2	gen_upcl	15:46	18:54	03:08	LINE CLEAR AVAIED
2806	14-Jun-24	MYSORE	66	LINE	BILIKERE-GVGUDI	GVGUDI_66	16:21	19:57	03:35	LINE CLEAR AVAIED
2807	14-Jun-24	MYSORE	66	LINE	CRNAGAR-GUNDLUPETE	TERAKANAMBI_66	10:13	17:16	07:03	LINE CLEAR AVAIED
2808	14-Jun-24	MYSORE	66	LINE	CRNAGAR-HONNALLI	HONNALLI_66 ARAKALAWADI_66 ATTIGULIPURA_66	07:26	07:35	00:09	TRIPPED ON FAULT
2809	14-Jun-24	MYSORE	66	LINE	HADLI-TUBINKERE	HADLI_66	10:03	16:48	06:44	LINE CLEAR AVAIED
2810	14-Jun-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	13:26	14:53	01:27	LINE CLEAR AVAIED
2811	14-Jun-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	10:54	12:13	01:19	LINE CLEAR AVAIED
2812	14-Jun-24	MYSORE	66	TRANSFORMER	HV1	HAMPAPURA_66	18:51	19:17	00:26	LINE CLEAR AVAIED
2813	14-Jun-24	MYSORE	66	TRANSFORMER	HV1	PANDAVAPURA_66	17:01	17:35	00:34	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2814	14-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI_66	09:55	11:25	01:30	LINE CLEAR AVAILED
2815	14-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
2816	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	HAMPAPURA_66	12:13	18:50	06:37	LINE CLEAR AVAILED
2817	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	PANDAVAPURA_66	17:36	18:44	01:07	LINE CLEAR AVAILED
2818	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	SFCSIVA_66	10:15	12:09	01:54	LINE CLEAR AVAILED
2819	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	SUTTUR_66	16:29	16:48	00:19	TRIPPED ON FAULT
2820	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	SUTTUR_66	16:48	18:10	01:21	LINE CLEAR AVAILED
2821	14-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARADANAHALLI_66	11:30	11:35	00:05	LINE CLEAR AVAILED
2822	14-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
2823	14-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
2824	14-Jun-24	MYSORE	66	TRANSFORMER	KR PETE 220-HV1	NO STATIONS EFFECTED	12:27	13:30	01:03	LINE CLEAR AVAILED
2825	14-Jun-24	MYSORE	66	LINE	KR PETE 220-KRPETE1	AKKIHEBBAL_66 KIKKER_66 KRPETE_66	14:42	14:49	00:07	TRIPPED ON FAULT
2826	14-Jun-24	MYSORE	66	LINE	KR PETE 220-KRPETE2	AKKIHEBBAL_66 KIKKER_66 KRPETE_66	14:42	14:55	00:13	TRIPPED ON FAULT
2827	14-Jun-24	MYSORE	66	LINE	KR PETE 220-KRPETE2	NO STATIONS EFFECTED	15:11	15:56	00:44	LINE CLEAR AVAILED
2828	14-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
2829	14-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	16:28	16:42	00:14	TRIPPED ON FAULT
2830	14-Jun-24	MYSORE	66	LINE	THUMBLA-VYASARAJAPURA	VYASARAJAPURA_66 THUMBLA_66 GARGESHWARI_66	10:05	17:25	07:20	LINE CLEAR AVAILED
2831	14-Jun-24	MYSORE	220	TRANSFORMER	KR PETE 220-HV1	NO STATIONS EFFECTED	10:32	13:50	03:17	LINE CLEAR AVAILED
2832	14-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 1	NO STATIONS EFFECTED	11:40	15:02	03:22	LINE CLEAR AVAILED
2833	14-Jun-24	MYSORE	220	LINE	NAGAMANGALA 220-ANCHEPALYA 2	NO STATIONS EFFECTED	17:28 (13/06/2024)	15:02 (14/06/2024)	21:34	TRIPPED ON FAULT
2834	14-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA,SASALUHALLA,C HIKKAJAJUR	06:33	06:43	00:10	TRIPPED ON FAULT
2835	14-Jun-24	TUMKUR	66	LINE	220KV SIRA-66KV TAVAREKERE LINE	66KV TAVAREKERE	05:43	06:10	00:27	TRIPPED ON FAULT
2836	14-Jun-24	TUMKUR	66	LINE	66KV KEREILACHI-66KV SHYGALE LINE	WATER SUPPLY	17:20	17:30	00:10	TRIPPED ON FAULT
2837	14-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	11:54	15:15	03:21	LINE CLEAR AVAILED
2838	14-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:03	16:28	05:25	LINE CLEAR AVAILED
2839	14-Jun-24	TUMKUR	66	LINE	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DEVARABELAKERE_66	11:03	16:28	05:25	LINE CLEAR AVAILED
2840	14-Jun-24	TUMKUR	66	LINE	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	10:46	11:03	00:17	LINE CLEAR AVAILED
2841	14-Jun-24	TUMKUR	220	LINE	220KV ANCHEPALYA- 220KV NAGAMANGALA LINE 2	ANCHEPALYA_220	16:39 (13.06.2024)	15:01 (14.06.2024)	22:22	TRIPPED ON FAULT
2842	14-Jun-24	TUMKUR	220	LINE	ANCHEPALYA 220KV-NAGAMANGALA1	NAGAMANGALA_220	11:40	15:02	03:22	LINE CLEAR AVAILED
2843	14-Jun-24	TUMKUR	220	LINE	ANCHEPALYA 220KV-NELMANGALA 2 (MAGADI)	MAGADI_220	12:14	14:06	01:52	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2844	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20 MVA)	ZALKI_110	16:05	17:04	00:59	LINE CLEAR AVAILED
2845	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KADANKOPPA_110	13:48	17:30	03:42	LINE CLEAR AVAILED
2846	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	TAKKALAKI_110	15:14	15:30	00:16	TRIPPED ON FAULT
2847	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	BAGALKOT_110	11:30	13:18	01:48	TRIPPED ON FAULT
2848	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2A(10MVA)	JAMKHANDI_110	18:08	18:16	00:08	LINE CLEAR AVAILED
2849	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA)	SIRSI_110	12:29	12:35	00:06	LINE CLEAR AVAILED
2850	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1(10MVA)	JAMKHANDI_110	10:11	18:20	08:09	LINE CLEAR AVAILED
2851	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	JAMKHANDI_110	10:11	18:21	08:10	LINE CLEAR AVAILED
2852	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10MVA)	ZALKI_110	13:37	14:00	00:23	LINE CLEAR AVAILED
2853	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10MVA)	ZALKI_110	17:56	18:52	00:56	LINE CLEAR AVAILED
2854	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4 (20MVA2)	ZALKI_110	13:28	14:57	01:29	LINE CLEAR AVAILED
2855	15-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4 (20MVA2)	ZALKI_110	18:57	19:33	00:36	LINE CLEAR AVAILED
2856	15-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
2857	15-Jun-24	BAGALKOTE	110	LINE	ATHANI220-KSSKN LINE	ATHANI_220	14:43	15:04	00:21	TRIPPED ON FAULT
2858	15-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
2859	15-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- BHOJ(NANADI)	CHIKKODI_220	05:48	06:26	00:38	TRIPPED ON FAULT
2860	15-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
2861	15-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
2862	15-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2863	15-Jun-24	BAGALKOTE	110	LINE	NVLGI-F1CBreaker(JMKD)	JAMAKHANDI_110 STATION NOT AFFECTED NAVALAGI_110	10:06	18:00	07:54	LINE CLEAR AVAILED
2864	15-Jun-24	BAGALKOTE	110	LINE	RANEBENNUR220- RATTIHALLI (TUMMINKATTE)	RANEBENNUR_220	15:25	17:04	01:39	LINE CLEAR AVAILED
2865	15-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
2866	15-Jun-24	BAGALKOTE	110	LINE	SIRSI-ESALE1	SIRSI_110	12:30	12:59	00:29	LINE CLEAR AVAILED
2867	15-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
2868	15-Jun-24	BAGALKOTE	110	LINE	SIRSI-KUMATA2	SIRSI_110	12:29	12:35	00:06	LINE CLEAR AVAILED
2869	15-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
2870	15-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
2871	15-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2872	15-Jun-24	BAGALKOTE	110	LINE	TODALB-JAMKHANDI	KAMBAGI_110 STATION NOT AFFECTED_110 TODALBAGI_110	08:43	09:01	00:18	TRIPPED ON FAULT
2873	15-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
2874	15-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI- KAVATAGI LIS	VAJRAMATTI_220	10:46	16:53	06:07	LINE CLEAR AVAILED
2875	15-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
2876	15-Jun-24	BAGALKOTE	220	LINE	AMBEWADI- PONDA2	AMBEWADI_220	11:36	12:20	00:44	TRIPPED ON FAULT
2877	15-Jun-24	BAGALKOTE	220	LINE	BIDNAL- NAGJHARI	BIDNAL_220	12:04	15:10	03:06	TRIPPED ON FAULT
2878	15-Jun-24	BAGALKOTE	220	LINE	GHATAPRABHA- NARENDRA1	GHATAPRABHA_220	13:54	16:42	02:48	LINE CLEAR AVAILED
2879	15-Jun-24	BAGALKOTE	220	LINE	HAVERI- GUTTUR2	HAVERI_220	10:02	15:44	05:42	LINE CLEAR AVAILED
2880	15-Jun-24	BAGALKOTE	220	LINE	RANEBENNUR- GUTTUR	RANEBENNUR_220	15:43	16:44	01:01	LINE CLEAR AVAILED
2881	15-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
2882	15-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- KAVATAGI LIS	VAJRAMATTI_220	15:23	17:29	02:06	LINE CLEAR AVAILED
2883	15-Jun-24	BANGALORE	66	LINE	66KV DG3_ MANYATA 220 - MANYATA 66	MANYATHA TECH PARK 66	11:14	16:09	04:55	LINE CLEAR AVAILED
2884	15-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL	11:13	13:48	02:35	LINE CLEAR AVAILED
2885	15-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA	BELL CERAMICS	14:51	16:25	01:34	LINE CLEAR AVAILED
2886	15-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	18:48	19:15	00:27	TRIPPED ON FAULT
2887	15-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTINIKETHAN	10:00	10:05	00:05	LINE CLEAR AVAILED
2888	15-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN	PRESTIGE SHANTINIKETHAN	18:12	18:16	00:04	LINE CLEAR AVAILED
2889	15-Jun-24	BANGALORE	66	LINE	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	09:40	09:44	00:04	LINE CLEAR AVAILED
2890	15-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	10:30	15:15	04:45	LINE CLEAR AVAILED
2891	15-Jun-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST	10:07	10:12	00:05	LINE CLEAR AVAILED
2892	15-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - CHATHRA - MARALAVADI - HANUMANTHANAGARA	MARALAVADI, CHATRA	10:38	15:15	04:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2893	15-Jun-24	BANGALORE	66	LINE	66KV KEONISC (ELECTRONIC CITY) - ELECTRONIC CITY PHASE-2 SECTOR-1 (VELANKANI)	ELECTRONIC CITY, INFOSYS, HULIMANGALA	10:02	10:34	00:32	LINE CLEAR AVAILED
2894	15-Jun-24	BANGALORE	66	LINE	66KV KEONISC (ELECTRONIC CITY) - HULIMANGALA	HULIMANGALA	10:34	16:45	06:11	LINE CLEAR AVAILED
2895	15-Jun-24	BANGALORE	66	LINE	66KV KEONISC (ELECTRONIC CITY) - HULIMANGALA	HULIMANGALA	10:02	16:46	06:44	LINE CLEAR AVAILED
2896	15-Jun-24	BANGALORE	66	LINE	66KV KEONISC (ELECTRONIC CITY) - INFOSIS EHT	INFOSYS(EHT)	10:34	13:41	03:07	LINE CLEAR AVAILED
2897	15-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA - DRDO	MALLASANDRA, DRDO	10:35	10:55	00:20	LINE CLEAR AVAILED
2898	15-Jun-24	BANGALORE	66	LINE	66KV MALGUDI - CHOKKASANDRA	HUSKUR	10:00	16:26	06:26	LINE CLEAR AVAILED
2899	15-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	NO STATION AFFECTED	09:01	10:28	01:27	LINE CLEAR AVAILED
2900	15-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	09:01	10:28	01:27	LINE CLEAR AVAILED
2901	15-Jun-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - JAYANAGARA GIS	JAYANAGARA	15:16	15:18	00:02	LINE CLEAR AVAILED
2902	15-Jun-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	11:08	11:12	00:04	LINE CLEAR AVAILED
2903	15-Jun-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	17:23	17:26	00:03	LINE CLEAR AVAILED
2904	15-Jun-24	BANGALORE	66	LINE	66KV NATIONAL COLLEGE - PADMANABHANAGAR	PADMANABHANAGARA	21:36	21:44	00:08	TRIPPED ON FAULT
2905	15-Jun-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYADEVA	JAYADEVA	10:15	16:22	06:07	LINE CLEAR AVAILED
2906	15-Jun-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	11:20	11:22	00:02	LINE CLEAR AVAILED
2907	15-Jun-24	BANGALORE	66	LINE	66KV NIMHANS 220 - JAYANAGAR GIS	JAYANAGARA	21:35	21:42	00:07	LINE CLEAR AVAILED
2908	15-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKON	10:05	10:10	00:05	LINE CLEAR AVAILED
2909	15-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	10:15	15:20	05:05	LINE CLEAR AVAILED
2910	15-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST	15:06	15:10	00:04	LINE CLEAR AVAILED
2911	15-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKON	14:54	15:00	00:06	LINE CLEAR AVAILED
2912	15-Jun-24	BANGALORE	66	LINE	66KV T D HALLI (MALLASANDRA) - DALASANUR	MALLASANDRA	15:23	15:27	00:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2913	15-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	09:39	18:59	09:20	LINE CLEAR AVAIED
2914	15-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - THAYALUR	TAYALUR, MN HALLI, NG HULKUR	09:40	18:43	09:03	LINE CLEAR AVAIED
2915	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	09:10	18:13	09:03	LINE CLEAR AVAIED
2916	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	09:39	18:30	08:51	LINE CLEAR AVAIED
2917	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML	09:00	18:25	09:25	LINE CLEAR AVAIED
2918	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	09:00	18:25	09:25	LINE CLEAR AVAIED
2919	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	09:32	18:08	08:36	LINE CLEAR AVAIED
2920	15-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI	H GOLLAHALLI, MUIDYANUR	09:46	18:34	08:48	LINE CLEAR AVAIED
2921	15-Jun-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - REMCO GIS	REMCO	11:03	16:45	05:42	LINE CLEAR AVAIED
2922	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MANYATHA TECH PARK 66	11:14	16:16	05:02	LINE CLEAR AVAIED
2923	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	10:46	10:54	00:08	LINE CLEAR AVAIED
2924	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYANAGARA	17:11	17:17	00:06	LINE CLEAR AVAIED
2925	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ELECTRONIC CITY	15:50	17:21	01:31	LINE CLEAR AVAIED
2926	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SOUTH CITY	10:18	14:54	04:36	LINE CLEAR AVAIED
2927	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	12:10	16:32	04:22	LINE CLEAR AVAIED
2928	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	05:00	05:12	00:12	TRIPPED ON FAULT
2929	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JANGMKOTE	11:27	11:30	00:03	LINE CLEAR AVAIED
2930	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	APPAREL PARK	11:45	13:20	01:35	TRIPPED ON FAULT
2931	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KUNDANA	20:39	20:50	00:11	LINE CLEAR AVAIED
2932	15-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HULLENAHALLI	05:50	06:10	00:20	TRIPPED ON FAULT
2933	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MANYATHA TECH PARK 66	11:14	16:18	05:04	LINE CLEAR AVAIED
2934	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	10:46	10:54	00:08	LINE CLEAR AVAIED
2935	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIJAYANAGARA	17:11	17:17	00:06	LINE CLEAR AVAIED
2936	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOODY 220	09:57	10:14	00:17	LINE CLEAR AVAIED
2937	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ELECTRONIC CITY	12:56	15:08	02:12	LINE CLEAR AVAIED
2938	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SOUTH CITY	10:18	14:54	04:36	LINE CLEAR AVAIED
2939	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KONDASAPURA	10:00	16:32	06:32	LINE CLEAR AVAIED
2940	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JANGMKOTE	09:46	09:48	00:02	LINE CLEAR AVAIED
2941	15-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	14:40	14:50	00:10	TRIPPED ON FAULT
2942	15-Jun-24	BANGALORE	66	TRANSFORMER	HV3	MANYATHA TECH PARK 66	11:14	16:23	05:09	LINE CLEAR AVAIED
2943	15-Jun-24	BANGALORE	66	TRANSFORMER	HV3	B STATION	22:35	23:15	00:40	TRIPPED ON FAULT
2944	15-Jun-24	BANGALORE	66	TRANSFORMER	HV3	ELECTRONIC CITY	10:34	13:34	03:00	LINE CLEAR AVAIED
2945	15-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLAHALLI 1	T GOLLAHALLI 220	09:44	17:42	07:58	LINE CLEAR AVAIED
2946	15-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - T GOLAHALLI 2	T GOLLAHALLI 220	09:44	17:42	07:58	LINE CLEAR AVAIED
2947	15-Jun-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - BIDADI 2	NO STATION AFFECTED	08:58	16:24	07:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2948	15-Jun-24	BANGALORE	220	TRANSFORMER	HV1	T GOLLAHALLI 220	09:46	19:29	09:43	LINE CLEAR AVAILED
2949	15-Jun-24	BANGALORE	220	TRANSFORMER	HV2	NRS 220(NO LOAD AFFECTED)	14:23	14:25	00:02	TRIPPED ON FAULT
2950	15-Jun-24	BANGALORE	220	TRANSFORMER	HV2	NAGANATHPURA 220	12:48	14:47	01:59	LINE CLEAR AVAILED
2951	15-Jun-24	BANGALORE	220	TRANSFORMER	HV2	T GOLLAHALLI 220	09:46	17:53	08:07	LINE CLEAR AVAILED
2952	15-Jun-24	BANGALORE	220	TRANSFORMER	HV3	NAGANATHPURA 220	11:02	11:10	00:08	LINE CLEAR AVAILED
2953	15-Jun-24	GULBARGA	66	LINE	CJ-HALLI-BADALADUKU	HOSAHALLI_66,HUDEM_66	05:40	06:00	00:20	TRIPPED ON FAULT
2954	15-Jun-24	GULBARGA	66	LINE	HOSAHALLI-BADALADUKU	HOSAHALLI_66,HUDEM_66	05:40	06:00	00:20	TRIPPED ON FAULT
2955	15-Jun-24	GULBARGA	66	LINE	HUDEM-BADALADUKU	HUDEM_66	05:40	06:00	00:20	TRIPPED ON FAULT
2956	15-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	12:35	12:50	00:15	TRIPPED ON FAULT
2957	15-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	14:35	14:45	00:10	TRIPPED ON FAULT
2958	15-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-JAWALGERA	ADAVIAMARESHWAR_110	10:00	12:38	02:38	LINE CLEAR AVAILED
2959	15-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-JAWALGERA	ADAVIAMARESHWAR_110	02:02	02:12	00:10	MAIN SUPPLY FAILURE
2960	15-Jun-24	GULBARGA	110	LINE	AURAD-DONGARGOAN	DONGARGOAN_110	14:50	18:30	03:40	LINE CLEAR AVAILED
2961	15-Jun-24	GULBARGA	110	LINE	GANGAVATI-VENKATAGIRI	VENKATAGIRI_110	19:13	19:18	00:05	MAIN SUPPLY FAILURE
2962	15-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-DEVAPUR	DEVAPUR_110	09:17	15:55	06:38	LINE CLEAR AVAILED
2963	15-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-M.KOLLUR	M.KOLLUR_110	05:55	06:00	00:05	LINE CLEAR AVAILED
2964	15-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-M.KOLLUR	M.KOLLUR_110	05:55	07:23	01:28	LINE CLEAR AVAILED
2965	15-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-NAGNOOR	NAGNOOR_110	05:07	05:14	00:07	TRIPPED ON FAULT
2966	15-Jun-24	GULBARGA	110	TRANSFORMER	HV1	HATTIGUDUR_220	23:59	08:37	08:38	TRIPPED ON FAULT
2967	15-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110, RUDRAWADI_110	00:20	00:40	00:20	TRIPPED ON FAULT
2968	15-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110, RUDRAWADI_110	01:20	01:49	00:29	TRIPPED ON FAULT
2969	15-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110, RUDRAWADI_110	02:50	15:11	12:21	TRIPPED ON FAULT
2970	15-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110, RUDRAWADI_110	15:12	17:10	01:58	LINE CLEAR AVAILED
2971	15-Jun-24	GULBARGA	110	LINE	KEMBHAVI-HATTIGUDUR	KEMBHAVI_110	03:24	03:32	00:08	TRIPPED ON FAULT
2972	15-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	12:50	13:55	01:05	LINE CLEAR AVAILED
2973	15-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONNATHI	SONNATHI_110	02:33	06:15	03:42	TRIPPED ON FAULT
2974	15-Jun-24	GULBARGA	110	LINE	KOLLURU-DEODURGA	KOLLURU_110	06:00	07:25	01:25	LINE CLEAR AVAILED
2975	15-Jun-24	GULBARGA	110	LINE	KOLLURU-SHAHPUR	KOLLURU_110	05:55	06:00	00:05	LINE CLEAR AVAILED
2976	15-Jun-24	GULBARGA	110	LINE	MOKA-NORTH	MOKA_110,YERRAGUDI_110	09:20	12:05	02:45	LINE CLEAR AVAILED
2977	15-Jun-24	GULBARGA	110	LINE	MUNIRABAD-BPCL	MUNIRABAD_220	10:55	12:50	01:55	LINE CLEAR AVAILED
2978	15-Jun-24	GULBARGA	110	LINE	MUNIRABAD-DONIMALAI	MUNIRABAD_220	09:33	12:50	03:17	LINE CLEAR AVAILED
2979	15-Jun-24	GULBARGA	110	LINE	NORTH-BISILAHALLI	BISILAHALLI_110	09:24	12:06	02:42	LINE CLEAR AVAILED
2980	15-Jun-24	GULBARGA	110	LINE	NORTH-BISILAHALLI	BISILAHALLI_110	13:25	14:07	00:42	LINE CLEAR AVAILED
2981	15-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	20:35	20:40	00:05	TRIPPED ON FAULT
2982	15-Jun-24	GULBARGA	110	LINE	WALKAMDINI-BYAGWAT	WALKAMDINI_110	09:55	09:58	00:03	LINE CLEAR AVAILED
2983	15-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	07:15	12:40	05:25	LINE CLEAR AVAILED
2984	15-Jun-24	GULBARGA	220	LINE	HALWARTHY-DMSPL	HALWARTHY_220	12:16	15:45	03:29	LINE CLEAR AVAILED
2985	15-Jun-24	GULBARGA	220	LINE	HALWARTHY-LINGAPUR2	LINGAPUR_220	09:48	13:17	03:29	LINE CLEAR AVAILED
2986	15-Jun-24	GULBARGA	220	TRANSFORMER	HV1	SHAHAPUR_220	21:45(14.06.2024)	8:20(15.06.2024)	10:35HRS	LINE CLEAR AVAILED
2987	15-Jun-24	GULBARGA	220	TRANSFORMER	HV2	ALIPUR_220	17:20	18:20	01:00	LINE CLEAR AVAILED
2988	15-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
2989	15-Jun-24	HASSAN	66	LINE	HNPR2-HASS3	HNPURA_220	10:10	13:02	02:52	LINE CLEAR AVAIED
2990	15-Jun-24	HASSAN	66	TRANSFORMER	HV1	BYACHANAHALLI_66	13:00	15:00	02:00	LINE CLEAR AVAIED
2991	15-Jun-24	HASSAN	66	TRANSFORMER	HV1	HOLALUR_66	10:00	15:30	05:30	LINE CLEAR AVAIED
2992	15-Jun-24	HASSAN	66	TRANSFORMER	HV1	SALAGAME_66	17:25	17:47	00:22	LINE CLEAR AVAIED
2993	15-Jun-24	HASSAN	66	TRANSFORMER	HV1	TAVARECHATNAHALLI_66	09:55	13:54	03:59	LINE CLEAR AVAIED
2994	15-Jun-24	HASSAN	66	TRANSFORMER	HV2	BYACHANAHALLI_66	11:15	13:15	02:00	LINE CLEAR AVAIED
2995	15-Jun-24	HASSAN	66	TRANSFORMER	HV2	HOLALUR_66	10:00	15:30	05:30	LINE CLEAR AVAIED
2996	15-Jun-24	HASSAN	66	TRANSFORMER	HV2	SALAGAME_66	17:25	17:47	00:22	LINE CLEAR AVAIED
2997	15-Jun-24	HASSAN	66	TRANSFORMER	HV2	TAVARECHATNAHALLI_66	09:55	13:48	03:53	LINE CLEAR AVAIED
2998	15-Jun-24	HASSAN	66	LINE	MRSSHM-HOLUR	MRSMSG_220	09:58	13:45	03:47	LINE CLEAR AVAIED
2999	15-Jun-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	16:00	17:47	01:47	LINE CLEAR AVAIED
3000	15-Jun-24	HASSAN	66	LINE	SALAGAM-UDURKOPPLU	SALAGAM	17:25	17:44	00:19	LINE CLEAR AVAIED
3001	15-Jun-24	HASSAN	66	LINE	TAVAREC-HONALI	TAVARECHATNAHALLI_66	09:55	15:30	05:35	LINE CLEAR AVAIED
3002	15-Jun-24	HASSAN	66	LINE	TAVAREC-HONALI	TAVARECHATNAHALLI_66	20:09	20:36	00:27	TRIPPED ON FAULT
3003	15-Jun-24	HASSAN	66	LINE	TAVAREC-MRS	TAVARECHATNAHALLI_66	09:55	13:48	03:53	LINE CLEAR AVAIED
3004	15-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR1	GURUVAYANKERE_110	10:40	16:15	05:35	LINE CLEAR AVAIED
3005	15-Jun-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	09:00	10:00	01:00	LINE CLEAR AVAIED
3006	15-Jun-24	HASSAN	110	TRANSFORMER	HV1	BELAGUMBA_110	16:07	17:05	00:58	LINE CLEAR AVAIED
3007	15-Jun-24	HASSAN	110	TRANSFORMER	HV3	SHIRALKOPPA_110	10:28	19:00	08:32	LINE CLEAR AVAIED
3008	15-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	10:36	10:44	00:08	LINE CLEAR AVAIED
3009	15-Jun-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	13:54	15:52	01:58	LINE CLEAR AVAIED
3010	15-Jun-24	HASSAN	110	LINE	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:22	19:01	08:39	LINE CLEAR AVAIED
3011	15-Jun-24	HASSAN	110	LINE	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	10:35	18:50	08:15	LINE CLEAR AVAIED
3012	15-Jun-24	HASSAN	220	LINE	ARSK2-NITTUR	ARSIKERE_220	13:23	17:49	04:26	LINE CLEAR AVAIED
3013	15-Jun-24	HASSAN	220	LINE	KEMAR-UPCL1	KEMAR_220	11:37	14:14	02:37	LINE CLEAR AVAIED
3014	15-Jun-24	HASSAN	220	LINE	KEMAR-UPCL2	KEMAR_220	14:19	17:05	02:46	LINE CLEAR AVAIED
3015	15-Jun-24	HASSAN	220	LINE	UPCL-KEMAR1	gen_upcl	11:37	14:14	02:37	LINE CLEAR AVAIED
3016	15-Jun-24	HASSAN	220	LINE	UPCL-KEMAR2	gen_upcl	14:19	17:05	02:46	LINE CLEAR AVAIED
3017	15-Jun-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	BEGUR_66	09:20	13:03	03:43	LINE CLEAR AVAIED
3018	15-Jun-24	MYSORE	66	LINE	BEGUR 220-BEGUR 2	BEGUR_66	09:20	13:03	03:43	LINE CLEAR AVAIED
3019	15-Jun-24	MYSORE	66	LINE	BEGUR 220-HARAVE	HARAVE_66	05:50	05:57	00:07	TRIPPED ON FAULT
3020	15-Jun-24	MYSORE	66	LINE	BGPURA-CHANDALLI	NO STATIONS EFFECTED	08:45	09:00	00:15	LINE CLEAR AVAIED
3021	15-Jun-24	MYSORE	66	LINE	BGPURA-HEBBANI	NO STATIONS EFFECTED	07:20	08:30	01:10	LINE CLEAR AVAIED
3022	15-Jun-24	MYSORE	66	LINE	BILIKERE-GV GUDI	GVGUDI_66	14:33	14:47	00:14	TRIPPED ON FAULT
3023	15-Jun-24	MYSORE	66	LINE	CRNAGAR-DR PETE 2	NO STATIONS EFFECTED	14:30	14:35	00:05	TRIPPED ON FAULT
3024	15-Jun-24	MYSORE	66	LINE	CRNAGAR-KOLLEGALA	NO STATIONS EFFECTED	10:23	12:30	02:07	LINE CLEAR AVAIED
3025	15-Jun-24	MYSORE	66	LINE	GUNDLUPETE-HANGALA	HANGALA_66 BARGI_66	10:50	10:55	00:05	TRIPPED ON FAULT
3026	15-Jun-24	MYSORE	66	LINE	HDKOTE-TARAKA	NO STATIONS EFFECTED	10:32	16:06	05:33	LINE CLEAR AVAIED
3027	15-Jun-24	MYSORE	66	TRANSFORMER	HV1	BGPURA_66	07:11	14:22	07:10	LINE CLEAR AVAIED
3028	15-Jun-24	MYSORE	66	TRANSFORMER	HV1	JYOTHINAGARA_66	08:04	08:29	00:24	LINE CLEAR AVAIED
3029	15-Jun-24	MYSORE	66	TRANSFORMER	HV1	KABHALLY_66	09:02	09:16	00:13	LINE CLEAR AVAIED
3030	15-Jun-24	MYSORE	66	TRANSFORMER	HV1	MUGUR_66	14:32	14:40	00:08	LINE CLEAR AVAIED
3031	15-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3032	15-Jun-24	MYSORE	66	TRANSFORMER	HV2	BETTADAPURA_66	16:59	17:10	00:11	TRIPPED ON FAULT
3033	15-Jun-24	MYSORE	66	TRANSFORMER	HV2	BGPURA_66	10:17	14:22	04:04	LINE CLEAR AVAIED
3034	15-Jun-24	MYSORE	66	TRANSFORMER	HV2	PERIAPATNA_66	14:46	17:12	02:25	LINE CLEAR AVAIED
3035	15-Jun-24	MYSORE	66	TRANSFORMER	HV2	SUTTUR_66	10:00	15:56	05:56	LINE CLEAR AVAIED
3036	15-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3037	15-Jun-24	MYSORE	66	LINE	KABHALLY-ATRIA SOLAR	NO STATIONS EFFECTED	19:00:00 (15/05/2024)			LINE CLEAR AVAILED
3038	15-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	MANDAKALLI_66	07:40	07:48	00:08	TRIPPED ON FAULT
3039	15-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	NO STATIONS EFFECTED	09:44	15:21	05:37	LINE CLEAR AVAILED
3040	15-Jun-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	09:44	15:32	05:48	LINE CLEAR AVAILED
3041	15-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)			LINE CLEAR AVAILED
3042	15-Jun-24	MYSORE	66	LINE	KOLLEGALA-THALAKADU	PARINAMIPURA_66 CHANDALLI_66	10:25	17:59	07:33	LINE CLEAR AVAILED
3043	15-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3044	15-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	14:31	17:41	03:09	TRIPPED ON FAULT
3045	15-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	14:05	15:00	00:55	LINE CLEAR AVAILED
3046	15-Jun-24	MYSORE	66	LINE	MUGUR-CR NAGAR	NO STATIONS EFFECTED	10:22	12:31	02:09	LINE CLEAR AVAILED
3047	15-Jun-24	MYSORE	66	LINE	MYSORE SOUTH-KDKLA	NO STATIONS EFFECTED	04:07	15:23	11:15	LINE CLEAR AVAILED
3048	15-Jun-24	MYSORE	66	LINE	PANYADUNDI-KREREHALLI	NO STATIONS EFFECTED	08:25	08:30	00:05	TRIPPED ON FAULT
3049	15-Jun-24	MYSORE	66	LINE	PERIAPATNA-HANGUD	PONNAMPETE_66 VIRAJPETE_66 SOMWARPETE_66	09:34	16:25	06:50	LINE CLEAR AVAILED
3050	15-Jun-24	MYSORE	66	LINE	PERIAPATNA-HUNSUR/KAMPLAPURA	NO STATIONS EFFECTED	11:25	13:09	01:43	LINE CLEAR AVAILED
3051	15-Jun-24	MYSORE	66	LINE	S R PATNA-G UKKADA	SRIRANGAPATNA_66	10:02	18:00	07:58	LINE CLEAR AVAILED
3052	15-Jun-24	MYSORE	66	LINE	YELANDUR-MADHUVANAHALLI	NO STATIONS EFFECTED	10:21	13:55	03:33	LINE CLEAR AVAILED
3053	15-Jun-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_66	09:10	15:10	06:00	LINE CLEAR AVAILED
3054	15-Jun-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	09:04	18:24	09:19	LINE CLEAR AVAILED
3055	15-Jun-24	MYSORE	220	LINE	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	13:07	18:30	05:23	LINE CLEAR AVAILED
3056	15-Jun-24	TUMKUR	66	LINE	66kV Kerebilachi(Devarahalli Line)- 220kV Benkikere Line	66kV Kerebilachi,Water supply	03:15	03:20	00:05	TRIPPED ON FAULT
3057	15-Jun-24	TUMKUR	66	LINE	66kV Kerebilachi(Devarahalli Line)- 220kV Benkikere Line	66kV Kerebilachi,Water supply	06:05	06:10	00:05	TRIPPED ON FAULT
3058	15-Jun-24	TUMKUR	66	LINE	66kV Mathod-220kV Hiriyur Line 1	HALRAMESWARA_66,MADADK ERE_66,RAMGIRI_66,BAGUR_6 6,HOSADURGA_66,NEERGUND A_66	18:45	18:50	00:05	TRIPPED ON FAULT
3059	15-Jun-24	TUMKUR	66	LINE	66kV Mathod-220kV Hiriyur Line 1	HALRAMESWARA_66,MADADK ERE_66,RAMGIRI_66,BAGUR_6 6,HOSADURGA_66,NEERGUND A_66	19:05	19:20	00:15	TRIPPED ON FAULT
3060	15-Jun-24	TUMKUR	66	LINE	66kV P N Halli-66kV C B Gere Line	66kV C B Gere,Hariaybbe,P D Kote	10:52	11:05	00:13	TRIPPED ON FAULT
3061	15-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220kV- ANCHEPALYA-66	ANCHEPALYA 66kV	12:50	13:07	00:17	LINE CLEAR AVAILED
3062	15-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220kV- KUNIGAL	KUNIGAL_66	12:14	12:32	00:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3063	15-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:10	15:06	03:56	LINE CLEAR AVAILED
3064	15-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	09:55	12:12	02:17	LINE CLEAR AVAILED
3065	15-Jun-24	TUMKUR	66	LINE	HIRIYUR220kv-P R PURA	HARIYABBE_66,PDKOTE_66	10:45	18:40	07:55	LINE CLEAR AVAILED
3066	15-Jun-24	TUMKUR	66	TRANSFORMER	TR-1	HIRIYUR_220kv	12:10	13:24	01:14	LINE CLEAR AVAILED
3067	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- DODDAGUNI	DODDAGUNI_110	14:20	18:12	03:52	LINE CLEAR AVAILED
3068	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- GUBBI	GUBBI_110, BIDARE_110	10:39	18:45	08:06	LINE CLEAR AVAILED
3069	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- KADABA	KADABA_110	10:50	19:05	08:15	LINE CLEAR AVAILED
3070	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- KALLUR	KALLUR_110	10:30	14:48	04:18	LINE CLEAR AVAILED
3071	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	12:40	18:15	05:35	LINE CLEAR AVAILED
3072	15-Jun-24	TUMKUR	110	LINE	NITTUR 220kv- SOMALAPURA	SOMALAPURA_66	10:40	17:50	07:10	LINE CLEAR AVAILED
3073	15-Jun-24	TUMKUR	110	TRANSFORMER	TR-1 (LV SIDE) NITTUR-110KV	NITTUR-110KV	14:22	15:47	01:25	LINE CLEAR AVAILED
3074	15-Jun-24	TUMKUR	110	TRANSFORMER	TR-2 (LV SIDE) NITTUR-110KV	NITTUR-110KV	14:22	15:47	01:25	LINE CLEAR AVAILED
3075	15-Jun-24	TUMKUR	220	LINE	HIRIYUR220-MADHUGIRI_220KV	MADHUGIRI_220	14:53	19:53	05:00	LINE CLEAR AVAILED
3076	15-Jun-24	TUMKUR	220	LINE	NITTUR 220kv- NELAMANGALA	NITTUR_220	14:06	15:34	01:28	LINE CLEAR AVAILED
3077	15-Jun-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA (HV SIDE) NITTUR-220KV	NITTUR-220KV	14:15	15:42	01:27	LINE CLEAR AVAILED
3078	15-Jun-24	TUMKUR	220	TRANSFORMER	TR-2 100MVA (HV SIDE) NITTUR-220KV	NITTUR-220KV	14:15	15:42	01:27	LINE CLEAR AVAILED
3079	15-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- HAVERI 2	HAVERI_220	10:02	15:44	05:42	LINE CLEAR AVAILED
3080	15-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERELINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3081	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	SULTANPUR_110	10:10	18:00	07:50	LINE CLEAR AVAILED
3082	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20 MVA)	ZALKI_110	17:02	18:37	01:35	LINE CLEAR AVAILED
3083	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	UDAYMBAG_110	09:00	15:50	06:50	LINE CLEAR AVAILED
3084	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	ISLAMPUR_110	11:53	11:56	00:03	TRIPPED ON FAULT
3085	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20 MVA)	ZALKI_110	19:15	19:45	00:30	TRIPPED ON FAULT
3086	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20 MVA)	ZALKI_110	21:15	21:20	00:05	TRIPPED ON FAULT
3087	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20 MVA)	ZALKI_110	21:25	21:40	00:15	TRIPPED ON FAULT
3088	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	UDAYMBAG_110	09:00	17:47	08:47	LINE CLEAR AVAILED
3089	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	THORVI_110	18:35	18:40	00:05	TRIPPED ON FAULT
3090	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	UDAYMBAG_110	09:00	15:50	06:50	LINE CLEAR AVAILED
3091	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	SULTANPUR_110	10:10	18:01	07:51	LINE CLEAR AVAILED
3092	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	ANKOLA_110	11:11	12:43	01:32	LINE CLEAR AVAILED
3093	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	CHIKKODI_110	10:19	15:40	05:21	LINE CLEAR AVAILED
3094	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	GOKAK_110	10:00	13:05	03:05	LINE CLEAR AVAILED
3095	16-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	UDAYMBAG_110	09:00	15:50	06:50	LINE CLEAR AVAILED
3096	16-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3097	16-Jun-24	BAGALKOTE	110	LINE	AEQUS220-SANKESHWAR	AEQUS_220	13:36	16:52	03:16	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3098	16-Jun-24	BAGALKOTE	110	LINE	ATHARGA- KN SOLAR	ATHARGA_110	05:30	05:56	00:26	TRIPPED ON FAULT
3099	16-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3100	16-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- CHIKKODI	CHIKKODI_220	11:17	15:31	04:14	LINE CLEAR AVAILED
3101	16-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
3102	16-Jun-24	BAGALKOTE	110	LINE	HONNAVAR- MURDESHWAR	HONNAVAR_110	11:43	12:07	00:24	TRIPPED ON FAULT
3103	16-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
3104	16-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-BIDI	MK HUBLI_220	10:20	18:33	08:13	LINE CLEAR AVAILED
3105	16-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3106	16-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220- LN8(SULTANPUR)	MUGALKHOD_220	10:11	17:44	07:33	LINE CLEAR AVAILED
3107	16-Jun-24	BAGALKOTE	110	LINE	MUNDAGOD- HUBLI220 (SHIGGOAN220)	MUNDAGOD_110	22:38 (16.06.2024)			LINE CLEAR AVAILED
3108	16-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
3109	16-Jun-24	BAGALKOTE	110	LINE	SANKS-CHIKKODI	SANKESHWAR_110	13:15	17:37	04:22	LINE CLEAR AVAILED
3110	16-Jun-24	BAGALKOTE	110	LINE	SANKS-HSFCG	SANKESHWAR_110	13:40	17:02	03:22	LINE CLEAR AVAILED
3111	16-Jun-24	BAGALKOTE	110	LINE	SANKS-HSFCG 2	SANKESHWAR_110	13:40	17:11	03:31	LINE CLEAR AVAILED
3112	16-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN220- LN2(MUNDAGOD)	SHIGGOAN_220	22:13 (16.06.2024)			TRIPPED ON FAULT
3113	16-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN220- LN3(SHIGGOAN)	SHIGGOAN_220	13:00	15:44	02:44	LINE CLEAR AVAILED
3114	16-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3115	16-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3116	16-Jun-24	BAGALKOTE	110	LINE	STPR-F2 Cbreaker (MUGHULKHOD)	SULTANPUR_110	10:10	18:00	07:50	LINE CLEAR AVAILED
3117	16-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3118	16-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3119	16-Jun-24	BAGALKOTE	110	LINE	TLKOT-FPEL Cbreaker	TALIKOTI_110	05:03	05:25	00:22	TRIPPED ON FAULT
3120	16-Jun-24	BAGALKOTE	110	LINE	TLKOT-FPEL Cbreaker	TALIKOTI_110	05:29	05:43	00:14	TRIPPED ON FAULT
3121	16-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3122	16-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-UCHAGOAN	UDAYMBAG_111	09:00	15:50	06:50	LINE CLEAR AVAILED
3123	16-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3124	16-Jun-24	BAGALKOTE	220	LINE	GHATAPRABHA- NARENDRA1	GHATAPRABHA_220	12:32	14:33	02:01	LINE CLEAR AVAILED
3125	16-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3126	16-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - KANTEERAVA GIS	KANTEERAVA	10:13	16:10	05:57	LINE CLEAR AVAILED
3127	16-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	09:00	17:34	08:34	LINE CLEAR AVAILED
3128	16-Jun-24	BANGALORE	66	LINE	66KV ANEKAL - ATTIBELE	ATTIBELE	09:20	09:25	00:05	LINE CLEAR AVAILED
3129	16-Jun-24	BANGALORE	66	LINE	66KV BYADARAHALLI - KODIGEHALI	KODIGEHALI	10:05	16:45	06:40	LINE CLEAR AVAILED
3130	16-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA, KALYANI TECH PARK, ORACLE(EHT)	11:50	11:58	00:08	LINE CLEAR AVAILED
3131	16-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA, KALYANI TECH PARK, ORACLE(EHT)	19:08	19:14	00:06	LINE CLEAR AVAILED
3132	16-Jun-24	BANGALORE	66	LINE	66KV GOWRIDIDANUR 220 - KUDUMULAKUNTE	KUDUMULKUNTE, TERIYUR	15:40	15:50	00:10	TRIPPED ON FAULT
3133	16-Jun-24	BANGALORE	66	LINE	66KV HAL 220 - BAGMANE WTC 1 - ISRO (TAP) - KADBISANAHALLI (TAP)	BAGHMANE WORLD TECH PARK	10:05	10:10	00:05	LINE CLEAR AVAILED
3134	16-Jun-24	BANGALORE	66	LINE	66KV JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	09:22	18:38	09:16	LINE CLEAR AVAILED
3135	16-Jun-24	BANGALORE	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD	08:34	08:39	00:05	LINE CLEAR AVAILED
3136	16-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	MELEHALLI, KEMPANAHALLI, URAGAHALLI, KOOTAGALU, CHIKKAGANGANAWADI, JALAMANGALA	19:00	19:10	00:10	TRIPPED ON FAULT
3137	16-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	10:00	16:00	06:00	LINE CLEAR AVAILED
3138	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, BEST STEEL(EHT)	09:55	10:12	00:17	LINE CLEAR AVAILED
3139	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A	MALUR IND AREA, BEST STEEL(EHT)	12:33	12:36	00:03	LINE CLEAR AVAILED
3140	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	09:55	10:10	00:15	LINE CLEAR AVAILED
3141	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	12:33	12:36	00:03	LINE CLEAR AVAILED
3142	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	09:55	10:12	00:17	LINE CLEAR AVAILED
3143	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MASTHI	MASTHI	12:33	12:36	00:03	LINE CLEAR AVAILED
3144	16-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE	10:25	10:45	00:20	LINE CLEAR AVAILED
3145	16-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - MUDDENAHALLI (NANDI)	CB PURA IA, CB PURA URBAN, NANDI	10:00	18:29	08:29	LINE CLEAR AVAILED
3146	16-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - TUBAGERE	TUBAGERE	10:38	17:20	06:42	LINE CLEAR AVAILED
3147	16-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMKOTE, MELUR	14:19	14:23	00:04	LINE CLEAR AVAILED
3148	16-Jun-24	BANGALORE	66	LINE	66KV SARAKKI - JAYADEVA 2	NO STATION AFFECTED	16:43	18:33	01:50	TRIPPED ON FAULT
3149	16-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	16:24	16:29	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3150	16-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	YEDAMADU, HANUMANTHAGARA	10:35	15:24	04:49	LINE CLEAR AVAILABLE
3151	16-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI - NALLIMARADANAHALLI	NALLIMARADANAHALLI	10:00	17:10	07:10	LINE CLEAR AVAILABLE
3152	16-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - KHB DG-1	NO STATION AFFECTED	13:23	14:09	00:46	TRIPPED ON FAULT
3153	16-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - PB NAGAR - AREHALLI	AREHALLI	10:28	10:45	00:17	LINE CLEAR AVAILABLE
3154	16-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML	10:22	10:44	00:22	TRIPPED ON FAULT
3155	16-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML	10:22	10:44	00:22	TRIPPED ON FAULT
3156	16-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	11:54	12:00	00:06	LINE CLEAR AVAILABLE
3157	16-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	19:17	19:22	00:05	LINE CLEAR AVAILABLE
3158	16-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 200 - SURYA CITY	SURYANAGARA	10:00	13:41	03:41	LINE CLEAR AVAILABLE
3159	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HEBBALA 220	05:17	05:42	00:25	TRIPPED ON FAULT
3160	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HEBBALA 220	06:12	06:38	00:26	TRIPPED ON FAULT
3161	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YELDUR	12:15	12:25	00:10	LINE CLEAR AVAILABLE
3162	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 220	09:22	18:29	09:07	LINE CLEAR AVAILABLE
3163	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	08:42	08:52	00:10	LINE CLEAR AVAILABLE
3164	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	20:30	20:40	00:10	LINE CLEAR AVAILABLE
3165	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	09:36	09:41	00:05	TRIPPED ON FAULT
3166	16-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	17:15	19:10	01:55	LINE CLEAR AVAILABLE
3167	16-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOODY 220	10:46	10:51	00:05	LINE CLEAR AVAILABLE
3168	16-Jun-24	BANGALORE	66	TRANSFORMER	HV2	IRAGAMPALLI	07:53	08:13	00:20	TRIPPED ON FAULT
3169	16-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 220	09:22	18:29	09:07	LINE CLEAR AVAILABLE
3170	16-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	08:42	08:52	00:10	LINE CLEAR AVAILABLE
3171	16-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	20:30	20:40	00:10	LINE CLEAR AVAILABLE
3172	16-Jun-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	08:42	08:52	00:10	LINE CLEAR AVAILABLE
3173	16-Jun-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	20:30	20:40	00:10	LINE CLEAR AVAILABLE
3174	16-Jun-24	BANGALORE	66	TRANSFORMER	HV3	YARANDANAHALLI 220	10:35	17:40	07:05	LINE CLEAR AVAILABLE
3175	16-Jun-24	BANGALORE	220	LINE	220KV MYLASANDRA 400 - JIGANI 220	JIGANI 220	09:23	18:01	08:38	LINE CLEAR AVAILABLE
3176	16-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	NO STATION AFFECTED	21:39	23:59	02:20	LINE CLEAR AVAILABLE
3177	16-Jun-24	BANGALORE	220	TRANSFORMER	HV1	JIGANI 220	09:22	20:33	11:11	LINE CLEAR AVAILABLE
3178	16-Jun-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	20:23	20:37	00:14	LINE CLEAR AVAILABLE
3179	16-Jun-24	GULBARGA	66	LINE	BADELADUKU-GUDEKOTE	CUDEKOTE_66,HOSAHALLI_66	05:45	06:00	00:15	TRIPPED ON FAULT
3180	16-Jun-24	GULBARGA	66	LINE	HALAVAGALU-NEELGUNDA	HARVI_66	06:09	06:19	00:10	MAIN SUPPLY FAILURE
3181	16-Jun-24	GULBARGA	66	LINE	HALAVAGALU-NEELGUNDA	HARVI_66	06:09	06:19	00:10	TRIPPED ON FAULT
3182	16-Jun-24	GULBARGA	66	TRANSFORMER	HV1	HOSAHALLI_66	13:50	13:55	00:05	TRIPPED ON FAULT
3183	16-Jun-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	13:00	18:35	05:35	LINE CLEAR AVAILABLE
3184	16-Jun-24	GULBARGA	110	LINE	GANGAVATI-VENKATAGIRI	VENKATAGIRI_110	19:47	20:07	00:20	MAIN SUPPLY FAILURE
3185	16-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	05:02	05:08	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3186	16-Jun-24	GULBARGA	110	LINE	SHAHPUR-KEMBHAVI	KEMBHAVI_110	05:30	05:35	00:05	TRIPPED ON FAULT
3187	16-Jun-24	GULBARGA	110	LINE	SHAHPUR-NAGNOOR	NAGNOOR_110	19:04	19:15	00:11	TRIPPED ON FAULT
3188	16-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3189	16-Jun-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	18:15	18:45	00:30	MAIN SUPPLY FAILURE
3190	16-Jun-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	18:18	18:28	00:10	TRIPPED ON FAULT
3191	16-Jun-24	HASSAN	66	TRANSFORMER	HV1	KIADB HASSAN_66	10:06	16:26	06:20	LINE CLEAR AVAILED
3192	16-Jun-24	HASSAN	66	TRANSFORMER	HV2	KIADB HASSAN_66	10:06	16:26	06:20	LINE CLEAR AVAILED
3193	16-Jun-24	HASSAN	220	LINE	MRSSHM-ANTRSNH	MRSMSG_220	10:46	17:39	06:53	LINE CLEAR AVAILED
3194	16-Jun-24	MYSORE	66	LINE	BYLUKUPPE-KUSHALANAGRA-2	BYLUKUPPE_66	10:00	18:20	08:19	LINE CLEAR AVAILED
3195	16-Jun-24	MYSORE	66	LINE	CR NAGARA-BADANAGUPPE- 1	BADANAGUPPE_66	09:16	16:51	07:35	LINE CLEAR AVAILED
3196	16-Jun-24	MYSORE	66	LINE	CR NAGARA-BADANAGUPPE- 2	BADANAGUPPE_66	09:17	16:52	07:35	LINE CLEAR AVAILED
3197	16-Jun-24	MYSORE	66	LINE	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	10:05	18:17	08:11	LINE CLEAR AVAILED
3198	16-Jun-24	MYSORE	66	LINE	CR NAGARA-PANNYADAHUNDI	KARYA_66, PANDYADAHUNDI_66	11:10	14:53	03:42	LINE CLEAR AVAILED
3199	16-Jun-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA- BG PURA	BGPURA_66 CHIDRAVALLI_66	04:55	05:11	00:16	TRIPPED ON FAULT
3200	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	BYLUKUPPE_66	10:00	18:21	08:20	LINE CLEAR AVAILED
3201	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	BYLUKUPPE_66	18:40	18:45	00:05	TRIPPED ON FAULT
3202	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	GUNDULPET_66	10:20	10:28	00:08	TRIPPED ON FAULT
3203	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	KARYA_66	10:00	17:20	07:20	LINE CLEAR AVAILED
3204	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	KMDODDI_66	09:35	17:05	07:30	LINE CLEAR AVAILED
3205	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	PANDYADAHUNDI_66	10:00	17:15	07:15	LINE CLEAR AVAILED
3206	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	PERIYAPATNA_66	10:12	12:42	02:30	LINE CLEAR AVAILED
3207	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	TNARASIPURA_66	10:00	18:10	08:10	LINE CLEAR AVAILED
3208	16-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3209	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	BYLUKUPPE_66	10:00	18:21	08:20	LINE CLEAR AVAILED
3210	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	KARYA_66	10:00	17:20	07:20	LINE CLEAR AVAILED
3211	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	KMDODDI_66	09:35	17:05	07:30	LINE CLEAR AVAILED
3212	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	PANDYADAHUNDI_66	10:00	17:15	07:15	LINE CLEAR AVAILED
3213	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	PERIYAPATNA_66	10:00	16:00	05:59	LINE CLEAR AVAILED
3214	16-Jun-24	MYSORE	66	TRANSFORMER	HV2	TNARASIPURA_66	10:00	18:10	08:10	LINE CLEAR AVAILED
3215	16-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
3216	16-Jun-24	MYSORE	66	LINE	KABHALLY-ATRIA SOLAR	NO STATIONS EFFECTED	19:00:00 (15/06/2024)	0:20 (16/06/2024)	5:20 HRs	LINE CLEAR AVAILED
3217	16-Jun-24	MYSORE	66	LINE	KADAKOLA-MANDAKALLI	NO STATIONS EFFECTED	14:50	15:00	00:10	TRIPPED ON FAULT
3218	16-Jun-24	MYSORE	66	LINE	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	17:07 (20/02/2024)	14:27 (16/06/2024)	2805:20 HRs	LINE CLEAR AVAILED
3219	16-Jun-24	MYSORE	66	LINE	LOKKANAHALLI-PG PALYA	PGPALYA_66	15:55	16:00	00:05	TRIPPED ON FAULT
3220	16-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3221	16-Jun-24	MYSORE	66	LINE	MALAVALLI-KK HALLI	KOLKARANADODDI_66	10:21	17:00	06:39	LINE CLEAR AVAILED
3222	16-Jun-24	MYSORE	66	LINE	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	10:00	17:45	07:44	LINE CLEAR AVAILED
3223	16-Jun-24	MYSORE	66	LINE	MUGUR-CR NAGARA	MUGUR_66	10:00	17:45	07:44	LINE CLEAR AVAILED
3224	16-Jun-24	MYSORE	66	LINE	MUGUR-JANNUR	JANNUR_66	10:00	17:45	07:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3225	16-Jun-24	MYSORE	66	LINE	MUGUR-THAYURU	TNARASIPURA_66 THAYURU_66	10:00	18:00	08:00	LINE CLEAR AVAILED
3226	16-Jun-24	MYSORE	66	LINE	PERIYAPATNA-HANAGODU	NO STATIONS EFFECTED	10:03	12:41	02:38	LINE CLEAR AVAILED
3227	16-Jun-24	MYSORE	66	LINE	PERIYAPATNA-KAMPLAPURA	NO STATIONS EFFECTED	10:00	10:04	00:04	LINE CLEAR AVAILED
3228	16-Jun-24	MYSORE	66	LINE	PERIYAPATNA-KAMPLAPURA	NO STATIONS EFFECTED	10:13	12:41	02:27	LINE CLEAR AVAILED
3229	16-Jun-24	MYSORE	66	LINE	PERIYAPATNA-KUSHALANAGARA- 1	PERIYAPATNA_66	09:55	18:23	08:28	LINE CLEAR AVAILED
3230	16-Jun-24	MYSORE	66	LINE	PERIYAPATNA-KUSHALANAGARA- 2	PERIYAPATNA_66	10:00	18:23	08:23	LINE CLEAR AVAILED
3231	16-Jun-24	MYSORE	66	LINE	TN PURA-THAYURU	NO STATIONS EFFECTED	10:00	18:10	08:10	LINE CLEAR AVAILED
3232	16-Jun-24	MYSORE	220	LINE	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	09:52	19:11	09:19	LINE CLEAR AVAILED
3233	16-Jun-24	TUMKUR	66	LINE	220KV GUTTUR-66KV HALASABALU LINE	66KV GUTTUR, 66KV HARIHAR HOSPETE	09:54	10:06	00:12	TRIPPED ON FAULT
3234	16-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALURAMESHWARA LINE 1	66KV HALURAMESHWARA,MADADKERE	03:00	03:15	00:15	TRIPPED ON FAULT
3235	16-Jun-24	TUMKUR	66	LINE	66KV MATHOD-220KV HIRIYUR LINE 1	HALRAMESWARA_66,MADADKERE_66,RAMGIRI_66,BAGUR_66,HOSADURGA_66,NEERGUNDA_66	05:50	06:20	00:30	TRIPPED ON FAULT
3236	16-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-ANCHEPALYA-2	ANCHEPALYA 66KV	09:01	17:34	08:33	LINE CLEAR AVAILED
3237	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	09:40	18:13	08:33	LINE CLEAR AVAILED
3238	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	09:46	18:01	08:15	LINE CLEAR AVAILED
3239	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KOLALA (DABASPETE)	KOLALA_66, URDIGERE_66	09:15	18:15	09:00	LINE CLEAR AVAILED
3240	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	09:46	18:01	08:15	LINE CLEAR AVAILED
3241	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	09:32	18:09	08:37	LINE CLEAR AVAILED
3242	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	09:46	18:09	08:23	LINE CLEAR AVAILED
3243	16-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	09:55	18:05	08:10	LINE CLEAR AVAILED
3244	16-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS- GUTTUR66	GUTTUR_66	07:22	10:38	03:16	LINE CLEAR AVAILED
3245	16-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	08:20	10:38	02:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3246	16-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	08:32	15:01	06:29	LINE CLEAR AVAILED
3247	16-Jun-24	TUMKUR	66	LINE	GUTTUR220-HALASABALU_66	HALASABALU_66, GUTTUR_66, HARIHARA HOSPET_66	09:54	10:06	00:12	TRIPPED ON FAULT
3248	16-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	07:55	18:40	10:45	LINE CLEAR AVAILED
3249	16-Jun-24	TUMKUR	66	LINE	MADHUGIRI 220KV-KORATAGERE 1	KORATAGERE_66	10:24	18:32	08:08	LINE CLEAR AVAILED
3250	16-Jun-24	TUMKUR	66	LINE	SIRA220-SIRA66 LINE 2	66KV KALLAMBELLA	19:10	19:25	00:15	TRIPPED ON FAULT
3251	16-Jun-24	TUMKUR	66	LINE	SIRA66-KALAMBELLA	66KV KALLAMBELLA	19:10	19:25	00:15	TRIPPED ON FAULT
3252	16-Jun-24	TUMKUR	66	LINE	THALLAK 220KV-GOWRASAMUDRA	GOWRASAMUDRA,KONANSAGARA	17:55	17:59	00:04	LINE CLEAR AVAILED
3253	16-Jun-24	TUMKUR	66	TRANSFORMER	TR-1 (LV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:22	18:17	08:55	LINE CLEAR AVAILED
3254	16-Jun-24	TUMKUR	66	TRANSFORMER	TR-2 (LV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:28	18:00	08:32	LINE CLEAR AVAILED
3255	16-Jun-24	TUMKUR	66	TRANSFORMER	TR-3 (LV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:28	17:48	08:20	LINE CLEAR AVAILED
3256	16-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-CHIKKANAYAKANAHALLI	CHIKKANAYAKANAHALLI_110, SHETYKERE_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	10:46	11:08	00:22	LINE CLEAR AVAILED
3257	16-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	10:04	10:07	00:03	LINE CLEAR AVAILED
3258	16-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	11:01	11:16	00:15	TRIPPED ON FAULT
3259	16-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-TURUVEKERE	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	10:46	11:00	00:14	LINE CLEAR AVAILED
3260	16-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-NELAMANGALA	ANTHRASANAHALLI_220	10:53	17:45	06:52	LINE CLEAR AVAILED
3261	16-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-SHIMOGA	ANTHRASANAHALLI_220	10:45	17:38	06:53	LINE CLEAR AVAILED
3262	16-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-VASANTHNARASAPURA 1	VASANTHNARASAPURA KDB_220	09:54	17:32	07:38	LINE CLEAR AVAILED
3263	16-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-VASANTHNARASAPURA 2	VASANTHNARASAPURA KDB_220	09:55	17:32	07:37	LINE CLEAR AVAILED
3264	16-Jun-24	TUMKUR	220	LINE	KB CROSS 220KV-ANTHARASANAHALLI	ANTHARASANAHALLI_220	10:46	17:47	07:01	LINE CLEAR AVAILED
3265	16-Jun-24	TUMKUR	220	TRANSFORMER	TR-1 100MVA (HV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:46	18:06	08:20	LINE CLEAR AVAILED
3266	16-Jun-24	TUMKUR	220	TRANSFORMER	TR-2 100MVA (HV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:40	17:56	08:16	LINE CLEAR AVAILED
3267	16-Jun-24	TUMKUR	220	TRANSFORMER	TR-3 100MVA (HV SIDE) ANTHARASANAHALLI_220KV	ANTHARASANAHALLI_220KV	09:41	17:46	08:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3268	16-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- BTPS LINE	GUTTUR_400	12:40	15:39	02:59	LINE CLEAR AVAILED
3269	16-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERELINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3270	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	UKKALI_110	06:40	06:55	00:15	LINE CLEAR AVAILED
3271	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1&HV2(10MVA)	KULAGERI CROSS_110	10:00	10:12	00:12	LINE CLEAR AVAILED
3272	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	THORVI_110	18:02	18:06	00:04	TRIPPED ON FAULT
3273	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	TUMMINAKATTI_110	12:41	13:23	00:42	LINE CLEAR AVAILED
3274	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	UKKALI_110	06:40	06:55	00:15	LINE CLEAR AVAILED
3275	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20 MVA)	ZALKI_110	11:40	11:50	00:10	TRIPPED ON FAULT
3276	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	ALBAL_110	06:42	08:25	01:43	LINE CLEAR AVAILED
3277	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20 MVA)	ZALKI_110	07:30	07:40	00:10	TRIPPED ON FAULT
3278	17-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20 MVA)	ZALKI_110	11:48	12:05	00:17	LINE CLEAR AVAILED
3279	17-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3280	17-Jun-24	BAGALKOTE	110	LINE	ALBAL- ALGUR	ALBAL_110	20:35	20:45	00:10	TRIPPED ON FAULT
3281	17-Jun-24	BAGALKOTE	110	LINE	ATHARGA- RAILWAY LINE	ATHARGA_110	19:56	20:17	00:21	TRIPPED ON FAULT
3282	17-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3283	17-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- HUKKERI(UCHAGOAN)	BELGAUM_220	04:26	04:53	00:27	TRIPPED ON FAULT
3284	17-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
3285	17-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)			LINE CLEAR AVAILED
3286	17-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3287	17-Jun-24	BAGALKOTE	110	LINE	MUNDAGOD- HUBLI220 (SHIGGOAN220)	MUNDAGOD_110	22:38 (16.06.2024)	12:15 (17.06.2024)	13:37	LINE CLEAR AVAILED
3288	17-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
3289	17-Jun-24	BAGALKOTE	110	LINE	SHIGGOAN220- LN2(MUNDAGOD)	SHIGGOAN_220	22:13 (16.06.2024)	10:44 (17.06.2024)	12:31	TRIPPED ON FAULT
3290	17-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3291	17-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3292	17-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3293	17-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3294	17-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3295	17-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3296	17-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3297	17-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	JIGANI LINK ROAD	06:35	06:40	00:05	LINE CLEAR AVAILED
3298	17-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - SK STEEL	SK STEEL, JINDAL	19:37	19:56	00:19	TRIPPED ON FAULT
3299	17-Jun-24	BANGALORE	66	LINE	66KV GOKULA - BEL EHT	BEL(EHT)	07:50	09:10	01:20	TRIPPED ON FAULT
3300	17-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:49	11:50	00:01	LINE CLEAR AVAILED
3301	17-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 2	SRINIVASAPURA 66	18:39	18:50	00:11	TRIPPED ON FAULT
3302	17-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOLU CROSS	06:25	06:56	00:31	TRIPPED ON FAULT
3303	17-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	08:32	08:57	00:25	TRIPPED ON FAULT
3304	17-Jun-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	10:50	11:00	00:10	TRIPPED ON FAULT
3305	17-Jun-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	16:05	16:25	00:20	TRIPPED ON FAULT
3306	17-Jun-24	BANGALORE	66	LINE	66KV TYAMAGONDALU - RAILWAY TRACTION DODDABELE (EHT)	DODDABELE(EHT)	16:50	18:10	01:20	TRIPPED ON FAULT
3307	17-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDABELAVANGALA	01:33	01:53	00:20	TRIPPED ON FAULT
3308	17-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DASHAVARA	15:18	15:23	00:05	TRIPPED ON FAULT
3309	17-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BAGHMANE WORLD TECH PARK	13:25	15:10	01:45	LINE CLEAR AVAILED
3310	17-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HEJJALA	12:01	12:02	00:01	LINE CLEAR AVAILED
3311	17-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	NO STATION AFFECTED	23:59	09:36	09:37	LINE CLEAR AVAILED
3312	17-Jun-24	GULBARGA	110	TRANSFORMER	HV2	SOMASAMUDRA_110	13:55	14:05	00:10	TRIPPED ON FAULT
3313	17-Jun-24	GULBARGA	110	TRANSFORMER	HV2	SOMASAMUDRA_110	13:55	14:05	00:10	TRIPPED ON FAULT
3314	17-Jun-24	GULBARGA	110	TRANSFORMER	HV3	GUDURU_110	07:04	07:12	00:08	TRIPPED ON FAULT
3315	17-Jun-24	GULBARGA	110	TRANSFORMER	HV3	SOMASAMUDRA_110	07:04	07:12	00:08	TRIPPED ON FAULT
3316	17-Jun-24	GULBARGA	110	TRANSFORMER	HV3	GODUDURU_110	07:04	07:12	00:08	TRIPPED ON FAULT
3317	17-Jun-24	GULBARGA	110	TRANSFORMER	HV3&HV4	MUNIRABAD_220	09:55	10:00	00:05	TRIPPED ON FAULT
3318	17-Jun-24	GULBARGA	110	LINE	M.KOLLUR-DEODURGA	M.KOLLUR_110	20:35	20:48	00:13	TRIPPED ON FAULT
3319	17-Jun-24	GULBARGA	110	LINE	M.KOLLUR-SHAHPUR	M.KOLLUR_110	20:36	20:47	00:11	TRIPPED ON FAULT
3320	17-Jun-24	GULBARGA	110	LINE	SHAHPUR-YADGIR	YADGIR_110	03:44	03:51	00:07	TRIPPED ON FAULT
3321	17-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3322	17-Jun-24	GULBARGA	220	LINE	SEDAM-2-RAMASAMUDRA	SEDAM-2_220	13:54	14:33	00:39	TRIPPED ON FAULT
3323	17-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMPURA_66	13:35	13:55	00:20	LINE CLEAR AVAILED
3324	17-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	14:50	15:09	00:19	MAIN SUPPLY FAILURE
3325	17-Jun-24	HASSAN	110	TRANSFORMER	GURUVA-SLVPWR	GURUVAYANKERE_110	14:50	15:09	00:19	MAIN SUPPLY FAILURE
3326	17-Jun-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	05:26	05:39	00:13	TRIPPED ON FAULT
3327	17-Jun-24	HASSAN	110	TRANSFORMER	HV1	PUTTUR_110	09:29	12:38	03:09	LINE CLEAR AVAILED
3328	17-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	14:50	15:09	00:19	TRIPPED ON FAULT
3329	17-Jun-24	HASSAN	110	LINE	SHIVAPU-BIRUR	SHIVAPURA_110	17:10	18:25	01:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3330	17-Jun-24	HASSAN	220	LINE	GERSOPA-TALGUPA1	gen_gersoppa	10:09	13:47	03:38	LINE CLEAR AVAILED
3331	17-Jun-24	HASSAN	220	LINE	MRSSHM-STRP1	MRSMSG_220	10:09	13:47	03:38	LINE CLEAR AVAILED
3332	17-Jun-24	MYSORE	66	LINE	CR NAGARA-CHANDAKAVADI	CHANDAKAVADI_66	12:22	14:29	02:06	LINE CLEAR AVAILED
3333	17-Jun-24	MYSORE	66	LINE	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	12:53	13:10	00:17	TRIPPED ON FAULT
3334	17-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3335	17-Jun-24	MYSORE	66	TRANSFORMER	HV2	SATHEGALA_66	07:21	08:28	01:07	TRIPPED ON FAULT
3336	17-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
3337	17-Jun-24	MYSORE	66	LINE	KR PETE 220-SANTHEBACHALLI-1	NO STATIONS EFFECTED	05:40	05:46	00:06	TRIPPED ON FAULT
3338	17-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3339	17-Jun-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	07:35	07:41	00:06	TRIPPED ON FAULT
3340	17-Jun-24	MYSORE	66	LINE	VIJAYANAGARA-HOOTAGALLI	NO STATIONS EFFECTED	13:01	13:16	00:15	LINE CLEAR AVAILED
3341	17-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	12:47	12:57	00:10	TRIPPED ON FAULT
3342	17-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV BAGUR LINE	66KV RAMAGIRI , CHICKJAJUR	18:00	18:15	00:15	TRIPPED ON FAULT
3343	17-Jun-24	TUMKUR	66	LINE	HIRIYUR 220KV- MATHOD_1	MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	18:55	19:00	00:10	TRIPPED ON FAULT
3344	17-Jun-24	TUMKUR	220	LINE	MADHUGIRI 220-PAVAGADA 220-2	MADHUGIRI_220	18:26 (17.06.2024)	Kept Open		TRIPPED ON FAULT
3345	17-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERE LINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3346	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TOLAMATTI_110	16:13	17:03	00:50	LINE CLEAR AVAILED
3347	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RON_110	05:26	05:43	00:17	TRIPPED ON FAULT
3348	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	KUD DHARWAD_110	10:53	12:02	01:09	LINE CLEAR AVAILED
3349	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	HIDIKAL_110	12:42	13:27	00:45	LINE CLEAR AVAILED
3350	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	HIDIKAL_110	16:37	17:11	00:34	LINE CLEAR AVAILED
3351	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	HIDIKAL_110	17:35	18:06	00:31	LINE CLEAR AVAILED
3352	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	GUTTAL_110	11:20	11:58	00:38	LINE CLEAR AVAILED
3353	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	TOLAMATTI_110	16:13	17:04	00:51	LINE CLEAR AVAILED
3354	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	RON_110	05:26	05:42	00:16	TRIPPED ON FAULT
3355	18-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GULEDAGUDDA_110	10:10	10:40	00:30	LINE CLEAR AVAILED
3356	18-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV1	VAJRAMATTI_220	11:03	20:33	09:30	LINE CLEAR AVAILED
3357	18-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2(LV3)	BIJAPUR_220	13:43	14:26	00:43	LINE CLEAR AVAILED
3358	18-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3359	18-Jun-24	BAGALKOTE	110	LINE	ANKOLA- KUMTA(L2)	ANKOLA_110	13:13	19:05	05:52	TRIPPED ON FAULT
3360	18-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3361	18-Jun-24	BAGALKOTE	110	LINE	GAJENDRAGAD- RON1	GAJENDRAGAD_110	05:50	07:17	01:27	LINE CLEAR AVAILED
3362	18-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3363	18-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(G)- SOUBHAGYA LAXMI SUGARS	MAMADAPUR(G)_110	16:48 (01.06.2024)	18:23 (18.06.2024)	409:35:00	LINE CLEAR AVAILED
3364	18-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3365	18-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
3366	18-Jun-24	BAGALKOTE	110	LINE	RON- GAJENDRAGAD1	RON_110	05:26	07:17	01:51	TRIPPED ON FAULT
3367	18-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3368	18-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3369	18-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3370	18-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3371	18-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3372	18-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3373	18-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	MAHALINGAPUR_220	17:35	18:35	01:00	TRIPPED ON FAULT
3374	18-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	VAJRAMATTI_220	11:04	20:31	09:27	LINE CLEAR AVAILED
3375	18-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2(HV3)	BIJAPUR_220	13:42	14:25	00:43	LINE CLEAR AVAILED
3376	18-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	MAHALINGAPUR_220	12:16	15:49	03:33	LINE CLEAR AVAILED
3377	18-Jun-24	BAGALKOTE	220	LINE	GADAG- HARTI1	GADAG_220	10:36	13:58	03:22	LINE CLEAR AVAILED
3378	18-Jun-24	BAGALKOTE	220	LINE	GADAG- HARTI2	GADAG_220	10:36	13:58	03:22	LINE CLEAR AVAILED
3379	18-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR- NARENDRA1	MAHALINGAPUR_220	17:36	19:33	01:57	TRIPPED ON FAULT
3380	18-Jun-24	BAGALKOTE	220	LINE	MAHALINGAPUR-KUDACHI	MAHALINGAPUR_220	17:35	18:44	01:09	TRIPPED ON FAULT
3381	18-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3382	18-Jun-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	CHIKKENAHALLI, SHIVANAHALLI	19:56	20:00	00:04	TRIPPED ON FAULT
3383	18-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - D PALYA	D PALYA, GUDIBANDE, MANDIKAL	06:57	07:20	00:23	TRIPPED ON FAULT
3384	18-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI	10:06	15:45	05:39	LINE CLEAR AVAILED
3385	18-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, ADDAGAL, RAYALPADU	18:58	19:11	00:13	TRIPPED ON FAULT
3386	18-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	01:37	07:20	05:43	TRIPPED ON FAULT
3387	18-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	08:05	08:50	00:45	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3388	18-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	11:45	11:50	00:05	LINE CLEAR AVAILED
3389	18-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, KAMASAMUDRA, BEML, BANGARPETE	12:03	12:16	00:13	TRIPPED ON FAULT
3390	18-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, KAMASAMUDRA, BEML, BANGARPETE	12:03	12:16	00:13	TRIPPED ON FAULT
3391	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	11:17	11:35	00:18	TRIPPED ON FAULT
3392	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	17:54	18:20	00:26	TRIPPED ON FAULT
3393	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	18:32	18:42	00:10	TRIPPED ON FAULT
3394	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDIGANAHALLI	09:22	09:40	00:18	TRIPPED ON FAULT
3395	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWNIPALLI	00:15	00:25	00:10	TRIPPED ON FAULT
3396	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GOWNIPALLI	02:50	03:05	00:15	TRIPPED ON FAULT
3397	18-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MALLASANDRA	12:25	12:30	00:05	LINE CLEAR AVAILED
3398	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	10:45	11:15	00:30	LINE CLEAR AVAILED
3399	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TUBAGERE	19:52	20:06	00:14	TRIPPED ON FAULT
3400	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GOWNIPALLI	10:25	10:45	00:20	TRIPPED ON FAULT
3401	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KGF	12:22	12:40	00:18	LINE CLEAR AVAILED
3402	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	15:18	15:42	00:24	LINE CLEAR AVAILED
3403	18-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	19:41	19:48	00:07	TRIPPED ON FAULT
3404	18-Jun-24	GULBARGA	66	LINE	BANVEKAL-HOSAHALLI	HOSAHALLI_66,HUDEM_66	10:30	17:00	06:30	TRIPPED ON FAULT
3405	18-Jun-24	GULBARGA	66	LINE	HOSAHALLI-HUDEM	HUDEM_66	10:30	17:05	06:35	TRIPPED ON FAULT
3406	18-Jun-24	GULBARGA	110	LINE	HALBARGA-KOLHAR-2	KOLHAR-2_110	15:50	17:00	01:10	LINE CLEAR AVAILED
3407	18-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110, RUDRAWADI_110	10:22	15:03	04:41	LINE CLEAR AVAILED
3408	18-Jun-24	GULBARGA	110	LINE	KURUGOD-KIADB	KURUGODU_110	03:44	03:54	00:10	MAIN SUPPLY FAILURE
3409	18-Jun-24	GULBARGA	110	LINE	MUNIRABAD-HAREKRISHANA	MUNIRABAD_220	10:07	17:17	07:10	LINE CLEAR AVAILED
3410	18-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGIRICROSS	SIRIGIRICROSS_110	04:25	07:30	03:05	TRIPPED ON FAULT
3411	18-Jun-24	GULBARGA	220	TRANSFORMER	HV2	MUNIRABAD_220	10:25	16:18	05:53	LINE CLEAR AVAILED
3412	18-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3413	18-Jun-24	HASSAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_66	10:05	10:09	00:04	LINE CLEAR AVAILED
3414	18-Jun-24	HASSAN	66	LINE	DODDAHA-HOOTGALLI	DODDAHALLI_66	11:59	12:06	00:07	LINE CLEAR AVAILED
3415	18-Jun-24	HASSAN	66	LINE	HADAVAN-HNPURA	HADAVANAHALLI_66	10:50	13:05	02:15	LINE CLEAR AVAILED
3416	18-Jun-24	HASSAN	66	LINE	HNPR2-CRPTN	HNPURA_220	10:39	13:20	02:41	LINE CLEAR AVAILED
3417	18-Jun-24	HASSAN	66	TRANSFORMER	HV1	RAMESHWARNAGARA_66	10:32	14:36	04:04	LINE CLEAR AVAILED
3418	18-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMESHWARNAGARA_66	10:08	14:36	04:28	LINE CLEAR AVAILED
3419	18-Jun-24	HASSAN	66	LINE	RMWNGR-HASSAN	RAMESHWARNAGARA_66	10:32	14:36	04:04	LINE CLEAR AVAILED
3420	18-Jun-24	HASSAN	66	LINE	SHANTHI-RMSWRNGR	SHANTHIGRAMA_66	10:31	14:14	03:43	LINE CLEAR AVAILED
3421	18-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	05:55	06:07	00:12	MAIN SUPPLY FAILURE
3422	18-Jun-24	HASSAN	110	TRANSFORMER	GURUVA-SLVPWR	GURUVAYANKERE_110	05:55	06:07	00:12	MAIN SUPPLY FAILURE
3423	18-Jun-24	HASSAN	110	TRANSFORMER	HV1	SORABA_110	09:42	10:15	00:33	LINE CLEAR AVAILED
3424	18-Jun-24	HASSAN	110	LINE	KADUR-YGTI	KADUR_220	14:19	15:01	00:42	TRIPPED ON FAULT
3425	18-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	05:55	06:07	00:12	TRIPPED ON FAULT
3426	18-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	05:55	06:07	00:12	TRIPPED ON FAULT
3427	18-Jun-24	HASSAN	220	LINE	KAVOOR-KEMAR3	KAVOOR_220	13:15	17:01	03:46	LINE CLEAR AVAILED
3428	18-Jun-24	HASSAN	220	LINE	KAVOOR-KEMR1	KAVOOR_220	10:22	11:49	01:27	LINE CLEAR AVAILED
3429	18-Jun-24	HASSAN	220	LINE	KEMAR-KAVR3	KEMAR_220	13:15	17:02	03:47	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3430	18-Jun-24	HASSAN	220	LINE	KEMAR-PUTUR1	KEMAR_220	14:30	16:40	02:10	LINE CLEAR AVAILED
3431	18-Jun-24	HASSAN	220	LINE	KEMAR-PUTUR2	KEMAR_220	10:15	14:14	03:59	LINE CLEAR AVAILED
3432	18-Jun-24	HASSAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	17:17	17:27	00:10	TRIPPED ON FAULT
3433	18-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	10:22	11:49	01:27	LINE CLEAR AVAILED
3434	18-Jun-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	14:30	16:40	02:10	LINE CLEAR AVAILED
3435	18-Jun-24	HASSAN	220	LINE	PUTTUR-KEMAR2	PUTTUR_220	10:15	14:14	03:59	LINE CLEAR AVAILED
3436	18-Jun-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA3	gen_sharavthy	13:14	15:58	02:44	TRIPPED ON FAULT
3437	18-Jun-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA4	gen_sharavthy	13:14	16:06	02:52	TRIPPED ON FAULT
3438	18-Jun-24	HASSAN	220	LINE	SHRAVITY-TALAGUPPA 2	gen_sharavthy	13:14	16:10	02:56	TRIPPED ON FAULT
3439	18-Jun-24	MYSORE	66	LINE	CHANDALLI-BG PURA	NO STATIONS EFFECTED	05:29	05:34	00:05	TRIPPED ON FAULT
3440	18-Jun-24	MYSORE	66	LINE	CHIKAMANDYA-MANDYA	NO STATIONS EFFECTED	13:42	13:52	00:10	TRIPPED ON FAULT
3441	18-Jun-24	MYSORE	66	LINE	HDKOTE-TARAKA	NO STATIONS EFFECTED	16:15	16:18	00:02	LINE CLEAR AVAILED
3442	18-Jun-24	MYSORE	66	LINE	HDKOTE-YEREHALLI HAND POST	HDKOTE_66 ANTARSANTE_66	13:47	13:59	00:11	TRIPPED ON FAULT
3443	18-Jun-24	MYSORE	66	LINE	HOTAGALLY-BELAGOLA	NO STATIONS EFFECTED	10:20	12:14	01:54	LINE CLEAR AVAILED
3444	18-Jun-24	MYSORE	66	LINE	HOTAGALLY-KAGGERE HAMPAPURA	NO STATIONS EFFECTED	10:22	11:58	01:36	LINE CLEAR AVAILED
3445	18-Jun-24	MYSORE	66	LINE	HOTAGALLY-VIJAYNAGAR	NO STATIONS EFFECTED	09:46	11:46	02:00	LINE CLEAR AVAILED
3446	18-Jun-24	MYSORE	66	TRANSFORMER	HV1	BANNIMANTAPA-66	11:54	13:00	01:05	LINE CLEAR AVAILED
3447	18-Jun-24	MYSORE	66	TRANSFORMER	HV1	HANAGODU_66	13:23	13:28	00:05	TRIPPED ON FAULT
3448	18-Jun-24	MYSORE	66	TRANSFORMER	HV1	KOLKARANADODDI_66	10:00	15:23	05:23	LINE CLEAR AVAILED
3449	18-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDGERE_66	19:41	20:04	00:22	LINE CLEAR AVAILED
3450	18-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3451	18-Jun-24	MYSORE	66	TRANSFORMER	HV2	BANNIMANTAPA-66	13:00	13:47	00:47	LINE CLEAR AVAILED
3452	18-Jun-24	MYSORE	66	TRANSFORMER	HV2	KOLKARANADODDI_66	10:00	15:23	05:23	LINE CLEAR AVAILED
3453	18-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
3454	18-Jun-24	MYSORE	66	LINE	KADAKOLA-JAYAPURA	NO STATIONS EFFECTED	06:35	06:46	00:11	TRIPPED ON FAULT
3455	18-Jun-24	MYSORE	66	LINE	KUSHALNAGAR-MYSORE 1	MIRLE_66	11:28	11:58	00:29	TRIPPED ON FAULT
3456	18-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3457	18-Jun-24	MYSORE	66	LINE	TUBINKERE-MANDYA2	NO STATIONS EFFECTED	05:25	05:34	00:08	TRIPPED ON FAULT
3458	18-Jun-24	MYSORE	66	LINE	VJAYANAGARA-HOTAGALY	NO STATIONS EFFECTED	09:44	11:44	02:00	LINE CLEAR AVAILED
3459	18-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2	66KV HULLENAHALLI,KUDUR,SRIGIRIPURA	06:34	06:44	00:10	TRIPPED ON FAULT
3460	18-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR, MALEBENNUR, DEVARBELAKERE	13:25	13:35	00:10	TRIPPED ON FAULT
3461	18-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS	15:27	15:57	00:30	TRIPPED ON FAULT
3462	18-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	05:54	06:15	00:21	TRIPPED ON FAULT
3463	18-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	18:44 (18.06.2024)	Kept Open		LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3464	18-Jun-24	TUMKUR	66	LINE	GUTTURU 220KV-66KV HALASABALU (O/G)	66KV GUTTUR 66KV HARIHAR HOSPETE POLY FIBER	04:28	06:10	01:42	TRIPPED ON FAULT
3465	18-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- KUNDUR66	KUNDUR,_66,MALEBENNUR_66 ,DEVARABELKERE_66	13:25	13:35	00:10	TRIPPED ON FAULT
3466	18-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV- NALLUR_66	NALLUR_66, BASAVAPATNA_66	10:08	10:18	00:10	TRIPPED ON FAULT
3467	18-Jun-24	TUMKUR	66	LINE	MADHUGIRI_220-MIDIGESHI_66-2 LINE	66KV MIDIGESHI	17:20	17:32	00:12	TRIPPED ON FAULT
3468	18-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-AMMASANDRA_110	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	15:58	16:17	00:19	LINE CLEAR AVAILED
3469	18-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-SHIMOGA	ANTHRASANAHALLI_220	17:18	17:26	00:08	MAIN SUPPLY FAILURE
3470	18-Jun-24	TUMKUR	220	LINE	MADHUGIRI_220-PAVAGADA_220-1	MADHUGIRI_220	09:40	12:28	02:48	LINE CLEAR AVAILED
3471	18-Jun-24	TUMKUR	220	LINE	MADHUGIRI_220-PAVAGADA_220-2	MADHUGIRI_220	18:26 (17.06.2024)	12:28 (18.06.2024)	18:02	TRIPPED ON FAULT
3472	18-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERE LINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3473	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KADANAKOPPA_110	10:38	18:58	08:20	LINE CLEAR AVAILED
3474	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HEBBALLI_110	12:19	12:40	00:21	LINE CLEAR AVAILED
3475	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HIDIKALDAM_110	14:41	17:10	02:29	LINE CLEAR AVAILED
3476	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALAGHATAGI_110	12:12	13:08	00:56	LINE CLEAR AVAILED
3477	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	NAVALAGI_110	11:27	12:17	00:50	LINE CLEAR AVAILED
3478	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MALGHAN(B)_110	16:24	17:06	00:42	LINE CLEAR AVAILED
3479	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	AINAPUR_110	04:06	04:25	00:19	TRIPPED ON FAULT
3480	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	BANAHATTI_110	10:02	17:36	07:34	LINE CLEAR AVAILED
3481	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	KADANAKOPPA_110	10:38	18:58	08:20	LINE CLEAR AVAILED
3482	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	BYADAGI_110	16:58	17:46	00:48	LINE CLEAR AVAILED
3483	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	HIDAKAL_110	15:42	16:34	00:52	LINE CLEAR AVAILED
3484	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	HIDAKAL_110	16:47	17:48	01:01	LINE CLEAR AVAILED
3485	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	HIDKALDAM_110	09:21	14:29	05:08	LINE CLEAR AVAILED
3486	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	YELPARAHATTI_110	11:57 (19.06.2024)			LINE CLEAR AVAILED
3487	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4(20MVA)	KULIGOD_110_110	16:27	16:52	00:25	TRIPPED ON FAULT
3488	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	BELLATTI_110	11:51	12:27	00:36	LINE CLEAR AVAILED
3489	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	KADANAKOPPA_110	10:38	18:58	08:20	LINE CLEAR AVAILED
3490	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (20MVA)	KANABARGI_110	11:07	11:46	00:39	LINE CLEAR AVAILED
3491	19-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2(10MVA)	MURDESHWAR_110	12:16	12:30	00:14	LINE CLEAR AVAILED
3492	19-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3493	19-Jun-24	BAGALKOTE	110	LINE	ANKALI-HERMS BIO IPP	HEMS BIO IPP_110 ANKALI_110	11:25	17:23	05:58	LINE CLEAR AVAILED
3494	19-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3495	19-Jun-24	BAGALKOTE	110	LINE	HIDKAL-MAHALINGAPUR	HIDAKAL_110	12:03	12:23	00:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3496	19-Jun-24	BAGALKOTE	110	LINE	HIDKAL-RAIBAG	HIDAKAL_110	12:03	12:25	00:22	LINE CLEAR AVAILED
3497	19-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL_110	9:50 (29.05.2024)			LINE CLEAR AVAILED
3498	19-Jun-24	BAGALKOTE	110	LINE	KADANAKOPPA-HUBLI	KADANAKOPPA_110	10:35	17:50	07:15	LINE CLEAR AVAILED
3499	19-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- BANAHAATTI	MAHALINGAPUR_220	13:02	15:33	02:31	LINE CLEAR AVAILED
3500	19-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- HIDIKAL	MAHALINGAPUR_220	07:40	12:11	04:31	TRIPPED ON FAULT
3501	19-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- TERDAL	MAHALINGAPUR_220	07:37	07:55	00:18	TRIPPED ON FAULT
3502	19-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- TERDAL	MAHALINGAPUR_220	09:07	09:56	00:49	TRIPPED ON FAULT
3503	19-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR(B)- BAGEWADI1	MAMADAPUR(B)_110	06:37	06:48	00:11	TRIPPED ON FAULT
3504	19-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3505	19-Jun-24	BAGALKOTE	110	LINE	NAVALAGI- F2(BANAHAATTI)	NAVALAGI_110	12:49	15:35	02:46	LINE CLEAR AVAILED
3506	19-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
3507	19-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3508	19-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3509	19-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3510	19-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3511	19-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3512	19-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3513	19-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2(HV3)	NARENDRA_220	10:30	12:17	01:47	LINE CLEAR AVAILED
3514	19-Jun-24	BAGALKOTE	220	LINE	BAGALKOT- GADAG1	BAGALKOT_220	10:45	16:02	05:17	LINE CLEAR AVAILED
3515	19-Jun-24	BAGALKOTE	220	LINE	BAGALKOT- GADAG2	BAGALKOT_220	10:46	16:02	05:16	LINE CLEAR AVAILED
3516	19-Jun-24	BAGALKOTE	220	LINE	GADAG- BAGALKOT1	GADAG_220	10:44	16:03	05:19	LINE CLEAR AVAILED
3517	19-Jun-24	BAGALKOTE	220	LINE	GADAG- BAGALKOT2	GADAG_220	10:45	16:03	05:18	LINE CLEAR AVAILED
3518	19-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3519	19-Jun-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	AGALAKOTE	10:00	17:40	07:40	LINE CLEAR AVAILED
3520	19-Jun-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	MATHIKERE	19:00	19:05	00:05	LINE CLEAR AVAILED
3521	19-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	07:02	07:28	00:26	MAIN SUPPLY FAILURE
3522	19-Jun-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	BURUDUGUNTE, DIBBURAHALLI	18:37	18:49	00:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3523	19-Jun-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	09:45	16:40	06:55	LINE CLEAR AVAILED
3524	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - 66KV CHINTAMANI	CHINTAMANI 66, SM MANGALA, 66/25kV RAILWAY TRACTION	09:44	18:10	08:26	LINE CLEAR AVAILED
3525	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	09:46	18:46	09:00	LINE CLEAR AVAILED
3526	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	09:46	18:46	09:00	LINE CLEAR AVAILED
3527	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - IRGAMPALLY	IRAGAMPALLI, M GOLLAHALLI	09:45	18:28	08:43	LINE CLEAR AVAILED
3528	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - NANDIGANAHALLY	NANDIGANAHALLI	09:44	18:16	08:32	LINE CLEAR AVAILED
3529	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - SIDDALAGHATTA	SIDDALAGHATTA, MELUR, Y HUNSENAHALLI	09:45	18:15	08:30	LINE CLEAR AVAILED
3530	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TADIGOL CROSS	NO STATION AFFECTED	06:58	07:10	00:12	TRIPPED ON FAULT
3531	19-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	09:45	18:54	09:09	LINE CLEAR AVAILED
3532	19-Jun-24	BANGALORE	66	LINE	66KV CHINTMANI 220 - RAGHUTTAHALLI	K RAGHUTTAHALLI, BOMMEPALLI, YENNIGADALE	09:45	18:12	08:27	LINE CLEAR AVAILED
3533	19-Jun-24	BANGALORE	66	LINE	66KV DG1 PUTTENAHALLI 220 - KHB DC_SC	KHB	12:46	15:44	02:58	LINE CLEAR AVAILED
3534	19-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - VATADAHOSAHALLI - MITTEMARI	VATADAHOSAHALLI	06:50	07:00	00:10	LINE CLEAR AVAILED
3535	19-Jun-24	BANGALORE	66	LINE	66KV IRGAMPALLI - BURUDAGUNTE	BURUDUGUNTE	09:44	16:52	07:08	LINE CLEAR AVAILED
3536	19-Jun-24	BANGALORE	66	LINE	66KV JALAMANGALA - MATHIKERE	MATHIKERE	10:00	11:30	01:30	LINE CLEAR AVAILED
3537	19-Jun-24	BANGALORE	66	LINE	66KV KEONISC (ELECTRONIC CITY) - HULIMANGALA	HULIMANGALA	14:43	15:41	00:58	LINE CLEAR AVAILED
3538	19-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	12:14	12:17	00:03	LINE CLEAR AVAILED
3539	19-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	09:25	10:40	01:15	LINE CLEAR AVAILED
3540	19-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI	17:05	17:10	00:05	LINE CLEAR AVAILED
3541	19-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	18:35	18:40	00:05	LINE CLEAR AVAILED
3542	19-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	TG HALLI, VG DODDI, TAVAREKERE	09:43	11:43	02:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3543	19-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	MALUR IND AREA, ADL(EHT), BEST STEEL(EHT)	05:42	06:40	00:58	TRIPPED ON FAULT
3544	19-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	23:13	23:24	00:11	TRIPPED ON FAULT
3545	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	13:16	13:28	00:12	MAIN SUPPLY FAILURE
3546	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKON	13:16	13:30	00:14	MAIN SUPPLY FAILURE
3547	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - KAGGALIPURA (BRIGADE MEADOWS)	BRIGADE MEADOWS, SHOBHA FOREST	13:16	13:27	00:11	MAIN SUPPLY FAILURE
3548	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI, SOUTH CITY	13:16	13:28	00:12	MAIN SUPPLY FAILURE
3549	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SAINT GOBIN - BHURUKA GAS - ORCHID LAMINTES 1 - A.O SMITH - ORCHID LAMINATES-2	ORCHID LAMINATES, AO SMITH(EHT), SAINT GOBIN, BHORUKA	13:20	13:24	00:04	MAIN SUPPLY FAILURE
3550	19-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	YEDAMADU, HANUMANTHNAGARA	13:16	13:28	00:12	MAIN SUPPLY FAILURE
3551	19-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - G KODIHALLI	G KODIHALLI	09:48	18:12	08:24	LINE CLEAR AVAILED
3552	19-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - LAKSHMIPURA 3	ADDAGAL, GOWNIPALLI, RAYALPADU, SOMAYAJANAHALLI, TATA SOLAR	09:48	18:15	08:27	LINE CLEAR AVAILED
3553	19-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - SRINIVASAPURA 66 LINE 2	SRINIVASAPURA	09:48	18:09	08:21	LINE CLEAR AVAILED
3554	19-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - TADIGOL CROSS	TADIGOLU CROSS	09:48	18:18	08:30	LINE CLEAR AVAILED
3555	19-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	YELDUR, DALASANUR	09:48	18:18	08:30	LINE CLEAR AVAILED
3556	19-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	12:27	15:43	03:16	LINE CLEAR AVAILED
3557	19-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI	18:16	18:21	00:05	TRIPPED ON FAULT
3558	19-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	NANGLI, BYRAKUR	18:43	18:55	00:12	TRIPPED ON FAULT
3559	19-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	DEVARABISANAHALLI	11:00	14:35	03:35	LINE CLEAR AVAILED
3560	19-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	11:00	11:05	00:05	LINE CLEAR AVAILED
3561	19-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	14:25	14:40	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3562	19-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, HULIMANGALA, INFOSYS(EHT)	17:51	18:20	00:29	TRIPPED ON FAULT
3563	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KHB	11:00	11:10	00:10	LINE CLEAR AVOIDED
3564	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KHB	12:46	15:46	03:00	LINE CLEAR AVOIDED
3565	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KENGERI SATELLITE TOWN	06:44	06:49	00:05	TRIPPED ON FAULT
3566	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SARAKKI	11:23	17:42	06:19	LINE CLEAR AVOIDED
3567	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SOMANAHALLI 220	13:18	13:25	00:07	MAIN SUPPLY FAILURE
3568	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SAUDELA	10:15	14:35	04:20	LINE CLEAR AVOIDED
3569	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DIBBURAHALLI	09:45	17:45	08:00	LINE CLEAR AVOIDED
3570	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIJAYAPURA	13:05	13:10	00:05	LINE CLEAR AVOIDED
3571	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHELUR	17:10	17:12	00:02	LINE CLEAR AVOIDED
3572	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HULIMANGALA	13:18	13:21	00:03	LINE CLEAR AVOIDED
3573	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	10:52	11:01	00:09	TRIPPED ON FAULT
3574	19-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	14:46	14:52	00:06	TRIPPED ON FAULT
3575	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KHB	12:46	15:47	03:01	LINE CLEAR AVOIDED
3576	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SARAKKI	10:08	15:46	05:38	LINE CLEAR AVOIDED
3577	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SOMANAHALLI 220	13:18	13:25	00:07	MAIN SUPPLY FAILURE
3578	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANJANAPURA	13:59	14:07	00:08	LINE CLEAR AVOIDED
3579	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SAUDELA	10:15	14:35	04:20	LINE CLEAR AVOIDED
3580	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DIBBURAHALLI	09:45	17:40	07:55	LINE CLEAR AVOIDED
3581	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	THAYALUR	16:10	16:45	00:35	LINE CLEAR AVOIDED
3582	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HANUMANTHNAGARA	12:00	13:25	01:25	LINE CLEAR AVOIDED
3583	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	08:30	08:35	00:05	TRIPPED ON FAULT
3584	19-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HULIMANGALA	11:47	11:57	00:10	LINE CLEAR AVOIDED
3585	19-Jun-24	BANGALORE	66	TRANSFORMER	HV3	SARAKKI	12:21	17:52	05:31	LINE CLEAR AVOIDED
3586	19-Jun-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASPURA 1	SRINIVASAPURA 220	09:48	17:53	08:05	LINE CLEAR AVOIDED
3587	19-Jun-24	BANGALORE	220	LINE	220KV CHINTAMANI 220 - SRINIVASPURA 2	SRINIVASAPURA 220	09:48	17:53	08:05	LINE CLEAR AVOIDED
3588	19-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 1	CHINTAMANI 220	09:59	20:19	10:20	LINE CLEAR AVOIDED
3589	19-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - CHINTAMANI 2	CHINTAMANI 220	09:59	17:50	07:51	LINE CLEAR AVOIDED
3590	19-Jun-24	BANGALORE	220	TRANSFORMER	HV1	SOMANAHALLI 220	13:20	13:24	00:04	LINE CLEAR AVOIDED
3591	19-Jun-24	BANGALORE	220	TRANSFORMER	HV3	SOMANAHALLI 220	13:20	13:24	00:04	LINE CLEAR AVOIDED
3592	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-GIRIYAPURA	GIRIYAPURA_66	12:40	13:45	01:05	TRIPPED ON FAULT
3593	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-HARVI	HARVI_66	12:40	13:20	00:40	MAIN SUPPLY FAILURE
3594	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-HARVI	HARVI_66	12:40	13:24	00:44	MAIN SUPPLY FAILURE
3595	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-HIREHADAGALI	HIREHADAGALI_66	12:40	13:45	01:05	TRIPPED ON FAULT
3596	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-MAGALA	MAGALA_66	12:40	13:45	01:05	TRIPPED ON FAULT
3597	19-Jun-24	GULBARGA	66	LINE	BADALADUKU-MOREGERE	MOREGERE_66	12:40	13:25	00:45	MAIN SUPPLY FAILURE
3598	19-Jun-24	GULBARGA	66	LINE	HARAPANAHALLI-BADALADUKU	HARAPANAHALLI_66,PUNABH GHATTA_66	12:40	13:24	00:44	MAIN SUPPLY FAILURE
3599	19-Jun-24	GULBARGA	66	LINE	HARAPANAHALLI- NEELGUNDA	HARAPANAHALLI_66	12:40	13:25	00:45	MAIN SUPPLY FAILURE
3600	19-Jun-24	GULBARGA	66	LINE	HB HALLI-ITTAGI	HB HALLI_66	12:40	13:25	00:45	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3601	19-Jun-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	12:40	13:45	01:05	TRIPPED ON FAULT
3602	19-Jun-24	GULBARGA	110	LINE	LADHA-KAMALNAGAR	LADHA_110	18:45	19:45	01:00	LINE CLEAR AVAILED
3603	19-Jun-24	GULBARGA	110	LINE	LINGASUGUR-GURGUNTA	GURGUNTA_110	15:05	17:38	02:33	LINE CLEAR AVAILED
3604	19-Jun-24	GULBARGA	110	LINE	LINGASUGUR-KAREPOWER	LINGASUGUR_220	05:31	05:40	00:09	TRIPPED ON FAULT
3605	19-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	05:15	05:25	00:10	TRIPPED ON FAULT
3606	19-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGIRICROSS	SIRIGIRICROSS_110	21:16	22:00	00:44	TRIPPED ON FAULT
3607	19-Jun-24	GULBARGA	110	LINE	YARADONA-BENNUR	YARADONA_110, BENNUR_110	10:00	16:25	06:25	LINE CLEAR AVAILED
3608	19-Jun-24	GULBARGA	220	LINE	HALWARTHY-DRUVADESH	HALWARTHY_220	13:18	17:31	04:13	LINE CLEAR AVAILED
3609	19-Jun-24	GULBARGA	220	LINE	LINGASUGUR-RTPS1	LINGASUGUR_220	09:45	11:43	01:58	LINE CLEAR AVAILED
3610	19-Jun-24	GULBARGA	220	LINE	MALLAT-RTPS	RTPS_220	16:18	17:09	00:51	TRIPPED ON FAULT
3611	19-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3612	19-Jun-24	GULBARGA	220	LINE	SHAHPUR-LINGASUGUR	SHAHPUR_220	12:11	13:30	01:19	LINE CLEAR AVAILED
3613	19-Jun-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	10:40	10:45	00:05	MAIN SUPPLY FAILURE
3614	19-Jun-24	HASSAN	66	LINE	ARAKAL-HASSAN	ARAKALGUD_66	12:30	12:33	00:03	MAIN SUPPLY FAILURE
3615	19-Jun-24	HASSAN	66	LINE	ARAKAL-MALLIPTNA	ARAKALGUD_66	10:45	11:05	00:20	LINE CLEAR AVAILED
3616	19-Jun-24	HASSAN	66	LINE	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	14:42	14:52	00:10	TRIPPED ON FAULT
3617	19-Jun-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	10:41	10:47	00:06	LINE CLEAR AVAILED
3618	19-Jun-24	HASSAN	66	LINE	HASSN22-ARAKALGUD	HASSAN_220	12:29	12:33	00:04	LINE CLEAR AVAILED
3619	19-Jun-24	HASSAN	66	LINE	HASSN22-BELUR	HASSAN_220	10:37	12:42	02:05	LINE CLEAR AVAILED
3620	19-Jun-24	HASSAN	66	LINE	HASSN22-HSN66	HASSAN_220	10:29	10:31	00:02	LINE CLEAR AVAILED
3621	19-Jun-24	HASSAN	66	LINE	HASSN22-HSN66	HASSAN_220	12:12	12:15	00:03	LINE CLEAR AVAILED
3622	19-Jun-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	10:36	10:40	00:04	LINE CLEAR AVAILED
3623	19-Jun-24	HASSAN	66	LINE	HASSN22-UDDURKOPLU	HASSAN_220	12:21	12:41	00:20	LINE CLEAR AVAILED
3624	19-Jun-24	HASSAN	66	LINE	HNPR2-HASS1	HNPURA_220	11:15	15:09	03:54	LINE CLEAR AVAILED
3625	19-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR2	HNPURA_220	01:03	01:13	00:10	TRIPPED ON FAULT
3626	19-Jun-24	HASSAN	66	TRANSFORMER	HV1	HNPURA_220	10:22	14:25	04:03	LINE CLEAR AVAILED
3627	19-Jun-24	HASSAN	66	TRANSFORMER	LV2	HASSAN_220	10:33	12:07	01:34	LINE CLEAR AVAILED
3628	19-Jun-24	HASSAN	110	TRANSFORMER	HV1	BIRUR_110	10:11	17:47	07:36	LINE CLEAR AVAILED
3629	19-Jun-24	HASSAN	110	TRANSFORMER	HV1	NERALEKERE_220	09:39	12:17	02:38	LINE CLEAR AVAILED
3630	19-Jun-24	HASSAN	110	TRANSFORMER	HV1	SHIVAPURA_110	10:11	20:26	10:15	LINE CLEAR AVAILED
3631	19-Jun-24	HASSAN	110	TRANSFORMER	HV2	BIRUR_110	10:11	17:48	07:37	LINE CLEAR AVAILED
3632	19-Jun-24	HASSAN	110	TRANSFORMER	HV2	NERALEKERE_220	09:56	12:17	02:21	LINE CLEAR AVAILED
3633	19-Jun-24	HASSAN	110	TRANSFORMER	HV6	KAVOOR_220	10:00	14:40	04:40	LINE CLEAR AVAILED
3634	19-Jun-24	HASSAN	110	LINE	KADUR-NAGENAHALI	KADUR_220	10:09	14:12	04:03	LINE CLEAR AVAILED
3635	19-Jun-24	HASSAN	110	LINE	KADUR-NERELEKERE	KADUR_220	10:10	17:46	07:36	LINE CLEAR AVAILED
3636	19-Jun-24	HASSAN	110	TRANSFORMER	LV1	KADUR_220	11:27	14:13	02:46	LINE CLEAR AVAILED
3637	19-Jun-24	HASSAN	110	LINE	NERALA-TEREKERE	NERALEKERE_220	10:05	12:19	02:14	LINE CLEAR AVAILED
3638	19-Jun-24	HASSAN	110	LINE	SHIVAPU-BIRUR	SHIVAPURA_110	10:11	20:26	10:15	LINE CLEAR AVAILED
3639	19-Jun-24	HASSAN	110	LINE	SHIVAPU-NERLEKERE	SHIVAPURA_110	10:11	20:26	10:15	LINE CLEAR AVAILED
3640	19-Jun-24	HASSAN	220	LINE	DAVANGERE	MRSMSG_220	10:01	15:39	05:38	LINE CLEAR AVAILED
3641	19-Jun-24	HASSAN	220	LINE	HGUNJE-KMR	HEGGUNJE_220	10:53	13:09	02:16	LINE CLEAR AVAILED
3642	19-Jun-24	HASSAN	220	TRANSFORMER	HV1	KADUR_220	11:27	14:13	02:46	LINE CLEAR AVAILED
3643	19-Jun-24	HASSAN	220	TRANSFORMER	HV2	HASSAN_220	10:33	12:07	01:34	LINE CLEAR AVAILED
3644	19-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor1	KEMAR_220	13:23	15:35	02:12	LINE CLEAR AVAILED
3645	19-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	15:39	16:41	01:02	LINE CLEAR AVAILED
3646	19-Jun-24	HASSAN	220	LINE	KEMAR-Varahi3	KEMAR_220	10:53	13:09	02:16	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3647	19-Jun-24	MYSORE	66	LINE	BEGUR-B MATTGERE	NO STATIONS EFFECTED	07:23	07:35	00:12	TRIPPED ON FAULT
3648	19-Jun-24	MYSORE	66	LINE	BGPURA-HEBBANI	NO STATIONS EFFECTED	11:01	12:01	00:59	LINE CLEAR AVAILED
3649	19-Jun-24	MYSORE	66	LINE	BOGADHI-MYSORE SOUTH	NO STATIONS EFFECTED	05:05	10:01	04:56	LINE CLEAR AVAILED
3650	19-Jun-24	MYSORE	66	LINE	CRNAGAR-YALANDUR	NO STATIONS EFFECTED	09:41	17:16	07:35	LINE CLEAR AVAILED
3651	19-Jun-24	MYSORE	66	LINE	GUNDLUPETE-KABBALLI	KABBALLI_66	05:30	05:35	00:05	TRIPPED ON FAULT
3652	19-Jun-24	MYSORE	66	LINE	HARVEY-BEGUR	NO STATIONS EFFECTED	09:02	16:59	07:57	LINE CLEAR AVAILED
3653	19-Jun-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	NO STATIONS EFFECTED	11:01	12:01	01:00	LINE CLEAR AVAILED
3654	19-Jun-24	MYSORE	66	LINE	HEBBANI-SATHEGALA	NO STATIONS EFFECTED	11:25	13:25	02:00	LINE CLEAR AVAILED
3655	19-Jun-24	MYSORE	66	LINE	HEBBANI-VADKEPURA	VADKEPURA_66 MALIYUR_66 KIRUGAVALU_66	02:52	03:08	00:16	TRIPPED ON FAULT
3656	19-Jun-24	MYSORE	66	TRANSFORMER	HV1	BOOKANAKERE_66	17:01	17:19	00:18	LINE CLEAR AVAILED
3657	19-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARVEY_66	09:02	17:01	07:59	LINE CLEAR AVAILED
3658	19-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDGERE_66	01:05	01:20	00:15	LINE CLEAR AVAILED
3659	19-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3660	19-Jun-24	MYSORE	66	TRANSFORMER	HV2	BOOKANAKERE_66	17:01	17:19	00:18	LINE CLEAR AVAILED
3661	19-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARVEY_66	09:02	17:01	07:59	LINE CLEAR AVAILED
3662	19-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	15:52	15:57	00:04	TRIPPED ON FAULT
3663	19-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
3664	19-Jun-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	16:20	16:37	00:17	TRIPPED ON FAULT
3665	19-Jun-24	MYSORE	66	LINE	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	18:34	18:39	00:05	TRIPPED ON FAULT
3666	19-Jun-24	MYSORE	66	LINE	MADDUR-MANDYA	MADDUR_66 KIADB SOMANAHALLI_66	14:30	14:40	00:10	TRIPPED ON FAULT
3667	19-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3668	19-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	23:16	23:21	00:04	LINE CLEAR AVAILED
3669	19-Jun-24	MYSORE	66	LINE	PERIAPATNA-HANGUD	NO STATIONS EFFECTED	11:26	13:29	02:02	LINE CLEAR AVAILED
3670	19-Jun-24	TUMKUR	66	LINE	220kV Anchepalya-66kV B.G Nagar Line	66KV Substations Jiddigere, Thippuru, Yadiyuru	07:03	07:11	00:08	TRIPPED ON FAULT
3671	19-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	18:44 (18.06.2024)	12:12 (19.06.2024)	17:28	LINE CLEAR AVAILED
3672	19-Jun-24	TUMKUR	66	LINE	CHITRADURGA -HIRIYUR I/C LINE(FROM CHITRADURGA 220)	66KV Substations JN Kote, Hiriyyur	13:50	13:56	00:06	TRIPPED ON FAULT
3673	19-Jun-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	19:12	19:20	00:08	LINE CLEAR AVAILED
3674	19-Jun-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	20:22	20:31	00:09	TRIPPED ON FAULT
3675	19-Jun-24	TUMKUR	66	LINE	HONNALLI220-HONNALLI66 LINE	HONNALLI_66, KATTIGE_66	21:37	22:01	00:24	TRIPPED ON FAULT
3676	19-Jun-24	TUMKUR	66	LINE	SIRA_220-TAVAREKERE_66	TAVAREKERE_66	18:51	19:02	00:11	TRIPPED ON FAULT
3677	19-Jun-24	TUMKUR	66	TRANSFORMER	TR-2 20 MVA (LV SIDE)	DAVANGERE_SRS_220	13:30	15:24	01:54	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3678	19-Jun-24	TUMKUR	220	LINE	MADHUGIRI_220 KDB VASANTANARASAPURA_220KV	66KV Substations Badavanahalli, Migigeshi, Koratagere, Pulamaghatta, Thumbadi, Sankenahalli, Holavanahalli, Guligenahalli, Madhugiri. & Nittrahalli	15:36	16:26	00:50	TRIPPED ON FAULT
3679	19-Jun-24	TUMKUR	220	LINE	HONNALLI 220kV- SHIMOGA 220kV1	MRSMSG_220	10:00	15:39	05:39	LINE CLEAR AVAILED
3680	19-Jun-24	TUMKUR	220	LINE	MADHUGIRI_220-100MVA Power Tr.1&2		15:35	15:56	00:21	TRIPPED ON FAULT
3681	19-Jun-24	TUMKUR	220	LINE	MADHUGIRI_220-HIRIYUR_220		15:35	15:41	00:06	TRIPPED ON FAULT
3682	19-Jun-24	TUMKUR	220	LINE	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	15:35	16:02	01:21	LINE CLEAR AVAILED
3683	19-Jun-24	TUMKUR	220	LINE	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	15:33	16:02	02:21	LINE CLEAR AVAILED
3684	19-Jun-24	TUMKUR	400	LINE	GUTTUR 400kV- BTPS LINE	GUTTUR_400	09:43	17:31	07:48	LINE CLEAR AVAILED
3685	19-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERELINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3686	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	LOKAPUR_110	15:49	17:11	01:22	LINE CLEAR AVAILED
3687	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	LOKAPUR_110	17:26	17:29	00:03	LINE CLEAR AVAILED
3688	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	GUTTAL_110	11:32	12:40	01:08	LINE CLEAR AVAILED
3689	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	SHIRGAON_110	12:42	12:50	00:08	TRIPPED ON FAULT
3690	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	MUDALAGI_110	5:00 (19.06.2024)	20:25 (20.06.2024)	39:25:00	TRIPPED ON FAULT
3691	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	RAIBAG_110	13:50	14:27	00:37	TRIPPED ON FAULT
3692	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	TERADAL_110	03:00	03:15	00:15	TRIPPED ON FAULT
3693	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	RANEBENNUR_220	10:17	18:13	07:56	LINE CLEAR AVAILED
3694	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	GUTTAL_110	11:32	12:40	01:08	LINE CLEAR AVAILED
3695	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ALBAL_110	09:24	16:05	06:41	LINE CLEAR AVAILED
3696	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	12:20	14:00	01:40	LINE CLEAR AVAILED
3697	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ITNAL_110	14:15	14:20	00:05	TRIPPED ON FAULT
3698	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	YELPARAHATTI_110	11:57 (19.06.2024)			LINE CLEAR AVAILED
3699	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	RANEBENNUR_220	10:15	18:13	07:58	LINE CLEAR AVAILED
3700	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	GUTTAL_110	11:32	12:40	01:08	LINE CLEAR AVAILED
3701	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	CHIKKODI_110	13:51	14:05	00:14	TRIPPED ON FAULT
3702	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	YARAGATTI_110	19:13	19:39	00:26	TRIPPED ON FAULT
3703	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GUTTAL_110	11:32	12:40	01:08	LINE CLEAR AVAILED
3704	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(20MVA)	RANEBENNUR_220	10:14	19:15	09:01	LINE CLEAR AVAILED
3705	20-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4(20MVA)	RANEBENNUR_220	10:14	18:15	08:01	LINE CLEAR AVAILED
3706	20-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3707	20-Jun-24	BAGALKOTE	110	LINE	ALBAL-RFE SOLAR	RFE SOLAR_110 ALBAL_110	08:15	11:20	03:05	LINE CLEAR AVAILED
3708	20-Jun-24	BAGALKOTE	110	LINE	ALBAL-SAIPRIYA SUGARS	SAIPRIYA SUGARS_110 ALBAL_110	08:15	11:20	03:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3709	20-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR _110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3710	20-Jun-24	BAGALKOTE	110	LINE	GUTTAL-HAVERI	GUTTAL _110	11:33	12:40	01:07	LINE CLEAR AVAILED
3711	20-Jun-24	BAGALKOTE	110	LINE	HIREHAL- RON	STATION NOT AFFECTED HIREHAL _110	9:50 (29.05.2024)	17:45 (20.06.2024)	535:55:00	LINE CLEAR AVAILED
3712	20-Jun-24	BAGALKOTE	110	LINE	HIREHAL-IDLE (BADAMI)	HIREHAL _110	17:05	19:25	02:20	LINE CLEAR AVAILED
3713	20-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-BIDI	MKHUBLI _220	16:10	16:30	00:20	LINE CLEAR AVAILED
3714	20-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI _220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3715	20-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI _110	13:40 (25.04.2024)			LINE CLEAR AVAILED
3716	20-Jun-24	BAGALKOTE	110	LINE	RON-HIREHAL	RON _110	10:47	17:39	06:52	LINE CLEAR AVAILED
3717	20-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI _110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3718	20-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI _220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3719	20-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA _110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3720	20-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL _110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3721	20-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG _110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3722	20-Jun-24	BAGALKOTE	110	LINE	UTTUR-MAHALINGAPUR	UTTUR _110	14:10	17:21	03:11	LINE CLEAR AVAILED
3723	20-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI _220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3724	20-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR1	VAJRAMATTI _220	14:33	15:37	01:04	LINE CLEAR AVAILED
3725	20-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- VAJRAMATTI	VAJRAMATTI _220	10:14	12:10	01:56	LINE CLEAR AVAILED
3726	20-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1&LV1	GHATAPRABHA _220	11:42	13:21	01:39	LINE CLEAR AVAILED
3727	20-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2(HV4)	GADAG _220	11:35	17:22	05:47	LINE CLEAR AVAILED
3728	20-Jun-24	BAGALKOTE	220	LINE	MKHUBLI-NARENDRA1	MKHUBLI _220	11:27	12:28	01:01	TRIPPED ON FAULT
3729	20-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI _220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3730	20-Jun-24	BAGALKOTE	220	LINE	SRISI- SHARATAHI2	SIRSI _220	15:17	19:55	04:38	TRIPPED ON FAULT
3731	20-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	HEJJALA	06:13	07:11	00:58	TRIPPED ON FAULT
3732	20-Jun-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	09:24	09:25	00:01	LINE CLEAR AVAILED
3733	20-Jun-24	BANGALORE	66	LINE	66KV DG2 PUTTENAHALLI 220 - SOLADEVANAHALLI 66KV DC_SC	SOLADEVANAHALLI	10:17	13:06	02:49	LINE CLEAR AVAILED
3734	20-Jun-24	BANGALORE	66	LINE	66KV EDC 220 - AUSTIN TOWN	AUSTIN TOWN	12:45	14:55	02:10	LINE CLEAR AVAILED
3735	20-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - ALLIPURA	THONDEBHAVI, ALIPURA	16:43	17:30	00:47	TRIPPED ON FAULT
3736	20-Jun-24	BANGALORE	66	LINE	66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE	MANCHENAHALLI	10:35	11:57	01:22	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3737	20-Jun-24	BANGALORE	66	LINE	66KV ITI 220 - DRDO (EHT)	DRDO(EHT)	14:55	15:54	00:59	TRIPPED ON FAULT
3738	20-Jun-24	BANGALORE	66	LINE	66KV ITI 220 - DRDO (EHT)	DRDO(EHT)	15:54	16:44	00:50	LINE CLEAR AVAILED
3739	20-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - SANJEEVANADODDI	SANJEEVANADODDI, RANGANADODDI	12:38	14:59	02:21	TRIPPED ON FAULT
3740	20-Jun-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN 1	AUSTIN TOWN	10:17	16:10	05:53	LINE CLEAR AVAILED
3741	20-Jun-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - AUSTIN TOWN-2	AUSTIN TOWN	10:17	16:10	05:53	LINE CLEAR AVAILED
3742	20-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA - MELEHALLI - KEMPANAHALLI	KEMPANAHALLI, URAGAHALLI	10:10	16:05	05:55	LINE CLEAR AVAILED
3743	20-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, RAYALPADU	07:07	07:17	00:10	TRIPPED ON FAULT
3744	20-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	GOWNIPALLI, RAYALPADU	19:56	20:09	00:13	TRIPPED ON FAULT
3745	20-Jun-24	BANGALORE	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	06:45	10:31	03:46	TRIPPED ON FAULT
3746	20-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	JADIGENAHALLI	06:45	07:02	00:17	MAIN SUPPLY FAILURE
3747	20-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	06:45	07:02	00:17	MAIN SUPPLY FAILURE
3748	20-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, KANASAWADI, GUNDAMGERE, SASLU	08:31	08:48	00:17	TRIPPED ON FAULT
3749	20-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, KANASAWADI, GUNDAMGERE, SASLU, KANASAWADI	10:09	18:42	08:33	LINE CLEAR AVAILED
3750	20-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, KANASAWADI, GUNDAMGERE, SASLU	19:34	19:35	00:01	LINE CLEAR AVAILED
3751	20-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	00:50	01:04	00:14	TRIPPED ON FAULT
3752	20-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	10:05	14:54	04:49	LINE CLEAR AVAILED
3753	20-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SAINT GOBIN - BHURUKA GAS - ORCHID LAMINTES 1 - A.O SMITH - ORCHID LAMINATES-2	SAINT GOBAIN, BHORUKA, ORCHID LAMINATES, AO SMITH(EHT)	14:07	14:10	00:03	LINE CLEAR AVAILED
3754	20-Jun-24	BANGALORE	66	LINE	66KV SRINIVASAPURA 220 - YELDUR - DALASNUR	DALASANUR	12:05	12:10	00:05	LINE CLEAR AVAILED
3755	20-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	10:12	12:46	02:34	LINE CLEAR AVAILED
3756	20-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	13:00	13:13	00:13	LINE CLEAR AVAILED
3757	20-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	19:15	19:20	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3758	20-Jun-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - RR NAGAR	RR NAGAR	10:38	14:35	03:57	LINE CLEAR AVAILED
3759	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	REMC0, GLOBAL(EHT)	10:12	10:24	00:12	LINE CLEAR AVAILED
3760	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BURUDAGUNTE	15:57	16:13	00:16	LINE CLEAR AVAILED
3761	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	G KODIHALLI	18:50	19:05	00:15	TRIPPED ON FAULT
3762	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SHIVANAHALLI DAIRY	10:30	13:00	02:30	LINE CLEAR AVAILED
3763	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRLE	06:13	06:21	00:08	TRIPPED ON FAULT
3764	20-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MAGADI 66	10:35	10:40	00:05	LINE CLEAR AVAILED
3765	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	RR NAGAR	14:59	15:35	00:36	LINE CLEAR AVAILED
3766	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SUBRAMANYAPURA 66	12:46	14:45	01:59	LINE CLEAR AVAILED
3767	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TUBAGERE	13:15	13:20	00:05	LINE CLEAR AVAILED
3768	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TAMAKA	13:00	13:50	00:50	LINE CLEAR AVAILED
3769	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	00:33	00:39	00:06	TRIPPED ON FAULT
3770	20-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KUMBARANAHALLI	12:15	12:21	00:06	TRIPPED ON FAULT
3771	20-Jun-24	BANGALORE	220	TRANSFORMER	LV1	MALUR 220	06:45	07:02	00:17	TRIPPED ON FAULT
3772	20-Jun-24	GULBARGA	110	LINE	ADAVIAMARESHWAR-JAWALGERA	JAWALGERA_110	10:20	12:25	02:05	LINE CLEAR AVAILED
3773	20-Jun-24	GULBARGA	110	LINE	BYAGWAT-WALKAMDINI	WALKAMDINI_110	10:20	12:35	02:15	LINE CLEAR AVAILED
3774	20-Jun-24	GULBARGA	110	LINE	CHIKSUGUR-SHAKTINAGAR	SHAKTINAGAR_110	15:49	16:04	00:15	TRIPPED ON FAULT
3775	20-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-KHANAPUR-2	KAHANAPUR_110	11:22	12:27	01:05	LINE CLEAR AVAILED
3776	20-Jun-24	GULBARGA	110	TRANSFORMER	HV1	BELLARYNORTH_110	09:40	09:49	00:09	TRIPPED ON FAULT
3777	20-Jun-24	GULBARGA	110	TRANSFORMER	HV1&HV2	SHAKTINAGAR_110	18:29	18:41	00:12	TRIPPED ON FAULT
3778	20-Jun-24	GULBARGA	110	TRANSFORMER	HV2	SOMASAMUDRA_110	05:06	06:09	01:03	TRIPPED ON FAULT
3779	20-Jun-24	GULBARGA	110	LINE	KALBURGI SOUTH-FHARTABAD	FARTHABAD_110	21:58	22:07	00:09	TRIPPED ON FAULT
3780	20-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	10:10	18:36	08:26	LINE CLEAR AVAILED
3781	20-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KADECHUR_110	05:12	05:24	00:12	TRIPPED ON FAULT
3782	20-Jun-24	GULBARGA	110	LINE	MUNIRABAD-DONIMALAI	DONIMALAI_110	16:40	17:22	00:42	TRIPPED ON FAULT
3783	20-Jun-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	KEREHALLI_110	19:16	19:29	00:13	TRIPPED ON FAULT
3784	20-Jun-24	GULBARGA	110	LINE	SHAHPUR-HATTIGUDUR	SHAHPUR_110	10:05	20:53	0.45	LINE CLEAR AVAILED
3785	20-Jun-24	GULBARGA	110	LINE	SHAHPUR-HATTIGUDUR	SHAHPUR_110	10:15	16:00	05:45	LINE CLEAR AVAILED
3786	20-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGIRICROSS	TEKKALAKOTE_110	03:24	03:54	00:30	TRIPPED ON FAULT
3787	20-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGIRICROSS	TEKKALAKOTE_110	10:45	15:30	04:45	LINE CLEAR AVAILED
3788	20-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	09:53	19:30	09:37	LINE CLEAR AVAILED
3789	20-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	20:15	21:35	01:20	TRIPPED ON FAULT
3790	20-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	20:14	20:20	00:06	TRIPPED ON FAULT
3791	20-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
3792	20-Jun-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	10:05	16:32	06:27	LINE CLEAR AVAILED
3793	20-Jun-24	HASSAN	66	LINE	BALEHN-ALDUR	BALEHONNUR_66	10:05	16:32	06:27	LINE CLEAR AVAILED
3794	20-Jun-24	HASSAN	66	LINE	HNPR2-HDVL CBreaker	HNPUA_220	11:10	11:25	00:15	LINE CLEAR AVAILED
3795	20-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR2	HNPUA_220	10:01	10:10	00:09	LINE CLEAR AVAILED
3796	20-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR2	HNPUA_220	12:02	13:15	01:13	LINE CLEAR AVAILED
3797	20-Jun-24	HASSAN	66	TRANSFORMER	HV1	BELUR_66	10:24	11:20	00:56	LINE CLEAR AVAILED
3798	20-Jun-24	HASSAN	66	TRANSFORMER	HV1	MALLAPURA_66	07:54	08:43	00:49	LINE CLEAR AVAILED
3799	20-Jun-24	HASSAN	66	TRANSFORMER	HV1 CB	MANJUNATHPURA_66	10:28	14:48	04:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3800	20-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	12:00	14:36	02:36	LINE CLEAR AVAILED
3801	20-Jun-24	HASSAN	66	TRANSFORMER	HV2 CB	MANJUNATHPURA_66	10:28	14:48	04:20	LINE CLEAR AVAILED
3802	20-Jun-24	HASSAN	66	TRANSFORMER	Lv1	HNPUA_220	11:11	13:20	02:09	LINE CLEAR AVAILED
3803	20-Jun-24	HASSAN	66	LINE	MNJUPR-L1 CB	MANJUNATHPURA_66	10:28	14:48	04:20	LINE CLEAR AVAILED
3804	20-Jun-24	HASSAN	66	LINE	MNJUPR-L2 CB	MANJUNATHPURA_66	10:28	14:48	04:20	LINE CLEAR AVAILED
3805	20-Jun-24	HASSAN	66	LINE	NGRTHI-KADVINKOTE	NAGARTHI_110	12:08	14:23	02:15	LINE CLEAR AVAILED
3806	20-Jun-24	HASSAN	66	LINE	SBELAG-SNTBCHL	S_BELAGOLA_66	10:30	14:30	04:00	LINE CLEAR AVAILED
3807	20-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	08:05	10:30	02:25	LINE CLEAR AVAILED
3808	20-Jun-24	HASSAN	110	TRANSFORMER	HV1	CHANDRAGUTTI_110	10:47	18:00	07:13	LINE CLEAR AVAILED
3809	20-Jun-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	08:05	10:30	02:25	LINE CLEAR AVAILED
3810	20-Jun-24	HASSAN	110	TRANSFORMER	HV1	GURUPURA_110	11:30	11:33	00:03	TRIPPED ON FAULT
3811	20-Jun-24	HASSAN	110	TRANSFORMER	HV1	SHIKARIPURA_110	10:11	19:14	09:03	LINE CLEAR AVAILED
3812	20-Jun-24	HASSAN	110	TRANSFORMER	HV1	SORABA_110	11:40	18:20	06:40	LINE CLEAR AVAILED
3813	20-Jun-24	HASSAN	110	TRANSFORMER	HV2	CHANDRAGUTTI_110	10:47	18:00	07:13	LINE CLEAR AVAILED
3814	20-Jun-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	08:05	10:30	02:25	LINE CLEAR AVAILED
3815	20-Jun-24	HASSAN	110	TRANSFORMER	HV2	KONDENALU_110	16:00	16:54	00:54	LINE CLEAR AVAILED
3816	20-Jun-24	HASSAN	110	TRANSFORMER	HV2	SHIKARIPURA_110	10:11	19:15	09:04	LINE CLEAR AVAILED
3817	20-Jun-24	HASSAN	110	TRANSFORMER	HV2	SORABA_110	10:05	18:20	08:15	LINE CLEAR AVAILED
3818	20-Jun-24	HASSAN	110	LINE	KAVOOR-KVR AMR	KAVOOR_220	11:54	13:02	01:08	LINE CLEAR AVAILED
3819	20-Jun-24	HASSAN	110	TRANSFORMER	LV2	KADUR_220	11:41	14:57	03:16	LINE CLEAR AVAILED
3820	20-Jun-24	HASSAN	110	TRANSFORMER	LV2	MRSMSG_220	10:42	19:31	08:49	LINE CLEAR AVAILED
3821	20-Jun-24	HASSAN	110	LINE	MRSSHM-RLW CBreaker	MRSMSG_220	10:34	10:38	00:04	LINE CLEAR AVAILED
3822	20-Jun-24	HASSAN	110	LINE	MSEZ-GSS3	MSEZ_220	09:45	17:42	07:57	LINE CLEAR AVAILED
3823	20-Jun-24	HASSAN	110	LINE	NANDIKU-NDKR-SUZLON	NANDIKUR_110	00:06	00:22	00:16	TRIPPED ON FAULT
3824	20-Jun-24	HASSAN	110	LINE	SHRLKP-SHIKARIPURA	SGIRALKOPPA_220	11:32	17:44	06:12	LINE CLEAR AVAILED
3825	20-Jun-24	HASSAN	220	TRANSFORMER	HV1	HNPUA_220	11:11	13:20	02:09	LINE CLEAR AVAILED
3826	20-Jun-24	HASSAN	220	TRANSFORMER	HV2	KADUR_220	11:41	14:57	03:16	LINE CLEAR AVAILED
3827	20-Jun-24	HASSAN	220	TRANSFORMER	HV2	MRSMSG_220	10:42	19:31	08:49	LINE CLEAR AVAILED
3828	20-Jun-24	HASSAN	220	LINE	KAVOOR-KVRBJPE1	KAVOOR_220	09:53	11:06	01:13	LINE CLEAR AVAILED
3829	20-Jun-24	HASSAN	220	LINE	KAVOOR-KVRBJPE2	KAVOOR_220	11:09	16:00	04:51	LINE CLEAR AVAILED
3830	20-Jun-24	HASSAN	220	LINE	MRSSHM-KBCRS	MRSMSG_220	16:29	16:46	00:17	LINE CLEAR AVAILED
3831	20-Jun-24	MYSORE	66	LINE	HOOTAGALLI-DATTAGALLI	DATTAGALLY_66	10:09	16:20	06:11	LINE CLEAR AVAILED
3832	20-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
3833	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	DODDINADUVADI_66	06:59	07:11	00:11	TRIPPED ON FAULT
3834	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	01:10	01:17	00:06	TRIPPED ON FAULT
3835	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	01:19	01:22	00:02	TRIPPED ON FAULT
3836	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	01:46	01:48	00:01	TRIPPED ON FAULT
3837	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	01:51	02:31	00:40	TRIPPED ON FAULT
3838	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	HUNSUR_66	10:28	12:43	02:14	LINE CLEAR AVAILED
3839	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	SANTHEMARAHALLI_66	13:35	13:43	00:08	TRIPPED ON FAULT
3840	20-Jun-24	MYSORE	66	TRANSFORMER	HV2	THANDYA_66	22:23	22:33	00:10	TRIPPED ON FAULT
3841	20-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
3842	20-Jun-24	MYSORE	66	LINE	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	03:34	09:08	05:33	LINE CLEAR AVAILED
3843	20-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
3844	20-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3845	20-Jun-24	MYSORE	66	LINE	MANDYA-M1 (MADDUR)	MADDUR_66, KIADB SOMANAHALLI_66	05:50	06:05	00:14	TRIPPED ON FAULT
3846	20-Jun-24	MYSORE	66	LINE	MANDYA-M1 (MADDUR)	MADDUR_66, KIADB SOMANAHALLI_66	06:09	10:06	03:56	LINE CLEAR AVAILED
3847	20-Jun-24	MYSORE	66	LINE	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	09:31	16:36	07:04	LINE CLEAR AVAILED
3848	20-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	14:23	14:29	00:06	TRIPPED ON FAULT
3849	20-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	14:29	17:25	02:55	TRIPPED ON FAULT
3850	20-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
3851	20-Jun-24	MYSORE	66	LINE	R K NAGARA-DATTAGALLI	DATTAGALLY_66	09:31	16:32	07:00	LINE CLEAR AVAILED
3852	20-Jun-24	MYSORE	66	LINE	R K NAGARA-MANDAKALLI	NO STATIONS EFFECTED	16:32	17:07	00:34	LINE CLEAR AVAILED
3853	20-Jun-24	MYSORE	66	LINE	TUBINAKERE-G UKKADA	NO STATIONS EFFECTED	15:41	16:45	01:04	LINE CLEAR AVAILED
3854	20-Jun-24	MYSORE	220	TRANSFORMER	HV2	MADHUVANAHALLI_220	11:31	13:55	02:23	LINE CLEAR AVAILED
3855	20-Jun-24	TUMKUR	66	LINE	220kv Anchepalya-66kV B.G Nagar Line	JIDDIGERE, THIPPUR, YEDIYUR	11:40	11:49	00:09	TRIPPED ON FAULT
3856	20-Jun-24	TUMKUR	66	LINE	220kv Davanagere- 66KV Mayakonda	66kV stations Mayakonda, Chikkajajuru, Sasaluhalla	11:06	11:15	00:09	TRIPPED ON FAULT
3857	20-Jun-24	TUMKUR	66	LINE	220kV Honnali-66kV Kundur Line	66kV Kundur, Malebennur, Devarbelakere	16:04	16:22	00:18	TRIPPED ON FAULT
3858	20-Jun-24	TUMKUR	66	LINE	220kV Honnali-66kV Nyamathi Line	66kV Nyamathi, Savalanga, Chilur	16:55	17:05	00:10	TRIPPED ON FAULT
3859	20-Jun-24	TUMKUR	66	LINE	220KV_DAVANAGERE-66KVM AYAKONDA LINE	MAYAKONDA_66	11:06	11:15	00:09	TRIPPED ON FAULT
3860	20-Jun-24	TUMKUR	66	LINE	66kv Mathod-Garaga-panchanahalli outgoing line	66kV stations Garaga, Panchanahalli	14:20	14:35	00:15	TRIPPED ON FAULT
3861	20-Jun-24	TUMKUR	66	LINE	66kV Sasaluhalla- 12.5MVA Tr.2	66kV Sasaluhalla	14:00	14:10	00:10	TRIPPED ON FAULT
3862	20-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220kV-CHALLAKERE(BALENAHALLI)	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	10:08	18:32	08:24	LINE CLEAR AVAILED
3863	20-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220kV-HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	10:10	18:31	08:21	LINE CLEAR AVAILED
3864	20-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220kV-PANDARAHALLI 1&2	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:08	18:34	08:26	LINE CLEAR AVAILED
3865	20-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	10:10	18:31	08:21	LINE CLEAR AVAILED
3866	20-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220kV-CHITRADURGA_66 LINE 1,2,3,4	CHITRADURGA_66	10:08	18:21	08:13	LINE CLEAR AVAILED
3867	20-Jun-24	TUMKUR	66	LINE	HIRIYUR220kV-P R PURA	HARIYABBE_66,PDKOTE_66	8:20 (20.06.2024)	Kept Open		LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3868	20-Jun-24	TUMKUR	66	LINE	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:10	11:35	01:25	LINE CLEAR AVAILED
3869	20-Jun-24	TUMKUR	66	TRANSFORMER	TR-1 &TR-2 (LV SIDE) CHITRADURGA_220	CHITRADURGA 220kV	10:10	17:54	07:44	LINE CLEAR AVAILED
3870	20-Jun-24	TUMKUR	66	TRANSFORMER	TR-1 20 MVA (LV SIDE)ANTHRASANAHALLI 220kV-	ANTHRASANAHALLI 220kV	11:30	12:09	00:39	LINE CLEAR AVAILED
3871	20-Jun-24	TUMKUR	66	TRANSFORMER	TR-2 20 MVA (LV SIDE)ANTHRASANAHALLI 220kV-	ANTHRASANAHALLI 220kV	12:13	12:33	00:20	LINE CLEAR AVAILED
3872	20-Jun-24	TUMKUR	66	TRANSFORMER	TR-3 (LV SIDE) CHITRADURGA_220	CHITRADURGA 220kV	11:35	18:15	06:40	LINE CLEAR AVAILED
3873	20-Jun-24	TUMKUR	66	TRANSFORMER	TR-3 20 MVA (LV SIDE)ANTHRASANAHALLI 220kV-	ANTHRASANAHALLI 220kV	12:35	12:56	00:21	LINE CLEAR AVAILED
3874	20-Jun-24	TUMKUR	110	LINE	KB CROSS 220kV- TIPTUR	TIPTUR_110,C N HALLI_110, THIMMANAHALLI_110HANDAN KERE_110,MAYASANDRA_110, KADEHALLI_110	11:35	16:28	04:53	LINE CLEAR AVAILED
3875	20-Jun-24	TUMKUR	110	TRANSFORMER	TR-1,TR2,TR3. K.B. CROSS_220	K.B. CROSS_220	11:35	16:28	04:53	LINE CLEAR AVAILED
3876	20-Jun-24	TUMKUR	220	LINE	220kV Thallak- 100MVA TR3	66/11KV Stations Challakere, Gowrasamudra, Konasagara, Mylanahalli, VV Pura, Dyavaranaahalli	11:59	12:06	00:07	TRIPPED ON FAULT
3877	20-Jun-24	TUMKUR	220	LINE	CHITRADURGA 220kV-- RVNL RAILWAY	CHITRADURGA 220kV	11:22	17:36	06:14	LINE CLEAR AVAILED
3878	20-Jun-24	TUMKUR	220	LINE	CHITRADURGA 220kV-- THALLAK_220KV	CHITRADURGA 220kV	11:36	18:06	06:30	LINE CLEAR AVAILED
3879	20-Jun-24	TUMKUR	220	LINE	CHITRADURGA 220kV-1_PGCL	CHITRADURGA_220	11:34	18:30	06:56	LINE CLEAR AVAILED
3880	20-Jun-24	TUMKUR	220	LINE	KB CROSS 220kV- SHIMOGA1	KBCROSS_220	11:35	16:28	04:53	LINE CLEAR AVAILED
3881	20-Jun-24	TUMKUR	220	TRANSFORMER	TR-1 &TR-2 100 MVA (HV SIDE) CHITRADURGA_220	CHITRADURGA 220kV	10:10	17:54	07:44	LINE CLEAR AVAILED
3882	20-Jun-24	TUMKUR	220	TRANSFORMER	TR-1 100 MVA (HV SIDE)ANTHRASANAHALLI 220kV-	ANTHRASANAHALLI 220kV	13:05	13:35	00:30	LINE CLEAR AVAILED
3883	20-Jun-24	TUMKUR	220	TRANSFORMER	TR-2 100 MVA (HV SIDE)ANTHRASANAHALLI 220kV-	ANTHRASANAHALLI 220kV	13:38	14:08	00:30	LINE CLEAR AVAILED
3884	20-Jun-24	TUMKUR	220	TRANSFORMER	TR-3 100 MVA (HV SIDE) CHITRADURGA_220	CHITRADURGA 220kV	11:35	18:15	06:40	LINE CLEAR AVAILED
3885	20-Jun-24	TUMKUR	400	LINE	ANTHRASANAHALLI 220KV- K B CROSS_220	ANTHRASANAHALLI 220	11:30	16:58	05:28	LINE CLEAR AVAILED
3886	20-Jun-24	TUMKUR	400	LINE	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	11:19	18:27	07:08	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3887	20-Jun-24	TUMKUR	400	LINE	GUTTUR_400-DAVANGERELINE-1	DAVANGERE_SRS_220	9:05 (15.06.2024)	Kept Open		LINE CLEAR AVAILED
3888	20-Jun-24	TUMKUR	400	LINE	JAGALURU_400KV-CHITRADURGA_220-LINE-1	JAGALURU_400KV-	10:44	17:35	06:51	LINE CLEAR AVAILED
3889	20-Jun-24	TUMKUR	400	LINE	JAGALURU_400KV-CHITRADURGA_220-LINE-2	JAGALURU_400KV-	10:45	17:35	06:50	LINE CLEAR AVAILED
3890	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1	TAKKALAKI_110	18:12	19:05	00:53	LINE CLEAR AVAILED
3891	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	NAREGAL_110	15:00	17:34	02:34	LINE CLEAR AVAILED
3892	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	CHIKKODI_220	10:07	14:02	03:55	LINE CLEAR AVAILED
3893	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BILAGI_110	15:50	16:03	00:13	TRIPPED ON FAULT
3894	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	RAIBAG_110	10:23	11:07	00:44	TRIPPED ON FAULT
3895	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	ALBAL_110	11:25	20:06	08:41	LINE CLEAR AVAILED
3896	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	NIPPANI_110	11:30	12:07	00:37	LINE CLEAR AVAILED
3897	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	YELPARAHATTI_110	11:57 (19.06.2024)	18:43 (21.06.2024)	54:46:00	LINE CLEAR AVAILED
3898	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	04:38	04:59	00:21	TRIPPED ON FAULT
3899	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	MUNDARGI_110	13:15	13:24	00:09	TRIPPED ON FAULT
3900	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (10MVA)	MUNDARGI_110	14:35	14:41	00:06	TRIPPED ON FAULT
3901	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (10MVA1)	TODALBAGI_110	10:15	19:38	09:23	LINE CLEAR AVAILED
3902	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	MKHUBLI_220	10:15	11:25	01:10	LINE CLEAR AVAILED
3903	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA2)	TODALBAGI_110	10:15	19:25	09:10	LINE CLEAR AVAILED
3904	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3 (10MVA)	TODALBAGI_110	10:15	19:00	08:45	LINE CLEAR AVAILED
3905	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (10MVA)	ANKOLA_110	04:36	04:41	00:05	TRIPPED ON FAULT
3906	21-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV4 (20MVA1)	TODALBAGI_110	10:15	19:40	09:25	LINE CLEAR AVAILED
3907	21-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
3908	21-Jun-24	BAGALKOTE	110	LINE	AEQUS220-SANKESHWAR	AEQUS_220	16:22	16:45	00:23	TRIPPED ON FAULT
3909	21-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220- SUPA1	AMBEWADI_220	16:10	16:13	00:03	LINE CLEAR AVAILED
3910	21-Jun-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	11:20	19:05	07:45	LINE CLEAR AVAILED
3911	21-Jun-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	20:51 (21.06.2024)			MAIN SUPPLY FAILURE
3912	21-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
3913	21-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F4-NAVANAGAR-2	BAGALKOT_220	17:35	17:49	00:14	LINE CLEAR AVAILED
3914	21-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220-SANKESHWAR(HUKKERI)	CHIKKODI_220	16:24	17:06	00:42	TRIPPED ON FAULT
3915	21-Jun-24	BAGALKOTE	110	LINE	GADAG220- DAMBAL1 (SAMBHAPUR ROAD)	GADAG_220	13:04	14:15	01:11	LINE CLEAR AVAILED
3916	21-Jun-24	BAGALKOTE	110	LINE	GADAG220-DAMBAL1 (SAMBAPUR ROAD)	GADAG_220	13:04	14:15	01:11	LINE CLEAR AVAILED
3917	21-Jun-24	BAGALKOTE	110	LINE	ISLAMPUR-F2 (HIDKALDAM)	ISLAMPUR_110	11:38	12:52	01:14	LINE CLEAR AVAILED
3918	21-Jun-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	MACHE_110	12:48	14:30	01:42	LINE CLEAR AVAILED
3919	21-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3920	21-Jun-24	BAGALKOTE	110	LINE	NAREGAL-RON	NAREGAL_110	17:18	17:34	00:16	LINE CLEAR AVAILED
3921	21-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3922	21-Jun-24	BAGALKOTE	110	LINE	SAMBAPUR-GADAG	STATION NOT AFFECTED SAMBAPUR ROAD_110	13:04	14:14	01:10	LINE CLEAR AVAILED
3923	21-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
3924	21-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
3925	21-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
3926	21-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
3927	21-Jun-24	BAGALKOTE	110	LINE	TODALB-JKD SUGRS	TODALBAGI_110	10:25	17:45	07:20	LINE CLEAR AVAILED
3928	21-Jun-24	BAGALKOTE	110	LINE	TODALB-KAMBAGI	TODALBAGI_110	10:25	20:00	09:35	LINE CLEAR AVAILED
3929	21-Jun-24	BAGALKOTE	110	LINE	TODALB-SAVALAGI	TODALBAGI_110	10:25	16:10	05:45	LINE CLEAR AVAILED
3930	21-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
3931	21-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
3932	21-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2 (100 MVA)	CHIKKODI_220	16:21	16:38	00:17	TRIPPED ON FAULT
3933	21-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1(HV2) &LV1(LV2)	GADAG_220	10:35	14:47	04:12	LINE CLEAR AVAILED
3934	21-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-NARENDRA2	AMBEWADI_220	13:25	18:17	04:52	LINE CLEAR AVAILED
3935	21-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI_220	08:39	10:05	01:26	TRIPPED ON FAULT
3936	21-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI_220	17:20	18:58	01:38	TRIPPED ON FAULT
3937	21-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI_220	17:20	19:14	01:54	TRIPPED ON FAULT
3938	21-Jun-24	BAGALKOTE	220	LINE	BIJAPUR- INDI1	BIJAPUR_220	13:57	14:43	00:46	LINE CLEAR AVAILED
3939	21-Jun-24	BAGALKOTE	220	LINE	BIJAPUR- INDI2	BIJAPUR_220	15:04	15:56	00:52	LINE CLEAR AVAILED
3940	21-Jun-24	BAGALKOTE	220	LINE	GHATAPRABHA- MUGALKHOD2	GHATAPRABHA_220	13:03	15:43	02:40	LINE CLEAR AVAILED
3941	21-Jun-24	BAGALKOTE	220	LINE	INDI- BIJAPUR1	INDI_220	13:57	14:43	00:46	LINE CLEAR AVAILED
3942	21-Jun-24	BAGALKOTE	220	LINE	INDI- BIJAPUR2	INDI_220	15:06	15:57	00:51	LINE CLEAR AVAILED
3943	21-Jun-24	BAGALKOTE	220	LINE	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	13:03	15:44	02:41	LINE CLEAR AVAILED
3944	21-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
3945	21-Jun-24	BAGALKOTE	220	LINE	SRISI- SHARAVATHI2	SIRSI_220	15:17 (20.06.2024)	12:25 (21.06.2024)	21:08:00	TRIPPED ON FAULT
3946	21-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR, SRIGIRIPURA	15:49	16:00	00:11	LINE CLEAR AVAILED
3947	21-Jun-24	BANGALORE	66	LINE	66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI	DIBBURAHALLI	18:58	19:21	00:23	TRIPPED ON FAULT
3948	21-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT	SHOBHA APARTMENT	15:20	15:29	00:09	LINE CLEAR AVAILED
3949	21-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALI 220 - SANJEEVANADODDI	RANGANADODDI, SANJEEVANADODDI	16:26	16:31	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3950	21-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - DODDERI - CHANDRAPPA CIRCLE	DODDERI, CHANDRAPPA CIRCLE	11:18	11:40	00:22	TRIPPED ON FAULT
3951	21-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	10:57	11:20	00:23	LINE CLEAR AVAILED
3952	21-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2	KENGERI SATELLITE TOWN	11:18	11:40	00:22	TRIPPED ON FAULT
3953	21-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - ISRO 1	ISRO LAYOUT	10:30	15:12	04:42	LINE CLEAR AVAILED
3954	21-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - GURUVINAPURA - V.R DODDI	GURUVINAPURA, BV HALLI	10:37	15:04	04:27	LINE CLEAR AVAILED
3955	21-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	PRIMAL	11:50	11:53	00:03	LINE CLEAR AVAILED
3956	21-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	DEVARABISANAHALLI	11:50	15:45	03:55	TRIPPED ON FAULT
3957	21-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	15:40	15:45	00:05	LINE CLEAR AVAILED
3958	21-Jun-24	BANGALORE	66	LINE	66KV VRUSHBAVATHI - BANASHANKARI	BANASHANKARI	11:18	11:26	00:08	TRIPPED ON FAULT
3959	21-Jun-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - SIR. M.V LAYOUT	SIR MV LAYOUT	11:18	11:28	00:10	TRIPPED ON FAULT
3960	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	14:40	14:45	00:05	LINE CLEAR AVAILED
3961	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ARMY WELFARE ORGANISATION	11:55	16:10	04:15	TRIPPED ON FAULT
3962	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHIKKABALLAPURA I/A	19:10	19:20	00:10	TRIPPED ON FAULT
3963	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NALLIMARADANAHALLI	12:00	14:20	02:20	LINE CLEAR AVAILED
3964	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	16:45	16:50	00:05	TRIPPED ON FAULT
3965	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	17:20	17:25	00:05	TRIPPED ON FAULT
3966	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	15:35	15:55	00:20	TRIPPED ON FAULT
3967	21-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	16:45	17:50	01:05	LINE CLEAR AVAILED
3968	21-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	14:40	14:45	00:05	LINE CLEAR AVAILED
3969	21-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SADALI	14:05	14:15	00:10	TRIPPED ON FAULT
3970	21-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HULLENAHALLI	06:10	06:30	00:20	LINE CLEAR AVAILED
3971	21-Jun-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	06:38	07:03	00:25	LINE CLEAR AVAILED
3972	21-Jun-24	GULBARGA	66	TRANSFORMER	HV2	C.J.HALLI_66	15:58	16:05	00:07	TRIPPED ON FAULT
3973	21-Jun-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	06:50	06:55	00:05	TRIPPED ON FAULT
3974	21-Jun-24	GULBARGA	66	LINE	ITTIGI-BENNIHALLI	BENNIHALLI_66,KOTTUR_66,UJINI_66	19:02	19:12	00:10	TRIPPED ON FAULT
3975	21-Jun-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	14:33	15:01	00:28	TRIPPED ON FAULT
3976	21-Jun-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	15:20	15:45	00:25	TRIPPED ON FAULT
3977	21-Jun-24	GULBARGA	110	TRANSFORMER	HV1	BELLARY NORTH_110	17:01	17:14	00:13	LINE CLEAR AVAILED
3978	21-Jun-24	GULBARGA	110	TRANSFORMER	HV1	ALIPURA_220	14:20	14:58	00:38	TRIPPED ON FAULT
3979	21-Jun-24	GULBARGA	110	TRANSFORMER	HV1	HANUMANAL_110	11:10	11:42	00:32	LINE CLEAR AVAILED
3980	21-Jun-24	GULBARGA	110	TRANSFORMER	HV3	WALKAMDINI_110	14:15	14:35	00:20	TRIPPED ON FAULT
3981	21-Jun-24	GULBARGA	110	LINE	KALBURGI SOUTH-FHARTABAD	FARTHABAD_110	04:55	05:00	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
3982	21-Jun-24	GULBARGA	110	LINE	KUSHTAGI-HANUMDAGAR	HANUMSAGAR_110, HIREGONNAGAR_110, HANUMAL_110	23:38	23:51	00:13	TRIPPED ON FAULT
3983	21-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	03:45	03:50	00:05	TRIPPED ON FAULT
3984	21-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	10:21	16:22	06:01	LINE CLEAR AVAIED
3985	21-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	10:06	15:10	05:04	LINE CLEAR AVAIED
3986	21-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SR NAGAR	KARATAGI_110	10:06	17:09	07:03	LINE CLEAR AVAIED
3987	21-Jun-24	GULBARGA	110	LINE	SINDHANOOR-WALKAMDINI	WALKAMDINI_110	12:25	13:00	00:35	MAIN SUPPLY FAILURE
3988	21-Jun-24	GULBARGA	110	LINE	SULEKAL-MALLAPUR	MALLAPUR_110	22:13	22:28	00:15	MAIN SUPPLY FAILURE
3989	21-Jun-24	GULBARGA	220	TRANSFORMER	HV1 & HV2	SINDHANOOR_220	12:28	12:55	00:27	TRIPPED ON FAULT
3990	21-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
3991	21-Jun-24	HASSAN	66	LINE	ATTICHO-HNPURA	ATTICHOWDENAHALLI_66	10:05	17:50	07:45	LINE CLEAR AVAIED
3992	21-Jun-24	HASSAN	66	LINE	BAGUR-RAMAPUR	BAGUR_66	10:28	17:50	07:22	LINE CLEAR AVAIED
3993	21-Jun-24	HASSAN	66	LINE	BALLUPE-KANDLI	BALLUPETE_66	11:25	12:51	01:26	LINE CLEAR AVAIED
3994	21-Jun-24	HASSAN	66	LINE	BYARAPU-BAGUR	BYARAPURA_66	10:27	17:52	07:25	LINE CLEAR AVAIED
3995	21-Jun-24	HASSAN	66	LINE	CHANNAR-CRPATNA1	CHANNARAYAPATNA_66	10:40	17:47	07:07	LINE CLEAR AVAIED
3996	21-Jun-24	HASSAN	66	LINE	CHANNAR-CRPATNA2	CHANNARAYAPATNA_66	10:40	17:40	07:00	LINE CLEAR AVAIED
3997	21-Jun-24	HASSAN	66	LINE	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	10:40	18:27	07:47	LINE CLEAR AVAIED
3998	21-Jun-24	HASSAN	66	LINE	CHANNAR-UDAYPURA	CHANNARAYAPATNA_66	10:40	17:47	07:07	LINE CLEAR AVAIED
3999	21-Jun-24	HASSAN	66	LINE	CRPATNA-CRPTNA1	CRPATNA_220	10:28	17:32	07:04	LINE CLEAR AVAIED
4000	21-Jun-24	HASSAN	66	LINE	CRPATNA-CRPTNA2	CRPATNA_220	10:28	17:32	07:04	LINE CLEAR AVAIED
4001	21-Jun-24	HASSAN	66	LINE	CRPATNA-MATTANAVILE	CRPATNA_220	12:50	14:10	01:20	LINE CLEAR AVAIED
4002	21-Jun-24	HASSAN	66	LINE	DIDIGA-CRPATNA1	DIDIGA_66	11:00	14:15	03:15	LINE CLEAR AVAIED
4003	21-Jun-24	HASSAN	66	LINE	HAGARE-HASSAN	HAGARE_66	11:15	11:30	00:15	MAIN SUPPLY FAILURE
4004	21-Jun-24	HASSAN	66	LINE	HASSN22-HN PURA	HASSAN_220	12:37	12:47	00:10	LINE CLEAR AVAIED
4005	21-Jun-24	HASSAN	66	LINE	HNPR2-RNPR1	HNPURA_220	11:15	12:23	01:08	LINE CLEAR AVAIED
4006	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	ATTICHOWDENAHALLI_66	10:05	17:50	07:45	LINE CLEAR AVAIED
4007	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	BAGUR_66	10:28	17:55	07:27	LINE CLEAR AVAIED
4008	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	BYARAPURA_66	10:27	17:52	07:25	LINE CLEAR AVAIED
4009	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHANNARAYAPATNA_66	10:40	17:40	07:00	LINE CLEAR AVAIED
4010	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	DIDIGA_66	11:00	14:15	03:15	LINE CLEAR AVAIED
4011	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	RAMNATHPURA_66	10:00	17:30	07:30	LINE CLEAR AVAIED
4012	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	RAMPURA_66	10:25	15:25	05:00	LINE CLEAR AVAIED
4013	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	SAKALESHPURA_66	11:37	12:52	01:15	LINE CLEAR AVAIED
4014	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	SINGAPURA_66	11:12	11:43	00:31	LINE CLEAR AVAIED
4015	21-Jun-24	HASSAN	66	TRANSFORMER	HV1	UDAYAPURA_66	11:13	17:48	06:35	LINE CLEAR AVAIED
4016	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	ATTICHOWDENAHALLI_66	10:05	17:50	07:45	LINE CLEAR AVAIED
4017	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	BAGUR_66	10:28	17:50	07:22	LINE CLEAR AVAIED
4018	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHANNARAYAPATNA_66	10:40	17:52	07:12	LINE CLEAR AVAIED
4019	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	DIDIGA_66	11:00	14:15	03:15	LINE CLEAR AVAIED
4020	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	10:00	17:30	07:30	LINE CLEAR AVAIED
4021	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMPURA_66	10:25	15:25	05:00	LINE CLEAR AVAIED
4022	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESHPURA_66	11:37	12:52	01:15	LINE CLEAR AVAIED
4023	21-Jun-24	HASSAN	66	TRANSFORMER	HV2	UDAYAPURA_66	11:13	17:48	06:35	LINE CLEAR AVAIED
4024	21-Jun-24	HASSAN	66	LINE	KANDLI-SAKLESHPUR	KANDLI_66	11:35	12:52	01:17	LINE CLEAR AVAIED
4025	21-Jun-24	HASSAN	66	TRANSFORMER	LV1	CRPATNA_220	11:29	13:50	02:21	LINE CLEAR AVAIED
4026	21-Jun-24	HASSAN	66	LINE	MALALI-CRPATNA	MALALI_66	10:20	12:32	02:12	LINE CLEAR AVAIED
4027	21-Jun-24	HASSAN	66	LINE	MRSSHM-DVG2	MRSMG_220	09:41	09:59	00:18	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4028	21-Jun-24	HASSAN	66	TRANSFORMER	RAMNAT-BELVADI	RAMNATHPURA_66	11:15	12:25	01:10	MAIN SUPPLY FAILURE
4029	21-Jun-24	HASSAN	66	LINE	RAMPUR-BEGUR	RAMPURA_66	10:25	15:23	04:58	LINE CLEAR AVAIED
4030	21-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALESHPURA_66	11:35	12:52	01:17	LINE CLEAR AVAIED
4031	21-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN1	SAKALESHPURA_66	11:35	12:49	01:14	LINE CLEAR AVAIED
4032	21-Jun-24	HASSAN	66	LINE	SAKALE-HASSAN2	SAKALESHPURA_66	11:25	12:52	01:27	LINE CLEAR AVAIED
4033	21-Jun-24	HASSAN	66	LINE	SAKALE-IPCL1	SAKALESHPURA_66	11:35	12:52	01:17	LINE CLEAR AVAIED
4034	21-Jun-24	HASSAN	66	LINE	SAKALE-IPCL2	SAKALESHPURA_66	11:35	12:52	01:17	LINE CLEAR AVAIED
4035	21-Jun-24	HASSAN	66	LINE	SALAGAM-HIREMANGLUR	SALAGAME_66	11:45	11:52	00:07	LINE CLEAR AVAIED
4036	21-Jun-24	HASSAN	66	LINE	SHANTHI-UDYAPURA	SHANTHIGRAMA_66	10:20	12:42	02:22	MAIN SUPPLY FAILURE
4037	21-Jun-24	HASSAN	66	LINE	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	10:34	17:49	07:15	LINE CLEAR AVAIED
4038	21-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	07:10	07:15	00:05	MAIN SUPPLY FAILURE
4039	21-Jun-24	HASSAN	110	LINE	DMKURK-HONNAVALLI	DMKURKE_110	16:40	17:25	00:45	LINE CLEAR AVAIED
4040	21-Jun-24	HASSAN	110	LINE	HGUNJE-HIRIYADKA	HEGGUNJE_220	11:18	13:24	02:06	LINE CLEAR AVAIED
4041	21-Jun-24	HASSAN	110	LINE	HIRIYA-HALADY	HIRIYADKA_110	11:20	13:24	02:04	LINE CLEAR AVAIED
4042	21-Jun-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	10:00	10:30	00:30	LINE CLEAR AVAIED
4043	21-Jun-24	HASSAN	110	TRANSFORMER	HV1	BARANGI_110	14:45	15:40	00:55	LINE CLEAR AVAIED
4044	21-Jun-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	07:10	07:15	00:05	MAIN SUPPLY FAILURE
4045	21-Jun-24	HASSAN	110	TRANSFORMER	HV1	DMKURKE_110	16:40	17:25	00:45	LINE CLEAR AVAIED
4046	21-Jun-24	HASSAN	110	TRANSFORMER	HV1	KITTADAHALLI_110	10:21	17:45	07:24	LINE CLEAR AVAIED
4047	21-Jun-24	HASSAN	110	TRANSFORMER	HV1CBreaker	KARKALA_110	22:35	22:41	00:06	TRIPPED ON FAULT
4048	21-Jun-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	07:10	07:15	00:05	MAIN SUPPLY FAILURE
4049	21-Jun-24	HASSAN	110	TRANSFORMER	HV2	DMKURKE_110	16:40	17:25	00:45	LINE CLEAR AVAIED
4050	21-Jun-24	HASSAN	110	TRANSFORMER	HV2	KITTADAHALLI_110	10:21	17:45	07:24	LINE CLEAR AVAIED
4051	21-Jun-24	HASSAN	110	LINE	KADUR-TNGL	KADUR_220	10:00	14:15	04:15	LINE CLEAR AVAIED
4052	21-Jun-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKALA_110	11:09	11:26	00:17	LINE CLEAR AVAIED
4053	21-Jun-24	HASSAN	110	LINE	KARKLA-L2 CBreaker	KARKALA_110	13:17	13:27	00:10	LINE CLEAR AVAIED
4054	21-Jun-24	HASSAN	110	LINE	KITTADA-BLGAVE	KITTADAHALLI_110	10:21	17:45	07:24	LINE CLEAR AVAIED
4055	21-Jun-24	HASSAN	110	TRANSFORMER	LV1	MRSMSG_220	17:13	17:38	00:25	LINE CLEAR AVAIED
4056	21-Jun-24	HASSAN	110	TRANSFORMER	LV2	MRSMSG_220	09:05	16:50	07:45	LINE CLEAR AVAIED
4057	21-Jun-24	HASSAN	110	LINE	MADHUV-KUNDAPURA	MADHUVANA_110	11:18	11:27	00:09	MAIN SUPPLY FAILURE
4058	21-Jun-24	HASSAN	110	LINE	MRSSHM-RLW CBreaker	MRSMSG_220	11:10	14:32	03:22	LINE CLEAR AVAIED
4059	21-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	17:13	17:38	00:25	LINE CLEAR AVAIED
4060	21-Jun-24	HASSAN	220	TRANSFORMER	HV1	CRPATNA_220	11:29	13:50	02:21	LINE CLEAR AVAIED
4061	21-Jun-24	HASSAN	220	TRANSFORMER	HV1 CBreaker	HEGGUNJE_220	10:25	12:25	02:00	LINE CLEAR AVAIED
4062	21-Jun-24	HASSAN	220	TRANSFORMER	HV2	MRSMSG_220	09:05	16:50	07:45	LINE CLEAR AVAIED
4063	21-Jun-24	HASSAN	220	LINE	KAVOOR-TK2	KAVOOR_220	10:00	12:44	02:44	LINE CLEAR AVAIED
4064	21-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	21:55(21.06.2024)			LINE CLEAR AVAIED
4065	21-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMSG_220	09:19	18:53	09:34	LINE CLEAR AVAIED
4066	21-Jun-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA3	gen_sharavathy	21:53(21.06.2024)			LINE CLEAR AVAIED
4067	21-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	09:19	18:53	09:34	LINE CLEAR AVAIED
4068	21-Jun-24	MYSORE	66	LINE	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	06:06	06:18	00:12	TRIPPED ON FAULT
4069	21-Jun-24	MYSORE	66	LINE	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	15:05	17:11	02:06	LINE CLEAR AVAIED
4070	21-Jun-24	MYSORE	66	LINE	HANNUR-AJJIPURA	BANDAHALLI_66AJJIPURA_66C OWDALLI_66RAMAPURA_66MA RTALLI_66	12:40	12:45	00:05	TRIPPED ON FAULT
4071	21-Jun-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAPA 2	NO STATIONS EFFECTED	12:29	12:42	00:13	TRIPPED ON FAULT
4072	21-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDAGERE_66	17:30	17:50	00:20	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4073	21-Jun-24	MYSORE	66	TRANSFORMER	HV1	NAGAMANGALA_220	10:48	12:20	01:32	TRIPPED ON FAULT
4074	21-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4075	21-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4076	21-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4077	21-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4078	21-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
4079	21-Jun-24	MYSORE	66	LINE	PONNAMPETE-VIRAJPET	NO STATIONS EFFECTED	10:57	13:23	02:25	LINE CLEAR AVAILED
4080	21-Jun-24	MYSORE	66	LINE	SHIVALLI-NAGAMANGALA	NO STATIONS EFFECTED	11:28	14:41	03:13	LINE CLEAR AVAILED
4081	21-Jun-24	MYSORE	66	LINE	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	10:40	15:25	04:45	LINE CLEAR AVAILED
4082	21-Jun-24	MYSORE	66	LINE	TUBINKERE-NAGAMANGALA 2	NO STATIONS EFFECTED	15:15	16:24	01:09	LINE CLEAR AVAILED
4083	21-Jun-24	TUMKUR	66	LINE	220KV ANCHEPLAYA-KUNIGAL	66KV KUNIGAL	17:05	17:17	00:12	TRIPPED ON FAULT
4084	21-Jun-24	TUMKUR	66	LINE	220KV BENKIKERE-66KV DEVARAHALLI	66KV DEVARAHALLI,SANTHEBENNU R,KEREBILACHI	17:32	17:36	00:04	TRIPPED ON FAULT
4085	21-Jun-24	TUMKUR	66	LINE	BENKIKERE 220KV-CHANNAGIRI	LINGADAHALLI_66, CHANNAGIRI_66	21:52	22:34	00:42	LINE CLEAR AVAILED
4086	21-Jun-24	TUMKUR	66	LINE	BENKIKERE 220KV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	17:36	23:10	05:34	LINE CLEAR AVAILED
4087	21-Jun-24	TUMKUR	66	LINE	BENKIKERE 220KV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	21:52	22:34	00:42	LINE CLEAR AVAILED
4088	21-Jun-24	TUMKUR	66	LINE	BENKIKERE 220KV-NALLUR	NALLUR_66	21:52	22:34	00:42	LINE CLEAR AVAILED
4089	21-Jun-24	TUMKUR	66	LINE	HIRIYUR SRS 220-66KV THALLAK	66KV RANGENAHALLY	14:19	14:43	00:24	TRIPPED ON FAULT
4090	21-Jun-24	TUMKUR	66	LINE	HIRIYUR SRS 220-66KV THALLAK	66KV RANGENAHALLY	14:54	15:56	01:02	TRIPPED ON FAULT
4091	21-Jun-24	TUMKUR	66	LINE	MADHUGIRI_220-PULAMAGHATTA_66	66KV PULAMAGHATTA	17:19	17:29	00:10	TRIPPED ON FAULT
4092	21-Jun-24	TUMKUR	66	LINE	PANDRALLI 66KV-HOLALAKERE 66KV	66KV HD PURA, CHITRALLI, HOLALKERE	11:34	11:44	00:10	TRIPPED ON FAULT
4093	21-Jun-24	TUMKUR	66	LINE	PANDRALLI 66KV-HOLALAKERE 66KV	66KV HD PURA, CHITRALLI, HOLALKERE	11:47	11:55	00:08	TRIPPED ON FAULT
4094	21-Jun-24	TUMKUR	220	LINE	DAVANGERE SRS- HONNALI LINE 1	HONNALLI_220, BENKIKERE_220, HOSADURGA_220	10:12	13:23	03:11	LINE CLEAR AVAILED
4095	21-Jun-24	TUMKUR	220	LINE	DAVANGERE SRS- HONNALI LINE 2	HONNALLI_220, BENKIKERE_220, HOSADURGA_220	13:26	19:19	05:53	LINE CLEAR AVAILED
4096	22-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	SIRSI_110	13:27	13:49	00:22	LINE CLEAR AVAILED
4097	22-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	NAVANAGAR(B)_110	00:15	00:25	00:10	TRIPPED ON FAULT
4098	22-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	YELPHARATTI_110	14:45	16:47	02:02	LINE CLEAR AVAILED
4099	22-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4100	22-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
4101	22-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220-NK-2(KAVALWADA)	AMBEWADI_220	18:54	19:09	00:15	TRIPPED ON FAULT
4102	22-Jun-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	20:51 (21.06.2024)	15:15 (22.06.2024)	21:52	LINE CLEAR AVAILED
4103	22-Jun-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	11:14	12:30	01:16	LINE CLEAR AVAILED
4104	22-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
4105	22-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
4106	22-Jun-24	BAGALKOTE	110	LINE	GADAG220-GADAG110	GADAG_220	12:48	13:06	00:18	LINE CLEAR AVAILED
4107	22-Jun-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	MACHE_110	12:25	12:38	00:13	LINE CLEAR AVAILED
4108	22-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4109	22-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4110	22-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4111	22-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
4112	22-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
4113	22-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4114	22-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4115	22-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
4116	22-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
4117	22-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
4118	22-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
4119	22-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
4120	22-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
4121	22-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4122	22-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4123	22-Jun-24	BAGALKOTE	220	LINE	BIDNAL- HARTI2	BIDNAL_220	05:40	09:06	03:26	TRIPPED ON FAULT
4124	22-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4125	22-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	06:24	06:45	00:21	MAIN SUPPLY FAILURE
4126	22-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	08:50	08:57	00:07	MAIN SUPPLY FAILURE
4127	22-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	11:50	11:58	00:08	LINE CLEAR AVAILED
4128	22-Jun-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	14:44	15:55	01:11	LINE CLEAR AVAILED
4129	22-Jun-24	BANGALORE	66	LINE	66KV HAL 220 - AMARJYOTHI 1 - LEE LAVENTURE (TAP)	AMAR JYOTHI	06:15	06:25	00:10	LINE CLEAR AVAILED
4130	22-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA	10:00	11:20	01:20	LINE CLEAR AVAILED
4131	22-Jun-24	BANGALORE	66	LINE	66KV KOTHIPURA 220 - RAMANAGARA	RAMANAGARA	13:55	15:45	01:50	LINE CLEAR AVAILED
4132	22-Jun-24	BANGALORE	66	LINE	66KV RAMANAGARA - DASHAVARA - SANKALGERE - BEVOOR	DASHAVARA, BEVOOR, SANKALGERE, VANDARAGUPPE	16:05	16:21	00:16	TRIPPED ON FAULT
4133	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	06:24	06:42	00:18	MAIN SUPPLY FAILURE
4134	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	09:18	09:20	00:02	LINE CLEAR AVAILED
4135	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	15:30	15:33	00:03	LINE CLEAR AVAILED
4136	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	06:24	06:42	00:18	MAIN SUPPLY FAILURE
4137	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	09:18	09:20	00:02	LINE CLEAR AVAILED
4138	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	15:30	15:33	00:03	LINE CLEAR AVAILED
4139	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	06:23	06:44	00:21	MAIN SUPPLY FAILURE
4140	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	09:18	09:21	00:03	LINE CLEAR AVAILED
4141	22-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	15:28	15:35	00:07	LINE CLEAR AVAILED
4142	22-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	10:07	14:48	04:41	LINE CLEAR AVAILED
4143	22-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	10:20	10:22	00:02	LINE CLEAR AVAILED
4144	22-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	06:20	06:40	00:20	MAIN SUPPLY FAILURE
4145	22-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	15:30	15:35	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4146	22-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHANNAPATNA 220	10:00	16:28	06:28	LINE CLEAR AVAIED
4147	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	06:20	06:40	00:20	MAIN SUPPLY FAILURE
4148	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	15:30	15:35	00:05	LINE CLEAR AVAIED
4149	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TALAGAWARA	03:55	04:15	00:20	TRIPPED ON FAULT
4150	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANASAWADI	10:20	10:22	00:02	LINE CLEAR AVAIED
4151	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TAMAKA	04:35	05:45	01:10	TRIPPED ON FAULT
4152	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HUKUNDA	17:10	17:15	00:05	LINE CLEAR AVAIED
4153	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHANNAPATNA 220	13:51	16:39	02:48	LINE CLEAR AVAIED
4154	22-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VANDARAGUPPE	16:25	16:27	00:02	LINE CLEAR AVAIED
4155	22-Jun-24	BANGALORE	220	LINE	220KV HOODY 220 - MALUR 220	EXORA 220, VIKAS TECH PARK 220	06:24	06:45	00:21	TRIPPED ON FAULT
4156	22-Jun-24	BANGALORE	220	LINE	220KV MANYATA 220 - ITI 220	NO STATION AFFECTED	16:59	18:54	01:55	TRIPPED ON FAULT
4157	22-Jun-24	BANGALORE	220	TRANSFORMER	HV1	CHANNAPATNA 220	14:46	16:25	01:39	LINE CLEAR AVAIED
4158	22-Jun-24	GULBARGA	66	LINE	BADALADUKU-BANVEKAL	BANVEKAL_66,ABRSL WIND IPP,SOLAR IPP	12:15	12:45	00:30	TRIPPED ON FAULT
4159	22-Jun-24	GULBARGA	66	LINE	BADALADUKU-MAGALA	MAGALA_66	10:00	16:00	0.25	LINE CLEAR AVAIED
4160	22-Jun-24	GULBARGA	66	TRANSFORMER	HV1	C.J.HALLI_66	11:20	12:15	00:55	LINE CLEAR AVAIED
4161	22-Jun-24	GULBARGA	66	TRANSFORMER	HV1	HARVI_66	11:55	12:20	00:25	LINE CLEAR AVAIED
4162	22-Jun-24	GULBARGA	66	TRANSFORMER	HV1	HARVI_66	04:40	05:00	00:20	LINE CLEAR AVAIED
4163	22-Jun-24	GULBARGA	66	TRANSFORMER	HV1,HV2	HALAVAGALU_66	17:15	17:30	00:15	LINE CLEAR AVAIED
4164	22-Jun-24	GULBARGA	66	LINE	ITTIGI-BENNIHALLI	BENNIHALLI_66	09:53	18:45	08:52	LINE CLEAR AVAIED
4165	22-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	21:08	21:14	00:06	MAIN SUPPLY FAILURE
4166	22-Jun-24	GULBARGA	110	LINE	RAICHUR-GABUR	GABUR_110, GUGAL_110	22:37	22:46	00:09	TRIPPED ON FAULT
4167	22-Jun-24	GULBARGA	110	LINE	RAICHUR-MATAMARI	MATAMARI_110	11:45	11:53	00:08	TRIPPED ON FAULT
4168	22-Jun-24	GULBARGA	110	LINE	SULEKAL-MALLAPUR	MALLAPUR_110	03:37	03:44	00:07	MAIN SUPPLY FAILURE
4169	22-Jun-24	GULBARGA	110	LINE	VADAVATTI-YAPALDINI	YAPALDINI_110	01:25	01:35	00:10	TRIPPED ON FAULT
4170	22-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	10:05	12:35	02:30	LINE CLEAR AVAIED
4171	22-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	10:02	12:25	02:23	TRIPPED ON FAULT
4172	22-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	12:25	18:21	05:56	LINE CLEAR AVAIED
4173	22-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	22:41	22:57	00:16	TRIPPED ON FAULT
4174	22-Jun-24	GULBARGA	220	TRANSFORMER	HV3	KUSHTAGI_220	15:55	16:12	00:17	LINE CLEAR AVAIED
4175	22-Jun-24	GULBARGA	220	LINE	LINGAPUR-GANGAVATHI2	GANGAVATHI_110	06:13	08:53	02:40	LINE CLEAR AVAIED
4176	22-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
4177	22-Jun-24	HASSAN	110	LINE	ALKOLA-SAGAR	ALKOLA_110	10:23	11:35	01:12	TRIPPED ON FAULT
4178	22-Jun-24	HASSAN	110	TRANSFORMER	HV1	SALATHUR_110	11:34	13:46	02:12	LINE CLEAR AVAIED
4179	22-Jun-24	HASSAN	110	TRANSFORMER	HV2	SALATHUR_110	11:34	13:46	02:12	LINE CLEAR AVAIED
4180	22-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	10:27	10:37	00:10	LINE CLEAR AVAIED
4181	22-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	14:39	14:44	00:05	LINE CLEAR AVAIED
4182	22-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	10:29	14:42	04:13	LINE CLEAR AVAIED
4183	22-Jun-24	HASSAN	110	TRANSFORMER	LV1	MRSMSG_220	09:02	18:45	09:43	LINE CLEAR AVAIED
4184	22-Jun-24	HASSAN	110	LINE	SAGARA-ALKLA	SAGARA_110	10:21	11:35	01:14	TRIPPED ON FAULT
4185	22-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	10:34	14:04	03:30	LINE CLEAR AVAIED
4186	22-Jun-24	HASSAN	110	LINE	SALATHU-NTMDNOR	SALATHUR_110	11:34	13:46	02:12	LINE CLEAR AVAIED
4187	22-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	09:02	18:45	09:43	LINE CLEAR AVAIED
4188	22-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY3	MRSMSG_220	21:55(21.06.2024)	12:28 (22.06.2024)	14:33HRS	LINE CLEAR AVAIED
4189	22-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH3	MRSMSG_220	09:13	18:12	08:59	LINE CLEAR AVAIED
4190	22-Jun-24	HASSAN	220	LINE	SHRAVITY-SHIMOGA3	gen_sharavathy	21:55(21.06.2024)	12:28 (22.06.2024)	14:33HRS	LINE CLEAR AVAIED
4191	22-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	09:13	18:12	08:59	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4192	22-Jun-24	MYSORE	66	LINE	HEBBANI-MEGHALAPURA	BGPURA_66 CHIDRAVALLI_66	06:23	06:35	00:12	TRIPPED ON FAULT
4193	22-Jun-24	MYSORE	66	TRANSFORMER	HV1	SRIRANGAPATNA_66	15:02	15:14	00:11	TRIPPED ON FAULT
4194	22-Jun-24	MYSORE	66	TRANSFORMER	HV1	VAJAMANGALA_220	10:04	15:52	05:48	LINE CLEAR AVAILED
4195	22-Jun-24	MYSORE	66	TRANSFORMER	HV1	YELANDUR_66	10:03	16:10	06:07	LINE CLEAR AVAILED
4196	22-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4197	22-Jun-24	MYSORE	66	TRANSFORMER	HV2	VAJAMANGALA_220	10:05	15:53	05:48	LINE CLEAR AVAILED
4198	22-Jun-24	MYSORE	66	TRANSFORMER	HV2	YELANDUR_66	10:03	16:10	06:07	LINE CLEAR AVAILED
4199	22-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4200	22-Jun-24	MYSORE	66	LINE	K K DODDI-MANDYA	NO STATIONS EFFECTED	10:40	12:31	01:51	LINE CLEAR AVAILED
4201	22-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4202	22-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4203	22-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
4204	22-Jun-24	MYSORE	66	LINE	YELANDURU-MAMBALLI	YELANDUR_66	10:08	16:09	06:00	LINE CLEAR AVAILED
4205	22-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 1	KUKKAWADA_66	14:23	14:33	00:10	TRIPPED ON FAULT
4206	22-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	12:37	12:47	00:10	TRIPPED ON FAULT
4207	22-Jun-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRAHALLI, HD PURA	11:21	11:43	00:22	TRIPPED ON FAULT
4208	22-Jun-24	TUMKUR	66	LINE	66KV MATHOD-220KV HIRIYUR LINE 1	MATHOD_66	04:30	04:40	00:10	TRIPPED ON FAULT
4209	22-Jun-24	TUMKUR	66	LINE	66KV MATHOD-220KV HIRIYUR LINE 1	MATHOD_66	04:55	05:15	00:20	TRIPPED ON FAULT
4210	22-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA, CHIKKAJAJUR	06:15	06:20	00:05	TRIPPED ON FAULT
4211	22-Jun-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI1	HOLALKERE_66	11:21	11:43	00:22	MAIN SUPPLY FAILURE
4212	22-Jun-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI2	PANDARAHALLI_66	11:21	11:43	00:22	MAIN SUPPLY FAILURE
4213	22-Jun-24	TUMKUR	66	LINE	HOSADURGA(MADHURE) 220KV-66 KV RAMAGIRI O/G LINE	66KV RAMAGIRI	06:45	07:00	00:15	TRIPPED ON FAULT
4214	22-Jun-24	TUMKUR	66	LINE	KUKKAWADA_66-BASAVAPATNA_66	66KV THAVANAGI S/S	12:53	13:03	00:10	TRIPPED ON FAULT
4215	22-Jun-24	TUMKUR	66	LINE	SHAGALE_66-KEREBILCHI_66	WATER WORKS	14:00	14:05	00:05	TRIPPED ON FAULT
4216	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 & HV2 (10MVA)	KULAGERI CROSS_110	14:37	15:46	01:09	LINE CLEAR AVAILED
4217	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BENAKATTI_110	07:11	19:36	12:25	LINE CLEAR AVAILED
4218	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	LAKAMANAHALLI_110	10:01	20:45	10:44	LINE CLEAR AVAILED
4219	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BENAKATTI_110	07:11	19:36	12:25	LINE CLEAR AVAILED
4220	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	LAKAMANAHALLI_110	10:00	13:29	03:29	LINE CLEAR AVAILED
4221	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA)	HUNAGUND_110	10:00	15:06	05:06	LINE CLEAR AVAILED
4222	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	10:37	10:41	00:04	TRIPPED ON FAULT
4223	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	17:29	17:43	00:14	TRIPPED ON FAULT
4224	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3 (20MVA)	HIREKERUR_110	08:42	08:46	00:04	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4225	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV3 (10MVA T1)	SADALAGA_110	11:02	17:44	06:42	LINE CLEAR AVAILED
4226	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4 (10MVA)	VADAGOAN_110	09:09	15:49	06:40	LINE CLEAR AVAILED
4227	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV4(10MVA T3)	SADALAGA_110	11:02	17:30	06:28	LINE CLEAR AVAILED
4228	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV1 (20MVA)	HUNAGUND_110	11:29	11:32	00:03	LINE CLEAR AVAILED
4229	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10MVA)	LAKAMANAHALLI_110	10:00	17:08	07:08	LINE CLEAR AVAILED
4230	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV4 (10MVA)	LAKAMANAHALLI_110	10:00	18:02	08:02	LINE CLEAR AVAILED
4231	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV1 (10MVA)	VADAGOAN_110	09:04	15:50	06:46	LINE CLEAR AVAILED
4232	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2 (10MVA)	VADAGOAN_110	09:04	15:50	06:46	LINE CLEAR AVAILED
4233	23-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV2 (20MVA T4)	SADALAGA_110	11:03	17:37	06:34	LINE CLEAR AVAILED
4234	23-Jun-24	BAGALKOTE	110	LINE	BELGAUM220-HUKKERI(UCHAGOAN)	BELGAUM_220	12:30	13:11	00:41	LINE CLEAR AVAILED
4235	23-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- VADAGAON	BELGAUM_220	09:13	14:36	05:23	LINE CLEAR AVAILED
4236	23-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- VADAGOAN	BELGAUM_220	22:11	22:48	00:37	TRIPPED ON FAULT
4237	23-Jun-24	BAGALKOTE	110	LINE	BELUR-NARENDRA2 (NARENDRA1)	BELUR_110	10:59	14:14	03:15	LINE CLEAR AVAILED
4238	23-Jun-24	BAGALKOTE	110	LINE	BENAKATTI-SOUDATTI220	BENAKATTI_110	07:11	19:38	12:27	LINE CLEAR AVAILED
4239	23-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220-SADALAGA	CHIKKODI_220	12:05	15:00	02:55	LINE CLEAR AVAILED
4240	23-Jun-24	BAGALKOTE	110	LINE	GARAG-NARENDRA	GARAG_110	10:50	14:11	03:21	LINE CLEAR AVAILED
4241	23-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220-GHATAPRABHA1	GHATAPRABHA_220	10:07	16:16	06:09	LINE CLEAR AVAILED
4242	23-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	5:14	5:21	00:07	TRIPPED ON FAULT
4243	23-Jun-24	BAGALKOTE	110	LINE	HUNAGUND-B.BAGEWADI (KUDALASNAGAM)	HUNAGUND_110	10:00	15:14	05:14	LINE CLEAR AVAILED
4244	23-Jun-24	BAGALKOTE	110	LINE	HUNAGUND-ILKAL1&2	HUNAGUND_110	09:59	15:05	05:06	LINE CLEAR AVAILED
4245	23-Jun-24	BAGALKOTE	110	LINE	HUNAGUND-JUNDAL	HUNAGUND_110	10:00	15:08	05:08	LINE CLEAR AVAILED
4246	23-Jun-24	BAGALKOTE	110	LINE	HUNAGUND-KBJNL	HUNAGUND_110	10:00	15:06	05:06	LINE CLEAR AVAILED
4247	23-Jun-24	BAGALKOTE	110	LINE	KUD DHARWAD-LAKAMANAHALLI	KUD DHARWAD_110	15:42	16:30	00:48	LINE CLEAR AVAILED
4248	23-Jun-24	BAGALKOTE	110	LINE	KUDACHI220-UGARKHUD(KUDACHI110)	KUDACHI_220	10:23	18:45	08:22	LINE CLEAR AVAILED
4249	23-Jun-24	BAGALKOTE	110	LINE	MACHE-UDYAMBAG	MACHE_110	11:27	17:05	05:38	LINE CLEAR AVAILED
4250	23-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4251	23-Jun-24	BAGALKOTE	110	LINE	MUNAVALLI-SOUDATTI220	MUNAVALLI_110	07:00	19:45	12:45	LINE CLEAR AVAILED
4252	23-Jun-24	BAGALKOTE	110	LINE	RAMDURG-BAGALKOT	RAMDURG_110	07:20	20:40	13:20	LINE CLEAR AVAILED
4253	23-Jun-24	BAGALKOTE	110	LINE	SADALA-VPPL	SADALAGA_110	12:30	15:53	03:23	LINE CLEAR AVAILED
4254	23-Jun-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON1	SOUDATTI_110	07:23	19:38	12:15	LINE CLEAR AVAILED
4255	23-Jun-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON2	SOUDATTI_110	07:23	19:38	12:15	LINE CLEAR AVAILED
4256	23-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- BENAKATTI	SOUDATTI_220	07:08	19:35	12:27	LINE CLEAR AVAILED
4257	23-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- MUNAVALLI	SOUDATTI_220	07:08	19:35	12:27	LINE CLEAR AVAILED
4258	23-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA1	SOUDATTI_220	07:08	19:52	12:44	LINE CLEAR AVAILED
4259	23-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA2	SOUDATTI_220	07:08	19:40	12:32	LINE CLEAR AVAILED
4260	23-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- UDAKERI	SOUDATTI_220	07:08	19:32	12:24	LINE CLEAR AVAILED
4261	23-Jun-24	BAGALKOTE	110	LINE	VADAGO-BELGAUM	VADAGOAN_110	09:11	14:35	05:24	LINE CLEAR AVAILED
4262	23-Jun-24	BAGALKOTE	110	LINE	VADAGO-BELGAUM	VADAGOAN_110	22:31	23:08	00:37	LINE CLEAR AVAILED
4263	23-Jun-24	BAGALKOTE	110	LINE	VADAGO-MACHE	VADAGOAN_110	09:10	15:12	06:02	LINE CLEAR AVAILED
4264	23-Jun-24	BAGALKOTE	110	LINE	YARAGA-KATAKOL	YARAGATTI_110	07:02	19:42	12:40	LINE CLEAR AVAILED
4265	23-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3&LV3	BELGAUM_220	10:31	13:29	02:58	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4266	23-Jun-24	BAGALKOTE	220	LINE	BELGAUM- KANABARGI1	BELGAUM_220	15:04	16:58	01:54	LINE CLEAR AVAILED
4267	23-Jun-24	BAGALKOTE	220	LINE	BELGAUM- KANABARGI2	BELGAUM_220	12:38	14:29	01:51	LINE CLEAR AVAILED
4268	23-Jun-24	BAGALKOTE	220	LINE	BIDNAL-SOUDATTI1	BIDNAL_220	07:09	20:10	13:01	LINE CLEAR AVAILED
4269	23-Jun-24	BAGALKOTE	220	LINE	BIDNAL-SOUDATTI2	BIDNAL_220	07:10	19:21	12:11	LINE CLEAR AVAILED
4270	23-Jun-24	BAGALKOTE	220	LINE	KUDACHI220-UGARKHUD	KUDACHI_220	10:23	18:45	08:22	LINE CLEAR AVAILED
4271	23-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	7:08	20:10	13:02	LINE CLEAR AVAILED
4272	23-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4273	23-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL	SOUDATTI_220	7:08	19:22	12:14	LINE CLEAR AVAILED
4274	23-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	A STATION 66	10:14	15:30	05:16	LINE CLEAR AVAILED
4275	23-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A2)	A STATION 66	10:14	15:30	05:16	LINE CLEAR AVAILED
4276	23-Jun-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	AGALAKOTE	10:10	10:15	00:05	LINE CLEAR AVAILED
4277	23-Jun-24	BANGALORE	66	LINE	66KV ANEKAL - ATTIBELE	ATTIBELE	10:08	16:24	06:16	LINE CLEAR AVAILED
4278	23-Jun-24	BANGALORE	66	LINE	66KV BAIL BEGUR 220 - 66 KV ITC AIRPORT ROAD (EHT)	NO STATION AFFECTED	10:18	17:10	06:52	LINE CLEAR AVAILED
4279	23-Jun-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - BIAL 1 (EHT)	NO STATION AFFECTED	10:10	15:15	05:05	LINE CLEAR AVAILED
4280	23-Jun-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - BIAL 2 (EHT)	NO STATION AFFECTED	10:10	15:15	05:05	LINE CLEAR AVAILED
4281	23-Jun-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGAR	NO STATION AFFECTED	10:14	17:43	07:29	LINE CLEAR AVAILED
4282	23-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - BOSCH (EHT)	BOSCH(EHT)	10:01	16:23	06:22	LINE CLEAR AVAILED
4283	23-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - COCA COLA (EHT)	COCOCOLA(EHT)	10:01	17:30	07:29	LINE CLEAR AVAILED
4284	23-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - HEJJALA 2	HEJJALA	10:03	10:13	00:10	LINE CLEAR AVAILED
4285	23-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - TTIPL (EHT)	TTIPL(EHT)	10:01	18:10	08:09	LINE CLEAR AVAILED
4286	23-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - HIREHALLI	NO STATION AFFECTED	10:00	16:47	06:47	LINE CLEAR AVAILED
4287	23-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - NELAMANGALA CKT 1	NO STATION AFFECTED	10:20	19:48	09:28	LINE CLEAR AVAILED
4288	23-Jun-24	BANGALORE	66	LINE	66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2)	NO STATION AFFECTED	10:20	16:49	06:29	LINE CLEAR AVAILED
4289	23-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWELL	10:00	18:27	08:27	LINE CLEAR AVAILED
4290	23-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	KONDASAPURA	10:02	10:09	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4291	23-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	VIDYANAGARA	10:00	17:10	07:10	LINE CLEAR AVAILED
4292	23-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA	BELL CERAMICS	10:00	17:45	07:45	LINE CLEAR AVAILED
4293	23-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - BUDIGERE	BUDIGERE	10:00	17:36	07:36	LINE CLEAR AVAILED
4294	23-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	10:00	17:34	07:34	LINE CLEAR AVAILED
4295	23-Jun-24	BANGALORE	66	TRANSFORMER	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	10:00	17:43	07:43	LINE CLEAR AVAILED
4296	23-Jun-24	BANGALORE	66	TRANSFORMER	66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI	VOLVO, NANDAGUDI	08:05	08:15	00:10	TRIPPED ON FAULT
4297	23-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	10:00	17:43	07:43	LINE CLEAR AVAILED
4298	23-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI	10:10	16:10	06:00	LINE CLEAR AVAILED
4299	23-Jun-24	BANGALORE	66	LINE	66KV JIGANI LINK ROAD - JIGANI OLD STATION	JIGANI LINK ROAD	10:04	16:55	06:51	LINE CLEAR AVAILED
4300	23-Jun-24	BANGALORE	66	LINE	66KV KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	10:00	17:30	07:30	LINE CLEAR AVAILED
4301	23-Jun-24	BANGALORE	66	LINE	66KV KIADB DODDABALLAPURA 220 - INDO MIM (EHT)	INDO MM(EHT)	10:02	16:41	06:39	LINE CLEAR AVAILED
4302	23-Jun-24	BANGALORE	66	LINE	66KV KIADB HARDWARE PARK 220 - 66KV SHELL EHT	SHELL	07:46	17:22	09:36	LINE CLEAR AVAILED
4303	23-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALI 220 - VR DODDI	VR DODDI	14:21	14:31	00:10	TRIPPED ON FAULT
4304	23-Jun-24	BANGALORE	66	LINE	66KV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP)	K&C VALLEY	11:52	12:09	00:17	LINE CLEAR AVAILED
4305	23-Jun-24	BANGALORE	66	LINE	66KV KUMBALAGODU 220 - HEJJALA	HEJJALA	18:01	18:11	00:10	LINE CLEAR AVAILED
4306	23-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	MAGADI 66	10:10	16:50	06:40	LINE CLEAR AVAILED
4307	23-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)	GUDEMARNAHALLI	10:10	16:59	06:49	LINE CLEAR AVAILED
4308	23-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - VG DODDI - TG HALLI	VG DODDI	10:10	16:50	06:40	LINE CLEAR AVAILED
4309	23-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - VIJAYAPURA	VIJAYAPURA	10:00	17:05	07:05	LINE CLEAR AVAILED
4310	23-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	10:00	16:30	06:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4311	23-Jun-24	BANGALORE	66	LINE	66KV SIDDALAGHATTA - MELUR	MELUR	18:05	18:10	00:05	LINE CLEAR AVAILED
4312	23-Jun-24	BANGALORE	66	LINE	66KV T GOLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI	BYRAKUR, NANGLI	16:18	16:38	00:20	TRIPPED ON FAULT
4313	23-Jun-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE, TG HALLI	10:15	16:05	05:50	LINE CLEAR AVAILED
4314	23-Jun-24	BANGALORE	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	JANGAMKOTE	10:00	17:45	07:45	LINE CLEAR AVAILED
4315	23-Jun-24	BANGALORE	66	LINE	66KV VIJAYPURA - JANGAMKOTE - MELURU	MELUR	09:00	09:10	00:10	LINE CLEAR AVAILED
4316	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	10:14	15:35	05:21	LINE CLEAR AVAILED
4317	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	PRESTIGE SHANTINIKETHAN	10:05	10:10	00:05	LINE CLEAR AVAILED
4318	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIAL BEGUR 220	10:22	17:12	06:50	LINE CLEAR AVAILED
4319	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOSKOTE 220	10:00	17:12	07:12	LINE CLEAR AVAILED
4320	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KIADB HP PARK 220	10:40	16:50	06:10	LINE CLEAR AVAILED
4321	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KIADB DB PURA 220	10:05	16:49	06:44	LINE CLEAR AVAILED
4322	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BYRAKUR	08:00	08:10	00:10	TRIPPED ON FAULT
4323	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	RANGANADODDI	10:45	16:15	05:30	LINE CLEAR AVAILED
4324	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SANJEEVANADODDI	10:30	14:40	04:10	LINE CLEAR AVAILED
4325	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DABUSPETE 220	10:10	17:17	07:07	LINE CLEAR AVAILED
4326	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	10:00	17:40	07:40	LINE CLEAR AVAILED
4327	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	10:01	15:45	05:44	LINE CLEAR AVAILED
4328	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIDADI 220	10:01	15:45	05:44	LINE CLEAR AVAILED
4329	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOTHIPURA 220	10:00	13:50	03:50	LINE CLEAR AVAILED
4330	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BOMMASANDRA I/A	16:26	16:35	00:09	LINE CLEAR AVAILED
4331	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	10:00	17:17	07:17	LINE CLEAR AVAILED
4332	23-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANHALLI 220	15:36	15:40	00:04	TRIPPED ON FAULT
4333	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BIAL BEGUR 220	10:19	17:22	07:03	LINE CLEAR AVAILED
4334	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOSKOTE 220	10:00	17:12	07:12	LINE CLEAR AVAILED
4335	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KIADB DB PURA 220	10:05	16:49	06:44	LINE CLEAR AVAILED
4336	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VOKKALERI	23:55	23:59	00:04	TRIPPED ON FAULT
4337	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	RANGANADODDI	10:45	16:15	05:30	LINE CLEAR AVAILED
4338	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRAPPA CIRCLE	15:50	16:20	00:30	LINE CLEAR AVAILED
4339	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	DABUSPETE 220	10:10	17:18	07:08	LINE CLEAR AVAILED
4340	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HOSPALYA CIRCLE	10:00	17:40	07:40	LINE CLEAR AVAILED
4341	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BIDADI 220	10:01	15:45	05:44	LINE CLEAR AVAILED
4342	23-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JIGANI 66	10:00	17:17	07:17	LINE CLEAR AVAILED
4343	23-Jun-24	BANGALORE	66	TRANSFORMER	HV3	A STATION 66	10:14	15:35	05:21	LINE CLEAR AVAILED
4344	23-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KIADB DB PURA 220	10:05	16:49	06:44	LINE CLEAR AVAILED
4345	23-Jun-24	BANGALORE	66	TRANSFORMER	HV3	JIGANI 66	08:00	08:10	00:10	LINE CLEAR AVAILED
4346	23-Jun-24	BANGALORE	66	TRANSFORMER	HV4	A STATION 66	10:14	15:35	05:21	LINE CLEAR AVAILED
4347	23-Jun-24	BANGALORE	220	LINE	220KV AERO SPACE 220 - BIAL BEGUR 220	NO STATION AFFECTED	10:21	17:40	07:19	LINE CLEAR AVAILED
4348	23-Jun-24	BANGALORE	220	LINE	220KV HOODY 400 - SHOBHA DREAMS 220	NO STATION AFFECTED	13:20	15:42	02:22	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4349	23-Jun-24	BANGALORE	220	LINE	220KV HSR LAYOUT 220 - KORAMANGALA 220	KORAMANGALA 220	12:32	12:45	00:13	LINE CLEAR AVAILED
4350	23-Jun-24	BANGALORE	220	LINE	220KV HSR LAYOUT 220 - KORAMANGALA 220	KORAMANGALA 220	15:00	15:05	00:05	LINE CLEAR AVAILED
4351	23-Jun-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - AERO SPACE 220	NO STATION AFFECTED	10:25	17:05	06:40	LINE CLEAR AVAILED
4352	23-Jun-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 1	NO STATION AFFECTED	10:23	17:03	06:40	LINE CLEAR AVAILED
4353	23-Jun-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - EKARAJPURA 1	NO STATION AFFECTED	10:12	16:53	06:41	LINE CLEAR AVAILED
4354	23-Jun-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - EKARAJPURA 2	NO STATION AFFECTED	10:12	17:09	06:57	LINE CLEAR AVAILED
4355	23-Jun-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - BIDADI 1	NO STATION AFFECTED	11:04	12:45	01:41	LINE CLEAR AVAILED
4356	23-Jun-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - BIDADI 2	NO STATION AFFECTED	12:50	13:40	00:50	LINE CLEAR AVAILED
4357	23-Jun-24	BANGALORE	220	LINE	220KV KOTHIPURA 220 - BIDADI 2	NO STATION AFFECTED	13:40	14:00	00:20	TRIPPED ON FAULT
4358	23-Jun-24	BANGALORE	220	LINE	220KV NRS DB PURA 220 - BIAL BEGUR 220	NO STATION AFFECTED	15:03	15:18	00:15	LINE CLEAR AVAILED
4359	23-Jun-24	BANGALORE	220	LINE	220KV NRS DB PURA 220 - BIAL BEGUR 220	NO STATION AFFECTED	09:08	15:03	05:55	LINE CLEAR AVAILED
4360	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	BIAL BEGUR 220	10:21	17:04	06:43	LINE CLEAR AVAILED
4361	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	HOSKOTE 220	10:00	17:12	07:12	LINE CLEAR AVAILED
4362	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	KIADB HP PARK 220	10:40	16:48	06:08	LINE CLEAR AVAILED
4363	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	KIADB DB PURA 220	10:02	16:41	06:39	LINE CLEAR AVAILED
4364	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	DABUSPETE 220	10:21	16:45	06:24	LINE CLEAR AVAILED
4365	23-Jun-24	BANGALORE	220	TRANSFORMER	HV1	MAGADI 220	10:10	16:40	06:30	LINE CLEAR AVAILED
4366	23-Jun-24	BANGALORE	220	TRANSFORMER	HV2	BIAL BEGUR 220	10:23	17:04	06:41	LINE CLEAR AVAILED
4367	23-Jun-24	BANGALORE	220	TRANSFORMER	HV2	HOSKOTE 220	10:00	17:12	07:12	LINE CLEAR AVAILED
4368	23-Jun-24	BANGALORE	220	TRANSFORMER	HV2	KIADB DB PURA 220	10:02	16:42	06:40	LINE CLEAR AVAILED
4369	23-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MAGADI 220	10:10	16:50	06:40	LINE CLEAR AVAILED
4370	23-Jun-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	10:05	17:17	07:12	LINE CLEAR AVAILED
4371	23-Jun-24	BANGALORE	220	TRANSFORMER	HV3	BIAL BEGUR 220	10:25	15:13	04:48	LINE CLEAR AVAILED
4372	23-Jun-24	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUDRA_110	09:21	17:35	08:14	LINE CLEAR AVAILED
4373	23-Jun-24	GULBARGA	110	LINE	KALBURGI SOUTH-FHARTABAD	FARTHABAD_110	21:35	21:50	00:15	TRIPPED ON FAULT
4374	23-Jun-24	GULBARGA	110	LINE	KUSHTAGI-ILKAL1&2	ILKAL_110	10:00	15:00	05:00	LINE CLEAR AVAILED
4375	23-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHAPUR2	GABUR_110, GUGAL_110	22:29	22:36	00:07	TRIPPED ON FAULT
4376	23-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	08:39	18:00	09:21	LINE CLEAR AVAILED
4377	23-Jun-24	GULBARGA	110	LINE	SINDHANOOR-DHADESUGUR	DHADESUGUR_110	10:40	12:40	02:00	LINE CLEAR AVAILED
4378	23-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	23:46	24:00:00	00:14	TRIPPED ON FAULT
4379	23-Jun-24	GULBARGA	110	LINE	WALKAMDINI-SINDHANOOR	WALKAMDINI_110, BYAGWAT_110	08:30	17:50	09:20	LINE CLEAR AVAILED
4380	23-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	22:42	23:00	00:18	TRIPPED ON FAULT
4381	23-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
4382	23-Jun-24	GULBARGA	220	LINE	SHAHPUR-FIROZABAD2	SHAHPUR_220	19:47	20:04	00:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4383	23-Jun-24	HASSAN	66	TRANSFORMER	HV1	HIREMANGALUR_66	22:45	23:17	00:32	LINE CLEAR AVAILED
4384	23-Jun-24	HASSAN	66	TRANSFORMER	HV2	RAMNATHPURA_66	14:00	14:20	00:20	TRIPPED ON FAULT
4385	23-Jun-24	HASSAN	110	TRANSFORMER	HV1	NAVUNDA_110	17:17	17:28	00:11	TRIPPED ON FAULT
4386	23-Jun-24	HASSAN	110	LINE	KAVOOR-GURUPURA	KAVOOR_220	09:26	13:07	03:41	LINE CLEAR AVAILED
4387	23-Jun-24	HASSAN	110	LINE	MRSSHM-BADRAVATY1	MRSMG_220	09:02	16:41	07:39	LINE CLEAR AVAILED
4388	23-Jun-24	HASSAN	110	LINE	MRSSHM-BADRAVATY2	MRSMG_220	09:02	16:41	07:39	LINE CLEAR AVAILED
4389	23-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMG_220	08:43	17:11	08:28	LINE CLEAR AVAILED
4390	23-Jun-24	HASSAN	220	TRANSFORMER	HV1	MSEZ_220	17:38	19:07	01:29	TRIPPED ON FAULT
4391	23-Jun-24	HASSAN	220	TRANSFORMER	HV2	MSEZ_220	17:38	18:31	00:53	TRIPPED ON FAULT
4392	23-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMG_220	08:24	18:21	09:57	LINE CLEAR AVAILED
4393	23-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR1	MSEZ_220	17:38	18:40	01:02	TRIPPED ON FAULT
4394	23-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	17:38	18:40	01:02	TRIPPED ON FAULT
4395	23-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	17:38	18:17	00:39	TRIPPED ON FAULT
4396	23-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	08:24	18:21	09:57	LINE CLEAR AVAILED
4397	23-Jun-24	MYSORE	66	LINE	HANNUR-MADHUVANAHALLI	NO STATIONS EFFECTED	03:10	03:19	00:08	TRIPPED ON FAULT
4398	23-Jun-24	MYSORE	66	TRANSFORMER	HV1	MALAVALLI_66	23:02	23:43	00:41	TRIPPED ON FAULT
4399	23-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4400	23-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4401	23-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4402	23-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4403	23-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:30	14:54	01:24	LINE CLEAR AVAILED
4404	23-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
4405	23-Jun-24	MYSORE	66	LINE	SANTHEMARALLI-DRPETE	SATHEMARALLI_66	10:11	17:03	06:52	LINE CLEAR AVAILED
4406	23-Jun-24	MYSORE	66	LINE	YELANDUR-MADHUVANAHALLI	MAMBALLI_66	13:16	15:10	01:53	LINE CLEAR AVAILED
4407	23-Jun-24	MYSORE	66	LINE	YEREHALLI HAND POST-HD KOTE	HDKOTE_66 ANTARSANTE_66	15:00	15:08	00:08	TRIPPED ON FAULT
4408	23-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA, SASALUHALLA,CHIKKAJAJUR	14:20	14:32	00:12	TRIPPED ON FAULT
4409	23-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA LINE	66KV MYLANAHALLI, VV PURA, DYAVARANAHALLI.	19:13	19:44	00:31	TRIPPED ON FAULT
4410	23-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	17:05	17:17	00:12	TRIPPED ON FAULT
4411	23-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV- PANDARAHALLI 2	SIRIGERE_66, BHARAMSAGARA_66, VIJAPURA_66, KNNL	14:30	16:35	02:05	LINE CLEAR AVAILED
4412	23-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:16	11:24	00:08	LINE CLEAR AVAILED
4413	23-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:01	12:13	00:12	LINE CLEAR AVAILED
4414	23-Jun-24	TUMKUR	66	LINE	HOLALKERE-PANDRAHALLI1	HOLALKERE_66	02:30	04:35	02:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4415	23-Jun-24	TUMKUR	66	LINE	KDBVNP- TMTP	TMTP_66, THOVINAKERE_66, BRAMASANDRA_66	10:00	16:39	06:39	LINE CLEAR AVAILED
4416	23-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(20MVA)	KIADB_220	10:02	16:37	06:35	LINE CLEAR AVAILED
4417	23-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(20MVA)	KIADB_220	10:02	16:37	06:35	LINE CLEAR AVAILED
4418	23-Jun-24	TUMKUR	220	LINE	ANCHEPALYA 220KV- NAGAMANGALA2	NAGAMANGALA_220	10:28	16:38	06:10	LINE CLEAR AVAILED
4419	23-Jun-24	TUMKUR	220	LINE	KDBVNP- MADHUGIRI220	MADHUGIRI_220	10:17	16:31	06:14	LINE CLEAR AVAILED
4420	23-Jun-24	TUMKUR	220	LINE	KDBVNP_PGCL	KDBVNP_220	10:23	17:20	06:57	LINE CLEAR AVAILED
4421	23-Jun-24	TUMKUR	220	LINE	THALLAK 220KV - BGKERE 1	BGKERE_66	10:29	15:56	05:27	LINE CLEAR AVAILED
4422	23-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(100MVA)	KIADB_220	09:35	16:35	07:00	LINE CLEAR AVAILED
4423	23-Jun-24	TUMKUR	220	TRANSFORMER	TR-2(100MVA)	KIADB_220	10:02	16:31	06:29	LINE CLEAR AVAILED
4424	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	LAKMANAHALLI_110	10:48	20:23	09:35	LINE CLEAR AVAILED
4425	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	KUDACHI_220	14:46	15:55	00:45	LINE CLEAR AVAILED
4426	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KALGHATAGI_110	15:42	17:21	01:39	LINE CLEAR AVAILED
4427	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	NAVANAGAR_110	11:45	13:34	01:49	LINE CLEAR AVAILED
4428	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	KHADAKALAT_110	10:54	11:38	00:44	LINE CLEAR AVAILED
4429	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MALGHAN(B)_110	14:22	18:20	03:58	LINE CLEAR AVAILED
4430	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (10MVA)	UKKALI_110	07:16	23:40	16:24	LINE CLEAR AVAILED
4431	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA)	MAMADAPUR (B)_110	17:18	19:03	01:45	LINE CLEAR AVAILED
4432	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1 (20MVA)	MAMADAPUR (B)_110	08:15	12:10	03:55	LINE CLEAR AVAILED
4433	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	MAMADAPUR (B)_110	08:15	12:10	03:55	LINE CLEAR AVAILED
4434	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3 (20MVA)	MAMADAPUR (B)_110	08:15	12:10	03:55	LINE CLEAR AVAILED
4435	24-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3 (20MVA)	MAMADAPUR (B)_110	18:56	19:03	00:07	LINE CLEAR AVAILED
4436	24-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
4437	24-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2(LV3)	KUDACHI_220	14:45	15:58	01:17	LINE CLEAR AVAILED
4438	24-Jun-24	BAGALKOTE	110	LINE	ANKOLA-ARGA	ANKOLA_110	13:21	14:08	00:47	LINE CLEAR AVAILED
4439	24-Jun-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	12:00	13:24	01:24	LINE CLEAR AVAILED
4440	24-Jun-24	BAGALKOTE	110	LINE	ANKOLA-KUMTA	ANKOLA_110	14:05	14:11	00:06	LINE CLEAR AVAILED
4441	24-Jun-24	BAGALKOTE	110	LINE	ATHANI220-GHATANATTI	ATHANI_220	22:23	22:38	00:15	TRIPPED ON FAULT
4442	24-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
4443	24-Jun-24	BAGALKOTE	110	LINE	BYADAGI- SUZLON	BYADAGI_110	12:44	12:50	00:06	LINE CLEAR AVAILED
4444	24-Jun-24	BAGALKOTE	110	LINE	BYADAGI- SUZLON	BYADAGI_110	13:26	14:54	01:28	LINE CLEAR AVAILED
4445	24-Jun-24	BAGALKOTE	110	LINE	BYADAGI- SUZLON	BYADAGI_110	15:12	15:23	00:11	LINE CLEAR AVAILED
4446	24-Jun-24	BAGALKOTE	110	LINE	HIREMURAL- F1(BAGEWADI)	HIREMURAL_110	08:00	19:05	11:05	LINE CLEAR AVAILED
4447	24-Jun-24	BAGALKOTE	110	LINE	HUNGUND- ILKAL2	HUNGUND_110	05:41	05:49	00:08	TRIPPED ON FAULT
4448	24-Jun-24	BAGALKOTE	110	LINE	JAMKHANDI- PRABHULINGESHWAR (SHIROL)	JAMKHANDI_110	09:39	09:40	00:01	LINE CLEAR AVAILED
4449	24-Jun-24	BAGALKOTE	110	LINE	JAMKHANDI- PRABHULINGESHWAR (SHIROL)	JAMKHANDI_110	10:54	10:56	00:02	LINE CLEAR AVAILED
4450	24-Jun-24	BAGALKOTE	110	LINE	KULIGOD- GAMESHA	KULIGOD_110	04:47	05:07	00:20	TRIPPED ON FAULT
4451	24-Jun-24	BAGALKOTE	110	LINE	MALGHAN- BAGEWADI(RAILWAY LINE)	MALGHAN(B)_110	14:22	14:49	00:27	LINE CLEAR AVAILED
4452	24-Jun-24	BAGALKOTE	110	LINE	MALGHAN- BASAVA SUGARS	MALGHAN(B)_110	08:00	14:51	06:51	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4453	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-B .BAGEWADI1	MAMADAPUR (B)_110	08:00	17:53	09:53	LINE CLEAR AVAILED
4454	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-B .BAGEWADI2	MAMADAPUR (B)_110	08:00	13:55	05:55	LINE CLEAR AVAILED
4455	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-BABLESWAR	MAMADAPUR (B)_110	08:15	18:10	09:55	LINE CLEAR AVAILED
4456	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-BLGM_SLR	MAMADAPUR (B)_110	08:15	12:25	04:10	LINE CLEAR AVAILED
4457	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-SHIRABUR	MAMADAPUR (B)_110	08:15	17:55	09:40	LINE CLEAR AVAILED
4458	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-TODALBAGI	MAMADAPUR (B)_110	08:15	12:12	03:57	LINE CLEAR AVAILED
4459	24-Jun-24	BAGALKOTE	110	LINE	MAMADA-TODALBAGI	MAMADAPUR (B)_110	17:48	18:13	00:25	LINE CLEAR AVAILED
4460	24-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4461	24-Jun-24	BAGALKOTE	110	LINE	MUDDEB-KNMSLR (KOLUR)	MUDDEBIHAL_110	11:30	18:57	07:27	LINE CLEAR AVAILED
4462	24-Jun-24	BAGALKOTE	110	LINE	MUKARTHA-L1-B BAGEWADI	MUKARTIHAL_110	08:22	17:39	09:17	LINE CLEAR AVAILED
4463	24-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4464	24-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
4465	24-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4466	24-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
4467	24-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
4468	24-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
4469	24-Jun-24	BAGALKOTE	110	LINE	UKLI-F2 Cbreaker (BAGEWADI)	UKKALI_110	07:17	17:50	10:33	LINE CLEAR AVAILED
4470	24-Jun-24	BAGALKOTE	110	LINE	UKLI-F2 Cbreaker (BAGEWADI)	UKKALI_110	18:20	23:40	05:20	LINE CLEAR AVAILED
4471	24-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4472	24-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2(HV3)	KUDACHI_220	14:46	15:55	01:09	LINE CLEAR AVAILED
4473	24-Jun-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA2	AMBEWADI_220	13:42	18:15	04:33	LINE CLEAR AVAILED
4474	24-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4475	24-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTHA	15:35	16:42	01:07	LINE CLEAR AVAILED
4476	24-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENHALLI	HULLENHALLI, KUDUR, SRIGIRIPURA	12:27	12:34	00:07	MAIN SUPPLY FAILURE
4477	24-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	JIGANI LINK ROAD	01:10	01:28	00:18	TRIPPED ON FAULT
4478	24-Jun-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	10:05	10:06	00:01	LINE CLEAR AVAILED
4479	24-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	PURVANKARA PALM BEACH	13:12	13:16	00:04	LINE CLEAR AVAILED
4480	24-Jun-24	BANGALORE	66	LINE	66KV DG4_ VIDYANAGAR - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	15:25	16:03	00:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4481	24-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWEL NORTON	15:57	16:05	00:08	LINE CLEAR AVAILED
4482	24-Jun-24	BANGALORE	66	LINE	66KV DG4_KIADB - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220	GRINDWEL NORTON	19:12	19:21	00:09	LINE CLEAR AVAILED
4483	24-Jun-24	BANGALORE	66	LINE	66KV EKARAJAPURA 220 - PILLAGUMPA	PILLAGUMPA	11:53	11:58	00:05	LINE CLEAR AVAILED
4484	24-Jun-24	BANGALORE	66	LINE	66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR	CHOKKASANDRA, ELECTRONIC CITY P2 S2	22:06	22:36	00:30	MAIN SUPPLY FAILURE
4485	24-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	07:04	07:20	00:16	TRIPPED ON FAULT
4486	24-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1	CESSNA, CESSNA(EHT)	15:20	15:30	00:10	LINE CLEAR AVAILED
4487	24-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2	CESSNA, CESSNA(EHT)	15:20	15:30	00:10	LINE CLEAR AVAILED
4488	24-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH VILLAGE	15:20	15:30	00:10	LINE CLEAR AVAILED
4489	24-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ ECO WORLD	15:14	15:29	00:15	LINE CLEAR AVAILED
4490	24-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1	HULIMANGALA, INFOSYS, ELECTRONIC CITY	21:58	22:18	00:20	LINE CLEAR AVAILED
4491	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HENNUR CROSS	10:57	11:00	00:03	LINE CLEAR AVAILED
4492	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	15:20	15:30	00:10	LINE CLEAR AVAILED
4493	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANNABEL(DLF)	10:10	13:27	03:17	LINE CLEAR AVAILED
4494	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KONDASAPURA	16:57	17:01	00:04	LINE CLEAR AVAILED
4495	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	M GOLLAHALLI	12:10	12:15	00:05	LINE CLEAR AVAILED
4496	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KAMASAMUDRA	08:30	08:45	00:15	TRIPPED ON FAULT
4497	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HAROBELA	17:00	18:00	01:00	LINE CLEAR AVAILED
4498	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUNSENAHALLI	13:00	13:05	00:05	LINE CLEAR AVAILED
4499	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRLCE	03:10	03:20	00:10	TRIPPED ON FAULT
4500	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KUDUR	18:06	18:12	00:06	TRIPPED ON FAULT
4501	24-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	07:31	07:39	00:08	TRIPPED ON FAULT
4502	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HENNUR CROSS	13:02	16:05	03:03	LINE CLEAR AVAILED
4503	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	15:20	15:30	00:10	LINE CLEAR AVAILED
4504	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANNABEL(DLF)	10:10	14:45	04:35	LINE CLEAR AVAILED
4505	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	M GOLLAHALLI	14:45	16:00	01:15	LINE CLEAR AVAILED
4506	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KUNDANA	10:35	10:40	00:05	LINE CLEAR AVAILED
4507	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VOKKALERI	23:59	00:05	00:06	TRIPPED ON FAULT
4508	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HUNSENAHALLI	10:30	10:35	00:05	LINE CLEAR AVAILED
4509	24-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KUMBARANAHALLI	11:33	11:43	00:10	TRIPPED ON FAULT
4510	24-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KONDASAPURA	16:57	17:01	00:04	LINE CLEAR AVAILED
4511	24-Jun-24	GULBARGA	110	LINE	HALAVARTHI-KOPPAL1	KOPPAL_110	10:04	16:29	06:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4512	24-Jun-24	GULBARGA	110	LINE	HALAVARTHI-KOPPAL1	KOPPAL_110	10:04	16:29	06:25	LINE CLEAR AVAIED
4513	24-Jun-24	GULBARGA	110	LINE	HALAVARTHI-MUNIRABAD	MUNIRABAD_110	12:00	13:48	01:48	LINE CLEAR AVAIED
4514	24-Jun-24	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALI_110,DUBALGUNDI_110	06:05	06:15	00:10	TRIPPED ON FAULT
4515	24-Jun-24	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALI_110,DUBALGUNDI_110	06:20	06:30	00:10	TRIPPED ON FAULT
4516	24-Jun-24	GULBARGA	110	LINE	HALBARGA-BHALKI	BHALI_110,DUBALGUNDI_110	06:40	17:40	11:00	LINE CLEAR AVAIED
4517	24-Jun-24	GULBARGA	110	LINE	HALWARTHY-KOPPAL 1	KOPPAL_110	10:04	16:29	06:25	LINE CLEAR AVAIED
4518	24-Jun-24	GULBARGA	110	LINE	HALWARTHY-MUNIRABAD	MUNIRABAD_110	12:00	13:48	01:48	LINE CLEAR AVAIED
4519	24-Jun-24	GULBARGA	110	LINE	HUMNABAD-ALAND	ALAND_110	05:45	05:50	00:05	TRIPPED ON FAULT
4520	24-Jun-24	GULBARGA	110	TRANSFORMER	HV3	KURGOD_110	18:15	18:23	00:08	TRIPPED ON FAULT
4521	24-Jun-24	GULBARGA	110	TRANSFORMER	HV3	KURUGODU_110	18:15	18:23	00:08	TRIPPED ON FAULT
4522	24-Jun-24	GULBARGA	110	LINE	KHANAPUR-KADECHUR	KEDECHUR_110	22:17	22:24	00:07	TRIPPED ON FAULT
4523	24-Jun-24	GULBARGA	110	LINE	KONKAL-RAMASAMUDRA	KONKAL_110	00:06	00:15	00:09	TRIPPED ON FAULT
4524	24-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	20:28	20:33	00:05	TRIPPED ON FAULT
4525	24-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	05:33	05:37	00:04	TRIPPED ON FAULT
4526	24-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	08:44	17:22	08:38	LINE CLEAR AVAIED
4527	24-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	05:30	05:40	00:10	TRIPPED ON FAULT
4528	24-Jun-24	GULBARGA	110	LINE	TEKKALKOTE-SIRIGERICROSS	SIRIGERICROSS_110	10:15	12:15	02:00	TRIPPED ON FAULT
4529	24-Jun-24	GULBARGA	220	TRANSFORMER	HV2	ALLIPUR_220	16:02	16:49	00:47	LINE CLEAR AVAIED
4530	24-Jun-24	GULBARGA	220	LINE	LINGASUGUR-BASAVAN BAGEWADI 2	BASAVAN BAGEWADI_220	08:16	17:14	08:58	LINE CLEAR AVAIED
4531	24-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
4532	24-Jun-24	HASSAN	66	LINE	BANDISH-HNPURA	BANDISHETTIHALLI_66	09:15	13:45	04:30	LINE CLEAR AVAIED
4533	24-Jun-24	HASSAN	66	LINE	HNPR2-HNPR1	HNPURA_220	09:00	13:35	04:35	LINE CLEAR AVAIED
4534	24-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR1	HNPURA_220	09:20	09:25	00:05	LINE CLEAR AVAIED
4535	24-Jun-24	HASSAN	66	LINE	HNPR2-RNPR1	HNPURA_220	09:00	13:36	04:36	LINE CLEAR AVAIED
4536	24-Jun-24	HASSAN	66	LINE	HNPR2-RNPR2	HNPURA_220	09:00	13:36	04:36	LINE CLEAR AVAIED
4537	24-Jun-24	HASSAN	66	LINE	HNPURA-HNPR2	HNPURA_66	09:05	13:31	04:26	LINE CLEAR AVAIED
4538	24-Jun-24	HASSAN	66	LINE	HNPURA-RAMNATHPURA	HNPURA_66	09:05	13:31	04:26	LINE CLEAR AVAIED
4539	24-Jun-24	HASSAN	66	TRANSFORMER	HV1	BYACHANAHALLI_66	14:45	15:00	00:15	TRIPPED ON FAULT
4540	24-Jun-24	HASSAN	66	TRANSFORMER	HV1	SBELAGOLA_66	12:45	16:10	03:25	LINE CLEAR AVAIED
4541	24-Jun-24	HASSAN	66	TRANSFORMER	HV2	DUDDA_66	13:08	14:10	01:02	LINE CLEAR AVAIED
4542	24-Jun-24	HASSAN	66	TRANSFORMER	HV2	SBELAGOLA_66	16:00	17:10	01:10	LINE CLEAR AVAIED
4543	24-Jun-24	HASSAN	66	LINE	SBELAG-C R PATNA	SBELAGOLA_66	16:13	16:15	00:02	TRIPPED ON FAULT
4544	24-Jun-24	HASSAN	110	LINE	KADUR-RLW CBreaker	KADUR_220	17:15	17:45	00:30	TRIPPED ON FAULT
4545	24-Jun-24	HASSAN	110	TRANSFORMER	LV2	MSEZ_220	11:33	13:52	02:19	LINE CLEAR AVAIED
4546	24-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	08:54	18:06	09:12	LINE CLEAR AVAIED
4547	24-Jun-24	HASSAN	220	TRANSFORMER	HV2	MSEZ_220	11:33	13:52	02:19	LINE CLEAR AVAIED
4548	24-Jun-24	HASSAN	220	LINE	KAVOOR-KEMR2	KAVOOR_220	10:15	13:43	03:28	LINE CLEAR AVAIED
4549	24-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMSG_220	08:39	18:56	10:17	LINE CLEAR AVAIED
4550	24-Jun-24	HASSAN	220	LINE	MSEZ-KAVOOR2	MSEZ_220	10:15	13:43	03:28	LINE CLEAR AVAIED
4551	24-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	08:39	18:57	10:18	LINE CLEAR AVAIED
4552	24-Jun-24	MYSORE	66	LINE	CHIKKAMANDYA-HAMPAPURA	NO STATIONS EFFECTED	02:53	03:00	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4553	24-Jun-24	MYSORE	66	LINE	HARADANAHALLI-SOMNAHALLI	HARADANAHALLI_66	10:05	10:15	00:10	LINE CLEAR AVAILED
4554	24-Jun-24	MYSORE	66	LINE	HEBBANI-VAJAMANGALA	GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	06:11	06:31	00:20	TRIPPED ON FAULT
4555	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	DODDARAYAPET_66	16:28	16:33	00:05	TRIPPED ON FAULT
4556	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI_66	09:00	09:40	00:40	MAIN SUPPLY FAILURE
4557	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	HARADANAHALLI_66	13:25	13:35	00:10	MAIN SUPPLY FAILURE
4558	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	PERIYAPATNA_66	12:38	13:16	00:38	LINE CLEAR AVAILED
4559	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	SRIRANGAPATNA_66	10:29	12:30	02:00	LINE CLEAR AVAILED
4560	24-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4561	24-Jun-24	MYSORE	66	TRANSFORMER	HV2	DODDARAYAPET_66	16:20	18:31	02:11	LINE CLEAR AVAILED
4562	24-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARADANAHALLI_66	09:00	09:40	00:40	MAIN SUPPLY FAILURE
4563	24-Jun-24	MYSORE	66	TRANSFORMER	HV2	HARADANAHALLI_66	13:25	13:35	00:10	MAIN SUPPLY FAILURE
4564	24-Jun-24	MYSORE	66	TRANSFORMER	HV2	SRIRANGAPATNA_66	12:32	14:03	01:31	LINE CLEAR AVAILED
4565	24-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4566	24-Jun-24	MYSORE	66	LINE	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	07:30	07:41	00:10	TRIPPED ON FAULT
4567	24-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4568	24-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4569	24-Jun-24	MYSORE	66	LINE	NAGAMANGALA 220-B G NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	08:02	08:09	00:07	TRIPPED ON FAULT
4570	24-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
4571	24-Jun-24	MYSORE	66	LINE	SB HALLI-HARIYALDAMMA	HARIYALDAMMATEMPLE_66	20:20	20:40	00:20	TRIPPED ON FAULT
4572	24-Jun-24	MYSORE	66	LINE	SB HALLI-HARIYALDAMMA	HARIYALDAMMATEMPLE_66	21:05	21:20	00:15	TRIPPED ON FAULT
4573	24-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV HOSADURGA LINE	66KV HOSADURGA AND NEERAGUDA GATE	01:40	02:00	00:20	TRIPPED ON FAULT
4574	24-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV HOSADURGA LINE	66KV HOSADURGA AND NEERAGUDA GATE	04:00	04:10	00:10	TRIPPED ON FAULT
4575	24-Jun-24	TUMKUR	66	LINE	66KV KUKKAWADA-66KV BASAVAPATNA LINE	66KV THAVANAGI	08:05	08:20	00:15	TRIPPED ON FAULT
4576	24-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	15:45	16:05	00:20	TRIPPED ON FAULT
4577	24-Jun-24	TUMKUR	66	LINE	66KV MAYAKONDA-66KV SASALUHALLA LINE	66KV SASALUHALLA,CHIKKAJAJUR	14:50	14:55	00:05	TRIPPED ON FAULT
4578	24-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV-HULIYURDURGA	HULIYURDURGA_66, CHOWDANAKUPPE_66	12:28	12:35	00:07	TRIPPED ON FAULT
4579	24-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV-ANCHEPALYA-2	ANCHEPALYA 66KV	12:27	12:34	00:07	TRIPPED ON FAULT
4580	24-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:02	10:07	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4581	24-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	10:07	10:20	00:13	LINE CLEAR AVAILED
4582	24-Jun-24	TUMKUR	66	LINE	THALLAK 220KV -HIRIYUR	SANEKERE_66, THALLAKK_220	16:40	19:34	02:54	LINE CLEAR AVAILED
4583	24-Jun-24	TUMKUR	66	LINE	THALLAK 220-P R PURA	PR PURA_66,MYLANAHALLI_66, V V PURA_66, DYAVARANAHALLI_66	11:20	11:26	00:06	LINE CLEAR AVAILED
4584	24-Jun-24	TUMKUR	110	LINE	110KV DODDAGUNI-SAMPIGE	DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110	13:32	14:17	00:45	LINE CLEAR AVAILED
4585	25-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	TAKKALAKI_110	07:59	08:27	00:28	LINE CLEAR AVAILED
4586	25-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	BIDNAL_220	16:39	17:07	00:28	TRIPPED ON FAULT
4587	25-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GAJENDRAGAD_110	18:02	18:32	00:30	TRIPPED ON FAULT
4588	25-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	GANESHWADI_110	10:57	11:12	00:15	TRIPPED ON FAULT
4589	25-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
4590	25-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
4591	25-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F4-NAVANAGAR-2	BAGALKOT_220	13:53	14:00	00:07	LINE CLEAR AVAILED
4592	25-Jun-24	BAGALKOTE	110	LINE	BASAVANAKATTI- HAVERI220	BASAVANAKATTI_110	12:10	12:50	00:40	LINE CLEAR AVAILED
4593	25-Jun-24	BAGALKOTE	110	LINE	BIDNAL220-NAVALGUND	BIDNAL_220	16:04 (25.06.2024)			TRIPPED ON FAULT
4594	25-Jun-24	BAGALKOTE	110	LINE	GADAG220-GADAG1(BETAGERI)	GADAG_220	11:42	13:49	02:07	LINE CLEAR AVAILED
4595	25-Jun-24	BAGALKOTE	110	LINE	GHATAPRABHA220- PG HUNSHYAL	GHATAPRABHA_220	02:17	02:44	00:27	TRIPPED ON FAULT
4596	25-Jun-24	BAGALKOTE	110	LINE	HATTARAGI-HUKKERI(GHATAPRABHA)	HATTARAGI_110	08:40	08:50	00:10	TRIPPED ON FAULT
4597	25-Jun-24	BAGALKOTE	110	LINE	HIDIKAL DAM- GHATAPRABHA	HIDIKAL DAM_110	08:45	09:03	00:18	LINE CLEAR AVAILED
4598	25-Jun-24	BAGALKOTE	110	LINE	HUBLI- SIRSI(KALGHATAGI)	HUBLI_220	13:22	14:47	01:25	LINE CLEAR AVAILED
4599	25-Jun-24	BAGALKOTE	110	LINE	KALGHATAGI- ASPL SOLAR	KALGHATAGI_110	19:34	20:35	01:01	LINE CLEAR AVAILED
4600	25-Jun-24	BAGALKOTE	110	LINE	KALGHATAGI- HUBLI220	KALGHATAGI_110	13:20	14:50	01:30	LINE CLEAR AVAILED
4601	25-Jun-24	BAGALKOTE	110	LINE	MAHALINGA220- TERDAL	MAHALINGAPUR_220	14:57	15:56	00:59	TRIPPED ON FAULT
4602	25-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4603	25-Jun-24	BAGALKOTE	110	LINE	MUDDEBIHAL-KNMSOLAR(HIREMURAL)	MUDDEBIHAL_110	19:28	19:37	00:09	TRIPPED ON FAULT
4604	25-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL	NAVALGUND_110	16:04 (25.06.2024)			TRIPPED ON FAULT
4605	25-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEKENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4606	25-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
4607	25-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4608	25-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
4609	25-Jun-24	BAGALKOTE	110	LINE	TALIKOT- FPPL SOLAR	TALIKOT_110	01:53	02:01	00:08	LINE CLEAR AVAILED
4610	25-Jun-24	BAGALKOTE	110	LINE	TERDAL- KUDACHI220	TERDAL_110	8:01 (04.06.2024)			LINE CLEAR AVAILED
4611	25-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
4612	25-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4613	25-Jun-24	BAGALKOTE	220	LINE	AMBEWADI- NARENDRA2	AMBEWADI_220	12:15	15:50	03:35	LINE CLEAR AVAILED
4614	25-Jun-24	BAGALKOTE	220	LINE	SIRSI- SHARAVATHI2	SIRSI_220	13:39	16:56	03:17	TRIPPED ON FAULT
4615	25-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4616	25-Jun-24	BANGALORE	66	LINE	66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE	12:15	12:37	00:22	LINE CLEAR AVAILED
4617	25-Jun-24	BANGALORE	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 1)	ELECTRONIC CITY, INFOSYS, HULIMANGALA	08:50	08:55	00:05	LINE CLEAR AVAILED
4618	25-Jun-24	BANGALORE	66	LINE	66KV ELECTRONIC CITY - ELECTRONIC CITY PH2 SEC 2 (MALGUDI 2)	ELECTRONIC CITY PH2 SEC 2, HUSKUR	08:41	09:00	00:19	LINE CLEAR AVAILED
4619	25-Jun-24	BANGALORE	66	LINE	66KV HSR 220 - COREMIND JAKKASANDRA	JAKKASANDRA	10:15	14:34	04:19	LINE CLEAR AVAILED
4620	25-Jun-24	BANGALORE	66	LINE	66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]	ARMY WELFARE HOUSING ORGANISATION	13:24	13:30	00:06	LINE CLEAR AVAILED
4621	25-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI	CHIKKENAHALLI, SHIVANAHALLI	14:22	14:27	00:05	MAIN SUPPLY FAILURE
4622	25-Jun-24	BANGALORE	66	LINE	66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI	DODDALAHALLI	12:55	13:30	00:35	LINE CLEAR AVAILED
4623	25-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	10:14	14:58	04:44	LINE CLEAR AVAILED
4624	25-Jun-24	BANGALORE	66	LINE	66KV KUDUMULAKUNTE - THERIYUR	THERIYUR	17:59	18:15	00:16	TRIPPED ON FAULT
4625	25-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	ADDAGAL, RAYALPADU, GOWNIPALLI	16:01	16:31	00:30	LINE CLEAR AVAILED
4626	25-Jun-24	BANGALORE	66	LINE	66KV SAHAKARANAGARA 66 - L&T REALTY BYATARAYANAPURA	BYATARAYANAPURA	15:51	15:58	00:07	LINE CLEAR AVAILED
4627	25-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	15:49	15:55	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4628	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, JIGANI LINK ROAD	17:54	18:30	00:36	LINE CLEAR AVAILED
4629	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	17:54	18:33	00:39	LINE CLEAR AVAILED
4630	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - KAGGALIPURA (BRIGADE MEADOWS)	BRIGADE MEADOWS	17:53	18:28	00:35	MAIN SUPPLY FAILURE
4631	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	RBI, SOUTH CITY	17:54	18:32	00:38	LINE CLEAR AVAILED
4632	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SAINT GOBIN - BHURUKA GAS - ORCHID LAMINTES 1 - A.O SMITH - ORCHID LAMINATES-2	SAINT GOBIN, BHURUKA, AO SMITH, ORCHID LAMINATES 2	17:54	18:33	00:39	LINE CLEAR AVAILED
4633	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - SANJEEVANADODDI	SANJEEVANADODDI	17:54	18:33	00:39	LINE CLEAR AVAILED
4634	25-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - YEDAMADU	YEDUMADU, HANUMANTHAGARA	17:54	18:33	00:39	LINE CLEAR AVAILED
4635	25-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	BANGARPETE,KGF,BEML, KAMASAMUDRA	11:05	11:22	00:17	TRIPPED ON FAULT
4636	25-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	BANGARPETE,KGF,BEML, KAMASAMUDRA, BANGARPETE	11:27	11:31	00:04	TRIPPED ON FAULT
4637	25-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	BANGARPETE,KGF,BEML, KAMASAMUDRA, BANGARPETE	06:20	06:44	00:24	TRIPPED ON FAULT
4638	25-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	BANGARPETE,KGF,BEML, KAMASAMUDRA	11:05	11:22	00:17	TRIPPED ON FAULT
4639	25-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	BANGARPETE,KGF,BEML, KAMASAMUDRA, BANGARPETE	06:20	06:44	00:24	TRIPPED ON FAULT
4640	25-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALURU, YETHAMBADI	10:50	12:55	02:05	LINE CLEAR AVAILED
4641	25-Jun-24	BANGALORE	66	LINE	66KV VRUSHBHAVATHI 220 - CHANDRA LAYOUT	CHANDRA LAYOUT	10:03	16:36	06:33	LINE CLEAR AVAILED
4642	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BYATARAYANAPURA	11:01	11:06	00:05	LINE CLEAR AVAILED
4643	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HBR LAYOUT 66	12:13	15:45	03:32	LINE CLEAR AVAILED
4644	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHANDRA LAYOUT	10:03	16:40	06:37	LINE CLEAR AVAILED
4645	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SOMANAHALLI 220	17:51	18:28	00:37	LINE CLEAR AVAILED
4646	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BOMMEPALLI CROSS	10:55	12:00	01:05	LINE CLEAR AVAILED
4647	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BURUDAGUNTE	17:05	18:20	01:15	LINE CLEAR AVAILED
4648	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YENNIGADALE	14:15	14:17	00:02	LINE CLEAR AVAILED
4649	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	LAKSHMIPURA	15:57	16:25	00:28	LINE CLEAR AVAILED
4650	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	RAYALPADU	17:45	18:30	00:45	LINE CLEAR AVAILED
4651	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	01:30	01:45	00:15	TRIPPED ON FAULT
4652	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KGF	17:15	17:20	00:05	LINE CLEAR AVAILED
4653	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	14:35	14:40	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4654	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HOSPALYA CIRCLE	16:40	18:30	01:50	TRIPPED ON FAULT
4655	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	IGGALUR	10:00	15:00	05:00	LINE CLEAR AVAILED
4656	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ATTIBELE	03:55	04:00	00:05	TRIPPED ON FAULT
4657	25-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ATTIBELE	13:25	13:45	00:20	LINE CLEAR AVAILED
4658	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYATARAYANAPURA	12:23	12:27	00:04	LINE CLEAR AVAILED
4659	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HBR LAYOUT 66	12:13	15:45	03:32	LINE CLEAR AVAILED
4660	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	CHANDRA LAYOUT	10:03	16:40	06:37	LINE CLEAR AVAILED
4661	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SOMANAHALLI 220	17:51	18:28	00:37	LINE CLEAR AVAILED
4662	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YENNIGADALE	15:18	15:20	00:02	LINE CLEAR AVAILED
4663	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	RAYALPADU	17:45	18:30	00:45	LINE CLEAR AVAILED
4664	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KGF	17:35	17:50	00:15	LINE CLEAR AVAILED
4665	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HAROBELE	17:00	17:05	00:05	LINE CLEAR AVAILED
4666	25-Jun-24	BANGALORE	66	TRANSFORMER	HV2	IGGALUR	10:00	15:00	05:00	LINE CLEAR AVAILED
4667	25-Jun-24	BANGALORE	66	TRANSFORMER	HV3	BYATARAYANAPURA	13:35	13:40	00:05	LINE CLEAR AVAILED
4668	25-Jun-24	BANGALORE	66	TRANSFORMER	HV3	HBR LAYOUT 66	10:58	12:45	01:47	LINE CLEAR AVAILED
4669	25-Jun-24	BANGALORE	66	TRANSFORMER	HV3	KGF	17:05	17:15	00:10	LINE CLEAR AVAILED
4670	25-Jun-24	BANGALORE	66	TRANSFORMER	HV3	IGGALUR	10:00	15:00	05:00	LINE CLEAR AVAILED
4671	25-Jun-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DB PURA 1	NO STATION AFFECTED	15:07	17:28	02:21	LINE CLEAR AVAILED
4672	25-Jun-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - DB PURA 2	NO STATION AFFECTED	10:25	15:00	04:35	LINE CLEAR AVAILED
4673	25-Jun-24	BANGALORE	220	LINE	220KV NELAMANGALA 400 - MAGADI CKT 2	NO STATION AFFECTED	11:13	12:35	01:22	LINE CLEAR AVAILED
4674	25-Jun-24	BANGALORE	220	TRANSFORMER	HV1	SOMANAHALLI 220	17:57	18:24	00:27	LINE CLEAR AVAILED
4675	25-Jun-24	BANGALORE	220	TRANSFORMER	HV3	SOMANAHALLI 220	17:57	18:24	00:27	LINE CLEAR AVAILED
4676	25-Jun-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	BANVEKAL_66,ABRSL IPP,SOLARS IPP	14:27	14:35	00:08	TRIPPED ON FAULT
4677	25-Jun-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	BANVEKAL_66,ABRSL IPP,SOLARS IPP	14:35	14:40	00:05	TRIPPED ON FAULT
4678	25-Jun-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	BANVEKAL_66,ABRSL IPP,SOLARS IPP	14:35	15:00	00:25	TRIPPED ON FAULT
4679	25-Jun-24	GULBARGA	66	TRANSFORMER	HV1,HV2	BANVEKAL_66	14:35	14:45	00:10	TRIPPED ON FAULT
4680	25-Jun-24	GULBARGA	66	TRANSFORMER	HV2	CJ.HALLI_66	06:45	06:50	00:05	TRIPPED ON FAULT
4681	25-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	07:00	07:10	00:10	TRIPPED ON FAULT
4682	25-Jun-24	GULBARGA	66	LINE	KUDALGI-CHOORNUR	CHOORNUR_66	10:30	14:10	03:40	LINE CLEAR AVAILED
4683	25-Jun-24	GULBARGA	66	LINE	TELGI-YARGUNTA	OBJ HALLI_66	06:50	07:00	00:10	TRIPPED ON FAULT
4684	25-Jun-24	GULBARGA	110	TRANSFORMER	HV2	HANUMASAGAR_110	08:15	12:15	04:00	LINE CLEAR AVAILED
4685	25-Jun-24	GULBARGA	110	LINE	JAWALGERA-VALABALLARI	JAWALGERA_110, WALABALLARI_110	00:48	01:00	00:12	TRIPPED ON FAULT
4686	25-Jun-24	GULBARGA	110	LINE	KAONOR-KAPNOR	KAPNOR_110	09:36	13:35	03:59	LINE CLEAR AVAILED
4687	25-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	RAILWAY_110	19:15	19:22	00:07	TRIPPED ON FAULT
4688	25-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	RAILWAY_110	21:55	22:15	00:20	TRIPPED ON FAULT
4689	25-Jun-24	GULBARGA	110	LINE	MALLAT-KAVITAL	KAVITAL_110	12:43	17:58	05:15	LINE CLEAR AVAILED
4690	25-Jun-24	GULBARGA	110	LINE	MALLAT-SIRWAR	SIRWAR_110	02:50	02:58	00:08	TRIPPED ON FAULT
4691	25-Jun-24	GULBARGA	110	LINE	MUNIRABAD-MALLAPUR	KEREHALLI_110	10:15	15:18	05:03	LINE CLEAR AVAILED
4692	25-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	8:52(25.06.2024)			LINE CLEAR AVAILED
4693	25-Jun-24	GULBARGA	110	LINE	SHAHPUR-NAGNOR	NAGNOR_110	02:57	03:04	00:07	TRIPPED ON FAULT
4694	25-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	23:59	00:14	00:15HRS	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4695	25-Jun-24	GULBARGA	220	LINE	KAPNOOR-HUMNABAD	KAPNOOR_220	11:55	15:37	03:42	LINE CLEAR AVAIED
4696	25-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
4697	25-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHBAD_220	16:52	17:40	00:48	TRIPPED ON FAULT
4698	25-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHBAD_220	17:40	20:40	03:00	LINE CLEAR AVAIED
4699	25-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHBAD_220	16:52	20:41	03:49	TRIPPED ON FAULT
4700	25-Jun-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	13:28	14:28	01:00	TRIPPED ON FAULT
4701	25-Jun-24	HASSAN	66	LINE	ALDUR-BALEHONNUR	ALDUR_66	14:35	14:50	00:15	TRIPPED ON FAULT
4702	25-Jun-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	13:28	14:28	01:00	TRIPPED ON FAULT
4703	25-Jun-24	HASSAN	66	LINE	BALEHN-JENUGADDE1	BALEHONNUR_66	13:28	15:02	01:34	MAIN SUPPLY FAILURE
4704	25-Jun-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONNUR_66	13:28	15:02	01:34	MAIN SUPPLY FAILURE
4705	25-Jun-24	HASSAN	66	TRANSFORMER	HV1	DIDIGA_66	11:30	13:20	01:50	LINE CLEAR AVAIED
4706	25-Jun-24	HASSAN	66	TRANSFORMER	HV1	MAGGE_66	17:29	17:40	00:11	TRIPPED ON FAULT
4707	25-Jun-24	HASSAN	66	TRANSFORMER	HV1	YESLUR_66	11:44	12:51	01:07	LINE CLEAR AVAIED
4708	25-Jun-24	HASSAN	66	TRANSFORMER	HV2	DIDIGA_66	13:15	14:20	01:05	LINE CLEAR AVAIED
4709	25-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESH PURA_66	07:00	07:10	00:10	TRIPPED ON FAULT
4710	25-Jun-24	HASSAN	66	TRANSFORMER	HV2	SAKALESH PURA_66	07:20	07:30	00:10	TRIPPED ON FAULT
4711	25-Jun-24	HASSAN	66	TRANSFORMER	HV2	UDAYAPURA_66	09:45	17:00	07:15	TRIPPED ON FAULT
4712	25-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON1	UDDURKOPPLU_66	06:27	06:40	00:13	TRIPPED ON FAULT
4713	25-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON2	UDDURKOPPLU_66	06:27	06:42	00:15	TRIPPED ON FAULT
4714	25-Jun-24	HASSAN	66	LINE	YESLUR-SNVRST	YESLUR_66	11:46	12:51	01:05	LINE CLEAR AVAIED
4715	25-Jun-24	HASSAN	110	TRANSFORMER	HV1	ARASIKERE-220	11:06	14:31	03:25	LINE CLEAR AVAIED
4716	25-Jun-24	HASSAN	110	TRANSFORMER	HV1	HULICAL_110	11:36	12:47	01:11	LINE CLEAR AVAIED
4717	25-Jun-24	HASSAN	110	TRANSFORMER	HV2	HOSANGADI_110	11:57	13:12	01:15	LINE CLEAR AVAIED
4718	25-Jun-24	HASSAN	110	LINE	KADUR-NERELEKERE	KADUR_220	17:43	18:40	00:57	TRIPPED ON FAULT
4719	25-Jun-24	HASSAN	110	LINE	KARAYA-PUTTUR	KARAYA_110	11:00	14:19	03:19	LINE CLEAR AVAIED
4720	25-Jun-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	12:07	13:41	01:34	LINE CLEAR AVAIED
4721	25-Jun-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	15:06	16:01	00:55	LINE CLEAR AVAIED
4722	25-Jun-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	15:06	16:01	00:55	LINE CLEAR AVAIED
4723	25-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	13:19	13:22	00:03	LINE CLEAR AVAIED
4724	25-Jun-24	HASSAN	110	LINE	KONAJE-MANJESWARG	KONAJE_110	15:07	15:14	00:07	LINE CLEAR AVAIED
4725	25-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	13:19	13:22	00:03	LINE CLEAR AVAIED
4726	25-Jun-24	HASSAN	110	LINE	KONAJE-SALATHUR	KONAJE_110	15:07	15:14	00:07	LINE CLEAR AVAIED
4727	25-Jun-24	HASSAN	110	TRANSFORMER	LV1	ARASIKERE-220	10:25	15:05	04:40	LINE CLEAR AVAIED
4728	25-Jun-24	HASSAN	110	TRANSFORMER	LV1	MRS MG_220	08:39	17:38	08:59	LINE CLEAR AVAIED
4729	25-Jun-24	HASSAN	110	TRANSFORMER	LV2	KEMAR_220	10:25	17:42	07:17	LINE CLEAR AVAIED
4730	25-Jun-24	HASSAN	110	LINE	MADHUV-BRK_MDV CBreaker	MADHUVANA_110	14:41	17:18	02:37	TRIPPED ON FAULT
4731	25-Jun-24	HASSAN	110	LINE	MADHUV-HIRIYADKA	MADHUVANA_110	14:42	17:20	02:38	TRIPPED ON FAULT
4732	25-Jun-24	HASSAN	110	LINE	MANIPAL-KEMAR1	MANIPAL_110	12:08	13:41	01:33	MAIN SUPPLY FAILURE
4733	25-Jun-24	HASSAN	110	LINE	MOODAB-GURUPURA	MOODABIDRE_110	10:56	13:36	02:40	LINE CLEAR AVAIED
4734	25-Jun-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	09:51	11:53	02:02	LINE CLEAR AVAIED
4735	25-Jun-24	HASSAN	110	LINE	PUTTUR-SLTR	PUTTUR_220	14:21	15:52	01:31	LINE CLEAR AVAIED
4736	25-Jun-24	HASSAN	110	LINE	PUTTUR-SULIA	PUTTUR_220	10:30	15:41	05:11	LINE CLEAR AVAIED
4737	25-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	13:30	13:39	00:09	MAIN SUPPLY FAILURE
4738	25-Jun-24	HASSAN	110	LINE	SALATHU-BNTWAL	SALATHUR_110	14:40	14:53	00:13	MAIN SUPPLY FAILURE
4739	25-Jun-24	HASSAN	110	LINE	SORABA-SHR220	SORABA_110	06:35	08:10	01:35	MAIN SUPPLY FAILURE
4740	25-Jun-24	HASSAN	110	LINE	SORABA-SHR220	SORABA_110	08:15	12:36	04:21	LINE CLEAR AVAIED
4741	25-Jun-24	HASSAN	220	LINE	GOPALAP-BASTIPURA	GOPALAPURA_220	09:47	17:52	08:05	LINE CLEAR AVAIED
4742	25-Jun-24	HASSAN	220	LINE	GOPALAP-HNPUR21	GOPALAPURA_220	12:00	15:13	03:13	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4743	25-Jun-24	HASSAN	220	LINE	GOPALAP-HNPUR22	GOPALAPURA_220	10:21	11:47	01:26	LINE CLEAR AVAILED
4744	25-Jun-24	HASSAN	220	LINE	HGUNJE-VRH	HEGGUNJE_220	10:03	14:44	04:41	LINE CLEAR AVAILED
4745	25-Jun-24	HASSAN	220	LINE	HNPR2-GPLPR1	HNPURA_220	12:01	15:14	03:13	LINE CLEAR AVAILED
4746	25-Jun-24	HASSAN	220	LINE	HNPR2-GPLPR2	HNPURA_220	10:22	11:49	01:27	LINE CLEAR AVAILED
4747	25-Jun-24	HASSAN	220	TRANSFORMER	HV1	MRSMSG_220	08:39	17:19	08:40	LINE CLEAR AVAILED
4748	25-Jun-24	HASSAN	220	TRANSFORMER	HV1	ARASIKERE-220	10:25	15:05	04:40	LINE CLEAR AVAILED
4749	25-Jun-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	10:25	17:42	07:17	LINE CLEAR AVAILED
4750	25-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	10:30	13:36	03:06	LINE CLEAR AVAILED
4751	25-Jun-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	14:53	16:49	01:56	LINE CLEAR AVAILED
4752	25-Jun-24	HASSAN	220	LINE	KEMAR-Varahi2	KEMAR_220	16:50	18:02	01:12	LINE CLEAR AVAILED
4753	25-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR2	MSEZ_220	10:31	13:37	03:06	LINE CLEAR AVAILED
4754	25-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	14:53	16:49	01:56	LINE CLEAR AVAILED
4755	25-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR2	gen_varahi	16:50	18:02	01:12	LINE CLEAR AVAILED
4756	25-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR3	gen_varahi	10:03	14:46	04:43	LINE CLEAR AVAILED
4757	25-Jun-24	MYSORE	66	LINE	BOGADHI-HOOTAGALLI	NO STATIONS EFFECTED	07:33	07:36	00:03	LINE CLEAR AVAILED
4758	25-Jun-24	MYSORE	66	LINE	BYLUKUPPE-KUSHALNAGARA	BYLUKUPPE_66	11:25	12:37	01:12	LINE CLEAR AVAILED
4759	25-Jun-24	MYSORE	66	LINE	DATAGALLI-HOOTAGALLI	NO STATIONS EFFECTED	12:49	13:09	00:20	LINE CLEAR AVAILED
4760	25-Jun-24	MYSORE	66	LINE	GARUDANAUKKADA-TUBINAKERE	NO STATIONS EFFECTED	12:37	12:42	00:05	LINE CLEAR AVAILED
4761	25-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 3	NO STATIONS EFFECTED	16:41	17:06	00:25	TRIPPED ON FAULT
4762	25-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 3	NO STATIONS EFFECTED	17:36	17:39	00:03	LINE CLEAR AVAILED
4763	25-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 4	NO STATIONS EFFECTED	17:36	17:39	00:03	LINE CLEAR AVAILED
4764	25-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 4	NO STATIONS EFFECTED	16:41	17:07	00:26	TRIPPED ON FAULT
4765	25-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 5	NO STATIONS EFFECTED	16:41	17:08	00:27	TRIPPED ON FAULT
4766	25-Jun-24	MYSORE	66	LINE	HOOTAGALLI-BANNIMANTAP 1	NO STATIONS EFFECTED	09:50	11:14	01:23	LINE CLEAR AVAILED
4767	25-Jun-24	MYSORE	66	LINE	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	10:30	11:56	01:26	LINE CLEAR AVAILED
4768	25-Jun-24	MYSORE	66	LINE	HOOTAGALLI-KHB	NO STATIONS EFFECTED	12:47	15:04	02:16	LINE CLEAR AVAILED
4769	25-Jun-24	MYSORE	66	TRANSFORMER	HV1	HOSURGATE_66	14:45	15:10	00:25	LINE CLEAR AVAILED
4770	25-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
4771	25-Jun-24	MYSORE	66	TRANSFORMER	HV2	BYLUKUPPE_66	14:14	20:00	05:46	LINE CLEAR AVAILED
4772	25-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
4773	25-Jun-24	MYSORE	66	LINE	KHB STATION-BILIKERE	DMG_HALLI_66	11:57	12:13	00:16	TRIPPED ON FAULT
4774	25-Jun-24	MYSORE	66	LINE	KK DODDI-TK HALLI	NO STATIONS EFFECTED	12:41	13:00	00:18	LINE CLEAR AVAILED
4775	25-Jun-24	MYSORE	66	LINE	KUSHALNAGARA-MUTHINA MULUSOGE	NO STATIONS EFFECTED	17:42	17:52	00:10	TRIPPED ON FAULT
4776	25-Jun-24	MYSORE	66	LINE	KUSHALNAGARA-RAMANATHAPURA	ALUR SIDDAPUR_66KANAGAL_66CB HALLI_66RUDRAPATNA_66	03:08	03:34	00:26	TRIPPED ON FAULT
4777	25-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
4778	25-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
4779	25-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
4780	25-Jun-24	MYSORE	66	LINE	SFC SIVA-PGCL	NO STATIONS EFFECTED	16:41	17:10	00:29	TRIPPED ON FAULT
4781	25-Jun-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	16:42	16:46	00:03	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4782	25-Jun-24	MYSORE	66	LINE	VAJMANGALA-BANNUR	BANNUR_66	09:29	09:33	00:04	TRIPPED ON FAULT
4783	25-Jun-24	MYSORE	66	LINE	VAJMANGALA-BANNUR	BANNUR_66	15:06	15:08	00:02	TRIPPED ON FAULT
4784	25-Jun-24	MYSORE	66	LINE	YETHAMBADI-TK HALLI	YETHAMBADI_66	10:40	12:57	02:17	LINE CLEAR AVAIED
4785	25-Jun-24	MYSORE	220	TRANSFORMER	HOOTAGALLI-HV3	NO STATIONS EFFECTED	13:12	14:45	01:32	LINE CLEAR AVAIED
4786	25-Jun-24	MYSORE	220	LINE	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	11:35	19:18	07:43	LINE CLEAR AVAIED
4787	25-Jun-24	MYSORE	220	LINE	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	10:06	17:51	07:45	LINE CLEAR AVAIED
4788	25-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR,MALEBENNUR,DEVARBELAKERE	14:30	14:40	00:10	TRIPPED ON FAULT
4789	25-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	11:07	11:18	00:11	TRIPPED ON FAULT
4790	25-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NYAMATHI LINE	66KV NYAMATHI,SAVALANGA,CHILUR	14:35	14:45	00:10	TRIPPED ON FAULT
4791	25-Jun-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE-2	66KV CHITRAHALLI, HD PURA	14:02	14:12	00:10	TRIPPED ON FAULT
4792	25-Jun-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE-2	66KV CHITRAHALLI, HD PURA	14:24	14:47	00:23	TRIPPED ON FAULT
4793	25-Jun-24	TUMKUR	66	LINE	66KV KUKKAWADA-66KV BASAVAPATNA LINE	66KV THAVANAGI	13:15	13:22	00:07	TRIPPED ON FAULT
4794	25-Jun-24	TUMKUR	66	LINE	CHIKKAJAJUR-HOLALKERE-1	CHIKKAJAJUR_66	15:55	16:05	00:10	MAIN SUPPLY FAILURE
4795	25-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-PANDARAHALLI 2	SIRIGERE_66, BHARAMSAGARA_66, VIJAPURA_66, KNNL	15:59	16:38	00:39	LINE CLEAR AVAIED
4796	25-Jun-24	TUMKUR	66	LINE	DAVANGERE SRS-AVAREGERE66	AVAREGERE_66	10:41	14:57	04:16	LINE CLEAR AVAIED
4797	25-Jun-24	TUMKUR	66	LINE	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	15:55	16:05	00:10	MAIN SUPPLY FAILURE
4798	25-Jun-24	TUMKUR	66	LINE	THALLAK 220KV- THALLAK	THALLAK_66	10:08	16:52	06:44	LINE CLEAR AVAIED
4799	25-Jun-24	TUMKUR	220	LINE	THALLAK 220KV - BARC 1	BARC 1	10:32	16:38	06:06	LINE CLEAR AVAIED
4800	25-Jun-24	TUMKUR	220	TRANSFORMER	TR-2(100MVA)	ANCHEPALYA2	12:46	15:13	02:27	LINE CLEAR AVAIED
4801	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1&HV2(10MVA)	MALGHAN(S)_110	10:10	16:50	06:40	LINE CLEAR AVAIED
4802	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	BASAVANAKATTI_110	16:29	16:38	00:09	LINE CLEAR AVAIED
4803	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	GADAG_110	19:54	20:12	00:18	TRIPPED ON FAULT
4804	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	HALIYAL_110	17:06	17:55	00:49	LINE CLEAR AVAIED
4805	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	NAVALAGI_110	13:26	13:34	00:08	TRIPPED ON FAULT
4806	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ZALKI_110	10:03	10:10	00:07	TRIPPED ON FAULT
4807	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ZALKI_110	10:46	10:55	00:09	TRIPPED ON FAULT
4808	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ZALKI_110	11:05	11:18	00:13	TRIPPED ON FAULT
4809	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	ZALKI_110	05:38	05:42	00:04	TRIPPED ON FAULT
4810	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	BASAVANAKATTI_110	16:29	16:38	00:09	LINE CLEAR AVAIED
4811	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4(10MVA)	BAGALKOT_220	16:24	18:46	02:22	LINE CLEAR AVAIED
4812	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIRSI_220	11:06	11:43	00:37	LINE CLEAR AVAIED
4813	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(10MVA)	SIRSI_220	11:48	12:21	00:33	LINE CLEAR AVAIED
4814	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	GAJENDRAGAD_110	16:37	18:23	01:46	TRIPPED ON FAULT
4815	26-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3(10MVA)	SHIGGOAN_110	16:04	16:10	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4816	26-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
4817	26-Jun-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-1 (104)	AHERI_220	05:35	05:45	00:10	TRIPPED ON FAULT
4818	26-Jun-24	BAGALKOTE	110	LINE	ATHANI220-GHATANATTI	ATHANI_220	21:00	21:10	00:10	TRIPPED ON FAULT
4819	26-Jun-24	BAGALKOTE	110	LINE	ATHANI220-GHATANATTI	ATHANI_220	21:58	22:11	00:13	TRIPPED ON FAULT
4820	26-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
4821	26-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	04:33	04:44	00:11	TRIPPED ON FAULT
4822	26-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F7-RAMDURG	BAGALKOT_220	15:33	18:24	02:51	LINE CLEAR AVAILED
4823	26-Jun-24	BAGALKOTE	110	LINE	BIDNAL220-NAVALGUND	BIDNAL_220	16:04 (25.06.2024)	9:24 (26.06.2024)	17:20	TRIPPED ON FAULT
4824	26-Jun-24	BAGALKOTE	110	LINE	CHIKKODI220- BHOJ(NANADI)	CHIKKODI_220	11:22	14:02	02:43	LINE CLEAR AVAILED
4825	26-Jun-24	BAGALKOTE	110	LINE	HIREBEVNUR-INDI-LACHYAN(RODAGI)	HIREBEVNUR_110	11:44	13:49	02:05	LINE CLEAR AVAILED
4826	26-Jun-24	BAGALKOTE	110	LINE	MALGHAN(S)- MANALI SUGARS	MALGHAN(S)_110	10:10	16:50	06:40	LINE CLEAR AVAILED
4827	26-Jun-24	BAGALKOTE	110	LINE	MALGHAN(S)- MORATAGI	MALGHAN(S)_110	10:10	16:50	06:40	LINE CLEAR AVAILED
4828	26-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4829	26-Jun-24	BAGALKOTE	110	LINE	NAREGAL- BETAGERI	NAREGAL_110	17:11	17:53	00:42	LINE CLEAR AVAILED
4830	26-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL	NAVALGUND_110	16:04 (25.06.2024)			TRIPPED ON FAULT
4831	26-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
4832	26-Jun-24	BAGALKOTE	110	LINE	SIRSI- KAVALWADA(EASLE2)	SIRSI_110	13:47	14:12	00:25	TRIPPED ON FAULT
4833	26-Jun-24	BAGALKOTE	110	LINE	SIRSI- KAVALWADA(EASLE2)	SIRSI_110	16:27	17:12	00:45	LINE CLEAR AVAILED
4834	26-Jun-24	BAGALKOTE	110	LINE	SIRSI220- SIRSI2	SIRSI_220	13:48	14:08	00:20	TRIPPED ON FAULT
4835	26-Jun-24	BAGALKOTE	110	LINE	SIRSI220- SIRSI2	SIRSI_220	16:26	17:12	00:46	LINE CLEAR AVAILED
4836	26-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)			LINE CLEAR AVAILED
4837	26-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
4838	26-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
4839	26-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
4840	26-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
4841	26-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1(110MVA)	SOUDATTI_220	12:09	13:26	01:17	LINE CLEAR AVAILED
4842	26-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2(110MVA)	SOUDATTI_220	14:09	14:53	00:44	LINE CLEAR AVAILED
4843	26-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3(110MVA)	SOUDATTI_220	15:04	16:04	01:00	LINE CLEAR AVAILED
4844	26-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
4845	26-Jun-24	BANGALORE	66	LINE	66KV AERO SPACE 220 - BOEING (EHT)	BOEING(EHT)	07:01	10:34	03:33	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4846	26-Jun-24	BANGALORE	66	LINE	66KV AGALAKOTE - MATHIKERE	MATHIKERE	10:00	16:35	06:35	LINE CLEAR AVAILED
4847	26-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	JIGANI LINK ROAD	05:48	06:02	00:14	TRIPPED ON FAULT
4848	26-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	JIGANI LINK ROAD	10:25	10:28	00:03	LINE CLEAR AVAILED
4849	26-Jun-24	BANGALORE	66	LINE	66KV BIAL BEGUR 220 - VIDYANAGARA	VIDYANAGARA	07:03	07:07	00:04	LINE CLEAR AVAILED
4850	26-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1	NO STATION AFFECTED	15:37	23:59	08:22	TRIPPED ON FAULT
4851	26-Jun-24	BANGALORE	66	LINE	66KV BRINDAVANA 220 - NELAKADARANAHALLI	PRESTIGE JINDAL CITY, WIDIA, NELAKADRENAHALLI	15:20	15:45	00:25	LINE CLEAR AVAILED
4852	26-Jun-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	12:07	12:12	00:05	TRIPPED ON FAULT
4853	26-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	11:03	11:06	00:03	LINE CLEAR AVAILED
4854	26-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	15:52	15:55	00:03	LINE CLEAR AVAILED
4855	26-Jun-24	BANGALORE	66	LINE	66KV MAGADI 220 - MAGADI - HOSPALYA - ANCHEPALYA	MAGADI 66, HOSPALYA CIRCLE	12:07	12:29	00:22	TRIPPED ON FAULT
4856	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	RMZ	11:54	11:58	00:04	LINE CLEAR AVAILED
4857	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUNDAMGERE	11:38	11:43	00:05	TRIPPED ON FAULT
4858	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KEMBODI	15:40	18:40	03:00	TRIPPED ON FAULT
4859	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SRINIVASAPURA 66	08:40	10:25	01:45	LINE CLEAR AVAILED
4860	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	TADIGOLU CROSS	15:22	15:48	00:26	LINE CLEAR AVAILED
4861	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOKKALERI	11:45	12:40	00:55	LINE CLEAR AVAILED
4862	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KGF	21:58	22:30	00:32	TRIPPED ON FAULT
4863	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KODIHALLI(KANAKAPURA)	13:15	13:20	00:05	LINE CLEAR AVAILED
4864	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 66	06:15	06:32	00:17	LINE CLEAR AVAILED
4865	26-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KUMBARANAHALLI	11:34	11:42	00:08	TRIPPED ON FAULT
4866	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	RMZ	13:02	13:05	00:03	LINE CLEAR AVAILED
4867	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	JADIGENAHALLI	15:00	16:00	01:00	LINE CLEAR AVAILED
4868	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KEMBODI	14:25	16:40	02:15	TRIPPED ON FAULT
4869	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SRINIVASAPURA 66	06:00	08:40	02:40	TRIPPED ON FAULT
4870	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	HAROHALLI I/A 220	11:10	15:40	04:30	LINE CLEAR AVAILED
4871	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KODIHALLI(KANAKAPURA)	11:05	11:10	00:05	LINE CLEAR AVAILED
4872	26-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TYAMAGONDLU	09:05	10:15	01:10	TRIPPED ON FAULT
4873	26-Jun-24	BANGALORE	66	TRANSFORMER	HV3	RMZ	14:28	14:30	00:02	LINE CLEAR AVAILED
4874	26-Jun-24	BANGALORE	66	LINE	KIADB HARDWARE PARK 220 - VIDYANAGARA 1	VIDYANAGARA	10:45	10:50	00:05	LINE CLEAR AVAILED
4875	26-Jun-24	BANGALORE	220	LINE	220KV KIADB DEVANAHALLI HP 220 - AERO SPACE 220	AERO SPACE 220	07:01	10:34	03:33	LINE CLEAR AVAILED
4876	26-Jun-24	BANGALORE	220	TRANSFORMER	HV2	HAROHALLI I/A 220	11:10	15:40	04:30	LINE CLEAR AVAILED
4877	26-Jun-24	GULBARGA	66	LINE	BADALADUKU-UJJINI	UJJINI_66	10:00	10:20	00:20	MAIN SUPPLY FAILURE
4878	26-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	13:22	13:35	00:13	TRIPPED ON FAULT
4879	26-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BENNEHALLI_66	10:55	12:55	02:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4880	26-Jun-24	GULBARGA	66	LINE	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66, HOLAGUNDI_66	12:55	13:04	00:09	TRIPPED ON FAULT
4881	26-Jun-24	GULBARGA	110	LINE	HANAWAL-MARALIHALLA	YARADONA_110	22:25	22:35	00:10	MAIN SUPPLY FAILURE
4882	26-Jun-24	GULBARGA	110	LINE	HUMNABAD-HALLIKHED	HALLIKHED_110	09:10	16:55	07:45	LINE CLEAR AVOIDED
4883	26-Jun-24	GULBARGA	110	TRANSFORMER	HV1	SOMASAMUDRA_110	10:54	11:05	00:11	TRIPPED ON FAULT
4884	26-Jun-24	GULBARGA	110	TRANSFORMER	HV1	MUNIRABAD_220	17:46	17:55	00:09	TRIPPED ON FAULT
4885	26-Jun-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	14:42	15:04	00:22	LINE CLEAR AVOIDED
4886	26-Jun-24	GULBARGA	110	TRANSFORMER	HV2	CHICKSUGUR_110	10:40	13:53	03:13	LINE CLEAR AVOIDED
4887	26-Jun-24	GULBARGA	110	TRANSFORMER	HV3	MUNIRABAD_220	17:46	17:55	00:09	LINE CLEAR AVOIDED
4888	26-Jun-24	GULBARGA	110	LINE	JAWALGERA-VALABALLARI	JAWALGERA_110, WALABALLARI_110	20:15	20:35	00:20	TRIPPED ON FAULT
4889	26-Jun-24	GULBARGA	110	LINE	KHANAPUR-SHAHPUR1	KHANAPUR_110	13:35	15:24	01:49	LINE CLEAR AVOIDED
4890	26-Jun-24	GULBARGA	110	LINE	KHANAPUR-SHAHPUR2	KHANAPUR_110	15:32	18:50	03:18	LINE CLEAR AVOIDED
4891	26-Jun-24	GULBARGA	110	LINE	KUSHTAGI-TAVARAGERA	TAVARAGERA_110	10:45	16:45	06:00	LINE CLEAR AVOIDED
4892	26-Jun-24	GULBARGA	110	LINE	MALLAPUR-SULEKAL	MALLAPUR_110	10:05	15:05	05:00	LINE CLEAR AVOIDED
4893	26-Jun-24	GULBARGA	110	LINE	MANDEWAL-BAGEWADI-2	YADRAMI_110	02:25	02:40	00:15	MAIN SUPPLY FAILURE
4894	26-Jun-24	GULBARGA	110	LINE	MANDEWAL-BAGEWADI-2	YADRAMI_110	23:27	23:35	00:08	MAIN SUPPLY FAILURE
4895	26-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	02:46	02:50	00:04	TRIPPED ON FAULT
4896	26-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHBAD	NALWAR_110	05:28	05:34	00:06	TRIPPED ON FAULT
4897	26-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHPUR2	GABUR_110, GUGAL_110	19:08	19:13	00:05	TRIPPED ON FAULT
4898	26-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	8:52(25.06.2024)			LINE CLEAR AVOIDED
4899	26-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	20:13	20:23	00:10	TRIPPED ON FAULT
4900	26-Jun-24	GULBARGA	110	LINE	SHAHPUR-KHANAPUR1	KHANAPUR_110	12:27	13:30	01:03	LINE CLEAR AVOIDED
4901	26-Jun-24	GULBARGA	110	LINE	SHAHPUR-KHANAPUR2	KHANAPUR_110	15:25	18:50	03:25	LINE CLEAR AVOIDED
4902	26-Jun-24	GULBARGA	110	LINE	SHAHPUR-YADGIR	YADGIR_110	04:25	04:30	00:05	LINE CLEAR AVOIDED
4903	26-Jun-24	GULBARGA	110	LINE	SULEKAL-SRIRAMANAGAR	SRIRAMANAGAR_110	10:00	14:05	04:05	LINE CLEAR AVOIDED
4904	26-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	20:13	20:23	00:10	TRIPPED ON FAULT
4905	26-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	04:25	04:30	00:05	MAIN SUPPLY FAILURE
4906	26-Jun-24	GULBARGA	220	LINE	HALBARGA-HUMNABAD	HALBARGA_220	14:10	17:50	03:40	LINE CLEAR AVOIDED
4907	26-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVOIDED
4908	26-Jun-24	GULBARGA	220	LINE	SHAHPUR-FIROZABAD-2	SHAHPUR_220	11:19	13:14	01:55	LINE CLEAR AVOIDED
4909	26-Jun-24	GULBARGA	220	LINE	SHAHPUR-FIROZABAD-2	SHAHPUR_220	13:20	17:21	04:01	LINE CLEAR AVOIDED
4910	26-Jun-24	HASSAN	66	LINE	ALDUR-CHIKKAMAGLUR	ALDUR_66	11:07	15:23	04:16	LINE CLEAR AVOIDED
4911	26-Jun-24	HASSAN	66	LINE	BALEHN-JENUGADDE1	BALEHONNUR_66	11:07	15:19	04:12	MAIN SUPPLY FAILURE
4912	26-Jun-24	HASSAN	66	LINE	BALEHN-JENUGADDE2	BALEHONNUR_66	11:07	15:19	04:12	MAIN SUPPLY FAILURE
4913	26-Jun-24	HASSAN	66	LINE	CHIKABO-HADAVANHALLI	CRPATNA_220	12:14	14:18	02:04	TRIPPED ON FAULT
4914	26-Jun-24	HASSAN	66	LINE	CHIKABO-KUSHLNAGAR	CHIKABOMMENAHALLI_66	10:00	16:06	06:06	LINE CLEAR AVOIDED
4915	26-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHIKABOMMENAHALLI_66	10:00	16:07	06:07	LINE CLEAR AVOIDED
4916	26-Jun-24	HASSAN	66	TRANSFORMER	HV1	HANUBAL_66	18:05	18:15	00:10	TRIPPED ON FAULT
4917	26-Jun-24	HASSAN	66	TRANSFORMER	HV1	HANUBAL_66	21:50	22:05	00:15	TRIPPED ON FAULT
4918	26-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHANNARAYAPATTANA_66	11:55	13:55	02:00	LINE CLEAR AVOIDED
4919	26-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	10:00	16:06	06:06	LINE CLEAR AVOIDED
4920	26-Jun-24	HASSAN	66	TRANSFORMER	HV4	BALEHONNUR_66	23:51	23:58	00:07	TRIPPED ON FAULT
4921	26-Jun-24	HASSAN	66	LINE	SBELAG-C R PATNA	SBELAGOLA_66	11:53	12:20	00:27	LINE CLEAR AVOIDED
4922	26-Jun-24	HASSAN	66	LINE	SBELAG-SNTBCHL	SBELAGOLA_66	11:53	12:22	00:29	LINE CLEAR AVOIDED
4923	26-Jun-24	HASSAN	110	LINE	AJAMPU-KADUR	AJJAMPURA_66	10:24	13:20	02:56	LINE CLEAR AVOIDED
4924	26-Jun-24	HASSAN	110	LINE	AJAMPU-SHIVANI	AJJAMPURA_66	10:24	13:06	02:42	LINE CLEAR AVOIDED
4925	26-Jun-24	HASSAN	110	LINE	ARSK2-GERUMARA	ARSIKERE_220	12:45	12:48	00:03	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4926	26-Jun-24	HASSAN	110	LINE	BAIKAM-KAVOOR	BAIKAMPADI_110	09:36	10:06	00:30	MAIN SUPPLY FAILURE
4927	26-Jun-24	HASSAN	110	LINE	BANTWA-SALATTUR	BANTWALA_110	11:00	13:08	02:08	LINE CLEAR AVAIED
4928	26-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVAYANKERE_110	09:34	10:41	01:07	MAIN SUPPLY FAILURE
4929	26-Jun-24	HASSAN	110	TRANSFORMER	GURUVA-SLVPWR	GURUVAYANKERE_110	09:34	10:41	01:07	MAIN SUPPLY FAILURE
4930	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	KEMAR_220	09:34	10:11	00:37	MAIN SUPPLY FAILURE
4931	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	AJJAMPURA_66	10:24	15:58	05:34	LINE CLEAR AVAIED
4932	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	ARSIKERE_220	11:00	17:15	06:15	LINE CLEAR AVAIED
4933	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	KAVOOR_220	09:33	09:54	00:21	MAIN SUPPLY FAILURE
4934	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	KONAJE_110	09:35	09:57	00:22	MAIN SUPPLY FAILURE
4935	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	KONAJE_110	10:49	13:00	02:11	LINE CLEAR AVAIED
4936	26-Jun-24	HASSAN	110	TRANSFORMER	HV1	MANIPAL_110	09:36	10:33	00:57	MAIN SUPPLY FAILURE
4937	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	KEMAR_220	09:34	10:10	00:36	MAIN SUPPLY FAILURE
4938	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	AJJAMPURA_66	10:24	15:58	05:34	LINE CLEAR AVAIED
4939	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	KAVOOR_220	09:33	09:54	00:21	MAIN SUPPLY FAILURE
4940	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	09:35	09:57	00:22	MAIN SUPPLY FAILURE
4941	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	KONAJE_110	10:49	14:14	03:25	LINE CLEAR AVAIED
4942	26-Jun-24	HASSAN	110	TRANSFORMER	HV2	VITTALA_110	13:45	15:48	02:03	LINE CLEAR AVAIED
4943	26-Jun-24	HASSAN	110	TRANSFORMER	HV3	HIRIYADKA_110	22:52	23:23	00:31	TRIPPED ON FAULT
4944	26-Jun-24	HASSAN	110	TRANSFORMER	HV3	KAVOOR_220	09:33	09:54	00:21	MAIN SUPPLY FAILURE
4945	26-Jun-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	09:35	09:57	00:22	MAIN SUPPLY FAILURE
4946	26-Jun-24	HASSAN	110	TRANSFORMER	HV3	KONAJE_110	10:49	12:41	01:52	LINE CLEAR AVAIED
4947	26-Jun-24	HASSAN	110	TRANSFORMER	HV4	KAVOOR_220	09:33	09:54	00:21	MAIN SUPPLY FAILURE
4948	26-Jun-24	HASSAN	110	TRANSFORMER	HV4	KAVOOR_220	10:40	13:32	02:52	LINE CLEAR AVAIED
4949	26-Jun-24	HASSAN	110	LINE	KADUR-AJAMPURA	KADUR_220	10:30	13:16	02:46	LINE CLEAR AVAIED
4950	26-Jun-24	HASSAN	110	LINE	KADUR-NERELEKERE	KADUR_220	11:44	14:30	02:46	LINE CLEAR AVAIED
4951	26-Jun-24	HASSAN	110	LINE	KADUR-YGTI	KADUR_220	11:31	13:35	02:04	LINE CLEAR AVAIED
4952	26-Jun-24	HASSAN	110	LINE	KARKLA-kemar	KARKALA_110	09:53	10:07	00:14	MAIN SUPPLY FAILURE
4953	26-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere1	KEMAR_220	09:34	10:41	01:07	MAIN SUPPLY FAILURE
4954	26-Jun-24	HASSAN	110	LINE	KEMAR-Guruvykere2	KEMAR_220	09:34	10:41	01:07	MAIN SUPPLY FAILURE
4955	26-Jun-24	HASSAN	110	LINE	KEMAR-HIRIYADKA	KEMAR_220	09:34	10:06	00:32	MAIN SUPPLY FAILURE
4956	26-Jun-24	HASSAN	110	LINE	KEMAR-Manipal1	KEMAR_220	09:34	10:05	00:31	MAIN SUPPLY FAILURE
4957	26-Jun-24	HASSAN	110	LINE	KEMAR-Manipal2	KEMAR_220	09:34	10:06	00:32	MAIN SUPPLY FAILURE
4958	26-Jun-24	HASSAN	110	LINE	KEMAR-NANDHIKUR1	KEMAR_220	09:34	10:18	00:44	TRIPPED ON FAULT
4959	26-Jun-24	HASSAN	110	LINE	KEMAR-NANDHIKUR2	KEMAR_220	09:34	10:17	00:43	TRIPPED ON FAULT
4960	26-Jun-24	HASSAN	110	LINE	KONAJE-JAPPU	KONAJE_110	10:49	12:41	01:52	LINE CLEAR AVAIED
4961	26-Jun-24	HASSAN	110	TRANSFORMER	LV1	KEMAR_220	09:34	10:01	00:27	MAIN SUPPLY FAILURE
4962	26-Jun-24	HASSAN	110	TRANSFORMER	LV1	ARSIKERE_220	11:00	17:15	06:15	LINE CLEAR AVAIED
4963	26-Jun-24	HASSAN	110	TRANSFORMER	LV1	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4964	26-Jun-24	HASSAN	110	TRANSFORMER	LV2	KEMAR_220	09:34	09:59	00:25	MAIN SUPPLY FAILURE
4965	26-Jun-24	HASSAN	110	TRANSFORMER	LV2	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4966	26-Jun-24	HASSAN	110	TRANSFORMER	LV3	KEMAR_220	09:34	10:09	00:35	MAIN SUPPLY FAILURE
4967	26-Jun-24	HASSAN	110	TRANSFORMER	LV3	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4968	26-Jun-24	HASSAN	110	LINE	MANIPAL-BRAMVR	MANIPAL_110	09:36	10:07	00:31	MAIN SUPPLY FAILURE
4969	26-Jun-24	HASSAN	110	LINE	MANIPAL-KEMAR1	MANIPAL_110	09:36	10:06	00:30	MAIN SUPPLY FAILURE
4970	26-Jun-24	HASSAN	110	LINE	MOODAB-SOHAM1	MOODABIDRE_66	09:35	10:08	00:33	MAIN SUPPLY FAILURE
4971	26-Jun-24	HASSAN	110	LINE	MOODAB-SOHAM2	MOODABIDRE_66	09:35	10:08	00:33	MAIN SUPPLY FAILURE
4972	26-Jun-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	10:14	17:01	06:47	LINE CLEAR AVAIED
4973	26-Jun-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	10:14	13:08	02:54	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
4974	26-Jun-24	HASSAN	110	LINE	NANDIKU-ISTR	NANDIKUR_110	09:35	10:22	00:47	MAIN SUPPLY FAILURE
4975	26-Jun-24	HASSAN	110	LINE	NANDIKU-NDKR-SUZLON	NANDIKUR_110	10:20	10:24	00:04	MAIN SUPPLY FAILURE
4976	26-Jun-24	HASSAN	220	LINE	GOPALAP-SHANTHIGRAMA	GOPALAPURA_220	08:27	19:20	10:53	LINE CLEAR AVOIDED
4977	26-Jun-24	HASSAN	220	TRANSFORMER	HV1	KEMAR_220	09:34	10:01	00:27	MAIN SUPPLY FAILURE
4978	26-Jun-24	HASSAN	220	TRANSFORMER	HV1	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4979	26-Jun-24	HASSAN	220	TRANSFORMER	HV2	KEMAR_220	09:34	09:59	00:25	MAIN SUPPLY FAILURE
4980	26-Jun-24	HASSAN	220	TRANSFORMER	HV2	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4981	26-Jun-24	HASSAN	220	TRANSFORMER	HV3	KEMAR_220	09:34	10:09	00:35	MAIN SUPPLY FAILURE
4982	26-Jun-24	HASSAN	220	TRANSFORMER	HV3	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4983	26-Jun-24	HASSAN	220	LINE	KAVOOR-KEMAR3	KAVOOR_220	09:33	09:56	00:23	MAIN SUPPLY FAILURE
4984	26-Jun-24	HASSAN	220	LINE	KAVOOR-KVBJPE1	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4985	26-Jun-24	HASSAN	220	LINE	KAVOOR-KVBJPE2	KAVOOR_220	09:33	10:25	00:52	MAIN SUPPLY FAILURE
4986	26-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor1	KEMAR_220	09:34	09:56	00:22	MAIN SUPPLY FAILURE
4987	26-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor2	KEMAR_220	09:34	09:59	00:25	MAIN SUPPLY FAILURE
4988	26-Jun-24	HASSAN	220	LINE	KEMAR-KAVR3	KEMAR_220	09:34	09:58	00:24	MAIN SUPPLY FAILURE
4989	26-Jun-24	HASSAN	220	LINE	KEMAR-UPCL1	KEMAR_220	09:34	09:54	00:20	TRIPPED ON FAULT
4990	26-Jun-24	HASSAN	220	LINE	KEMAR-UPCL2	KEMAR_220	09:34	09:54	00:20	TRIPPED ON FAULT
4991	26-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMG_220	09:22	18:17	08:55	LINE CLEAR AVOIDED
4992	26-Jun-24	HASSAN	220	LINE	UPCL-KEMAR1	gen_upcl	09:34	09:54	00:20	TRIPPED ON FAULT
4993	26-Jun-24	HASSAN	220	LINE	UPCL-KEMAR2	gen_upcl	09:34	09:55	00:21	TRIPPED ON FAULT
4994	26-Jun-24	HASSAN	220	LINE	VARAH1-SHMG3	gen_vaarhi	09:31	18:17	08:46	LINE CLEAR AVOIDED
4995	26-Jun-24	MYSORE	66	LINE	GOLUR-DEVNUR(N'GUD)	DEVNUR(N'GUD)_66 SUTTUR_66	18:59	19:09	00:10	TRIPPED ON FAULT
4996	26-Jun-24	MYSORE	66	LINE	HEBBANI-SATHEGALA	CHANDALLI_66 PARINAMIPURA_66 SATHEGALA_66 KOLLEGALA_66	06:09	06:17	00:08	TRIPPED ON FAULT
4997	26-Jun-24	MYSORE	66	LINE	HEBBANI-SFC 7	NO STATIONS EFFECTED	02:17	09:41	07:24	TRIPPED ON FAULT
4998	26-Jun-24	MYSORE	66	LINE	HUNSUR 220-KAMPLAPURA	NO STATIONS EFFECTED	11:34	15:11	03:37	LINE CLEAR AVOIDED
4999	26-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5000	26-Jun-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_66	08:36	08:50	00:14	TRIPPED ON FAULT
5001	26-Jun-24	MYSORE	66	TRANSFORMER	HV2	KADAKOLA_66	08:54	08:58	00:04	TRIPPED ON FAULT
5002	26-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVOIDED
5003	26-Jun-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 1	NO STATIONS EFFECTED	11:15	12:20	01:05	LINE CLEAR AVOIDED
5004	26-Jun-24	MYSORE	66	LINE	KADAKOLA-VAJAMANGALA 2	NO STATIONS EFFECTED	11:15	12:20	01:05	LINE CLEAR AVOIDED
5005	26-Jun-24	MYSORE	66	LINE	KHB STATION-BILIKERE	DMG_HALLI_66	07:47	11:24	03:36	TRIPPED ON FAULT
5006	26-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5007	26-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVOIDED
5008	26-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	06:10	06:19	00:09	TRIPPED ON FAULT
5009	26-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVOIDED
5010	26-Jun-24	MYSORE	66	LINE	POONAMPETE-VIRAJPET	NO STATIONS EFFECTED	20:58	21:08	00:10	TRIPPED ON FAULT
5011	26-Jun-24	MYSORE	66	LINE	POONAMPETE-VIRAJPET	NO STATIONS EFFECTED	21:40	22:35	00:54	TRIPPED ON FAULT
5012	26-Jun-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 8	NO STATIONS EFFECTED	00:02	12:20	12:18	LINE CLEAR AVOIDED
5013	26-Jun-24	MYSORE	66	LINE	SFCSIVA-HEBBANI 9	NO STATIONS EFFECTED	00:02	12:20	12:18	LINE CLEAR AVOIDED
5014	26-Jun-24	MYSORE	220	TRANSFORMER	HV1	BEGUR_220	12:17	12:48	00:31	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5015	26-Jun-24	MYSORE	220	LINE	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	10:37	14:39	04:02	LINE CLEAR AVAILED
5016	26-Jun-24	TUMKUR	66	LINE	220KV ANCHEPALYA-66KV B G NAGAR LINE	66KV JIDDIGERE,THIPPUR,YEDIYUR	06:55	07:07	00:12	TRIPPED ON FAULT
5017	26-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV NALLUR LINE	66KV BASAVAPATNA	11:59	12:09	00:10	TRIPPED ON FAULT
5018	26-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV HALURAMESHWARA LINE 1	66KV HALURAMESHWARA,MADADAKERE	17:45	18:00	00:15	TRIPPED ON FAULT
5019	26-Jun-24	TUMKUR	66	LINE	66KV CHITRADURGA-66KV PANDARAHALLI LINE 2	66KV CHITRAHALLI, HD PURA	11:03	11:18	00:15	TRIPPED ON FAULT
5020	26-Jun-24	TUMKUR	66	LINE	66KV SIRA-66KV KALLAMBELLA LINE	66KV KALLAMBELLA	06:25	06:50	00:25	TRIPPED ON FAULT
5021	26-Jun-24	TUMKUR	66	LINE	66KV SIRA-66KV KALLAMBELLA LINE	66KV KALLAMBELLA	07:10	07:50	00:40	TRIPPED ON FAULT
5022	26-Jun-24	TUMKUR	66	LINE	66KV SIRA-66KV KALLAMBELLA LINE	66KV KALLAMBELLA	09:00	09:10	00:10	TRIPPED ON FAULT
5023	26-Jun-24	TUMKUR	66	LINE	HALURAMESWARA-MADURE220	HALURAMESWARA_66, HOSADURGA_66	17:45	18:00	00:15	MAIN SUPPLY FAILURE
5024	26-Jun-24	TUMKUR	66	LINE	THALLAK 220KV- CHALLAKERE LINE-2	CHALLAKERE_66, SANIKERE_66	12:37	13:35	00:58	LINE CLEAR AVAILED
5025	26-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	THIMMASANDRA_66	11:20	12:00	00:40	LINE CLEAR AVAILED
5026	26-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 1	GUTUR_400	08:13	14:16	06:03	LINE CLEAR AVAILED
5027	26-Jun-24	TUMKUR	400	LINE	GUTTUR 400KV- KAIGA 2	GUTUR_400	14:55	19:01	04:06	LINE CLEAR AVAILED
5028	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1&HV2(10MVA)	BENAKATTI_110	07:19	19:37	12:18	LINE CLEAR AVAILED
5029	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (20MVA HV1)	TIKOTA_110	16:02	17:34	01:32	LINE CLEAR AVAILED
5030	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	AMBEWADI_220	15:35	17:53	02:18	LINE CLEAR AVAILED
5031	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	BAGALKOT_220	12:10	14:07	01:57	LINE CLEAR AVAILED
5032	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV1(20MVA)	BILAGI_110	07:44	08:00	00:16	TRIPPED ON FAULT
5033	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2 (20MVA)	UCHAGOAN_110	17:02	18:31	01:29	TRIPPED ON FAULT
5034	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	13:46	13:54	00:08	TRIPPED ON FAULT
5035	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV,HV2(20MVA)	MALGHAN(B)_110	13:58	14:06	00:08	TRIPPED ON FAULT
5036	27-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (10MVA)	SHIGGOAN_110	07:16	07:24	00:08	TRIPPED ON FAULT
5037	27-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV2	BIJAPUR_220	08:19	08:36	00:17	TRIPPED ON FAULT
5038	27-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
5039	27-Jun-24	BAGALKOTE	110	LINE	AMBEWADI220-NK-1(HALIYAL)	AMBEWADI_220	06:56	07:04	00:08	TRIPPED ON FAULT
5040	27-Jun-24	BAGALKOTE	110	LINE	ANKOLA- KUMATA2	ANKOLA_110	10:40	10:44	00:04	LINE CLEAR AVAILED
5041	27-Jun-24	BAGALKOTE	110	LINE	ANKOLA- KUMATA2	ANKOLA_110	16:37	17:38	01:01	LINE CLEAR AVAILED
5042	27-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)			LINE CLEAR AVAILED
5043	27-Jun-24	BAGALKOTE	110	LINE	BENAKATTI- F1(SOUDATTI)	BENAKATTI_110	07:19	19:37	12:18	LINE CLEAR AVAILED
5044	27-Jun-24	BAGALKOTE	110	LINE	BENAKATTI- F2(YARAGATTI)	BENAKATTI_110	07:19	19:38	12:19	LINE CLEAR AVAILED
5045	27-Jun-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR	BIJAPUR_220	08:19	08:51	00:32	TRIPPED ON FAULT
5046	27-Jun-24	BAGALKOTE	110	LINE	KUMATA- SIRSI1	KUMATA_110	10:07	17:46	07:39	LINE CLEAR AVAILED
5047	27-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- GSML2	MAHLINGAPUR_220	14:12	18:42	04:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5048	27-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220- TERDAL	MAHLINGAPUR_220	14:12	18:42	04:30	LINE CLEAR AVAILED
5049	27-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5050	27-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220-LN11(NAGANUR)	MUGALKHOD_220	20:07	20:17	00:10	TRIPPED ON FAULT
5051	27-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL	NAVALGUND_110	16:04 (25.06.2024)			TRIPPED ON FAULT
5052	27-Jun-24	BAGALKOTE	110	LINE	RAMDURGA- BAGALKOT	RAMDURGA_110	20:57	22:00	01:03	LINE CLEAR AVAILED
5053	27-Jun-24	BAGALKOTE	110	LINE	RAMDURGA- SOUDATTI	RAMDURGA_110	06:06	20:57	14:51	LINE CLEAR AVAILED
5054	27-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANE BENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
5055	27-Jun-24	BAGALKOTE	110	LINE	SIRSI-HUBLI (ESALE 1)	SIRSI_110	11:43	15:49	04:06	LINE CLEAR AVAILED
5056	27-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	19:57 (23.05.2024)	11:43 (27.06.2024)	87:46:00	LINE CLEAR AVAILED
5057	27-Jun-24	BAGALKOTE	110	LINE	SIRSI-JOG2	SIRSI_110	15:49	16:09	00:20	LINE CLEAR AVAILED
5058	27-Jun-24	BAGALKOTE	110	LINE	SIRSI-KAVALWADA (ESALE 2)	SIRSI_110	11:41	15:49	04:08	LINE CLEAR AVAILED
5059	27-Jun-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON1	SOUDATTI_110	13:28	19:42	06:14	LINE CLEAR AVAILED
5060	27-Jun-24	BAGALKOTE	110	LINE	SOUDAT-ENERCON2	SOUDATTI_110	13:28	19:42	06:14	LINE CLEAR AVAILED
5061	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- BENAKATTI	SOUDATTI_220	7:20	19:37	12:17	LINE CLEAR AVAILED
5062	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- MUNAVALLI	SOUDATTI_220	7:23	19:34	12:11	LINE CLEAR AVAILED
5063	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA1	SOUDATTI_220	6:06	20:47	14:41	LINE CLEAR AVAILED
5064	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- RAMDURGA2	SOUDATTI_220	6:06	20:48	14:42	LINE CLEAR AVAILED
5065	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- SOUDATTI1	SOUDATTI_220	7:23	19:35	12:12	LINE CLEAR AVAILED
5066	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- SOUDATTI2	SOUDATTI_220	7:23	19:35	12:12	LINE CLEAR AVAILED
5067	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220- UDAKERI	SOUDATTI_220	7:20	19:42	12:22	LINE CLEAR AVAILED
5068	27-Jun-24	BAGALKOTE	110	LINE	SOUDATTI220-MMCL	SOUDATTI_220	07:23	19:38	12:15	LINE CLEAR AVAILED
5069	27-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5070	27-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
5071	27-Jun-24	BAGALKOTE	110	LINE	TAKLI-KNSCBreaker	TAKKALAKI_110	19:07	20:05	#VALUE!	LINE CLEAR AVAILED
5072	27-Jun-24	BAGALKOTE	110	LINE	TAKLI-WRDCBreaker	TAKKALAKI_110	19:09	20:05	00:56	LINE CLEAR AVAILED
5073	27-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
5074	27-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
5075	27-Jun-24	BAGALKOTE	110	LINE	YARAGA-KATAKOL	KATAKOLA_110	07:19	19:48	12:29	LINE CLEAR AVAILED
5076	27-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1	SOUDATTI_220	07:24	19:30	12:06	LINE CLEAR AVAILED
5077	27-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	BIJAPUR_220	08:19	08:35	00:16	TRIPPED ON FAULT
5078	27-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	SOUDATTI_220	07:24	19:30	12:06	LINE CLEAR AVAILED
5079	27-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	SOUDATTI_220	07:24	19:54	12:30	LINE CLEAR AVAILED
5080	27-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3&LV3	ATHANI_220	15:01	18:20	03:19	LOAD CURTAILMENT
5081	27-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA-2	AMBEWADI_220	13:02	17:17	04:15	TRIPPED ON FAULT
5082	27-Jun-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI1	BAGALKOT_220	10:33	13:09	02:36	LINE CLEAR AVAILED
5083	27-Jun-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI2	BAGALKOT_220	15:49	17:26	01:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5084	27-Jun-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI1	BIDNAL_220	07:25	19:28	12:03	LINE CLEAR AVAILED
5085	27-Jun-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI2	BIDNAL_220	7:26 (27.06.2024)			LINE CLEAR AVAILED
5086	27-Jun-24	BAGALKOTE	220	LINE	HUBLI- NARENDRA2	HUBLI_220	12:55	17:55	05:00	LINE CLEAR AVAILED
5087	27-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
5088	27-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-BIDNAL1	SOUDATTI_220	07:24	19:28	12:04	LINE CLEAR AVAILED
5089	27-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-MAHALINGAPUR (BIDNAL2)	SOUDATTI_220	7:24 (27.06.2024)			LINE CLEAR AVAILED
5090	27-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	10:36	13:11	02:35	LINE CLEAR AVAILED
5091	27-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	15:52	17:29	01:37	LINE CLEAR AVAILED
5092	27-Jun-24	BANGALORE	66	LINE	66KV BIDADI 220 - HEJJALA 2	HEJJALA	18:57	19:00	00:03	LINE CLEAR AVAILED
5093	27-Jun-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	12:20	12:28	00:08	TRIPPED ON FAULT
5094	27-Jun-24	BANGALORE	66	LINE	66KV HBR 220 - LR BANDE	LR BANDE	12:56	15:48	02:52	LINE CLEAR AVAILED
5095	27-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ELITA PROMONEDE	ELITA PROMENENDE	10:25	14:35	04:10	LINE CLEAR AVAILED
5096	27-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALI 220 - VR DODDI	VR DODDI	13:54	14:02	00:08	TRIPPED ON FAULT
5097	27-Jun-24	BANGALORE	66	LINE	66KV KUDUMULAKUNTE - THERIYUR	THERIYUR	08:35	08:55	00:20	TRIPPED ON FAULT
5098	27-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - D CROSS 2	AIR(EHT)	12:05	13:50	01:45	LINE CLEAR AVAILED
5099	27-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	10:06	13:45	03:39	LINE CLEAR AVAILED
5100	27-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALI 220 - KGF 1	NO STATION AFFECTED	16:13	17:48	01:35	TRIPPED ON FAULT
5101	27-Jun-24	BANGALORE	66	LINE	66KV TALGAWARA - Y HUNSEANAHALLY	Y HUNSENAHALI	14:30	14:35	00:05	LINE CLEAR AVAILED
5102	27-Jun-24	BANGALORE	66	LINE	66KV TALGAWARA - Y HUNSEANAHALLY	Y HUNSENAHALI	16:35	16:45	00:10	LINE CLEAR AVAILED
5103	27-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - KIADB HAROHALI 220	NO STATION AFFECTED	15:31	17:51	02:20	TRIPPED ON FAULT
5104	27-Jun-24	BANGALORE	66	TRANSFORMER	HV1	LR BANDE	11:08	17:30	06:22	LINE CLEAR AVAILED
5105	27-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MATHIKERE	10:15	17:13	06:58	LINE CLEAR AVAILED
5106	27-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SUGUTUR	11:20	11:25	00:05	TRIPPED ON FAULT
5107	27-Jun-24	BANGALORE	66	TRANSFORMER	HV1	JIGANI 220	08:51	09:32	00:41	TRIPPED ON FAULT
5108	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	LR BANDE	12:45	17:30	04:45	LINE CLEAR AVAILED
5109	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MATHIKERE	10:48	17:23	06:35	LINE CLEAR AVAILED
5110	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	GOWRIBIDANUR 220	12:55	13:05	00:10	TRIPPED ON FAULT
5111	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KEMBODI	12:05	12:07	00:02	LINE CLEAR AVAILED
5112	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SRINIVASPURA 66	11:55	12:25	00:30	LINE CLEAR AVAILED
5113	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VR DODDI	12:40	12:45	00:05	LINE CLEAR AVAILED
5114	27-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BEVOOR	11:30	11:39	00:09	TRIPPED ON FAULT
5115	27-Jun-24	GULBARGA	66	LINE	BADALADUKU-CJ.HALLI	CJ.HALLI_66,HOSAHALLI_66,H UDEM	04:15	04:25	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5116	27-Jun-24	GULBARGA	66	LINE	BADALADUKU-CJ.HALLI	CJ.HALLI_66,HOSAHALLI_66,HUDEM	10:00	18:50	08:50	LINE CLEAR AVAILED
5117	27-Jun-24	GULBARGA	66	LINE	BANVEKAL-BADALADUKU	BANVEKAL_110	10:00	18:50	08:50	LINE CLEAR AVAILED
5118	27-Jun-24	GULBARGA	66	LINE	HOSAHALLI-BADALADUKU	HOSAHALLI_66	04:15	04:25	00:10	TRIPPED ON FAULT
5119	27-Jun-24	GULBARGA	66	LINE	HOSAHALLI-BADALADUKU	HOSAHALLI_66	10:00	18:50	08:50	LINE CLEAR AVAILED
5120	27-Jun-24	GULBARGA	66	LINE	HUDEM-BADALADUKU	HUDEM_66	04:15	04:25	00:10	TRIPPED ON FAULT
5121	27-Jun-24	GULBARGA	66	LINE	HUDEM-BADALADUKU	HUDEM_66	10:00	18:50	08:50	LINE CLEAR AVAILED
5122	27-Jun-24	GULBARGA	66	LINE	ITTAGI-SUZLON 1,2	SUZLONE_66,1,2	11:05	17:30	06:25	LINE CLEAR AVAILED
5123	27-Jun-24	GULBARGA	66	LINE	ITTAGI-SUZLON 1,2	SUZLONE_66,1,2	11:05	18:05	07:00	LINE CLEAR AVAILED
5124	27-Jun-24	GULBARGA	66	LINE	ITTIGI-TELAGI	YARAGUNTA_66	17:10	23:59	06:49	LINE CLEAR AVAILED
5125	27-Jun-24	GULBARGA	66	LINE	UJJINI-BADALADUKU	UJJINI_66	10:30	16:10	05:40	LINE CLEAR AVAILED
5126	27-Jun-24	GULBARGA	110	TRANSFORMER	HV1	VALKAMDINNI_110	13:53	14:13	00:20	TRIPPED ON FAULT
5127	27-Jun-24	GULBARGA	110	TRANSFORMER	HV1	GANGAVATHI_110	10:10	17:55	07:45	LINE CLEAR AVAILED
5128	27-Jun-24	GULBARGA	110	TRANSFORMER	HV1	FARTHABAD_110	20:30(27.06.2024)			TRIPPED ON FAULT
5129	27-Jun-24	GULBARGA	110	TRANSFORMER	HV2	GANGAVATHI_110	10:10	17:55	07:45	LINE CLEAR AVAILED
5130	27-Jun-24	GULBARGA	110	TRANSFORMER	HV3	GANGAVATHI_110	10:10	18:10	08:00	LINE CLEAR AVAILED
5131	27-Jun-24	GULBARGA	110	LINE	KHANAPUR-SIRWAL	SIRWAL_110	18:45	18:55	00:10	LINE CLEAR AVAILED
5132	27-Jun-24	GULBARGA	110	LINE	MALLAPURA-SULEKAL	MALLAPURA_110	21:40	22:00	00:20	MAIN SUPPLY FAILURE
5133	27-Jun-24	GULBARGA	110	LINE	MUKKUNDA-SINDHANOOR	MUKKUNDA_110	02:10	02:25	00:15	MAIN SUPPLY FAILURE
5134	27-Jun-24	GULBARGA	110	LINE	MUNIRABAD-BHORUKA LINE	MUNIRABAD_220	10:38	10:46	00:08	TRIPPED ON FAULT
5135	27-Jun-24	GULBARGA	110	LINE	MUNIRABAD-BHORUKA LINE	MUNIRABAD_220	11:08	17:29	06:21	TRIPPED ON FAULT
5136	27-Jun-24	GULBARGA	110	LINE	MUNIRABAD-DONIMALAI	DONIMALAI_110	12:43	13:35	00:52	LINE CLEAR AVAILED
5137	27-Jun-24	GULBARGA	110	LINE	NALWAR-SHAHPUR	NALWAR_110	05:00	05:15	00:15	TRIPPED ON FAULT
5138	27-Jun-24	GULBARGA	110	LINE	RAICHUR-SHAHPUR2	GABUR_110,DEODURGA_110,GUGAL_110	21:27	21:32	00:05	TRIPPED ON FAULT
5139	27-Jun-24	GULBARGA	110	LINE	RAICHUR-SINDHANOOR2	KURDICROSS_110	16:43	16:54	00:11	LINE CLEAR AVAILED
5140	27-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	8:52(25.06.2024)			LINE CLEAR AVAILED
5141	27-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	10:23	17:40	07:17	TRIPPED ON FAULT
5142	27-Jun-24	GULBARGA	110	LINE	SHAHPUR-YADGIR	YADGIR_110	02:15	02:17	00:02	TRIPPED ON FAULT
5143	27-Jun-24	GULBARGA	110	LINE	SULEKAL-GANGAVATHI	GANGAVATHI_110	10:38	11:48	01:10	MAIN SUPPLY FAILURE
5144	27-Jun-24	GULBARGA	110	LINE	SULEKAL-GANGAVATHI	GANGAVATHI_110	10:10	11:48	01:38	MAIN SUPPLY FAILURE
5145	27-Jun-24	GULBARGA	110	LINE	SULEKAL-GANGAVATHI	GANGAVATHI_110	10:10	18:10	08:00	LINE CLEAR AVAILED
5146	27-Jun-24	GULBARGA	110	LINE	VENKATGIR-MUNIRABAD	VENKATGIRI_110	10:10	10:35	00:25	MAIN SUPPLY FAILURE
5147	27-Jun-24	GULBARGA	110	LINE	VENKATGIR-MUNIRABAD	VENKATGIRI_110	10:38	11:48	01:10	MAIN SUPPLY FAILURE
5148	27-Jun-24	GULBARGA	110	LINE	VENKATGIR-MUNIRABAD	VENKATGIRI_110	10:10	10:35	00:25	LINE CLEAR AVAILED
5149	27-Jun-24	GULBARGA	110	LINE	YADGIR-KBJNL	YADGIR_110	10:25	10:30	00:05	TRIPPED ON FAULT
5150	27-Jun-24	GULBARGA	110	LINE	YADGIR-KBJNL	YADGIR_110	10:30	11:05	00:35	LINE CLEAR AVAILED
5151	27-Jun-24	GULBARGA	110	LINE	YADGIR-RAMASAMUDRA	YADGIR_110	10:25	11:20	00:55	TRIPPED ON FAULT
5152	27-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	10:25	10:30	00:05	TRIPPED ON FAULT
5153	27-Jun-24	GULBARGA	220	LINE	ITTAGI-BADALADUKU	BADALADUKU_220	15:25	17:25	02:00	LINE CLEAR AVAILED
5154	27-Jun-24	GULBARGA	220	LINE	LINGASUGUR-SHAHPUR	LINGASUGUR_220	05:09	10:52	05:43	TRIPPED ON FAULT
5155	27-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
5156	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-FIROZABAD-1	SHAHPUR_220	17:45	19:06	01:21	LINE CLEAR AVAILED
5157	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-LINGASUGUR	SHAHPUR_220	05:11	10:52	05:41	TRIPPED ON FAULT
5158	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHPUR_220	04:28	04:54	00:26	TRIPPED ON FAULT
5159	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHPUR_220	14:55	19:04	04:09	TRIPPED ON FAULT
5160	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHPUR_220	04:28	04:54	00:26	TRIPPED ON FAULT
5161	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHPUR_220	14:54	15:28	00:34	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5162	27-Jun-24	GULBARGA	220	LINE	SHAHPUR-SHAHBAD	SHAHPUR_220	15:28	19:04	03:36	LINE CLEAR AVAILED
5163	27-Jun-24	HASSAN	66	LINE	CHIKABO-SIDPR	CHIKABOMMENAHALLI_66	12:05	12:30	00:25	MAIN SUPPLY FAILURE
5164	27-Jun-24	HASSAN	66	LINE	CRPATNA-CHMUNDSUG	CRPATNA_220	16:18	16:22	00:04	LINE CLEAR AVAILED
5165	27-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHIKABOMMENAHALLI_66	12:05	12:30	00:25	MAIN SUPPLY FAILURE
5166	27-Jun-24	HASSAN	66	TRANSFORMER	HV1	DUDDA_66	10:45	10:55	00:10	TRIPPED ON FAULT
5167	27-Jun-24	HASSAN	66	TRANSFORMER	HV1	HADAVANAHALLI_66	13:00	14:03	01:03	LINE CLEAR AVAILED
5168	27-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	12:05	12:30	00:25	MAIN SUPPLY FAILURE
5169	27-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	13:45	13:55	00:10	LINE CLEAR AVAILED
5170	27-Jun-24	HASSAN	66	LINE	KUDLIGE-ANVRPP	KUDLIGERE_66	11:18	11:40	00:22	TRIPPED ON FAULT
5171	27-Jun-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	19:30(27.06.2024)			TRIPPED ON FAULT
5172	27-Jun-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANGADI_110	19:30(27.06.2024)			TRIPPED ON FAULT
5173	27-Jun-24	HASSAN	110	TRANSFORMER	HV1	KADUR_220	09:50	15:52	06:02	LINE CLEAR AVAILED
5174	27-Jun-24	HASSAN	110	TRANSFORMER	HV3	KADUR_220	10:00	15:52	05:52	LINE CLEAR AVAILED
5175	27-Jun-24	HASSAN	110	LINE	KAVOOR-KONAJE	KAVOOR_220	10:53	13:00	02:07	LINE CLEAR AVAILED
5176	27-Jun-24	HASSAN	110	LINE	KONAJE-JAPPU	KONAJE_110	10:55	13:36	02:41	LINE CLEAR AVAILED
5177	27-Jun-24	HASSAN	110	TRANSFORMER	LV2	PUTTUR_220	09:43	15:51	06:08	LINE CLEAR AVAILED
5178	27-Jun-24	HASSAN	110	TRANSFORMER	LV3	KAVOOR_220	16:35	17:37	01:02	LINE CLEAR AVAILED
5179	27-Jun-24	HASSAN	110	LINE	MRSSHM-SS1	MRSMG_220	10:43	12:37	01:54	LINE CLEAR AVAILED
5180	27-Jun-24	HASSAN	110	LINE	MSEZ-GSS31	MSEZ_220	10:32	13:13	02:41	LINE CLEAR AVAILED
5181	27-Jun-24	HASSAN	110	LINE	MSEZ-GSS32	MSEZ_220	13:20	14:24	01:04	LINE CLEAR AVAILED
5182	27-Jun-24	HASSAN	110	LINE	SAGARA-TAL	SAGARA_110	07:20	16:52	09:32	TRIPPED ON FAULT
5183	27-Jun-24	HASSAN	110	LINE	TALAGU-SAGAR	TALAGUPPA_110	09:00	16:50	07:50	TRIPPED ON FAULT
5184	27-Jun-24	HASSAN	220	TRANSFORMER	HV1	HEGGUNJE_220	10:32	13:58	03:26	LINE CLEAR AVAILED
5185	27-Jun-24	HASSAN	220	TRANSFORMER	HV2	PUTTUR_220	09:43	15:51	06:08	LINE CLEAR AVAILED
5186	27-Jun-24	HASSAN	220	TRANSFORMER	HV3	KAVOOR_220	16:35	17:37	01:02	LINE CLEAR AVAILED
5187	27-Jun-24	HASSAN	220	LINE	KEMAR-Kavoor1	KEMAR_220	10:31	13:56	03:25	LINE CLEAR AVAILED
5188	27-Jun-24	HASSAN	220	LINE	KEMAR-Varahi1	KEMAR_220	11:25	13:50	02:25	TRIPPED ON FAULT
5189	27-Jun-24	HASSAN	220	LINE	MRSSHM-HASSAN	MRSMG_220	12:24	13:56	01:32	TRIPPED ON FAULT
5190	27-Jun-24	HASSAN	220	LINE	MRSSHM-VARAH13	MRSMG_220	09:12	17:32	08:20	LINE CLEAR AVAILED
5191	27-Jun-24	HASSAN	220	LINE	MSEZ-KEMAR1	MSEZ_220	10:32	13:56	03:24	LINE CLEAR AVAILED
5192	27-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR1	gen_varahi	11:25	13:50	02:25	TRIPPED ON FAULT
5193	27-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	gen_varahi	09:12	17:32	08:20	LINE CLEAR AVAILED
5194	27-Jun-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED
5195	27-Jun-24	MYSORE	66	LINE	HUNSUR 220-HUNSUR-2	NO STATIONS EFFECTED	03:26	03:45	00:19	TRIPPED ON FAULT
5196	27-Jun-24	MYSORE	66	LINE	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	03:26	03:45	00:19	TRIPPED ON FAULT
5197	27-Jun-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	17:48	17:57	00:09	TRIPPED ON FAULT
5198	27-Jun-24	MYSORE	66	TRANSFORMER	HV1	HONNALLY_MYS_66	09:19	09:25	00:06	TRIPPED ON FAULT
5199	27-Jun-24	MYSORE	66	TRANSFORMER	HV1	JYOTHINAGARA_66	11:15	12:26	01:10	LINE CLEAR AVAILED
5200	27-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5201	27-Jun-24	MYSORE	66	TRANSFORMER	HV2	JYOTHINAGARA_66	12:27	13:35	01:08	LINE CLEAR AVAILED
5202	27-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
5203	27-Jun-24	MYSORE	66	LINE	KM DODDI-SCSL	NO STATIONS EFFECTED	11:59 (27/06/2024)			LINE CLEAR AVAILED
5204	27-Jun-24	MYSORE	66	LINE	KUSHALANAGARA 220-RAMANATHAPURA 1	ALUR SIDDAPURA_66, KANAGAL_66	12:04	12:32	00:28	LINE CLEAR AVAILED
5205	27-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5206	27-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5207	27-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
5208	27-Jun-24	MYSORE	66	LINE	POONAMPETE-VIRAJPET	NO STATIONS EFFECTED	22:52 (26/6/2024)			TRIPPED ON FAULT
5209	27-Jun-24	MYSORE	66	LINE	POONAMPETE-VIRAJPET	NO STATIONS EFFECTED	22:52 (26/06/2024)	10:17 (27/06/2024)	11:25 HRs	TRIPPED ON FAULT
5210	27-Jun-24	MYSORE	66	LINE	SFC SIVA-5 MW	NO STATIONS EFFECTED	18:15	19:35	01:20	TRIPPED ON FAULT
5211	27-Jun-24	MYSORE	66	LINE	TUBINKERE-SHIVALLI	SHIVALLI_66 NAGAMANGALA_66	16:06:00 (26/6/2024)			TRIPPED ON FAULT
5212	27-Jun-24	MYSORE	66	LINE	TUBINKERE-SHIVALLI	SHIVALLI_66 NAGAMANGALA_66	16:06:00 (26/06/2024)	12:07 (27/06/2024)	20:00 HRs	TRIPPED ON FAULT
5213	27-Jun-24	MYSORE	66	LINE	VAJAMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	15:52	17:41	01:49	LINE CLEAR AVAILED
5214	27-Jun-24	MYSORE	220	TRANSFORMER	HV1	VAJAMANGALA_220	13:15	15:50	02:35	LINE CLEAR AVAILED
5215	27-Jun-24	TUMKUR	66	LINE	220KV HONNALI-66KV KUNDUR LINE	66KV KUNDUR, MALEBENNUR,DEVARBELAKE RE	11:16	11:26	00:10	TRIPPED ON FAULT
5216	27-Jun-24	TUMKUR	66	LINE	CHIKKAJAJUR-HOLALKERE-1	CHIKKAJAJUR_66	15:50	16:00	00:10	LINE CLEAR AVAILED
5217	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	09:28	09:44	00:16	LINE CLEAR AVAILED
5218	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	15:41	15:48	00:07	LINE CLEAR AVAILED
5219	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	09:28	09:44	00:16	LINE CLEAR AVAILED
5220	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV- SUZLON 1	SUZLON1_IPP_66	09:28	09:44	00:16	LINE CLEAR AVAILED
5221	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:41	16:06	00:25	LINE CLEAR AVAILED
5222	27-Jun-24	TUMKUR	66	LINE	CHITRADURGA 220KV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	16:46	17:14	00:28	LINE CLEAR AVAILED
5223	27-Jun-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	10:00	10:30	00:30	LINE CLEAR AVAILED
5224	27-Jun-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	15:40	16:05	00:25	LINE CLEAR AVAILED
5225	27-Jun-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	16:45	17:15	00:30	MAIN SUPPLY FAILURE
5226	27-Jun-24	TUMKUR	66	LINE	SOKKE-JAGLUR	SOKKE_66	18:25	18:30	00:05	LINE CLEAR AVAILED
5227	27-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	UJJINI, KUDLIGI	10:00	10:30	00:30	LINE CLEAR AVAILED
5228	27-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	UJJINI, KUDLIGI	15:40	16:05	00:25	LINE CLEAR AVAILED
5229	27-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	UJJINI, KUDLIGI	16:45	17:15	00:30	MAIN SUPPLY FAILURE
5230	27-Jun-24	TUMKUR	66	LINE	SOKKE-UJJINI	UJJINI, KUDLIGI	18:25	18:30	00:05	LINE CLEAR AVAILED
5231	27-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	THIMMASANDRA_66	16:30	18:00	01:30	LINE CLEAR AVAILED
5232	27-Jun-24	TUMKUR	66	TRANSFORMER	TR-1(12.5MVA)	THIMMASANDRA_66	18:15	19:45	01:30	LINE CLEAR AVAILED
5233	27-Jun-24	TUMKUR	110	TRANSFORMER	TR-1(10MVA)	HONNAVALLI_110	10:30	17:46	07:16	LINE CLEAR AVAILED
5234	27-Jun-24	TUMKUR	110	TRANSFORMER	TR-1(10MVA)	CNHALLI_110	10:00	16:30	06:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5235	27-Jun-24	TUMKUR	220	TRANSFORMER	TR-2(100MVA)	CHITRADURGA_220	15:50	19:50	04:00	LINE CLEAR AVAILED
5236	27-Jun-24	TUMKUR	220	TRANSFORMER	TR-3(100MVA)	CHITRADURGA_220	09:15	14:15	05:00	LINE CLEAR AVAILED
5237	28-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	MORATGI_110	10:44	10:54	00:10	TRIPPED ON FAULT
5238	28-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	YADWAD_110	17:00	18:23	01:23	LINE CLEAR AVAILED
5239	28-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	HOSAHONNATTI_110	13:45	15:15	01:30	LINE CLEAR AVAILED
5240	28-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	KAVALWADA_110	10:39	12:08	01:29	LINE CLEAR AVAILED
5241	28-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	GHATAPRABHA_220	07:45	10:55	03:10	LINE CLEAR AVAILED
5242	28-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
5243	28-Jun-24	BAGALKOTE	110	LINE	AHERI220- CHANDKAVATE	AHERI_220	14:35	15:40	01:05	LINE CLEAR AVAILED
5244	28-Jun-24	BAGALKOTE	110	LINE	AHERI220- DEVAR-HIPPARAGI	AHERI_220	14:35	15:40	01:05	LINE CLEAR AVAILED
5245	28-Jun-24	BAGALKOTE	110	LINE	AHERI220- MALAGHAN	AHERI_220	14:35	15:40	01:05	LINE CLEAR AVAILED
5246	28-Jun-24	BAGALKOTE	110	LINE	AHERI220- MORATAGI	AHERI_220	16:10	17:05	00:55	LINE CLEAR AVAILED
5247	28-Jun-24	BAGALKOTE	110	LINE	AHERI220- SINDAGI	AHERI_220	16:10	17:05	00:55	LINE CLEAR AVAILED
5248	28-Jun-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-1	AHERI_220	14:35	15:40	01:05	LINE CLEAR AVAILED
5249	28-Jun-24	BAGALKOTE	110	LINE	AHERI220-ALMEL-2	AHERI_220	16:10	17:05	00:55	LINE CLEAR AVAILED
5250	28-Jun-24	BAGALKOTE	110	LINE	ARGA- KARWAR	ARGA_110	21:22	21:25	00:03	LINE CLEAR AVAILED
5251	28-Jun-24	BAGALKOTE	110	LINE	BABALESHWAR -F2 CB (TIKOTA)	STATION NOT AFFECTED BABALESHWAR_110	9:09 (10.05.2024)	13:57 (28.06.2024)	1180:48:00	LINE CLEAR AVAILED
5252	28-Jun-24	BAGALKOTE	110	LINE	BIJAPUR220- BIJAPUR CITY	BIJAPUR_220	14:00	18:28	04:28	LINE CLEAR AVAILED
5253	28-Jun-24	BAGALKOTE	110	LINE	BIJAPUR220- ENERCON	BIJAPUR_220	16:00	17:40	01:40	LINE CLEAR AVAILED
5254	28-Jun-24	BAGALKOTE	110	LINE	BIJAPUR220- KIADB1&2	BIJAPUR_220	14:10	18:46	04:36	LINE CLEAR AVAILED
5255	28-Jun-24	BAGALKOTE	110	LINE	GADAG220-LAXMESHWAR2	GADAG_220	10:38	12:01	01:23	LINE CLEAR AVAILED
5256	28-Jun-24	BAGALKOTE	110	LINE	HATTARAGI- HUKKERI(SANGAM SUGARS)	HATTARAGI_110	06:08	07:43	01:35	TRIPPED ON FAULT
5257	28-Jun-24	BAGALKOTE	110	LINE	HIDIKAL DAM- GHATAPRABAH	HIDIKAL DAM_110	06:14	07:58	01:44	LINE CLEAR AVAILED
5258	28-Jun-24	BAGALKOTE	110	LINE	KMBAG-F2 Cbreaker (TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	18:05 (24.06.2024)	14:31 (28.06.2024)	92:26:00	LINE CLEAR AVAILED
5259	28-Jun-24	BAGALKOTE	110	LINE	KMBAG-F2 Cbreaker (TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	17:45 (28.06.2024)			LINE CLEAR AVAILED
5260	28-Jun-24	BAGALKOTE	110	LINE	KONNUR-KERUR (BAGALKOT)	STATION NOT AFFECTED KONNUR_110	9:05 (28.06.2024)			LINE CLEAR AVAILED
5261	28-Jun-24	BAGALKOTE	110	LINE	LAKMESWR-GADAG1	STATION NOT AFFECETD LAXMESHWAR_110	10:38	12:01	01:23	LINE CLEAR AVAILED
5262	28-Jun-24	BAGALKOTE	110	LINE	MALGHAN-MAMDAPUR (MATTIHAL)	MALGHAN_110	11:06	11:24	00:18	TRIPPED ON FAULT
5263	28-Jun-24	BAGALKOTE	110	LINE	MAMADA-B .BAGEWADI2	MAMADAPUR (B)_110	11:06	14:30	03:24	LINE CLEAR AVAILED
5264	28-Jun-24	BAGALKOTE	110	LINE	MAMADA-SHIRBUR	MAMADAPUR (B)_110	11:06	11:13	00:07	LINE CLEAR AVAILED
5265	28-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5266	28-Jun-24	BAGALKOTE	110	LINE	MUNDAR-VIJAYA SUGARS	STATION NOT AFFECTED MUNADARAGI_110	18:10	18:19	00:09	TRIPPED ON FAULT
5267	28-Jun-24	BAGALKOTE	110	LINE	NARAGU-BPCL	STATION NOT AFFECTED NARAGUND_110	13:36 (28.06.2024)			LINE CLEAR AVAILED
5268	28-Jun-24	BAGALKOTE	110	LINE	NAVALGUND- BIDNAL	NAVALGUND_110	16:04 (25.06.2024)	9:12 (28.06.2024)	65:08:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5269	28-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEBENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
5270	28-Jun-24	BAGALKOTE	110	LINE	SADALA-BORGAON	SADALAGA_110	11:18	13:01	#VALUE!	LINE CLEAR AVAILED
5271	28-Jun-24	BAGALKOTE	110	LINE	SADALA-VPPL	SADALAGA_110	11:19	13:02	01:43	LINE CLEAR AVAILED
5272	28-Jun-24	BAGALKOTE	110	LINE	SANKS110-CHIKKODI	CHIKKODI_110	18:55	19:34	00:39	TRIPPED ON FAULT
5273	28-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5274	28-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
5275	28-Jun-24	BAGALKOTE	110	LINE	TAKLI-TRVCBbreaker(KIADB BIJAPUR)	TAKKALAKI_110	14:00	18:55	04:55	LINE CLEAR AVAILED
5276	28-Jun-24	BAGALKOTE	110	LINE	THORVI- BHUTANAL	THORVI_110	13:55	18:58	05:03	LINE CLEAR AVAILED
5277	28-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)			LINE CLEAR AVAILED
5278	28-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
5279	28-Jun-24	BAGALKOTE	110	LINE	YLWD-F2 Cbreaker (SAVALAGI)	STATION NOT AFFECTED YELLAMANWADI_110	11:48	11:51	00:03	LINE CLEAR AVAILED
5280	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV1&LV1	BIJAPUR_220	14:27	18:48	04:21	LINE CLEAR AVAILED
5281	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2	KARWAR_220	11:05	13:01	01:56	LINE CLEAR AVAILED
5282	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2&LV2	BIJAPUR_220	14:42	17:40	02:58	LINE CLEAR AVAILED
5283	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV2(HV3)	BAGALKOT_220	15:50	17:34	01:44	LINE CLEAR AVAILED
5284	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3	ATHANI_220	16:40	17:24	00:44	LINE CLEAR AVAILED
5285	28-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV, HV3&LV3	BIJAPUR_220	16:00	18:57	02:57	LINE CLEAR AVAILED
5286	28-Jun-24	BAGALKOTE	220	LINE	AHERI-BIJAPUR1	AHERI_220	14:55	15:45	00:50	LINE CLEAR AVAILED
5287	28-Jun-24	BAGALKOTE	220	LINE	AHERI-BIJAPUR2	AHERI_220	16:00	16:45	00:45	LINE CLEAR AVAILED
5288	28-Jun-24	BAGALKOTE	220	LINE	BAGALKOT - VAJARAMATTI1	BAGALKOT_220	10:44	12:09	01:25	LINE CLEAR AVAILED
5289	28-Jun-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI2	BIDNAL_220	7:26 (27.06.2024)			LINE CLEAR AVAILED
5290	28-Jun-24	BAGALKOTE	220	LINE	HUBLI-NARENDRA-1	HUBLI_220	11:49	15:26	03:37	LINE CLEAR AVAILED
5291	28-Jun-24	BAGALKOTE	220	LINE	NARENDRA- HUBLI1	NARENDRA_220	11:48	15:26	03:38	LINE CLEAR AVAILED
5292	28-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
5293	28-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-MAHALINGAPUR (BIDNAL2)	SOUDATTI_220	7:24 (27.06.2024)			LINE CLEAR AVAILED
5294	28-Jun-24	BAGALKOTE	220	LINE	VAJRAMATTI-BAGALKOT -1	VALRAMATTI_220	09:20	12:08	02:48	TRIPPED ON FAULT
5295	28-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - A STATION 66/11KV (A1)	A STATION 66	06:08	06:11	00:03	LINE CLEAR AVAILED
5296	28-Jun-24	BANGALORE	66	LINE	66KV A STATION 220 - SHOBHA INDRAPRASTA (A1)	SHOBHA INDRAPRASTA	06:13	06:26	00:13	LINE CLEAR AVAILED
5297	28-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:01	10:26	00:25	LINE CLEAR AVAILED
5298	28-Jun-24	BANGALORE	66	LINE	66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE)	BANANSAWADI	12:43	14:45	02:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5299	28-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 1	BAGHMANE WORLD TECH PARK	14:56	15:05	00:09	LINE CLEAR AVAILED
5300	28-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - BAGAMANE WTC 2	BAGHMANE WORLD TECH PARK	14:56	15:05	00:09	LINE CLEAR AVAILED
5301	28-Jun-24	BANGALORE	66	LINE	66KV HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:19	15:26	00:07	LINE CLEAR AVAILED
5302	28-Jun-24	BANGALORE	66	LINE	66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)	BANANSAWADI	12:43	14:45	02:02	LINE CLEAR AVAILED
5303	28-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - ANJANAPURA	ANJANAPURA	09:26	09:31	00:05	LINE CLEAR AVAILED
5304	28-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	00:58	01:08	00:10	TRIPPED ON FAULT
5305	28-Jun-24	BANGALORE	66	LINE	66KV KIADB HAROHALLI 220 - VR DODDI	VR DODDI	12:34	12:44	00:10	LINE CLEAR AVAILED
5306	28-Jun-24	BANGALORE	66	LINE	66KV MALUR - LAKKUR	LAKKUR, DEVANAGUNDHI	14:03	14:13	00:10	MAIN SUPPLY FAILURE
5307	28-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - BANGARPET - KGF 2	BANGARPETE	19:30	20:00	00:30	LINE CLEAR AVAILED
5308	28-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	14:03	14:20	00:17	TRIPPED ON FAULT
5309	28-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - VOKKALERI 1 - HOSKOTE 2	JADIGENAHALLI	14:03	14:13	00:10	MAIN SUPPLY FAILURE
5310	28-Jun-24	BANGALORE	66	LINE	66KV MITTEMARI 220 - SADHALI	SADALI	16:00	16:17	00:17	TRIPPED ON FAULT
5311	28-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - SHOBHA INDRAPRASTHA (A1)	SHOBHA INDRAPRASTA	23:08	23:14	00:06	LINE CLEAR AVAILED
5312	28-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD	01:54	02:36	00:42	TRIPPED ON FAULT
5313	28-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	BG ROAD, ANJANAPURA	11:51	12:11	00:20	LINE CLEAR AVAILED
5314	28-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)	ANJANAPURA	11:41	11:47	00:06	LINE CLEAR AVAILED
5315	28-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - ANDERSONPET	ANDERSONPETE	16:00	16:59	00:59	LINE CLEAR AVAILED
5316	28-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 1	KGF, BEML, KAMASAMUDRA, BANGARPETE	16:00	16:59	00:59	LINE CLEAR AVAILED
5317	28-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	NO STATION AFFECTED	16:59	17:19	00:20	LINE CLEAR AVAILED
5318	28-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KGF 2	KGF, BEML, KAMASAMUDRA, BANGARPETE	16:00	16:59	00:59	LINE CLEAR AVAILED
5319	28-Jun-24	BANGALORE	66	LINE	66KV T GOLLAHALLI 220 - KYASAMBALLI	KYASAMBALLI, DODDAKARI	16:00	16:59	00:59	LINE CLEAR AVAILED
5320	28-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA	17:30	17:35	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5321	28-Jun-24	BANGALORE	66	LINE	66KV TK HALLI 220 - IGGALURU	IGGALUR, YETHAMBADI	15:11	15:38	00:27	TRIPPED ON FAULT
5322	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BANANSAWADI	11:11	15:31	04:20	LINE CLEAR AVAILED
5323	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	06:08	06:11	00:03	LINE CLEAR AVAILED
5324	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	14:32	14:36	00:04	LINE CLEAR AVAILED
5325	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KANTEERAVA	18:48	18:52	00:04	LINE CLEAR AVAILED
5326	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KUNDANA	15:45	16:40	00:55	LINE CLEAR AVAILED
5327	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	H GOLLAHALLI	14:00	14:25	00:25	LINE CLEAR AVAILED
5328	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HUKUNDA	09:35	09:40	00:05	TRIPPED ON FAULT
5329	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	CHOKKASANDRA	10:58	11:28	00:30	LINE CLEAR AVAILED
5330	28-Jun-24	BANGALORE	66	TRANSFORMER	HV1	YARANDANAHALLI 220	00:56	01:01	00:05	TRIPPED ON FAULT
5331	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BANANSAWADI	11:00	17:18	06:18	LINE CLEAR AVAILED
5332	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	14:32	14:36	00:04	LINE CLEAR AVAILED
5333	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KANTEERAVA	18:48	18:52	00:04	LINE CLEAR AVAILED
5334	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	TALAGAWARA	12:50	13:20	00:30	LINE CLEAR AVAILED
5335	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	12:40	12:55	00:15	TRIPPED ON FAULT
5336	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	H GOLLAHALLI	13:45	14:00	00:15	LINE CLEAR AVAILED
5337	28-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KUDUR	12:23	12:27	00:04	TRIPPED ON FAULT
5338	28-Jun-24	BANGALORE	66	TRANSFORMER	HV3	BANANSAWADI	12:43	14:45	02:02	LINE CLEAR AVAILED
5339	28-Jun-24	BANGALORE	220	LINE	220KV PUTTENAHALLI 220 - KPCL 3	NO STATION AFFECTED	15:05	15:37	00:32	TRIPPED ON FAULT
5340	28-Jun-24	BANGALORE	220	TRANSFORMER	HV1	MALUR 220	14:03	14:13	00:10	TRIPPED ON FAULT
5341	28-Jun-24	GULBARGA	66	LINE	NEELGUNDA-HARAPPANAHALLI	HARAPPANAHALLI_66	05:30	05:38	00:08	TRIPPED ON FAULT
5342	28-Jun-24	GULBARGA	110	LINE	GABUR-RAICHUR	GABUR_110,GUGAL_110	05:26	05:31	00:05	TRIPPED ON FAULT
5343	28-Jun-24	GULBARGA	110	TRANSFORMER	HV1	FARTHABAD_110	20:30(27.06.2024)			TRIPPED ON FAULT
5344	28-Jun-24	GULBARGA	110	TRANSFORMER	HV1	SIRIGERICROSS_110	11:20	12:40	01:20	LINE CLEAR AVAILED
5345	28-Jun-24	GULBARGA	110	TRANSFORMER	HV1	FHARTABAD_110	23:58	23:59	00:01	TRIPPED ON FAULT
5346	28-Jun-24	GULBARGA	110	TRANSFORMER	HV2	KURUGODU_110	13:20	14:15	00:55	LINE CLEAR AVAILED
5347	28-Jun-24	GULBARGA	110	LINE	KAPNOOR-ALAND	ALAND_110	10:00	17:20	07:20	LINE CLEAR AVAILED
5348	28-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONNATHI	SONNATHI_110	20:05	20:25	00:20	TRIPPED ON FAULT
5349	28-Jun-24	GULBARGA	110	LINE	LINGASUGUR-HATTI	HATTI_110	06:26	06:36	00:10	TRIPPED ON FAULT
5350	28-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	8:52(25.06.2024)			LINE CLEAR AVAILED
5351	28-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	11:30	16:10	04:40	LINE CLEAR AVAILED
5352	28-Jun-24	GULBARGA	110	LINE	SHAHAPUR-YADGIR	YADGIR_110	11:30	16:13	04:43	LINE CLEAR AVAILED
5353	28-Jun-24	GULBARGA	110	LINE	SINDHANOOR- SR NAGAR	SR NAGAR_110	02:35	02:45	00:10	TRIPPED ON FAULT
5354	28-Jun-24	GULBARGA	110	LINE	SINDHANOOR- SR NAGAR	SR NAGAR_110	02:35	02:45	00:10	TRIPPED ON FAULT
5355	28-Jun-24	GULBARGA	110	LINE	SINDHANOOR-MARALIHALLA	MUKUNDA_110	13:00	13:10	00:10	TRIPPED ON FAULT
5356	28-Jun-24	GULBARGA	110	LINE	SINDHANOOR-WALABALLARI	WALABALLARI_110	11:40	11:53	00:13	LINE CLEAR AVAILED
5357	28-Jun-24	GULBARGA	110	LINE	WALKAMDINI-SINDHANOOR	WALKAMDINI_110	05:40	06:00	00:20	MAIN SUPPLY FAILURE
5358	28-Jun-24	GULBARGA	220	LINE	KUDALGI-CYCLIC_IPP	KUDALGI_220	13:40	14:00	00:20	TRIPPED ON FAULT
5359	28-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
5360	28-Jun-24	HASSAN	66	LINE	CHIKABO-KUSHLNAGAR	CHIKABOMMENAHALLI_66	13:20	13:40	00:20	LINE CLEAR AVAILED
5361	28-Jun-24	HASSAN	66	LINE	CHIKABO-SIDPR	CHIKABOMMENAHALLI_66	13:20	13:35	00:15	LINE CLEAR AVAILED
5362	28-Jun-24	HASSAN	66	LINE	HNPR2-MYSOR2	HNPURA_220	19:25	19:33	00:08	TRIPPED ON FAULT
5363	28-Jun-24	HASSAN	66	TRANSFORMER	HV1	BASAVAGHATTA_66	15:55	16:52	00:57	LINE CLEAR AVAILED
5364	28-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHANNARAYAPATTANA_66	11:37	14:13	02:36	LINE CLEAR AVAILED
5365	28-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHIKABOMMENAHALLI_66	13:20	13:40	00:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5366	28-Jun-24	HASSAN	66	TRANSFORMER	HV2	BASAVAGHATTA_66	13:28	15:34	02:06	LINE CLEAR AVAIED
5367	28-Jun-24	HASSAN	66	TRANSFORMER	HV2	CHIKABOMMENAHALLI_66	13:20	13:35	00:15	LINE CLEAR AVAIED
5368	28-Jun-24	HASSAN	66	TRANSFORMER	HV2	HOLALUR_66	17:15	18:20	01:05	LINE CLEAR AVAIED
5369	28-Jun-24	HASSAN	66	LINE	NGRTHI-L2 CB	NAGARTHI_110	19:25	20:20	00:55	MAIN SUPPLY FAILURE
5370	28-Jun-24	HASSAN	110	LINE	HALADY1-HOSANGADI	HALADY_110	19:30(27.06.2024)	9:58(28.6.2024)	14:28HRS	LINE CLEAR AVAIED
5371	28-Jun-24	HASSAN	110	LINE	HOSNGD-HALDY	HOSANAGADI_110	19:30(27.06.2024)	10:19(28.06.2024)	14:49HRS	TRIPPED ON FAULT
5372	28-Jun-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	12:32	13:01	00:29	LINE CLEAR AVAIED
5373	28-Jun-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	13:03	13:34	00:31	LINE CLEAR AVAIED
5374	28-Jun-24	HASSAN	110	TRANSFORMER	HV1	HALADY_110	18:06	18:46	00:40	LINE CLEAR AVAIED
5375	28-Jun-24	HASSAN	110	TRANSFORMER	HV1	NANDIKUR_110	11:20	11:54	00:34	LINE CLEAR AVAIED
5376	28-Jun-24	HASSAN	110	TRANSFORMER	HV2	JADE_110	15:55	16:50	00:55	TRIPPED ON FAULT
5377	28-Jun-24	HASSAN	110	TRANSFORMER	HV2	KARKALA_110	11:24	11:30	00:06	TRIPPED ON FAULT
5378	28-Jun-24	HASSAN	110	LINE	MSEZ-GSS4	MSEZ_220	12:30	15:00	02:30	LINE CLEAR AVAIED
5379	28-Jun-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gersoppa	13:35(28.6.2024)			TRIPPED ON FAULT
5380	28-Jun-24	HASSAN	220	LINE	HGUNJE-VRH CBreaker	HEGGUNJE_220	09:51	18:00	08:09	LINE CLEAR AVAIED
5381	28-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMG_220	13:35(28.6.2024)			TRIPPED ON FAULT
5382	28-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR3	gen_varahi	09:51	18:00	08:09	LINE CLEAR AVAIED
5383	28-Jun-24	MYSORE	66	LINE	220KV HUNSUR-KAMPLAPURA	NO STATIONS EFFECTED	05:05	05:23	00:18	TRIPPED ON FAULT
5384	28-Jun-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAIED
5385	28-Jun-24	MYSORE	66	LINE	HAMPAPURA-JAYAPURA	NO STATIONS EFFECTED	14:00	14:05	00:05	TRIPPED ON FAULT
5386	28-Jun-24	MYSORE	66	LINE	HEBBANI -TK HALLI	NO STATIONS EFFECTED	04:36	07:06	02:30	TRIPPED ON FAULT
5387	28-Jun-24	MYSORE	66	TRANSFORMER	HV1	MANDAGERE_66	19:25	20:25	01:00	LINE CLEAR AVAIED
5388	28-Jun-24	MYSORE	66	TRANSFORMER	HV1	SRIRANGAPATNA_66	13:18	13:25	00:07	TRIPPED ON FAULT
5389	28-Jun-24	MYSORE	66	TRANSFORMER	HV1	YETHAMBADI_66	15:14	15:40	00:25	LINE CLEAR AVAIED
5390	28-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5391	28-Jun-24	MYSORE	66	TRANSFORMER	HV2	SRIRANGAPATNA_66	12:44	12:48	00:04	TRIPPED ON FAULT
5392	28-Jun-24	MYSORE	66	TRANSFORMER	HV2	ADDIHALLI_66	13:58	14:28	00:30	TRIPPED ON FAULT
5393	28-Jun-24	MYSORE	66	TRANSFORMER	HV2	ADDIHALLI_66	14:44	17:24	02:40	TRIPPED ON FAULT
5394	28-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAIED
5395	28-Jun-24	MYSORE	66	LINE	KADAKOLA-NANJANGUDU	NANJANGUDU_66	19:02	19:22	00:19	TRIPPED ON FAULT
5396	28-Jun-24	MYSORE	66	LINE	KADAKOLA-THANDYA	THANDYA_66	19:02	19:22	00:20	TRIPPED ON FAULT
5397	28-Jun-24	MYSORE	66	LINE	KM DODDI-SCSL	NO STATIONS EFFECTED	11:59 (27/06/2024)	14:08 (28/06/2024)	26:08	LINE CLEAR AVAIED
5398	28-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5399	28-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAIED
5400	28-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAIED
5401	28-Jun-24	MYSORE	66	LINE	TALAKADU-CHANDAHALLI	CHANDALLI_66	07:21	07:29	00:08	TRIPPED ON FAULT
5402	28-Jun-24	MYSORE	66	LINE	YETHAMBADI-IGLOOR	K_HONNALGERE_66	15:11	15:40	00:29	TRIPPED ON FAULT
5403	28-Jun-24	TUMKUR	66	LINE	220kv DAVANAGERE-66kv KUKKAWADA LINE 1	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	04:20	04:45	00:25	TRIPPED ON FAULT
5404	28-Jun-24	TUMKUR	66	LINE	66kv CHALLKERE -220kv THALLAK LINE	66kv CHALLKERE	16:56	17:06	00:10	TRIPPED ON FAULT
5405	28-Jun-24	TUMKUR	66	LINE	BALENAHALLI-CHALKERE	CHALKERE_66	16:56	18:33	01:37	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5406	28-Jun-24	TUMKUR	66	LINE	BENKIKERE 220kV- HOSADURGA LINE 1 & 2 (MADHURE)	HOSADURGA_220	11:54	18:22	06:28	LINE CLEAR AVAIED
5407	28-Jun-24	TUMKUR	66	TRANSFORMER	TR-2(12.5MVA)	ANCHEPALYA_66	07:05	07:15	00:10	TRIPPED ON FAULT
5408	28-Jun-24	TUMKUR	110	LINE	NITTUR 220kV- KALLUR	KALLUR_110	12:52	14:40	01:48	LINE CLEAR AVAIED
5409	28-Jun-24	TUMKUR	110	LINE	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	12:52	14:40	01:48	LINE CLEAR AVAIED
5410	28-Jun-24	TUMKUR	110	LINE	SAMPIGE- DODDAGUNI	DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110	04:00	04:20	00:20	MAIN SUPPLY FAILURE
5411	28-Jun-24	TUMKUR	220	LINE	220kV ANTHARASANAHALI- 220kV K B CROSS (NELAMANGALA) LINE	110kV BANDHIHALLI, KARADI,KEREKODI, TIPTUR,HUNSEGATTA,HALKURKE,AMMASANDRA, SAMPIGE,TURUVEKERE, NONAVINAKERE, THANDGA, GUNGURUMALE,C N HALLI,SHETTIKERE THIMMANAHALLI KATHRIKEHAL	04:01	08:07	04:06	TRIPPED ON FAULT
5412	28-Jun-24	TUMKUR	220	LINE	220kV ANTHARASANAHALI- 220kV SHIVAMOGGA LINE	ANTHRASANAHALLI_220	06:20	10:47	04:27	TRIPPED ON FAULT
5413	28-Jun-24	TUMKUR	220	LINE	HOSADURGA220-BENKIKERE 2	HOSADURGA_220	12:00	18:20	06:20	LINE CLEAR AVAIED
5414	28-Jun-24	TUMKUR	220	TRANSFORMER	TR-1(100MVA)	CHITRADURGA_220	10:00	15:00	05:00	LINE CLEAR AVAIED
5415	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	BELLATTI_110	10:33	17:09	06:36	LINE CLEAR AVAIED
5416	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	GULEDAGUDDA_110	09:30	10:42	01:12	LINE CLEAR AVAIED
5417	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BJCTY (THORVI)_110	18:01	18:06	00:05	TRIPPED ON FAULT
5418	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	KALGHATAGI_110	06:05	06:16	00:11	TRIPPED ON FAULT
5419	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (20MVA)	BAGALKOT_110	09:05	11:05	02:00	LINE CLEAR AVAIED
5420	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1&HV2(10MVA)	TALIKOTE_110	11:24	15:33	04:09	LINE CLEAR AVAIED
5421	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MUKARTIHAL_110	07:12	07:17	00:05	TRIPPED ON FAULT
5422	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	LOKAPUR_110	09:21	18:40	09:19	LINE CLEAR AVAIED
5423	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	LAXMESHWAR_110	13:41	16:39	02:58	LINE CLEAR AVAIED
5424	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	UTTUR_110	15:54	16:02	00:08	TRIPPED ON FAULT
5425	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	KULAGERI CROSS_110	10:45	18:03	07:18	LINE CLEAR AVAIED
5426	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BELLATTI_110	10:53	17:16	06:23	LINE CLEAR AVAIED
5427	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2 (10MVA)	BAGALKOT_110	09:05	11:05	02:00	LINE CLEAR AVAIED
5428	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	KULAGERI CROSS_110	10:46	15:04	04:18	LINE CLEAR AVAIED
5429	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	HIDIKAL DAM_110	10:36	10:38	00:02	LINE CLEAR AVAIED
5430	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	LOKAPUR_110	10:03	18:40	08:37	LINE CLEAR AVAIED
5431	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	LAXMESHWAR_110	10:13	12:51	02:38	LINE CLEAR AVAIED
5432	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	HIDIKAL DAM_110	10:59	15:09	04:10	LINE CLEAR AVAIED
5433	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	HUKKERI_110	22:37 (29.06.2024)			LINE CLEAR AVAIED
5434	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (20MVA)	KERUR_110	09:16	14:14	04:58	LINE CLEAR AVAIED
5435	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	GULEDAGUDDA_110	12:00	13:29	01:29	LINE CLEAR AVAIED
5436	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(10MVA)	LAXMESHWAR_110	16:39	17:52	01:13	LINE CLEAR AVAIED
5437	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV3 (20MVA)	BELLATTI_110	10:27	17:16	06:49	LINE CLEAR AVAIED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5438	29-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV,HV3&HV4(20MVA)	MACHE_110	11:24	13:23	01:59	LINE CLEAR AVAILED
5439	29-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
5440	29-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	KARWAR_220	11:46	12:01	0:15	LINE CLEAR AVAILED
5441	29-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	BAGALKOT_220	10:00	17:22	07:22	LINE CLEAR AVAILED
5442	29-Jun-24	BAGALKOTE	110	LINE	ATHANI220- BALIGERI	ATHANI_220	5:47	6:06	0:19	TRIPPED ON FAULT
5443	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT110- SIGIKERI(BAGALKOT220)	BAGALKOT_110	09:05	11:05	02:00	LINE CLEAR AVAILED
5444	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F10KALADAGI	BAGALKOT_220	11:06	11:58	00:52	LINE CLEAR AVAILED
5445	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F6KERUR	BAGALKOT_220	09:46	14:08	04:22	LINE CLEAR AVAILED
5446	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F7RAMDURG	BAGALKOT_220	09:45	14:10:00	04:25	LINE CLEAR AVAILED
5447	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220-F8LOKAPUR	BAGALKOT_220	12:29	14:42	02:13	LINE CLEAR AVAILED
5448	29-Jun-24	BAGALKOTE	110	LINE	BAGALKOT220- F9NEERABUDIHAI	BAGALKOT_220	10:14	12:13	01:59	LINE CLEAR AVAILED
5449	29-Jun-24	BAGALKOTE	110	LINE	BELGAUM220- ANKALAGI(HUDALI)	BELGAUM_220	12:24	13:55	1:31	LINE CLEAR AVAILED
5450	29-Jun-24	BAGALKOTE	110	LINE	BELGAUM220-MACHE	BELGAUM_220	10:39	15:56	5:17	LINE CLEAR AVAILED
5451	29-Jun-24	BAGALKOTE	110	LINE	BELLATTI-ENERCON WIND	ENERCONE WIND_110 BELLATTI_110	10:40	16:44	06:04	LINE CLEAR AVAILED
5452	29-Jun-24	BAGALKOTE	110	LINE	GADAG220-GADAG	GADAG_220	14:28	15:43	01:15	LINE CLEAR AVAILED
5453	29-Jun-24	BAGALKOTE	110	LINE	HIREHAL- IDLE(BADAMI)	HIREHAL_110	10:07	13:00	02:53	LINE CLEAR AVAILED
5454	29-Jun-24	BAGALKOTE	110	LINE	HUDLI- BELGAUM220	HUDLI_110	12:20	13:55	01:35	LINE CLEAR AVAILED
5455	29-Jun-24	BAGALKOTE	110	LINE	HUNGUND- BAGEWADI (KUDAL SANGAM)	HUNGUND_110	05:47	05:54	00:07	TRIPPED ON FAULT
5456	29-Jun-24	BAGALKOTE	110	LINE	KERUR- BADAMI	KERUR_110	09:16	14:55	05:39	LINE CLEAR AVAILED
5457	29-Jun-24	BAGALKOTE	110	LINE	KERUR- BAGALKOT	KERUR_110	09:15	14:08	04:53	LINE CLEAR AVAILED
5458	29-Jun-24	BAGALKOTE	110	LINE	KERUR- KONNUR	KERUR_110	09:16	12:32	03:16	LINE CLEAR AVAILED
5459	29-Jun-24	BAGALKOTE	110	LINE	KERUR- KONNUR	KERUR_110	13:36	14:26	00:50	LINE CLEAR AVAILED
5460	29-Jun-24	BAGALKOTE	110	LINE	KMBAG-F2 Cbreaker (TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	17:45 (28.06.2024)			LINE CLEAR AVAILED
5461	29-Jun-24	BAGALKOTE	110	LINE	KONNUR-KERUR (BAGALKOT)	STATION NOT AFFECTED KONNUR_110	9:05 (28.06.2024)	9:15 (29.06.2024)	24:10:00	LINE CLEAR AVAILED
5462	29-Jun-24	BAGALKOTE	110	LINE	KULAGERI CROSS- KERUR	KULAGERI CROSS_110	09:06	12:31	03:25	LINE CLEAR AVAILED
5463	29-Jun-24	BAGALKOTE	110	LINE	KULAGERI CROSS- KERUR	KULAGERI CROSS_110	13:53	17:57	04:04	LINE CLEAR AVAILED
5464	29-Jun-24	BAGALKOTE	110	LINE	KULAGERI CROSS- KONNUR	KULAGERI CROSS_110	10:02	10:57	00:55	LINE CLEAR AVAILED
5465	29-Jun-24	BAGALKOTE	110	LINE	KULAGERI CROSS- MRN SUGARS	KULAGERI CROSS_110	10:02	11:07	01:05	LINE CLEAR AVAILED
5466	29-Jun-24	BAGALKOTE	110	LINE	KUMATA- SIRSI1	KUMATA_110	11:56	19:16	07:20	TRIPPED ON FAULT
5467	29-Jun-24	BAGALKOTE	110	LINE	MAMADAPUR- BAGEWADI2	MAMADAPUR(B)_110	09:51	12:00	02:09	LINE CLEAR AVAILED
5468	29-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5469	29-Jun-24	BAGALKOTE	110	LINE	NARAGU-BPCL	STATION NOT AFFECTED NARAGUND_110	13:36 (28.06.2024)			LINE CLEAR AVAILED
5470	29-Jun-24	BAGALKOTE	110	LINE	RAMDURG- SODATTI(BAGALKOT)	RAMDURGA_110	09:47	20:21	10:34	LINE CLEAR AVAILED
5471	29-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEKENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
5472	29-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMTA2	SIRSI_110	15:12	19:12	04:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5473	29-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMTA2	SIRSI_110	19:32 (29.06.2024)			TRIPPED ON FAULT
5474	29-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5475	29-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
5476	29-Jun-24	BAGALKOTE	110	LINE	TALIKOTE- FPEL SOLAR	TALIKOTE_110	11:24	15:41	04:17	LINE CLEAR AVAILED
5477	29-Jun-24	BAGALKOTE	110	LINE	UDAYMBAG-MACHE	STATION NOT AFFECTED UDYAMBAG_110	6:25 (04.05.2024)	10:34 (29.06.2024)	1348:09:00	LINE CLEAR AVAILED
5478	29-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED
5479	29-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	KARWAR_220	11:43	11:59	00:16	LINE CLEAR AVAILED
5480	29-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	BAGALKOT_220	10:00	17:17	07:17	LINE CLEAR AVAILED
5481	29-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV3,LV3	SOUNDATTI_220,BENAKATTI_1 10,YARAGATTI_110,KATAKOL_ 110,ITNAL_110,MUGALIHAI_11 0	14:16	15:40	01:24	TRIPPED ON FAULT
5482	29-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI	11:18 (29.06.2024)			LINE CLEAR AVAILED
5483	29-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI	11:15 (29.06.2024)			LINE CLEAR AVAILED
5484	29-Jun-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI2	BIDNAL_220	7:26 (27.06.2024)			LINE CLEAR AVAILED
5485	29-Jun-24	BAGALKOTE	220	LINE	GADAG220-LINGAPUR(DHONI2)	GADAG_220	12:46	13:33	00:47	TRIPPED ON FAULT
5486	29-Jun-24	BAGALKOTE	220	LINE	KARWAR-KADRA1	KARWAR_220	09:45	19:56	10:11	LINE CLEAR AVAILED
5487	29-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
5488	29-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-MAHALINGAPUR (BIDNAL2)	SOUDATTI_220	7:24 (27.06.2024)			LINE CLEAR AVAILED
5489	29-Jun-24	BAGALKOTE	220	LINE	VAJJARMATTI-BAGALKOT LINE- 1	VAJJARMATTI_220	1:22	1:36	0:14	TRIPPED ON FAULT
5490	29-Jun-24	BANGALORE	66	LINE	66KV CHIKKENAHALLI - SHIVANAHALLI - VANDARGUPPE - CHANNAPATNA	SHIVANAHALLI	09:46	09:56	00:10	TRIPPED ON FAULT
5491	29-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:00	10:10	00:10	LINE CLEAR AVAILED
5492	29-Jun-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	11:50	11:52	00:02	LINE CLEAR AVAILED
5493	29-Jun-24	BANGALORE	66	LINE	66KV D CROSS - KANASWADI	KANASAWADI	18:00	18:02	00:02	LINE CLEAR AVAILED
5494	29-Jun-24	BANGALORE	66	LINE	66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK	DEVARABISANAHALLI, GLOBAL TECH PARK	10:03	10:14	00:11	TRIPPED ON FAULT
5495	29-Jun-24	BANGALORE	66	LINE	66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW	SHOBHA FOREST VIEW	10:52	10:56	00:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5496	29-Jun-24	BANGALORE	66	LINE	66KV KHODAYS 220 - SOUTH CITY	SOUTH CITY	09:34	09:40	00:06	LINE CLEAR AVAILED
5497	29-Jun-24	BANGALORE	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	08:50	09:10	00:20	LINE CLEAR AVAILED
5498	29-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	VEMGAL, KYALANUR, TALAGUNDA, TALAGAWARA	12:58	13:11	00:13	TRIPPED ON FAULT
5499	29-Jun-24	BANGALORE	66	LINE	66KV NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	11:57	12:06	00:09	LINE CLEAR AVAILED
5500	29-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SALU, KANASWADI	09:46	09:54	00:08	TRIPPED ON FAULT
5501	29-Jun-24	BANGALORE	66	LINE	66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA, GUNDAMGERE, SALU, KANASWADI	13:51	14:03	00:12	TRIPPED ON FAULT
5502	29-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	09:16	09:25	00:09	TRIPPED ON FAULT
5503	29-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	12:51	13:10	00:19	TRIPPED ON FAULT
5504	29-Jun-24	BANGALORE	66	LINE	66KV RMV - TATA INSTITUTE EHT	IISc(EHT)	12:23	13:22	00:59	LINE CLEAR AVAILED
5505	29-Jun-24	BANGALORE	66	LINE	66KV SAHAKARNAGAR 220 - SAHAKARNAGAR 66	SAHAKARINAGAR 66	10:55	15:44	04:49	LINE CLEAR AVAILED
5506	29-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - ISKCON	ISKCON	10:50	10:58	00:08	LINE CLEAR AVAILED
5507	29-Jun-24	BANGALORE	66	LINE	66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)	SOUTH CITY	07:30	07:35	00:05	LINE CLEAR AVAILED
5508	29-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT	MAHALAKSHMI LAYOUT	11:55	11:57	00:02	LINE CLEAR AVAILED
5509	29-Jun-24	BANGALORE	66	LINE	66KV SRS PEENYA 220 - PLATINUM CITY DG-4	PLATINUM CITY	09:45	10:00	00:15	LINE CLEAR AVAILED
5510	29-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SHOBHA FOREST VIEW - KHODAYS	SHOBHA FOREST VIEW	15:27	15:30	00:03	LINE CLEAR AVAILED
5511	29-Jun-24	BANGALORE	66	LINE	66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON	ISKCON	15:46	15:52	00:06	LINE CLEAR AVAILED
5512	29-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA	10:00	10:10	00:10	LINE CLEAR AVAILED
5513	29-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA	12:58	13:18	00:20	LINE CLEAR AVAILED
5514	29-Jun-24	BANGALORE	66	LINE	66KV TALAGAWARA - CHEEMANGALA	CHEEMANGALA	18:19	18:29	00:10	LINE CLEAR AVAILED
5515	29-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	DEVARABISANAHALLI, GLOBAL TECH PARK	19:02	19:07	00:05	LINE CLEAR AVAILED
5516	29-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - GTP	GLOBAL TECH PARK	19:20	19:24	00:04	LINE CLEAR AVAILED
5517	29-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	10:05	11:40	01:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5518	29-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - PRIMAL	PRIMAL	19:28	19:31	00:03	LINE CLEAR AVAILED
5519	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BYATARAYANAPURA	03:20	03:45	00:25	TRIPPED ON FAULT
5520	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SAHAKARINAGAR 66	10:15	14:30	04:15	LINE CLEAR AVAILED
5521	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	A STATION 66	06:08	06:09	00:01	LINE CLEAR AVAILED
5522	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	MAHALAKSHMI LAYOUT	11:45	11:55	00:10	LINE CLEAR AVAILED
5523	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ITI 220	10:00	10:13	00:13	LINE CLEAR AVAILED
5524	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NANDAGUDI	13:06	13:16	00:10	TRIPPED ON FAULT
5525	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VOLVO	06:30	06:40	00:10	TRIPPED ON FAULT
5526	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NALLIMARADANAHALLI	10:30	11:25	00:55	LINE CLEAR AVAILED
5527	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NARASAPURA	13:35	14:00	00:25	LINE CLEAR AVAILED
5528	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BIJJAHALLI	10:10	12:10	02:00	LINE CLEAR AVAILED
5529	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	GUDEMARANAHALLI	08:40	09:10	00:30	LINE CLEAR AVAILED
5530	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	HULLENAHALLI	08:35	09:15	00:40	LINE CLEAR AVAILED
5531	29-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BV HALLI	06:55	07:30	00:35	TRIPPED ON FAULT
5532	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SAHAKARINAGAR 66	12:05	15:44	03:39	LINE CLEAR AVAILED
5533	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MAHALAKSHMI LAYOUT	11:45	11:55	00:10	LINE CLEAR AVAILED
5534	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NALLIMARADANAHALLI	06:45	06:50	00:05	LINE CLEAR AVAILED
5535	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	02:00	02:30	00:30	TRIPPED ON FAULT
5536	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	02:35	02:55	00:20	TRIPPED ON FAULT
5537	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BYRAKUR	10:35	10:52	00:17	TRIPPED ON FAULT
5538	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	NARASAPURA	13:00	13:30	00:30	LINE CLEAR AVAILED
5539	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	MASTHI	13:49	14:14	00:25	TRIPPED ON FAULT
5540	29-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	13:18	13:24	00:06	TRIPPED ON FAULT
5541	29-Jun-24	BANGALORE	66	TRANSFORMER	HV3	SAHAKARINAGAR 66	12:00	14:30	02:30	LINE CLEAR AVAILED
5542	29-Jun-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 1	TALAGAWADI, KM DODDI, KK DODDI, TUMBGERE, KIADB MANDYA	16:50	17:08	00:18	TRIPPED ON FAULT
5543	29-Jun-24	BANGALORE	66	LINE	TK HALLI 220 - MANDYA 2	TALAGAWADI, KM DODDI, KK DODDI, TUMBGERE, KIADB MANDYA	16:50	17:02	00:12	TRIPPED ON FAULT
5544	29-Jun-24	GULBARGA	66	TRANSFORMER	HV2	BANVEKAL_66	14:00	14:25	00:25	LINE CLEAR AVAILED
5545	29-Jun-24	GULBARGA	66	TRANSFORMER	HV2	HALAVAGALU_66	18:05	18:10	00:05	TRIPPED ON FAULT
5546	29-Jun-24	GULBARGA	66	LINE	NEELGUNDA-TELGI	TELGI_66, KURUBANAHALLI_66, OBJ HALLI_66	20:20	20:26	00:06	TRIPPED ON FAULT
5547	29-Jun-24	GULBARGA	66	LINE	NEELGUNDA-TELGI	TELGI_66, KURUBANAHALLI_66, OBJ HALLI_66	22:23	22:30	00:07	TRIPPED ON FAULT
5548	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-KHANAPUR-1	KHANAPUR_110	11:15	13:35	13:35	LINE CLEAR AVAILED
5549	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-KHANAPUR-2	KHANAPUR_110	11:15	13:35	13:35	LINE CLEAR AVAILED
5550	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-M.KOLLUR	M.KOLLUR_110	17:22	18:53	01:31	TRIPPED ON FAULT
5551	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-NAGNOOR	NAGNOOR_110	10:08	15:23	05:15	LINE CLEAR AVAILED
5552	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-RAICHUR-2	DEVAPUR_110	17:22	19:03	01:41	TRIPPED ON FAULT
5553	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	18:58	19:03	00:05	TRIPPED ON FAULT
5554	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	19:58	20:18	00:20	TRIPPED ON FAULT
5555	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	20:52	21:10	00:18	TRIPPED ON FAULT
5556	29-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	21:10	23:59	02:49	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5557	29-Jun-24	GULBARGA	110	LINE	HATTIGUGUDUR-KEMBHAVI	KEMBHAVI_110	10:07	15:22	05:15	LINE CLEAR AVAIED
5558	29-Jun-24	GULBARGA	110	LINE	HUMNABAD-BHALKI	BHALKI_110	19:05	19:25	00:20	TRIPPED ON FAULT
5559	29-Jun-24	GULBARGA	110	TRANSFORMER	HV1	FHARTABAD_110	23:59	18:55	18:56	LINE CLEAR AVAIED
5560	29-Jun-24	GULBARGA	110	TRANSFORMER	HV1 & HV2	ITTAGI_220	10:30	17:17	06:47	LINE CLEAR AVAIED
5561	29-Jun-24	GULBARGA	110	TRANSFORMER	HV2	NAGNOOR_110	10:00	17:23	07:23	LINE CLEAR AVAIED
5562	29-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	YADGIR_110	19:25	22:16	02:51	TRIPPED ON FAULT
5563	29-Jun-24	GULBARGA	110	LINE	KOLURU-DEODURGA	KOLURU_110	17:20	18:05	00:45	TRIPPED ON FAULT
5564	29-Jun-24	GULBARGA	110	LINE	MALLAPURA-SULEKAL	MALLAPURA_110	09:05	09:15	00:10	LINE CLEAR AVAIED
5565	29-Jun-24	GULBARGA	110	LINE	MALLAPURA-SULEKAL	MALLAPURA_110	14:50	15:00	00:10	LINE CLEAR AVAIED
5566	29-Jun-24	GULBARGA	110	LINE	MALLAPURA-SULEKAL	MALLAPURA_110	17:20	17:22	00:02	LINE CLEAR AVAIED
5567	29-Jun-24	GULBARGA	110	LINE	MUNIRABBAD-SULEKAL	GANGAVATHI_110	08:50	09:15	00:25	MAIN SUPPLY FAILURE
5568	29-Jun-24	GULBARGA	110	LINE	MUNIRABBAD-SULEKAL	GANGAVATHI_110	14:05	14:15	00:10	MAIN SUPPLY FAILURE
5569	29-Jun-24	GULBARGA	110	LINE	SHAHPUR-KOLURU	KOLURU_110	17:20	18:51	01:31	MAIN SUPPLY FAILURE
5570	29-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	03:52	04:02	00:10	TRIPPED ON FAULT
5571	29-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	18:55	19:05	00:10	TRIPPED ON FAULT
5572	29-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	20:00	20:20	00:20	TRIPPED ON FAULT
5573	29-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	20:55	21:05	00:10	TRIPPED ON FAULT
5574	29-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	21:05	00:00	02:55	LINE CLEAR AVAIED
5575	29-Jun-24	GULBARGA	220	TRANSFORMER	HV2	HATTIGUDUR_220	12:53	15:10	02:17	LINE CLEAR AVAIED
5576	29-Jun-24	GULBARGA	220	TRANSFORMER	HV3	ALLIPUR_220	11:34	11:37	10:15	LINE CLEAR AVAIED
5577	29-Jun-24	GULBARGA	220	LINE	ITTAGI-BMM_IPP	ITTAGI_220	22:17	23:49	09:15	LINE CLEAR AVAIED
5578	29-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAIED
5579	29-Jun-24	HASSAN	66	TRANSFORMER	HV1	CHIKMA	12:52	15:56	03:04	LINE CLEAR AVAIED
5580	29-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR	03:00	03:05	00:05	TRIPPED ON FAULT
5581	29-Jun-24	HASSAN	110	LINE	GURUVA-KEMAR2	GURUVA	20:36	20:50	00:14	MAIN SUPPLY FAILURE
5582	29-Jun-24	HASSAN	110	TRANSFORMER	HV4	PUTUR11	10:36	11:52	01:16	LINE CLEAR AVAIED
5583	29-Jun-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gersoppa	13:35(28.6.2024)			LINE CLEAR AVAIED
5584	29-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMG_220	13:35(28.6.2024)			LINE CLEAR AVAIED
5585	29-Jun-24	HASSAN	220	LINE	VARAHI-KEMAR2	VARAHI	10:43	11:52	01:09	LINE CLEAR AVAIED
5586	29-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	VARAHI	03:01	08:14	05:13	TRIPPED ON FAULT
5587	29-Jun-24	MYSORE	66	LINE	CHIKKA MANDYA-MANDYA	NO STATIONS EFFECTED	10:49	16:37	05:48	LINE CLEAR AVAIED
5588	29-Jun-24	MYSORE	66	LINE	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:17	12:15	01:58	LINE CLEAR AVAIED
5589	29-Jun-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAIED
5590	29-Jun-24	MYSORE	66	LINE	HONGANURU-YELANDUR	NO STATIONS EFFECTED	03:03	03:10	00:07	TRIPPED ON FAULT
5591	29-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5592	29-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAIED
5593	29-Jun-24	MYSORE	66	LINE	KM DODDI-TK-HALLI-MANDYA(M1)	KMDODDI_66 KOLKARANADODDI_66	16:48	17:09	00:21	MAIN SUPPLY FAILURE
5594	29-Jun-24	MYSORE	66	LINE	MADDUR-SOMANAHALLI	NO STATIONS EFFECTED	10:54	14:35	03:40	LINE CLEAR AVAIED
5595	29-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5596	29-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAIED
5597	29-Jun-24	MYSORE	66	LINE	MANDAKALLI-KADAKOLA	NO STATIONS EFFECTED	06:44	07:00	00:16	TRIPPED ON FAULT
5598	29-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAIED
5599	29-Jun-24	MYSORE	66	LINE	TALAGAVADI-TK-HALLI(M2)	TALAGAVADI_66 KIADBMANDYA_66 TUMBEKERE_66	16:48	17:03	00:15	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5600	29-Jun-24	MYSORE	66	LINE	THANDYA-NANJUNGUD	NO STATIONS EFFECTED	10:40	13:28	02:48	LINE CLEAR AVAILED
5601	29-Jun-24	MYSORE	66	LINE	TUBINKERE-MANDYA 2	NO STATIONS EFFECTED	11:00	12:52	01:52	LINE CLEAR AVAILED
5602	29-Jun-24	MYSORE	66	LINE	TUBINKERE-MANDYA 4	NO STATIONS EFFECTED	12:53	14:31	01:37	LINE CLEAR AVAILED
5603	29-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV MAYAKONDA LINE	66KV MAYAKONDA	06:12	06:28	00:16	TRIPPED ON FAULT
5604	29-Jun-24	TUMKUR	66	LINE	220KV MADHURE-66KV HOSADURGA LINE	66KV HOSADURGA,NEERGUNDA GATE	07:05	07:15	00:10	TRIPPED ON FAULT
5605	29-Jun-24	TUMKUR	66	LINE	220KV THALLAK-66KV P.R PURA LINE	66KV MYLANAHALLI ,VV PURA	19:13	19:26	00:13	TRIPPED ON FAULT
5606	29-Jun-24	TUMKUR	66	LINE	66KV PANDARAHALLI-66KV HOLALKERE LINE	66KV HOLALKERE,CHIKKAJAJUR,SA SALUHALLA	08:10	08:25	00:15	TRIPPED ON FAULT
5607	29-Jun-24	TUMKUR	66	LINE	66KV TURUVANUR-220KV CHITRADURGA LINE	66KV TURUVANUR,JAGALUR, BIDARKERE	07:32	07:42	00:10	TRIPPED ON FAULT
5608	29-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	09:10	17:05	07:55	LINE CLEAR AVAILED
5609	29-Jun-24	TUMKUR	66	LINE	THALLAK 220-P R PURA	PR PURA_66,MYLANAHALLI_66, V V PORA_66, DYAVARANAHALLI_66	19:13	19:26	00:13	TRIPPED ON FAULT
5610	29-Jun-24	TUMKUR	110	LINE	220KV K.B CROSS-110KV HANDANKERE LINE	110KV HULIYAR, HANDANKERE, DODDAYENNEGERE	11:10	11:25	00:15	TRIPPED ON FAULT
5611	29-Jun-24	TUMKUR	110	LINE	KB CROSS 220KV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	15:46	17:15	01:29	LINE CLEAR AVAILED
5612	29-Jun-24	TUMKUR	220	LINE	ANTHRASANAHALLI 220KV-SHIMOGA	ANTHRASANAHALLI_220	12:10	17:35	05:25	LINE CLEAR AVAILED
5613	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HIDIKAL_110	10:30	18:25	07:55	LINE CLEAR AVAILED
5614	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	HIDIKAL_110	10:30	18:25	07:55	LINE CLEAR AVAILED
5615	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1 (10MVA)	KAVALWADA_110	10:15	10:20	00:05	LINE CLEAR AVAILED
5616	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(10MVA)	MUKARTIHAL_110	11:13	13:45	02:32	LINE CLEAR AVAILED
5617	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	TIKOTA_110	14:30	15:21	00:51	LINE CLEAR AVAILED
5618	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV1(20MVA)	MRUTHYUNJAY NAGAR_110	06:06	15:29	09:23	LINE CLEAR AVAILED
5619	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	TALIKOTE_110	10:01	10:14	00:13	TRIPPED ON FAULT
5620	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	TARIHAL_110	10:50	18:31	07:41	LINE CLEAR AVAILED
5621	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(10MVA)	MRUTHYUNJAY NAGAR_110	07:02	08:24	01:22	LINE CLEAR AVAILED
5622	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV2(20MVA)	MUKARTIHAL_110	11:13	13:45	02:32	LINE CLEAR AVAILED
5623	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	HUKKERI_110	22:37 (29.06.2024)	00:33 (30.06.2024)	1:56:00	LINE CLEAR AVAILED
5624	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV3(20MVA)	TIKOTA_110	16:26	16:49	00:23	LINE CLEAR AVAILED
5625	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/11KV, HV4 (10 MVA)	BAILHONGAL_110	09:48	12:46	02:58	LINE CLEAR AVAILED
5626	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	HIDIKAL_110	10:30	18:25	07:55	LINE CLEAR AVAILED
5627	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2 (20MVA)	HIDIKAL_110	10:30	18:25	07:55	LINE CLEAR AVAILED
5628	30-Jun-24	BAGALKOTE	110	TRANSFORMER	110/33KV, HV2(20MVA)	TARIHAL_110	10:50	18:34	07:44	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5629	30-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:18 (03.06.2024)			LINE CLEAR AVAILED
5630	30-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV1	MK HUBLI_220	14:32	15:35	1:03	LINE CLEAR AVAILED
5631	30-Jun-24	BAGALKOTE	110	TRANSFORMER	220/110KV,LV2	MK HUBLI_220	14:32	15:35	1:03	LINE CLEAR AVAILED
5632	30-Jun-24	BAGALKOTE	110	LINE	BIJAPUR220-KIADB2	BIJAPUR_220	10:01	10:13	00:12	TRIPPED ON FAULT
5633	30-Jun-24	BAGALKOTE	110	LINE	GADAG220-BETAGERI	GADAG_220	12:14	16:16	04:02	LINE CLEAR AVAILED
5634	30-Jun-24	BAGALKOTE	110	LINE	GADAG220-BETAGERI	GADAG_220	18:20	20:22	02:02	LINE CLEAR AVAILED
5635	30-Jun-24	BAGALKOTE	110	LINE	HATTARAGI-SANGAM SUGARS	HATTARAGI_110	01:06	01:19	00:13	TRIPPED ON FAULT
5636	30-Jun-24	BAGALKOTE	110	LINE	HIDIKALL-MAHALINGAPUR	HIDIKAL_110	10:24	18:25	08:01	LINE CLEAR AVAILED
5637	30-Jun-24	BAGALKOTE	110	LINE	ITANAL- BPCL	ITANAL_110	10:13	13:35	03:22	LINE CLEAR AVAILED
5638	30-Jun-24	BAGALKOTE	110	LINE	ITANAL- HIDIKAL	ITANAL_110	10:14	18:00	07:46	LINE CLEAR AVAILED
5639	30-Jun-24	BAGALKOTE	110	LINE	ITANAL- KABBUR1	ITANAL_110	10:07	13:20	03:13	LINE CLEAR AVAILED
5640	30-Jun-24	BAGALKOTE	110	LINE	ITANAL- KABBUR3	ITANAL_110	10:10	13:28	03:18	LINE CLEAR AVAILED
5641	30-Jun-24	BAGALKOTE	110	LINE	KMBAG-F2 Cbreaker (TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	17:45 (28.06.2024)	11:45 (30.06.2024)	42:00:00	LINE CLEAR AVAILED
5642	30-Jun-24	BAGALKOTE	110	LINE	KUDUCHI220-KUDUCHI(AINAPUR)	KUDACHI_220	13:39	14:15	00:36	TRIPPED ON FAULT
5643	30-Jun-24	BAGALKOTE	110	LINE	MAHALINGAPUR220-HIDIKAL	MAHALINGAPUR_220	10:40	18:22	7:42	LINE CLEAR AVAILED
5644	30-Jun-24	BAGALKOTE	110	LINE	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
5645	30-Jun-24	BAGALKOTE	110	LINE	MRUTHYUNJAY NAGAR-GOPPANAKOPPA	MRUTHYUNJAY NAGAR_110	07:01	08:23	01:22	LINE CLEAR AVAILED
5646	30-Jun-24	BAGALKOTE	110	LINE	MRUTHYUNJAY NAGAR-NARENDRA1&2	MRUTHYUNJAY NAGAR_110	07:01	08:22	01:21	LINE CLEAR AVAILED
5647	30-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220-ITNAL1 ltnal-1	MUGALKHOD_220	10:07	13:28	03:21	LINE CLEAR AVAILED
5648	30-Jun-24	BAGALKOTE	110	LINE	MUGALKHOD220-ITNAL3	MUGALKHOD_220	10:10	13:27	03:17	LINE CLEAR AVAILED
5649	30-Jun-24	BAGALKOTE	110	LINE	NARAGU-BPCL	STATION NOT AFFECTED NARAGUND_110	13:36 (28.06.2024)	20:13 (30.06.2024)	54:37:00	LINE CLEAR AVAILED
5650	30-Jun-24	BAGALKOTE	110	LINE	NAREGAL- BETAGERI	NAREGAL_110	10:52	16:35	05:43	LINE CLEAR AVAILED
5651	30-Jun-24	BAGALKOTE	110	LINE	RATHIHAL-RANEENNUR (HIREKERUR)	STATION NOT AFFECTED RATTIHALLI_110	13:40 (25.04.2024)			LINE CLEAR AVAILED
5652	30-Jun-24	BAGALKOTE	110	LINE	SIRSI- KUMTA2	SIRSI_110	19:32 (29.06.2024)	13:34 (30.06.2024)	18:02:00	TRIPPED ON FAULT
5653	30-Jun-24	BAGALKOTE	110	LINE	SRS HUBLI220- ANANDNAGAR	STATION NOT AFFECTED HUBLI_220	8:13 (24.03.2024)			LINE CLEAR AVAILED
5654	30-Jun-24	BAGALKOTE	110	LINE	TADASINAKOPPA-KUD DHARWAD (GAMANAGHATTI)	STATION NOT AFFECTED TADASINAKOPPA_110	21:51 (14.05.2024)			LINE CLEAR AVAILED
5655	30-Jun-24	BAGALKOTE	110	LINE	TADASINKOPPA- KUD DHARWAD (GAMANAGATTI)	TADASINKOPPA_110	10:35	17:47	07:12	LINE CLEAR AVAILED
5656	30-Jun-24	BAGALKOTE	110	LINE	TARIHAL- IDLE(KIADB GAMANAGATTI)	TARIHAL_110	10:45	17:40	06:55	LINE CLEAR AVAILED
5657	30-Jun-24	BAGALKOTE	110	LINE	TIKOTA- BHUTNAL	TIKOTA_110	15:21	16:11	00:50	LINE CLEAR AVAILED
5658	30-Jun-24	BAGALKOTE	110	LINE	VAJRAMATTI220- MANTUR (KD JAMBAGI)	STATION NOT AFFECTED VAJRAMATTI_220	15:44 (05.02.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5659	30-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV1	MK HUBLI_220	14:32	15:35	1:03	LINE CLEAR AVAILED
5660	30-Jun-24	BAGALKOTE	220	TRANSFORMER	220/110KV,HV2	MK HUBLI_220	15:41	17:06	1:25	LINE CLEAR AVAILED
5661	30-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA1	AMBEWADI	11:18 (29.06.2024)			LINE CLEAR AVAILED
5662	30-Jun-24	BAGALKOTE	220	LINE	AMBEWADI-PONDA2	AMBEWADI	11:15 (29.06.2024)			LINE CLEAR AVAILED
5663	30-Jun-24	BAGALKOTE	220	LINE	BIDNAL- SOUDATTI2	BIDNAL_220	7:26 (27.06.2024)			LINE CLEAR AVAILED
5664	30-Jun-24	BAGALKOTE	220	LINE	KADRA-KARWAR LINE-1	KARWAR_220	09:39	18:55	09:16	LINE CLEAR AVAILED
5665	30-Jun-24	BAGALKOTE	220	LINE	SOUDATTI- MAHALINGAPURA	STATION NOT AFFECTED SOUDATTI_220	10:06 (12.03.2024)			LINE CLEAR AVAILED
5666	30-Jun-24	BAGALKOTE	220	LINE	SOUDATTI-MAHALINGAPUR (BIDNAL2)	SOUDATTI_220	7:24 (27.06.2024)			LINE CLEAR AVAILED
5667	30-Jun-24	BANGALORE	66	LINE	66KV ANCHEPALYA 220 - HULLENAHALLI	HULLENAHALLI, KUDUR. SRIGIRIPURA	09:45	17:34	07:49	LINE CLEAR AVAILED
5668	30-Jun-24	BANGALORE	66	LINE	66KV ANEKAL - SAMANDURU	SAMANDURU	10:00	15:20	05:20	LINE CLEAR AVAILED
5669	30-Jun-24	BANGALORE	66	LINE	66KV BG ROAD - JIGANI LINK ROAD DC	NO STATION AFFECTED	21:49	22:02	00:13	TRIPPED ON FAULT
5670	30-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	EXORA 66, CESSNA, KALYANI TECH PARK, ORACLE(EHT)	08:53	08:54	00:01	LINE CLEAR AVAILED
5671	30-Jun-24	BANGALORE	66	LINE	66KV CESSNA BUSINESS PARK 220 - EXORA 66	EXORA 66, CESSNA, KALYANI TECH PARK, ORACLE(EHT)	19:05	19:09	00:04	LINE CLEAR AVAILED
5672	30-Jun-24	BANGALORE	66	LINE	66KV CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA	10:01	18:08	08:07	LINE CLEAR AVAILED
5673	30-Jun-24	BANGALORE	66	LINE	66KV DG4_ HBR 220 - SHOBHA CITY (TAP) - HENNUR	HENNUR CROSS, PURVANKARA PALM BEACH	05:15	05:51	00:36	TRIPPED ON FAULT
5674	30-Jun-24	BANGALORE	66	LINE	66KV DRDO - T D HALLI (MALLASANDRA)	DRDO, MALLASANDRA, DALASANUR	10:00	17:22	07:22	LINE CLEAR AVAILED
5675	30-Jun-24	BANGALORE	66	LINE	66KV KEMPANAHALLI - AGALKOTE	AGALAKOTE	09:45	09:50	00:05	LINE CLEAR AVAILED
5676	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - BANGARPET 2	BANGARPETE	10:00	19:03	09:03	LINE CLEAR AVAILED
5677	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - KEMBODI	KEMBODI	10:00	17:20	07:20	LINE CLEAR AVAILED
5678	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 1	NARSAPURA, HONDA, WISTRON, KC VALLEY	10:00	17:32	07:32	LINE CLEAR AVAILED
5679	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - NARSAPURA 2	NARSAPURA, HONDA, WISTRON, KC VALLEY	10:00	17:32	07:32	LINE CLEAR AVAILED
5680	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TALAGUNDA	VEMGAL, TALAGUNDA, KYALANUR	10:00	17:33	07:33	LINE CLEAR AVAILED
5681	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - TAMAKA - DRDO	TAMAKA	10:00	17:20	07:20	LINE CLEAR AVAILED
5682	30-Jun-24	BANGALORE	66	LINE	66KV KOLAR - VOKKALERI	VOKKALERI, KC VALLEY	10:00	17:32	07:32	LINE CLEAR AVAILED
5683	30-Jun-24	BANGALORE	66	LINE	66KV LAKSHMIPURA - GOWNIPALLI	RAYALPADU, GOWNIPALLI	05:28	05:37	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5684	30-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR I/A - JADIGENAHALLY (HOSKOTE -1)	MALUR I/A, BEST STEEL(EHT), ADL(EHT)	09:43	19:20	09:37	LINE CLEAR AVAILED
5685	30-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - MALUR TOWN	MALUR TOWN	09:43	19:12	09:29	LINE CLEAR AVAILED
5686	30-Jun-24	BANGALORE	66	LINE	66KV MALUR 220 - TEKAL - KGF 1	TEKAL, BUDIKOTE, THORALAKKI	09:45	19:40	09:55	LINE CLEAR AVAILED
5687	30-Jun-24	BANGALORE	66	LINE	66KV PGCIL - SUGUTUR - KOLAR - SM MANGALA	PGCIL, SUGUTUR	10:00	17:32	07:32	LINE CLEAR AVAILED
5688	30-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - KANASWADI	KANASAWADI	16:40	16:51	00:11	TRIPPED ON FAULT
5689	30-Jun-24	BANGALORE	66	LINE	66KV PUTTENAHALLI 220 - RAJANKUNTE	RAJANKUNTE	12:52	13:02	00:10	TRIPPED ON FAULT
5690	30-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	09:06	10:35	01:29	LINE CLEAR AVAILED
5691	30-Jun-24	BANGALORE	66	LINE	66KV SARJAPURA 220 - ATTIBELE	ATTIBELE	12:55	19:41	06:46	LINE CLEAR AVAILED
5692	30-Jun-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	ANEKAL, ATTIBELE, SAMANDURU	10:00	12:30	02:30	LINE CLEAR AVAILED
5693	30-Jun-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYANAGAR	11:35	12:08	00:33	LINE CLEAR AVAILED
5694	30-Jun-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYANAGAR	10:17	12:30	02:13	LINE CLEAR AVAILED
5695	30-Jun-24	BANGALORE	66	LINE	66KV SURYA CITY - ANEKAL 1	SURYANAGAR	09:38	10:10	00:32	MAIN SUPPLY FAILURE
5696	30-Jun-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	11:07	11:20	00:13	LINE CLEAR AVAILED
5697	30-Jun-24	BANGALORE	66	LINE	66KV TG HALLI - BWSSB TG HALLI - TAVAREKERE	TAVAREKERE	20:30	20:38	00:08	LINE CLEAR AVAILED
5698	30-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 1	EMBASSY TECH PARK	08:45	08:50	00:05	LINE CLEAR AVAILED
5699	30-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - EMBASSY 2	EMBASSY TECH PARK	19:03	19:06	00:03	LINE CLEAR AVAILED
5700	30-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	08:43	08:50	00:07	LINE CLEAR AVAILED
5701	30-Jun-24	BANGALORE	66	LINE	66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT	RMZ	19:03	19:06	00:03	LINE CLEAR AVAILED
5702	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, ATTIBELE, SAMANDURU	10:00	12:17	02:17	LINE CLEAR AVAILED
5703	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	09:38	10:19	00:41	MAIN SUPPLY FAILURE
5704	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - ANEKAL 2	ANEKAL	10:19	12:16	01:57	MAIN SUPPLY FAILURE
5705	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	09:38	10:08	00:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5706	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - COLEMAN LTD. TIMES OF INDIA EHT	TIMES OF INDIA	09:38	10:05	00:27	MAIN SUPPLY FAILURE
5707	30-Jun-24	BANGALORE	66	LINE	66KV YARANDANAHALLI 220 - SURYA CITY	SURYANAGAR, ANEKAL	09:41	10:17	00:36	MAIN SUPPLY FAILURE
5708	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	08:45	08:50	00:05	LINE CLEAR AVAILED
5709	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	VIKAS TECH PARK 220	19:00	19:05	00:05	LINE CLEAR AVAILED
5710	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	BRIGADE ORCHIDS	10:30	12:00	01:30	LINE CLEAR AVAILED
5711	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	KOLAR 220	10:00	17:25	07:25	LINE CLEAR AVAILED
5712	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	NARASAPURA	18:15	18:25	00:10	LINE CLEAR AVAILED
5713	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANDERSONPETE	05:55	06:35	00:40	TRIPPED ON FAULT
5714	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	DODDALAHALLI	16:12	16:22	00:10	TRIPPED ON FAULT
5715	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	ANEKAL	10:00	15:20	05:20	LINE CLEAR AVAILED
5716	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	09:13	09:30	00:17	LINE CLEAR AVAILED
5717	30-Jun-24	BANGALORE	66	TRANSFORMER	HV1	SARJAPURA 220	19:25	19:29	00:04	LINE CLEAR AVAILED
5718	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	08:45	08:50	00:05	LINE CLEAR AVAILED
5719	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	VIKAS TECH PARK 220	19:00	19:05	00:05	LINE CLEAR AVAILED
5720	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	BRIGADE ORCHIDS	09:50	12:10	02:20	LINE CLEAR AVAILED
5721	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KIADB DB PURA 220	11:00	12:12	01:12	LINE CLEAR AVAILED
5722	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	KOLAR 220	10:00	17:40	07:40	LINE CLEAR AVAILED
5723	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	ANEKAL	10:00	15:20	05:20	LINE CLEAR AVAILED
5724	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	09:13	09:30	00:17	LINE CLEAR AVAILED
5725	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	SARJAPURA 220	19:25	19:30	00:05	LINE CLEAR AVAILED
5726	30-Jun-24	BANGALORE	66	TRANSFORMER	HV2	YARANDANAHALLI 220	09:38	10:01	00:23	MAIN SUPPLY FAILURE
5727	30-Jun-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 1	BANGARPETE RAILWAY TRACTION 1	10:02	14:35	04:33	LINE CLEAR AVAILED
5728	30-Jun-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 2	BANGARPETE RAILWAY TRACTION 2	10:02	14:35	04:33	LINE CLEAR AVAILED
5729	30-Jun-24	BANGALORE	220	LINE	220KV KOLAR 220 - BANGARPET TRACTION 2	BANGARPETE RAILWAY TRACTION 2	17:40	18:06	00:26	TRIPPED ON FAULT
5730	30-Jun-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 1	MALUR 220	10:04	18:48	08:44	LINE CLEAR AVAILED
5731	30-Jun-24	BANGALORE	220	LINE	220KV KOLAR 220 - MALUR 3	MALUR 220	10:04	18:48	08:44	LINE CLEAR AVAILED
5732	30-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - KOLAR 1	KOLAR 220	10:06	16:11	06:05	LINE CLEAR AVAILED
5733	30-Jun-24	BANGALORE	220	LINE	220KV PGCIL KOLAR 400 - KOLAR 2	KOLAR 220	10:08	14:31	04:23	LINE CLEAR AVAILED
5734	30-Jun-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - MALUR 1	VIKAS TECH PARK 220, EXORA 220	09:13	18:56	09:43	LINE CLEAR AVAILED
5735	30-Jun-24	BANGALORE	220	LINE	220KV SOMANAHALLI 220 - MALUR 2	SARJAPURA 220	09:13	18:54	09:41	LINE CLEAR AVAILED
5736	30-Jun-24	BANGALORE	220	TRANSFORMER	HV1	KOLAR 220	10:04	17:16	07:12	LINE CLEAR AVAILED
5737	30-Jun-24	BANGALORE	220	TRANSFORMER	HV1	MALUR 220	09:43	19:17	09:34	LINE CLEAR AVAILED
5738	30-Jun-24	BANGALORE	220	TRANSFORMER	HV1	SARJAPURA 220	09:13	19:29	10:16	LINE CLEAR AVAILED
5739	30-Jun-24	BANGALORE	220	TRANSFORMER	HV2	KOLAR 220	10:04	17:30	07:26	LINE CLEAR AVAILED
5740	30-Jun-24	BANGALORE	220	TRANSFORMER	HV2	MALUR 220	09:43	19:17	09:34	LINE CLEAR AVAILED
5741	30-Jun-24	BANGALORE	220	TRANSFORMER	HV2	JIGANI 220	14:51	14:59	00:08	LINE CLEAR AVAILED
5742	30-Jun-24	BANGALORE	220	TRANSFORMER	HV2	SARJAPURA 220	09:13	19:30	10:17	LINE CLEAR AVAILED
5743	30-Jun-24	BANGALORE	220	TRANSFORMER	HV3	YARANDANAHALLI 220	09:38	10:01	00:23	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5744	30-Jun-24	GULBARGA	66	LINE	ITTAGI-HARAPPANAHALLI	HARAPPANAHALLI_66	10:10	19:05	08:55	LINE CLEAR AVAILED
5745	30-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-M.KOLLUR	M.KOLLUR_110	12:10	14:29	02:19	LINE CLEAR AVAILED
5746	30-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-RAICHUR-2	DEODURGA_110	12:10	14:30	02:20	LINE CLEAR AVAILED
5747	30-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	23:59	11:28	11:29	LINE CLEAR AVAILED
5748	30-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	19:20	19:30	00:10	TRIPPED ON FAULT
5749	30-Jun-24	GULBARGA	110	LINE	HATTIGUDUR-YADGIR	YADGIR_110	19:47	19:52	00:05	TRIPPED ON FAULT
5750	30-Jun-24	GULBARGA	110	TRANSFORMER	HV1	BALLARI NORTH_110	00:55	01:05	00:10	TRIPPED ON FAULT
5751	30-Jun-24	GULBARGA	110	TRANSFORMER	HV2	ALLIPUR_220	13:21	13:28	00:07	TRIPPED ON FAULT
5752	30-Jun-24	GULBARGA	110	TRANSFORMER	HV2	M.KOLLUR_110	12:30	14:35	02:05	LINE CLEAR AVAILED
5753	30-Jun-24	GULBARGA	110	TRANSFORMER	HV3	MUNIRABAD_220	09:01	11:49	02:48	LINE CLEAR AVAILED
5754	30-Jun-24	GULBARGA	110	LINE	KALBURGI SOUTH-FARTHABAD	FARTHABAD_110	01:48	01:58	00:10	TRIPPED ON FAULT
5755	30-Jun-24	GULBARGA	110	LINE	KHANAPUR-RAILWAY	KHANAPUR_110	20:08	20:13	00:05	TRIPPED ON FAULT
5756	30-Jun-24	GULBARGA	110	LINE	KHANAPUR-SONATHI	SONATHI_110	16:50	19:40	02:50	TRIPPED ON FAULT
5757	30-Jun-24	GULBARGA	110	LINE	KOLURU-SHAHPUR	KOLURU_110	12:10	14:30	02:20	LINE CLEAR AVAILED
5758	30-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-KONKAL	KONKAL_110	11:35	16:13	04:38	LINE CLEAR AVAILED
5759	30-Jun-24	GULBARGA	110	LINE	RAMASAMUDRA-YADGIR	YADGIR_110	13:19	13:38	00:19	TRIPPED ON FAULT
5760	30-Jun-24	GULBARGA	110	LINE	SINDHANOOR-SUZALON	SINDHANOOR_220	12:45	12:55	00:10	TRIPPED ON FAULT
5761	30-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	19:20	19:30	00:10	TRIPPED ON FAULT
5762	30-Jun-24	GULBARGA	110	LINE	YADGIR-SHAHPUR	YADGIR_110	19:50	19:55	00:05	TRIPPED ON FAULT
5763	30-Jun-24	GULBARGA	220	LINE	HATTIGUDUR-LINGASUGUR	LINGUSUGUR_220	10:14	14:02	03:48	LINE CLEAR AVAILED
5764	30-Jun-24	GULBARGA	220	LINE	KUSHTAGI-SUZLON-2-IPP	KUSHTAGI_220	09:20	11:04	01:44	LINE CLEAR AVAILED
5765	30-Jun-24	GULBARGA	220	LINE	LINGASUGUR-SHAHAPUR	LINGASUGUR_220	10:20	14:03	03:43	LINE CLEAR AVAILED
5766	30-Jun-24	GULBARGA	220	LINE	NEELGUNDA-GUTTUR	NEELGUNDA_220	9:21(21.05.2024)			LINE CLEAR AVAILED
5767	30-Jun-24	GULBARGA	220	LINE	NEELGUNDA-ITTAGI	NEELGUNDA_220	11:10	18:30	07:20	LINE CLEAR AVAILED
5768	30-Jun-24	GULBARGA	220	LINE	RAMASAMUDRA-RTPS-1	RAMASAMUDRA_220	10:05	12:05	02:00	LINE CLEAR AVAILED
5769	30-Jun-24	GULBARGA	220	LINE	RAMASAMUDRA-RTPS-2	RAMASAMUDRA_220	12:22	16:00	03:38	LINE CLEAR AVAILED
5770	30-Jun-24	HASSAN	66	LINE	HONALI-TAVAREC	TAVAREC	10:25	10:35	00:10	TRIPPED ON FAULT
5771	30-Jun-24	HASSAN	66	TRANSFORMER	HV1	DUDDA	09:00	09:45	00:45	LINE CLEAR AVAILED
5772	30-Jun-24	HASSAN	66	LINE	SAKALE-HANBAL	SAKALE	08:10	18:37	10:27	LINE CLEAR AVAILED
5773	30-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON1	UDDURKO	03:08	03:25	00:17	TRIPPED ON FAULT
5774	30-Jun-24	HASSAN	66	LINE	UDDURKO-SUZLON2	UDDURKO	03:08	03:25	00:17	TRIPPED ON FAULT
5775	30-Jun-24	HASSAN	110	LINE	ALKOLA-MRS	ALKOLA	10:24	17:57	07:33	LINE CLEAR AVAILED
5776	30-Jun-24	HASSAN	110	LINE	GAJNUR-IPP IC LINE	GAJNUR	14:25	14:30	00:05	TRIPPED ON FAULT
5777	30-Jun-24	HASSAN	110	TRANSFORMER	HV1	KADUR	16:18	16:33	00:15	TRIPPED ON FAULT
5778	30-Jun-24	HASSAN	110	TRANSFORMER	HV1	KARKLA	11:14	12:15	01:01	LINE CLEAR AVAILED
5779	30-Jun-24	HASSAN	110	TRANSFORMER	HV2	KEMAR	02:44	02:51	00:07	TRIPPED ON FAULT
5780	30-Jun-24	HASSAN	110	LINE	MRSSHM-SS1	MRSSHM	10:24	17:56	07:32	LINE CLEAR AVAILED
5781	30-Jun-24	HASSAN	220	LINE	GERSOPA-SHIMOGA1	gen_gersoppa	13:35(28.6.2024)			LINE CLEAR AVAILED
5782	30-Jun-24	HASSAN	220	LINE	MRSSHM-SHARAVATHY1	MRSMSG_220	13:35(28.6.2024)			LINE CLEAR AVAILED
5783	30-Jun-24	HASSAN	220	LINE	VARAHI-SHMG3	VARAHI	14:25	14:41	00:16	TRIPPED ON FAULT
5784	30-Jun-24	MYSORE	66	LINE	BEGUR-220-GUNDLUPETE-2	NO STATIONS EFFECTED	15:55	16:05	00:10	LINE CLEAR AVAILED
5785	30-Jun-24	MYSORE	66	LINE	D K MAIDANA-JYOTHINAGARA	DKMAIDANA_66	07:30	08:37	01:07	LINE CLEAR AVAILED
5786	30-Jun-24	MYSORE	66	LINE	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	10:48 (27/06/2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5787	30-Jun-24	MYSORE	66	LINE	HANNUR-AJJIPURA	AJJIPURA_66 BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	03:29	03:36	00:06	TRIPPED ON FAULT
5788	30-Jun-24	MYSORE	66	LINE	HANNUR-KOTTANURU	NO STATIONS EFFECTED	17:28	17:33	00:05	TRIPPED ON FAULT
5789	30-Jun-24	MYSORE	66	LINE	HEBBANI-T K HALLI	NO STATIONS EFFECTED	04:19	04:30	00:11	TRIPPED ON FAULT
5790	30-Jun-24	MYSORE	66	TRANSFORMER	HV1	DKMAIDANA_66	07:30	08:38	01:08	LINE CLEAR AVAILED
5791	30-Jun-24	MYSORE	66	TRANSFORMER	HV1	SFC SIVA_66	7:01 (15/02/2024)			TRIPPED ON FAULT
5792	30-Jun-24	MYSORE	66	TRANSFORMER	HV2	DKMAIDANA_66	07:30	08:38	01:08	LINE CLEAR AVAILED
5793	30-Jun-24	MYSORE	66	TRANSFORMER	HV5	SFC SIVA_66	17:44 (24/04/2024)			LINE CLEAR AVAILED
5794	30-Jun-24	MYSORE	66	LINE	KADAKOLA-D K MAIDANA	NO STATIONS EFFECTED	07:46	16:02	08:16	LINE CLEAR AVAILED
5795	30-Jun-24	MYSORE	66	LINE	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	19:03	19:15	00:12	TRIPPED ON FAULT
5796	30-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	10:01 (30/05/2024)			TRIPPED ON FAULT
5797	30-Jun-24	MYSORE	66	LINE	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	14:16 (20/06/2024)			LINE CLEAR AVAILED
5798	30-Jun-24	MYSORE	66	LINE	PANDAVAPURA-CHINAKURALI	NO STATIONS EFFECTED	11:14 (20/06/2024)			LINE CLEAR AVAILED
5799	30-Jun-24	MYSORE	66	LINE	SFC SIVA-10MW IPP	NO STATIONS EFFECTED	04:20	06:01	01:41	TRIPPED ON FAULT
5800	30-Jun-24	MYSORE	66	LINE	SFC SIVA-5MW IPP	NO STATIONS EFFECTED	04:20	06:01	01:41	TRIPPED ON FAULT
5801	30-Jun-24	MYSORE	66	LINE	SFC SIVA-PGL	NO STATIONS EFFECTED	04:19	04:21	00:02	TRIPPED ON FAULT
5802	30-Jun-24	MYSORE	66	LINE	TUBINAKERE-JAKKANALLI	NO STATIONS EFFECTED	06:11	06:27	00:16	TRIPPED ON FAULT
5803	30-Jun-24	TUMKUR	66	LINE	220KV DAVANGERE-66KV KUKKAWADA LINE 2	KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66	16:12	16:22	00:10	TRIPPED ON FAULT
5804	30-Jun-24	TUMKUR	66	LINE	220KV HIRIYUR-66KV HIRIYURU	66KV HIRIYUR	06:48	10:56	04:08	TRIPPED ON FAULT
5805	30-Jun-24	TUMKUR	66	LINE	66KV KUKKAWADA-66KV BASAVAPATNA	66KV THAVANAGI SS	14:34	14:44	00:10	TRIPPED ON FAULT
5806	30-Jun-24	TUMKUR	66	LINE	66KV MATHOD-66KV KANCHIPURA LINE	66KV KANCHIPURA	08:25	08:35	00:10	TRIPPED ON FAULT
5807	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	09:45	17:39	07:54	LINE CLEAR AVAILED
5808	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66, THIPPUR_66, B G NAGARA_66	09:45	17:38	07:53	LINE CLEAR AVAILED
5809	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	09:45	17:37	07:52	LINE CLEAR AVAILED
5810	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	09:45	17:34	07:49	LINE CLEAR AVAILED
5811	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- KUNIGAL	KUNIGAL_66	09:45	17:32	07:47	LINE CLEAR AVAILED
5812	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- VIJAYA STEEL	VIJAYA STEEL	09:45	17:43	07:58	LINE CLEAR AVAILED
5813	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 220KV- ANCHEPALYA 1&2	ANCHEPALYA_66	09:45	17:32	07:47	LINE CLEAR AVAILED
5814	30-Jun-24	TUMKUR	66	LINE	ANCHEPALYA 66KV- HEBBUR	HEBBUR_66	09:45	17:34	07:49	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRF	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION (C=B-A)	REMARKS
5815	30-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	11:30	13:28	01:58	LINE CLEAR AVAILED
5816	30-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	09:50	09:58	00:08	TRIPPED ON FAULT
5817	30-Jun-24	TUMKUR	66	LINE	ANTHRASANAHALLI 220KV-MELEKOTE	MELKOTE_66, BADDIHALLI_66	10:20	13:28	03:08	LINE CLEAR AVAILED
5818	30-Jun-24	TUMKUR	66	LINE	HIRIYUR220KV-P R PURA	HARIYABBE_66,PDKOTE_66	09:18	18:53	09:35	LINE CLEAR AVAILED
5819	30-Jun-24	TUMKUR	66	LINE	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66	08:23	08:34	00:11	TRIPPED ON FAULT
5820	30-Jun-24	TUMKUR	66	LINE	SHAGALE_66-KEREBILCHI_66	WATER WORKS	16:13	16:38	00:25	TRIPPED ON FAULT
5821	30-Jun-24	TUMKUR	220	TRANSFORMER	TR-1&2 (100MVA HV SIDE)	ANCHEPALYA 220KV	09:45	17:25	07:40	LINE CLEAR AVAILED