

**400/220/110/66 kV TRANSMISSION OUTAGES FOR THE MONTH OF SEPTEMBER-2024**

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name                             | Open_At               | Closed_At        | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------------------|------------------------------------------|-----------------------|------------------|-----------|--------------------|
| 1     | 01-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR               | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                  |           | LINE CLEAR AVOIDED |
| 2     | 01-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                    | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                  |           | LINE CLEAR AVOIDED |
| 3     | 01-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                       | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                  |           | LINE CLEAR AVOIDED |
| 4     | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                         | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) |                  |           | TRIPPED ON FAULT   |
| 5     | 01-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-ANKALGI                      | HIDKALDAM_110                            | 16:56<br>(22.08.2024) | 5:21(01.09.2024) | 228:25:00 | LINE CLEAR AVOIDED |
| 6     | 01-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)               | UTTUR_110                                | 14:09<br>(27.08.2024) |                  |           | LINE CLEAR AVOIDED |
| 7     | 01-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                           | KONNUR_110                               | 8:19<br>(29.08.2024)  |                  |           | LINE CLEAR AVOIDED |
| 8     | 01-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-SIRSI(AMBEWADI)              | KIRUVATTI_110                            | 14:50<br>(31.08.2024) |                  |           | LINE CLEAR AVOIDED |
| 9     | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33 KV, HV4 (20MVA)                 | BAILHONGAL_110                           | 10:18                 | 14:10            | 03:52     | LINE CLEAR AVOIDED |
| 10    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11 KV, HV3 (10MVA)                 | BAILHONGAL_110                           | 10:10                 | 14:17            | 04:07     | LINE CLEAR AVOIDED |
| 11    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11 KV, HV1 (10MVA)                 | STATION NOT AFFECTED<br>GARAG_110        | 12:02                 | 12:37            | 00:35     | LINE CLEAR AVOIDED |
| 12    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11 KV, HV2 (10MVA)                 | STATION NOT AFFECTED<br>GARAG_110        | 12:41                 | 13:04            | 00:23     | LINE CLEAR AVOIDED |
| 13    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)                  | HIREKER_110                              | 10:05                 | 17:14            | 07:09     | LINE CLEAR AVOIDED |
| 14    | 01-Sep-24 | BAGALKOT | 110     | LINE        | KANABARAGI LAYOUT-BELGAUM              | KANABARAGI LAYOUT_110                    | 05:58                 | 08:04            | 02:06     | LINE CLEAR AVOIDED |
| 15    | 01-Sep-24 | BAGALKOT | 110     | LINE        | VADAGOAM-BELGAUM                       | VADAGOAM_110                             | 05:19                 | 08:09            | 02:50     | TRIPPED ON FAULT   |
| 16    | 01-Sep-24 | BAGALKOT | 110     | LINE        | VADAGOAM-MACHE                         | VADAGOAM_110                             | 08:11                 | 16:32            | 08:21     | LINE CLEAR AVOIDED |
| 17    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA-HV1)                | VADAGOAM_110                             | 10:04                 | 12:55            | 02:51     | LINE CLEAR AVOIDED |
| 18    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(10MVA)                    | VADAGOAM_110                             | 09:17                 | 12:58            | 03:41     | LINE CLEAR AVOIDED |
| 19    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(10MVA-HV4)                | SADALAGA_110                             | 12:14                 | 12:44            | 00:30     | TRIPPED ON FAULT   |
| 20    | 01-Sep-24 | BAGALKOT | 110     | LINE        | RAMDURGA-BAGALKOT                      | RAMDURGA_110                             | 09:10                 | 17:36            | 08:26     | LINE CLEAR AVOIDED |
| 21    | 01-Sep-24 | BAGALKOT | 110     | LINE        | RAMDURGA-SOUDATTI                      | RAMDURGA_110                             | 09:14                 | 17:48            | 08:34     | LINE CLEAR AVOIDED |
| 22    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)                | RAMDURGA_110                             | 09:09                 | 16:00            | 06:51     | LINE CLEAR AVOIDED |
| 23    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA-HV1)                | RAMDURGA_110                             | 09:09                 | 17:32            | 08:23     | LINE CLEAR AVOIDED |
| 24    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA)                    | RAMDURGA_110                             | 09:10                 | 15:53            | 06:43     | LINE CLEAR AVOIDED |
| 25    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                    | KAMBAGI_110                              | 09:13                 | 09:31            | 00:18     | LINE CLEAR AVOIDED |
| 26    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220- VADAGOAN                   | BELGAUM_220                              | 05:20                 | 08:09            | 02:49     | LINE CLEAR AVOIDED |
| 27    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220- ANKALAGI(HUDLI)            | BELGAUM_220                              | 05:25                 | 08:11            | 02:46     | LINE CLEAR AVOIDED |
| 28    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220- BELGAUM110<br>(NEHRUNAGAR) | BELGAUM_220                              | 05:57                 | 08:08            | 02:11     | LINE CLEAR AVOIDED |
| 29    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220- KANABARGI<br>LAYOUT        | BELGAUM_220                              | 05:58                 | 08:05            | 02:07     | LINE CLEAR AVOIDED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name                                                | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------------------|-------------------------------------------------------------|-----------------------|-----------|----------|--------------------|
| 30    | 01-Sep-24 | BAGALKOT | 110     | LINE        | CHIKKODI220- DKSS COGEN                | CHIKKODI_220                                                | 11:21                 | 11:25     | 00:04    | LINE CLEAR AVAILED |
| 31    | 01-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220- HIREKERUR                | RANEENNUR_220                                               | 10:49                 | 17:01     | 06:12    | LINE CLEAR AVAILED |
| 32    | 01-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220- RATTIHALLI (TUMMINKATTE) | RANEENNUR_220                                               | 23:47                 | 23:55     | 00:08    | TRIPPED ON FAULT   |
| 33    | 01-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                    | STATION NOT AFFECTED<br>MKHUBLI_220                         | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 34    | 01-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2              | STATION NOT AFFECTED<br>SOUNDATTI_220                       | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 35    | 01-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                     | STATION NOT AFFECTED<br>SOUNDATTI_220                       | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 36    | 01-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                  | STATION NOT AFFECTED<br>BAGALKOT_220                        | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 37    | 01-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                         | STATION NOT AFFECTED<br>HUBLI_220                           | 18:52<br>(17.08.2024) |           |          | TRIPPED ON FAULT   |
| 38    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                    | TERDAL_110                                                  | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 39    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-BAGEWADI                      | STATION NOT AFFECTED<br>BELGAUM_110<br>STATION NOT AFFECTED | 05:55                 | 06:19     | 00:24    | TRIPPED ON FAULT   |
| 40    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11 KV, HV1 (20MVA)                 | BELGAUM_110                                                 | 05:58                 | 08:24     | 02:26    | LINE CLEAR AVAILED |
| 41    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11 KV, HV2 (20MVA)                 | BELGAUM_110                                                 | 05:58                 | 08:24     | 02:26    | LINE CLEAR AVAILED |
| 42    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33 KV, HV1 (20MVA)                 | BELGAUM_110                                                 | 05:58                 | 08:24     | 02:26    | LINE CLEAR AVAILED |
| 43    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33 KV, HV2 (20MVA)                 | BELGAUM_110                                                 | 05:58                 | 08:24     | 02:26    | LINE CLEAR AVAILED |
| 44    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM -NEHARUNAGARA                  | STATION NOT AFFECTED<br>BELGAUM_110<br>STATION NOT AFFECTED | 05:58                 | 08:07     | 02:09    | LINE CLEAR AVAILED |
| 45    | 01-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                       | STATION NOT AFFECTED<br>HIDKALDAM_110                       | 8:13 (1.09.2024)      |           |          | LINE CLEAR AVAILED |
| 46    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33 KV, HV1 (20MVA)                 | HIREKER_110                                                 | 10:05                 | 16:55     | 06:50    | LINE CLEAR AVAILED |
| 47    | 01-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | HIREKER_110                                                 | 10:05                 | 16:55     | 06:50    | LINE CLEAR AVAILED |
| 48    | 01-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BELAGVI 220KV                   | HUDALI-110                                                  | 05:21                 | 08:13     | 02:52    | LINE CLEAR AVAILED |
| 49    | 01-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                           | STATION NOT AFFECTED<br>HUDALI_110                          | 11:05 (01.09.2024)    |           |          | LINE CLEAR AVAILED |
| 50    | 01-Sep-24 | BAGALKOT | 110     | LINE        | SOUDATTI220-RAMDURGA1                  | SOUDATTI_220                                                | 09:35                 | 15:39     | 06:04    | LINE CLEAR AVAILED |
| 51    | 01-Sep-24 | BAGALKOT | 110     | LINE        | SOUDATTI220-RAMDURGA2                  | SOUDATTI_220                                                | 09:36                 | 15:40     | 06:04    | LINE CLEAR AVAILED |
| 52    | 01-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F7-RAMDURG                 | BAGALKOT_220                                                | 09:30                 | 17:19     | 07:49    | LINE CLEAR AVAILED |
| 53    | 01-Sep-24 | BAGALKOT | 110     | LINE        | HAVERI220- BASAVANAKATTI               | HAVERI_220                                                  | 06:14                 | 06:36     | 00:22    | TRIPPED ON FAULT   |
| 54    | 02-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR               | STATION NOT AFFECTED<br>HUBLI_220                           | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAILED |
| 55    | 02-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                    | STATION NOT AFFECTED<br>NAVANAGAR(B)_110                    | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                               | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|------------------------------------|---------------------------------------|-----------------------|-----------|----------|-------------------|
| 56    | 02-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                   | STATION NOT AFFECTED<br>BIDNAL_220    | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 57    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                     | STATION NOT AFFECTED<br>HUBLI_220     | 18:52<br>(17.08.2024) |           |          | TRIPPED ON FAULT  |
| 58    | 02-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)           | UTTUR_110                             | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 59    | 02-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                       | KONNUR_110                            | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 60    | 02-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-SIRSI(AMBEWADI)          | KIRUVATTI_110                         | 14:50<br>(31.08.2024) |           |          | LINE CLEAR AVAIED |
| 61    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20MVA)               | BABLESHWARA_110                       | 13:53                 | 14:30     | 00:37    | LINE CLEAR AVAIED |
| 62    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4 (10MVA)               | BAILAHONGAL_110                       | 13:52                 | 14:02     | 00:10    | LINE CLEAR AVAIED |
| 63    | 02-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-ENERCON2 WIND             | BELLATTI_110                          | 05:40                 | 05:43     | 00:03    | LINE CLEAR AVAIED |
| 64    | 02-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-AB SOLAR                  | BELLATTI_110                          | 05:40                 | 05:43     | 00:03    | LINE CLEAR AVAIED |
| 65    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4 (10MVA)               | GHATAPRABHA_110                       | 11:57                 | 13:12     | 01:15    | LINE CLEAR AVAIED |
| 66    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3 (20MVA)               | GOKAK_110                             | 06:57                 | 07:06     | 00:09    | TRIPPED ON FAULT  |
| 67    | 02-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-THORVI(KIADB<br>BIJAPUR) | TAKKALAKI_110                         | 07:29                 | 10:41     | 03:12    | LINE CLEAR AVAIED |
| 68    | 02-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-TIKOTA                   | TAKKALAKI_110                         | 07:29                 | 10:41     | 03:12    | LINE CLEAR AVAIED |
| 69    | 02-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-WARADA                   | TAKKALAKI_110                         | 07:29                 | 10:41     | 03:12    | LINE CLEAR AVAIED |
| 70    | 02-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-KN SOLAR                 | TAKKALAKI_110                         | 07:30                 | 10:42     | 03:12    | LINE CLEAR AVAIED |
| 71    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA-HV2)            | ZALKI_110                             | 23:54<br>(02.09.2024) |           |          | TRIPPED ON FAULT  |
| 72    | 02-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-KUMTA2                       | SIRSI_110                             | 11:29                 | 13:23     | 01:54    | TRIPPED ON FAULT  |
| 73    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                | PH COMPOUND_110                       | 04:58                 | 06:41     | 01:43    | TRIPPED ON FAULT  |
| 74    | 02-Sep-24 | BAGALKOT | 110     | LINE        | MURDESHWARRAILWAT LINE             | MURDESHWAR_110                        | 22:22                 | 22:31     | 00:09    | LINE CLEAR AVAIED |
| 75    | 02-Sep-24 | BAGALKOT | 110     | LINE        | LAXMESHWAR-GADAG                   | LAXMESHWAR_110                        | 05:19                 | 05:40     | 00:21    | TRIPPED ON FAULT  |
| 76    | 02-Sep-24 | BAGALKOT | 110     | LINE        | KUMTA-SIRSI1                       | KUMTA_110                             | 22:34                 | 22:41     | 00:07    | LINE CLEAR AVAIED |
| 77    | 02-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI-NAGZHARI1                 | AMBEWADI_220                          | 14:59                 | 15:15     | 00:16    | TRIPPED ON FAULT  |
| 78    | 02-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHRAVATHY1                  | SIRSI_220                             | 22:29 (02.09.2024)    |           |          | LINE CLEAR AVAIED |
| 79    | 02-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220-<br>HUKKERI(UCHAGOAN)   | BELGAUM_220                           | 03:36                 | 03:45     | 00:09    | TRIPPED ON FAULT  |
| 80    | 02-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-VPPL COGEN                | SADALAGA_110                          | 09:17                 | 18:30     | 09:13    | LINE CLEAR AVAIED |
| 81    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)               | INDI_220                              | 19:22                 | 19:35     | 00:13    | LINE CLEAR AVAIED |
| 82    | 02-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- BAILHONGAL             | MKHUBLI_220                           | 12:08                 | 12:34     | 00:26    | TRIPPED ON FAULT  |
| 83    | 02-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |
| 84    | 02-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2          | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED |
| 85    | 02-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                 | STATION NOT AFFECTED<br>SOUDATTI_220  | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED |
| 86    | 02-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS              | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED |
| 87    | 02-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                     | STATION NOT AFFECTED<br>HUBLI_220     | 18:52<br>(17.08.2024) |           |          | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                             | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|----------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 88    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)              | TERDAL_110                               | 12:50<br>(21.08.2024) |                       |          | TRIPPED ON FAULT  |
| 89    | 02-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                 | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |          | LINE CLEAR AVAIED |
| 90    | 02-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                     | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |          | LINE CLEAR AVAIED |
| 91    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20MVA)             | BABLESHWARA_110                          | 12:20                 | 13:25                 | 01:05    | LINE CLEAR AVAIED |
| 92    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)          | ZALKI_110                                | 15:55                 | 17:00                 | 01:05    | TRIPPED ON FAULT  |
| 93    | 02-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)          | ZALKI_110                                | 20:40<br>(02.09.2024) |                       |          | LINE CLEAR AVAIED |
| 94    | 02-Sep-24 | BAGALKOT | 110     | LINE        | LAXMESHWAR-BELLATTI              | LAXMESHWAR_110                           | 05:19                 | 05:40                 | 00:21    | TRIPPED ON FAULT  |
| 95    | 02-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHRAVATHY2                | SIRSI_220                                | 22:29 (02.09.2024)    |                       |          | LINE CLEAR AVAIED |
| 96    | 02-Sep-24 | BAGALKOT | 110     | LINE        | SOUDATTI220-MMCL                 | SOUDATTI_220                             | 09:36                 | 09:44                 | 00:08    | LINE CLEAR AVAIED |
| 97    | 03-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR         | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 98    | 03-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2              | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 99    | 03-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                 | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 100   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                   | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) |                       |          | TRIPPED ON FAULT  |
| 101   | 03-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)         | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 102   | 03-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                     | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 103   | 03-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-SIRSI(AMBEWADI)        | STATION NOT AFFECTED<br>KIRUVATTI_110    | 14:50<br>(31.08.2024) |                       |          | LINE CLEAR AVAIED |
| 104   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA-HV2)          | ZALKI_110                                | 23:54<br>(02.09.2024) | 0:03<br>(03.09.2024)  | 00:09    | TRIPPED ON FAULT  |
| 105   | 03-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHRAVATHY1                | STATION NOT AFFECTED<br>SIRSI_220        | 22:29<br>(02.09.2024) | 10:16<br>(03.09.2024) | 11:47    | LINE CLEAR AVAIED |
| 106   | 03-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220- HIREKERUR          | RANEENNUR_220                            | 12:32                 | 13:50                 | 01:18    | LINE CLEAR AVAIED |
| 107   | 03-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220-<br>HUKKERI(UCHAGOAN) | BELGAUM_220                              | 11:55                 | 16:25                 | 04:30    | LINE CLEAR AVAIED |
| 108   | 03-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-<br>KUDACHI(AINAPUR)  | KUDACHI_220                              | 19:36                 | 20:25                 | 00:49    | TRIPPED ON FAULT  |
| 109   | 03-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                   | KARWAR_220                               | 11:42                 | 12:09                 | 00:27    | LINE CLEAR AVAIED |
| 110   | 03-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220- LN3(GANJIGATTI)     | SHIGGOAN_220                             | 14:02                 | 16:16                 | 02:14    | LINE CLEAR AVAIED |
| 111   | 03-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220- KALGHATAGI             | HUBLI_220                                | 18:08                 | 20:40                 | 02:32    | TRIPPED ON FAULT  |
| 112   | 03-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI- SIRSI2                    | HUBLI_220                                | 16:05                 | 16:31                 | 00:26    | TRIPPED ON FAULT  |
| 113   | 03-Sep-24 | BAGALKOT | 110     | LINE        | KALGHATAGI-HUBLI                 | KALGHATAGI_110                           | 18:08                 | 20:45                 | 02:37    | LINE CLEAR AVAIED |
| 114   | 03-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                   | MACHE_110                                | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                           | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|--------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 115   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)          | MAMADAPURA_110                           | 20:47                 | 20:58                 | 00:11    | TRIPPED ON FAULT  |
| 116   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)          | MAMADAPURA_110                           | 23:04                 | 23:11                 | 00:07    | TRIPPED ON FAULT  |
| 117   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV2 (10MVA)          | MATTIHAL_110                             | 14:29                 | 14:40                 | 00:11    | LINE CLEAR AVAIED |
| 118   | 03-Sep-24 | BAGALKOT | 110     | LINE        | RAIBAG-CHIKKODI2               | RAIBAG_110                               | 17:07                 | 17:17                 | 00:10    | TRIPPED ON FAULT  |
| 119   | 03-Sep-24 | BAGALKOT | 110     | LINE        | UDYAMBAG-UCHAGOAN              | UDYAMBAG_110                             | 11:59                 | 16:27                 | 04:28    | LINE CLEAR AVAIED |
| 120   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)            | SUVARNA SOUDA_110                        | 12:15                 | 12:45                 | 00:30    | LINE CLEAR AVAIED |
| 121   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)            | SHIGGOAN_110                             | 10:02                 | 16:38                 | 06:36    | LINE CLEAR AVAIED |
| 122   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)            | SHIGGOAN_110                             | 10:00                 | 16:35                 | 06:35    | LINE CLEAR AVAIED |
| 123   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA)            | SHIGGOAN_110                             | 10:02                 | 16:38                 | 06:36    | LINE CLEAR AVAIED |
| 124   | 03-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN-RAMANAKOPPA(MUNDAGOD) | SHIGGOAN_110                             | 13:25                 | 17:47                 | 04:22    | LINE CLEAR AVAIED |
| 125   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA-HV2)        | ZALKI_110                                | 08:25                 | 08:30                 | 00:05    | TRIPPED ON FAULT  |
| 126   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA-HV2)        | ZALKI_110                                | 12:21                 | 12:46                 | 00:25    | LINE CLEAR AVAIED |
| 127   | 03-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1            | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |          | LINE CLEAR AVAIED |
| 128   | 03-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2      | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |          | LINE CLEAR AVAIED |
| 129   | 03-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2             | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |                       |          | LINE CLEAR AVAIED |
| 130   | 03-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS          | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 131   | 03-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                 | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) |                       |          | TRIPPED ON FAULT  |
| 132   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)            | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |                       |          | TRIPPED ON FAULT  |
| 133   | 03-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI               | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |          | LINE CLEAR AVAIED |
| 134   | 03-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                   | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |          | LINE CLEAR AVAIED |
| 135   | 03-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHRAVATHY2              | STATION NOT AFFECTED<br>SIRSI_220        | 22:29<br>(02.09.2024) | 10:17<br>(03.09.2024) | 11:48    | LINE CLEAR AVAIED |
| 136   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)        | ZALKI_110                                | 20:40<br>(02.09.2024) |                       |          | LINE CLEAR AVAIED |
| 137   | 03-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV2 (10MVA)          | MALGHAN_110                              | 15:45                 | 15:52                 | 00:07    | TRIPPED ON FAULT  |
| 138   | 03-Sep-24 | BAGALKOT | 110     | LINE        | HALIYAL-KAVALWAD               | HALIYAL_110                              | 06:08                 | 06:52                 | 00:44    | TRIPPED ON FAULT  |
| 139   | 03-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                 | KARWAR_220                               | 10:37                 | 10:59                 | 00:22    | LINE CLEAR AVAIED |
| 140   | 03-Sep-24 | BAGALKOT | 110     | LINE        | TIGADI- MUDALGI                | TIGADI_110                               | 01:00                 | 01:18                 | 00:18    | TRIPPED ON FAULT  |
| 141   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR       | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 142   | 04-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2            | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 143   | 04-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2               | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                          | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-----------------------------------|---------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 144   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                    | STATION NOT AFFECTED<br>HUBLI_220     | 18:52<br>(17.08.2024) |                       |          | TRIPPED ON FAULT  |
| 145   | 04-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)          | STATION NOT AFFECTED<br>UTTUR_110     | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 146   | 04-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                      | STATION NOT AFFECTED<br>KONNUR_110    | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 147   | 04-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-SIRSI(AMBEWADI)         | STATION NOT AFFECTED<br>KIRUVATTI_110 | 14:50<br>(31.08.2024) | 10:10<br>(04.09.2024) | 91:20:00 | LINE CLEAR AVAIED |
| 148   | 04-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                    | MACHE_110                             | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 149   | 04-Sep-24 | BAGALKOT | 110     | LINE        | BANAHATTI-MAHALINGAPURA           | BANAHATTI_110                         | 10:39                 | 14:38                 | 03:59    | LINE CLEAR AVAIED |
| 150   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)             | BANAHATTI_110                         | 10:16                 | 17:04                 | 06:48    | LINE CLEAR AVAIED |
| 151   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)             | BANAHATTI_110                         | 11:04                 | 14:39                 | 03:35    | LINE CLEAR AVAIED |
| 152   | 04-Sep-24 | BAGALKOT | 110     | LINE        | GADAG RAOD-RAILWAY LINE           | GADAG ROAD_110                        | 12:58                 | 12:59                 | 00:01    | LINE CLEAR AVAIED |
| 153   | 04-Sep-24 | BAGALKOT | 110     | LINE        | GARAG-NARENDRA                    | GARAG_110                             | 11:58                 | 13:31                 | 01:33    | LINE CLEAR AVAIED |
| 154   | 04-Sep-24 | BAGALKOT | 110     | LINE        | HUDLI-BSPL2<br>(BELGAUM SUGARS)   | HUDLI_110                             | 12:11                 | 12:25                 | 00:14    | LINE CLEAR AVAIED |
| 155   | 04-Sep-24 | BAGALKOT | 110     | LINE        | ITANAL-BORUKA (KABBUR)            | ITANAL_110                            | 12:05                 | 12:29                 | 00:24    | TRIPPED ON FAULT  |
| 156   | 04-Sep-24 | BAGALKOT | 110     | LINE        | ITANAL-RAIBK2 (BPCL)              | ITANAL_110                            | 12:06                 | 12:27                 | 00:21    | TRIPPED ON FAULT  |
| 157   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)             | KALADAGI_110                          | 00:06                 | 00:11                 | 00:05    | TRIPPED ON FAULT  |
| 158   | 04-Sep-24 | BAGALKOT | 110     | LINE        | KALGHATAGI-HUBLI                  | KALGHATAGI_110                        | 11:45                 | 15:00                 | 03:15    | LINE CLEAR AVAIED |
| 159   | 04-Sep-24 | BAGALKOT | 110     | LINE        | UMMACHAGI-SIRSI                   | UMMACHAGI                             | 10:16                 | 18:07                 | 07:51    | LINE CLEAR AVAIED |
| 160   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)               | UGAR KHUD_110                         | 10:17                 | 17:23                 | 07:06    | LINE CLEAR AVAIED |
| 161   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)               | UGAR KHUD_110                         | 10:29                 | 18:10                 | 07:41    | LINE CLEAR AVAIED |
| 162   | 04-Sep-24 | BAGALKOT | 110     | LINE        | UGAR KHUD-KAGAWAD                 | UGAR KHUD_110                         | 10:29                 | 18:10                 | 07:41    | LINE CLEAR AVAIED |
| 163   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)               | SULTANPUR_110                         | 10:01                 | 19:06                 | 09:05    | LINE CLEAR AVAIED |
| 164   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)               | SULTANPUR_110                         | 10:01                 | 19:05                 | 09:04    | LINE CLEAR AVAIED |
| 165   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SULTANPUR-F2(MUGALKHOD)           | SULTANPUR_110                         | 10:01                 | 19:00                 | 08:59    | LINE CLEAR AVAIED |
| 166   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-KAVALWADA(SIRSI1)           | SIRSI_110                             | 10:04                 | 18:10                 | 08:06    | LINE CLEAR AVAIED |
| 167   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-HUBLI1(SIRSI2)              | SIRSI_110                             | 10:05                 | 18:10                 | 08:05    | LINE CLEAR AVAIED |
| 168   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)              | SIRSI_110                             | 18:10<br>(05.09.2024) |                       |          | LINE CLEAR AVAIED |
| 169   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)               | SHIRGOAN_110                          | 10:02                 | 16:11                 | 06:09    | LINE CLEAR AVAIED |
| 170   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWAR-HSFCG2(HIRA<br>SUGAR)  | SANKESHWAR_110                        | 09:15                 | 15:30                 | 06:15    | LINE CLEAR AVAIED |
| 171   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWAR-CHIKKODI               | SANKESHWAR_110                        | 12:40                 | 15:31                 | 02:51    | LINE CLEAR AVAIED |
| 172   | 04-Sep-24 | BAGALKOT | 110     | LINE        | RON-NAREGAL                       | RON_110                               | 10:17                 | 17:39                 | 07:22    | LINE CLEAR AVAIED |
| 173   | 04-Sep-24 | BAGALKOT | 110     | LINE        | RAMANAKOPPA-<br>SAVANUR(DUNDASHI) | RAMANAKOPPA_110                       | 09:30                 | 15:15                 | 05:45    | LINE CLEAR AVAIED |
| 174   | 04-Sep-24 | BAGALKOT | 110     | LINE        | RAMANAKOPPA-<br>SAVANUR(DUNDASHI) | RAMANAKOPPA_110                       | 15:27                 | 15:32                 | 00:05    | LINE CLEAR AVAIED |
| 175   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | PH COMPOUND_110                       | 10:40                 | 14:51                 | 04:11    | LINE CLEAR AVAIED |
| 176   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | PH COMPOUND_110                       | 15:06                 | 15:08                 | 00:02    | LINE CLEAR AVAIED |
| 177   | 04-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGI-F2(BANAHATTI)            | NAVALAGI_110                          | 10:25                 | 17:58                 | 07:33    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                       | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------|---------------------------------------|-----------------------|-----------|----------|--------------------|
| 178   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)        | NAREGAL_110                           | 10:15                 | 17:42     | 07:27    | LINE CLEAR AVAILED |
| 179   | 04-Sep-24 | BAGALKOT | 110     | LINE        | NAREGALBETAGERI            | NAREGAL_110                           | 10:31                 | 17:50     | 07:19    | LINE CLEAR AVAILED |
| 180   | 04-Sep-24 | BAGALKOT | 110     | LINE        | MURDESHWAR-RAILWAY LINE    | MURDESHWAR_110                        | 10:07                 | 12:34     | 02:27    | LINE CLEAR AVAILED |
| 181   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA-HV3)    | KULIGOD_110                           | 07:32                 | 08:09     | 00:37    | TRIPPED ON FAULT   |
| 182   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)        | KUD DHARWAD_110                       | 02:32                 | 14:06     | 11:34    | TRIPPED ON FAULT   |
| 183   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220- LN1(SAVANUR)  | SHIGGOAN_220                          | 09:59                 | 14:01     | 04:02    | LINE CLEAR AVAILED |
| 184   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220-LN4(DUNDASI)   | SHIGGOAN_220                          | 10:03                 | 15:37     | 05:34    | LINE CLEAR AVAILED |
| 185   | 04-Sep-24 | BAGALKOT | 110     | LINE        | GHATAPRABHA220- SHIRAGOAN  | GHATAPRABAH_220                       | 10:06                 | 15:55     | 05:49    | LINE CLEAR AVAILED |
| 186   | 04-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-SIRSI1               | HUBLI_220                             | 10:19                 | 17:20     | 07:01    | LINE CLEAR AVAILED |
| 187   | 04-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-SIRSI2               | HUBLI_220                             | 10:19                 | 17:18     | 06:59    | LINE CLEAR AVAILED |
| 188   | 04-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220-SIRSI(KALGHATAGI) | HUBLI_220                             | 11:47                 | 14:59     | 03:12    | LINE CLEAR AVAILED |
| 189   | 04-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220-PH COMPOUND       | HUBLI_220                             | 11:00                 | 14:46     | 03:46    | LINE CLEAR AVAILED |
| 190   | 04-Sep-24 | BAGALKOT | 110     | LINE        | CHIKKODI220- NANADI        | CHIKKODI_220                          | 15:07                 | 16:39     | 01:32    | LINE CLEAR AVAILED |
| 191   | 04-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS1            | BELGAUM_220                           | 11:21                 | 12:42     | 01:21    | LINE CLEAR AVAILED |
| 192   | 04-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS2            | BELGAUM_220                           | 12:52                 | 14:24     | 01:32    | LINE CLEAR AVAILED |
| 193   | 04-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -F1(BELGAUM1)        | AEQUS_220                             | 11:18                 | 12:42     | 01:24    | LINE CLEAR AVAILED |
| 194   | 04-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -BELGAUM2            | AEQUS_220                             | 12:51                 | 14:24     | 01:33    | LINE CLEAR AVAILED |
| 195   | 04-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN2(SANKESHWAR)   | AEQUS_220                             | 12:57                 | 15:16     | 02:19    | LINE CLEAR AVAILED |
| 196   | 04-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220- SATTI(BALIGERI) | ATHANI_220                            | 10:27                 | 17:41     | 07:14    | LINE CLEAR AVAILED |
| 197   | 04-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHARAVATHY1         | SIRSI_220                             | 10:10                 | 17:28     | 07:18    | LINE CLEAR AVAILED |
| 198   | 04-Sep-24 | BAGALKOT | 110     | LINE        | BIDNAL220- PH COMPOUND     | BIDNAL_220                            | 10:55                 | 15:25     | 04:30    | LINE CLEAR AVAILED |
| 199   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)      | THORVI_110                            | 14:50                 | 14:55     | 00:05    | TRIPPED ON FAULT   |
| 200   | 04-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1        | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 201   | 04-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2  | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 202   | 04-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2         | STATION NOT AFFECTED<br>SOUDATTI_220  | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 203   | 04-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS      | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 204   | 04-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2             | STATION NOT AFFECTED<br>HUBLI_220     | 18:52<br>(17.08.2024) |           |          | TRIPPED ON FAULT   |
| 205   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)        | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 206   | 04-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI           | STATION NOT AFFECTED<br>HIDKALDAM_110 | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAILED |
| 207   | 04-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2               | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-------------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 208   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)             | ZALKI_110                                | 20:40<br>(02.09.2024) | 11:46<br>(04.09.2024) | 15:10    | LINE CLEAR AVAIED |
| 209   | 04-Sep-24 | BAGALKOT | 110     | LINE        | ARGA-ANKOLA                         | ANKOLA_110                               | 06:45                 | 07:38                 | 00:53    | TRIPPED ON FAULT  |
| 210   | 04-Sep-24 | BAGALKOT | 110     | LINE        | BANAHATTI-JAMAKHANDI<br>(NAVALAGI ) | BANAHATTI_110                            | 10:25                 | 17:55                 | 07:30    | LINE CLEAR AVAIED |
| 211   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | ZALKI_110                                | 06:30                 | 06:35                 | 00:05    | TRIPPED ON FAULT  |
| 212   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | UGAR KHUD_110                            | 10:15                 | 17:15                 | 07:00    | LINE CLEAR AVAIED |
| 213   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                | NANADI_110                               | 11:51                 | 16:42                 | 04:51    | LINE CLEAR AVAIED |
| 214   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                | NANADI_110                               | 10:08                 | 17:50                 | 07:42    | LINE CLEAR AVAIED |
| 215   | 04-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- NARENDRA2                  | BELGAUM_220                              | 15:10                 | 16:08                 | 00:58    | LINE CLEAR AVAIED |
| 216   | 04-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220- SULTANPUR             | MUGALKHOD_220                            | 10:40                 | 18:47                 | 08:07    | LINE CLEAR AVAIED |
| 217   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                | SIRSI_220                                | 10:02                 | 19:30                 | 09:28    | LINE CLEAR AVAIED |
| 218   | 04-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                | SIRSI_220                                | 10:02                 | 18:05                 | 08:03    | LINE CLEAR AVAIED |
| 219   | 04-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                      | SIRSI_220                                | 10:09                 | 17:53                 | 07:44    | LINE CLEAR AVAIED |
| 220   | 04-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                      | SIRSI_220                                | 10:09                 | 17:54                 | 07:45    | LINE CLEAR AVAIED |
| 221   | 04-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHARAVATHY2                  | SIRSI_220                                | 10:10                 | 17:29                 | 07:19    | LINE CLEAR AVAIED |
| 222   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI220- SIRSI1                    | SIRSI_220                                | 10:08                 | 18:04                 | 07:56    | LINE CLEAR AVAIED |
| 223   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI220- SIRSI2                    | SIRSI_220                                | 10:08                 | 18:04                 | 07:56    | LINE CLEAR AVAIED |
| 224   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI220- KAWALWADA                 | SIRSI_220                                | 10:08                 | 18:02                 | 07:54    | LINE CLEAR AVAIED |
| 225   | 04-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI220- UMMACHAGI                 | SIRSI_220                                | 10:08                 | 18:06                 | 07:58    | LINE CLEAR AVAIED |
| 226   | 05-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR            | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 227   | 05-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                 | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 228   | 05-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                    | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 229   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                      | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) |                       |          | TRIPPED ON FAULT  |
| 230   | 05-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)            | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 231   | 05-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                        | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 232   | 05-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                      | MACHE_110                                | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 233   | 05-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)                | SIRSI_110                                | 18:10<br>(04.09.2024) |                       |          | LINE CLEAR AVAIED |
| 234   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV4(20MVA)                | ATHANI_110                               | 10:20                 | 11:22                 | 01:02    | TRIPPED ON FAULT  |
| 235   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV4(20MVA)                | ATHANI_110                               | 12:20                 | 12:27                 | 00:07    | TRIPPED ON FAULT  |
| 236   | 05-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGI-JAMAKHANDI                 | NAVALAGI_110                             | 16:13                 | 18:11                 | 01:58    | LINE CLEAR AVAIED |
| 237   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | UAS DHARWAD_110                          | 19:21                 | 19:31                 | 00:10    | TRIPPED ON FAULT  |
| 238   | 05-Sep-24 | BAGALKOT | 110     | LINE        | UAS DHARWAD-1(NARENDRA1)            | UAS DHARWAD_110                          | 11:35                 | 14:57                 | 03:22    | LINE CLEAR AVAIED |
| 239   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | SULTANPUR_110                            | 14:50                 | 16:25                 | 01:35    | LINE CLEAR AVAIED |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                           | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS           |
|-------|-----------|----------|---------|-------------|--------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|-------------------|
| 240   | 05-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN-RAMANAKOPPA(MUNDAGOD) | SHIGGOAN_110                             | 15:41                 | 18:05                 | 02:24     | LINE CLEAR AVAIED |
| 241   | 05-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-MANTUR1          | VAJRAMATTI_220                           | 11:08                 | 13:44                 | 02:36     | LINE CLEAR AVAIED |
| 242   | 05-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-MANTUR2          | VAJRAMATTI_220                           | 15:09                 | 17:11                 | 02:02     | LINE CLEAR AVAIED |
| 243   | 05-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220-LN2(MUNDAGOD)      | SHIGGOAN_220                             | 15:39                 | 17:54                 | 02:15     | LINE CLEAR AVAIED |
| 244   | 05-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220-LN4(SAVANUR)       | SHIGGOAN_220                             | 01:13                 | 01:43                 | 00:30     | TRIPPED ON FAULT  |
| 245   | 05-Sep-24 | BAGALKOT | 220     | LINE        | BIJAPUR- VAISHALI1             | BIJAPUR_220                              | 12:04                 | 17:00                 | 04:56     | LINE CLEAR AVAIED |
| 246   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)           | HALIYAL(ATHANI)_110                      | 09:01                 | 14:02                 | 05:01     | LINE CLEAR AVAIED |
| 247   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)           | HALIYAL(ATHANI)_110                      | 09:01                 | 14:02                 | 05:01     | LINE CLEAR AVAIED |
| 248   | 05-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1            | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAIED |
| 249   | 05-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2      | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAIED |
| 250   | 05-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2             | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAIED |
| 251   | 05-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS          | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 252   | 05-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                 | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) | 20:14<br>(05.09.2024) | 457:22:00 | TRIPPED ON FAULT  |
| 253   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)            | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |                       |           | TRIPPED ON FAULT  |
| 254   | 05-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI               | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |           | LINE CLEAR AVAIED |
| 255   | 05-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                   | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |           | LINE CLEAR AVAIED |
| 256   | 05-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)           | HALIYAL_110                              | 10:17                 | 11:42                 | 01:25     | TRIPPED ON FAULT  |
| 257   | 06-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR       | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAIED |
| 258   | 06-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2            | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAIED |
| 259   | 06-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2               | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 260   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2 (100MVA)        | STATION NOT AFFECTED<br>HUBLI_220        | 18:52<br>(17.08.2024) | 13:22<br>(06.09.2024) | 474:30:00 | TRIPPED ON FAULT  |
| 261   | 06-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)       | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAIED |
| 262   | 06-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                   | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 263   | 06-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                 | MACHE_110                                | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAIED |
| 264   | 06-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)           | SIRSI_110                                | 18:10<br>(04.09.2024) |                       |           | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------------------|---------------------------------------|-----------------------|-----------|----------|--------------------|
| 265   | 06-Sep-24 | BAGALKOT | 110     | LINE        | DADDI-F2 (HONAGA)                     | DADDI_110                             | 14:53                 | 15:18     | 00:25    | TRIPPED ON FAULT   |
| 266   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA-HV2)               | GAJENDRAGAD_110                       | 09:14                 | 09:46     | 00:32    | TRIPPED ON FAULT   |
| 267   | 06-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | GAJENDRAGAD_110                       | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAILED |
| 268   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(10 MVA)                  | HUKKERI_110                           | 11:05                 | 11:43     | 00:38    | LINE CLEAR AVAILED |
| 269   | 06-Sep-24 | BAGALKOT | 110     | LINE        | KUMTA-SIRSI1                          | KUMTA_110                             | 13:53                 | 15:05     | 01:12    | LINE CLEAR AVAILED |
| 270   | 06-Sep-24 | BAGALKOT | 66      | TRANSFORMER | 66/11KV,HV2(12.5MVA)                  | HARIHAR-HOSPET_66                     | 16:05                 | 16:43     | 00:38    | LINE CLEAR AVAILED |
| 271   | 06-Sep-24 | BAGALKOT | 66      | TRANSFORMER | 66/11KV HV2 (12.5MVA)                 | HARIHAR-HOSPET_66                     | 16:05                 | 16:43     | 00:38    | LINE CLEAR AVAILED |
| 272   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)                 | UTTUR_110                             | 10:27                 | 11:23     | 00:56    | LINE CLEAR AVAILED |
| 273   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                 | SULTANPUR_110                         | 14:46                 | 15:01     | 00:15    | LINE CLEAR AVAILED |
| 274   | 06-Sep-24 | BAGALKOT | 110     | LINE        | UGARKHUD-KUDACHI                      | UGARKHUD_110                          | 11:50                 | 14:10     | 02:20    | LINE CLEAR AVAILED |
| 275   | 06-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-HUBLI1                          | SIRSI_110                             | 14:01                 | 14:51     | 00:50    | LINE CLEAR AVAILED |
| 276   | 06-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-HUBLI2                          | SIRSI_110                             | 14:01                 | 14:51     | 00:50    | LINE CLEAR AVAILED |
| 277   | 06-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- NAGJHARI2                     | BIDNAL_220                            | 11:07                 | 13:33     | 02:26    | LINE CLEAR AVAILED |
| 278   | 06-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- BEDI                      | MKHUBLI_220                           | 06:36                 | 07:07     | 00:31    | TRIPPED ON FAULT   |
| 279   | 06-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220-<br>LN10(KULIGOD)        | MUGALKHOD_220                         | 04:53                 | 05:07     | 00:14    | TRIPPED ON FAULT   |
| 280   | 06-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                        | KUDACHI_220                           | 10:13                 | 13:21     | 03:08    | LINE CLEAR AVAILED |
| 281   | 06-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                        | KUDACHI_220                           | 14:35                 | 18:41     | 04:06    | LINE CLEAR AVAILED |
| 282   | 06-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- RATTIHALLI             | RANEBENNUR_220                        | 16:15                 | 16:25     | 00:10    | LINE CLEAR AVAILED |
| 283   | 06-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- HIREKERUR              | RANEBENNUR_220                        | 16:20                 | 16:21     | 00:01    | LINE CLEAR AVAILED |
| 284   | 06-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220-<br>AREMELLAPUR         | RANEBENNUR_220                        | 16:20                 | 16:21     | 00:01    | LINE CLEAR AVAILED |
| 285   | 06-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- BYADAGI                | RANEBENNUR_220                        | 16:20                 | 16:22     | 00:02    | LINE CLEAR AVAILED |
| 286   | 06-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220- LOKAPUR                | VAJRAMATTI_220                        | 10:44                 | 12:24     | 01:40    | LINE CLEAR AVAILED |
| 287   | 06-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 288   | 06-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 289   | 06-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 290   | 06-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 291   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 292   | 06-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110 | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAILED |
| 293   | 06-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAILED |
| 294   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                          | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT   |
| 295   | 06-Sep-24 | BAGALKOT | 110     | LINE        | KUMTA-SIRSI2                          | KUMTA_110                             | 13:48                 | 14:59     | 01:11    | LINE CLEAR AVAILED |
| 296   | 06-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-ESSALE                          | SIRSI_110                             | 14:01                 | 14:51     | 00:50    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 297   | 06-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)                 | MKHUBLI_110                              | 11:55                 | 12:30     | 00:35    | LINE CLEAR AVAIED |
| 298   | 06-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-ARGA(KUMTA)                 | KARWAR_220                               | 14:58                 | 15:02     | 00:04    | TRIPPED ON FAULT  |
| 299   | 06-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220- UGARKHUD                  | KUDACHI_220                              | 11:50                 | 14:10     | 02:20    | LINE CLEAR AVAIED |
| 300   | 06-Sep-24 | BAGALKOT | 220     | LINE        | RANEENNUR- BELLIGAVI                  | RANEENNUR_220                            | 16:15                 | 19:27     | 03:12    | TRIPPED ON FAULT  |
| 301   | 07-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 302   | 07-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 303   | 07-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 304   | 07-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 305   | 07-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 306   | 07-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | MACHE_110                                | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 307   | 07-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)                  | SIRSI_110                                | 18:10<br>(04.09.2024) |           |          | LINE CLEAR AVAIED |
| 308   | 07-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | GAJENDRAGAD_110                          | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 309   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | ANKALAGI_110                             | 11:03                 | 12:09     | 01:06    | LINE CLEAR AVAIED |
| 310   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(10 MVA,HV4)              | HANGAL_110                               | 17:10<br>(07.09.2024) |           |          | TRIPPED ON FAULT  |
| 311   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA-HV3)               | KULIGOD_110                              | 15:37                 | 16:20     | 00:43    | TRIPPED ON FAULT  |
| 312   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)                 | ZALKI_110                                | 13:57                 | 14:05     | 00:08    | TRIPPED ON FAULT  |
| 313   | 07-Sep-24 | BAGALKOT | 110     | LINE        | SALAHALI-SHIVASAGAR SUGARS            | SALAHALLI_110                            | 18:46                 | 18:49     | 00:03    | LINE CLEAR AVAIED |
| 314   | 07-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220- TERDAL(MORAB)             | KUDACHI_220                              | 03:21                 | 03:34     | 00:13    | TRIPPED ON FAULT  |
| 315   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                        | HUBLI_220                                | 11:51                 | 13:30     | 01:39    | LINE CLEAR AVAIED |
| 316   | 07-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |
| 317   | 07-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED |
| 318   | 07-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED |
| 319   | 07-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED |
| 320   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT  |
| 321   | 07-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAIED |
| 322   | 07-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 323   | 07-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |                       |          | TRIPPED ON FAULT  |
| 324   | 08-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 325   | 08-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 326   | 08-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 327   | 08-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 328   | 08-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 329   | 08-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | MACHE_110                                | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 330   | 08-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)                  | SIRSI_110                                | 18:10<br>(04.09.2024) |                       |          | LINE CLEAR AVAIED |
| 331   | 08-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | GAJENDRAGAD_110                          | 11:05 (06.09.2024)    |                       |          | LINE CLEAR AVAIED |
| 332   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV3 (10 MVA,HV4)            | HANGAL_110                               | 17:10<br>(07.09.2024) | 17:49<br>(08.09.2024) | 24:39:00 | TRIPPED ON FAULT  |
| 333   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20 MVA)                  | AINAPURA_110                             | 16:19                 | 18:39                 | 02:20    | TRIPPED ON FAULT  |
| 334   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA )                  | BANAHATTI_110                            | 16:38                 | 16:45                 | 00:07    | TRIPPED ON FAULT  |
| 335   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20 MVA)                  | ITNAL_110                                | 03:26                 | 03:31                 | 00:05    | TRIPPED ON FAULT  |
| 336   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV4 (10MVA)                 | SADALAGA_110                             | 16:42                 | 17:04                 | 00:22    | TRIPPED ON FAULT  |
| 337   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)                 | RATTIHALLI_110                           | 06:50                 | 06:55                 | 00:05    | TRIPPED ON FAULT  |
| 338   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)                 | MAMADAPUR(B)_110                         | 14:32                 | 14:40                 | 00:08    | TRIPPED ON FAULT  |
| 339   | 08-Sep-24 | BAGALKOT | 110     | LINE        | HAVERI220- TILUVALLI(HANGAL)          | HAVERI_220                               | 06:18                 | 06:38                 | 00:20    | TRIPPED ON FAULT  |
| 340   | 08-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR220- GSML1                | MAHALINGAPUR_220                         | 08:36                 | 16:40                 | 08:04    | LINE CLEAR AVAIED |
| 341   | 08-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR220- GSML2                | MAHALINGAPUR_220                         | 08:36                 | 16:40                 | 08:04    | LINE CLEAR AVAIED |
| 342   | 08-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |          | LINE CLEAR AVAIED |
| 343   | 08-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |          | LINE CLEAR AVAIED |
| 344   | 08-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |                       |          | LINE CLEAR AVAIED |
| 345   | 08-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 346   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |                       |          | TRIPPED ON FAULT  |
| 347   | 08-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |          | LINE CLEAR AVAIED |
| 348   | 08-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 349   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT  |
| 350   | 08-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                  | ATHANI_220                               | 23:30<br>(08.09.2024) |           |          | TRIPPED ON FAULT  |
| 351   | 09-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 352   | 09-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 353   | 09-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 354   | 09-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 355   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 356   | 09-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | MACHE_110                                | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 357   | 09-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)                  | SIRSI_110                                | 18:10<br>(04.09.2024) |           |          | LINE CLEAR AVAIED |
| 358   | 09-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | GAJENDRAGAD_110                          | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 359   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                        | HUBLI_220                                | 02:20                 | 12:42     | 10:22    | TRIPPED ON FAULT  |
| 360   | 09-Sep-24 | BAGALKOT | 220     | LINE        | KUDACHI- RVNL(SWR CHINCHALI)          | KUDACHI_220                              | 13:29                 | 16:32     | 03:03    | LINE CLEAR AVAIED |
| 361   | 09-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI- PONDA2                      | AMBEWADI_220                             | 14:26                 | 15:42     | 01:16    | TRIPPED ON FAULT  |
| 362   | 09-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI- NAGJHARI1                   | AMBEWADI_220                             | 14:27                 | 14:47     | 00:20    | TRIPPED ON FAULT  |
| 363   | 09-Sep-24 | BAGALKOT | 220     | LINE        | KARWAR-KADRA1                         | KARWAR_220                               | 19:09 (09.09.2024)    |           |          | TRIPPED ON FAULT  |
| 364   | 09-Sep-24 | BAGALKOT | 220     | LINE        | HAVERI220- SAVANUR                    | HAVERI_220                               | 17:35                 | 17:45     | 00:10    | TRIPPED ON FAULT  |
| 365   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-SOLARIS(BINAGA)             | KARWAR_220                               | 19:44                 | 22:05     | 02:21    | LINE CLEAR AVAIED |
| 366   | 09-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1                         | KARWAR_220                               | 19:35                 | 21:58     | 02:23    | LINE CLEAR AVAIED |
| 367   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-ARGA(KUMTA)                 | KARWAR_220                               | 21:43                 | 21:49     | 00:06    | LINE CLEAR AVAIED |
| 368   | 09-Sep-24 | BAGALKOT | 220     | LINE        | MUGALKHOD- GHATAPRABHA1               | MUGALKHOD_220                            | 11:15                 | 12:59     | 01:44    | LINE CLEAR AVAIED |
| 369   | 09-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220-<br>LN8(SULTANPUR)       | MUGALKHOD_220                            | 18:19                 | 18:33     | 00:14    | TRIPPED ON FAULT  |
| 370   | 09-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220- LN4(SHIGGOAN)            | SHIGGOAN_220                             | 15:11                 | 17:21     | 02:10    | LINE CLEAR AVAIED |
| 371   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR-ARGA                           | ARGA_110                                 | 19:36                 | 19:37     | 00:01    | LINE CLEAR AVAIED |
| 372   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR-ARGA                           | ARGA_110                                 | 19:44                 | 19:50     | 00:06    | LINE CLEAR AVAIED |
| 373   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)                 | THORVI_110                               | 13:09                 | 13:16     | 00:07    | TRIPPED ON FAULT  |
| 374   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)                 | THORVI_110                               | 14:17                 | 14:23     | 00:06    | TRIPPED ON FAULT  |
| 375   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KADANKOPPA-KAVALWADA                  | KADANKOPPA_110                           | 02:20                 | 09:38     | 07:18    | LINE CLEAR AVAIED |
| 376   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                 | KADANKOPPA_110                           | 02:20                 | 03:03     | 00:43    | TRIPPED ON FAULT  |
| 377   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                 | KADANKOPPA_110                           | 02:20                 | 03:03     | 00:43    | TRIPPED ON FAULT  |
| 378   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KADANKOPPA-SRS HUBLI                  | KADANKOPPA_110                           | 02:20                 | 03:03     | 00:43    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                        | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|-----------------------------|------------------------------------------|-----------------------|-----------------------|-----------|--------------------|
| 379   | 09-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-SIRSI             | KIRUVATTI_110                            | 10:10<br>(04.09.2024) | 14:12<br>(09.09.2024) | 124:02:00 | LINE CLEAR AVAILED |
| 380   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)       | LAKAMANAHALLI_110                        | 14:32                 | 15:02                 | 0:30      | LINE CLEAR AVAILED |
| 381   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)       | SIRSI_110                                | 11:06                 | 11:20                 | 0:14      | LINE CLEAR AVAILED |
| 382   | 09-Sep-24 | BAGALKOT | 110     | LINE        | SALAHALLI-SHIVASAGAR SUGARS | SALAHALLI_110                            | 05:10                 | 06:54                 | 1:44      | TRIPPED ON FAULT   |
| 383   | 09-Sep-24 | BAGALKOT | 110     | LINE        | TODALBAGI-JAMAKHANDI SUGARS | TODALBAGI_110                            | 06:08                 | 06:45                 | 0:37      | TRIPPED ON FAULT   |
| 384   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)       | RAMANAKOPPA_110                          | 12:42                 | 13:05                 | 0:23      | LINE CLEAR AVAILED |
| 385   | 09-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1         | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAILED |
| 386   | 09-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2   | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAILED |
| 387   | 09-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2          | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAILED |
| 388   | 09-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS       | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 389   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)         | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |                       |           | TRIPPED ON FAULT   |
| 390   | 09-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI            | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |           | LINE CLEAR AVAILED |
| 391   | 09-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |           | LINE CLEAR AVAILED |
| 392   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)        | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |                       |           | TRIPPED ON FAULT   |
| 393   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)        | ATHANI_220                               | 23:30<br>(08.09.2024) | 13:15<br>(09.09.2024) | 13:15     | TRIPPED ON FAULT   |
| 394   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV4(20MVA)        | ANKALI_110                               | 01:20                 | 01:40                 | 00:20     | TRIPPED ON FAULT   |
| 395   | 09-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2              | KARWAR_220                               | 11:08                 | 12:43                 | 01:35     | LINE CLEAR AVAILED |
| 396   | 09-Sep-24 | BAGALKOT | 220     | LINE        | KARWAR-KADRA2               | KARWAR_220                               | 19:09                 | 21:36                 | 02:27     | TRIPPED ON FAULT   |
| 397   | 09-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV2               | KARWAR_220                               | 19:35                 | 21:44                 | 02:09     | LINE CLEAR AVAILED |
| 398   | 09-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220- GHATANATTI       | ATHANI_220                               | 6:11                  | 6:28                  | 00:17     | TRIPPED ON FAULT   |
| 399   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)       | MORATAGI_110                             | 07:50                 | 08:20                 | 00:30     | LINE CLEAR AVAILED |
| 400   | 09-Sep-24 | BAGALKOT | 110     | LINE        | SALAHALLI-LOKAPUR           | SALAHALLI_110                            | 05:10                 | 05:28                 | 00:18     | TRIPPED ON FAULT   |
| 401   | 09-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)        | ATHANI_220                               | 17:33                 | 18:24                 | 0:55      | TRIPPED ON FAULT   |
| 402   | 10-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR    | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAILED |
| 403   | 10-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2         | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAILED |
| 404   | 10-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2           | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 405   | 10-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)    | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAILED |
| 406   | 10-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |           | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                          | Open_At               | Closed_At             | Duration  | REMARKS             |
|-------|-----------|----------|---------|-------------|---------------------------------------|---------------------------------------|-----------------------|-----------------------|-----------|---------------------|
| 407   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | MACHE_110                             | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAILED  |
| 408   | 10-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-JOG1(SIDDAPUR)                  | SIRSI_110                             | 18:10<br>(04.09.2024) | 9:47<br>(10.09.2024)  | 135:37:00 | LINE CLEAR AVAILED  |
| 409   | 10-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | GAJENDRAGAD_110                       | 11:05 (06.09.2024)    |                       |           | LINE CLEAR AVAILED  |
| 410   | 10-Sep-24 | BAGALKOT | 220     | LINE        | KARWAR-KADRA1                         | KARWAR_220                            | 19:09 (09.09.2024)    | 14:34<br>(10.09.2024) | 19:25     | TRIPPED ON FAULT    |
| 411   | 10-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-BIDNAL2                         | HUBLI_220                             | 11:41                 | 17:41                 | 06:00     | LINE CLEAR AVAILED  |
| 412   | 10-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-HUBLI3(HUBLI2)                 | BIDNAL_220                            | 11:41                 | 17:41                 | 06:00     | LINE CLEAR AVAILED  |
| 413   | 10-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-ARGA(KUMTA)                 | KARWAR_220                            | 11:22                 | 11:32                 | 00:10     | LINE CLEAR AVAILED  |
| 414   | 10-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-SOLARIS(BINAGA)             | KARWAR_220                            | 11:27                 | 12:23                 | 00:56     | LINE CLEAR AVAILED  |
| 415   | 10-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-SOLARIS(BINAGA)             | KARWAR_220                            | 14:40                 | 14:46                 | 00:06     | LINE CLEAR AVAILED  |
| 416   | 10-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR220-ARGA(KUMTA)                 | KARWAR_220                            | 14:41                 | 14:47                 | 00:06     | LINE CLEAR AVAILED  |
| 417   | 10-Sep-24 | BAGALKOT | 110     | LINE        | ALBHAL_RAY SOLAR                      | ALBAL_110                             | 19:17<br>(10.09.2024) |                       |           | LINE CLEAR AVAILED  |
| 418   | 10-Sep-24 | BAGALKOT | 110     | LINE        | ARGA-ANKOLA                           | ARGA_110                              | 20:49                 | 22:20                 | 1:31      | TRIPPED ON FAULT    |
| 419   | 10-Sep-24 | BAGALKOT | 110     | LINE        | ATHARGA-B BAGEWADI                    | ATHARGA_110                           | 14:15                 | 21:19                 | 7:04      | MAIN SUPPLY FAILURE |
| 420   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)                 | BANAHATTI_110                         | 16:35                 | 17:30                 | 0:55      | LINE CLEAR AVAILED  |
| 421   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV2 (20MVA,HV1)             | GAJENDRAGADA_110                      | 18:18                 | 18:47                 | 0:29      | TRIPPED ON FAULT    |
| 422   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA)                 | KALADAGI_110                          | 14:52                 | 15:29                 | 0:37      | LINE CLEAR AVAILED  |
| 423   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | TUMMINAKATTI_110                      | 10:16                 | 11:06                 | 0:50      | LINE CLEAR AVAILED  |
| 424   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                   | TUMMINAKATTI_110                      | 11:16                 | 17:01                 | 5:45      | TRIPPED ON FAULT    |
| 425   | 10-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-KAVALWADA(SIRSI2)               | SIRSI_110                             | 09:46                 | 18:07                 | 8:21      | LINE CLEAR AVAILED  |
| 426   | 10-Sep-24 | BAGALKOT | 110     | LINE        | SIRSI-HUBLI1(SIRSI1)                  | SIRSI_110                             | 09:47                 | 18:06                 | 8:19      | LINE CLEAR AVAILED  |
| 427   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(10MVA)                   | RATTIHALLI_110                        | 16:07                 | 16:31                 | 0:24      | LINE CLEAR AVAILED  |
| 428   | 10-Sep-24 | BAGALKOT | 110     | LINE        | NAREGAL-BETAGERI                      | NAREGAL_110                           | 15:52<br>(10.09.2024) |                       |           | LINE CLEAR AVAILED  |
| 429   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MUDEDEBIHAL-KNMSLR(KOLUR)             | MUDEDEBIHAL_110                       | 16:12<br>(10.09.2024) |                       |           | TRIPPED ON FAULT    |
| 430   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                   | MANTUR(GHP)_110                       | 16:05                 | 17:02                 | 00:57     | LINE CLEAR AVAILED  |
| 431   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR-BAGEWADI                    | MAMADAPUR(B)_110                      | 22:02                 | 22:16                 | 00:14     | TRIPPED ON FAULT    |
| 432   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAILED  |
| 433   | 10-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAILED  |
| 434   | 10-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAILED  |
| 435   | 10-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAILED  |
| 436   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |                       |           | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|-------------------|
| 437   | 10-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |           | LINE CLEAR AVAIED |
| 438   | 10-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |           | LINE CLEAR AVAIED |
| 439   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |                       |           | TRIPPED ON FAULT  |
| 440   | 10-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F7-RAMDURG                | BAGALKOT_220                             | 14:50                 | 17:28                 | 02:38     | LINE CLEAR AVAIED |
| 441   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV1                        | KARWAR_220                               | 11:28                 | 14:41                 | 03:13     | LINE CLEAR AVAIED |
| 442   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                        | KARWAR_220                               | 11:33                 | 14:41                 | 03:08     | LINE CLEAR AVAIED |
| 443   | 10-Sep-24 | BAGALKOT | 220     | LINE        | KARWAR- KADRA2                        | KARWAR_220                               | 11:40                 | 14:36                 | 02:56     | LINE CLEAR AVAIED |
| 444   | 10-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220- GHATANATTI                 | ATHANI_220                               | 06:11                 | 06:28                 | 00:17     | TRIPPED ON FAULT  |
| 445   | 10-Sep-24 | BAGALKOT | 110     | LINE        | BAGEWADI220-<br>DEVARHIPPARAGI        | BAGEWADI_220                             | 14:13                 | 21:08                 | 06:55     | TRIPPED ON FAULT  |
| 446   | 10-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | ZALKI_110                                | 12:15                 | 12:25                 | 00:10     | TRIPPED ON FAULT  |
| 447   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MUDEDEBIHAL-BAALAJI SUGAR             | MUDEDEBIHAL_110                          | 16:15                 | 16:40                 | 00:25     | TRIPPED ON FAULT  |
| 448   | 10-Sep-24 | BAGALKOT | 110     | LINE        | MUDEDEBIHAL-BAALAJI SUGAR             | MUDEDEBIHAL_110                          | 18:35                 | 18:45                 | 00:10     | TRIPPED ON FAULT  |
| 449   | 11-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAIED |
| 450   | 11-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAIED |
| 451   | 11-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 452   | 11-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAIED |
| 453   | 11-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 454   | 11-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAIED |
| 455   | 11-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |                       |           | LINE CLEAR AVAIED |
| 456   | 11-Sep-24 | BAGALKOT | 110     | LINE        | ALBHAL_RAY SOLAR                      | STATION NOT AFFECTED<br>ALBAL_110        | 19:17<br>(10.09.2024) | 3:56<br>(11.09.2024)  | 8:39:00   | LINE CLEAR AVAIED |
| 457   | 11-Sep-24 | BAGALKOT | 110     | LINE        | NAREGAL-BETAGERI                      | STATION NOT AFFECTED<br>NAREGAL_110      | 15:52<br>(10.09.2024) | 14:19<br>(11.09.2024) | 22:27:00  | LINE CLEAR AVAIED |
| 458   | 11-Sep-24 | BAGALKOT | 110     | LINE        | MUDEDEBIHAL-KNMSLR(KOLUR)             | STATION NOT AFFECTED<br>MUDEDEBIHAL_110  | 16:12<br>(10.09.2024) | 1:58<br>(11.09.2024)  | 9:46:00   | TRIPPED ON FAULT  |
| 459   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | THORVI_110                               | 15:27                 | 15:34                 | 0:07      | TRIPPED ON FAULT  |
| 460   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(10MVA-HV4)               | HANGAL_110                               | 12:04                 | 16:48                 | 4:44      | LINE CLEAR AVAIED |
| 461   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(10MVA-HV2)               | SADALAGA_110                             | 15:00                 | 15:29                 | 00:29     | TRIPPED ON FAULT  |
| 462   | 11-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-VPPL                         | SADALAGA_110                             | 16:14                 | 16:38                 | 00:24     | LINE CLEAR AVAIED |
| 463   | 11-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGI-F2(BANAHATTI)                | NAVALAGI_110                             | 01:06                 | 07:00                 | 05:54     | LINE CLEAR AVAIED |
| 464   | 11-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGI-F1(JAMAKHANDI)               | NAVALAGI_110                             | 17:55<br>(04.09.2024) | 1:11<br>(11.09.2024)  | 151:16:00 | LINE CLEAR AVAIED |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 465   | 11-Sep-24 | BAGALKOT | 110     | LINE        | NARAGUND-BPCL                         | NARAGUND_110                             | 12:17                 | 13:08     | 00:51    | TRIPPED ON FAULT  |
| 466   | 11-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI- SIRSI1                         | HUBLI_220                                | 09:58                 | 14:18     | 04:20    | TRIPPED ON FAULT  |
| 467   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV2(20MVA)                  | HUBLI_220                                | 11:15                 | 16:45     | 05:30    | LINE CLEAR AVAIED |
| 468   | 11-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |
| 469   | 11-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED |
| 470   | 11-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED |
| 471   | 11-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED |
| 472   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT  |
| 473   | 11-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAIED |
| 474   | 11-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAIED |
| 475   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT  |
| 476   | 11-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                  | RAIBAL_110                               | 16:52                 | 17:36     | 00:44    | TRIPPED ON FAULT  |
| 477   | 11-Sep-24 | BAGALKOT | 110     | LINE        | BIDNAL220- PH COMPOUND                | BIDNAL_220                               | 12:16                 | 15:14     | 02:58    | LINE CLEAR AVAIED |
| 478   | 11-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1&LV1                    | NARENDRA_220                             | 09:31                 | 11:20     | 01:49    | LINE CLEAR AVAIED |
| 479   | 11-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2&LV2                    | NARENDRA_220                             | 11:46                 | 14:20     | 02:34    | LINE CLEAR AVAIED |
| 480   | 11-Sep-24 | BAGALKOT | 110     | LINE        | GUTTAL- HOSAHONNATTI                  | GUTTAL_110                               | 18:02                 | 18:22     | 00:20    | TRIPPED ON FAULT  |
| 481   | 12-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 482   | 12-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 483   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 484   | 12-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 485   | 12-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 486   | 12-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 487   | 12-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 488   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (10MVA)                  | ANNIGERE_110                             | 11:35                 | 12:41     | 1:06     | TRIPPED ON FAULT  |
| 489   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | BILAGI_110                               | 11:36                 | 11:59     | 0:23     | LINE CLEAR AVAIED |
| 490   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA-HV1)               | KADANKOPPA_110                           | 22:20                 | 23:16     | 0:56     | LINE CLEAR AVAIED |
| 491   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | SAMBAPUR ROAD_110                        | 13:45                 | 14:20     | 00:35    | LINE CLEAR AVAIED |
| 492   | 12-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                           | RON_110                                  | 03:39                 | 04:10     | 00:31    | TRIPPED ON FAULT  |
| 493   | 12-Sep-24 | BAGALKOT | 110     | LINE        | NIPPANI-HSSSK                         | NIPPANI_110                              | 10:41                 | 11:33     | 00:52    | TRIPPED ON FAULT  |
| 494   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | KAVALLWADA_110                           | 11:47                 | 12:24     | 00:37    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|-----------------------------------|---------------------------------------|-----------------------|-----------|----------|--------------------|
| 495   | 12-Sep-24 | BAGALKOT | 220     | LINE        | GHATAPRABHA- MUGALKHOD2           | GHATAPRABHA_220                       | 11:45                 | 13:14     | 01:29    | LINE CLEAR AVAILED |
| 496   | 12-Sep-24 | BAGALKOT | 220     | LINE        | SHIGGOAN- BIDNAL                  | SHIGGOAN_220                          | 13:30                 | 15:40     | 02:10    | LINE CLEAR AVAILED |
| 497   | 12-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI- PONDA2                  | AMBEWADI_220                          | 8:27<br>(12.09.2024)  |           |          | LINE CLEAR AVAILED |
| 498   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - VAJRAMATTI1            | BAGALKOT_220                          | 12:21                 | 19:46     | 07:25    | LINE CLEAR AVAILED |
| 499   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - VAJRAMATTI2            | BAGALKOT_220                          | 10:43                 | 12:19     | 01:36    | LINE CLEAR AVAILED |
| 500   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-<br>TADAS2(HIREBENDIGER12) | BIDNAL_220                            | 05:48                 | 09:34     | 03:46    | TRIPPED ON FAULT   |
| 501   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-<br>TADAS1(HIREBENDIGER11) | BIDNAL_220                            | 05:46                 | 08:34     | 02:48    | TRIPPED ON FAULT   |
| 502   | 12-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                    | HUBLI_220                             | 5:44<br>(12.08.2024)  |           |          | TRIPPED ON FAULT   |
| 503   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV1(20MVA)              | HUBLI_220                             | 11:08                 | 17:20     | 06:12    | LINE CLEAR AVAILED |
| 504   | 12-Sep-24 | BAGALKOT | 220     | LINE        | MUGALKHOD- GHATAPRABHA2           | MUGALKHOD_220                         | 11:36                 | 13:14     | 01:38    | LINE CLEAR AVAILED |
| 505   | 12-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220-LN10(KULIGOD)        | MUGALKHOD_220                         | 01:16                 | 01:38     | 00:22    | TRIPPED ON FAULT   |
| 506   | 12-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220- LN5(ITANAL3)        | MUGALKHOD_220                         | 15:52                 | 16:09     | 00:17    | TRIPPED ON FAULT   |
| 507   | 12-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI-BAGALKOT2              | VAJRAMATTI_220                        | 10:43                 | 12:19     | 01:36    | LINE CLEAR AVAILED |
| 508   | 12-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI-BAGALKOT1              | VAJRAMATTI_220                        | 12:36                 | 19:46     | 07:10    | LINE CLEAR AVAILED |
| 509   | 12-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1               | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 510   | 12-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2         | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 511   | 12-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 512   | 12-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS             | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 513   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 514   | 12-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                  | STATION NOT AFFECTED<br>HIDKALDAM_110 | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAILED |
| 515   | 12-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                      | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAILED |
| 516   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)              | AMBEWADI_220                          | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT   |
| 517   | 12-Sep-24 | BAGALKOT | 110     | LINE        | HALIYAL-GMR SUGARS                | HALIYAL_110                           | 18:43                 | 18:57     | 00:14    | TRIPPED ON FAULT   |
| 518   | 12-Sep-24 | BAGALKOT | 110     | LINE        | NIPPANI- HSL COGEN                | NIPPANI_110                           | 10:40                 | 11:30     | 00:50    | TRIPPED ON FAULT   |
| 519   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)              | SIRSI_220                             | 12:00                 | 14:11     | 02:11    | LINE CLEAR AVAILED |
| 520   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (10MVA)              | BAGALKOT_110                          | 17:00                 | 17:23     | 0:23     | LINE CLEAR AVAILED |
| 521   | 12-Sep-24 | BAGALKOT | 110     | LINE        | ITANAL-HIDKAL (KABBUR3)           | ITANAL_110                            | 15:52                 | 16:09     | 0:17     | TRIPPED ON FAULT   |
| 522   | 12-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)               | MORATAGI_110                          | 15:00                 | 15:30     | 00:30    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 523   | 13-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 524   | 13-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 525   | 13-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 526   | 13-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 527   | 13-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 528   | 13-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 529   | 13-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 530   | 13-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI- PONDA2                      | STATION NOT AFFECTED<br>AMBEWADI_220     | 8:27<br>(12.09.2024)  |           |          | LINE CLEAR AVAIED |
| 531   | 13-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                        | STATION NOT AFFECTED<br>HUBLI_220        | 5:44<br>(12.09.2024)  |           |          | TRIPPED ON FAULT  |
| 532   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | ATHARGA_110                              | 15:23                 | 16:53     | 1:30     | LINE CLEAR AVAIED |
| 533   | 13-Sep-24 | BAGALKOT | 110     | LINE        | HUKKER-HATARGI ( AEQUES220)           | HUKKERI_110                              | 17:41                 | 17:47     | 0:06     | LINE CLEAR AVAIED |
| 534   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20 MVA)                 | YALLAMANAWADI_110                        | 15:16                 | 15:58     | 0:42     | LINE CLEAR AVAIED |
| 535   | 13-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-VPPL                         | SADALAGA_110                             | 09:43                 | 12:32     | 2:49     | LINE CLEAR AVAIED |
| 536   | 13-Sep-24 | BAGALKOT | 110     | LINE        | NARAGUND-BPCL(WIND)                   | STATION NOT AFFECTED<br>NARAGUND_110     | 12:13                 | 12:56     | 0:43     | TRIPPED ON FAULT  |
| 537   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20 MVA)                  | MUNAVALLI_110                            | 08:23                 | 08:47     | 0:24     | TRIPPED ON FAULT  |
| 538   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                  | MALGHAN(B)_110                           | 18:02                 | 18:04     | 0:02     | TRIPPED ON FAULT  |
| 539   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                  | MAMADAPUR(B)_110                         | 16:32                 | 17:49     | 1:17     | LINE CLEAR AVAIED |
| 540   | 13-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                                | 11:00                 | 15:23     | 4:23     | LINE CLEAR AVAIED |
| 541   | 13-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUTTUR                         | DHONI_400                                | 11:00                 | 15:23     | 4:23     | LINE CLEAR AVAIED |
| 542   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | ATHARGA_110                              | 15:23                 | 16:53     | 1:30     | LINE CLEAR AVAIED |
| 543   | 13-Sep-24 | BAGALKOT | 110     | LINE        | HUKKER-HATARGI ( AEQUES220)           | HUKKERI_110                              | 17:41                 | 17:47     | 0:06     | LINE CLEAR AVAIED |
| 544   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20 MVA)                 | YALLAMANAWADI_110                        | 15:16                 | 15:58     | 0:42     | LINE CLEAR AVAIED |
| 545   | 13-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-VPPL                         | SADALAGA_110                             | 09:43                 | 12:32     | 2:49     | LINE CLEAR AVAIED |
| 546   | 13-Sep-24 | BAGALKOT | 110     | LINE        | NARAGUND-BPCL(WIND)                   | STATION NOT AFFECTED<br>NARAGUND_110     | 12:13                 | 12:56     | 0:43     | TRIPPED ON FAULT  |
| 547   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20 MVA)                  | MUNAVALLI_110                            | 08:23                 | 08:47     | 0:24     | TRIPPED ON FAULT  |
| 548   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                  | MALGHAN(B)_110                           | 18:02                 | 18:04     | 0:02     | TRIPPED ON FAULT  |
| 549   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                  | MAMADAPUR(B)_110                         | 16:32                 | 17:49     | 1:17     | LINE CLEAR AVAIED |
| 550   | 13-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                                | 11:00                 | 15:23     | 4:23     | LINE CLEAR AVAIED |
| 551   | 13-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUTTUR                         | DHONI_400                                | 11:00                 | 15:23     | 4:23     | LINE CLEAR AVAIED |
| 552   | 13-Sep-24 | BAGALKOT | 220     | LINE        | GADAG-BAGALKOT-1                      | GADAG_220                                | 10:28                 | 11:24     | 0:56     | LINE CLEAR AVAIED |
| 553   | 13-Sep-24 | BAGALKOT | 110     | LINE        | KUDUCHI-TERDAL(MORAB )                | KUDUCHI_220                              | 21:33                 | 22:01     | 0:28     | TRIPPED ON FAULT  |
| 554   | 13-Sep-24 | BAGALKOT | 220     | LINE        | KARWAR -KADRA2                        | KARWAR_220                               | 11:05                 | 12:44     | 1:39     | LINE CLEAR AVAIED |
| 555   | 13-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-KARIMASUTTI                 | ATHANI_220                               | 18:05                 | 19:25     | 1:20     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------------------|------------------------------------------|-----------------------|-----------|----------|--------------------|
| 556   | 13-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT-GADAG1                        | BAGALKOT_220                             | 10:29                 | 11:23     | 0:54     | LINE CLEAR AVAILED |
| 557   | 13-Sep-24 | BAGALKOT | 220     | LINE        | GHATAPRABHA-RAILWAY<br>LINE(GOKAK SWR) | GHATAPRABHA_220                          | 14:01                 | 14:44     | 0:43     | LINE CLEAR AVAILED |
| 558   | 13-Sep-24 | BAGALKOT | 110     | LINE        | KANAGALA-LN1(GOLD PLUS)                | KANAGALA_220                             | 10:14                 | 17:36     | 7:22     | LINE CLEAR AVAILED |
| 559   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                    | KANAGALA_220                             | 10:05                 | 17:23     | 7:18     | LINE CLEAR AVAILED |
| 560   | 13-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1                      | KANAGALA_220                             | 10:39                 | 17:17     | 6:38     | LINE CLEAR AVAILED |
| 561   | 13-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                    | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 562   | 13-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2              | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 563   | 13-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                     | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 564   | 13-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                  | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 565   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                    | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 566   | 13-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                       | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAILED |
| 567   | 13-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                           | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAILED |
| 568   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                   | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT   |
| 569   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 570   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                  | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 571   | 13-Sep-24 | BAGALKOT | 110     | LINE        | RAMANNKOPPA-HUBLI                      | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 572   | 13-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220- HUKKERI                      | AEQUS_220                                | 17:22                 | 17:42     | 0:20     | TRIPPED ON FAULT   |
| 573   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                   | KIADB BIJAPUR_110                        | 15:54                 | 16:55     | 1:01     | LINE CLEAR AVAILED |
| 574   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 575   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                  | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 576   | 13-Sep-24 | BAGALKOT | 110     | LINE        | RAMANNKOPPA-HUBLI                      | RAMANNKOPPA_110                          | 12:00                 | 13:45     | 1:45     | LINE CLEAR AVAILED |
| 577   | 13-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220- HUKKERI                      | AEQUS_220                                | 17:22                 | 17:42     | 0:20     | TRIPPED ON FAULT   |
| 578   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                   | KIADB BIJAPUR_110                        | 15:54                 | 16:55     | 1:01     | LINE CLEAR AVAILED |
| 579   | 13-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1                      | KUDUCHI_220                              | 09:20                 | 09:35     | 0:15     | TRIPPED ON FAULT   |
| 580   | 13-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV2,LV2                      | KUDUCHI_220                              | 09:20                 | 09:35     | 0:15     | TRIPPED ON FAULT   |
| 581   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                    | KUDUCHI_220                              | 09:20                 | 09:35     | 0:15     | TRIPPED ON FAULT   |
| 582   | 13-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-GHATANATTI                   | ATHANI_220                               | 13:46                 | 19:26     | 5:40     | LINE CLEAR AVAILED |
| 583   | 13-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                    | KANAGALA_220                             | 10:06                 | 17:24     | 7:18     | LINE CLEAR AVAILED |
| 584   | 14-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR               | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAILED |
| 585   | 14-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                    | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAILED |
| 586   | 14-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAILED |
| 587   | 14-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)               | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                            | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|-----------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 588   | 14-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110      | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 589   | 14-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110       | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 590   | 14-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110 | 11:05 (06.09.2024)    |                       |          | LINE CLEAR AVAIED |
| 591   | 14-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI- PONDA2                      | STATION NOT AFFECTED<br>AMBEWADI_220    | 8:27<br>(12.09.2024)  | 11:50<br>(14.09.2024) | 51:23:00 | LINE CLEAR AVAIED |
| 592   | 14-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                        | STATION NOT AFFECTED<br>HUBLI_220       | 5:44<br>(12.09.2024)  | 17:04<br>(14.09.2024) | 59:20:00 | TRIPPED ON FAULT  |
| 593   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)                   | ATHANI_110                              | 14:11                 | 14:45                 | 0:34     | LINE CLEAR AVAIED |
| 594   | 14-Sep-24 | BAGALKOT | 110     | LINE        | ATHARGA-KNISLR                        | ATHARGA_110                             | 18:37                 | 18:48                 | 0:11     | TRIPPED ON FAULT  |
| 595   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | BEDI_110                                | 11:52                 | 13:50                 | 1:58     | LINE CLEAR AVAIED |
| 596   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (10MVA)                  | JAMKHANDI_110                           | 09:18                 | 19:19                 | 10:01    | LINE CLEAR AVAIED |
| 597   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (10MVA)                  | JAMKHANDI_110                           | 09:20                 | 19:20                 | 10:00    | LINE CLEAR AVAIED |
| 598   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 ( HV1-10MVA)             | KADANAKOPPA_110                         | 13:00                 | 15:13                 | 2:13     | LINE CLEAR AVAIED |
| 599   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA,HV2)             | ZALKI_110                               | 22:18                 | 22:20                 | 0:02     | TRIPPED ON FAULT  |
| 600   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (10 MVA)                 | TUMMINAKATTE_110                        | 12:10                 | 13:58                 | 1:48     | LINE CLEAR AVAIED |
| 601   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)                 | NAVALAGI_110                            | 15:41                 | 16:45                 | 1:04     | LINE CLEAR AVAIED |
| 602   | 14-Sep-24 | BAGALKOT | 110     | LINE        | MATTIHAL-<br>MKHUBLI(BAGEWADI)        | MATTIHAL_110                            | 13:38                 | 13:47                 | 0:09     | TRIPPED ON FAULT  |
| 603   | 14-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                               | 8:25<br>(14.09.2024)  |                       |          | TRIPPED ON FAULT  |
| 604   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)                   | ATHANI_110                              | 14:11                 | 14:45                 | 0:34     | LINE CLEAR AVAIED |
| 605   | 14-Sep-24 | BAGALKOT | 110     | LINE        | ATHARGA-KNISLR                        | ATHARGA_110                             | 18:37                 | 18:48                 | 0:11     | TRIPPED ON FAULT  |
| 606   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | BEDI_110                                | 11:52                 | 13:50                 | 1:58     | LINE CLEAR AVAIED |
| 607   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (10MVA)                  | JAMKHANDI_110                           | 09:18                 | 19:19                 | 10:01    | LINE CLEAR AVAIED |
| 608   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (10MVA)                  | JAMKHANDI_110                           | 09:20                 | 19:20                 | 10:00    | LINE CLEAR AVAIED |
| 609   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 ( HV1-10MVA)             | KADANAKOPPA_110                         | 13:00                 | 15:13                 | 2:13     | LINE CLEAR AVAIED |
| 610   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA,HV2)             | ZALKI_110                               | 22:18                 | 22:20                 | 0:02     | TRIPPED ON FAULT  |
| 611   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (10 MVA)                 | TUMMINAKATTE_110                        | 12:10                 | 13:58                 | 1:48     | LINE CLEAR AVAIED |
| 612   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)                 | NAVALAGI_110                            | 15:41                 | 16:45                 | 1:04     | LINE CLEAR AVAIED |
| 613   | 14-Sep-24 | BAGALKOT | 110     | LINE        | MATTIHAL-<br>MKHUBLI(BAGEWADI)        | MATTIHAL_110                            | 13:38                 | 13:47                 | 0:09     | TRIPPED ON FAULT  |
| 614   | 14-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR - ARGA                         | KARWAR_220                              | 02:33                 | 16:26                 | 13:53    | TRIPPED ON FAULT  |
| 615   | 14-Sep-24 | BAGALKOT | 110     | LINE        | KARWAR -SOLARIS(BINAGA)               | KARWAR_220                              | 11:18                 | 15:02                 | 3:44     | LINE CLEAR AVAIED |
| 616   | 14-Sep-24 | BAGALKOT | 220     | LINE        | GHATAPRABHA220-<br>GHATAPRABHA-2      | GHATAPRABHA_220                         | 10:26                 | 11:12                 | 0:46     | TRIPPED ON FAULT  |
| 617   | 14-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220     | 12:40<br>(18.09.2022) |                       |          | LINE CLEAR AVAIED |
| 618   | 14-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220   | 11:47<br>(06.07.2024) |                       |          | LINE CLEAR AVAIED |
| 619   | 14-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUDATTI_220    | 10:49<br>(18.07.2024) |                       |          | LINE CLEAR AVAIED |
| 620   | 14-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220    | 4:35<br>(11.08.2024)  |                       |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 621   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT  |
| 622   | 14-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAIED |
| 623   | 14-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAIED |
| 624   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT  |
| 625   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:10     | 9:40     | LINE CLEAR AVAIED |
| 626   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:05     | 9:35     | LINE CLEAR AVAIED |
| 627   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:05     | 9:35     | LINE CLEAR AVAIED |
| 628   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:10     | 9:40     | LINE CLEAR AVAIED |
| 629   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:05     | 9:35     | LINE CLEAR AVAIED |
| 630   | 14-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2 (10MVA)                  | JAMKHANDI_110                            | 09:30                 | 19:05     | 9:35     | LINE CLEAR AVAIED |
| 631   | 14-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI-NAGJERI2-                    | AMBEWADI_220                             | 14:36                 | 15:10     | 0:34     | TRIPPED ON FAULT  |
| 632   | 14-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1                     | AMBEWADI_220                             | 15:29                 | 17:50     | 2:21     | LINE CLEAR AVAIED |
| 633   | 14-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1                     | AMBEWADI_220                             | 20:30<br>(14.09.2024) |           |          | LINE CLEAR AVAIED |
| 634   | 14-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220-MACHE EXPRESS<br>LINE      | BELGAUM_220                              | 06:19                 | 07:07     | 00:48    | TRIPPED ON FAULT  |
| 635   | 14-Sep-24 | BAGALKOT | 220     | LINE        | SOUDATTI220-MAHALINGAPURA -<br>1      | SOUDATTI_220                             | 11:16                 | 14:12     | 02:56    | LINE CLEAR AVAIED |
| 636   | 14-Sep-24 | BAGALKOT | 110     | LINE        | VAJJARAMATTI220-MANTUR LINE<br>1      | VAJJARAMATTI_220                         | 10:19                 | 14:54     | 04:35    | LINE CLEAR AVAIED |
| 637   | 14-Sep-24 | BAGALKOT | 110     | LINE        | VAJJARAMATTI220-MANTUR LINE<br>2      | VAJJARAMATTI_220                         | 10:19                 | 14:54     | 04:35    | LINE CLEAR AVAIED |
| 638   | 15-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 639   | 15-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 640   | 15-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 641   | 15-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 642   | 15-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 643   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 644   | 15-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 645   | 15-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                                | 8:25<br>(14.09.2024)  |           |          | TRIPPED ON FAULT  |
| 646   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)                   | ATHANI_110                               | 10:02                 | 11:26     | 1:24     | LINE CLEAR AVAIED |
| 647   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | BEDI_110                                 | 12:22                 | 15:10     | 2:48     | LINE CLEAR AVAIED |
| 648   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (10 MVA)                 | TUMMINAKATTE_110                         | 14:15                 | 14:51     | 0:36     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                           | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|--------------------------------|---------------------------------------|-----------------------|-----------|----------|--------------------|
| 649   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)          | NAVALAGI_110                          | 10:02                 | 12:02     | 2:00     | LINE CLEAR AVAILED |
| 650   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)          | NAVALAGI_110                          | 12:11                 | 13:00     | 0:49     | LINE CLEAR AVAILED |
| 651   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20 MVA)          | NIPPANI_110                           | 15:10                 | 15:16     | 0:06     | TRIPPED ON FAULT   |
| 652   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MUNDARGI-VIJAY SUGARS          | MUNDARGI_110                          | 06:22                 | 10:10     | 3:48     | LINE CLEAR AVAILED |
| 653   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(20 MVA)           | MUNDARGI_110                          | 15:57                 | 16:14     | 0:17     | LINE CLEAR AVAILED |
| 654   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)           | MALGHAN(B)_110                        | 03:01                 | 03:05     | 0:04     | TRIPPED ON FAULT   |
| 655   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-MAMADAPUR(MATTIHAL) | MALGHAN(B)_110                        | 10:31                 | 10:46     | 0:15     | TRIPPED ON FAULT   |
| 656   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI1         | MAMADAPUR(B)_110                      | 10:41                 | 10:45     | 0:04     | LINE CLEAR AVAILED |
| 657   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2         | MAMADAPUR(B)_110                      | 10:41                 | 10:59     | 0:18     | LINE CLEAR AVAILED |
| 658   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-SHIRABUR          | MAMADAPUR(B)_110                      | 10:40                 | 10:46     | 0:06     | LINE CLEAR AVAILED |
| 659   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)           | MAMADAPUR(B)_110                      | 22:59                 | 23:10     | 0:11     | TRIPPED ON FAULT   |
| 660   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)            | ATHANI_110                            | 10:02                 | 11:26     | 1:24     | LINE CLEAR AVAILED |
| 661   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)            | BEDI_110                              | 12:22                 | 15:10     | 2:48     | LINE CLEAR AVAILED |
| 662   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (10 MVA)          | TUMMINAKATTE_110                      | 14:15                 | 14:51     | 0:36     | LINE CLEAR AVAILED |
| 663   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)          | NAVALAGI_110                          | 10:02                 | 12:02     | 2:00     | LINE CLEAR AVAILED |
| 664   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)          | NAVALAGI_110                          | 12:11                 | 13:00     | 0:49     | LINE CLEAR AVAILED |
| 665   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20 MVA)          | NIPPANI_110                           | 15:10                 | 15:16     | 0:06     | TRIPPED ON FAULT   |
| 666   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MUNDARGI-VIJAY SUGARS          | MUNDARGI_110                          | 06:22                 | 10:10     | 3:48     | LINE CLEAR AVAILED |
| 667   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(20 MVA)           | MUNDARGI_110                          | 15:57                 | 16:14     | 0:17     | LINE CLEAR AVAILED |
| 668   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)           | MALGHAN(B)_110                        | 03:01                 | 03:05     | 0:04     | TRIPPED ON FAULT   |
| 669   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-MAMADAPUR(MATTIHAL) | MALGHAN(B)_110                        | 10:31                 | 10:46     | 0:15     | TRIPPED ON FAULT   |
| 670   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI1         | MAMADAPUR(B)_110                      | 10:41                 | 10:45     | 0:04     | LINE CLEAR AVAILED |
| 671   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2         | MAMADAPUR(B)_110                      | 10:41                 | 10:59     | 0:18     | LINE CLEAR AVAILED |
| 672   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-SHIRABUR          | MAMADAPUR(B)_110                      | 10:40                 | 10:46     | 0:06     | LINE CLEAR AVAILED |
| 673   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)           | MAMADAPUR(B)_110                      | 22:59                 | 23:10     | 0:11     | TRIPPED ON FAULT   |
| 674   | 15-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-NAGAJHARI-2              | HUBLI_220                             | 10:31                 | 13:37     | 3:06     | LINE CLEAR AVAILED |
| 675   | 15-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI-PONDA1(XELDOM )       | AMBEWADI_220                          | 15:13                 | 16:10     | 0:57     | TRIPPED ON FAULT   |
| 676   | 15-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1            | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 677   | 15-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2      | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 678   | 15-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2             | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 679   | 15-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS          | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 680   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)            | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 681   | 15-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   |                       |          | LINE CLEAR AVAIED |
| 682   | 15-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |          | LINE CLEAR AVAIED |
| 683   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |                       |          | TRIPPED ON FAULT  |
| 684   | 15-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1                     | AMBEWADI_220                             | 20:30<br>(14.09.2024) | 13:39<br>(15.09.2024) | 17:09    | LINE CLEAR AVAIED |
| 685   | 15-Sep-24 | BAGALKOT | 110     | LINE        | HAVERI220-SAVANUR                     | HAVERI_220                               | 14:30                 | 15:30                 | 01:00    | TRIPPED ON FAULT  |
| 686   | 15-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-ALMEL-02(103)                | AHERI_220                                | 21:52                 | 22:02                 | 00:10    | TRIPPED ON FAULT  |
| 687   | 15-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | NIPPANI_110                              | 15:10                 | 15:15                 | 00:05    | TRIPPED ON FAULT  |
| 688   | 16-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 689   | 16-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 690   | 16-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 691   | 16-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 692   | 16-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 693   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 694   | 16-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |                       |          | LINE CLEAR AVAIED |
| 695   | 16-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                                | 8:25<br>(14.09.2024)  |                       |          | TRIPPED ON FAULT  |
| 696   | 16-Sep-24 | BAGALKOT | 110     | LINE        | ANKOLA-KUMTA2                         | ANKOLA_110                               | 00:07                 | 13:54                 | 13:47    | TRIPPED ON FAULT  |
| 697   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | THORVI_110                               | 18:02                 | 18:09                 | 0:07     | TRIPPED ON FAULT  |
| 698   | 16-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-BORGAON                      | SADALAGA_110                             | 04:37                 | 05:13                 | 0:36     | TRIPPED ON FAULT  |
| 699   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-<br>MAMADAPUR(MATTIHAL)    | MALGHAN(B)_110                           | 11:49                 | 12:05                 | 0:16     | TRIPPED ON FAULT  |
| 700   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                  | MALGHAN(B)_110                           | 09:29                 | 09:32                 | 0:03     | TRIPPED ON FAULT  |
| 701   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                  | MALGHAN(B)_110                           | 14:28                 | 14:32                 | 0:04     | TRIPPED ON FAULT  |
| 702   | 16-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV3                        | MAHALINGAPUR_220                         | 11:43                 | 12:03                 | 0:20     | TRIPPED ON FAULT  |
| 703   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- RABKAVI                 | MAHALINGAPUR_220                         | 11:49                 | 12:07                 | 0:18     | LINE CLEAR AVAIED |
| 704   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- HIDIKAL                 | MAHALINGAPUR_220                         | 11:53                 | 12:07                 | 0:14     | LINE CLEAR AVAIED |
| 705   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- BANAHATTI               | MAHALINGAPUR_220                         | 11:53                 | 11:57                 | 0:04     | LINE CLEAR AVAIED |
| 706   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI1                | MAMADAPUR(B)_110                         | 11:56                 | 11:58                 | 0:02     | LINE CLEAR AVAIED |
| 707   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-SHIRABUR                 | MAMADAPUR(B)_110                         | 11:57                 | 11:59                 | 0:02     | LINE CLEAR AVAIED |
| 708   | 16-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- SOUDATTI1                     | BIDNAL_220                               | 20:46                 | 23:09                 | 2:23     | TRIPPED ON FAULT  |
| 709   | 16-Sep-24 | BAGALKOT | 110     | LINE        | ANKOLA-KUMTA2                         | ANKOLA_110                               | 00:07                 | 13:54                 | 13:47    | TRIPPED ON FAULT  |
| 710   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | THORVI_110                               | 18:02                 | 18:09                 | 0:07     | TRIPPED ON FAULT  |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                               | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|------------------------------------|---------------------------------------|-----------------------|-----------|----------|--------------------|
| 711   | 16-Sep-24 | BAGALKOT | 110     | LINE        | SADALAGA-BORGAON                   | SADALAGA_110                          | 04:37                 | 05:13     | 0:36     | TRIPPED ON FAULT   |
| 712   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-<br>MAMADAPUR(MATTIHAL) | MALGHAN(B)_110                        | 11:49                 | 12:05     | 0:16     | TRIPPED ON FAULT   |
| 713   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)               | MALGHAN(B)_110                        | 09:29                 | 09:32     | 0:03     | TRIPPED ON FAULT   |
| 714   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)               | MALGHAN(B)_110                        | 14:28                 | 14:32     | 0:04     | TRIPPED ON FAULT   |
| 715   | 16-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV3                     | MAHALINGAPUR_220                      | 11:43                 | 12:03     | 0:20     | TRIPPED ON FAULT   |
| 716   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- RABKAVI              | MAHALINGAPUR_220                      | 11:49                 | 12:07     | 0:18     | LINE CLEAR AVAILED |
| 717   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- HIDIKAL              | MAHALINGAPUR_220                      | 11:53                 | 12:07     | 0:14     | LINE CLEAR AVAILED |
| 718   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- BANAHAATTI           | MAHALINGAPUR_220                      | 11:53                 | 11:57     | 0:04     | LINE CLEAR AVAILED |
| 719   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI1             | MAMADAPUR(B)_110                      | 11:56                 | 11:58     | 0:02     | LINE CLEAR AVAILED |
| 720   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2             | MAMADAPUR(B)_110<br>(16.09.2024)      | 11:57                 |           |          | LINE CLEAR AVAILED |
| 721   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-SHIRABUR              | MAMADAPUR(B)_110                      | 11:57                 | 11:59     | 0:02     | LINE CLEAR AVAILED |
| 722   | 16-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- SOUDATTI1                  | BIDNAL_220                            | 20:46                 | 23:09     | 2:23     | TRIPPED ON FAULT   |
| 723   | 16-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-SIRSI1                       | HUBLI_220                             | 12:45                 | 18:50     | 6:05     | TRIPPED ON FAULT   |
| 724   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MUGALAKHOD220-<br>LN10(KULAGOD)    | MUGALAKHOD_220                        | 05:36                 | 05:47     | 0:11     | TRIPPED ON FAULT   |
| 725   | 16-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV3,LV3                  | KUDUCHI_220                           | 15:35                 | 18:33     | 2:58     | TRIPPED ON FAULT   |
| 726   | 16-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 727   | 16-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2          | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 728   | 16-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                 | STATION NOT AFFECTED<br>SOUDATTI_220  | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 729   | 16-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS              | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 730   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                | STATION NOT AFFECTED<br>TERDAL_110    | 12:50<br>(21.08.2024) |           |          | TRIPPED ON FAULT   |
| 731   | 16-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                   | STATION NOT AFFECTED<br>HIDKALDAM_110 | 8:13<br>(1.09.2024)   |           |          | LINE CLEAR AVAILED |
| 732   | 16-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                       | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAILED |
| 733   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)               | AMBEWADI_220                          | 9:02<br>(06.09.2024)  |           |          | TRIPPED ON FAULT   |
| 734   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)              | TERDAL_110                            | 14:35                 | 20:25     | 5:50     | TRIPPED ON FAULT   |
| 735   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)              | TERDAL_110                            | 20:35                 | 21:30     | 0:55     | TRIPPED ON FAULT   |
| 736   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)              | TERDAL_110                            | 14:35                 | 20:25     | 5:50     | TRIPPED ON FAULT   |
| 737   | 16-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1 (20 MVA)              | TERDAL_110                            | 20:35                 | 21:30     | 0:55     | TRIPPED ON FAULT   |
| 738   | 16-Sep-24 | BAGALKOT | 110     | LINE        | VAJJARAMATTI220-MELLIGERI          | VAJJARAMATTI_220                      | 10:10                 | 10:20     | 0:10     | LINE CLEAR AVAILED |
| 739   | 16-Sep-24 | BAGALKOT | 110     | LINE        | KUDUCHI-HARUGERI                   | KUDUCHI_220                           | 03:30                 | 03:50     | 0:20     | TRIPPED ON FAULT   |
| 740   | 16-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI220-BIDNAL 1              | SOUNDATTI_220                         | 20:47                 | 23:08     | 2:21     | TRIPPED ON FAULT   |
| 741   | 16-Sep-24 | BAGALKOT | 110     | LINE        | SOUNDATTI220-BENAKATTI             | SOUNDATTI_220                         | 10:24                 | 10:37     | 0:13     | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 742   | 16-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI-NARENDRA 1                   | AMBEWADI_220                             | 14:14                 | 14:48     | 0:34     | TRIPPED ON FAULT  |
| 743   | 16-Sep-24 | BAGALKOT | 220     | LINE        | NARENDRA-AMBEWADI1                    | NARENDRA_220                             | 14:14                 | 14:48     | 0:34     | TRIPPED ON FAULT  |
| 744   | 17-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 745   | 17-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 746   | 17-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 747   | 17-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 748   | 17-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |           |          | LINE CLEAR AVAIED |
| 749   | 17-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 750   | 17-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |           |          | LINE CLEAR AVAIED |
| 751   | 17-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | DHONI_400                                | 8:25<br>(14.09.2024)  |           |          | TRIPPED ON FAULT  |
| 752   | 17-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2                | MAMADAPUR(B)_110                         | 11:57<br>(16.09.2024) |           |          | LINE CLEAR AVAIED |
| 753   | 17-Sep-24 | BAGALKOT | 110     | LINE        | ANKALAGI- BELGAUM2<br>(HUDLI)         | ANKALAGI_110                             | 09:25                 | 09:49     | 0:24     | LINE CLEAR AVAIED |
| 754   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)                   | ATHANI_110                               | 06:35                 | 06:43     | 0:08     | TRIPPED ON FAULT  |
| 755   | 17-Sep-24 | BAGALKOT | 110     | LINE        | ATHARGA- BAGEWADI(RAILWAY)            | ATHARGA_110                              | 10:07                 | 10:32     | 0:25     | TRIPPED ON FAULT  |
| 756   | 17-Sep-24 | BAGALKOT | 110     | LINE        | HONNAVAR-MURDESHWAR                   | HONNAVAR_110                             | 12:56                 | 13:17     | 0:21     | LINE CLEAR AVAIED |
| 757   | 17-Sep-24 | BAGALKOT | 110     | LINE        | HUNGUND-JINDAL                        | HUNGUND_110                              | 06:02                 | 06:28     | 0:26     | TRIPPED ON FAULT  |
| 758   | 17-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)                 | ISLAMPUR_110                             | 9:47<br>(17.09.2024)  |           |          | LINE CLEAR AVAIED |
| 759   | 17-Sep-24 | BAGALKOT | 110     | LINE        | JAMBAGI-MUDHOL(HALKI)                 | JAMBAGI_110                              | 10:15                 | 14:04     | 3:49     | LINE CLEAR AVAIED |
| 760   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | KULAGERI CROSS_110                       | 14:07                 | 16:39     | 2:32     | LINE CLEAR AVAIED |
| 761   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | KULIGOD_110                              | 16:56                 | 17:29     | 0:33     | LINE CLEAR AVAIED |
| 762   | 17-Sep-24 | BAGALKOT | 110     | LINE        | LAXMESHWAR-GADAG1                     | LAXMESHWAR_110                           | 14:09                 | 17:07     | 2:58     | LINE CLEAR AVAIED |
| 763   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | MALGHAN(B)_110                           | 08:21                 | 08:24     | 0:03     | TRIPPED ON FAULT  |
| 764   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | MALGHAN(B)_110                           | 13:52                 | 13:59     | 0:07     | TRIPPED ON FAULT  |
| 765   | 17-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-BAGEWADI                      | MALGHAN(B)_110                           | 19:12                 | 19:25     | 0:13     | TRIPPED ON FAULT  |
| 766   | 17-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-BAGEWADI                      | MALGHAN(B)_110                           | 19:12                 | 19:29     | 0:17     | TRIPPED ON FAULT  |
| 767   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                  | YELLAMMANAWADI_110                       | 14:43                 | 15:32     | 0:49     | LINE CLEAR AVAIED |
| 768   | 17-Sep-24 | BAGALKOT | 110     | LINE        | SUVARNA SOUDA-<br>HIREBAGEWADI        | SUVARNA SOUDA_110                        | 16:09                 | 16:21     | 0:12     | LINE CLEAR AVAIED |
| 769   | 17-Sep-24 | BAGALKOT | 110     | LINE        | SULTANPUR-MUGALKHOD (F2)              | SULTANPUR_110                            | 15:48                 | 16:37     | 0:49     | LINE CLEAR AVAIED |
| 770   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                  | SULTANPUR_110                            | 15:49                 | 16:37     | 0:48     | LINE CLEAR AVAIED |
| 771   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | SULTANPUR_110                            | 15:49                 | 16:37     | 0:48     | LINE CLEAR AVAIED |
| 772   | 17-Sep-24 | BAGALKOT | 110     | LINE        | RONIHAL-MAMADAPUR(F2)                 | RONIHAL_110                              | 19:12                 | 19:22     | 0:10     | TRIPPED ON FAULT  |
| 773   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                  | MALGHAN(S)_110                           | 17:00                 | 17:45     | 0:45     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|--------------------|
| 774   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | MALGHAN(S)_110                           | 17:28                 | 17:48                 | 0:20      | LINE CLEAR AVAILED |
| 775   | 17-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-NAGJHARI1                       | HUBLI_220                                | 10:33                 | 14:52                 | 4:19      | LINE CLEAR AVAILED |
| 776   | 17-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1&LV1                    | MKHUBLI_220                              | 16:28                 | 19:08                 | 2:40      | TRIPPED ON FAULT   |
| 777   | 17-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                        | MKHUBLI_220                              | 16:28                 | 18:47                 | 2:19      | TRIPPED ON FAULT   |
| 778   | 17-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220- SHIRAHATTI                  | GADAG_220                                | 11:37                 | 13:22                 | 1:45      | LINE CLEAR AVAILED |
| 779   | 17-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220- LAXMESHWAR2                 | GADAG_220                                | 14:07                 | 17:07                 | 3:00      | LINE CLEAR AVAILED |
| 780   | 17-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAILED |
| 781   | 17-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAILED |
| 782   | 17-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAILED |
| 783   | 17-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 784   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | STATION NOT AFFECTED<br>TERDAL_110       | 12:50<br>(21.08.2024) | 18:10<br>(17.09.2024) | 653:20:00 | TRIPPED ON FAULT   |
| 785   | 17-Sep-24 | BAGALKOT | 110     | LINE        | HIDKALDAM-HUDALI                      | STATION NOT AFFECTED<br>HIDKALDAM_110    | 8:13<br>(1.09.2024)   | 9:42<br>(17.09.2024)  | 385:29:00 | LINE CLEAR AVAILED |
| 786   | 17-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |           | LINE CLEAR AVAILED |
| 787   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  |                       |           | TRIPPED ON FAULT   |
| 788   | 17-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | KALAGATAGI_110                           | 08:15                 | 08:20                 | 0:05      | TRIPPED ON FAULT   |
| 789   | 17-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-MELLIGERI               | VAJRAMATTI_220                           | 07:05                 | 07:08                 | 0:03      | LINE CLEAR AVAILED |
| 790   | 18-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAILED |
| 791   | 18-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAILED |
| 792   | 18-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 793   | 18-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAILED |
| 794   | 18-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 795   | 18-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAILED |
| 796   | 18-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |                       |           | LINE CLEAR AVAILED |
| 797   | 18-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  |                       |           | TRIPPED ON FAULT   |
| 798   | 18-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2                | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                       |           | LINE CLEAR AVAILED |
| 799   | 18-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)                 | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                       |           | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|---------------------------------------|-----------------------|-----------|----------|-------------------|
| 800   | 18-Sep-24 | BAGALKOT | 110     | LINE        | BANAHATTI-JAMAKHANDI(NAVALAGI)        | BANAHATTI_110                         | 03:53                 | 04:01     | 0:08     | TRIPPED ON FAULT  |
| 801   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | DADDI_110                             | 11:17                 | 13:45     | 2:28     | LINE CLEAR AVAIED |
| 802   | 18-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL-ASE(AKHILAGYA SOLAR            | DAMBAL_110                            | 19:35                 | 19:51     | 0:16     | TRIPPED ON FAULT  |
| 803   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | HIDIKAL DAM_110                       | 11:51                 | 12:05     | 0:14     | LINE CLEAR AVAIED |
| 804   | 18-Sep-24 | BAGALKOT | 110     | LINE        | KUMTA-SIRSI1                          | KUMTA_110                             | 14:24                 | 15:32     | 1:08     | LINE CLEAR AVAIED |
| 805   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | MUNDAGOD_110                          | 11:17                 | 11:35     | 0:18     | LINE CLEAR AVAIED |
| 806   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | ZALKI_110                             | 14:05                 | 16:15     | 2:10     | LINE CLEAR AVAIED |
| 807   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (20MVA,HV1)             | YARAGATTI_110                         | 20:58                 | 21:58     | 1:00     | TRIPPED ON FAULT  |
| 808   | 18-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR -MAHALINGAPURA (RANNA BALAGALI) | UTTUR_110                             | 10:38                 | 16:40     | 6:02     | LINE CLEAR AVAIED |
| 809   | 18-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR -YADAWAD                        | UTTUR_110                             | 10:40                 | 16:50     | 6:10     | LINE CLEAR AVAIED |
| 810   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | UTTUR_110                             | 10:20                 | 17:06     | 6:46     | LINE CLEAR AVAIED |
| 811   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | UTTUR_110                             | 10:21                 | 17:06     | 6:45     | LINE CLEAR AVAIED |
| 812   | 18-Sep-24 | BAGALKOT | 110     | LINE        | UGAR KHUD-UGAR SUGAR                  | UGAR KHUD_110                         | 08:57                 | 09:00     | 0:03     | LINE CLEAR AVAIED |
| 813   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20MVA)                  | UDYAMBAG_110                          | 11:06                 | 17:17     | 6:11     | TRIPPED ON FAULT  |
| 814   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3 (20MVA,HV2)              | TIKOTA_110                            | 11:25                 | 11:31     | 0:06     | TRIPPED ON FAULT  |
| 815   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2 (20MVA)                  | TERDAL_110                            | 11:09                 | 11:20     | 0:11     | TRIPPED ON FAULT  |
| 816   | 18-Sep-24 | BAGALKOT | 220     | LINE        | AMBEWADI-PONDA1                       | AMBEWADI_220                          | 12:40                 | 13:45     | 1:05     | TRIPPED ON FAULT  |
| 817   | 18-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2(HV1)                   | GADAG_220                             | 10:35                 | 14:12     | 3:37     | LINE CLEAR AVAIED |
| 818   | 18-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1(HV2)                   | GADAG_220                             | 15:02                 | 19:33     | 4:31     | LINE CLEAR AVAIED |
| 819   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV1                        | GADAG_220                             | 10:35                 | 14:13     | 3:38     | LINE CLEAR AVAIED |
| 820   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                        | GADAG_220                             | 15:02                 | 19:34     | 4:32     | LINE CLEAR AVAIED |
| 821   | 18-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI-AEQUS1(MUGALKHOD2)           | CHIKKODI_220                          | 14:14                 | 15:26     | 1:12     | LINE CLEAR AVAIED |
| 822   | 18-Sep-24 | BAGALKOT | 220     | LINE        | KANAGALA- CHIKKODI2                   | KANAGALA_220                          | 07:13                 | 10:57     | 3:44     | TRIPPED ON FAULT  |
| 823   | 18-Sep-24 | BAGALKOT | 220     | LINE        | MAHALINGAPUR- NARENDRA1               | MAHALINGAPUR_220                      | 15:00                 | 19:04     | 4:04     | LINE CLEAR AVAIED |
| 824   | 18-Sep-24 | BAGALKOT | 220     | LINE        | MUGALKHOD- CHIKKODI2                  | MUGALKHOD_220                         | 14:14                 | 15:20     | 1:06     | LINE CLEAR AVAIED |
| 825   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | AMBEWADI_220                          | 19:39<br>(18.09.2024) |           |          | LINE CLEAR AVAIED |
| 826   | 18-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- BEDI                      | MKHUBLI_220                           | 18:22                 | 18:52     | 00:30    | TRIPPED ON FAULT  |
| 827   | 18-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUTTUR                         | DHONI_400                             | 09:30                 | 21:02     | 11:32    | LINE CLEAR AVAIED |
| 828   | 18-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220- KATARKI                | VAJRAMATTI_220                        | 08:03                 | 08:08     | 00:05    | LINE CLEAR AVAIED |
| 829   | 18-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                   | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |
| 830   | 18-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2             | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED |
| 831   | 18-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                    | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED |
| 832   | 18-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                 | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED |
| 833   | 18-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                          | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|--------------------|
| 834   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                  | AMBEWADI_220                             | 9:02<br>(06.09.2024)  | 15:20<br>(18.09.2024) | 294:18:00 | TRIPPED ON FAULT   |
| 835   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | HIDIKAL_110                              | 12:35<br>(18.09.2024) |                       |           | LINE CLEAR AVAILED |
| 836   | 18-Sep-24 | BAGALKOT | 110     | LINE        | KUMTA-SIRSI2                          | KUMTA_110                                | 14:20                 | 15:32                 | 1:12      | LINE CLEAR AVAILED |
| 837   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | KALADAGI_110                             | 17:35                 | 18:05                 | 0:30      | LINE CLEAR AVAILED |
| 838   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | UTTUR_110                                | 10:20                 | 17:00                 | 6:40      | LINE CLEAR AVAILED |
| 839   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | KIADB BIJAPUR                            | 13:05                 | 19:10                 | 6:05      | LINE CLEAR AVAILED |
| 840   | 18-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV,HV1,LV1                     | MK HUBLI_220                             | 16:05<br>(17.09.2024) | 6:18<br>(18.09.2024)  | 14:13     | TRIPPED ON FAULT   |
| 841   | 19-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAILED |
| 842   | 19-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAILED |
| 843   | 19-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 844   | 19-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAILED |
| 845   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                          | STATION NOT AFFECTED<br>KONNUR_110       | 8:19<br>(29.08.2024)  | 10:05<br>(19.09.2024) | 505:46:00 | LINE CLEAR AVAILED |
| 846   | 19-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAILED |
| 847   | 19-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    |                       |           | LINE CLEAR AVAILED |
| 848   | 19-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  |                       |           | TRIPPED ON FAULT   |
| 849   | 19-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2                | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                       |           | LINE CLEAR AVAILED |
| 850   | 19-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)                 | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                       |           | LINE CLEAR AVAILED |
| 851   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | AMBEWADI_220                             | 19:39<br>(18.09.2024) | 18:34<br>(19.09.2024) | 22:55     | LINE CLEAR AVAILED |
| 852   | 19-Sep-24 | BAGALKOT | 110     | LINE        | ANKALI-HERMS                          | ANKALI_110                               | 07:25                 | 19:15                 | 11:50     | LINE CLEAR AVAILED |
| 853   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA-HV1)               | HIDAKAL DAM_110                          | 16:10                 | 16:17                 | 0:07      | TRIPPED ON FAULT   |
| 854   | 19-Sep-24 | BAGALKOT | 110     | LINE        | AINAPUR-KUDUCHI220                    | AINAPUR_110                              | 10:04                 | 17:02                 | 6:58      | LINE CLEAR AVAILED |
| 855   | 19-Sep-24 | BAGALKOT | 110     | LINE        | AINAPUR-IDLE(AINAPUR LIS)             | AINAPUR_110                              | 10:04                 | 17:33                 | 7:29      | LINE CLEAR AVAILED |
| 856   | 19-Sep-24 | BAGALKOT | 110     | LINE        | ITNAL-RAIBAG(HIDAKAL)                 | ITNAL_110                                | 10:00                 | 19:15                 | 9:15      | LINE CLEAR AVAILED |
| 857   | 19-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-MF SOLAR                      | HIREHAL_110                              | 10:00                 | 17:59                 | 7:59      | LINE CLEAR AVAILED |
| 858   | 19-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-IDLE(BADAMI)                  | HIREHAL_110                              | 10:00                 | 17:59                 | 7:59      | LINE CLEAR AVAILED |
| 859   | 19-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-RON                           | HIREHAL_110                              | 10:20                 | 18:10                 | 7:50      | LINE CLEAR AVAILED |
| 860   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | HIDIKAL_110                              | 08:30                 | 18:00                 | 9:30      | LINE CLEAR AVAILED |
| 861   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | HIDIKAL_110                              | 10:39                 | 18:04                 | 7:25      | LINE CLEAR AVAILED |
| 862   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA)                   | HIDIKAL_110                              | 10:40                 | 18:04                 | 7:24      | LINE CLEAR AVAILED |
| 863   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(20MVA)                   | BYADAGI_110                              | 11:09                 | 11:44                 | 0:35      | LINE CLEAR AVAILED |
| 864   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | THORVI_110                               | 16:08                 | 16:11                 | 0:03      | TRIPPED ON FAULT   |
| 865   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | TERDAL_110                               | 10:47                 | 14:36                 | 3:49      | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                            | Station_Name                          | Open_At               | Closed_At            | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------|---------------------------------------|-----------------------|----------------------|----------|-------------------|
| 866   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(20MVA)             | SOUDATTI_110                          | 15:08                 | 16:07                | 0:59     | LINE CLEAR AVAIED |
| 867   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA,HV1)         | SALAHALLI_110                         | 16:11                 | 17:12                | 1:01     | LINE CLEAR AVAIED |
| 868   | 19-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                     | RON_110                               | 10:21                 | 18:10                | 7:49     | LINE CLEAR AVAIED |
| 869   | 19-Sep-24 | BAGALKOT | 110     | LINE        | RAIBAG-CHIKOKODI1               | RAIBAG_110                            | 09:21                 | 11:55                | 2:34     | LINE CLEAR AVAIED |
| 870   | 19-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGUND-BIDNAL               | NAVALAGUND_110                        | 14:45                 | 14:49                | 0:04     | TRIPPED ON FAULT  |
| 871   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | NAVALAGUND_110                        | 14:45                 | 17:44                | 2:59     | TRIPPED ON FAULT  |
| 872   | 19-Sep-24 | BAGALKOT | 110     | LINE        | NARGUND-BPCL                    | NARGUND_110                           | 15:18                 | 16:03                | 0:45     | TRIPPED ON FAULT  |
| 873   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KUD DHARWAD -<br>LAKHAMANAHALLI | KUD DHARWAD_110                       | 09:42                 | 19:50                | 10:08    | LINE CLEAR AVAIED |
| 874   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-BAGALKOT                  | KERUR_110                             | 10:35                 | 12:56                | 2:21     | TRIPPED ON FAULT  |
| 875   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-KONNUR                    | KERUR_110                             | 12:57                 | 14:05                | 1:08     | LINE CLEAR AVAIED |
| 876   | 19-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI- SIRSI1                   | HUBLI_220                             | 10:58                 | 17:31                | 6:33     | LINE CLEAR AVAIED |
| 877   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-KUDUCHI(AINAPUR)     | KUDACHI_220                           | 10:00                 | 17:00                | 7:00     | LINE CLEAR AVAIED |
| 878   | 19-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI-KAVATAGI LIS         | VAJRAMATTI_220                        | 11:43                 | 14:13                | 2:30     | LINE CLEAR AVAIED |
| 879   | 19-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1,LV1              | VAJRAMATTI_220                        | 18:11                 | 19:08                | 0:57     | LINE CLEAR AVAIED |
| 880   | 19-Sep-24 | BAGALKOT | 110     | LINE        | NARENDRA-BIDNAL                 | NARENDRA_220                          | 05:40                 | 08:55                | 3:15     | TRIPPED ON FAULT  |
| 881   | 19-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-NARENDRA                 | BIDNAL_220                            | 05:40                 | 08:55                | 3:15     | TRIPPED ON FAULT  |
| 882   | 19-Sep-24 | BAGALKOT | 110     | LINE        | NARENDRA-KUD1(KUD<br>DHARWAD)   | NARENDRA_220                          | 10:15                 | 17:09                | 6:54     | LINE CLEAR AVAIED |
| 883   | 19-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1             | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                      |          | LINE CLEAR AVAIED |
| 884   | 19-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2       | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                      |          | LINE CLEAR AVAIED |
| 885   | 19-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2              | STATION NOT AFFECTED<br>SOUDATTI_220  | 10:49<br>(18.07.2024) |                      |          | LINE CLEAR AVAIED |
| 886   | 19-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS           | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |                      |          | LINE CLEAR AVAIED |
| 887   | 19-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                    | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |                      |          | LINE CLEAR AVAIED |
| 888   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)             | HIDIKAL_110                           | 12:35<br>(18.09.2024) | 19:0<br>(19.09.2024) | 30:25:00 | LINE CLEAR AVAIED |
| 889   | 19-Sep-24 | BAGALKOT | 110     | LINE        | AINAPUR-ATHANI SUGARS           | AINAPUR_110                           | 10:04                 | 17:25                | 7:21     | LINE CLEAR AVAIED |
| 890   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)             | AINAPUR_110                           | 10:05                 | 17:00                | 6:55     | LINE CLEAR AVAIED |
| 891   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)             | AINAPUR_110                           | 10:05                 | 17:00                | 6:55     | LINE CLEAR AVAIED |
| 892   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | NAVALAGUND_110                        | 14:45                 | 14:49                | 0:04     | TRIPPED ON FAULT  |
| 893   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KUD DHARWAD-NARENDRA            | KUD DHARWAD_110                       | 10:05                 | 17:10                | 7:05     | LINE CLEAR AVAIED |
| 894   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | KUD DHARWAD_110                       | 10:00                 | 18:00                | 8:00     | LINE CLEAR AVAIED |
| 895   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | KUD DHARWAD_110                       | 10:00                 | 18:40                | 8:40     | LINE CLEAR AVAIED |
| 896   | 19-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | HALIYAL_110                           | 08:10                 | 08:30                | 0:20     | LINE CLEAR AVAIED |
| 897   | 19-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F7-RAMDURG          | BAGALKOT_220                          | 19:21                 | 20:13                | 0:52     | TRIPPED ON FAULT  |
| 898   | 19-Sep-24 | BAGALKOT | 110     | LINE        | CHIKKODI220-RAIBAG1             | CHIKKODI_220                          | 09:20                 | 11:55                | 2:35     | LINE CLEAR AVAIED |
| 899   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-SHIRAGUPPI           | KUDACHI_220                           | 16:45                 | 17:45                | 1:00     | LINE CLEAR AVAIED |
| 900   | 19-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-HARUGERI             | KUDACHI_220                           | 18:45                 | 18:55                | 0:10     | TRIPPED ON FAULT  |
| 901   | 19-Sep-24 | BAGALKOT | 110     | LINE        | SOUDATTI220-BENAKATTI           | SOUDATTI_220                          | 15:36                 | 16:00                | 0:24     | TRIPPED ON FAULT  |
| 902   | 19-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                     | RON_110                               | 21:05                 | 22:20                | 1:15     | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                  | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS           |
|-------|-----------|----------|---------|-------------|---------------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|-------------------|
| 903   | 20-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR              | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAIED |
| 904   | 20-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                   | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAIED |
| 905   | 20-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 906   | 20-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)              | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAIED |
| 907   | 20-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                        | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAIED |
| 908   | 20-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-KUSTAGI<br>(HANUMASAGARA) | STATION NOT AFFECTED<br>GAJENDRAGAD_110  | 11:05 (06.09.2024)    | 10:13<br>(20.09.2024) | 335:08:00 | LINE CLEAR AVAIED |
| 909   | 20-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                    | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  |                       |           | TRIPPED ON FAULT  |
| 910   | 20-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2                | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                       |           | LINE CLEAR AVAIED |
| 911   | 20-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)                 | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                       |           | LINE CLEAR AVAIED |
| 912   | 20-Sep-24 | BAGALKOT | 110     | LINE        | ALABAL-SPRR(SAI PRIYA)                | ALABAL_110                               | 08:03                 | 14:00                 | 5:57      | LINE CLEAR AVAIED |
| 913   | 20-Sep-24 | BAGALKOT | 110     | LINE        | ALABAL-RAY SOLAR                      | ALABAL_110                               | 08:03                 | 09:30                 | 1:27      | LINE CLEAR AVAIED |
| 914   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                   | ALABAL_110                               | 08:08                 | 15:40                 | 7:32      | LINE CLEAR AVAIED |
| 915   | 20-Sep-24 | BAGALKOT | 110     | LINE        | ANKALI-HERMES                         | ANKALI_110                               | 08:25                 | 17:52                 | 9:27      | LINE CLEAR AVAIED |
| 916   | 20-Sep-24 | BAGALKOT | 110     | LINE        | ANNIGERI-GADAG                        | ANNIGERI_110                             | 09:35                 | 22:35                 | 13:00     | LINE CLEAR AVAIED |
| 917   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA)                   | ATHANI_110                               | 06:25                 | 06:33                 | 0:08      | TRIPPED ON FAULT  |
| 918   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | BILAGI_110                               | 09:08                 | 16:52                 | 7:44      | LINE CLEAR AVAIED |
| 919   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                   | BILAGI_110                               | 09:08                 | 16:52                 | 7:44      | LINE CLEAR AVAIED |
| 920   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | BILAGI_110                               | 09:09                 | 16:49                 | 7:40      | LINE CLEAR AVAIED |
| 921   | 20-Sep-24 | BAGALKOT | 110     | LINE        | BILAGI-KATARAKI                       | BILAGI_110                               | 09:09                 | 16:48                 | 7:39      | LINE CLEAR AVAIED |
| 922   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | GADAG_110                                | 10:07                 | 15:37                 | 5:30      | LINE CLEAR AVAIED |
| 923   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                   | GADAG_110                                | 10:06                 | 18:01                 | 7:55      | LINE CLEAR AVAIED |
| 924   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV4(20MVA)                   | GADAG_110                                | 10:06                 | 18:00                 | 7:54      | LINE CLEAR AVAIED |
| 925   | 20-Sep-24 | BAGALKOT | 110     | LINE        | GADAG-ANNIGERI                        | GADAG_110                                | 10:23                 | 22:20                 | 11:57     | LINE CLEAR AVAIED |
| 926   | 20-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-RON1                      | GAJENDRAGAD_110                          | 10:13                 | 19:08                 | 8:55      | LINE CLEAR AVAIED |
| 927   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | HEBBALLI_110                             | 12:36                 | 15:22                 | 2:46      | LINE CLEAR AVAIED |
| 928   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA)                   | HIDIKAL DAM_110                          | 16:13                 | 16:17                 | 0:04      | TRIPPED ON FAULT  |
| 929   | 20-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-RON                           | HIREHAL_110                              | 10:21<br>(20.09.2024) |                       |           | LINE CLEAR AVAIED |
| 930   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-KONNUR                          | KERUR_110                                | 10:14                 | 10:22                 | 00:08     | LINE CLEAR AVAIED |
| 931   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA,HV2)               | ZALKI_110                                | 10:49                 | 11:14                 | 00:25     | TRIPPED ON FAULT  |
| 932   | 20-Sep-24 | BAGALKOT | 110     | LINE        | YALLAMANAWADI-ALBHAL                  | YALLAMANAWADI_110                        | 08:08                 | 09:28                 | 01:20     | LINE CLEAR AVAIED |
| 933   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                   | TOLAMATTI_110                            | 09:15                 | 16:51                 | 07:36     | LINE CLEAR AVAIED |
| 934   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA)                   | TOLAMATTI_110                            | 09:17                 | 17:00                 | 07:43     | LINE CLEAR AVAIED |
| 935   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-NAREGAL                           | RON_110                                  | 10:12                 | 19:10                 | 08:58     | LINE CLEAR AVAIED |
| 936   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAJENDRAGADA1                     | RON_110                                  | 10:14                 | 19:07                 | 08:53     | LINE CLEAR AVAIED |
| 937   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAJENDRAGADA2                     | RON_110                                  | 10:15                 | 19:07                 | 08:52     | LINE CLEAR AVAIED |
| 938   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAMESA(GMSH)                      | RON_110                                  | 10:00                 | 19:02                 | 09:02     | LINE CLEAR AVAIED |
| 939   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA)                   | RON_110                                  | 10:01                 | 19:06                 | 09:05     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                          | Open_At               | Closed_At            | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-----------------------------------|---------------------------------------|-----------------------|----------------------|----------|-------------------|
| 940   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                       | RON_110                               | 10:18                 | 19:27                | 09:09    | LINE CLEAR AVAIED |
| 941   | 20-Sep-24 | BAGALKOT | 110     | LINE        | NAREGAL-RON                       | NAREGAL_110                           | 10:11                 | 19:10                | 08:59    | LINE CLEAR AVAIED |
| 942   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | MALGHAN (S)_110                       | 10:30                 | 10:36                | 00:06    | TRIPPED ON FAULT  |
| 943   | 20-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-BASAVA SUGARS             | MALGHAN_110                           | 10:10                 | 18:40                | 08:30    | LINE CLEAR AVAIED |
| 944   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)               | MALGHAN_110                           | 13:19                 | 13:25                | 00:06    | TRIPPED ON FAULT  |
| 945   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KUDALASANGAM-HUNAGUNDA            | KUDALASANGAM_110                      | 18:06                 | 18:11                | 00:05    | TRIPPED ON FAULT  |
| 946   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KUDALASANGAM-HUNAGUNDA            | KUDALASANGAM_110                      | 18:33                 | 18:38                | 00:05    | TRIPPED ON FAULT  |
| 947   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-KERUR                      | KONNUR_110                            | 9:59<br>(20.09.2024)  | 2:26<br>(21.09.2024) | 16:27    | LINE CLEAR AVAIED |
| 948   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-NAVALAGUND                 | KONNUR_110                            | 10:00                 | 17:10                | 07:10    | LINE CLEAR AVAIED |
| 949   | 20-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                | KIRUVATTI_110                         | 9:15<br>(20.09.2024)  |                      |          | LINE CLEAR AVAIED |
| 950   | 20-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220- BETAGERI(RON1)          | GADAG_220                             | 10:19                 | 19:00                | 08:41    | LINE CLEAR AVAIED |
| 951   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)              | AMBEWADI_220                          | 10:28                 | 11:01                | 00:33    | LINE CLEAR AVAIED |
| 952   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV3(20MVA)              | HUBLI_220                             | 10:29                 | 17:17                | 06:48    | LINE CLEAR AVAIED |
| 953   | 20-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- KUDACHI1                | CHIKKODI_220                          | 14:08                 | 16:38                | 02:30    | LINE CLEAR AVAIED |
| 954   | 20-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI-<br>KOLAHPUA1(TALANDAGE) | CHIKKODI_220                          | 15:40                 | 17:00                | 01:20    | LINE CLEAR AVAIED |
| 955   | 20-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- NARENDRA                  | BIDNAL_220                            | 11:29                 | 14:18                | 02:49    | LINE CLEAR AVAIED |
| 956   | 20-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                    | VAJRAMATTI_220                        | 5:28                  | 5:59                 | 00:31    | LINE CLEAR AVAIED |
| 957   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-<br>MANTUR(MUDHOL)  | VAJRAMATTI_220                        | 5:35                  | 6:19                 | 00:44    | LINE CLEAR AVAIED |
| 958   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-BILAGI              | VAJRAMATTI_220                        | 9:23                  | 16:39                | 07:16    | LINE CLEAR AVAIED |
| 959   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-BILAGI              | VAJRAMATTI_220                        | 5:35                  | 6:08                 | 00:33    | LINE CLEAR AVAIED |
| 960   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-KATARKI             | VAJRAMATTI_220                        | 9:38                  | 17:10                | 07:32    | LINE CLEAR AVAIED |
| 961   | 20-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1&LV1                | VAJRAMATTI_220                        | 14:13                 | 14:20                | 00:07    | LINE CLEAR AVAIED |
| 962   | 20-Sep-24 | BAGALKOT | 220     | LINE        | KUDACHI- CHIKKODI1                | KUDACHI_220                           | 14:07                 | 16:30                | 02:23    | LINE CLEAR AVAIED |
| 963   | 20-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- HIREBAGEWADI          | MKHUBLI_220                           | 14:23                 | 14:25                | 00:02    | LINE CLEAR AVAIED |
| 964   | 20-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1               | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                      |          | LINE CLEAR AVAIED |
| 965   | 20-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2         | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                      |          | LINE CLEAR AVAIED |
| 966   | 20-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |                      |          | LINE CLEAR AVAIED |
| 967   | 20-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS             | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |                      |          | LINE CLEAR AVAIED |
| 968   | 20-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                      | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) |                      |          | LINE CLEAR AVAIED |
| 969   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | ALABAL_110                            | 08:03                 | 15:40                | 07:37    | LINE CLEAR AVAIED |
| 970   | 20-Sep-24 | BAGALKOT | 110     | LINE        | BILAGI-GIRISAGAR                  | BILAGI_110                            | 10:20                 | 16:55                | 06:35    | LINE CLEAR AVAIED |
| 971   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)               | GADAG_110                             | 10:06                 | 18:00                | 07:54    | LINE CLEAR AVAIED |
| 972   | 20-Sep-24 | BAGALKOT | 110     | LINE        | RON-BELAVANAKI                    | RON_110                               | 10:11                 | 19:00                | 08:49    | LINE CLEAR AVAIED |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name                             | Open_At               | Closed_At            | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|-------------------------------------|------------------------------------------|-----------------------|----------------------|----------|--------------------|
| 973   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | RON_110                                  | 10:01                 | 19:06                | 09:05    | LINE CLEAR AVAILED |
| 974   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | MORATAGI_110                             | 06:55                 | 07:00                | 00:05    | TRIPPED ON FAULT   |
| 975   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | MORATAGI_110                             | 09:00                 | 09:05                | 00:05    | TRIPPED ON FAULT   |
| 976   | 20-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-NK-1(HALIYAL)           | AMBEWADI_220                             | 10:08                 | 13:18                | 03:10    | LINE CLEAR AVAILED |
| 977   | 20-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220- GADAG                     | GADAG_220                                | 10:13                 | 15:57                | 05:44    | LINE CLEAR AVAILED |
| 978   | 20-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220- MACHE EXPRESS           | BELGAUM_220                              | 02:10                 | 02:23                | 00:13    | TRIPPED ON FAULT   |
| 979   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-MANTUR1               | VAJRAMATTI_220                           | 5:35                  | 6:04                 | 00:29    | LINE CLEAR AVAILED |
| 980   | 20-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-MANTUR2               | VAJRAMATTI_220                           | 5:35                  | 6:04                 | 00:29    | LINE CLEAR AVAILED |
| 981   | 20-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)                 | ILKAL_110                                | 18:07                 | 21:36                | 03:29    | TRIPPED ON FAULT   |
| 982   | 21-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR            | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                      |          | LINE CLEAR AVAILED |
| 983   | 21-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                 | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                      |          | LINE CLEAR AVAILED |
| 984   | 21-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                    | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                      |          | LINE CLEAR AVAILED |
| 985   | 21-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)            | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                      |          | LINE CLEAR AVAILED |
| 986   | 21-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                      | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                      |          | LINE CLEAR AVAILED |
| 987   | 21-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                  | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  |                      |          | TRIPPED ON FAULT   |
| 988   | 21-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2              | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                      |          | LINE CLEAR AVAILED |
| 989   | 21-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)               | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                      |          | LINE CLEAR AVAILED |
| 990   | 21-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-RON                         | HIREHAL_110                              | 10:21<br>(20.09.2024) | 9:39<br>(21.09.2024) | 23:18    | LINE CLEAR AVAILED |
| 991   | 21-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                  | KIRUVATTI_110                            | 9:15<br>(20.09.2024)  |                      |          | LINE CLEAR AVAILED |
| 992   | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | AINAPUR_110                              | 11:30                 | 13:25                | 01:55    | LINE CLEAR AVAILED |
| 993   | 21-Sep-24 | BAGALKOT | 110     | LINE        | BANAHATTI-<br>JAMAKHANDI(NAVALAGI)  | BANAHATTI_110                            | 17:45                 | 17:55                | 00:10    | TRIPPED ON FAULT   |
| 994   | 21-Sep-24 | BAGALKOT | 110     | LINE        | DEVANGOAN-F1(GATTARAGI)             | DEVANGOAN_110                            | 12:41                 | 17:55                | 05:14    | LINE CLEAR AVAILED |
| 995   | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(20MVA)                 | GULEDAGUDDA_110                          | 09:15                 | 14:34                | 05:19    | LINE CLEAR AVAILED |
| 996   | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | GULEDAGUDDA_110                          | 09:15                 | 14:14                | 04:59    | LINE CLEAR AVAILED |
| 997   | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | HEBBALI_110                              | 09:40                 | 13:49                | 04:09    | LINE CLEAR AVAILED |
| 998   | 21-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-IDLE(BADAMI)                | HIREHAL_110                              | 09:39                 | 14:02                | 04:23    | LINE CLEAR AVAILED |
| 999   | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | HIREKERUR_110                            | 08:13                 | 08:18                | 00:05    | TRIPPED ON FAULT   |
| 1000  | 21-Sep-24 | BAGALKOT | 110     | LINE        | HUNGUND-B BAGEWADI(KUDAL<br>SANGAM) | HUNGUND_110                              | 10:01                 | 21:22                | 11:21    | LINE CLEAR AVAILED |
| 1001  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA-HV1)             | KANABARAGI_110                           | 11:01                 | 12:00                | 00:59    | LINE CLEAR AVAILED |
| 1002  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | KALADADI_110                             | 07:20                 | 07:27                | 00:07    | TRIPPED ON FAULT   |
| 1003  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                 | KALADADI_110                             | 07:20                 | 07:26                | 00:06    | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|----------|---------|-------------|-------------------------------------|------------------|---------|-----------|----------|---------------------|
| 1004  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KALADADI-BAGALKOT                   | KALADADI_110     | 09:25   | 15:26     | 06:01    | LINE CLEAR AVAIED   |
| 1005  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-KONNUR                        | KERUR_110        | 09:25   | 13:37     | 04:12    | LINE CLEAR AVAIED   |
| 1006  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-KONNUR                        | KERUR_110        | 14:07   | 14:15     | 00:08    | LINE CLEAR AVAIED   |
| 1007  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-BADAMI                        | KERUR_110        | 09:25   | 14:31     | 05:06    | LINE CLEAR AVAIED   |
| 1008  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KERUR-BAGALKOT                      | KERUR_110        | 09:25   | 14:08     | 04:43    | LINE CLEAR AVAIED   |
| 1009  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA)                 | KERUR_110        | 09:35   | 14:25     | 04:50    | LINE CLEAR AVAIED   |
| 1010  | 21-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-YADWAD                        | UTTUR_110        | 06:27   | 06:43     | 00:16    | TRIPPED ON FAULT    |
| 1011  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA)                 | TOLAMATTI_110    | 08:43   | 16:40     | 07:57    | LINE CLEAR AVAIED   |
| 1012  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | TALIKOT_110      | 09:10   | 09:17     | 00:07    | TRIPPED ON FAULT    |
| 1013  | 21-Sep-24 | BAGALKOT | 110     | LINE        | TERDAL-KUDACHI(HARUGERI)            | TERDAL_110       | 13:55   | 14:02     | 00:07    | LINE CLEAR AVAIED   |
| 1014  | 21-Sep-24 | BAGALKOT | 110     | LINE        | TERDAL -MAHALINGAPUR<br>(YARAGATTI) | TERDAL_110       | 02:18   | 14:02     | 11:44    | LINE CLEAR AVAIED   |
| 1015  | 21-Sep-24 | BAGALKOT | 110     | LINE        | SULTANPURA-F2(MUGALKHOD)            | SULTANPURA_110   | 14:54   | 14:59     | 00:05    | LINE CLEAR AVAIED   |
| 1016  | 21-Sep-24 | BAGALKOT | 110     | LINE        | SULTANPURA-<br>F1(MAHALINGAPUR)     | SULTANPURA_110   | 14:55   | 15:02     | 00:07    | LINE CLEAR AVAIED   |
| 1017  | 21-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                         | RON_110          | 09:29   | 09:35     | 00:06    | LINE CLEAR AVAIED   |
| 1018  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | NAVALAGI_110     | 10:22   | 16:16     | 05:54    | LINE CLEAR AVAIED   |
| 1019  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | NARAGUND_110     | 11:37   | 17:17     | 05:40    | LINE CLEAR AVAIED   |
| 1020  | 21-Sep-24 | BAGALKOT | 110     | LINE        | NARAGUND-BPCL(WIND)                 | NARAGUND_110     | 11:37   | 17:17     | 05:40    | LINE CLEAR AVAIED   |
| 1021  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(20MVA,HV2)             | MUDHOL_110       | 21:24   | 22:01     | 00:37    | TRIPPED ON FAULT    |
| 1022  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                 | MALGHAN_110      | 08:09   | 08:12     | 00:03    | TRIPPED ON FAULT    |
| 1023  | 21-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-<br>BABALESHWARA       | MAMADAPUR(B)     | 10:43   | 17:27     | 06:44    | LINE CLEAR AVAIED   |
| 1024  | 21-Sep-24 | BAGALKOT | 110     | LINE        | LOKAPUR-VAJRAMATTI                  | LOKAPUR_110      | 14:41   | 16:44     | 02:03    | LINE CLEAR AVAIED   |
| 1025  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | KULGERICROSS_110 | 07:35   | 07:40     | 00:05    | TRIPPED ON FAULT    |
| 1026  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KUDALASANGAM-HUNAGUNDA              | KUDALASANGAM_110 | 10:14   | 16:40     | 06:26    | LINE CLEAR AVAIED   |
| 1027  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KUDALASANGAM-HUNAGUNDA              | KUDALASANGAM_110 | 21:06   | 21:21     | 00:15    | MAIN SUPPLY FAILURE |
| 1028  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-NAVALAGUND                   | KONNUR_110       | 14:20   | 17:27     | 03:07    | MAIN SUPPLY FAILURE |
| 1029  | 21-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220- LN5(ITANAL3)          | MUGALKHOD_220    | 23:26   | 23:38     | 00:12    | TRIPPED ON FAULT    |
| 1030  | 21-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1&LV1                  | BAGALKOT_220     | 09:20   | 12:13     | 02:53    | LINE CLEAR AVAIED   |
| 1031  | 21-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2&LV2                  | BAGALKOT_220     | 09:20   | 09:23     | 00:03    | LINE CLEAR AVAIED   |
| 1032  | 21-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2(HV3)                 | BAGALKOT_220     | 09:20   | 09:23     | 00:03    | LINE CLEAR AVAIED   |
| 1033  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- BAGALKOT2              | BAGALKOT_220     | 10:03   | 16:09     | 06:06    | LINE CLEAR AVAIED   |
| 1034  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- NAVANAGAR1             | BAGALKOT_220     | 09:20   | 12:15     | 02:55    | LINE CLEAR AVAIED   |
| 1035  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- NAVANAGAR2             | BAGALKOT_220     | 09:20   | 12:12     | 02:52    | LINE CLEAR AVAIED   |
| 1036  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- GULEDAGUDDA            | BAGALKOT_220     | 09:24   | 13:42     | 04:18    | LINE CLEAR AVAIED   |
| 1037  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- GULEDAGUDDA            | BAGALKOT_220     | 16:03   | 19:34     | 03:31    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                 | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS             |
|-------|-----------|----------|---------|-------------|--------------------------------------|------------------------------------------|-----------------------|-----------|----------|---------------------|
| 1038  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- KERUR                   | BAGALKOT_220                             | 09:20                 | 13:51     | 04:31    | LINE CLEAR AVAIED   |
| 1039  | 21-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-<br>KATARKI(NEERBUDIHAI) | BAGALKOT_220                             | 14:48                 | 16:33     | 01:45    | LINE CLEAR AVAIED   |
| 1040  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV4                        | BAGALKOT_220                             | 09:20                 | 09:32     | 00:12    | LINE CLEAR AVAIED   |
| 1041  | 21-Sep-24 | BAGALKOT | 220     | LINE        | DHONI-<br>LINGAPUR2(HALVARTHI1)      | DHONI_400                                | 11:16                 | 14:46     | 03:30    | LINE CLEAR AVAIED   |
| 1042  | 21-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220- VAJRAMATTI            | VAJRAMATTI_220                           | 10:55                 | 10:58     | 00:03    | LINE CLEAR AVAIED   |
| 1043  | 21-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220- VAJRAMATTI            | VAJRAMATTI_220                           | 13:17                 | 13:29     | 00:12    | LINE CLEAR AVAIED   |
| 1044  | 21-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220- MELLIGERI             | VAJRAMATTI_220                           | 13:16                 | 13:39     | 00:23    | LINE CLEAR AVAIED   |
| 1045  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                 | CHIKKODI_220                             | 10:03                 | 13:39     | 03:36    | LINE CLEAR AVAIED   |
| 1046  | 21-Sep-24 | BAGALKOT | 220     | LINE        | SIRSI- SHARAVATHY1                   | SIRSI_220                                | 08:50                 | 17:43     | 08:53    | TRIPPED ON FAULT    |
| 1047  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                 | AMBEWADI_220                             | 11:02                 | 11:24     | 00:22    | LINE CLEAR AVAIED   |
| 1048  | 21-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                  | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED   |
| 1049  | 21-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2            | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED   |
| 1050  | 21-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                   | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED   |
| 1051  | 21-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED   |
| 1052  | 21-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                         | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |           |          | LINE CLEAR AVAIED   |
| 1053  | 21-Sep-24 | BAGALKOT | 110     | LINE        | ITNAL-BORUKA                         | ITNAL_110                                | 23:25                 | 23:35     | 0:10     | TRIPPED ON FAULT    |
| 1054  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA)                  | KERUR_110                                | 09:25                 | 14:25     | 5:00     | LINE CLEAR AVAIED   |
| 1055  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                  | YADAWAD_110                              | 06:44                 | 07:02     | 0:18     | TRIPPED ON FAULT    |
| 1056  | 21-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                  | MORATAGI_110                             | 06:40                 | 06:45     | 0:05     | TRIPPED ON FAULT    |
| 1057  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KULGERI CROSS-KERUR                  | KULGERICROSS_110                         | 09:22                 | 13:49     | 4:27     | LINE CLEAR AVAIED   |
| 1058  | 21-Sep-24 | BAGALKOT | 110     | LINE        | KONNUR-NAVALAGUND                    | KONNUR_110                               | 13:20                 | 13:25     | 0:05     | MAIN SUPPLY FAILURE |
| 1059  | 21-Sep-24 | BAGALKOT | 220     | LINE        | HAVERI- SHIGGOAN1                    | HAVERI_220                               | 15:30                 | 18:48     | 3:18     | TRIPPED ON FAULT    |
| 1060  | 21-Sep-24 | BAGALKOT | 220     | LINE        | SHIGGOAN- HAVERI1                    | SHIGGOAN_220                             | 17:19                 | 18:39     | 1:20     | LINE CLEAR AVAIED   |
| 1061  | 22-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR             | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED   |
| 1062  | 22-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                  | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED   |
| 1063  | 22-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2                    | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED   |
| 1064  | 22-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)             | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED   |
| 1065  | 22-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                       | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED   |
| 1066  | 22-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI                   | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  |           |          | TRIPPED ON FAULT    |
| 1067  | 22-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2               | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |           |          | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                        | Station_Name                         | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-----------------------------|--------------------------------------|-----------------------|-----------|----------|-------------------|
| 1068  | 22-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)       | STATION NOT AFFECTED<br>ISLAMPUR_110 | 9:47<br>(17.09.2024)  |           |          | LINE CLEAR AVAIED |
| 1069  | 22-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI          | KIRUVATTI_110                        | 9:15<br>(20.09.2024)  |           |          | LINE CLEAR AVAIED |
| 1070  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)     | ANKOLA_110                           | 9:38<br>(22.09.2024)  |           |          | LINE CLEAR AVAIED |
| 1071  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)         | BELLATTI_110                         | 18:20<br>(22.09.2024) |           |          | TRIPPED ON FAULT  |
| 1072  | 22-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-ENERCON2           | BELLATTI_110                         | 18:29                 | 19:15     | 0:46     | LINE CLEAR AVAIED |
| 1073  | 22-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-AB_SLR             | BELLATTI_110                         | 18:29                 | 19:15     | 0:46     | LINE CLEAR AVAIED |
| 1074  | 22-Sep-24 | BAGALKOT | 110     | LINE        | THORVI-BHUTNAL              | THORVI_110                           | 09:07                 | 14:45     | 5:38     | LINE CLEAR AVAIED |
| 1075  | 22-Sep-24 | BAGALKOT | 110     | LINE        | THORVI-TIKOTA               | THORVI_110                           | 00:43                 | 00:50     | 0:07     | TRIPPED ON FAULT  |
| 1076  | 22-Sep-24 | BAGALKOT | 110     | LINE        | BYADAGI-RAILWAY             | BYADAGI_110                          | 19:40                 | 19:59     | 0:19     | TRIPPED ON FAULT  |
| 1077  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)         | GOKAK_110                            | 10:29                 | 12:55     | 2:26     | LINE CLEAR AVAIED |
| 1078  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)         | GOKAK_110                            | 13:53                 | 14:08     | 0:15     | LINE CLEAR AVAIED |
| 1079  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA-HV3)     | HANAGAL_110                          | 10:41                 | 10:43     | 0:02     | TRIPPED ON FAULT  |
| 1080  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)         | HATTARAGI_110                        | 06:06                 | 06:20     | 0:14     | TRIPPED ON FAULT  |
| 1081  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)         | HATTARAGI_110                        | 07:09                 | 07:45     | 0:36     | TRIPPED ON FAULT  |
| 1082  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)         | HIREKERUR_110                        | 14:23                 | 14:27     | 0:04     | TRIPPED ON FAULT  |
| 1083  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA-HV3)     | HUNGUND_110                          | 19:36                 | 19:40     | 0:04     | TRIPPED ON FAULT  |
| 1084  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(20MVA)         | KADANAKOPPA_110                      | 16:41                 | 18:03     | 1:22     | LINE CLEAR AVAIED |
| 1085  | 22-Sep-24 | BAGALKOT | 110     | LINE        | UGAR KHUD-KAGWADA           | UGAR KHUD_110                        | 18:27                 | 19:02     | 0:35     | TRIPPED ON FAULT  |
| 1086  | 22-Sep-24 | BAGALKOT | 110     | LINE        | UGAR KHUD-UGAR SUGAR        | UGAR KHUD_110                        | 18:27                 | 19:01     | 0:34     | TRIPPED ON FAULT  |
| 1087  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)         | UDAYMBAG_110                         | 09:17                 | 12:27     | 3:10     | LINE CLEAR AVAIED |
| 1088  | 22-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-TIKOTA            | TAKKALAKI_110                        | 00:43                 | 00:51     | 0:08     | TRIPPED ON FAULT  |
| 1089  | 22-Sep-24 | BAGALKOT | 110     | LINE        | SHIGOAN-RMKP(MUNDAGHOD)     | SHIGOAN_110                          | 15:35                 | 17:20     | 1:45     | TRIPPED ON FAULT  |
| 1090  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(10MVA)         | RAIBHGA_110                          | 21:44                 | 21:58     | 0:14     | TRIPPED ON FAULT  |
| 1091  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV1(20MVA)         | MKHUBLI_110                          | 16:33                 | 17:32     | 0:59     | TRIPPED ON FAULT  |
| 1092  | 22-Sep-24 | BAGALKOT | 110     | LINE        | LAKSHMESHWARA-GADAG1        | LAKSHMESHWARA_110                    | 18:20                 | 19:04     | 0:44     | TRIPPED ON FAULT  |
| 1093  | 22-Sep-24 | BAGALKOT | 110     | LINE        | GHATAPRABHA220-GOKAK        | GHATAPRABHA_220                      | 10:13                 | 12:42     | 2:29     | LINE CLEAR AVAIED |
| 1094  | 22-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- AEQUS2(KANAGALA2) | CHIKKODI_220                         | 21:02                 | 21:45     | 0:43     | TRIPPED ON FAULT  |
| 1095  | 22-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- AEQUS1(KANAGALA1) | CHIKKODI_220                         | 21:02                 | 21:48     | 0:46     | TRIPPED ON FAULT  |
| 1096  | 22-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS1             | BELGAUM_220                          | 21:03                 | 21:26     | 0:23     | TRIPPED ON FAULT  |
| 1097  | 22-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS2             | BELGAUM_220                          | 21:03 (22.09.2024)    |           |          | TRIPPED ON FAULT  |
| 1098  | 22-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -F1(BELGAUM1)         | AEQUS_220                            | 21:03                 | 21:34     | 00:31    | TRIPPED ON FAULT  |
| 1099  | 22-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -F2(BELGAUM2)         | AEQUS_220                            | 21:03 (22.09.2024)    |           |          | TRIPPED ON FAULT  |
| 1100  | 22-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220- TERDAL(MORAB)   | KUDACHI_220                          | 19:41                 | 20:13     | 00:32    | TRIPPED ON FAULT  |
| 1101  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)         | KUDACHI_220                          | 14:18                 | 18:56     | 04:38    | LINE CLEAR AVAIED |
| 1102  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV1              | AEQUS_220                            | 21:16                 | 21:36     | 00:20    | LINE CLEAR AVAIED |
| 1103  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2              | AEQUS_220                            | 21:16                 | 21:38     | 00:22    | LINE CLEAR AVAIED |
| 1104  | 22-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN3(HUKKERI)       | AEQUS_220                            | 21:24                 | 21:51     | 00:27    | LINE CLEAR AVAIED |
| 1105  | 22-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN2(SANKESHWAR)    | AEQUS_220                            | 21:24                 | 21:54     | 00:30    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                      | Station_Name                          | Open_At               | Closed_At             | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------|---------------------------------------|-----------------------|-----------------------|----------|--------------------|
| 1106  | 22-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN1(DADDI)       | AEQUS_220                             | 21:23                 | 21:50                 | 00:27    | LINE CLEAR AVAILED |
| 1107  | 22-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN4(HATTARGI)    | STATION NOT AFFECTED HATTARGI_110     | 21:02                 | 21:59                 | 00:57    | LINE CLEAR AVAILED |
| 1108  | 22-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR220- GSML1    | MAHALINGAPUR_220                      | 08:55                 | 16:25                 | 07:30    | LINE CLEAR AVAILED |
| 1109  | 22-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR220- GSML2    | MAHALINGAPUR_220                      | 08:56                 | 16:25                 | 07:29    | LINE CLEAR AVAILED |
| 1110  | 22-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- NAGJHARI2         | BIDNAL_220                            | 15:03                 | 18:50                 | 03:47    | TRIPPED ON FAULT   |
| 1111  | 22-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1       | STATION NOT AFFECTED MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |          | LINE CLEAR AVAILED |
| 1112  | 22-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2 | STATION NOT AFFECTED SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |          | LINE CLEAR AVAILED |
| 1113  | 22-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2        | STATION NOT AFFECTED SOUDATTI_220     | 10:49<br>(18.07.2024) |                       |          | LINE CLEAR AVAILED |
| 1114  | 22-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS     | STATION NOT AFFECTED BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |          | LINE CLEAR AVAILED |
| 1115  | 22-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2              | STATION NOT AFFECTED HUDALI_110       | 11:05<br>(01.09.2024) |                       |          | LINE CLEAR AVAILED |
| 1116  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)       | HANAGAL_110                           | 10:50                 | 10:55                 | 0:05     | TRIPPED ON FAULT   |
| 1117  | 22-Sep-24 | BAGALKOT | 110     | LINE        | SHIGOAN-GANJIGUTTI        | SHIGOAN_110                           | 15:35                 | 16:20                 | 0:45     | TRIPPED ON FAULT   |
| 1118  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)       | MALGHAN_110                           | 14:40                 | 14:45                 | 0:05     | TRIPPED ON FAULT   |
| 1119  | 22-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN220- SHIGGOAN     | SHIGGOAN_220                          | 15:35                 | 16:20                 | 0:45     | TRIPPED ON FAULT   |
| 1120  | 22-Sep-24 | BAGALKOT | 110     | LINE        | SHIGGOAN- MUNDAGOD        | SHIGGOAN_110                          | 15:35                 | 17:20                 | 1:45     | TRIPPED ON FAULT   |
| 1121  | 22-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)       | SHIRBUR_110                           | 03:35                 | 11:51                 | 8:16     | TRIPPED ON FAULT   |
| 1122  | 23-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR  | STATION NOT AFFECTED HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAILED |
| 1123  | 23-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2       | STATION NOT AFFECTED NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAILED |
| 1124  | 23-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2          | STATION NOT AFFECTED BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAILED |
| 1125  | 23-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)  | STATION NOT AFFECTED UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAILED |
| 1126  | 23-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG            | STATION NOT AFFECTED MACHE_110        | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAILED |
| 1127  | 23-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI        | STATION NOT AFFECTED DHONI_400        | 8:25<br>(14.09.2024)  |                       |          | TRIPPED ON FAULT   |
| 1128  | 23-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2    | STATION NOT AFFECTED MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                       |          | LINE CLEAR AVAILED |
| 1129  | 23-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)     | STATION NOT AFFECTED ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                       |          | LINE CLEAR AVAILED |
| 1130  | 23-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI        | KIRUVATTI_110                         | 9:15<br>(20.09.2024)  |                       |          | LINE CLEAR AVAILED |
| 1131  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)   | ANKOLA_110                            | 9:38<br>(22.09.2024)  |                       |          | LINE CLEAR AVAILED |
| 1132  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)       | BELLATTI_110                          | 18:20<br>(22.09.2024) | 9:14<br>(23.09.2024)  | 14:54:00 | TRIPPED ON FAULT   |
| 1133  | 23-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS2           | BELGAUM_220                           | 21:03 (22.09.2024)    | 12:18<br>(23.09.2024) | 15:15:00 | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                            | Station_Name                      | Open_At               | Closed_At             | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------------|-----------------------------------|-----------------------|-----------------------|----------|--------------------|
| 1134  | 23-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -F2(BELGAUM2)             | AEQUS_220                         | 21:03 (22.09.2024)    | 12:25<br>(23.09.2024) | 15:22:00 | TRIPPED ON FAULT   |
| 1135  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | ANKOLA_110                        | 09:51                 | 10:10                 | 0:19     | LINE CLEAR AVAILED |
| 1136  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(20MVA)             | ATHANI_110                        | 19:11                 | 19:40                 | 0:29     | TRIPPED ON FAULT   |
| 1137  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA-HV2)         | BAILHONGAL_110                    | 13:01                 | 14:20                 | 1:19     | LINE CLEAR AVAILED |
| 1138  | 23-Sep-24 | BAGALKOT | 110     | LINE        | HALIYAL-HALIYAAL LIS            | HALIYAL(ATHANI)_110               | 10:28                 | 13:40                 | 3:12     | LINE CLEAR AVAILED |
| 1139  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA-HV1)         | HIDIKAL DAM_110                   | 10:53                 | 11:01                 | 0:08     | TRIPPED ON FAULT   |
| 1140  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | HOSAHONNATTI_110                  | 10:29                 | 16:21                 | 5:52     | LINE CLEAR AVAILED |
| 1141  | 23-Sep-24 | BAGALKOT | 110     | LINE        | ITNAL-HIDIKAL(KABBUR3)          | ITNAL_110                         | 16:53                 | 17:08                 | 0:15     | TRIPPED ON FAULT   |
| 1142  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA-HV2)         | KALADAGI_110                      | 18:45                 | 18:56                 | 0:11     | TRIPPED ON FAULT   |
| 1143  | 23-Sep-24 | BAGALKOT | 110     | LINE        | KALAGHATAGI-HUBLI               | KALAGHATAGI_110                   | 13:41                 | 17:07                 | 3:26     | TRIPPED ON FAULT   |
| 1144  | 23-Sep-24 | BAGALKOT | 110     | LINE        | KALAGHATAGI-ABS(KAVALWADA)      | KALAGHATAGI_110                   | 16:03                 | 17:10                 | 1:07     | LINE CLEAR AVAILED |
| 1145  | 23-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-ENERCON2               | BELLATTI_110                      | 19:43                 | 20:16                 | 0:33     | LINE CLEAR AVAILED |
| 1146  | 23-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-AB_SLR                 | BELLATTI_110                      | 19:43                 | 20:22                 | 0:39     | LINE CLEAR AVAILED |
| 1147  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | TALIKOTI_110                      | 09:41                 | 09:55                 | 0:14     | TRIPPED ON FAULT   |
| 1148  | 23-Sep-24 | BAGALKOT | 110     | LINE        | SISRSI-KUMTA2                   | SISRSI_110                        | 2:29<br>(23.09.2024)  | 11:45<br>(24.09.2024) | 33:16:00 | TRIPPED ON FAULT   |
| 1149  | 23-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKODI             | SANKESHWARA_110                   | 11:26<br>(23.09.2024) |                       |          | LINE CLEAR AVAILED |
| 1150  | 23-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-HUKKERI (AQUES 220) | SANKESHWARA_110                   | 21:02<br>(22.09.2024) | 11:26<br>(23.09.2024) | 14:24    | LINE CLEAR AVAILED |
| 1151  | 23-Sep-24 | BAGALKOT | 110     | LINE        | SAMBAPUR-GADAG                  | SAMBAPUR_110                      | 13:38                 | 14:59                 | 1:21     | LINE CLEAR AVAILED |
| 1152  | 23-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                     | RON_110                           | 05:42                 | 06:03                 | 0:21     | TRIPPED ON FAULT   |
| 1153  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)             | MALGHAN(B)_110                    | 15:53                 | 15:57                 | 0:04     | TRIPPED ON FAULT   |
| 1154  | 23-Sep-24 | BAGALKOT | 110     | LINE        | LAXMESWAR-GADAG1                | LAXMESWAR_110                     | 19:41                 | 20:11                 | 0:30     | TRIPPED ON FAULT   |
| 1155  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | KUMATA_110                        | 02:46                 | 02:51                 | 0:05     | TRIPPED ON FAULT   |
| 1156  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | KUD DHARWAD_110                   | 11:32                 | 12:23                 | 0:51     | LINE CLEAR AVAILED |
| 1157  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | KUD DHARWAD_110                   | 15:34                 | 17:01                 | 1:27     | LINE CLEAR AVAILED |
| 1158  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV 4(20MVA)            | KERUR_110                         | 08:10                 | 08:22                 | 0:12     | LINE CLEAR AVAILED |
| 1159  | 23-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220- SIRSI(KALGHATAGI)     | HUBLI_220                         | 13:40                 | 17:07                 | 3:27     | TRIPPED ON FAULT   |
| 1160  | 23-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220-GADAG1(BETAGERI)       | GADAG_220                         | 11:07                 | 14:35                 | 3:28     | LINE CLEAR AVAILED |
| 1161  | 23-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220-DAMBAL2(DAMBAL)        | GADAG_220                         | 12:04                 | 13:34                 | 1:30     | LINE CLEAR AVAILED |
| 1162  | 23-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220-DAMBAL1(SAMBAPUR ROAD) | GADAG_220                         | 13:38                 | 14:59                 | 1:21     | LINE CLEAR AVAILED |
| 1163  | 23-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-NK 2(HALIYAL)       | AMBEWADI_220                      | 16:05                 | 16:09                 | 0:04     | LINE CLEAR AVAILED |
| 1164  | 23-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- KUDACHI2              | CHIKKODI_220                      | 11:32                 | 13:15                 | 1:43     | LINE CLEAR AVAILED |
| 1165  | 23-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- AEQUS1                 | BELGAUM_220                       | 8:20                  | 12:18                 | 3:58     | LINE CLEAR AVAILED |
| 1166  | 23-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS -F1(BELGAUM1)             | STATION NOT AFFECTED<br>AEQUS_220 | 8:12                  | 12:24                 | 4:12     | LINE CLEAR AVAILED |
| 1167  | 23-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                  | KUDACHI_220                       | 10:34                 | 16:52                 | 6:18     | LINE CLEAR AVAILED |
| 1168  | 23-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, LV1                  | KUDACHI_220                       | 10:32                 | 16:55                 | 6:23     | LINE CLEAR AVAILED |
| 1169  | 23-Sep-24 | BAGALKOT | 220     | LINE        | KUDACHI- CHIKKODI2              | KUDACHI_220                       | 11:31                 | 13:16                 | 1:45     | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                      | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------|------------------------------------------|-----------------------|-----------------------|-----------|--------------------|
| 1170  | 23-Sep-24 | BAGALKOT | 110     | LINE        | AEQUS220-LN2(SANKESHWAR)  | AEQUS_220                                | 11:08                 | 11:34                 | 0:26      | LINE CLEAR AVAILED |
| 1171  | 23-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI220-KATARAKI    | VAJRAMATTI_220                           | 22:31                 | 22:37                 | 0:06      | TRIPPED ON FAULT   |
| 1172  | 23-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1       | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAILED |
| 1173  | 23-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2 | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAILED |
| 1174  | 23-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2        | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAILED |
| 1175  | 23-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS     | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 1176  | 23-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2              | STATION NOT AFFECTED<br>HUDALI_110       | 11:05<br>(01.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1177  | 23-Sep-24 | BAGALKOT | 110     | LINE        | HALIYAL-HALIYAAL LIS      | HALIYAL(ATHANI)_110                      | 01:15                 | 01:35                 | 0:20      | TRIPPED ON FAULT   |
| 1178  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)       | HIDIKAL DAM_110                          | 13:17                 | 13:22                 | 0:05      | TRIPPED ON FAULT   |
| 1179  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)       | KHADAKLAT_110                            | 08:30                 | 08:45                 | 0:15      | LINE CLEAR AVAILED |
| 1180  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)       | KHADAKLAT_110                            | 10:55                 | 11:50                 | 0:55      | LINE CLEAR AVAILED |
| 1181  | 23-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA)       | GHATAPRABHA_110                          | 20:15<br>(22.09.2024) | 12:15<br>(23.09.2024) | 16:00     | TRIPPED ON FAULT   |
| 1182  | 23-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(S)-MANALI SUGARS  | MALGHAN(S)_110                           | 15:35                 | 16:04                 | 0:29      | TRIPPED ON FAULT   |
| 1183  | 23-Sep-24 | BAGALKOT | 110     | LINE        | LAXMESWAR-BELLATTI        | LAXMESWAR_110                            | 19:41                 | 20:11                 | 0:30      | TRIPPED ON FAULT   |
| 1184  | 23-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1            | RANEBENNUR_220                           | 10:28                 | 17:22                 | 6:54      | LINE CLEAR AVAILED |
| 1185  | 23-Sep-24 | BAGALKOT | 220     | LINE        | HAVERI- SHIGGOAN1         | HAVERI_220                               | 10:50                 | 12:46                 | 1:56      | LINE CLEAR AVAILED |
| 1186  | 23-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220- ITANAL3     | MUGALKHOD_220                            | 16:52                 | 17:06                 | 0:14      | TRIPPED ON FAULT   |
| 1187  | 23-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-HALIYAL         | ATHANI_220                               | 01:14                 | 01:35                 | 0:21      | TRIPPED ON FAULT   |
| 1188  | 23-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-AIGALI2         | ATHANI_220                               | 18:30                 | 18:47                 | 0:17      | TRIPPED ON FAULT   |
| 1189  | 23-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-BALIGERI        | ATHANI_220                               | 20:09                 | 20:50                 | 0:41      | TRIPPED ON FAULT   |
| 1190  | 23-Sep-24 | BAGALKOT | 220     | LINE        | SHIGGOAN- HAVERI1         | SHIGGOAN_220                             | 10:50                 | 12:46                 | 1:56      | LINE CLEAR AVAILED |
| 1191  | 23-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220- HARUGERI      | KUDACHI_220                              | 12:20                 | 12:40                 | 0:20      | TRIPPED ON FAULT   |
| 1192  | 24-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR  | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAILED |
| 1193  | 24-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2       | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAILED |
| 1194  | 24-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2         | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 1195  | 24-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)  | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAILED |
| 1196  | 24-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG            | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1197  | 24-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUDADAHALLI        | STATION NOT AFFECTED<br>DHONI_400        | 8:25<br>(14.09.2024)  | 17:37<br>(24.09.2024) | 249:12:00 | TRIPPED ON FAULT   |
| 1198  | 24-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2    | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1199  | 24-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)     | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  |                       |           | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                     | Station_Name       | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|------------------------------------------|--------------------|-----------------------|-----------------------|-----------|--------------------|
| 1200  | 24-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                       | KIRUVATTI_110      | 9:15<br>(20.09.2024)  | 12:33<br>(24.09.2024) | 99:18:00  | LINE CLEAR AVAILED |
| 1201  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)                  | ANKOLA_110         | 9:38<br>(22.09.2024)  |                       |           | LINE CLEAR AVAILED |
| 1202  | 24-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKODI                      | SANKESHWARA_110    | 11:26<br>(23.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1203  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BABLESHWAR-<br>(MAMADAPUR)TIKOTA         | BABLESHWAR_110     | 16:00<br>(24.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1204  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-AB SLR                          | BELLATTI_110       | 10:23                 | 18:53                 | 8:30      | LINE CLEAR AVAILED |
| 1205  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-ENERCON2                        | BELLATTI_110       | 10:23                 | 18:18                 | 7:55      | LINE CLEAR AVAILED |
| 1206  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                      | BELLATTI_110       | 10:25                 | 18:15                 | 7:50      | LINE CLEAR AVAILED |
| 1207  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                      | BELLATTI_110       | 10:25                 | 18:15                 | 7:50      | LINE CLEAR AVAILED |
| 1208  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                      | KALAGHATAGI_110    | 10:52                 | 11:44                 | 0:52      | TRIPPED ON FAULT   |
| 1209  | 24-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                       | KIRUVATTI_110      | 12:45<br>(24.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1210  | 24-Sep-24 | BAGALKOT | 110     | LINE        | KAMBAGI-F1(MAMADAPUR)                    | KAMBAGI_110        | 10:0<br>(19.09.2024)  | 10:12<br>(24.09.2024) | 120:12:00 | LINE CLEAR AVAILED |
| 1211  | 24-Sep-24 | BAGALKOT | 110     | LINE        | KULAGERI CROSS-MRN                       | KULAGERI CROSS_110 | 14:28                 | 14:30                 | 0:02      | TRIPPED ON FAULT   |
| 1212  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                      | KULAGERI CROSS_110 | 06:01                 | 06:03                 | 0:02      | TRIPPED ON FAULT   |
| 1213  | 24-Sep-24 | BAGALKOT | 110     | LINE        | LAKMESHWAR-GADAG1                        | LAKMESHWAR_110     | 09:57                 | 17:09                 | 7:12      | LINE CLEAR AVAILED |
| 1214  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                      | LAKMESHWAR_110     | 10:04                 | 17:14                 | 7:10      | LINE CLEAR AVAILED |
| 1215  | 24-Sep-24 | BAGALKOT | 110     | LINE        | LAKMESHWAR-BELLATTI                      | LAKMESHWAR_110     | 10:35                 | 17:53                 | 7:18      | LINE CLEAR AVAILED |
| 1216  | 24-Sep-24 | BAGALKOT | 110     | LINE        | LAKMESHWAR-BELLATTI                      | LAKMESHWAR_110     | 18:02                 | 18:11                 | 0:09      | LINE CLEAR AVAILED |
| 1217  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                      | MALGHAN(B)_110     | 02:05                 | 02:06                 | 0:01      | TRIPPED ON FAULT   |
| 1218  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                      | MALGHAN(B)_110     | 07:35                 | 07:40                 | 0:05      | TRIPPED ON FAULT   |
| 1219  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                      | MALGHAN(B)_110     | 14:55                 | 15:11                 | 0:16      | LINE CLEAR AVAILED |
| 1220  | 24-Sep-24 | BAGALKOT | 110     | LINE        | YELLAMMANAWADI-SAVALAGI                  | YELLAMMANAWADI_110 | 07:44                 | 08:10                 | 0:26      | TRIPPED ON FAULT   |
| 1221  | 24-Sep-24 | BAGALKOT | 110     | LINE        | YELLAMMANAWADI-SAVALAGI                  | YELLAMMANAWADI_110 | 10:18                 | 15:42                 | 5:24      | LINE CLEAR AVAILED |
| 1222  | 24-Sep-24 | BAGALKOT | 110     | LINE        | TODALBAGI-JAMAKHANDI<br>SUGARS           | TODALBAGI_110      | 07:44                 | 08:00                 | 0:16      | TRIPPED ON FAULT   |
| 1223  | 24-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-THORVI(KIADB<br>BIJAPUR)       | TAKKALAKI_110      | 09:03                 | 15:57                 | 6:54      | LINE CLEAR AVAILED |
| 1224  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RAIBAG-CHIKKODI1                         | RAIBAG_110         | 11:15                 | 15:40                 | 4:25      | LINE CLEAR AVAILED |
| 1225  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                     | PG HUNSYAL_110     | 16:31                 | 17:14                 | 0:43      | LINE CLEAR AVAILED |
| 1226  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                     | NAVALGUND_110      | 11:41                 | 12:43                 | 1:02      | LINE CLEAR AVAILED |
| 1227  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV3(20MVA-HV2)                 | MUDHOL_110         | 12:39                 | 18:55                 | 6:16      | LINE CLEAR AVAILED |
| 1228  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220- HIREKERUR                  | RANEENNUR_220      | 05:37                 | 05:41                 | 0:04      | LINE CLEAR AVAILED |
| 1229  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220-<br>AREMALLAPUR( HONNATTI)  | RANEENNUR_220      | 05:37                 | 05:41                 | 0:04      | LINE CLEAR AVAILED |
| 1230  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220-<br>RATTIHALLI(TUMMINKATTI) | RANEENNUR_220      | 05:37                 | 05:44                 | 0:07      | LINE CLEAR AVAILED |
| 1231  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                           | RANEENNUR_220      | 11:13                 | 18:07                 | 6:54      | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name                          | Open_At               | Closed_At             | Duration  | REMARKS           |
|-------|-----------|----------|---------|-------------|-------------------------------------|---------------------------------------|-----------------------|-----------------------|-----------|-------------------|
| 1232  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220- HIREKERUR             | RANEENNUR_220                         | 11:08                 | 18:10                 | 7:02      | LINE CLEAR AVAIED |
| 1233  | 24-Sep-24 | BAGALKOT | 110     | LINE        | RANEENNUR220-AREMALLAPUR( HONNATTI) | RANEENNUR_220                         | 11:05                 | 18:10                 | 7:05      | LINE CLEAR AVAIED |
| 1234  | 24-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-NK2(HALIYAL)            | AMBEWADI_220                          | 10:43 (24.09.2024)    |                       |           | LINE CLEAR AVAIED |
| 1235  | 24-Sep-24 | BAGALKOT | 220     | LINE        | SHIGGOAN- HAVERI2                   | SHIGGOAN_220                          | 4:20                  | 4:22                  | 00:02     | LINE CLEAR AVAIED |
| 1236  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                | BIDNAL_220                            | 11:54                 | 13:32                 | 01:38     | LINE CLEAR AVAIED |
| 1237  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                | BIDNAL_220                            | 13:33                 | 14:07                 | 00:34     | LINE CLEAR AVAIED |
| 1238  | 24-Sep-24 | BAGALKOT | 110     | LINE        | GADAG-LAXMESHWAR2                   | GADAG_220                             | 9:57                  | 17:01                 | 07:04     | LINE CLEAR AVAIED |
| 1239  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F8 LOKAPUR1             | BAGALKOT_220                          | 04:34                 | 04:47                 | 00:13     | TRIPPED ON FAULT  |
| 1240  | 24-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS-F3(KANAGALA1)                 | AEQUS_220                             | 10:45                 | 12:22                 | 01:37     | LINE CLEAR AVAIED |
| 1241  | 24-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS-F4(KANAGALA2)                 | AEQUS_220                             | 12:26                 | 13:35                 | 01:09     | LINE CLEAR AVAIED |
| 1242  | 24-Sep-24 | BAGALKOT | 220     | LINE        | BIJAPUR- INDI1                      | BIJAPUR_220                           | 12:12                 | 12:47                 | 00:35     | LINE CLEAR AVAIED |
| 1243  | 24-Sep-24 | BAGALKOT | 220     | LINE        | BIJAPUR- INDI2                      | BIJAPUR_220                           | 12:54                 | 13:23                 | 00:29     | LINE CLEAR AVAIED |
| 1244  | 24-Sep-24 | BAGALKOT | 220     | LINE        | BIJAPUR- AHERI2                     | BIJAPUR_220                           | 16:17                 | 17:03                 | 00:46     | LINE CLEAR AVAIED |
| 1245  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BIJAPUR220-BAGEWADI(ENERCON)        | BIJAPUR_220                           | 09:25                 | 15:19                 | 05:54     | LINE CLEAR AVAIED |
| 1246  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BIJAPUR220- BIJAPUR CITY            | BIJAPUR_220                           | 09:11                 | 15:47                 | 06:36     | LINE CLEAR AVAIED |
| 1247  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                | BIJAPUR_220                           | 09:23                 | 15:18                 | 05:55     | LINE CLEAR AVAIED |
| 1248  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BIJAPUR220- KIADB1                  | BIJAPUR_220                           | 09:11                 | 15:44                 | 06:33     | LINE CLEAR AVAIED |
| 1249  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BIJAPUR220- KIADB1                  | BIJAPUR_220                           | 09:11                 | 15:44                 | 06:33     | LINE CLEAR AVAIED |
| 1250  | 24-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1                       | BIJAPUR_220                           | 09:39                 | 15:13                 | 05:34     | LINE CLEAR AVAIED |
| 1251  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV,LV1                       | BIJAPUR_220                           | 09:11                 | 15:10                 | 05:59     | LINE CLEAR AVAIED |
| 1252  | 24-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV2                       | BIJAPUR_220                           | 09:39                 | 15:13                 | 05:34     | LINE CLEAR AVAIED |
| 1253  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV,LV2                       | BIJAPUR_220                           | 09:12                 | 15:16                 | 06:04     | LINE CLEAR AVAIED |
| 1254  | 24-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV2(HV3)                  | BIJAPUR_220                           | 09:39                 | 15:17                 | 05:38     | LINE CLEAR AVAIED |
| 1255  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV,LV2(LV3)                  | BIJAPUR_220                           | 09:24                 | 15:17                 | 05:53     | LINE CLEAR AVAIED |
| 1256  | 24-Sep-24 | BAGALKOT | 220     | LINE        | INDI- BIJAPUR1                      | INDI_220                              | 12:11                 | 12:46                 | 00:35     | LINE CLEAR AVAIED |
| 1257  | 24-Sep-24 | BAGALKOT | 220     | LINE        | INDI- BIJAPUR2                      | INDI_220                              | 12:53                 | 13:19                 | 00:26     | LINE CLEAR AVAIED |
| 1258  | 24-Sep-24 | BAGALKOT | 220     | LINE        | KANAGALA- F1(AEQUS1)                | KANAGALA_220                          | 10:41                 | 12:20                 | 01:39     | LINE CLEAR AVAIED |
| 1259  | 24-Sep-24 | BAGALKOT | 220     | LINE        | KANAGALA- F2(AEQUS2)                | KANAGALA_220                          | 12:25                 | 13:35                 | 01:10     | LINE CLEAR AVAIED |
| 1260  | 24-Sep-24 | BAGALKOT | 400     | LINE        | DHONI- GUTTUR                       | DHONI_400                             | 10:28                 | 17:35                 | 07:07     | LINE CLEAR AVAIED |
| 1261  | 24-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                 | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAIED |
| 1262  | 24-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2           | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAIED |
| 1263  | 24-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                  | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAIED |
| 1264  | 24-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS               | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 1265  | 24-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                        | STATION NOT AFFECTED<br>HUDALI_110    | 11:05<br>(01.09.2024) | 16:06<br>(24.09.2024) | 557:01:00 | LINE CLEAR AVAIED |
| 1266  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BELLATTI-BAGEWADI                   | BELLATTI_110                          | 10:25                 | 18:20                 | 7:55      | LINE CLEAR AVAIED |
| 1267  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | HALIYAL(ATHANI)                       | 21:0<br>(24.09.2024)  |                       |           | TRIPPED ON FAULT  |
| 1268  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | HALIYAL(ATHANI)                       | 21:50                 | 22:35                 | 0:45      | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS            |
|-------|-----------|----------|---------|-------------|-----------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|--------------------|
| 1269  | 24-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-KANMBADI                | TAKKALAKI_110                            | 15:00                 | 17:25                 | 2:25      | LINE CLEAR AVAILED |
| 1270  | 24-Sep-24 | BAGALKOT | 220     | LINE        | RANEENNUR- GUTTUR                 | RANEENNUR_220                            | 05:36                 | 06:50                 | 1:14      | TRIPPED ON FAULT   |
| 1271  | 24-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-ALMEL-02(103)            | AHERI_220                                | 0:50                  | 1:05                  | 0:15      | TRIPPED ON FAULT   |
| 1272  | 24-Sep-24 | BAGALKOT | 220     | LINE        | AHERI-BIJAPUR1                    | AHERI_220                                | 12:37                 | 12:57                 | 0:20      | LINE CLEAR AVAILED |
| 1273  | 24-Sep-24 | BAGALKOT | 220     | LINE        | AHERI-BIJAPUR2                    | AHERI_220                                | 16:12                 | 16:54                 | 0:42      | LINE CLEAR AVAILED |
| 1274  | 24-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F7-RAMDURG            | BAGALKOT_220                             | 14:28                 | 14:34                 | 0:06      | TRIPPED ON FAULT   |
| 1275  | 24-Sep-24 | BAGALKOT | 220     | LINE        | HAVERI- SHIGGOAN2                 | HAVERI_220                               | 02:21                 | 04:22                 | 2:01      | TRIPPED ON FAULT   |
| 1276  | 24-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)               | MAHALINGAPUR_220                         | 07:40                 | 13:53                 | 06:13     | LINE CLEAR AVAILED |
| 1277  | 25-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR          | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAILED |
| 1278  | 25-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2               | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAILED |
| 1279  | 25-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                  | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAILED |
| 1280  | 25-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)          | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAILED |
| 1281  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                    | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1282  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BAGEWADI2            | STATION NOT AFFECTED<br>MAMADAPUR(B)_110 | 11:57<br>(16.09.2024) | 15:43<br>(25.09.2024) | 213:34:00 | LINE CLEAR AVAILED |
| 1283  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ISLAMPUR-F1(ANKALAGI)             | STATION NOT AFFECTED<br>ISLAMPUR_110     | 9:47<br>(17.09.2024)  | 11:00<br>(25.09.2027) | 193:13:00 | LINE CLEAR AVAILED |
| 1284  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)           | ANKOLA_110                               | 9:38<br>(22.09.2024)  |                       |           | LINE CLEAR AVAILED |
| 1285  | 25-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI              | SANKESHWARA_110                          | 11:26<br>(23.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1286  | 25-Sep-24 | BAGALKOT | 110     | LINE        | BABLESHWAR-<br>(MAMADAPUR)TIKOTA  | BABLESHWAR_110                           | 16:00<br>(24.09.2024) | 9:31<br>(25.09.2024)  | 17:31:00  | LINE CLEAR AVAILED |
| 1287  | 25-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                | KIRUVATTI_110                            | 12:45<br>(24.09.2024) |                       |           | LINE CLEAR AVAILED |
| 1288  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-NK2(HALIYAL)          | AMBEWADI_220                             | 10:43 (24.09.2024)    | 8:31<br>(25.09.2024)  | 21:48:00  | LINE CLEAR AVAILED |
| 1289  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)              | BABLESHWAR_110                           | 07:13                 | 07:34                 | 0:21      | LINE CLEAR AVAILED |
| 1290  | 25-Sep-24 | BAGALKOT | 110     | LINE        | BABLESHWAR- MAMADAPUR             | BABLESHWAR_110                           | 09:30                 | 16:20                 | 6:50      | LINE CLEAR AVAILED |
| 1291  | 25-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL- EILS                      | DAMBAL_110                               | 10:05                 | 17:56                 | 7:51      | LINE CLEAR AVAILED |
| 1292  | 25-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL- EILS(ASE SOLAR)           | DAMBAL_110                               | 10:07                 | 17:45                 | 7:38      | LINE CLEAR AVAILED |
| 1293  | 25-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL- SUZLON1(L3)               | DAMBAL_110                               | 10:05                 | 17:59                 | 7:54      | LINE CLEAR AVAILED |
| 1294  | 25-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL- SUZLON2(L2)               | DAMBAL_110                               | 10:05                 | 18:00                 | 7:55      | LINE CLEAR AVAILED |
| 1295  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)              | HALIYAL(ATH)_110                         | 09:57                 | 10:43                 | 0:46      | LINE CLEAR AVAILED |
| 1296  | 25-Sep-24 | BAGALKOT | 110     | LINE        | HAVERI220- BYADAGI                | HAVERI_220                               | 12:22                 | 14:28                 | 2:06      | LINE CLEAR AVAILED |
| 1297  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(10MVA)              | HIDIKAL DAM_110                          | 10:00                 | 10:04                 | 0:04      | TRIPPED ON FAULT   |
| 1298  | 25-Sep-24 | BAGALKOT | 110     | LINE        | HUKKERI- HATTARGI(AEQUUS)         | HUKKERI_110                              | 10:25                 | 10:57                 | 0:32      | LINE CLEAR AVAILED |
| 1299  | 25-Sep-24 | BAGALKOT | 110     | LINE        | HUKKERI- VS(VISHWANATH<br>SUGARS) | HUKKERI_110                              | 10:29                 | 10:48                 | 0:19      | LINE CLEAR AVAILED |
| 1300  | 25-Sep-24 | BAGALKOT | 110     | LINE        | HUKKERI- KOTWAGI LIS              | HUKKERI_110                              | 10:29                 | 10:53                 | 0:24      | LINE CLEAR AVAILED |
| 1301  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)              | INDI_220                                 | 09:15                 | 15:36                 | 6:21      | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name      | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------------------|-------------------|---------|-----------|----------|--------------------|
| 1302  | 25-Sep-24 | BAGALKOT | 110     | LINE        | INDI220- INDI                          | INDI_220          | 09:24   | 15:45     | 6:21     | LINE CLEAR AVAILED |
| 1303  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV4(20MVA,HV2)               | ZALKI_110         | 09:02   | 15:40     | 6:38     | LINE CLEAR AVAILED |
| 1304  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(10MVA,HV1)               | ZALKI_110         | 09:02   | 15:40     | 6:38     | LINE CLEAR AVAILED |
| 1305  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                   | YARAGATTI_110     | 09:47   | 09:48     | 0:01     | LINE CLEAR AVAILED |
| 1306  | 25-Sep-24 | BAGALKOT | 110     | LINE        | YARAGATTI-KATAKOL                      | YARAGATTI_110     | 09:47   | 09:57     | 0:10     | TRIPPED ON FAULT   |
| 1307  | 25-Sep-24 | BAGALKOT | 110     | LINE        | UKLI-B BAGEWADI(F2)                    | UKLI_110          | 09:00   | 14:33     | 5:33     | LINE CLEAR AVAILED |
| 1308  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                   | UKLI_110          | 09:02   | 14:36     | 5:34     | LINE CLEAR AVAILED |
| 1309  | 25-Sep-24 | BAGALKOT | 110     | LINE        | SAMBAPUR-DAMBAL                        | SAMBAPUR_110      | 10:14   | 15:16     | 5:02     | LINE CLEAR AVAILED |
| 1310  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                   | NAVANAGAR (B)_110 | 09:49   | 13:18     | 3:29     | LINE CLEAR AVAILED |
| 1311  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MUNDARAGI-VIJAY SUGARS                 | MUNDARAGI_110     | 10:28   | 17:53     | 7:25     | LINE CLEAR AVAILED |
| 1312  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MUNDARAGI-DAMBAL                       | MUNDARAGI_110     | 10:28   | 17:50     | 7:22     | LINE CLEAR AVAILED |
| 1313  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MUDEDEBIHAL-KM SOLAR                   | MUDEDEBIHAL_110   | 10:03   | 17:39     | 7:36     | LINE CLEAR AVAILED |
| 1314  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                   | MUDEDEBIHAL_110   | 17:39   | 17:44     | 0:05     | LINE CLEAR AVAILED |
| 1315  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                   | MATTIHAL_110      | 10:25   | 15:55     | 5:30     | LINE CLEAR AVAILED |
| 1316  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                   | MANTUR_110        | 02:03   | 02:14     | 0:11     | TRIPPED ON FAULT   |
| 1317  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-<br>BABELESHWARA          | MAMADAPUR(B)_110  | 09:31   | 16:01     | 6:30     | LINE CLEAR AVAILED |
| 1318  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-BELGAUM<br>SOLAR          | MAMADAPUR(B)_110  | 09:31   | 14:22     | 4:51     | LINE CLEAR AVAILED |
| 1319  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)-SHIRBUR                   | MAMADAPUR(B)_110  | 09:32   | 16:01     | 6:29     | LINE CLEAR AVAILED |
| 1320  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)_TODALBAGI                 | MAMADAPUR(B)_110  | 09:32   | 15:55     | 6:23     | LINE CLEAR AVAILED |
| 1321  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR(B)_B BAGEWADI1               | MAMADAPUR(B)_110  | 09:32   | 15:57     | 6:25     | LINE CLEAR AVAILED |
| 1322  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                   | MAMADAPUR(B)_110  | 09:31   | 15:56     | 6:25     | LINE CLEAR AVAILED |
| 1323  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)                   | MAMADAPUR(B)_110  | 18:32   | 18:41     | 0:09     | TRIPPED ON FAULT   |
| 1324  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                   | MAMADAPUR(B)_110  | 09:31   | 14:41     | 5:10     | LINE CLEAR AVAILED |
| 1325  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                   | MAMADAPUR(B)_110  | 09:32   | 16:02     | 6:30     | LINE CLEAR AVAILED |
| 1326  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(20MVA)                   | MAMADAPUR(B)_110  | 16:15   | 16:22     | 0:07     | LINE CLEAR AVAILED |
| 1327  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(20MVA)                   | MALGHAN(B)_110    | 10:11   | 18:16     | 8:05     | LINE CLEAR AVAILED |
| 1328  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                   | MALGHAN(B)_110    | 10:13   | 15:49     | 5:36     | LINE CLEAR AVAILED |
| 1329  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-MAMADAPUR<br>(MATTYAL)      | MALGHAN(B)_110    | 10:16   | 15:54     | 5:38     | LINE CLEAR AVAILED |
| 1330  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-BAGEWADI                    | MALGHAN(B)_110    | 10:16   | 15:36     | 5:20     | LINE CLEAR AVAILED |
| 1331  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-BASAVA SUGARS               | MALGHAN(B)_110    | 10:20   | 15:38     | 5:18     | LINE CLEAR AVAILED |
| 1332  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN(B)-BAGEWADI<br>(RAILWAY TRACK) | MALGHAN(B)_110    | 10:21   | 15:38     | 5:17     | LINE CLEAR AVAILED |
| 1333  | 25-Sep-24 | BAGALKOT | 110     | LINE        | KAMBAGI-MAMADAPUR(F1)                  | KAMBAGI_110       | 08:29   | 13:13     | 4:44     | LINE CLEAR AVAILED |
| 1334  | 25-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220-SHIRHATTI                     | GADAG_220         | 10:10   | 16:39     | 6:29     | LINE CLEAR AVAILED |
| 1335  | 25-Sep-24 | BAGALKOT | 110     | LINE        | GADAG220-DAMBAL2(DAMBAL)               | GADAG_220         | 10:21   | 15:18     | 4:57     | LINE CLEAR AVAILED |
| 1336  | 25-Sep-24 | BAGALKOT | 220     | LINE        | GADAG220-LINGAPUR1(DHONI1)             | GADAG_220         | 12:01   | 17:16     | 5:15     | LINE CLEAR AVAILED |
| 1337  | 25-Sep-24 | BAGALKOT | 220     | LINE        | DHONI- GADAG1                          | DHONI_400         | 12:01   | 17:16     | 5:15     | LINE CLEAR AVAILED |
| 1338  | 25-Sep-24 | BAGALKOT | 110     | LINE        | BAGAKOT220-F2-BAGALKOT-2               | BAGAKOT_220       | 11:22   | 11:28     | 0:06     | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                            | Station_Name                          | Open_At               | Closed_At            | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|---------------------------------|---------------------------------------|-----------------------|----------------------|----------|--------------------|
| 1339  | 25-Sep-24 | BAGALKOT | 110     | LINE        | BAGAKOT220-F6-KERUR             | BAGAKOT_220                           | 13:25                 | 13:31                | 0:06     | LINE CLEAR AVAILED |
| 1340  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV1                  | AHERI_220                             | 15:06                 | 15:49                | 0:43     | LINE CLEAR AVAILED |
| 1341  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2                  | AHERI_220                             | 15:54                 | 17:08                | 1:14     | LINE CLEAR AVAILED |
| 1342  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN7(MALAGHAN)          | AHERI_220                             | 15:10                 | 15:52                | 0:42     | LINE CLEAR AVAILED |
| 1343  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN5(DEVAR HIPPARAGI)   | AHERI_220                             | 15:10                 | 15:50                | 0:40     | LINE CLEAR AVAILED |
| 1344  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                  | AHERI_220                             | 15:06                 | 15:48                | 0:42     | LINE CLEAR AVAILED |
| 1345  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                  | AHERI_220                             | 15:55                 | 17:07                | 1:12     | LINE CLEAR AVAILED |
| 1346  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN6(MORATAGI)          | AHERI_220                             | 15:56                 | 16:58                | 1:02     | LINE CLEAR AVAILED |
| 1347  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | AHERI_220                             | 15:18                 | 16:16                | 0:58     | LINE CLEAR AVAILED |
| 1348  | 25-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220-SIRSI(KALGHATAGI)      | HUBLI_220                             | 08:26                 | 11:50                | 3:24     | TRIPPED ON FAULT   |
| 1349  | 25-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI220-KOLAHPUR(TALANDAGE) | STATION NOT AFFECTED<br>CHIKKODI_220  | 13:45<br>(25.09.2024) |                      |          | TRIPPED ON FAULT   |
| 1350  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2(100MVA)          | CHIKKODI_220                          | 10:30                 | 15:13                | 4:43     | LINE CLEAR AVAILED |
| 1351  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2(100MVA)          | CHIKKODI_220                          | 10:28                 | 15:11                | 4:43     | LINE CLEAR AVAILED |
| 1352  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)             | KUDUCHI_220                           | 12:50                 | 13:15                | 0:25     | LINE CLEAR AVAILED |
| 1353  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1             | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                      |          | LINE CLEAR AVAILED |
| 1354  | 25-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2       | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                      |          | LINE CLEAR AVAILED |
| 1355  | 25-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2              | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |                      |          | LINE CLEAR AVAILED |
| 1356  | 25-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS           | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |                      |          | LINE CLEAR AVAILED |
| 1357  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | HALIYAL(ATHANI)                       | 21:00<br>(24.09.2024) | 9:31<br>(25.09.2024) | 12:31    | TRIPPED ON FAULT   |
| 1358  | 25-Sep-24 | BAGALKOT | 110     | LINE        | DAMBAL- GADAG                   | DAMBAL_110                            | 10:21                 | 15:18                | 4:57     | LINE CLEAR AVAILED |
| 1359  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(20MVA)            | MATTIHAL_110                          | 10:25                 | 15:55                | 5:30     | LINE CLEAR AVAILED |
| 1360  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV3(10MVA)            | MATTIHAL_110                          | 10:25                 | 15:55                | 5:30     | LINE CLEAR AVAILED |
| 1361  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MATTIHAL-B BAGEWADI             | MATTIHAL_110                          | 10:25                 | 15:55                | 5:30     | LINE CLEAR AVAILED |
| 1362  | 25-Sep-24 | BAGALKOT | 110     | LINE        | BAGAKOT220-F1-BAGALKOT-1        | BAGAKOT_220                           | 11:00                 | 17:05                | 6:05     | LINE CLEAR AVAILED |
| 1363  | 25-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)             | BAGAKOT_220                           | 12:20                 | 13:34                | 1:14     | TRIPPED ON FAULT   |
| 1364  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-CHANDAKAVATE           | AHERI_220                             | 04:22                 | 04:32                | 0:10     | TRIPPED ON FAULT   |
| 1365  | 25-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-ALMEL--1               | AHERI_220                             | 15:10                 | 15:50                | 0:40     | LINE CLEAR AVAILED |
| 1366  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV3                  | SOUNDATTI_220                         | 11:47                 | 14:24                | 2:37     | LINE CLEAR AVAILED |
| 1367  | 25-Sep-24 | BAGALKOT | 110     | LINE        | SOUNDATTI220-BENAKATTI          | SOUNDATTI_220                         | 09:17                 | 09:42                | 0:25     | TRIPPED ON FAULT   |
| 1368  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV3                  | SOUNDATTI_220                         | 11:47                 | 14:24                | 2:37     | LINE CLEAR AVAILED |
| 1369  | 25-Sep-24 | BAGALKOT | 110     | LINE        | SOUNDATTI220-BENAKATTI          | SOUNDATTI_220                         | 09:17                 | 09:42                | 0:25     | TRIPPED ON FAULT   |
| 1370  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MUGALAKHOD220-KULIGOD           | MUGALAKHOD_220                        | 02:04                 | 02:15                | 0:11     | TRIPPED ON FAULT   |
| 1371  | 25-Sep-24 | BAGALKOT | 110     | LINE        | MUGALAKHOD220-KULIGOD           | MUGALAKHOD_220                        | 03:42                 | 04:02                | 0:20     | TRIPPED ON FAULT   |
| 1372  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-BALIGERI              | ATHANI_220                            | 10:26                 | 19:41                | 9:15     | LINE CLEAR AVAILED |
| 1373  | 25-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV,HV1,LV1               | ATHANI_220                            | 12:03                 | 15:02                | 2:59     | LINE CLEAR AVAILED |
| 1374  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-BALIGERI              | ATHANI_220                            | 23:34                 | 23:48                | 0:14     | TRIPPED ON FAULT   |
| 1375  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-ATHANI 2              | ATHANI_220                            | 23:34                 | 23:50                | 0:16     | TRIPPED ON FAULT   |
| 1376  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-AIGALI1               | ATHANI_220                            | 23:34                 | 23:59                | 0:25     | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name                             | Open_At               | Closed_At             | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-------------------------------------|------------------------------------------|-----------------------|-----------------------|----------|-------------------|
| 1377  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-AIGALI2                   | ATHANI_220                               | 23:34                 | 23:49                 | 0:15     | TRIPPED ON FAULT  |
| 1378  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220- KARIMASUTI               | ATHANI_220                               | 23:34                 | 23:51                 | 0:17     | TRIPPED ON FAULT  |
| 1379  | 25-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-GHATANATTI                | ATHANI_220                               | 23:34                 | 23:50                 | 0:16     | TRIPPED ON FAULT  |
| 1380  | 26-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR            | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |          | LINE CLEAR AVAIED |
| 1381  | 26-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                 | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |          | LINE CLEAR AVAIED |
| 1382  | 26-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                    | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |          | LINE CLEAR AVAIED |
| 1383  | 26-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)            | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |          | LINE CLEAR AVAIED |
| 1384  | 26-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                      | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |                       |          | LINE CLEAR AVAIED |
| 1385  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)             | STATION NOT AFFECTED<br>ANKOLA_110       | 9:38<br>(22.09.2024)  |                       |          | LINE CLEAR AVAIED |
| 1386  | 26-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI                | STATION NOT AFFECTED<br>SANKESHWARA_110  | 11:26<br>(23.09.2024) |                       |          | LINE CLEAR AVAIED |
| 1387  | 26-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                  | STATION NOT AFFECTED<br>KIRUVATTI_110    | 12:45<br>(24.09.2024) |                       |          | LINE CLEAR AVAIED |
| 1388  | 26-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI220-<br>KOLAHPUR(TALANDAGE) | STATION NOT AFFECTED<br>CHIKKODI_220     | 13:45 (25.09.2024)    | 17:17<br>(26.09.2024) | 27:32:00 | TRIPPED ON FAULT  |
| 1389  | 26-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN3(CHANDKAVATE)           | AHERI_220                                | 09:10                 | 18:15                 | 09:05    | LINE CLEAR AVAIED |
| 1390  | 26-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN7(MALAGHAN)              | AHERI_220                                | 09:33                 | 17:06                 | 07:33    | LINE CLEAR AVAIED |
| 1391  | 26-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-LN6(MORATAGI)              | AHERI_220                                | 09:46                 | 14:34                 | 04:48    | LINE CLEAR AVAIED |
| 1392  | 26-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220- F8-LOKAPUR             | BAGALKOT_220                             | 12:03                 | 13:37                 | 01:34    | LINE CLEAR AVAIED |
| 1393  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- HIREKERUR            | RANEBENNUR_220                           | 20:31                 | 20:37                 | 00:06    | TRIPPED ON FAULT  |
| 1394  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- HIREKERUR            | RANEBENNUR_220                           | 22:02                 | 22:12                 | 00:10    | TRIPPED ON FAULT  |
| 1395  | 26-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI-KUDUGI2(KUDAGI1)         | VAJRAMATTI_220                           | 10:23                 | 13:07                 | 02:44    | LINE CLEAR AVAIED |
| 1396  | 26-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI-MAHALINGAPUR2            | VAJRAMATTI_220                           | 10:43                 | 13:01                 | 02:18    | LINE CLEAR AVAIED |
| 1397  | 26-Sep-24 | BAGALKOT | 220     | LINE        | MAHALINGAPUR- VAJRAMATTI2           | MAHALINGAPUR_220                         | 10:42                 | 13:01                 | 02:19    | LINE CLEAR AVAIED |
| 1398  | 26-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                      | BIDNAL_220                               | 11:15                 | 14:26                 | 03:11    | LINE CLEAR AVAIED |
| 1399  | 26-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                      | CHIKKODI_220                             | 14:08                 | 14:36                 | 00:28    | LINE CLEAR AVAIED |
| 1400  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (20MVA)               | ANKALAGI_110                             | 15:01                 | 15:59                 | 00:58    | LINE CLEAR AVAIED |
| 1401  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)               | ANKOLA_110                               | 02:27                 | 02:33                 | 00:06    | TRIPPED ON FAULT  |
| 1402  | 26-Sep-24 | BAGALKOT | 110     | LINE        | LAKSHMESHWAR-GADAG1                 | LAKSHMESHWAR_110                         | 09:03                 | 19:17                 | 10:14    | LINE CLEAR AVAIED |
| 1403  | 26-Sep-24 | BAGALKOT | 110     | LINE        | YELLAMMANAWADI-ALBHAL(F3)           | YELLAMMANAWADI_110                       | 05:31                 | 06:59                 | 01:28    | TRIPPED ON FAULT  |
| 1404  | 26-Sep-24 | BAGALKOT | 110     | LINE        | TUMMINKATTI-RATTIHALLI(F2)          | TUMMINKATTI_110                          | 10:21                 | 18:02                 | 07:41    | LINE CLEAR AVAIED |
| 1405  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAJENDRAGADA1                   | RON_110                                  | 10:16                 | 16:36                 | 06:20    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name                          | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|----------------------------------------|---------------------------------------|-----------------------|-----------|----------|-------------------|
| 1406  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAJENDRAGADA2                      | RON_110                               | 10:16                 | 16:36     | 06:20    | LINE CLEAR AVAIED |
| 1407  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                    | RATTIHALLI_110                        | 10:14                 | 17:41     | 07:27    | LINE CLEAR AVAIED |
| 1408  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                    | RATTIHALLI_110                        | 10:14                 | 18:06     | 07:52    | LINE CLEAR AVAIED |
| 1409  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                    | RATTIHALLI_110                        | 10:14                 | 18:07     | 07:53    | LINE CLEAR AVAIED |
| 1410  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RATTIHALLI-RANEENNUR<br>(TUMMINAKATTI) | RATTIHALLI_110                        | 10:25                 | 17:41     | 07:16    | LINE CLEAR AVAIED |
| 1411  | 26-Sep-24 | BAGALKOT | 110     | LINE        | RAIBHAG-CHIKKODI1                      | RAIBHAG_110                           | 10:58                 | 15:41     | 04:43    | LINE CLEAR AVAIED |
| 1412  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                    | NIDAGUNDI_110                         | 10:10                 | 15:20     | 05:10    | LINE CLEAR AVAIED |
| 1413  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | DADDI_110                             | 15:57                 | 16:58     | 01:01    | LINE CLEAR AVAIED |
| 1414  | 26-Sep-24 | BAGALKOT | 110     | LINE        | DEVANGOAN-F2(GATTARAGI)                | DEVANGOAN_110                         | 10:50                 | 17:59     | 07:09    | LINE CLEAR AVAIED |
| 1415  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | GADAGROAD_110                         | 11:17                 | 12:32     | 01:15    | LINE CLEAR AVAIED |
| 1416  | 26-Sep-24 | BAGALKOT | 110     | LINE        | GAJENDRAGAD-RON1                       | GAJENDRAGAD_110                       | 10:09                 | 16:36     | 06:27    | LINE CLEAR AVAIED |
| 1417  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA-HV2)              | MACHE_110                             | 06:40                 | 07:16     | 00:36    | LINE CLEAR AVAIED |
| 1418  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV3 (10MVA)                  | LOKAPUR_110                           | 10:35                 | 17:50     | 07:15    | LINE CLEAR AVAIED |
| 1419  | 26-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                    | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |
| 1420  | 26-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2              | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAIED |
| 1421  | 26-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                     | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAIED |
| 1422  | 26-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                  | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAIED |
| 1423  | 26-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-ALMEL-02(103)                 | AHERI_220                             | 00:05                 | 00:15     | 00:10    | TRIPPED ON FAULT  |
| 1424  | 26-Sep-24 | BAGALKOT | 110     | LINE        | CHIKKODI220- RAIBAG                    | CHIKKODI_220                          | 11:10                 | 15:50     | 04:40    | LINE CLEAR AVAIED |
| 1425  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                   | RANEENNUR_220                         | 12:50                 | 13:15     | 00:25    | LINE CLEAR AVAIED |
| 1426  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                   | RANEENNUR_220                         | 12:05                 | 13:40     | 01:35    | LINE CLEAR AVAIED |
| 1427  | 26-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-SHIRAGUPPI                  | KUDACHI_220                           | 00:45                 | 01:00     | 00:15    | TRIPPED ON FAULT  |
| 1428  | 26-Sep-24 | BAGALKOT | 110     | LINE        | KUDACHI220-SHIRAGUPPI                  | KUDACHI_220                           | 00:45                 | 01:00     | 00:15    | TRIPPED ON FAULT  |
| 1429  | 26-Sep-24 | BAGALKOT | 110     | LINE        | ATHANI220-AIGALI1                      | ATHANI_220                            | 23:59                 | 00:10     | 00:10    | TRIPPED ON FAULT  |
| 1430  | 26-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2                         | SOUNDATTI_220                         | 09:50                 | 14:12     | 04:22    | LINE CLEAR AVAIED |
| 1431  | 26-Sep-24 | BAGALKOT | 110     | LINE        | SALAHALLI-GMNVN                        | SALAHALLI_110                         | 09:50                 | 17:06     | 07:16    | LINE CLEAR AVAIED |
| 1432  | 26-Sep-24 | BAGALKOT | 110     | LINE        | SALAHALLI-LOKAPUR                      | SALAHALLI_110                         | 10:00                 | 16:25     | 06:25    | LINE CLEAR AVAIED |
| 1433  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                    | SALAHALLI_110                         | 10:00                 | 16:40     | 06:40    | LINE CLEAR AVAIED |
| 1434  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                    | SALAHALLI_110                         | 10:00                 | 16:45     | 06:45    | LINE CLEAR AVAIED |
| 1435  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(10MVA)                    | SALAHALLI_110                         | 10:00                 | 16:50     | 06:50    | LINE CLEAR AVAIED |
| 1436  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                    | NIDAGUNDI_110                         | 10:10                 | 15:30     | 05:20    | LINE CLEAR AVAIED |
| 1437  | 26-Sep-24 | BAGALKOT | 110     | LINE        | NIDAGUNDI-B BAGEWADI                   | NIDAGUNDI_110                         | 10:10                 | 15:30     | 05:20    | LINE CLEAR AVAIED |
| 1438  | 26-Sep-24 | BAGALKOT | 110     | LINE        | NIDAGUNDI-RAMPUR                       | NIDAGUNDI_110                         | 10:10                 | 15:30     | 05:20    | LINE CLEAR AVAIED |
| 1439  | 26-Sep-24 | BAGALKOT | 110     | LINE        | NIDAGUNDI-ALBC(JAQUEL)                 | NIDAGUNDI_110                         | 10:10                 | 15:30     | 05:20    | LINE CLEAR AVAIED |
| 1440  | 26-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-MANALI SUGARS                  | MALGHAN(S)_110                        | 07:07                 | 17:10     | 10:03    | LINE CLEAR AVAIED |
| 1441  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | MALGHAN(S)_110                        | 07:07                 | 17:10     | 10:03    | LINE CLEAR AVAIED |
| 1442  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                  | MALGHAN(S)_110                        | 07:07                 | 17:10     | 10:03    | LINE CLEAR AVAIED |
| 1443  | 26-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-MORATAGI                       | MALGHAN(S)_110                        | 07:07                 | 17:10     | 10:03    | LINE CLEAR AVAIED |
| 1444  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV1 (10MVA)                  | LOKAPUR_110                           | 11:00                 | 17:50     | 06:50    | LINE CLEAR AVAIED |
| 1445  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV2 (10MVA)                  | LOKAPUR_110                           | 11:00                 | 17:50     | 06:50    | LINE CLEAR AVAIED |
| 1446  | 26-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV, HV24(20MVA)                  | LOKAPUR_110                           | 11:00                 | 17:50     | 06:50    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-------------------------------------|------------------------------------------|-----------------------|-----------|----------|-------------------|
| 1447  | 27-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR            | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAIED |
| 1448  | 27-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                 | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAIED |
| 1449  | 27-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                    | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAIED |
| 1450  | 27-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)            | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAIED |
| 1451  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                      | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAIED |
| 1452  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)             | STATION NOT AFFECTED<br>ANKOLA_110       | 9:38<br>(22.09.2024)  |           |          | LINE CLEAR AVAIED |
| 1453  | 27-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI                | STATION NOT AFFECTED<br>SANKESHWARA_110  | 11:26<br>(23.09.2024) |           |          | LINE CLEAR AVAIED |
| 1454  | 27-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                  | STATION NOT AFFECTED<br>KIRUVATTI_110    | 12:45<br>(24.09.2024) |           |          | LINE CLEAR AVAIED |
| 1455  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | ANAND NAGAR_110                          | 13:11                 | 15:20     | 2:09     | LINE CLEAR AVAIED |
| 1456  | 27-Sep-24 | BAGALKOT | 110     | LINE        | THORVI-TIKOTA                       | THORVI_110                               | 09:05                 | 16:04     | 6:59     | LINE CLEAR AVAIED |
| 1457  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(20MVA-HV2)             | BELGAUM_110                              | 10:05                 | 14:21     | 4:16     | LINE CLEAR AVAIED |
| 1458  | 27-Sep-24 | BAGALKOT | 110     | LINE        | GADAG ROAD-<br>BIDNAL(GOPPANAKOPPA) | GADAG ROAD_110                           | 10:59                 | 15:02     | 4:03     | LINE CLEAR AVAIED |
| 1459  | 27-Sep-24 | BAGALKOT | 110     | LINE        | HUDALI-BSPL2                        | HUDALI_110                               | 12:10                 | 12:20     | 0:10     | LINE CLEAR AVAIED |
| 1460  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                 | KALADAGI_110                             | 19:14                 | 19:20     | 0:06     | TRIPPED ON FAULT  |
| 1461  | 27-Sep-24 | BAGALKOT | 110     | LINE        | KAMBAGI-F2(TODALBAGI)               | KAMBAGI_110                              | 10:44                 | 18:34     | 7:50     | LINE CLEAR AVAIED |
| 1462  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MALGHAN-<br>MAMADAPUR(MATTIHAL)     | MALGHAN(B)_110                           | 04:04                 | 04:24     | 0:20     | TRIPPED ON FAULT  |
| 1463  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MAMADAPUR-BAGEWADI1                 | MAMADAPUR_110                            | 04:05                 | 04:19     | 0:14     | TRIPPED ON FAULT  |
| 1464  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MK HUBLI-MACHE(MK HUBLI 2)          | MK HUBLI_110                             | 11:32                 | 18:55     | 7:23     | LINE CLEAR AVAIED |
| 1465  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MRUTHYUMJAYANAGR-<br>GOPPANAKOPPA   | MRUTHYUMJAYANAGR_110                     | 10:33                 | 15:02     | 4:29     | LINE CLEAR AVAIED |
| 1466  | 27-Sep-24 | BAGALKOT | 110     | LINE        | TODALABAGI-JAMAKHANDI               | TODALABAGI_110                           | 10:40                 | 18:27     | 7:47     | LINE CLEAR AVAIED |
| 1467  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(10MVA)                 | TODALABAGI_110                           | 10:10                 | 18:41     | 8:31     | LINE CLEAR AVAIED |
| 1468  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                 | TAKKALAKI_110                            | 09:12                 | 16:12     | 7:00     | LINE CLEAR AVAIED |
| 1469  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | TAKKALAKI_110                            | 09:12                 | 16:12     | 7:00     | LINE CLEAR AVAIED |
| 1470  | 27-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-WARDHA                    | TAKKALAKI_110                            | 09:12                 | 15:46     | 6:34     | LINE CLEAR AVAIED |
| 1471  | 27-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-KN BIJAPUR SOLAR          | TAKKALAKI_110                            | 09:12                 | 15:46     | 6:34     | LINE CLEAR AVAIED |
| 1472  | 27-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-TIKOTA                    | TAKKALAKI_110                            | 09:04                 | 16:06     | 7:02     | LINE CLEAR AVAIED |
| 1473  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                 | RATTIHALI_110                            | 15:20                 | 15:31     | 0:11     | LINE CLEAR AVAIED |
| 1474  | 27-Sep-24 | BAGALKOT | 110     | LINE        | RAMANAKOPPA-SRS HUBLI               | RAMANAKOPPA_110                          | 10:00                 | 17:58     | 7:58     | LINE CLEAR AVAIED |
| 1475  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                 | PG HUNSYAL_110                           | 16:00                 | 17:05     | 1:05     | LINE CLEAR AVAIED |
| 1476  | 27-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - GADAG1                   | BAGALKOT_220                             | 12:25                 | 15:47     | 03:22    | LINE CLEAR AVAIED |
| 1477  | 27-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - GADAG2                   | BAGALKOT_220                             | 12:26                 | 15:47     | 03:21    | LINE CLEAR AVAIED |
| 1478  | 27-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL- NAGJHARI2                   | BIDNAL_220                               | 16:04                 | 16:39     | 00:35    | LINE CLEAR AVAIED |
| 1479  | 27-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV3                      | MAHALINGAPUR_220                         | 12:02                 | 13:10     | 01:08    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                   | Station_Name                             | Open_At               | Closed_At | Duration | REMARKS            |
|-------|-----------|----------|---------|-------------|----------------------------------------|------------------------------------------|-----------------------|-----------|----------|--------------------|
| 1480  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- HIDIKAL                  | MAHALINGAPUR_220                         | 12:00                 | 13:17     | 01:17    | LINE CLEAR AVAILED |
| 1481  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- TERDAL                   | MAHALINGAPUR_220                         | 12:02                 | 13:13     | 01:11    | LINE CLEAR AVAILED |
| 1482  | 27-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV, HV4(10MVA)                   | BAGALKOT_220                             | 04:00                 | 04:05     | 00:05    | TRIPPED ON FAULT   |
| 1483  | 27-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220- RAMANKOPPA                   | HUBLI_220                                | 01:24                 | 17:44     | 16:20    | TRIPPED ON FAULT   |
| 1484  | 27-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- HIREKERUR               | RANEBENNUR_220                           | 04:41                 | 04:44     | 00:03    | LINE CLEAR AVAILED |
| 1485  | 27-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- AREMALLAPUR(HONNATTI)   | RANEBENNUR_220                           | 04:41                 | 04:44     | 00:03    | LINE CLEAR AVAILED |
| 1486  | 27-Sep-24 | BAGALKOT | 110     | LINE        | RANEBENNUR220- RATTIHALLI(TUMMINKATTI) | RANEBENNUR_220                           | 4:40                  | 4:45      | 00:05    | LINE CLEAR AVAILED |
| 1487  | 27-Sep-24 | BAGALKOT | 220     | LINE        | GADAG- BAGALKOT1                       | GADAG_220                                | 12:25                 | 15:44     | 03:19    | LINE CLEAR AVAILED |
| 1488  | 27-Sep-24 | BAGALKOT | 220     | LINE        | GADAG- BAGALKOT2                       | GADAG_220                                | 12:26                 | 15:45     | 03:19    | LINE CLEAR AVAILED |
| 1489  | 27-Sep-24 | BAGALKOT | 220     | LINE        | MKHUBLI- NARENDRA1                     | MKHUBLI_220                              | 12:39                 | 15:50     | 03:11    | LINE CLEAR AVAILED |
| 1490  | 27-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                         | MKHUBLI_220                              | 10:49                 | 14:50     | 04:01    | LINE CLEAR AVAILED |
| 1491  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- BIDI                       | MKHUBLI_220                              | 12:48                 | 14:27     | 01:39    | LINE CLEAR AVAILED |
| 1492  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- KHANAPUR                   | MKHUBLI_220                              | 12:51                 | 14:25     | 01:34    | LINE CLEAR AVAILED |
| 1493  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- HIREBAGEWADI               | MKHUBLI_220                              | 12:52                 | 17:14     | 04:22    | LINE CLEAR AVAILED |
| 1494  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- KITTUR(MK HBULI1)          | MKHUBLI_220                              | 12:52                 | 14:27     | 01:35    | LINE CLEAR AVAILED |
| 1495  | 27-Sep-24 | BAGALKOT | 110     | LINE        | HAVERI220- TILUVALLI(HANGAL)           | HAVERI_220                               | 7:10                  | 7:17      | 00:07    | TRIPPED ON FAULT   |
| 1496  | 27-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                    | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAILED |
| 1497  | 27-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2              | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |           |          | LINE CLEAR AVAILED |
| 1498  | 27-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                     | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |           |          | LINE CLEAR AVAILED |
| 1499  | 27-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                  | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |           |          | LINE CLEAR AVAILED |
| 1500  | 27-Sep-24 | BAGALKOT | 110     | LINE        | TAKKALAKI-KANAMADI                     | TAKKALAKI_110                            | 09:04                 | 16:06     | 7:02     | LINE CLEAR AVAILED |
| 1501  | 27-Sep-24 | BAGALKOT | 220     | LINE        | RANEBENNUR- GUTTUR                     | RANEBENNUR_220                           | 04:40                 | 07:27     | 02:47    | TRIPPED ON FAULT   |
| 1502  | 28-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR               | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |           |          | LINE CLEAR AVAILED |
| 1503  | 28-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                    | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |           |          | LINE CLEAR AVAILED |
| 1504  | 28-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2                      | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |           |          | LINE CLEAR AVAILED |
| 1505  | 28-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)               | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |           |          | LINE CLEAR AVAILED |
| 1506  | 28-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                         | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) |           |          | LINE CLEAR AVAILED |
| 1507  | 28-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)                | STATION NOT AFFECTED<br>ANKOLA_110       | 9:38<br>(22.09.2024)  |           |          | LINE CLEAR AVAILED |
| 1508  | 28-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI                   | STATION NOT AFFECTED<br>SANKESHWARA_110  | 11:26<br>(23.09.2024) |           |          | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                          | Station_Name                             | Open_At               | Closed_At             | Duration  | REMARKS           |
|-------|-----------|----------|---------|-------------|-------------------------------|------------------------------------------|-----------------------|-----------------------|-----------|-------------------|
| 1509  | 28-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI            | STATION NOT AFFECTED<br>KIRUVATTI_110    | 12:45<br>(24.09.2024) |                       |           | LINE CLEAR AVAIED |
| 1510  | 28-Sep-24 | BAGALKOT | 110     | LINE        | JAMBAGI-VAJRAMATTI            | JAMBAGI_110                              | 13:41                 | 18:33                 | 4:52      | LINE CLEAR AVAIED |
| 1511  | 28-Sep-24 | BAGALKOT | 110     | LINE        | JAMBAGI-MUDHOL(HALKI)         | JAMBAGI_110                              | 10:00                 | 13:41                 | 3:41      | LINE CLEAR AVAIED |
| 1512  | 28-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(20MVA,HV2)       | MUDHOL_110                               | 10:20                 | 18:34                 | 8:14      | LINE CLEAR AVAIED |
| 1513  | 28-Sep-24 | BAGALKOT | 110     | LINE        | VAJRAMATTI-<br>MANTUR(MUDHOL) | VAJRAMATTI_220                           | 11:39                 | 13:33                 | 01:54     | LINE CLEAR AVAIED |
| 1514  | 28-Sep-24 | BAGALKOT | 110     | LINE        | MUGALKHOD220-LN10(KULIGOD)    | MUGALKHOD_220                            | 19:15                 | 19:30                 | 00:15     | TRIPPED ON FAULT  |
| 1515  | 28-Sep-24 | BAGALKOT | 220     | LINE        | GADAG- HARTI2                 | GADAG_220                                | 11:11                 | 18:53                 | 07:42     | LINE CLEAR AVAIED |
| 1516  | 28-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- TERDAL          | MAHALINGAPUR_220                         | 10:18                 | 17:48                 | 07:30     | LINE CLEAR AVAIED |
| 1517  | 28-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR- HIDIKAL         | MAHALINGAPUR_220                         | 16:09                 | 17:47                 | 01:38     | LINE CLEAR AVAIED |
| 1518  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-2            | AMBEWADI_220                             | 01:00                 | 01:20                 | 00:20     | TRIPPED ON FAULT  |
| 1519  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-2            | AMBEWADI_220                             | 01:35                 | 02:03                 | 00:28     | TRIPPED ON FAULT  |
| 1520  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-1            | AMBEWADI_220                             | 02:02                 | 04:15                 | 02:13     | LINE CLEAR AVAIED |
| 1521  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-2            | AMBEWADI_220                             | 11:08                 | 14:15                 | 03:07     | LINE CLEAR AVAIED |
| 1522  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-1            | AMBEWADI_220                             | 11:52                 | 14:14                 | 02:22     | LINE CLEAR AVAIED |
| 1523  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI220-SUPA-1            | AMBEWADI_220                             | 14:33                 | 18:47                 | 04:14     | TRIPPED ON FAULT  |
| 1524  | 28-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1           | STATION NOT AFFECTED<br>MKHUBLI_220      | 12:40<br>(18.09.2022) |                       |           | LINE CLEAR AVAIED |
| 1525  | 28-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2     | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |           | LINE CLEAR AVAIED |
| 1526  | 28-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2            | STATION NOT AFFECTED<br>SOUNDATTI_220    | 10:49<br>(18.07.2024) |                       |           | LINE CLEAR AVAIED |
| 1527  | 28-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS         | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 1528  | 28-Sep-24 | BAGALKOT | 110     | LINE        | JAMBAGI-MUDHOL                | JAMBAGI_110                              | 11:10                 | 17:05                 | 5:55      | LINE CLEAR AVAIED |
| 1529  | 28-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)           | MALGHAN(B)_110                           | 10:45                 | 10:50                 | 0:05      | TRIPPED ON FAULT  |
| 1530  | 28-Sep-24 | BAGALKOT | 110     | LINE        | TERDAL-YARAGATTI              | TERDAL_110                               | 10:20                 | 19:05                 | 8:45      | LINE CLEAR AVAIED |
| 1531  | 28-Sep-24 | BAGALKOT | 110     | LINE        | AHERI220-CHANDKAVATE-106      | AHERI_220                                | 13:01                 | 13:07                 | 00:06     | TRIPPED ON FAULT  |
| 1532  | 28-Sep-24 | BAGALKOT | 220     | LINE        | GADAG- HARTI1                 | GADAG_220                                | 11:11                 | 16:32                 | 05:21     | LINE CLEAR AVAIED |
| 1533  | 28-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220- PH COMPOUND         | HUBLI_220                                | 07:38                 | 09:07                 | 01:29     | TRIPPED ON FAULT  |
| 1534  | 29-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR      | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |           | LINE CLEAR AVAIED |
| 1535  | 29-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2           | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) |                       |           | LINE CLEAR AVAIED |
| 1536  | 29-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUNDATTI2             | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |           | LINE CLEAR AVAIED |
| 1537  | 29-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)      | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |           | LINE CLEAR AVAIED |
| 1538  | 29-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-UDYAMBAG                | STATION NOT AFFECTED<br>MACHE_110        | 16:28<br>(03.09.2024) | 10:12<br>(29.09.2024) | 617:44:00 | LINE CLEAR AVAIED |
| 1539  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)       | STATION NOT AFFECTED<br>ANKOLA_110       | 9:38<br>(22.09.2024)  |                       |           | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                    | Station_Name                            | Open_At               | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-----------------------------------------|-----------------------------------------|-----------------------|-----------|----------|-------------------|
| 1540  | 29-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI                    | STATION NOT AFFECTED<br>SANKESHWARA_110 | 11:26<br>(23.09.2024) |           |          | LINE CLEAR AVAIED |
| 1541  | 29-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                      | STATION NOT AFFECTED<br>KIRUVATTI_110   | 12:45<br>(24.09.2024) |           |          | LINE CLEAR AVAIED |
| 1542  | 29-Sep-24 | BAGALKOT | 110     | LINE        | DEVANGOAN-F2(AFZLAPUR)                  | DEVANGOAN_110                           | 20:40                 | 20:47     | 0:07     | TRIPPED ON FAULT  |
| 1543  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVAHV4)                  | GAJENDRAGAD_110                         | 16:35                 | 17:54     | 1:19     | TRIPPED ON FAULT  |
| 1544  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                     | GHATAPRABHA_110                         | 10:35                 | 17:41     | 7:06     | LINE CLEAR AVAIED |
| 1545  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(10MVA-HV1)                 | GHATAPRABHA_110                         | 10:10                 | 17:40     | 7:30     | LINE CLEAR AVAIED |
| 1546  | 29-Sep-24 | BAGALKOT | 110     | LINE        | HIDIKAL DAM-GHATAPRABHA                 | HIDIKAL DAM_110                         | 09:55                 | 17:23     | 7:28     | LINE CLEAR AVAIED |
| 1547  | 29-Sep-24 | BAGALKOT | 110     | LINE        | HIREHAL-IDLE(RON)                       | HIREHAL_110                             | 18:57                 | 19:01     | 0:04     | TRIPPED ON FAULT  |
| 1548  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                     | MALGHAN(B)_110                          | 10:18<br>(29.09.2024) |           |          | LINE CLEAR AVAIED |
| 1549  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)                     | MALGHAN(B)_110                          | 11:36                 | 16:33     | 4:57     | LINE CLEAR AVAIED |
| 1550  | 29-Sep-24 | BAGALKOT | 110     | LINE        | YARAGATTI-KATAKOL                       | YARAGATTI_110                           | 02:11                 | 02:42     | 0:31     | TRIPPED ON FAULT  |
| 1551  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                     | TUMMINKATTI_110                         | 10:20                 | 17:51     | 7:31     | LINE CLEAR AVAIED |
| 1552  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                     | TUMMINKATTI_110                         | 10:20                 | 17:05     | 6:45     | LINE CLEAR AVAIED |
| 1553  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)                     | TARIHAL_110                             | 08:01                 | 13:20     | 5:19     | LINE CLEAR AVAIED |
| 1554  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                     | TARIHAL_110                             | 08:16                 | 13:25     | 5:09     | LINE CLEAR AVAIED |
| 1555  | 29-Sep-24 | BAGALKOT | 110     | LINE        | TARIHAL-SRS HUBLI1                      | TARIHAL_110                             | 13:00                 | 13:01     | 0:01     | TRIPPED ON FAULT  |
| 1556  | 29-Sep-24 | BAGALKOT | 110     | LINE        | TARIHAL-KIADB                           | TARIHAL_110                             | 08:29                 | 14:35     | 6:06     | LINE CLEAR AVAIED |
| 1557  | 29-Sep-24 | BAGALKOT | 110     | LINE        | TADASINAKOPPA-KUD DHARWAD               | TADASINAKOPPA_110                       | 08:14                 | 13:13     | 4:59     | LINE CLEAR AVAIED |
| 1558  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV4(10MVA)                     | SADALAGA_110                            | 08:25                 | 09:09     | 0:44     | LINE CLEAR AVAIED |
| 1559  | 29-Sep-24 | BAGALKOT | 110     | LINE        | RON-GAJENDRAGADA1                       | RON_110                                 | 08:36                 | 21:41     | 13:05    | TRIPPED ON FAULT  |
| 1560  | 29-Sep-24 | BAGALKOT | 110     | LINE        | RON-HIREHAL                             | RON_110                                 | 08:36                 | 18:53     | 10:17    | TRIPPED ON FAULT  |
| 1561  | 29-Sep-24 | BAGALKOT | 110     | LINE        | RAMANAKOPPA-SRS HUBLI                   | RAMANAKOPPA_110                         | 18:10                 | 19:53     | 1:43     | LINE CLEAR AVAIED |
| 1562  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                     | RAIBAG_110                              | 10:01                 | 11:01     | 1:00     | TRIPPED ON FAULT  |
| 1563  | 29-Sep-24 | BAGALKOT | 110     | LINE        | NAVALGUND-KONNUR<br>NAVALAGUND (KNRNGO) | NAVALGUND_110                           | 21:06                 | 22:04     | 0:58     | TRIPPED ON FAULT  |
| 1564  | 29-Sep-24 | BAGALKOT | 110     | LINE        | NARAGUND-BPCL                           | NARAGUND_110                            | 20:28                 | 23:11     | 2:43     | TRIPPED ON FAULT  |
| 1565  | 29-Sep-24 | BAGALKOT | 110     | LINE        | BIDNAL220- ANNIGERI                     | BIDNAL_220                              | 13:43                 | 19:06     | 05:23    | TRIPPED ON FAULT  |
| 1566  | 29-Sep-24 | BAGALKOT | 110     | LINE        | GHATAPRABHA220-<br>GHATPRABHA1          | GHATAPRABHA_220                         | 10:57                 | 17:12     | 06:15    | LINE CLEAR AVAIED |
| 1567  | 29-Sep-24 | BAGALKOT | 110     | LINE        | GHATAPRABHA220-<br>GHATPRABHA2          | GHATAPRABHA_220                         | 10:38                 | 17:12     | 06:34    | LINE CLEAR AVAIED |
| 1568  | 29-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- AEQUS1(KANAGALA1)             | CHIKKODI_220                            | 12:57                 | 13:07     | 00:10    | TRIPPED ON FAULT  |
| 1569  | 29-Sep-24 | BAGALKOT | 220     | LINE        | BELGAUM- KANABARGI1                     | BELGAUM_220                             | 15:35                 | 16:49     | 01:14    | LINE CLEAR AVAIED |
| 1570  | 29-Sep-24 | BAGALKOT | 110     | LINE        | BELGAUM220-<br>HEKKERI(UCHAGOAN)        | BELGAUM_220                             | 11:45                 | 12:51     | 01:06    | LINE CLEAR AVAIED |
| 1571  | 29-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI- TARIHAL2                         | HUBLI_220                               | 08:35                 | 12:46     | 04:11    | LINE CLEAR AVAIED |
| 1572  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV3(20MVA)                     | HUBLI_220                               | 10:44                 | 10:54     | 00:10    | TRIPPED ON FAULT  |
| 1573  | 29-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220-MKHUBLI1                     | STATION NOT AFFECTED<br>MKHUBLI_220     | 12:40<br>(18.09.2022) |           |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                           | Station_Name                             | Open_At               | Closed_At             | Duration   | REMARKS           |
|-------|-----------|----------|---------|-------------|------------------------------------------------|------------------------------------------|-----------------------|-----------------------|------------|-------------------|
| 1574  | 29-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2                      | STATION NOT AFFECTED<br>SOUNDATTI_220    | 11:47<br>(06.07.2024) |                       |            | LINE CLEAR AVAIED |
| 1575  | 29-Sep-24 | BAGALKOT | 220     | LINE        | SOUNDATTI-BIDNAL 2                             | STATION NOT AFFECTED<br>SOUDATTI_220     | 10:49<br>(18.07.2024) |                       |            | LINE CLEAR AVAIED |
| 1576  | 29-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT - KOPPAL LIS                          | STATION NOT AFFECTED<br>BAGALKOT_220     | 4:35<br>(11.08.2024)  |                       |            | LINE CLEAR AVAIED |
| 1577  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA)                            | TUMMINKATTI_110                          | 10:15                 | 17:55                 | 7:40       | LINE CLEAR AVAIED |
| 1578  | 29-Sep-24 | BAGALKOT | 110     | LINE        | TARIHAL-YARAGATTI                              | TARIHAL_110                              | 10:20                 | 19:05                 | 8:45       | LINE CLEAR AVAIED |
| 1579  | 29-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                            | TARIHAL_110                              | 08:05                 | 13:25                 | 5:20       | LINE CLEAR AVAIED |
| 1580  | 29-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220- RAMANKOPPA                           | HUBLI_220                                | 18:08                 | 19:32                 | 01:24      | TRIPPED ON FAULT  |
| 1581  | 29-Sep-24 | BAGALKOT | 110     | LINE        | AMBEWADI- NARENDRA1                            | AMBEWADI_220                             | 09:13                 | 13:03                 | 03:50      | TRIPPED ON FAULT  |
| 1582  | 30-Sep-24 | BAGALKOT | 110     | LINE        | SRS HUBLI220- ANANDNAGAR                       | STATION NOT AFFECTED<br>HUBLI_220        | 8:13<br>(24.03.2024)  |                       |            | LINE CLEAR AVAIED |
| 1583  | 30-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGAR-BAGALKOT2                            | STATION NOT AFFECTED<br>NAVANAGAR(B)_110 | 10:51<br>(17.07.2024) | 16:55<br>(30.09.2024) | 1806:04:00 | LINE CLEAR AVAIED |
| 1584  | 30-Sep-24 | BAGALKOT | 220     | LINE        | BIDNAL-SOUDATTI2                               | STATION NOT AFFECTED<br>BIDNAL_220       | 9:32<br>(06.08.2024)  |                       |            | LINE CLEAR AVAIED |
| 1585  | 30-Sep-24 | BAGALKOT | 110     | LINE        | UTTUR-F1 JAMBAGI(MUDHOL)                       | STATION NOT AFFECTED<br>UTTUR_110        | 14:09<br>(27.08.2024) |                       |            | LINE CLEAR AVAIED |
| 1586  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV2(10MVA-HV1)                        | STATION NOT AFFECTED<br>ANKOLA_110       | 9:38<br>(22.09.2024)  |                       |            | LINE CLEAR AVAIED |
| 1587  | 30-Sep-24 | BAGALKOT | 110     | LINE        | SANKESHWARA-CHIKKODI                           | STATION NOT AFFECTED<br>SANKESHWARA_110  | 11:26<br>(23.09.2024) |                       |            | LINE CLEAR AVAIED |
| 1588  | 30-Sep-24 | BAGALKOT | 110     | LINE        | KIRUVATTI-AMBEWADI                             | STATION NOT AFFECTED<br>KIRUVATTI_110    | 12:45<br>(24.09.2024) |                       |            | LINE CLEAR AVAIED |
| 1589  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(10MVA)                            | MALGHAN(B)_110                           | 10:18<br>(29.09.2024) |                       |            | LINE CLEAR AVAIED |
| 1590  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/33KV,HV3(20MVA,HV4)                        | UGARKHUD_110                             | 17:01                 | 17:22                 | 0:21       | TRIPPED ON FAULT  |
| 1591  | 30-Sep-24 | BAGALKOT | 110     | LINE        | TODALABHAGI-JAMAKHANDI<br>SUGARS (JAMAKHANDI)  | TODALABHAGI_110                          | 03:53                 | 04:05                 | 0:12       | TRIPPED ON FAULT  |
| 1592  | 30-Sep-24 | BAGALKOT | 110     | LINE        | SUVARNA SOUDA-HIRE<br>BAGEWADI                 | SUVARNA SOUDA_110                        | 19:33                 | 19:55                 | 0:22       | LINE CLEAR AVAIED |
| 1593  | 30-Sep-24 | BAGALKOT | 110     | LINE        | NAVALAGUND-BIDNAL                              | NAVALAGUND_110                           | 23:33<br>(30.09.2024) |                       |            | TRIPPED ON FAULT  |
| 1594  | 30-Sep-24 | BAGALKOT | 110     | LINE        | NAVANAGARA-<br>BAGALKOT1                       | NAVANAGARA_110                           | 16:50<br>(30.09.2024) |                       |            | LINE CLEAR AVAIED |
| 1595  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MRUTHYUNJAY NAGAR-<br>GOPPANKOPPA L-1          | MRUTHYUNJAY NAGAR_110                    | 9:45<br>(30.09.2024)  |                       |            | TRIPPED ON FAULT  |
| 1596  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MUDALAGI-SAIDAPUR                              | MUDALAGI_110                             | 19:05                 | 19:40                 | 0:35       | LINE CLEAR AVAIED |
| 1597  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-SUVARNA SOUDHA (MK<br>HUBLI)             | MACHE_110                                | 16:20                 | 16:50                 | 0:30       | LINE CLEAR AVAIED |
| 1598  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-SUVARNA SOUDHA (MK<br>HUBLI)             | MACHE_110                                | 17:23                 | 17:25                 | 0:02       | LINE CLEAR AVAIED |
| 1599  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MACHE-ASHOKA IRON PLANT 3<br>(ASHOKA IRON PLA) | MACHE_110                                | 16:20                 | 16:50                 | 0:30       | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                      | Open_At            | Closed_At | Duration | REMARKS           |
|-------|-----------|----------|---------|-------------|-----------------------------------|-----------------------------------|--------------------|-----------|----------|-------------------|
| 1600  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(10MVA)               | LAKMANAHALLI_110                  | 13:59              | 14:14     | 0:15     | LINE CLEAR AVAIED |
| 1601  | 30-Sep-24 | BAGALKOT | 110     | LINE        | KULGERI CROSS-MRN KN POWER (MRN)  | KULGERI CROSS_110                 | 13:20              | 13:30     | 0:10     | TRIPPED ON FAULT  |
| 1602  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)               | KULGERI CROSS_110                 | 19:53              | 19:57     | 0:04     | LINE CLEAR AVAIED |
| 1603  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 110/11KV,HV2(20MVA)               | KULGERI CROSS_110                 | 19:53              | 19:57     | 0:04     | LINE CLEAR AVAIED |
| 1604  | 30-Sep-24 | BAGALKOT | 110     | LINE        | KUD DHARWAD-LAKMANAHALLI          | KUD DHARWAD_110                   | 17:12              | 17:40     | 0:28     | LINE CLEAR AVAIED |
| 1605  | 30-Sep-24 | BAGALKOT | 220     | LINE        | GADAG- LINGAPUR2(DHONI2)          | GADAG_220                         | 11:37              | 17:56     | 6:19     | LINE CLEAR AVAIED |
| 1606  | 30-Sep-24 | BAGALKOT | 220     | LINE        | DHONI- GADAG2                     | DHONI_400                         | 11:36              | 17:55     | 6:19     | LINE CLEAR AVAIED |
| 1607  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MAHALINGAPUR220- GSML1            | MAHALINGAPUR_220                  | 13:17              | 13:43     | 0:26     | TRIPPED ON FAULT  |
| 1608  | 30-Sep-24 | BAGALKOT | 220     | LINE        | MAHALINGAPUR- VAJRAMATTI1         | MAHALINGAPUR_220                  | 13:17              | 14:20     | 1:03     | TRIPPED ON FAULT  |
| 1609  | 30-Sep-24 | BAGALKOT | 110     | LINE        | KADANKOPPA- KAWALWADA(AMBEWADI)   | KADANKOPPA_110                    | 10:37              | 11:14     | 0:37     | LINE CLEAR AVAIED |
| 1610  | 30-Sep-24 | BAGALKOT | 110     | LINE        | KADANKOPPA- HUBLI                 | KADANKOPPA_110                    | 11:01              | 16:06     | 5:05     | LINE CLEAR AVAIED |
| 1611  | 30-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-NARENDRA-2                  | HUBLI_220                         | 12:04              | 14:51     | 2:47     | TRIPPED ON FAULT  |
| 1612  | 30-Sep-24 | BAGALKOT | 220     | LINE        | HUBLI-SIRSI-2                     | HUBLI_220                         | 12:43              | 13:33     | 0:50     | TRIPPED ON FAULT  |
| 1613  | 30-Sep-24 | BAGALKOT | 110     | LINE        | MKHUBLI220- KITTUR (HIREBAGEWADI) | MKHUBLI_220                       | 18:53              | 19:35     | 0:42     | TRIPPED ON FAULT  |
| 1614  | 30-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220-KADANKOPPA               | HUBLI_220                         | 11:02              | 13:16     | 2:14     | LINE CLEAR AVAIED |
| 1615  | 30-Sep-24 | BAGALKOT | 110     | LINE        | HUBLI220-SIRSI-2                  | HUBLI_220                         | 13:41              | 17:26     | 3:45     | TRIPPED ON FAULT  |
| 1616  | 30-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT- VAJRAMATTI1             | BAGALKOT_220                      | 13:17              | 16:10     | 2:53     | TRIPPED ON FAULT  |
| 1617  | 30-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT- VAJRAMATTI1             | BAGALKOT_220                      | 16:28              | 18:19     | 1:51     | LINE CLEAR AVAIED |
| 1618  | 30-Sep-24 | BAGALKOT | 220     | LINE        | BAGALKOT- VAJRAMATTI2             | BAGALKOT_220                      | 13:17              | 14:12     | 0:55     | TRIPPED ON FAULT  |
| 1619  | 30-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F3NAVANAGAR1          | BAGALKOT_220                      | 16:53              | 20:17     | 3:24     | LINE CLEAR AVAIED |
| 1620  | 30-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F3NAVANAGAR2          | BAGALKOT_220                      | 16:54              | 16:57     | 0:03     | LINE CLEAR AVAIED |
| 1621  | 30-Sep-24 | BAGALKOT | 110     | LINE        | BAGALKOT220-F5-GULEDGUDDA         | BAGALKOT_220                      | 17:02              | 19:31     | 2:29     | LINE CLEAR AVAIED |
| 1622  | 30-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                    | BAGALKOT_220                      | 17:11              | 20:00     | 2:49     | LINE CLEAR AVAIED |
| 1623  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV1                    | BAGALKOT_220                      | 17:11              | 20:11     | 3:00     | LINE CLEAR AVAIED |
| 1624  | 30-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV2(HV3)               | BAGALKOT_220                      | 13:19              | 14:21     | 1:02     | TRIPPED ON FAULT  |
| 1625  | 30-Sep-24 | BAGALKOT | 110     | TRANSFORMER | 220/110KV, LV2(LV3)               | BAGALKOT_220                      | 13:18              | 14:09     | 0:51     | TRIPPED ON FAULT  |
| 1626  | 30-Sep-24 | BAGALKOT | 110     | LINE        | BIDNAL220- NAVALGUND              | BIDNAL_220                        | 23:44 (30.09.2024) |           |          | TRIPPED ON FAULT  |
| 1627  | 30-Sep-24 | BAGALKOT | 220     | LINE        | CHIKKODI- AEQUS1(KANAGALA1)       | CHIKKODI_220                      | 19:40              | 20:03     | 00:23    | TRIPPED ON FAULT  |
| 1628  | 30-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS-F3(KANAGALA1)               | STATION NOT AFFECTED<br>AEQUS_220 | 19:41              | 20:10     | 00:29    | TRIPPED ON FAULT  |
| 1629  | 30-Sep-24 | BAGALKOT | 220     | LINE        | AEQUS-F4(KANAGALA2)               | STATION NOT AFFECTED<br>AEQUS_220 | 19:41              | 20:10     | 00:29    | TRIPPED ON FAULT  |
| 1630  | 30-Sep-24 | BAGALKOT | 110     | LINE        | AINAPUR- KUDACHI220               | AINAPUR_110                       | 11:17              | 11:39     | 00:22    | TRIPPED ON FAULT  |
| 1631  | 30-Sep-24 | BAGALKOT | 220     | LINE        | VAJRAMATTI- BAGALKOT1             | VAJRAMATTI_220                    | 13:26              | 18:24     | 04:58    | TRIPPED ON FAULT  |
| 1632  | 30-Sep-24 | BAGALKOT | 220     | TRANSFORMER | 220/110KV, HV1                    | VAJRAMATTI_220                    | 13:19              | 13:41     | 00:22    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                        | Station_Name                          | Open_At               | Closed_At             | Duration   | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------|---------------------------------------|-----------------------|-----------------------|------------|---------------------|
| 1633  | 30-Sep-24 | BAGALKOT  | 220     | TRANSFORMER | 220/110KV, HV2                              | VAJRAMATTI_220                        | 13:19                 | 13:56                 | 00:37      | TRIPPED ON FAULT    |
| 1634  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | VAJRAMATTI220- BILAGI                       | VAJRAMATTI_220                        | 13:31                 | 14:05                 | 00:34      | LINE CLEAR AVAILED  |
| 1635  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | VAJRAMATTI220- MANTUR1                      | VAJRAMATTI_220                        | 13:31                 | 14:06                 | 00:35      | LINE CLEAR AVAILED  |
| 1636  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | VAJRAMATTI220- MANTUR2                      | VAJRAMATTI_220                        | 13:31                 | 14:07                 | 00:36      | LINE CLEAR AVAILED  |
| 1637  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | VAJRAMATTI220- MANTUR (MUDHOL)              | VAJRAMATTI_220                        | 13:31                 | 13:45                 | 00:14      | LINE CLEAR AVAILED  |
| 1638  | 30-Sep-24 | BAGALKOT  | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                        | ANANDNAGAR_110                        | 11:32                 | 12:58                 | 01:26      | LINE CLEAR AVAILED  |
| 1639  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | MKHUBLI220-MKHUBLI1                         | STATION NOT AFFECTED<br>MKHUBLI_220   | 12:40<br>(18.09.2022) |                       |            | LINE CLEAR AVAILED  |
| 1640  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | SOUNDATTI-MAHALINGAPURA-2                   | STATION NOT AFFECTED<br>SOUNDATTI_220 | 11:47<br>(06.07.2024) |                       |            | LINE CLEAR AVAILED  |
| 1641  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | SOUNDATTI-BIDNAL 2                          | STATION NOT AFFECTED<br>SOUNDATTI_220 | 10:49<br>(18.07.2024) |                       |            | LINE CLEAR AVAILED  |
| 1642  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | BAGALKOT - KOPPAL LIS                       | STATION NOT AFFECTED<br>BAGALKOT_220  | 4:35<br>(11.08.2024)  | 11:54<br>(30.09.2024) | 1207:19:00 | LINE CLEAR AVAILED  |
| 1643  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | MANTUR-VAJRAMATTI                           | MANTUR_110                            | 13:18                 | 14:08                 | 0:50       | MAIN SUPPLY FAILURE |
| 1644  | 30-Sep-24 | BAGALKOT  | 110     | TRANSFORMER | 110/11KV,HV1(20MVA)                         | LAKMANAHALLI_110                      | 14:14                 | 16:11                 | 1:57       | LINE CLEAR AVAILED  |
| 1645  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | LAKMANAHALLI- KUD DHARWAD                   | LAKMANAHALLI_110                      | 17:17                 | 17:43                 | 0:26       | LINE CLEAR AVAILED  |
| 1646  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | SUARNASOUDA- MACHE                          | SUARNASOUDA_110                       | 16:20                 | 16:50                 | 0:30       | TRIPPED ON FAULT    |
| 1647  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | SOUNDATTI220- MMCL                          | SOUNDATTI_220                         | 18:23                 | 18:37                 | 0:14       | TRIPPED ON FAULT    |
| 1648  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | ISLAMPUR- HIDIKAL DAM                       | ISLAMPUR_110                          | 20:40                 | 21:23                 | 0:43       | TRIPPED ON FAULT    |
| 1649  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | DADDI- HONAGA                               | DADDI_110                             | 21:08                 | 21:50                 | 0:42       | TRIPPED ON FAULT    |
| 1650  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | BELGAUM- AEQUS1                             | BELGAUM_220                           | 20:39                 | 21:15                 | 0:36       | TRIPPED ON FAULT    |
| 1651  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | BELGAUM- AEQUS2                             | BELGAUM_220                           | 20:39                 | 21:15                 | 0:36       | TRIPPED ON FAULT    |
| 1652  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | BELGAUM220- UCHAGOAN                        | BELGAUM_220                           | 22:02                 | 22:09                 | 0:07       | TRIPPED ON FAULT    |
| 1653  | 30-Sep-24 | BAGALKOT  | 110     | TRANSFORMER | 110/11KV, HV1(10MVA)                        | GHATAPRABHA_110                       | 12:05                 | 12:25                 | 0:20       | TRIPPED ON FAULT    |
| 1654  | 30-Sep-24 | BAGALKOT  | 110     | TRANSFORMER | 110/11KV, HV2(10MVA)                        | GHATAPRABHA_110                       | 12:05                 | 12:25                 | 0:20       | TRIPPED ON FAULT    |
| 1655  | 30-Sep-24 | BAGALKOT  | 110     | TRANSFORMER | 110/33KV, HV3(10MVA)                        | GHATAPRABHA_110                       | 12:05                 | 12:20                 | 0:15       | TRIPPED ON FAULT    |
| 1656  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | NARENDRA- HUBLI2                            | NARENDRA_220                          | 12:04                 | 14:52                 | 2:48       | TRIPPED ON FAULT    |
| 1657  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | BAGALKOT220-F5-GULEDGUDDA                   | BAGALKOT_220                          | 20:03                 | 20:13                 | 0:10       | LINE CLEAR AVAILED  |
| 1658  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | BAGALKOT220-F10-KALADAGI                    | BAGALKOT_220                          | 17:05                 | 20:14                 | 3:09       | LINE CLEAR AVAILED  |
| 1659  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | CHIKKODI220-RAIBAG 1                        | CHIKKODI_220                          | 20:33                 | 21:34                 | 1:01       | TRIPPED ON FAULT    |
| 1660  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | CHIKKODI220-RAIBAG 2                        | CHIKKODI_220                          | 20:33                 | 21:34                 | 1:01       | TRIPPED ON FAULT    |
| 1661  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | CHIKKODI-MUGALKHOD1                         | CHIKKODI_220                          | 20:41                 | 21:25                 | 0:44       | TRIPPED ON FAULT    |
| 1662  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | CHIKKODI220-SADALAGA                        | CHIKKODI_220                          | 20:56                 | 21:28                 | 0:32       | TRIPPED ON FAULT    |
| 1663  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | AEQUS -BELGAUM1                             | STATION NOT AFFECTED<br>BELGAUM_220   | 20:40                 | 21:15                 | 0:35       | TRIPPED ON FAULT    |
| 1664  | 30-Sep-24 | BAGALKOT  | 220     | LINE        | AEQUS -BELGAUM2                             | STATION NOT AFFECTED<br>BELGAUM_220   | 20:40                 | 21:15                 | 0:35       | TRIPPED ON FAULT    |
| 1665  | 30-Sep-24 | BAGALKOT  | 110     | LINE        | MUGALKHOD220- NAGNUR                        | MUGALKHOD_220                         | 19:07                 | 19:38                 | 0:31       | LINE CLEAR AVAILED  |
| 1666  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 -<br>MAHALAKSHMI LAYOUT | NO STATION AFFECTED                   | 13:09                 | 13:56                 | 00:47      | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                         | Station_Name                   | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------------|--------------------------------|---------|-----------|----------|--------------------|
| 1667  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - NANDINI LAYOUT                                | NANDINI LAYOUT                 | 11:23   | 11:30     | 00:07    | TRIPPED ON FAULT   |
| 1668  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - NANDINI LAYOUT                                | NO STATION AFFECTED            | 12:09   | 12:22     | 00:13    | TRIPPED ON FAULT   |
| 1669  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                                     | PALLADIUM                      | 12:42   | 16:18     | 03:36    | LINE CLEAR AVAILED |
| 1670  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BRINDAVAN HTLS                         | NO STATION AFFECTED            | 07:19   | 11:11     | 03:52    | TRIPPED ON FAULT   |
| 1671  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - IISC                                          | IISc                           | 22:15   | 22:18     | 00:03    | LINE CLEAR AVAILED |
| 1672  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BRINDAVANA 220                         | NANDINI LAYOUT                 | 07:19   | 07:33     | 00:14    | TRIPPED ON FAULT   |
| 1673  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - BAGAMANE WTC 2                                | NO STATION AFFECTED            | 08:06   | 10:04     | 01:58    | TRIPPED ON FAULT   |
| 1674  | 01-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                          | KHODAYS 220                    | 17:15   | 17:19     | 00:04    | LINE CLEAR AVAILED |
| 1675  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - REMCO 2 - RR NAGARA - GLOBAL (EHT) | NO STATION AFFECTED            | 10:35   | 14:50     | 04:15    | LINE CLEAR AVAILED |
| 1676  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - TUBAGERE                              | TUBAGERE                       | 10:19   | 10:32     | 00:13    | TRIPPED ON FAULT   |
| 1677  | 01-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                          | KIADB DB PURA 220              | 11:29   | 11:50     | 00:21    | TRIPPED ON FAULT   |
| 1678  | 01-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                          | KIADB DB PURA 220              | 11:50   | 14:30     | 02:40    | LINE CLEAR AVAILED |
| 1679  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV TUBAGERE - CB PURA I/A 1                                | NO STATION AFFECTED            | 10:19   | 10:34     | 00:15    | TRIPPED ON FAULT   |
| 1680  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                                   | VEMGAL, KYALANUR, TALAGUNDA    | 11:30   | 11:47     | 00:17    | TRIPPED ON FAULT   |
| 1681  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV LAKSHMIPURA - GOWNIPALLI                                | ADDAGAL, RAYALPADU, GOWNIPALLI | 18:31   | 18:42     | 00:11    | TRIPPED ON FAULT   |
| 1682  | 01-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                          | HUKUNDA                        | 13:05   | 13:10     | 00:05    | TRIPPED ON FAULT   |
| 1683  | 01-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA - TUBINAKERE 220                             | NO STATION AFFECTED            | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 1684  | 01-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220                         | NO STATION AFFECTED            | 07:49   | 18:30     | 10:41    | LINE CLEAR AVAILED |
| 1685  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - ATTIBELE                                       | ATTIBELE                       | 10:27   | 10:32     | 00:05    | LINE CLEAR AVAILED |
| 1686  | 01-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                                | ATTIBELE                       | 10:27   | 10:32     | 00:05    | LINE CLEAR AVAILED |
| 1687  | 01-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                          | BOMMASANDRA I/A                | 08:45   | 10:50     | 02:05    | LINE CLEAR AVAILED |
| 1688  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                          | KHB                            | 12:16   | 12:23     | 00:07    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                               | Station_Name                                     | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------------------------------------------|--------------------------------------------------|---------|-----------|----------|--------------------|
| 1689  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV CESSNA BUSINESS PARK 220 - EXORA 66                                                           | CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT) | 13:51   | 14:06     | 00:15    | LINE CLEAR AVAILED |
| 1690  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV CESSNA BUSINESS PARK 220 - DEVARBISANAHALLI                                                   | CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT) | 15:30   | 15:40     | 00:10    | LINE CLEAR AVAILED |
| 1691  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 1                                                               | EMBASSY TECH PARK                                | 14:27   | 14:31     | 00:04    | LINE CLEAR AVAILED |
| 1692  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 2                                                               | EMBASSY TECH PARK                                | 14:27   | 14:31     | 00:04    | LINE CLEAR AVAILED |
| 1693  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 1                                                               | EMBASSY TECH PARK                                | 15:10   | 15:55     | 00:45    | LINE CLEAR AVAILED |
| 1694  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 2                                                               | EMBASSY TECH PARK                                | 15:10   | 15:55     | 00:45    | LINE CLEAR AVAILED |
| 1695  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                | HAL 220                                          | 03:36   | 03:46     | 00:10    | TRIPPED ON FAULT   |
| 1696  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT                                | RMZ                                              | 14:24   | 15:08     | 00:44    | LINE CLEAR AVAILED |
| 1697  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT                                | RMZ                                              | 15:50   | 15:55     | 00:05    | LINE CLEAR AVAILED |
| 1698  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 - JAYANAGAR GIS                                                                   | JAYANAGARA, NATIONAL COLLEGE                     | 19:09   | 19:19     | 00:10    | TRIPPED ON FAULT   |
| 1699  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NATIONAL COLLEGE - JAYANAGAR GIS                                                              | NATIONAL COLLEGE                                 | 19:09   | 19:30     | 00:21    | TRIPPED ON FAULT   |
| 1700  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                                                | NO STATION AFFECTED                              | 07:42   | 12:15     | 04:33    | TRIPPED ON FAULT   |
| 1701  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - YARANDANAHALLI 1                                                            | NO STATION AFFECTED                              | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED |
| 1702  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                | RR NAGAR                                         | 15:00   | 15:05     | 00:05    | LINE CLEAR AVAILED |
| 1703  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4 | GRINDWELL NORTON(EHT)                            | 12:41   | 12:48     | 00:07    | LINE CLEAR AVAILED |
| 1704  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - VIJAYAPURA                                                                  | VIJAYAPURA, JANGAMKOTE                           | 05:20   | 05:49     | 00:29    | TRIPPED ON FAULT   |
| 1705  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3                                                    | DODDABELAVANGALA, GUNDAMGERE, SASALU             | 09:13   | 09:24     | 00:11    | TRIPPED ON FAULT   |
| 1706  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3                                                    | DODDABELAVANGALA, GUNDAMGERE, SASALU             | 09:48   | 09:55     | 00:07    | TRIPPED ON FAULT   |
| 1707  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - D CROSS 2                                                                   | AIR(EHT)                                         | 09:54   | 09:55     | 00:01    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name            | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|-------------------------|---------|-----------|----------|--------------------|
| 1708  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - KEMBODI                      | KEMBODI                 | 11:00   | 11:35     | 00:35    | LINE CLEAR AVAILED |
| 1709  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KEMBODI                 | 11:35   | 11:40     | 00:05    | LINE CLEAR AVAILED |
| 1710  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | KEMBODI                 | 12:00   | 12:05     | 00:05    | LINE CLEAR AVAILED |
| 1711  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KEMBODI                 | 13:15   | 13:50     | 00:35    | LINE CLEAR AVAILED |
| 1712  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KOLAR 220               | 12:43   | 13:04     | 00:21    | TRIPPED ON FAULT   |
| 1713  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | LAKSHMIPURA             | 13:00   | 13:21     | 00:21    | TRIPPED ON FAULT   |
| 1714  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | LAKSHMIPURA             | 13:40   | 13:56     | 00:16    | TRIPPED ON FAULT   |
| 1715  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | MALLASANDRA             | 11:00   | 11:13     | 00:13    | TRIPPED ON FAULT   |
| 1716  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | MALLASANDRA             | 14:05   | 14:06     | 00:01    | LINE CLEAR AVAILED |
| 1717  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 220 - MALUR 220                   | NO STATION AFFECTED     | 14:39   | 15:30     | 00:51    | LINE CLEAR AVAILED |
| 1718  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | DODDALAHALLI            | 15:14   | 15:24     | 00:10    | TRIPPED ON FAULT   |
| 1719  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALLI 220 - VR DODDI           | VR DODDI                | 06:33   | 06:50     | 00:17    | TRIPPED ON FAULT   |
| 1720  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | AGALAKOTE               | 07:40   | 09:05     | 01:25    | LINE CLEAR AVAILED |
| 1721  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV DABASPETE 220 - KADUR 220               | NO STATION AFFECTED     | 10:50   | 14:30     | 03:40    | LINE CLEAR AVAILED |
| 1722  | 02-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | GUDEMARANAHALLI         | 15:15   | 16:20     | 01:05    | TRIPPED ON FAULT   |
| 1723  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - NITTUR                | NO STATION AFFECTED     | 10:54   | 16:20     | 05:26    | LINE CLEAR AVAILED |
| 1724  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI | KEMPANAHALLI, MELEHALLI | 10:15   | 10:35     | 00:20    | LINE CLEAR AVAILED |
| 1725  | 02-Sep-24 | BENGALURU | 66      | LINE        | 66KV URAGAHALLI - KEMPANAHALLI                | KEMPANAHALLI, MELEHALLI | 14:40   | 15:00     | 00:20    | LINE CLEAR AVAILED |
| 1726  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2            | NO STATION AFFECTED     | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 1727  | 02-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220          | NO STATION AFFECTED     | 06:57   | 23:59     | 17:02    | LINE CLEAR AVAILED |
| 1728  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KHB                     | 12:15   | 12:20     | 00:05    | LINE CLEAR AVAILED |
| 1729  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - KANASWADI             | KANASAWADI              | 07:19   | 07:37     | 00:18    | TRIPPED ON FAULT   |
| 1730  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV PUTTENAHALLI 220 - KPCL 2               | NO STATION AFFECTED     | 12:37   | 13:38     | 01:01    | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS | Line                                                                         | Station_Name                                                                    | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-----------|------------------------------------------------------------------------------|---------------------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 1731  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV EDC 220 - BMTC                                                          | BMTC                                                                            | 15:52   | 17:18     | 01:26    | TRIPPED ON FAULT    |
| 1732  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV HSR 220 - JAKKASANDRA                                                   | JAKKASANDRA                                                                     | 22:51   | 22:57     | 00:06    | LINE CLEAR AVAILED  |
| 1733  | 03-Sep-24 | BENGALURU | 220     | LINE      | 220KV MYLASANDRA 400 - NAGANATHPURA 220                                      | NAGANATHPURA 220                                                                | 12:00   | 12:55     | 00:55    | TRIPPED ON FAULT    |
| 1734  | 03-Sep-24 | BENGALURU | 220     | LINE      | 220KV KORAMANGALA 220 - NIMHANS 220                                          | NO STATION AFFECTED                                                             | 12:00   | 12:46     | 00:46    | TRIPPED ON FAULT    |
| 1735  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV NIMHANS 220 - BMTC                                                      | BMTC                                                                            | 16:08   | 17:18     | 01:10    | TRIPPED ON FAULT    |
| 1736  | 03-Sep-24 | BENGALURU | 220     | LINE      | 220KV SOMANAHALLI 220 - BIDADI 220 -1                                        | NO STATION AFFECTED                                                             | 08:51   | 23:59     | 15:08    | LINE CLEAR AVAILED  |
| 1737  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV HSR LAYOUT 220 - ST JOHN WOOD                                           | ST JOHN WOOD                                                                    | 11:05   | 11:13     | 00:08    | LINE CLEAR AVAILED  |
| 1738  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV HSR LAYOUT 220 - ST JOHN WOOD                                           | ST JOHN WOOD                                                                    | 17:29   | 17:33     | 00:04    | LINE CLEAR AVAILED  |
| 1739  | 03-Sep-24 | BENGALURU | 220     | LINE      | 220KV MYLASANDRA 400 - YARANDANAHALLI 1                                      | NO STATION AFFECTED                                                             | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED  |
| 1740  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 1 (VELANKANI)               | ELECTRONIC CITY PH 2 SEC 1, HULIMANGALA, TATA BICON(EHT), TATA POWER SOLAR(EHT) | 12:00   | 12:55     | 00:55    | MAIN SUPPLY FAILURE |
| 1741  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 1 (VELANKANI)               | ELECTRONIC CITY PH 2 SEC 1, HULIMANGALA, TATA BICON(EHT), TATA POWER SOLAR(EHT) | 14:15   | 15:40     | 01:25    | LINE CLEAR AVAILED  |
| 1742  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR | ELECTRONIC CITY PH 2 SEC 2, TATA BP SOLAR, TECH MACHINDRA(EHT), HUSKUR          | 12:00   | 12:55     | 00:55    | MAIN SUPPLY FAILURE |
| 1743  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 2 (MALGUDI) - TATA BP SOLAR | ELECTRONIC CITY PH 2 SEC 2, TATA BP SOLAR, TECH MACHINDRA(EHT), HUSKUR          | 14:15   | 15:40     | 01:25    | LINE CLEAR AVAILED  |
| 1744  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV MALGUDI - CHOKKASANDRA                                                  | HUSKUR(CHOKKASANDRA)                                                            | 12:00   | 15:43     | 03:43    | MAIN SUPPLY FAILURE |
| 1745  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV SOMANAHALLI 220 - BG ROAD - ANJANAPURA (JIGANI 2)                       | BG ROAD                                                                         | 10:22   | 13:00     | 02:38    | LINE CLEAR AVAILED  |
| 1746  | 03-Sep-24 | BENGALURU | 220     | LINE      | 220KV SRS PEENYA 220 - SUBRAMANYAPURA 220                                    | NO STATION AFFECTED                                                             | 12:38   | 17:59     | 05:21    | LINE CLEAR AVAILED  |
| 1747  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV HOODY 220 - HOSKOTE 66                                                  | HOSKOTE 66                                                                      | 14:05   | 14:10     | 00:05    | TRIPPED ON FAULT    |
| 1748  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV GUNDAMGERE - D CROSS                                                    | GUNDAMGERE                                                                      | 18:00   | 18:05     | 00:05    | LINE CLEAR AVAILED  |
| 1749  | 03-Sep-24 | BENGALURU | 66      | LINE      | 66KV D CROSS - KANASWADI                                                     | KANASAWADI                                                                      | 09:40   | 09:43     | 00:03    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                         | Station_Name         | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------|----------------------|---------|-----------|----------|--------------------|
| 1750  | 03-Sep-24 | BENGALURU | 66      | LINE        | GOWRIBIDANUR 220 - AFTL                      | AFTL                 | 18:38   | 19:04     | 00:26    | TRIPPED ON FAULT   |
| 1751  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | TAMAKA               | 09:50   | 10:30     | 00:40    | LINE CLEAR AVAILED |
| 1752  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALI 220 - SANJEEVANADODDI    | RANGANADODDI         | 07:13   | 07:17     | 00:04    | LINE CLEAR AVAILED |
| 1753  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALI 220 - ORCHID LAMINATES-2 | ORCHID LAMINATE      | 07:13   | 07:17     | 00:04    | LINE CLEAR AVAILED |
| 1754  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | HAROHALI I/A 220     | 07:27   | 07:32     | 00:05    | LINE CLEAR AVAILED |
| 1755  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | HAROHALI I/A 220     | 07:27   | 07:32     | 00:05    | LINE CLEAR AVAILED |
| 1756  | 03-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                          | HAROHALI I/A 220     | 10:10   | 17:13     | 07:03    | LINE CLEAR AVAILED |
| 1757  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALI 220 - ORCHID LAMINATES-2 | ORCHID LAMINATE      | 18:22   | 18:26     | 00:04    | LINE CLEAR AVAILED |
| 1758  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALI 220 - VR DODDI           | VR DODDI             | 18:22   | 18:26     | 00:04    | LINE CLEAR AVAILED |
| 1759  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | CHANDRAPPA CIRCLE    | 02:25   | 04:40     | 02:15    | TRIPPED ON FAULT   |
| 1760  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV MAGADI 220 - ANCHEPALYA CKT 2          | NO STATION AFFECTED  | 09:35   | 16:51     | 07:16    | LINE CLEAR AVAILED |
| 1761  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE      | MATHIKERE, AGALAKOTE | 14:10   | 14:25     | 00:15    | TRIPPED ON FAULT   |
| 1762  | 03-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - TALAGUPPA            | NO STATION AFFECTED  | 05:56   | 10:14     | 04:18    | TRIPPED ON FAULT   |
| 1763  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2           | NO STATION AFFECTED  | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 1764  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220       | NO STATION AFFECTED  | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 1765  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220         | NO STATION AFFECTED  | 23:59   | 18:16     | 05:43    | LINE CLEAR AVAILED |
| 1766  | 03-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                          | TK HALLI 220         | 10:50   | 10:51     | 00:01    | LINE CLEAR AVAILED |
| 1767  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                | ATTIBELE             | 11:10   | 11:14     | 00:04    | LINE CLEAR AVAILED |
| 1768  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                | ATTIBELE             | 12:07   | 12:10     | 00:03    | LINE CLEAR AVAILED |
| 1769  | 03-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                          | SARJAPURA 220        | 11:10   | 11:13     | 00:03    | LINE CLEAR AVAILED |
| 1770  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                | ATTIBELE             | 11:10   | 11:14     | 00:04    | LINE CLEAR AVAILED |
| 1771  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | SARJAPURA 220        | 11:07   | 11:13     | 00:06    | LINE CLEAR AVAILED |
| 1772  | 03-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                | ATTIBELE             | 12:07   | 12:10     | 00:03    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                               | Station_Name        | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------|---------------------|---------|-----------|----------|--------------------|
| 1773  | 03-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | SARJAPURA 220       | 12:06   | 12:10     | 00:04    | LINE CLEAR AVAILED |
| 1774  | 03-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - YARANDANAHALLI 3            | NO STATION AFFECTED | 13:05   | 14:55     | 01:50    | LINE CLEAR AVAILED |
| 1775  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | WIDIA               | 15:48   | 15:50     | 00:02    | LINE CLEAR AVAILED |
| 1776  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | RMZ                 | 11:03   | 11:05     | 00:02    | LINE CLEAR AVAILED |
| 1777  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | RMZ                 | 15:00   | 15:03     | 00:03    | LINE CLEAR AVAILED |
| 1778  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                | RMZ                 | 16:00   | 16:05     | 00:05    | LINE CLEAR AVAILED |
| 1779  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - JAKKASANDRA                         | JAKKASANDRA         | 08:25   | 08:30     | 00:05    | LINE CLEAR AVAILED |
| 1780  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV ADUGODI - JAKKASANDRA                         | JAKKASANDRA         | 00:54   | 00:59     | 00:05    | LINE CLEAR AVAILED |
| 1781  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - JAKKASANDRA                         | JAKKASANDRA         | 08:25   | 08:30     | 00:05    | LINE CLEAR AVAILED |
| 1782  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - YARANDANAHALLI 1            | NO STATION AFFECTED | 23:59   | 19:03     | 04:56    | LINE CLEAR AVAILED |
| 1783  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRINIVASAPURA 220 - G KODIHALLI               | G KODIHALLI         | 15:16   | 15:25     | 00:09    | TRIPPED ON FAULT   |
| 1784  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIJAYAPURA - JANGAMKOTE - MELUR               | MELUR               | 09:02   | 09:10     | 00:08    | LINE CLEAR AVAILED |
| 1785  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | SIDLAGHATTA         | 16:36   | 17:00     | 00:24    | TRIPPED ON FAULT   |
| 1786  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 1 | NO STATION AFFECTED | 10:18   | 23:59     | 13:41    | LINE CLEAR AVAILED |
| 1787  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2 | NO STATION AFFECTED | 10:18   | 23:59     | 13:41    | LINE CLEAR AVAILED |
| 1788  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 1      | NO STATION AFFECTED | 10:47   | 23:59     | 13:12    | LINE CLEAR AVAILED |
| 1789  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2      | NO STATION AFFECTED | 10:47   | 23:59     | 13:12    | LINE CLEAR AVAILED |
| 1790  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV CB PURA I/A - NALLIMARADANAHALLI              | NALLIMARADANAHALLI  | 08:30   | 08:35     | 00:05    | LINE CLEAR AVAILED |
| 1791  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | H GOLLAHALLI        | 13:00   | 13:30     | 00:30    | LINE CLEAR AVAILED |
| 1792  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | H GOLLAHALLI        | 13:30   | 13:55     | 00:25    | LINE CLEAR AVAILED |
| 1793  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI    | H GOLLAHALLI        | 13:55   | 14:10     | 00:15    | LINE CLEAR AVAILED |
| 1794  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | MUDIYANUR           | 10:50   | 10:55     | 00:05    | LINE CLEAR AVAILED |
| 1795  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | MUDIYANUR           | 11:26   | 11:28     | 00:02    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                           | Station_Name                                                                                                   | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 1796  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI                | MUDIYANUR                                                                                                      | 12:00   | 12:30     | 00:30    | LINE CLEAR AVAIED |
| 1797  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                              | NARASAPURA, KC VALLEY                                                                                          | 07:35   | 23:59     | 16:24    | TRIPPED ON FAULT  |
| 1798  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | SUGUTUR                                                                                                        | 09:05   | 09:20     | 00:15    | TRIPPED ON FAULT  |
| 1799  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | ACHALU                                                                                                         | 13:09   | 13:15     | 00:06    | LINE CLEAR AVAIED |
| 1800  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | ACHALU                                                                                                         | 13:15   | 13:45     | 00:30    | LINE CLEAR AVAIED |
| 1801  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | MAGADI 220                                                                                                     | 14:40   | 16:00     | 01:20    | LINE CLEAR AVAIED |
| 1802  | 04-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - HASSAN                                 | NO STATION AFFECTED                                                                                            | 10:42   | 18:12     | 07:30    | LINE CLEAR AVAIED |
| 1803  | 04-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1                      | HEJJALA                                                                                                        | 09:30   | 10:05     | 00:35    | TRIPPED ON FAULT  |
| 1804  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220                         | NO STATION AFFECTED                                                                                            | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 1805  | 04-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | CHANNAPATNA 220                                                                                                | 08:51   | 09:00     | 00:09    | TRIPPED ON FAULT  |
| 1806  | 04-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220                           | NO STATION AFFECTED                                                                                            | 23:59   | 18:16     | 05:43    | LINE CLEAR AVAIED |
| 1807  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - KANASWADI                              | KANASAWADI MUSS                                                                                                | 18:31   | 18:41     | 00:10    | TRIPPED ON FAULT  |
| 1808  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HOSKOTE 66                                    | 66KV HOSKOTE STATION                                                                                           | 18:05   | 18:45     | 00:40    | TRIPPED ON FAULT  |
| 1809  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION) | 66 KV KACHAMARANAHALLI, 66 KV DIVYASREE TECH PARK, 66 KV MINOR IRRIGATION, 66 KV MINOR IRRIGATION , DOMASANDRA | 10:31   | 10:48     | 00:17    | TRIPPED ON FAULT  |
| 1810  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 220 - SIDDALAGHATTA                            | SHIDLAGHATTA, Y.HUNASENAHALLI & MELUR                                                                          | 05:43   | 05:57     | 00:14    | TRIPPED ON FAULT  |
| 1811  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR                            | G.KOTTUR                                                                                                       | 19:50   | 20:00     | 00:10    | TRIPPED ON FAULT  |
| 1812  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN                      | PRESTIGE SHANTHINIKETHAN                                                                                       | 12:03   | 12:24     | 00:21    | LINE CLEAR AVAIED |
| 1813  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | PRESTIGE SHANTHINIKETHAN                                                                                       | 12:03   | 12:36     | 00:33    | LINE CLEAR AVAIED |
| 1814  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - JAKKASANDRA                                     | JAKKASANDRA                                                                                                    | 11:43   | 11:47     | 00:04    | LINE CLEAR AVAIED |
| 1815  | 05-Sep-24 | BENGALURU | 66      | LINE        | 220KV SOMANAHALLI 220 - BIDADI 220 -1                          | NO STATION AFFECTED                                                                                            | 23:59   | 20:23     | 03:36    | LINE CLEAR AVAIED |
| 1816  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV D CROSS - KANASWADI                                       | KANASAWADI MUSS                                                                                                | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                             | Station_Name                                                     | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------------|------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 1817  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                              | KIADB DB PURA 220                                                | 02:23   | 02:50     | 00:27    | TRIPPED ON FAULT  |
| 1818  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                              | BYRAKUR                                                          | 11:40   | 11:50     | 00:10    | LINE CLEAR AVAIED |
| 1819  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI              | BYRAKUR                                                          | 12:08   | 12:50     | 00:42    | LINE CLEAR AVAIED |
| 1820  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | BYRAKUR                                                          | 12:50   | 12:52     | 00:02    | LINE CLEAR AVAIED |
| 1821  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV LAKSHMIPURA - SOMAYAJANAHALLI                               | GOWNIPALLI, RAYALPADU, ADDAGAL                                   | 15:07   | 17:30     | 02:23    | LINE CLEAR AVAIED |
| 1822  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | MALLASANDRA                                                      | 11:35   | 11:45     | 00:10    | TRIPPED ON FAULT  |
| 1823  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | MALLASANDRA                                                      | 11:45   | 11:50     | 00:05    | LINE CLEAR AVAIED |
| 1824  | 05-Sep-24 | BENGALURU | 220     | LINE        | 66KV RAYALAPADU - ADDAGAL                                        | GOWNIPALLI, RAYALPADU, ADDAGAL                                   | 19:12   | 19:52     | 00:40    | LINE CLEAR AVAIED |
| 1825  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                              | YELDUR                                                           | 11:25   | 12:25     | 01:00    | LINE CLEAR AVAIED |
| 1826  | 05-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                              | KANAKAPURA 220                                                   | 15:43   | 16:40     | 00:57    | TRIPPED ON FAULT  |
| 1827  | 05-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                              | KANAKAPURA 220                                                   | 15:43   | 23:59     | 08:16    | TRIPPED ON FAULT  |
| 1828  | 05-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                              | KANAKAPURA 220                                                   | 18:26   | 18:36     | 00:10    | TRIPPED ON FAULT  |
| 1829  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - AVERAHALLI                                  | AVERAHALLI AND T-BEGUR                                           | 12:28   | 12:35     | 00:07    | LINE CLEAR AVAIED |
| 1830  | 05-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - HASSAN                                   | NO STATION AFFECTED                                              | 10:43   | 18:38     | 07:55    | LINE CLEAR AVAIED |
| 1831  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | DOMMASANDRA                                                      | 17:25   | 18:00     | 00:35    | LINE CLEAR AVAIED |
| 1832  | 05-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220                             | NO STATION AFFECTED                                              | 08:11   | 19:01     | 10:50    | LINE CLEAR AVAIED |
| 1833  | 05-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                               | NO STATION AFFECTED                                              | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 1834  | 05-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220                           | NO STATION AFFECTED                                              | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 1835  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KUNUR                                      | KUNUR, HAROBELE, HUKUNDA, BIJJALAHALLI, KODIHALLI, HUNASANAHALLI | 15:43   | 16:42     | 00:59    | TRIPPED ON FAULT  |
| 1836  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - ACHALU                                     | AACHALU, HONNIGALANAHALLI, HALGURU                               | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT  |
| 1837  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI | SHIVANAHALLI KMF - DODDALAHALLI                                  | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                               | Station_Name                                                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------------------------------------------|------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 1838  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1                                                        | NO STATION AFFECTED                                              | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT    |
| 1839  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI                                            | ALLIMARADANAHALLI - CHIKKENAHALLI                                | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT    |
| 1840  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KANAKAPURA 66                                                                | KANAKAPURA 66                                                    | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT    |
| 1841  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA                                      | CHATRA, MARALWADI, GODUR                                         | 15:43   | 16:41     | 00:58    | TRIPPED ON FAULT    |
| 1842  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KUNUR                                                                        | KUNUR, HAROBELE, HUKUNDA, BIJJALAHALLI, KODIHALLI, HUNASANAHALLI | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1843  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - ACHALU                                                                       | AACHALU, HONNIGALANAHALLI, HALGURU                               | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1844  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI                                   | SHIVANAHALLI KMF - DODDALAHALLI                                  | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1845  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1                                                        | NO STATION AFFECTED                                              | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1846  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI                                            | ALLIMARADANAHALLI - CHIKKENAHALLI                                | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1847  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KANAKAPURA 66                                                                | KANAKAPURA 66                                                    | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1848  | 05-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA                                      | CHATRA, MARALWADI, GODUR                                         | 18:27   | 18:36     | 00:09    | MAIN SUPPLY FAILURE |
| 1849  | 05-Sep-24 | BENGALURU | 220     | LINE        | 220KV MAGADI 220 - ANCHEPALYA CKT 2                                                                | NO STATION AFFECTED                                              | 11:30   | 19:09     | 07:39    | LINE CLEAR AVAIED   |
| 1850  | 05-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                | AGALKOTE                                                         | 08:10   | 09:05     | 00:55    | LINE CLEAR AVAIED   |
| 1851  | 06-Sep-24 | BENGALURU | 66      | LINE        | 220KV PUTTENAHALLI 220 - KPCL 2                                                                    | NO STATION AFFECTED                                              | 17:08   | 17:45     | 00:37    | LINE CLEAR AVAIED   |
| 1852  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                                                | NO STATION AFFECTED                                              | 08:45   | 11:30     | 02:45    | TRIPPED ON FAULT    |
| 1853  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 - BMTC                                                                            | NO STATION AFFECTED                                              | 09:32   | 23:59     | 14:27    | TRIPPED ON FAULT    |
| 1854  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4 | HOSKOTE 66                                                       | 06:25   | 06:30     | 00:05    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS | Line                                                    | Station_Name                    | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-----------|---------------------------------------------------------|---------------------------------|---------|-----------|----------|---------------------|
| 1855  | 06-Sep-24 | BENGALURU | 220     | LINE      | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 1      | NO STATION AFFECTED             | 23:59   | 16:13     | 07:46    | LINE CLEAR AVAILED  |
| 1856  | 06-Sep-24 | BENGALURU | 220     | LINE      | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2      | NO STATION AFFECTED             | 23:59   | 16:13     | 07:46    | LINE CLEAR AVAILED  |
| 1857  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV KIADB DB PURA 220 - APPAREL PARK                   | APPAREL PARK                    | 18:15   | 18:39     | 00:24    | MAIN SUPPLY FAILURE |
| 1858  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - ALIPURA                         | ALIPURA                         | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1859  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - BAGEPALLI 2                        | BAGEPALLI                       | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1860  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - SOMANATHAPURA                      | SOMANATHPURA, CHELUR, CHAKAVELU | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1861  | 06-Sep-24 | BENGALURU | 220     | LINE      | 220KV GOWRIBIDANUR 220 - MADHUGIRI                      | GOWRIBIDANUR 220, MITTEMARI 220 | 18:15   | 18:40     | 00:25    | TRIPPED ON FAULT    |
| 1862  | 06-Sep-24 | BENGALURU | 220     | LINE      | 220KV GOWRIBIDANUR 220 - SIRA 1                         | GOWRIBIDANUR 220, MITTEMARI 220 | 18:15   | 18:41     | 00:26    | TRIPPED ON FAULT    |
| 1863  | 06-Sep-24 | BENGALURU | 220     | LINE      | 220KV GOWRIBIDANUR 220 - SIRA 2                         | GOWRIBIDANUR 220, MITTEMARI 220 | 18:15   | 18:41     | 00:26    | TRIPPED ON FAULT    |
| 1864  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV KIADB DB PURA - HIMAT SINGH (EHT)                  | HIMAT SINGH(EHT)                | 18:15   | 18:39     | 00:24    | MAIN SUPPLY FAILURE |
| 1865  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV KIADB DB PURA 220 - INDO MIM (EHT)                 | INDO MM(EHT)                    | 18:15   | 18:39     | 00:24    | MAIN SUPPLY FAILURE |
| 1866  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - D PALYA                         | D PALYA, GUDIBANDE, MANDIKAL    | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1867  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - PATHPALYA - GULUR                  | PATHPALYA, GULUR, THIMMAMPALLI  | 18:15   | 19:20     | 01:05    | MAIN SUPPLY FAILURE |
| 1868  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - VIDHURASHWATHA                  | VIDHURASHWATHA, GUNDLU KOTTUR   | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1869  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - RAMAPURA                        | HOSUR RAMAPURA                  | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1870  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - JULPALYA                           | JULUPALYA                       | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1871  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - KUDUMULAKUNTE                   | KUDUMULKUNTE                    | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1872  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE      | MANCHENAHALLI, GUNDAMGERE       | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1873  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - SOMENAHALLI 1                      | PERESANDRA, SOMENAHALLI         | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1874  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV MITTEMARI 220 - SOMENAHALLI 2                      | PERESANDRA, SOMENAHALLI         | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1875  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV GUNDAMGERE - D CROSS                               | D CROSS                         | 18:15   | 18:45     | 00:30    | MAIN SUPPLY FAILURE |
| 1876  | 06-Sep-24 | BENGALURU | 66      | LINE      | 66KV D CROSS - DODDABELAVANGALA - THONDEBHAVI - ALIPURA | DODDABELAVANGALA, THONDEBHAVI   | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                          | Station_Name                                                              | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------|---------------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 1877  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - VATA DAHOSA HALLI - MITTEMARI         | VATA DAHOSA HALLI                                                         | 18:15   | 19:00     | 00:45    | MAIN SUPPLY FAILURE |
| 1878  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - KIADB DB PURA 220                    | KIADB DB PURA 220                                                         | 18:15   | 18:39     | 00:24    | TRIPPED ON FAULT    |
| 1879  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA             | SUGUTUR                                                                   | 15:50   | 16:02     | 00:12    | TRIPPED ON FAULT    |
| 1880  | 06-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | NANGLI                                                                    | 12:35   | 12:40     | 00:05    | LINE CLEAR AVAILED  |
| 1881  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                             | NARASAPURA, KC VALLEY                                                     | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT    |
| 1882  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRINIVASAPURA 220 - LAKSHMIPURA 3                        | LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANA HALLI, SOLAR(IPP) | 17:16   | 17:26     | 00:10    | TRIPPED ON FAULT    |
| 1883  | 06-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | THAYALUR                                                                  | 14:28   | 15:13     | 00:45    | LINE CLEAR AVAILED  |
| 1884  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV ACHALU - HONNIGANA HALLI                                 | HONNIGANA HALLI                                                           | 09:22   | 09:23     | 00:01    | LINE CLEAR AVAILED  |
| 1885  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV ACHALU - HONNIGANA HALLI                                 | HONNIGANA HALLI, ACHALU, HALAGUR                                          | 09:38   | 10:01     | 00:23    | LINE CLEAR AVAILED  |
| 1886  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA | CHATHRA, MANIYAMBAL, MARALWAVADI, GODUR                                   | 20:25   | 20:29     | 00:04    | LINE CLEAR AVAILED  |
| 1887  | 06-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | KANAKAPURA 66                                                             | 15:07   | 15:12     | 00:05    | TRIPPED ON FAULT    |
| 1888  | 06-Sep-24 | BENGALURU | 220     | TRANSFORMER | LV1                                                           | BIDADI 220                                                                | 14:47   | 14:56     | 00:09    | TRIPPED ON FAULT    |
| 1889  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANA HALLI - HEJJALA 1                    | HEJJALA                                                                   | 14:50   | 15:20     | 00:30    | LINE CLEAR AVAILED  |
| 1890  | 06-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANA HALLI - HEJJALA 1                    | HEJJALA                                                                   | 17:05   | 17:10     | 00:05    | LINE CLEAR AVAILED  |
| 1891  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                            | NO STATION AFFECTED                                                       | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED  |
| 1892  | 06-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | BEVOOR                                                                    | 01:15   | 01:20     | 00:05    | TRIPPED ON FAULT    |
| 1893  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220                        | NO STATION AFFECTED                                                       | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 1894  | 06-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                                        | TK HALLI 220                                                              | 09:50   | 11:18     | 01:28    | LINE CLEAR AVAILED  |
| 1895  | 06-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | SARJAPURA 220                                                             | 11:12   | 11:19     | 00:07    | TRIPPED ON FAULT    |
| 1896  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 1                    | SOMESHWARA 220                                                            | 18:15   | 18:44     | 00:29    | TRIPPED ON FAULT    |
| 1897  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - RVNL SOMESHWARA 2                    | SOMESHWARA 220                                                            | 18:15   | 18:44     | 00:29    | TRIPPED ON FAULT    |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name                                                                 | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|------------------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 1898  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - MITTEMARI 1          | MITTEMARI 220                                                                | 18:15   | 18:41     | 00:26    | MAIN SUPPLY FAILURE |
| 1899  | 06-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - MITTEMARI 2          | MITTEMARI 220                                                                | 18:15   | 18:41     | 00:26    | MAIN SUPPLY FAILURE |
| 1900  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | ATTUR YELAHANKA                                                              | 00:05   | 02:57     | 02:52    | TRIPPED ON FAULT    |
| 1901  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | ATTUR YELAHANKA                                                              | 00:05   | 03:40     | 03:35    | TRIPPED ON FAULT    |
| 1902  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | LR BANDE                                                                     | 09:37   | 12:08     | 02:31    | TRIPPED ON FAULT    |
| 1903  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 - BMTC                       | NO STATION AFFECTED                                                          | 10:35   | 23:59     | 13:24    | LINE CLEAR AVAIED   |
| 1904  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | CHINTAMANI 66                                                                | 17:21   | 17:35     | 00:14    | TRIPPED ON FAULT    |
| 1905  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | G KODIHALLI                                                                  | 16:40   | 16:50     | 00:10    | LINE CLEAR AVAIED   |
| 1906  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMENAHALLI - NALLIMARADANAHALLI         | NALLIMARADANAHALLI                                                           | 08:45   | 08:50     | 00:05    | LINE CLEAR AVAIED   |
| 1907  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUDUMULAKUNTE - THERIYUR                 | THERIYUR, VENKATAPURA                                                        | 04:25   | 04:50     | 00:25    | TRIPPED ON FAULT    |
| 1908  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)             | NARASAPURA, KC VALLEY                                                        | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT    |
| 1909  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE       | AGALAKOTE, MATHIKERE                                                         | 12:18   | 12:36     | 00:18    | TRIPPED ON FAULT    |
| 1910  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV JALAMANGALA - MATHIKERE                  | JALAMANGALA, CHIKKAGANGANAWADI, KUTAGAL, MELEHALLI                           | 12:18   | 17:20     | 05:02    | TRIPPED ON FAULT    |
| 1911  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1     | HEJJALA                                                                      | 16:19   | 16:35     | 00:16    | TRIPPED ON FAULT    |
| 1912  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI | KEMPANAHALLI, URAGAHALLI                                                     | 14:35   | 15:17     | 00:42    | LINE CLEAR AVAIED   |
| 1913  | 07-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI | KEMPANAHALLI, URAGAHALLI, MELEHALLI, KUTAGAL, CHIKKAGANGANAWADI, JALAMANGALA | 16:37   | 17:15     | 00:38    | LINE CLEAR AVAIED   |
| 1914  | 07-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220        | NO STATION AFFECTED                                                          | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 1915  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | SANKALGERE                                                                   | 07:15   | 07:25     | 00:10    | TRIPPED ON FAULT    |
| 1916  | 07-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220          | NO STATION AFFECTED                                                          | 17:04   | 19:24     | 02:20    | LINE CLEAR AVAIED   |
| 1917  | 07-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | YARANDANAHALLI 220                                                           | 15:04   | 15:31     | 00:27    | TRIPPED ON FAULT    |
| 1918  | 07-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2            | NO STATION AFFECTED                                                          | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                               | Station_Name         | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------------------|----------------------|---------|-----------|----------|---------------------|
| 1919  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II | BIEC, ALUR           | 07:33   | 08:58     | 01:25    | MAIN SUPPLY FAILURE |
| 1920  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV NELAMANGALA 66 - ALUR                                         | ALUR                 | 09:14   | 09:19     | 00:05    | LINE CLEAR AVAIED   |
| 1921  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOKULA - BEL EHT                                              | BEL(EHT)             | 10:13   | 11:53     | 01:40    | LINE CLEAR AVAIED   |
| 1922  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - MEI LAYOUT                                   | MEI LAYOUT, WIDIA    | 07:32   | 07:35     | 00:03    | LINE CLEAR AVAIED   |
| 1923  | 08-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | TRIPPED ON FAULT    |
| 1924  | 08-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | TRIPPED ON FAULT    |
| 1925  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | MAIN SUPPLY FAILURE |
| 1926  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | MAIN SUPPLY FAILURE |
| 1927  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | MAIN SUPPLY FAILURE |
| 1928  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                                                | SRS PEENYA 220       | 07:40   | 08:40     | 01:00    | MAIN SUPPLY FAILURE |
| 1929  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - AUSTIN TOWN                                         | AUSTIN TOWN          | 10:58   | 11:05     | 00:07    | LINE CLEAR AVAIED   |
| 1930  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - AUSTIN TOWN 1                               | AUSTIN TOWN          | 16:12   | 16:18     | 00:06    | LINE CLEAR AVAIED   |
| 1931  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV NAGANATHAPURA 220 - HSR LAYOUT 220                           | NO STATION AFFECTED  | 09:10   | 15:54     | 06:44    | LINE CLEAR AVAIED   |
| 1932  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                              | NO STATION AFFECTED  | 09:38   | 17:38     | 08:00    | LINE CLEAR AVAIED   |
| 1933  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BWSSB HAROHALI 220                         | NO STATION AFFECTED  | 16:02   | 19:01     | 02:59    | LINE CLEAR AVAIED   |
| 1934  | 08-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                | SOMANAHALLI 220      | 11:27   | 17:01     | 05:34    | LINE CLEAR AVAIED   |
| 1935  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - HSR LAYOUT 2                                | NO STATION AFFECTED  | 09:54   | 15:52     | 05:58    | LINE CLEAR AVAIED   |
| 1936  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - RBI - SOUTH CITY (JIGANI 1)                 | RBI                  | 09:42   | 09:47     | 00:05    | LINE CLEAR AVAIED   |
| 1937  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV RBI - ELITA PROMENADE                                         | RBI                  | 17:49   | 17:53     | 00:04    | LINE CLEAR AVAIED   |
| 1938  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                | D PALYA              | 15:27   | 15:32     | 00:05    | TRIPPED ON FAULT    |
| 1939  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - ALIPURA                                    | ALIPURA, THONDEBHAVI | 18:30   | 18:45     | 00:15    | TRIPPED ON FAULT    |
| 1940  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV BAGEPALLI - GULUR                                             | NO STATION AFFECTED  | 07:17   | 07:37     | 00:20    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                        | Station_Name                 | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------|------------------------------|---------|-----------|----------|---------------------|
| 1941  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | MITTEMARI 220                | 04:57   | 05:47     | 00:50    | TRIPPED ON FAULT    |
| 1942  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)           | NARASAPURA, KC VALLEY        | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT    |
| 1943  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | MAASTHI                      | 12:45   | 13:00     | 00:15    | LINE CLEAR AVAIED   |
| 1944  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | HEJJALA                      | 11:20   | 11:25     | 00:05    | TRIPPED ON FAULT    |
| 1945  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 - HEJJALA              | HEJJALA                      | 18:15   | 18:25     | 00:10    | LINE CLEAR AVAIED   |
| 1946  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2          | NO STATION AFFECTED          | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED   |
| 1947  | 08-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220      | NO STATION AFFECTED          | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 1948  | 08-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | ATTIBELE                     | 10:15   | 10:35     | 00:20    | LINE CLEAR AVAIED   |
| 1949  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV JIGANI 220 - KUMBARANAHALLI            | KUMBARANAHALLI, BAGGANADODDI | 08:03   | 08:41     | 00:38    | TRIPPED ON FAULT    |
| 1950  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV JIGANI 220 - KUMBARANAHALLI            | KUMBARANAHALLI, BAGGANADODDI | 08:50   | 09:00     | 00:10    | TRIPPED ON FAULT    |
| 1951  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                  | NO STATION AFFECTED          | 13:18   | 13:32     | 00:14    | TRIPPED ON FAULT    |
| 1952  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1 | ELECTRONIC CITY, HULIMANGALA | 11:42   | 12:06     | 00:24    | TRIPPED ON FAULT    |
| 1953  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV SULIBELE - CHANNARAYAPATNA             | CHANNARAYAPATNA              | 01:03   | 01:37     | 00:34    | TRIPPED ON FAULT    |
| 1954  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - D CROSS 1            | GUNDAMGERE, SASALU           | 05:55   | 06:25     | 00:30    | TRIPPED ON FAULT    |
| 1955  | 08-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - D CROSS 2            | DODDABELAVANGALA, AIR(EHT)   | 05:55   | 06:25     | 00:30    | TRIPPED ON FAULT    |
| 1956  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | BANASAWADI                   | 00:09   | 00:19     | 00:10    | MAIN SUPPLY FAILURE |
| 1957  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                         | BANASAWADI                   | 00:09   | 00:19     | 00:10    | MAIN SUPPLY FAILURE |
| 1958  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | MAHALAKSHMI LAYOUT           | 18:41   | 18:46     | 00:05    | LINE CLEAR AVAIED   |
| 1959  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                         | MAHALAKSHMI LAYOUT           | 18:41   | 18:46     | 00:05    | LINE CLEAR AVAIED   |
| 1960  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV SRS PEENYA 220 - NRS 220              | NO STATION AFFECTED          | 22:14   | 23:37     | 01:23    | LINE CLEAR AVAIED   |
| 1961  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                         | NRS 220                      | 18:42   | 18:50     | 00:08    | LINE CLEAR AVAIED   |
| 1962  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - BANASHANKARI       | BANASHANKARI                 | 23:36   | 23:59     | 00:23    | LINE CLEAR AVAIED   |
| 1963  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | EPIP 220                     | 15:44   | 16:14     | 00:30    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                           | Station_Name                           | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------|----------------------------------------|---------|-----------|----------|-------------------|
| 1964  | 09-Sep-24 | BENGALURU | 400     | LINE        | HOODY 400 - KOLAR 1                                            | NO STATION AFFECTED                    | 00:16   | 05:44     | 05:28    | LINE CLEAR AVAIED |
| 1965  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION) | MINOR IRRIGATION, DIVYASHREE TECH PARK | 12:17   | 12:22     | 00:05    | TRIPPED ON FAULT  |
| 1966  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KEONISC (ELECTRONIC CITY) - INFOSIS EHT                   | INFOSYS(EHT)                           | 10:30   | 10:55     | 00:25    | LINE CLEAR AVAIED |
| 1967  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                          | NO STATION AFFECTED                    | 08:55   | 17:32     | 08:37    | LINE CLEAR AVAIED |
| 1968  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BWSSB HAROHALI 220                     | NO STATION AFFECTED                    | 12:25   | 18:41     | 06:16    | LINE CLEAR AVAIED |
| 1969  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | KONDASAPURA                            | 02:12   | 02:22     | 00:10    | TRIPPED ON FAULT  |
| 1970  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHINTAMANI 220 - SRINIVASAPURA 2                         | NO STATION AFFECTED                    | 17:03   | 18:12     | 01:09    | LINE CLEAR AVAIED |
| 1971  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - MADHUGIRI                             | NO STATION AFFECTED                    | 16:23   | 19:16     | 02:53    | LINE CLEAR AVAIED |
| 1972  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV MITTEMARI 220 - SOMENAHALLI 2                             | NO STATION AFFECTED                    | 13:30   | 13:34     | 00:04    | LINE CLEAR AVAIED |
| 1973  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV MITTEMARI 220 - PATHPALYA - GULUR                         | PATHPALYA                              | 15:25   | 15:50     | 00:25    | TRIPPED ON FAULT  |
| 1974  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV PATHPALYA - THIMMAMPALLI                                  | THIMMAMPALLI                           | 15:25   | 15:50     | 00:25    | TRIPPED ON FAULT  |
| 1975  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | PATHPALYA                              | 15:50   | 15:55     | 00:05    | LINE CLEAR AVAIED |
| 1976  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | THONDEBHAVI                            | 18:55   | 19:05     | 00:10    | TRIPPED ON FAULT  |
| 1977  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                                     | VEMGAL, KYALANUR                       | 10:09   | 10:10     | 00:01    | LINE CLEAR AVAIED |
| 1978  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                                     | TALAGUNDA                              | 17:40   | 18:40     | 01:00    | LINE CLEAR AVAIED |
| 1979  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                                     | TALAGUNDA                              | 10:00   | 11:10     | 01:10    | LINE CLEAR AVAIED |
| 1980  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                     | KYALANUR, VEMGAL                       | 18:48   | 18:51     | 00:03    | LINE CLEAR AVAIED |
| 1981  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV THAYALUR - MN HALLI (MALLANAYAKANAHALLI)                  | MALLANAYAKANAHALLI                     | 12:17   | 13:12     | 00:55    | LINE CLEAR AVAIED |
| 1982  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV AVANI - MULABAGAL                                         | MULBAGAL                               | 14:47   | 15:49     | 01:02    | LINE CLEAR AVAIED |
| 1983  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | MULBAGAL                               | 15:49   | 16:32     | 00:43    | LINE CLEAR AVAIED |
| 1984  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | MULBAGAL                               | 16:36   | 16:41     | 00:05    | TRIPPED ON FAULT  |
| 1985  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | MULBAGAL                               | 16:41   | 17:31     | 00:50    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                             | Station_Name                                                  | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------|---------------------------------------------------------------|---------|-----------|----------|-------------------|
| 1986  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | NANGLI                                                        | 11:25   | 11:50     | 00:25    | LINE CLEAR AVAIED |
| 1987  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | NANGLI                                                        | 15:15   | 15:25     | 00:10    | TRIPPED ON FAULT  |
| 1988  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                | NARASAPURA, KC VALLEY                                         | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT  |
| 1989  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | TALAGUNDA                                                     | 09:25   | 09:45     | 00:20    | TRIPPED ON FAULT  |
| 1990  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                              | THAYALUR                                                      | 10:55   | 11:25     | 00:30    | LINE CLEAR AVAIED |
| 1991  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | THAYALUR                                                      | 11:30   | 11:55     | 00:25    | LINE CLEAR AVAIED |
| 1992  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV THAYALUR - NG HULKURU                       | NG HULKUR                                                     | 11:55   | 12:40     | 00:45    | LINE CLEAR AVAIED |
| 1993  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - THAYALUR                 | THAYALUR, NG HULKUR                                           | 12:18   | 12:40     | 00:22    | LINE CLEAR AVAIED |
| 1994  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | MAASTHI                                                       | 12:00   | 13:23     | 01:23    | LINE CLEAR AVAIED |
| 1995  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KODIHALLI - BIJJALLI - HUNASENAHALLI        | BIJJAHALLI                                                    | 13:00   | 18:15     | 05:15    | LINE CLEAR AVAIED |
| 1996  | 09-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                              | KANAKAPURA 220                                                | 15:43   | 23:59     | 08:16    | LINE CLEAR AVAIED |
| 1997  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KUNUR                      | KUNUR, HAROBELE, HUKUNDA, KODIHALLI, BIJJAHALLI, HUNSENAHALLI | 05:32   | 05:46     | 00:14    | TRIPPED ON FAULT  |
| 1998  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - RANGANADODDI - SOMANAHALLI | NO STATION AFFECTED                                           | 12:45   | 23:59     | 11:14    | LINE CLEAR AVAIED |
| 1999  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | HOSPALYA CIRCLE                                               | 18:16   | 18:21     | 00:05    | TRIPPED ON FAULT  |
| 2000  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2               | NO STATION AFFECTED                                           | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED |
| 2001  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220           | NO STATION AFFECTED                                           | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 2002  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR      | BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE                   | 13:57   | 14:04     | 00:07    | TRIPPED ON FAULT  |
| 2003  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220             | NO STATION AFFECTED                                           | 06:43   | 10:49     | 04:06    | LINE CLEAR AVAIED |
| 2004  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220             | NO STATION AFFECTED                                           | 12:23   | 18:45     | 06:22    | LINE CLEAR AVAIED |
| 2005  | 09-Sep-24 | BENGALURU | 220     | LINE        | 220KV KANAKAPURA 220 - TK HALLI 220              | NO STATION AFFECTED                                           | 06:43   | 11:58     | 05:15    | LINE CLEAR AVAIED |
| 2006  | 09-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                              | JIGANI 220                                                    | 01:09   | 01:32     | 00:23    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                   | Station_Name                      | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------|-----------------------------------|---------|-----------|----------|---------------------|
| 2007  | 09-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                             | NO STATION AFFECTED               | 17:28   | 17:45     | 00:17    | TRIPPED ON FAULT    |
| 2008  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4        | ATTUR, PLATINUM CITY              | 10:55   | 11:06     | 00:11    | TRIPPED ON FAULT    |
| 2009  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV ABBIGERE - ATTURU - MANYATA DG-3                  | ATTUR YELAHANKA                   | 14:48   | 14:58     | 00:10    | LINE CLEAR AVAIED   |
| 2010  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | BANASAWADI                        | 00:09   | 01:06     | 00:57    | MAIN SUPPLY FAILURE |
| 2011  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                    | BANASAWADI                        | 00:09   | 01:06     | 00:57    | MAIN SUPPLY FAILURE |
| 2012  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV HEBBAL 220 - BANASAWADI - POTTERY ROAD (TAP LINE) | BANASAWADI                        | 00:09   | 00:19     | 00:10    | TRIPPED ON FAULT    |
| 2013  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - MAHALAKSHMI LAYOUT               | MAHALAKSHMI LAYOUT                | 08:06   | 08:24     | 00:18    | MAIN SUPPLY FAILURE |
| 2014  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - MAHALAKSHMI LAYOUT                      | MAHALAKSHMI LAYOUT                | 11:02   | 13:57     | 02:55    | LINE CLEAR AVAIED   |
| 2015  | 10-Sep-24 | BENGALURU | 66      | LINE        | 220KV NRS 220 - VRUSHABHAVATI 220                      | NO STATION AFFECTED               | 11:27   | 15:00     | 03:33    | LINE CLEAR AVAIED   |
| 2016  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV HEBBAL 220 - IISC                                 | IISc                              | 15:40   | 15:45     | 00:05    | LINE CLEAR AVAIED   |
| 2017  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - NANDINI LAYOUT                   | NANDINI LAYOUT                    | 08:06   | 08:24     | 00:18    | MAIN SUPPLY FAILURE |
| 2018  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BRINDAVAN HTLS                   | NANINI LAYOUT, MAHALAKSHMI LAYOUT | 08:06   | 08:32     | 00:26    | TRIPPED ON FAULT    |
| 2019  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV WELCAST STEEL - ABBIGERE                          | WELCAST                           | 11:25   | 11:30     | 00:05    | LINE CLEAR AVAIED   |
| 2020  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - WELCAST STEEL DG-3               | WELCAST                           | 18:09   | 18:12     | 00:03    | LINE CLEAR AVAIED   |
| 2021  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV HAL 220 - AMARJYOTHI 2 - LEELAVENTURE (TAP)       | AMARJYOTHI, GOLF LINK             | 10:48   | 10:55     | 00:07    | TRIPPED ON FAULT    |
| 2022  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | LEELA VENTURE                     | 05:49   | 06:20     | 00:31    | TRIPPED ON FAULT    |
| 2023  | 10-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                    | SHOBHA DREAMS 220                 | 10:45   | 12:35     | 01:50    | LINE CLEAR AVAIED   |
| 2024  | 10-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                    | SHOBHA DREAMS 220                 | 12:48   | 14:20     | 01:32    | LINE CLEAR AVAIED   |
| 2025  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                  | NO STATION AFFECTED               | 08:41   | 18:24     | 09:43    | LINE CLEAR AVAIED   |
| 2026  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BWSSB HAROHALLI 220            | NO STATION AFFECTED               | 10:36   | 19:11     | 08:35    | LINE CLEAR AVAIED   |
| 2027  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | ISRO LAYOUT                       | 08:24   | 08:36     | 00:12    | TRIPPED ON FAULT    |
| 2028  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 1        | NO STATION AFFECTED               | 18:33   | 19:10     | 00:37    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                             | Station_Name                           | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------|----------------------------------------|---------|-----------|----------|--------------------|
| 2029  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BIAL<br>BEGUR 220         | NO STATION AFFECTED                    | 05:29   | 05:51     | 00:22    | TRIPPED ON FAULT   |
| 2030  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                              | IRAGAMPALLI                            | 15:48   | 16:02     | 00:14    | TRIPPED ON FAULT   |
| 2031  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                              | M GOLLAHALLI                           | 12:10   | 12:22     | 00:12    | TRIPPED ON FAULT   |
| 2032  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>VIJAYAPURA             | VIJAYAPURA, JANGAMKOTE                 | 06:11   | 06:27     | 00:16    | TRIPPED ON FAULT   |
| 2033  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 220 -<br>SIDDALAGHATTA           | SIDDALAGHATTA, MELUR                   | 01:38   | 01:47     | 00:09    | TRIPPED ON FAULT   |
| 2034  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | SOMANATHPURA                           | 13:05   | 13:25     | 00:20    | LINE CLEAR AVAILED |
| 2035  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                       | VEMGAL, KYALANUR                       | 10:00   | 10:05     | 00:05    | LINE CLEAR AVAILED |
| 2036  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                       | VEMGAL, KYALANUR                       | 18:41   | 18:45     | 00:04    | LINE CLEAR AVAILED |
| 2037  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | LAKSHMIPURA                            | 12:05   | 12:10     | 00:05    | LINE CLEAR AVAILED |
| 2038  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | LAKSHMIPURA                            | 17:55   | 18:08     | 00:13    | TRIPPED ON FAULT   |
| 2039  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY<br>(EHT)             | NARASAPURA, KC VALLEY                  | 23:59   | 10:45     | 13:14    | TRIPPED ON FAULT   |
| 2040  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY<br>(EHT)             | NARASAPURA, KC VALLEY                  | 11:30   | 23:59     | 12:29    | TRIPPED ON FAULT   |
| 2041  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                       | TALAGUNDA                              | 10:00   | 10:45     | 00:45    | LINE CLEAR AVAILED |
| 2042  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                       | TALAGUNDA                              | 17:40   | 18:35     | 00:55    | LINE CLEAR AVAILED |
| 2043  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - LAKKUR                          | LAKKUR, DEVANAGUNDHI                   | 15:10   | 15:25     | 00:15    | LINE CLEAR AVAILED |
| 2044  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - LAKKUR                          | LAKKUR, DEVANAGUNDHI                   | 01:10   | 01:25     | 00:15    | TRIPPED ON FAULT   |
| 2045  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                              | AGALAKOTE                              | 16:00   | 16:35     | 00:35    | LINE CLEAR AVAILED |
| 2046  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV DABASPETE 220 - KADUR<br>220               | NO STATION AFFECTED                    | 11:10   | 18:09     | 06:59    | LINE CLEAR AVAILED |
| 2047  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                              | HOSPALYA CIRCLE                        | 09:00   | 09:05     | 00:05    | TRIPPED ON FAULT   |
| 2048  | 10-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 -<br>HIRIYUR 1             | NO STATION AFFECTED                    | 16:48   | 23:59     | 07:11    | TRIPPED ON FAULT   |
| 2049  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - BIDADI<br>220 -1           | NO STATION AFFECTED                    | 12:15   | 13:34     | 01:19    | LINE CLEAR AVAILED |
| 2050  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 -<br>MELEHALLI - KEMPANAHALLI | KEMPANAHALLI, MELEHALLI,<br>URAGAHALLI | 11:27   | 11:37     | 00:10    | LINE CLEAR AVAILED |
| 2051  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV URAGAHALLI -<br>KEMPANAHALLI                | KEMPANAHALLI, MELEHALLI,<br>URAGAHALLI | 13:45   | 13:50     | 00:05    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name               | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|----------------------------|---------|-----------|----------|---------------------|
| 2052  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2            | NO STATION AFFECTED        | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED  |
| 2053  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220        | NO STATION AFFECTED        | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 2054  | 10-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220          | NO STATION AFFECTED        | 10:35   | 19:15     | 08:40    | LINE CLEAR AVAILED  |
| 2055  | 10-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                        | NO STATION AFFECTED        | 18:32   | 18:44     | 00:12    | TRIPPED ON FAULT    |
| 2056  | 10-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | ANEKAL                     | 15:04   | 15:10     | 00:06    | TRIPPED ON FAULT    |
| 2057  | 10-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                    | NO STATION AFFECTED        | 07:10   | 07:23     | 00:13    | TRIPPED ON FAULT    |
| 2058  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - SAHAKARNAGAR 220      | NO STATION AFFECTED        | 04:54   | 19:33     | 14:39    | TRIPPED ON FAULT    |
| 2059  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV SRS PEENYA 220 - SAHAKARNAGAR 220       | NO STATION AFFECTED        | 23:35   | 23:38     | 00:03    | LINE CLEAR AVAILED  |
| 2060  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV A STATION 220 - NRS 220                 | A STATION 220, NRS 220     | 11:31   | 11:40     | 00:09    | MAIN SUPPLY FAILURE |
| 2061  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV A STATION 220 - EDC 220                 | A STATION 220              | 11:31   | 11:42     | 00:11    | MAIN SUPPLY FAILURE |
| 2062  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | A STATION 66               | 11:31   | 11:42     | 00:11    | MAIN SUPPLY FAILURE |
| 2063  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | A STATION 66               | 11:31   | 11:42     | 00:11    | MAIN SUPPLY FAILURE |
| 2064  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                           | A STATION 66               | 11:31   | 11:42     | 00:11    | MAIN SUPPLY FAILURE |
| 2065  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KANTEERAVA                 | 11:31   | 11:50     | 00:19    | MAIN SUPPLY FAILURE |
| 2066  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | KANTEERAVA                 | 11:31   | 11:50     | 00:19    | MAIN SUPPLY FAILURE |
| 2067  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - MAHALAKSHMI LAYOUT             | NO STATION AFFECTED        | 10:47   | 11:59     | 01:12    | LINE CLEAR AVAILED  |
| 2068  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - TELECOM LAYOUT 1               | TELECOM LAYOUT             | 11:31   | 11:46     | 00:15    | MAIN SUPPLY FAILURE |
| 2069  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - BRIGADE GATEWAY                | BRIGADE GATEWAY            | 11:31   | 11:48     | 00:17    | MAIN SUPPLY FAILURE |
| 2070  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                      | PALLADIUM                  | 11:31   | 11:47     | 00:16    | MAIN SUPPLY FAILURE |
| 2071  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - SHOBHA INDRAPRASTHA (A1) | SHOBHA INDRAPRASTHA        | 11:31   | 11:52     | 00:21    | MAIN SUPPLY FAILURE |
| 2072  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - VICTORIA HOSPITAL        | VICTORIA, NATIONAL COLLEGE | 11:31   | 11:50     | 00:19    | MAIN SUPPLY FAILURE |
| 2073  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - IISC                           | IISc                       | 09:10   | 09:12     | 00:02    | LINE CLEAR AVAILED  |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                     | Station_Name                          | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------------------------|---------------------------------------|---------|-----------|----------|---------------------|
| 2074  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - NANDINI LAYOUT                                            | NANDINI LAYOUT                        | 09:03   | 09:11     | 00:08    | LINE CLEAR AVAILED  |
| 2075  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                      | NANDINI LAYOUT                        | 09:03   | 09:11     | 00:08    | LINE CLEAR AVAILED  |
| 2076  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV EDC 220 - HAL 220                                                  | EAST DIVISION COMPOUND 220            | 11:31   | 11:46     | 00:15    | TRIPPED ON FAULT    |
| 2077  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP) | K&C VALLEY, MINOR IRRIGATION          | 11:31   | 13:06     | 01:35    | MAIN SUPPLY FAILURE |
| 2078  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - AUSTIN TOWN                                               | AUSTIN TOWN                           | 11:31   | 11:53     | 00:22    | MAIN SUPPLY FAILURE |
| 2079  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - BMTc                                                      | BMTc                                  | 11:31   | 11:57     | 00:26    | MAIN SUPPLY FAILURE |
| 2080  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 - JAYADEVA                                              | JAYADEVA, SARAkKI                     | 11:31   | 12:04     | 00:33    | MAIN SUPPLY FAILURE |
| 2081  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 - JAYANAGAR GIS                                         | JAYANAGARA                            | 11:31   | 12:03     | 00:32    | MAIN SUPPLY FAILURE |
| 2082  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV HSR LAYOUT 220 - KORAMANGALA 220                                   | KORAMANGALA 220, NIMHANS 220          | 11:32   | 11:55     | 00:23    | TRIPPED ON FAULT    |
| 2083  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NAGANATHPURA 220 - ELECTRONIC CITY PH 2 SEC 1 (VELANKANI)           | ELECTRONIC CITY PH 2 SEC 1(VELANKANI) | 15:55   | 16:12     | 00:17    | TRIPPED ON FAULT    |
| 2084  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                                    | NO STATION AFFECTED                   | 08:31   | 18:16     | 09:45    | LINE CLEAR AVAILED  |
| 2085  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BWSSB HAROHALLI 220                              | NO STATION AFFECTED                   | 11:10   | 18:35     | 07:25    | LINE CLEAR AVAILED  |
| 2086  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BIDADI 220 -2                                    | NO STATION AFFECTED                   | 08:41   | 23:59     | 15:18    | LINE CLEAR AVAILED  |
| 2087  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA (SAFAL)           | KONDASAPURA                           | 10:46   | 10:50     | 00:04    | LINE CLEAR AVAILED  |
| 2088  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                      | SULIBELE                              | 13:00   | 13:45     | 00:45    | LINE CLEAR AVAILED  |
| 2089  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV SIDDALAGHATTA - MELUR                                               | MELUR                                 | 14:31   | 14:40     | 00:09    | LINE CLEAR AVAILED  |
| 2090  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1                           | DEVANAHALLI, KUNDANA                  | 05:24   | 05:40     | 00:16    | TRIPPED ON FAULT    |
| 2091  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - DEVANAHALLI 2                                     | DEVANAHALLI                           | 05:24   | 05:40     | 00:16    | TRIPPED ON FAULT    |
| 2092  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - VIJAYAPURA                                        | VIJAYAPURA                            | 12:46   | 13:29     | 00:43    | LINE CLEAR AVAILED  |
| 2093  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIJAYAPURA - JANGAMKOTE - MELUR                                     | JANGAMKOTE                            | 12:44   | 12:49     | 00:05    | LINE CLEAR AVAILED  |
| 2094  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIJAYAPURA - JANGAMKOTE - MELUR                                     | JANGAMKOTE                            | 13:35   | 14:40     | 01:05    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                        | Station_Name                                                    | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|---------------------------------------------|-----------------------------------------------------------------|---------|-----------|----------|--------------------|
| 2095  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | KUNDANA                                                         | 11:20   | 11:40     | 00:20    | LINE CLEAR AVAILED |
| 2096  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | SOMANATHPURA                                                    | 07:40   | 10:00     | 02:20    | LINE CLEAR AVAILED |
| 2097  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                  | VEMGAL, KYALANUR, TALAGUNDA                                     | 10:00   | 10:07     | 00:07    | LINE CLEAR AVAILED |
| 2098  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGUNDA - VEMGAL                     | TALAGUNDA                                                       | 17:22   | 18:04     | 00:42    | LINE CLEAR AVAILED |
| 2099  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                  | KYALANUR, VEMGAL                                                | 18:16   | 18:21     | 00:05    | LINE CLEAR AVAILED |
| 2100  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)           | NARASAPURA, KC VALLEY                                           | 23:59   | 17:10     | 06:49    | TRIPPED ON FAULT   |
| 2101  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - KGF 1               | NO STATION AFFECTED                                             | 09:41   | 10:21     | 00:40    | TRIPPED ON FAULT   |
| 2102  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV KGF - BEML (EHT)                       | BEML                                                            | 13:53   | 14:31     | 00:38    | LINE CLEAR AVAILED |
| 2103  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - KGF 1               | NO STATION AFFECTED                                             | 15:37   | 16:40     | 01:03    | LINE CLEAR AVAILED |
| 2104  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV KGF - KAMASAMUDRA                      | KAMASAMUDRA                                                     | 16:11   | 16:37     | 00:26    | LINE CLEAR AVAILED |
| 2105  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                         | KGF                                                             | 11:07   | 11:45     | 00:38    | LINE CLEAR AVAILED |
| 2106  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | KGF                                                             | 11:33   | 12:00     | 00:27    | LINE CLEAR AVAILED |
| 2107  | 11-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                         | KGF                                                             | 12:00   | 12:50     | 00:50    | LINE CLEAR AVAILED |
| 2108  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV DABASPETE 220 - KADUR 220             | NO STATION AFFECTED                                             | 12:32   | 15:48     | 03:16    | LINE CLEAR AVAILED |
| 2109  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE     | AGALAKOTE, MATHIKERE, CHIKKAGANGANAWADI, JALAMANGALA, MELEHALLI | 05:45   | 06:07     | 00:22    | TRIPPED ON FAULT   |
| 2110  | 11-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - HIRIYUR 1           | NO STATION AFFECTED                                             | 23:59   | 19:17     | 04:42    | TRIPPED ON FAULT   |
| 2111  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2          | NO STATION AFFECTED                                             | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED |
| 2112  | 11-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR | BEVOOR, DASHAVARA, VANDARAGUPPE, SANKALGERE                     | 13:22   | 13:32     | 00:10    | TRIPPED ON FAULT   |
| 2113  | 11-Sep-24 | BENGALURU | 220     | LINE        | 220KV EPIP 220 - HSR LAYOUT 220             | NO STATION AFFECTED                                             | 11:40   | 14:30     | 02:50    | TRIPPED ON FAULT   |
| 2114  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV ABBIGERE - ATTURU - MANYATA DG-3       | ABBIGERE                                                        | 14:05   | 14:15     | 00:10    | LINE CLEAR AVAILED |
| 2115  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                         | IISc                                                            | 16:52   | 16:56     | 00:04    | LINE CLEAR AVAILED |
| 2116  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV WELCAST STEEL - ABBIGERE               | WELCAST STEEL                                                   | 13:55   | 13:58     | 00:03    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                           | Station_Name                | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------|-----------------------------|---------|-----------|----------|-------------------|
| 2117  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - WELCAST STEEL DG-3                       | WELCAST STEEL               | 18:15   | 18:21     | 00:06    | LINE CLEAR AVAIED |
| 2118  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                            | EMBASSY TECH PARK           | 07:50   | 08:09     | 00:19    | TRIPPED ON FAULT  |
| 2119  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | SHOBHA DREAMS 66            | 11:00   | 11:05     | 00:05    | LINE CLEAR AVAIED |
| 2120  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | SHOBHA DREAMS 66            | 14:05   | 14:10     | 00:05    | LINE CLEAR AVAIED |
| 2121  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV DIVYASREE TECH PARK - KACHAMARANAHALLI (MINOR IRRIGATION) | NO STATION AFFECTED         | 12:10   | 16:05     | 03:55    | LINE CLEAR AVAIED |
| 2122  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV NATIONAL COLLEGE - JAYANAGARA GIS                         | NATIONAL COLLEGE            | 14:03   | 23:59     | 09:56    | LINE CLEAR AVAIED |
| 2123  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                          | NO STATION AFFECTED         | 08:41   | 18:56     | 10:15    | LINE CLEAR AVAIED |
| 2124  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BWSSB HAROHALLI 220                    | NO STATION AFFECTED         | 08:45   | 18:48     | 10:03    | LINE CLEAR AVAIED |
| 2125  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - BIDADI 220 -2                          | NO STATION AFFECTED         | 23:59   | 18:16     | 05:43    | LINE CLEAR AVAIED |
| 2126  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | RR NAGAR                    | 14:15   | 14:19     | 00:04    | LINE CLEAR AVAIED |
| 2127  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA                              | PILLAGUMPA                  | 10:20   | 10:29     | 00:09    | LINE CLEAR AVAIED |
| 2128  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV BURUDAGUNTE - GANJIGUNTE - DIBBURHALLI                    | BURUDAGUNTE, DIBBURAHALLI   | 05:40   | 05:56     | 00:16    | TRIPPED ON FAULT  |
| 2129  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | DODDABELAVANGALA            | 08:40   | 09:05     | 00:25    | LINE CLEAR AVAIED |
| 2130  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | DODDABELAVANGALA            | 11:05   | 11:55     | 00:50    | LINE CLEAR AVAIED |
| 2131  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | GUNDAMGERE                  | 15:20   | 15:45     | 00:25    | TRIPPED ON FAULT  |
| 2132  | 12-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                            | GOWRIBIDANUR 220            | 17:04   | 17:45     | 00:41    | LINE CLEAR AVAIED |
| 2133  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                                     | VEMGAL, KYALANUR, TALAGUNDA | 10:00   | 10:05     | 00:05    | LINE CLEAR AVAIED |
| 2134  | 12-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                     | KYALANUR, VEMGAL            | 18:06   | 18:20     | 00:14    | LINE CLEAR AVAIED |
| 2135  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | LAKSHMIPURA                 | 13:03   | 13:22     | 00:19    | LINE CLEAR AVAIED |
| 2136  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | SRINIVASAPURA 66            | 13:05   | 13:15     | 00:10    | TRIPPED ON FAULT  |
| 2137  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                            | SRINIVASAPURA 66            | 13:15   | 14:50     | 01:35    | LINE CLEAR AVAIED |
| 2138  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                            | TAMAKA                      | 10:20   | 11:55     | 01:35    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                         | Station_Name                                                           | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|----------------------------------------------|------------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2139  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV DABASPETE 220 - KADUR 220              | NO STATION AFFECTED                                                    | 16:26   | 17:16     | 00:50    | LINE CLEAR AVAIED |
| 2140  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | DABUSPETE 220                                                          | 11:58   | 12:52     | 00:54    | LINE CLEAR AVAIED |
| 2141  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | DABUSPETE 220                                                          | 14:47   | 17:30     | 02:43    | TRIPPED ON FAULT  |
| 2142  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | GUDEMARANAHALLI                                                        | 09:00   | 09:07     | 00:07    | TRIPPED ON FAULT  |
| 2143  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | GUDEMARANAHALLI                                                        | 12:20   | 13:10     | 00:50    | LINE CLEAR AVAIED |
| 2144  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | HULLENAHALLI                                                           | 16:20   | 17:05     | 00:45    | LINE CLEAR AVAIED |
| 2145  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2           | NO STATION AFFECTED                                                    | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED |
| 2146  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220       | NO STATION AFFECTED                                                    | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 2147  | 12-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220         | NO STATION AFFECTED                                                    | 08:44   | 18:52     | 10:08    | LINE CLEAR AVAIED |
| 2148  | 12-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                       | NO STATION AFFECTED                                                    | 10:25   | 11:35     | 01:10    | LINE CLEAR AVAIED |
| 2149  | 12-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | YARANDANAHALLI 220                                                     | 00:58   | 01:03     | 00:05    | TRIPPED ON FAULT  |
| 2150  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)    | NO STATION AFFECTED                                                    | 12:16   | 18:38     | 06:22    | LINE CLEAR AVAIED |
| 2151  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | EXORA PARK 66                                                          | 10:55   | 10:58     | 00:03    | LINE CLEAR AVAIED |
| 2152  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | EXORA PARK 66                                                          | 11:45   | 11:48     | 00:03    | LINE CLEAR AVAIED |
| 2153  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV KEONICS (ELECTRONIC CITY) - HULIMANGALA | HULIMANGALA                                                            | 08:32   | 18:49     | 10:17    | LINE CLEAR AVAIED |
| 2154  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | RR NAGAR                                                               | 15:28   | 15:32     | 00:04    | LINE CLEAR AVAIED |
| 2155  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - KODIGENAHALLI        | ID HALLI LINE , KODIGNAHALLI LINE                                      | 12:30   | 14:02     | 01:32    | LINE CLEAR AVAIED |
| 2156  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - YEDAMADU              | YEDAMADU, HANUMANTHA NAGARA, CHATHRA, GODURU, MANIYAMBAL & MARALAVADI. | 06:45   | 06:52     | 00:07    | TRIPPED ON FAULT  |
| 2157  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - YEDAMADU              | YEDAMADU, HANUMANTHA NAGARA, CHATHRA, GODURU, MANIYAMBAL & MARALAVADI. | 07:07   | 07:15     | 00:08    | TRIPPED ON FAULT  |
| 2158  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - YEDAMADU              | YEDAMADU, HANUMANTHA NAGARA, CHATHRA, GODURU, MANIYAMBAL & MARALAVADI. | 10:18   | 10:27     | 00:09    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                | Station_Name                                                 | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------------|--------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2159  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV HANUMANTHANAGAR - YEDAMADU                     | HANUMANTHA NAGARA, CHATHRA, GODURU, MANIYAMBAL & MARALAVADI. | 10:30   | 10:44     | 00:14    | LINE CLEAR AVAIED |
| 2160  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR                 | GUNDLU KOTTUR                                                | 06:15   | 06:25     | 00:10    | TRIPPED ON FAULT  |
| 2161  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV GUNDLU KOTHUR - BAGEPALLI                      | NO STATION AFFECTED                                          | 06:15   | 06:25     | 00:10    | TRIPPED ON FAULT  |
| 2162  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                          | VEMGAL, KYALANUR AND TALGUNDA                                | 10:00   | 10:04     | 00:04    | LINE CLEAR AVAIED |
| 2163  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | MALLANAYAKANAHALLI                                           | 10:50   | 11:30     | 00:40    | LINE CLEAR AVAIED |
| 2164  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | MALLANAYAKANAHALLI                                           | 11:25   | 11:45     | 00:20    | LINE CLEAR AVAIED |
| 2165  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | NANGLI                                                       | 12:40   | 12:55     | 00:15    | LINE CLEAR AVAIED |
| 2166  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | NANGLI                                                       | 13:00   | 13:10     | 00:10    | LINE CLEAR AVAIED |
| 2167  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI | NANGLI                                                       | 13:13   | 13:30     | 00:17    | LINE CLEAR AVAIED |
| 2168  | 13-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                          | VEMGAL, KYALANUR AND TALGUNDA                                | 17:45   | 17:48     | 00:03    | LINE CLEAR AVAIED |
| 2169  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | VEMGAL                                                       | 07:45   | 07:55     | 00:10    | TRIPPED ON FAULT  |
| 2170  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | KGF                                                          | 12:35   | 13:20     | 00:45    | LINE CLEAR AVAIED |
| 2171  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | KYASAMBALLI                                                  | 16:20   | 17:05     | 00:45    | LINE CLEAR AVAIED |
| 2172  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | HUKUNDHA                                                     | 03:55   | 14:55     | 11:00    | TRIPPED ON FAULT  |
| 2173  | 13-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | JIGANI 66                                                    | 06:50   | 08:18     | 01:28    | LINE CLEAR AVAIED |
| 2174  | 13-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                  | NO STATION AFFECTED                                          | 23:58   | 23:59     | 23:59    | LINE CLEAR AVAIED |
| 2175  | 13-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220              | NO STATION AFFECTED                                          | 23:58   | 23:59     | 23:59    | LOAD CURTAILMENT  |
| 2176  | 13-Sep-24 | BENGALURU | 220     | LINE        | 220KV TK HALLI 220 - VAJAMANGALA 220                | NO STATION AFFECTED                                          | 08:44   | 18:52     | 10:08    | LINE CLEAR AVAIED |
| 2177  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | BANASAWADI                                                   | 02:55   | 03:26     | 00:31    | TRIPPED ON FAULT  |
| 2178  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - KANASWADI                   | KANASAWADI                                                   | 06:56   | 07:08     | 00:12    | TRIPPED ON FAULT  |
| 2179  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV REMCO - VIJAYANAGAR                            | VIJAYANAGARA                                                 | 09:47   | 09:55     | 00:08    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                  | Station_Name                | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------------|-----------------------------|---------|-----------|----------|--------------------|
| 2180  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOKULA - RMV                                     | RMV, IISc(EHT)              | 10:05   | 16:44     | 06:39    | LINE CLEAR AVAILED |
| 2181  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                   | HAL 220                     | 19:52   | 20:00     | 00:08    | TRIPPED ON FAULT   |
| 2182  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                   | HOODY 220                   | 13:31   | 14:32     | 01:01    | LINE CLEAR AVAILED |
| 2183  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                   | HOODY 220                   | 15:02   | 15:56     | 00:54    | LINE CLEAR AVAILED |
| 2184  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARAKKI - JAYADEVA 1                             | SARAKKI                     | 11:15   | 16:05     | 04:50    | LINE CLEAR AVAILED |
| 2185  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARAKKI - JAYADEVA 2                             | SARAKKI                     | 11:15   | 16:05     | 04:50    | LINE CLEAR AVAILED |
| 2186  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - ADUGODI-2                      | NO STATION AFFECTED         | 07:23   | 11:58     | 04:35    | TRIPPED ON FAULT   |
| 2187  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - AUDUGODI-1                     | NO STATION AFFECTED         | 07:23   | 11:58     | 04:35    | TRIPPED ON FAULT   |
| 2188  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)   | NO STATION AFFECTED         | 11:53   | 12:58     | 01:05    | LINE CLEAR AVAILED |
| 2189  | 14-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - TATHAGUNI 220                 | NO STATION AFFECTED         | 10:52   | 12:53     | 02:01    | LINE CLEAR AVAILED |
| 2190  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV ISRO LAYOUT - SARAKKI 1                          | NO STATION AFFECTED         | 11:35   | 16:55     | 05:20    | LINE CLEAR AVAILED |
| 2191  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                   | KHODAYS 66                  | 22:16   | 22:23     | 00:07    | LINE CLEAR AVAILED |
| 2192  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                   | KHODAYS 66                  | 22:16   | 22:23     | 00:07    | LINE CLEAR AVAILED |
| 2193  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SARAKKI 2                   | NO STATION AFFECTED         | 11:21   | 16:58     | 05:37    | LINE CLEAR AVAILED |
| 2194  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI | VOLVO, NANDAGUDI            | 23:07   | 23:59     | 00:52    | TRIPPED ON FAULT   |
| 2195  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                   | YENNIGADALE                 | 14:40   | 15:35     | 00:55    | LINE CLEAR AVAILED |
| 2196  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                   | YENNIGADALE                 | 14:40   | 15:35     | 00:55    | LINE CLEAR AVAILED |
| 2197  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                   | YENNIGADALE                 | 15:35   | 16:20     | 00:45    | LINE CLEAR AVAILED |
| 2198  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                            | VEMGAL, KYALANUR            | 10:00   | 10:04     | 00:04    | LINE CLEAR AVAILED |
| 2199  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                            | TALAGUNDA, VEMGAL, KYALANUR | 17:05   | 17:48     | 00:43    | LINE CLEAR AVAILED |
| 2200  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                            | KYALANUR, VEMGAL            | 17:55   | 18:00     | 00:05    | LINE CLEAR AVAILED |
| 2201  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                            | VEMGAL, KYALANUR            | 10:00   | 10:50     | 00:50    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                | Station_Name                  | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------------|-------------------------------|---------|-----------|----------|---------------------|
| 2202  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - YEDAMADU                     | MANIYAMBAL, MARALAWADI, GODUR | 07:54   | 07:57     | 00:03    | LINE CLEAR AVAILED  |
| 2203  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | MARALAWADI                    | 15:03   | 15:11     | 00:08    | TRIPPED ON FAULT    |
| 2204  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | GUDEMARANAHALLI               | 17:40   | 18:15     | 00:35    | LINE CLEAR AVAILED  |
| 2205  | 14-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI       | KEMPANAHALLI, URAGAHALLI      | 10:00   | 15:30     | 05:30    | LINE CLEAR AVAILED  |
| 2206  | 14-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                  | NO STATION AFFECTED           | 23:59   | 11:50     | 12:09    | LINE CLEAR AVAILED  |
| 2207  | 14-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                  | NO STATION AFFECTED           | 19:43   | 23:59     | 04:16    | LINE CLEAR AVAILED  |
| 2208  | 14-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220              | NO STATION AFFECTED           | 23:59   | 11:53     | 12:06    | LOAD CURTAILMENT    |
| 2209  | 14-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220              | NO STATION AFFECTED           | 19:47   | 23:59     | 04:12    | LOAD CURTAILMENT    |
| 2210  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | TK HALLI 220                  | 15:28   | 15:34     | 00:06    | TRIPPED ON FAULT    |
| 2211  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | TK HALLI 220                  | 16:27   | 16:30     | 00:03    | TRIPPED ON FAULT    |
| 2212  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | DOMMASANDRA                   | 16:35   | 16:46     | 00:11    | LINE CLEAR AVAILED  |
| 2213  | 14-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | DOMMASANDRA                   | 16:51   | 17:33     | 00:42    | LINE CLEAR AVAILED  |
| 2214  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | ATTUR YELAHANKA               | 14:57   | 15:05     | 00:08    | LINE CLEAR AVAILED  |
| 2215  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR                          | VIJAYANAGARA                  | 22:17   | 22:30     | 00:13    | LINE CLEAR AVAILED  |
| 2216  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV REMCO - VIJAYANAGAR                            | VIJAYANAGARA                  | 22:11   | 22:23     | 00:12    | LINE CLEAR AVAILED  |
| 2217  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - PLATINUM CITY DG-4            | PLATINUM CITY                 | 10:10   | 15:05     | 04:55    | LINE CLEAR AVAILED  |
| 2218  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4     | PLATINUM CITY                 | 10:10   | 15:05     | 04:55    | LINE CLEAR AVAILED  |
| 2219  | 15-Sep-24 | BENGALURU | 66      | LINE        | ELECTRONIC CITY - KEONICS GIS 220                   | ELECTRONIC CITY, INFOSYS(EHT) | 10:49   | 11:30     | 00:41    | MAIN SUPPLY FAILURE |
| 2220  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP) | NO STATION AFFECTED           | 17:30   | 19:55     | 02:25    | TRIPPED ON FAULT    |
| 2221  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - KHODAYS 220                 | NO STATION AFFECTED           | 11:20   | 16:16     | 04:56    | LINE CLEAR AVAILED  |
| 2222  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - MYLASANDRA 2                | NO STATION AFFECTED           | 11:26   | 15:46     | 04:20    | LINE CLEAR AVAILED  |
| 2223  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - JIGANI 220                   | NO STATION AFFECTED           | 10:55   | 14:49     | 03:54    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                              | Station_Name        | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------------------------------|---------------------|---------|-----------|----------|--------------------|
| 2224  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR - AREHALLI                                             | AREHALLI            | 10:40   | 10:50     | 00:10    | LINE CLEAR AVAILED |
| 2225  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV AREHALLI - BANASHANKARI                                                                      | AREHALLI            | 17:20   | 17:30     | 00:10    | LINE CLEAR AVAILED |
| 2226  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV BG ROAD - JIGANI LINK ROAD DC                                                                | NO STATION AFFECTED | 00:39   | 11:20     | 10:41    | TRIPPED ON FAULT   |
| 2227  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV BG ROAD - JIGANI LINK ROAD DC                                                                | NO STATION AFFECTED | 12:00   | 14:46     | 02:46    | LINE CLEAR AVAILED |
| 2228  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV KHODAYS 220 - ELITA PROMENADE                                                                | ELITA PROMENENDE    | 08:30   | 08:36     | 00:06    | LINE CLEAR AVAILED |
| 2229  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - KHODAYS 220                                                               | NO STATION AFFECTED | 11:19   | 16:16     | 04:57    | LINE CLEAR AVAILED |
| 2230  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | RBI                 | 14:14   | 14:18     | 00:04    | LINE CLEAR AVAILED |
| 2231  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | RBI                 | 14:14   | 14:18     | 00:04    | LINE CLEAR AVAILED |
| 2232  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | RBI                 | 17:22   | 17:28     | 00:06    | LINE CLEAR AVAILED |
| 2233  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | RBI                 | 17:22   | 17:28     | 00:06    | LINE CLEAR AVAILED |
| 2234  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - BMRCL PUTTENAHALLI EHT 66/33KV                                          | NO STATION AFFECTED | 00:47   | 00:49     | 00:02    | LINE CLEAR AVAILED |
| 2235  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66                                                       | SUBRAMANYAPURA 66   | 09:26   | 09:32     | 00:06    | LINE CLEAR AVAILED |
| 2236  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON                                              | SUBRAMANYAPURA 66   | 16:35   | 16:40     | 00:05    | LINE CLEAR AVAILED |
| 2237  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220_DG4 | GRIND WELL(EHT)     | 12:22   | 12:54     | 00:32    | TRIPPED ON FAULT   |
| 2238  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI                                             | VOLVO, NANDAGUDI    | 23:59   | 00:37     | 23:22    | TRIPPED ON FAULT   |
| 2239  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI                                             | VOLVO, NANDAGUDI    | 00:37   | 02:16     | 01:39    | LINE CLEAR AVAILED |
| 2240  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | G KODIHALLI         | 10:30   | 10:45     | 00:15    | TRIPPED ON FAULT   |
| 2241  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - KIADB DB PURA 220                                                        | NO STATION AFFECTED | 15:56   | 19:07     | 03:11    | LINE CLEAR AVAILED |
| 2242  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | D PALYA             | 11:07   | 11:12     | 00:05    | TRIPPED ON FAULT   |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                               | Station_Name                      | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------|-----------------------------------|---------|-----------|----------|--------------------|
| 2243  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | GOWRIBIDANUR 220                  | 07:20   | 07:30     | 00:10    | TRIPPED ON FAULT   |
| 2244  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - SIRA 1                    | NO STATION AFFECTED               | 16:15   | 18:43     | 02:28    | LINE CLEAR AVAILED |
| 2245  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - SIRA 2                    | NO STATION AFFECTED               | 10:24   | 16:15     | 05:51    | TRIPPED ON FAULT   |
| 2246  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - SIRA 2                    | NO STATION AFFECTED               | 16:15   | 18:42     | 02:27    | LINE CLEAR AVAILED |
| 2247  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE | MANCHENAHALLI                     | 18:15   | 18:35     | 00:20    | TRIPPED ON FAULT   |
| 2248  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR                | GUNDLU KOTTUR                     | 08:32   | 08:42     | 00:10    | TRIPPED ON FAULT   |
| 2249  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV GUNDLU KOTHUR - BAGEPALLI                     | NO STATION AFFECTED               | 08:32   | 08:42     | 00:10    | TRIPPED ON FAULT   |
| 2250  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | KOLAR 220                         | 05:45   | 06:15     | 00:30    | TRIPPED ON FAULT   |
| 2251  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | KOLAR 220                         | 06:40   | 11:51     | 05:11    | LINE CLEAR AVAILED |
| 2252  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - BANGARPET 2                       | BANGARPETE                        | 09:13   | 09:54     | 00:41    | TRIPPED ON FAULT   |
| 2253  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | GODUR                             | 07:23   | 07:28     | 00:05    | TRIPPED ON FAULT   |
| 2254  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE            | AGALAKOTE, MATHIKERE, JALAMANGALA | 06:54   | 07:22     | 00:28    | TRIPPED ON FAULT   |
| 2255  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | DABUSPETE 220                     | 11:29   | 17:28     | 05:59    | LINE CLEAR AVAILED |
| 2256  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | DABUSPETE 220                     | 12:50   | 17:44     | 04:54    | LINE CLEAR AVAILED |
| 2257  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                 | NO STATION AFFECTED               | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED |
| 2258  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220             | NO STATION AFFECTED               | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 2259  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                | IGGALUR                           | 19:09   | 19:19     | 00:10    | TRIPPED ON FAULT   |
| 2260  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV KANAKAPURA 220 - TK HALLI 220                | NO STATION AFFECTED               | 17:47   | 23:59     | 06:12    | TRIPPED ON FAULT   |
| 2261  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBARANAHALLI - BAGGANADODDI                 | BAGGANADODDI                      | 10:02   | 15:12     | 05:10    | LINE CLEAR AVAILED |
| 2262  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV JIGANI 220 - YARANDANAHALLI 220              | JIGANI 220                        | 10:48   | 10:50     | 00:02    | LINE CLEAR AVAILED |
| 2263  | 15-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                | JIGANI 220                        | 10:04   | 14:51     | 04:47    | LINE CLEAR AVAILED |
| 2264  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV JIGANI 220 - KUMBARANAHALLI                   | KUMBARANAHALLI                    | 10:04   | 14:51     | 04:47    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                     | Station_Name                               | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------|--------------------------------------------|---------|-----------|----------|--------------------|
| 2265  | 15-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                      | JIGANI 220                                 | 10:04   | 15:55     | 05:51    | LINE CLEAR AVAILED |
| 2266  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV JIGANI LINK ROAD - JIGANI OLD STATION               | JIGANI 66                                  | 10:04   | 16:00     | 05:56    | LINE CLEAR AVAILED |
| 2267  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                      | JIGANI 220                                 | 10:03   | 14:54     | 04:51    | LINE CLEAR AVAILED |
| 2268  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                      | JIGANI 220                                 | 10:03   | 14:54     | 04:51    | LINE CLEAR AVAILED |
| 2269  | 15-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                      | JIGANI 66                                  | 10:00   | 20:00     | 10:00    | LINE CLEAR AVAILED |
| 2270  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV JIGANI LINK ROAD - JIGANI OLD STATION               | JIGANI LINK ROAD                           | 10:03   | 16:27     | 06:24    | LINE CLEAR AVAILED |
| 2271  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2                       | ANEKAL, ATTIBELE(HV1), SAMANDURU           | 10:30   | 10:52     | 00:22    | LINE CLEAR AVAILED |
| 2272  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2                       | ANEKAL, ATTIBELE(HV1), SAMANDURU           | 15:02   | 15:17     | 00:15    | LINE CLEAR AVAILED |
| 2273  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                               | SURYA CITY                                 | 10:32   | 10:50     | 00:18    | LINE CLEAR AVAILED |
| 2274  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                               | SURYA CITY                                 | 15:02   | 15:17     | 00:15    | LINE CLEAR AVAILED |
| 2275  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT | TIMES OF INDIA                             | 10:33   | 10:50     | 00:17    | LINE CLEAR AVAILED |
| 2276  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT | TIMES OF INDIA                             | 15:05   | 15:17     | 00:12    | LINE CLEAR AVAILED |
| 2277  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1              | ELECTRONIC CITY, INFOSYS(EHT), HULIMANGALA | 06:18   | 06:30     | 00:12    | TRIPPED ON FAULT   |
| 2278  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1              | ELECTRONIC CITY, INFOSYS(EHT), HULIMANGALA | 06:30   | 06:40     | 00:10    | LINE CLEAR AVAILED |
| 2279  | 15-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ELECTRONIC CITY 1              | ELECTRONIC CITY, INFOSYS(EHT), HULIMANGALA | 10:49   | 11:27     | 00:38    | LINE CLEAR AVAILED |
| 2280  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - YARANDANAHALLI 1                  | KEONICS CITY GIS 220                       | 10:48   | 11:20     | 00:32    | LINE CLEAR AVAILED |
| 2281  | 15-Sep-24 | BENGALURU | 220     | LINE        | 220KV YARANDANAHALLI 220 - HOSUR 220                     | NO STATION AFFECTED                        | 10:48   | 11:20     | 00:32    | LINE CLEAR AVAILED |
| 2282  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2          | KENGERI SATELLITE TOWN                     | 10:24   | 10:27     | 00:03    | LINE CLEAR AVAILED |
| 2283  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT              | KENGERI SATELLITE TOWN                     | 14:23   | 14:27     | 00:04    | LINE CLEAR AVAILED |
| 2284  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                      | ARMY WELFARE ORGANISATION                  | 20:02   | 20:08     | 00:06    | TRIPPED ON FAULT   |
| 2285  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - ADUGODI-2                         | NO STATION AFFECTED                        | 18:21   | 20:08     | 01:47    | TRIPPED ON FAULT   |
| 2286  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - AUDUGODI-1                        | NO STATION AFFECTED                        | 18:21   | 20:08     | 01:47    | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                                        | Station_Name                                                                      | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2287  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK<br>220 - VIDYANAGAR - 12 POLE -<br>GRINDWILL - HOSKOTE 66 -<br>EKARAJPURA 220 _DG4 | GRINDWELL(EHT)                                                                    | 12:22   | 12:54     | 00:32    | TRIPPED ON FAULT  |
| 2288  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | RAMADEVARAGUDI                                                                    | 08:25   | 08:50     | 00:25    | TRIPPED ON FAULT  |
| 2289  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>VIJAYAPURA                                                                        | VIJAYAPURA, MELUR,<br>JANGAMKOTE                                                  | 18:28   | 18:41     | 00:13    | TRIPPED ON FAULT  |
| 2290  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | KIADB DB PURA 220                                                                 | 10:00   | 10:05     | 00:05    | LINE CLEAR AVAIED |
| 2291  | 16-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                                                         | KIADB DB PURA 220                                                                 | 10:50   | 11:11     | 00:21    | LINE CLEAR AVAIED |
| 2292  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 -<br>VATADAHOSAHALLI - MITTEMARI                                                      | VATADAHOSAHALLI                                                                   | 15:18   | 15:35     | 00:17    | TRIPPED ON FAULT  |
| 2293  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | THONDEBHAVI                                                                       | 13:20   | 13:30     | 00:10    | TRIPPED ON FAULT  |
| 2294  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | THAYALUR                                                                          | 13:10   | 13:35     | 00:25    | LINE CLEAR AVAIED |
| 2295  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | VOKKALERI                                                                         | 09:45   | 09:50     | 00:05    | LINE CLEAR AVAIED |
| 2296  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHIKKENAHALLI -<br>SHIVANAHALLI - VANDARGUPPE -<br>CHANNAPATNA                                         | SHIVANAHALLI                                                                      | 14:29   | 14:35     | 00:06    | TRIPPED ON FAULT  |
| 2297  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | CHANDRAPPA CIRCLE                                                                 | 00:25   | 00:30     | 00:05    | TRIPPED ON FAULT  |
| 2298  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | CHANDRAPPA CIRCLE                                                                 | 13:40   | 13:50     | 00:10    | TRIPPED ON FAULT  |
| 2299  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | CHANDRAPPA CIRCLE                                                                 | 13:50   | 16:10     | 02:20    | LINE CLEAR AVAIED |
| 2300  | 16-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE -<br>MATHIKERE                                                                  | AGALAKOTE, MATHIKERE,<br>JALAMANGALA,<br>CHIKKAGANGANAWADI, KUTAGAL,<br>MELEHALLI | 06:54   | 07:22     | 00:28    | TRIPPED ON FAULT  |
| 2301  | 16-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | KEMPANAHALLI                                                                      | 10:57   | 11:07     | 00:10    | TRIPPED ON FAULT  |
| 2302  | 16-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 -<br>KOTHIPURA 2                                                                       | NO STATION AFFECTED                                                               | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED |
| 2303  | 16-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 -<br>TUBINAKERE 220                                                                   | NO STATION AFFECTED                                                               | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 2304  | 16-Sep-24 | BENGALURU | 220     | LINE        | 220KV KANAKAPURA 220 - TK<br>HALLI 220                                                                      | NO STATION AFFECTED                                                               | 23:59   | 10:07     | 13:52    | TRIPPED ON FAULT  |
| 2305  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | BANASAWADI                                                                        | 14:41   | 14:49     | 00:08    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                           | Station_Name                                        | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|------------------------------------------------|-----------------------------------------------------|---------|-----------|----------|-------------------|
| 2306  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                            | BANASAWADI                                          | 14:41   | 14:49     | 00:08    | LINE CLEAR AVAIED |
| 2307  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | BANASAWADI                                          | 22:12   | 22:35     | 00:23    | LINE CLEAR AVAIED |
| 2308  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                            | BANASAWADI                                          | 22:12   | 22:35     | 00:23    | LINE CLEAR AVAIED |
| 2309  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV REMCO - VIJAYANAGAR                       | VIJAYANAGARA                                        | 11:13   | 11:21     | 00:08    | LINE CLEAR AVAIED |
| 2310  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR                     | VIJAYANAGARA                                        | 22:06   | 22:13     | 00:07    | LINE CLEAR AVAIED |
| 2311  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - BANASHANKARI          | BANASHANKARI                                        | 06:35   | 07:14     | 00:39    | TRIPPED ON FAULT  |
| 2312  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - BANASHANKARI          | BANASHANKARI                                        | 07:21   | 07:38     | 00:17    | TRIPPED ON FAULT  |
| 2313  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | G KODIHALLI                                         | 14:36   | 14:38     | 00:02    | LINE CLEAR AVAIED |
| 2314  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - KUNDANA - DEVANAHALLI 1 | DEVANAHALLI 66, KUNDANA, BRIGADE ORCHIDS            | 16:04   | 16:46     | 00:42    | LINE CLEAR AVAIED |
| 2315  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - DEVANAHALLI 2           | DEVANAHALLI 66, BRIGADE ORCHIDS                     | 16:04   | 16:46     | 00:42    | LINE CLEAR AVAIED |
| 2316  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | GUNDAMGERE                                          | 10:53   | 11:00     | 00:07    | TRIPPED ON FAULT  |
| 2317  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV CB PURA I/A - NALLIMARADANAHALLI          | NALLIMARADANAHALLI                                  | 18:00   | 18:05     | 00:05    | LINE CLEAR AVAIED |
| 2318  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | MITTEMARI 220                                       | 17:00   | 17:10     | 00:10    | TRIPPED ON FAULT  |
| 2319  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI                         | NO STATION AFFECTED                                 | 14:15   | 14:23     | 00:08    | LINE CLEAR AVAIED |
| 2320  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV RAYALAPADU - ADDAGAL                      | ADDAGAL                                             | 18:00   | 18:15     | 00:15    | TRIPPED ON FAULT  |
| 2321  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | KAMASAMUDRA                                         | 11:20   | 11:25     | 00:05    | LINE CLEAR AVAIED |
| 2322  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                            | KAMASAMUDRA                                         | 12:00   | 12:05     | 00:05    | LINE CLEAR AVAIED |
| 2323  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV KGF - KAMASAMUDRA                         | KAMASAMUDRA                                         | 12:30   | 12:55     | 00:25    | LINE CLEAR AVAIED |
| 2324  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | THORALAKKI                                          | 11:30   | 11:50     | 00:20    | LINE CLEAR AVAIED |
| 2325  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | VR DODDI                                            | 12:55   | 14:10     | 01:15    | LINE CLEAR AVAIED |
| 2326  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                            | HULLENAHALLI                                        | 17:40   | 18:00     | 00:20    | LINE CLEAR AVAIED |
| 2327  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV JALAMANGALA - MATHIKERE                   | JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALU, MELEHALLI | 10:05   | 16:30     | 06:25    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                     | Station_Name                               | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------|--------------------------------------------|---------|-----------|----------|--------------------|
| 2328  | 17-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                       | NO STATION AFFECTED                        | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED |
| 2329  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                      | BEVOOR                                     | 08:16   | 08:21     | 00:05    | LINE CLEAR AVAILED |
| 2330  | 17-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220                   | NO STATION AFFECTED                        | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT   |
| 2331  | 17-Sep-24 | BENGALURU | 220     | LINE        | 220KV KANAKAPURA 220 - TK HALLI 220                      | NO STATION AFFECTED                        | 09:55   | 14:22     | 04:27    | LINE CLEAR AVAILED |
| 2332  | 17-Sep-24 | BENGALURU | 220     | LINE        | TK HALLI 220 - VAJAMANGALA 220                           | NO STATION AFFECTED                        | 10:12   | 14:22     | 04:10    | LINE CLEAR AVAILED |
| 2333  | 17-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - LIMBAVALI IPP                             | NO STATION AFFECTED                        | 11:08   | 11:42     | 00:34    | TRIPPED ON FAULT   |
| 2334  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                      | SURYANAGARA                                | 10:42   | 10:58     | 00:16    | LINE CLEAR AVAILED |
| 2335  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                      | SURYANAGARA                                | 11:18   | 11:24     | 00:06    | LINE CLEAR AVAILED |
| 2336  | 17-Sep-24 | BENGALURU | 220     | LINE        | 220KV YARANDANAHALLI 220 - HOSUR 220                     | NO STATION AFFECTED                        | 13:01   | 13:15     | 00:14    | LINE CLEAR AVAILED |
| 2337  | 17-Sep-24 | BENGALURU | 220     | LINE        | 220KV JIGANI 220 - YARANDANAHALLI 220                    | NO STATION AFFECTED                        | 13:08   | 13:20     | 00:12    | LINE CLEAR AVAILED |
| 2338  | 17-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                      | YARANDANAHALLI 220                         | 13:08   | 13:15     | 00:07    | LINE CLEAR AVAILED |
| 2339  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2                       | ANEKAL, ATTIBELE(HV1), SAMANDURU           | 13:08   | 13:17     | 00:09    | LINE CLEAR AVAILED |
| 2340  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                               | SURYA CITY                                 | 13:08   | 13:17     | 00:09    | LINE CLEAR AVAILED |
| 2341  | 17-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT | TIMES OF INDIA                             | 13:01   | 13:15     | 00:14    | LINE CLEAR AVAILED |
| 2342  | 17-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                      | YARANDANAHALLI 220                         | 13:08   | 13:18     | 00:10    | LINE CLEAR AVAILED |
| 2343  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV HEBBAL 220 - LR BANDE (ITI-HEBBAL-2)                | NO STATION AFFECTED                        | 12:40   | 13:58     | 01:18    | LINE CLEAR AVAILED |
| 2344  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 - KENGERI SATELLITE TOWN 2          | KENGERI SATELLITE TOWN                     | 10:31   | 10:36     | 00:05    | LINE CLEAR AVAILED |
| 2345  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV KENGERI SATELLITE TOWN - SIR MV LAYOUT              | KENGERI SATELLITE TOWN                     | 14:02   | 14:07     | 00:05    | LINE CLEAR AVAILED |
| 2346  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BRINDAVAN HTLS                     | NO STATION AFFECTED                        | 10:46   | 15:55     | 05:09    | LINE CLEAR AVAILED |
| 2347  | 18-Sep-24 | BENGALURU | 66      | LINE        | ELECTRONIC CITY - KEONICS GIS 2                          | ELECTRONIC CITY, INFOSYS(EHT), HULIMANGALA | 08:04   | 08:27     | 00:23    | LINE CLEAR AVAILED |
| 2348  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66              | SUBRAMANYAPURA 66                          | 10:08   | 12:27     | 02:19    | LINE CLEAR AVAILED |
| 2349  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - RAJANKUNTE                       | RAJANKUNTE                                 | 13:35   | 13:50     | 00:15    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                    | Station_Name             | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------|--------------------------|---------|-----------|----------|-------------------|
| 2350  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 220 - TALAGAWARA                        | TALAGAWARA, CHEEMANGALA  | 11:01   | 11:09     | 00:08    | LINE CLEAR AVAIED |
| 2351  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | DIBBURAHALLI             | 11:25   | 11:40     | 00:15    | LINE CLEAR AVAIED |
| 2352  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | DIBBURAHALLI             | 13:00   | 14:25     | 01:25    | LINE CLEAR AVAIED |
| 2353  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | G KODIHALLI              | 07:30   | 07:45     | 00:15    | TRIPPED ON FAULT  |
| 2354  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                              | KYALANUR, TALAGAWARA     | 19:00   | 19:03     | 00:03    | LINE CLEAR AVAIED |
| 2355  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | DEVANAHALLI 66           | 02:00   | 02:15     | 00:15    | TRIPPED ON FAULT  |
| 2356  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | CHELUR                   | 00:30   | 00:50     | 00:20    | TRIPPED ON FAULT  |
| 2357  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | CHELUR                   | 00:50   | 01:00     | 00:10    | TRIPPED ON FAULT  |
| 2358  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | MANCHENAHALLI            | 05:30   | 05:45     | 00:15    | TRIPPED ON FAULT  |
| 2359  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | MANCHENAHALLI            | 05:45   | 07:35     | 01:50    | LINE CLEAR AVAIED |
| 2360  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - NARASAPURA 2                           | NO STATION AFFECTED      | 14:29   | 15:28     | 00:59    | TRIPPED ON FAULT  |
| 2361  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | SUGUTUR                  | 14:05   | 14:25     | 00:20    | TRIPPED ON FAULT  |
| 2362  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | VOKKALERI                | 11:40   | 12:35     | 00:55    | LINE CLEAR AVAIED |
| 2363  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                     | KGF                      | 16:30   | 17:05     | 00:35    | LINE CLEAR AVAIED |
| 2364  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR TOWN                             | MALUR 66                 | 12:10   | 13:10     | 01:00    | LINE CLEAR AVAIED |
| 2365  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | MALUR IND AREA           | 17:20   | 18:05     | 00:45    | LINE CLEAR AVAIED |
| 2366  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | MALUR IND AREA           | 16:50   | 17:25     | 00:35    | LINE CLEAR AVAIED |
| 2367  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR I/A - JADIGENAHALLI (HOSKOTE -1) | NO STATION AFFECTED      | 16:50   | 17:15     | 00:25    | LINE CLEAR AVAIED |
| 2368  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR I/A                              | NO STATION AFFECTED      | 17:16   | 17:55     | 00:39    | LINE CLEAR AVAIED |
| 2369  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR INDUSTRIAL AREA - ASSOCIATE DÉCOR LTD (EHT)  | ASSOCIATE DÉCOR LTD(EHT) | 16:05   | 16:40     | 00:35    | LINE CLEAR AVAIED |
| 2370  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR INDUSTRIAL AREA - BEST STEELS LTD (EHT)      | BEST STEELS(EHT)         | 16:30   | 16:50     | 00:20    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                             | Station_Name                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------------|----------------------------------|---------|-----------|----------|---------------------|
| 2371  | 18-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                              | T GOLLAHALLI 220                 | 16:30   | 16:56     | 00:26    | LINE CLEAR AVAILED  |
| 2372  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - SHIVANAHALLI KMF - DODDALAHALLI - TK HALLI | SHIVANAHALLI DAIRY, DODDALAHALLI | 07:22   | 07:32     | 00:10    | TRIPPED ON FAULT    |
| 2373  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | DABUSPETE 220                    | 18:12   | 18:18     | 00:06    | LINE CLEAR AVAILED  |
| 2374  | 18-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - ANTHAHRASANAHALLI (B1)                   | NO STATION AFFECTED              | 14:27   | 16:10     | 01:43    | TRIPPED ON FAULT    |
| 2375  | 18-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                              | BIDADI 220                       | 21:10   | 22:13     | 01:03    | LINE CLEAR AVAILED  |
| 2376  | 18-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2                               | NO STATION AFFECTED              | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAILED  |
| 2377  | 18-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220                           | NO STATION AFFECTED              | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 2378  | 18-Sep-24 | BENGALURU | 220     | LINE        | TK HALLIN 220 - HEBBANI 2                                        | NO STATION AFFECTED              | 09:45   | 11:30     | 01:45    | LINE CLEAR AVAILED  |
| 2379  | 18-Sep-24 | BENGALURU | 220     | LINE        | TK HALLIN 220 - HEBBANI 1                                        | NO STATION AFFECTED              | 11:40   | 14:03     | 02:23    | LINE CLEAR AVAILED  |
| 2380  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - ATTIBELE                                           | ATTIBELE                         | 13:41   | 14:45     | 01:04    | LINE CLEAR AVAILED  |
| 2381  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | KUMBARANAHALLI                   | 08:27   | 09:06     | 00:39    | TRIPPED ON FAULT    |
| 2382  | 18-Sep-24 | BENGALURU | 220     | LINE        | 220KV YARANDANAHALLI 220 - HOSUR 220                             | YARANDANAHALLI 220               | 13:40   | 15:08     | 01:28    | MAIN SUPPLY FAILURE |
| 2383  | 18-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                              | YARANDANAHALLI 220               | 13:40   | 16:30     | 02:50    | MAIN SUPPLY FAILURE |
| 2384  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - SURYA CITY                             | SURYA CITY                       | 13:40   | 15:08     | 01:28    | MAIN SUPPLY FAILURE |
| 2385  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2                               | ANEKAL                           | 13:40   | 15:08     | 01:28    | MAIN SUPPLY FAILURE |
| 2386  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - SURYA CITY                             | SURYA CITY                       | 17:50   | 17:55     | 00:05    | LINE CLEAR AVAILED  |
| 2387  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2                               | ANEKAL                           | 17:50   | 17:55     | 00:05    | LINE CLEAR AVAILED  |
| 2388  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - COLEMAN LTD TIMES OF INDIA EHT         | TIMES OF INDIA(EHT)              | 13:40   | 14:09     | 00:29    | MAIN SUPPLY FAILURE |
| 2389  | 18-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                              | YARANDANAHALLI 220               | 10:28   | 10:33     | 00:05    | LINE CLEAR AVAILED  |
| 2390  | 18-Sep-24 | BENGALURU | 66      | LINE        | 66KV MEI LAYOUT - WIDIA                                          | NO STATION AFFECTED              | 16:18   | 16:48     | 00:30    | LINE CLEAR AVAILED  |
| 2391  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV HBR LAYOUT 66 - MANYATA 66 - KONDA SPURA (SAFAL) _DG3       | NO STATION AFFECTED              | 11:32   | 16:10     | 04:38    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                    | Station_Name        | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|-----------------------------------------|---------------------|---------|-----------|----------|--------------------|
| 2392  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV MANYATA 220 - MANYATA 66_DG3       | MANYATHA 66         | 11:09   | 15:44     | 04:35    | LINE CLEAR AVAILED |
| 2393  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                     | MANYATHA 66         | 11:07   | 16:10     | 05:03    | LINE CLEAR AVAILED |
| 2394  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV SRS PEENYA 220 - SAHAKARNAGAR 220 | NO STATION AFFECTED | 13:23   | 15:13     | 01:50    | LINE CLEAR AVAILED |
| 2395  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV SRS PEENYA 220 - NRS 220          | NRS 220             | 10:26   | 16:57     | 06:31    | LINE CLEAR AVAILED |
| 2396  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV A STATION 220 - NRS 220           | NRS 220             | 10:18   | 17:01     | 06:43    | LINE CLEAR AVAILED |
| 2397  | 19-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                     | NRS 220             | 10:21   | 17:04     | 06:43    | LINE CLEAR AVAILED |
| 2398  | 19-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                     | NRS 220             | 10:21   | 17:04     | 06:43    | LINE CLEAR AVAILED |
| 2399  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - TELECOM LAYOUT 1         | TELECOM LAYOUT      | 10:10   | 17:10     | 07:00    | LINE CLEAR AVAILED |
| 2400  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - BRIGADE GATEWAY          | BRIGADE GATEWAY     | 10:10   | 17:11     | 07:01    | LINE CLEAR AVAILED |
| 2401  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                | PALLADIUM           | 10:10   | 17:17     | 07:07    | LINE CLEAR AVAILED |
| 2402  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR              | NO STATION AFFECTED | 09:12   | 17:48     | 08:36    | LINE CLEAR AVAILED |
| 2403  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - A.R.CIRCLE STATION (A2)  | NO STATION AFFECTED | 09:12   | 17:41     | 08:29    | LINE CLEAR AVAILED |
| 2404  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - IISC                     | IISc                | 09:12   | 17:41     | 08:29    | LINE CLEAR AVAILED |
| 2405  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                     | NRS 220             | 10:12   | 17:13     | 07:01    | LINE CLEAR AVAILED |
| 2406  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV5                                     | NRS 220             | 10:12   | 17:13     | 07:01    | LINE CLEAR AVAILED |
| 2407  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | NRS 220             | 10:12   | 17:17     | 07:05    | LINE CLEAR AVAILED |
| 2408  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | NRS 220             | 10:12   | 17:20     | 07:08    | LINE CLEAR AVAILED |
| 2409  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                     | NRS 220             | 10:12   | 17:16     | 07:04    | LINE CLEAR AVAILED |
| 2410  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - GOKULA 1          | NO STATION AFFECTED | 13:52   | 15:15     | 01:23    | TRIPPED ON FAULT   |
| 2411  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | BRIGADE TECH GARDEN | 11:20   | 11:25     | 00:05    | LINE CLEAR AVAILED |
| 2412  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | BRIGADE MEADOWS     | 05:30   | 05:42     | 00:12    | TRIPPED ON FAULT   |
| 2413  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | BRIGADE MEADOWS     | 11:13   | 11:18     | 00:05    | TRIPPED ON FAULT   |
| 2414  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | KONDASAPURA         | 02:35   | 02:50     | 00:15    | TRIPPED ON FAULT   |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                          | Station_Name                                                                 | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-------------------------------|------------------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2415  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA | CHEEMANGALA                                                                  | 11:00   | 11:17     | 00:17    | LINE CLEAR AVAIED |
| 2416  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA | CHEEMANGALA                                                                  | 19:00   | 19:10     | 00:10    | LINE CLEAR AVAIED |
| 2417  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | IRAGAMPALLI                                                                  | 17:45   | 17:50     | 00:05    | TRIPPED ON FAULT  |
| 2418  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | IRAGAMPALLI                                                                  | 17:50   | 18:40     | 00:50    | LINE CLEAR AVAIED |
| 2419  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                           | D CROSS                                                                      | 16:35   | 17:15     | 00:40    | LINE CLEAR AVAIED |
| 2420  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | D CROSS                                                                      | 16:35   | 17:15     | 00:40    | LINE CLEAR AVAIED |
| 2421  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | KIADB DB PURA 220                                                            | 09:46   | 09:58     | 00:12    | TRIPPED ON FAULT  |
| 2422  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                           | GOWRIBIDANUR 220                                                             | 15:05   | 15:15     | 00:10    | TRIPPED ON FAULT  |
| 2423  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                           | GUNDLU KOTTUR                                                                | 14:00   | 14:07     | 00:07    | TRIPPED ON FAULT  |
| 2424  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | GUNDLU KOTTUR                                                                | 16:10   | 16:20     | 00:10    | TRIPPED ON FAULT  |
| 2425  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | GUNDLU KOTTUR                                                                | 16:20   | 16:25     | 00:05    | LINE CLEAR AVAIED |
| 2426  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV MITTEMARI 220 - SADALI   | SADALI                                                                       | 05:42   | 05:53     | 00:11    | TRIPPED ON FAULT  |
| 2427  | 19-Sep-24 | BENGALURU | 66      | LINE        | GOWNIPALLI - ADDAGAL          | ADDAGAL                                                                      | 11:40   | 11:50     | 00:10    | LINE CLEAR AVAIED |
| 2428  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV RAYALAPADU - ADDAGAL     | ADDAGAL, RAYALPADU                                                           | 14:00   | 14:05     | 00:05    | LINE CLEAR AVAIED |
| 2429  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV LAKSHMIPURA - GOWNIPALLI | GOWNIPALLI, LAKSHMIPURA, RAYALAPDU, ADDAGAL, SOMAYAJANAHALLI, TATA SOLAR IPP | 10:38   | 10:48     | 00:10    | LINE CLEAR AVAIED |
| 2430  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - VOKKALERI    | VOKKALERI                                                                    | 09:08   | 10:05     | 00:57    | LINE CLEAR AVAIED |
| 2431  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI        | NO STATION AFFECTED                                                          | 09:58   | 13:50     | 03:52    | TRIPPED ON FAULT  |
| 2432  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI        | NO STATION AFFECTED                                                          | 13:50   | 15:37     | 01:47    | LINE CLEAR AVAIED |
| 2433  | 19-Sep-24 | BENGALURU | 66      | LINE        | LAKSHMIPURA - RAYALAPDU       | RAYALAPDU, ADDAGAL                                                           | 10:37   | 12:10     | 01:33    | TRIPPED ON FAULT  |
| 2434  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV RAYALAPADU - ADDAGAL     | RAYALPADU                                                                    | 13:35   | 13:40     | 00:05    | LINE CLEAR AVAIED |
| 2435  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                           | SRINIVASPURA 66                                                              | 16:31   | 16:50     | 00:19    | LINE CLEAR AVAIED |
| 2436  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                           | VOKKALERI                                                                    | 08:35   | 08:45     | 00:10    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name                             | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|------------------------------------------|---------|-----------|----------|-------------------|
| 2437  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - VOKKALERI                    | VOKKALERI, KC VALLEY PUMP HOUSE          | 09:12   | 10:05     | 00:53    | LINE CLEAR AVAIED |
| 2438  | 19-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | VOKKALERI                                | 14:40   | 14:45     | 00:05    | LINE CLEAR AVAIED |
| 2439  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB HAROHALLI 220 - KANAKAPURA 220    | KANAKAPURA 220                           | 07:40   | 09:35     | 01:55    | LINE CLEAR AVAIED |
| 2440  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - HAROBELE - TK HALLI 1   | NO STATION AFFECTED                      | 07:45   | 12:58     | 05:13    | TRIPPED ON FAULT  |
| 2441  | 19-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                           | KANAKAPURA 220                           | 07:45   | 07:55     | 00:10    | TRIPPED ON FAULT  |
| 2442  | 19-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - TALAGUPPA             | NO STATION AFFECTED                      | 11:40   | 17:57     | 06:17    | LINE CLEAR AVAIED |
| 2443  | 19-Sep-24 | BENGALURU | 400     | LINE        | 400KV NELAMANGALA 400 - TALAGUPPA             | NO STATION AFFECTED                      | 18:12   | 22:34     | 04:22    | TRIPPED ON FAULT  |
| 2444  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - ANTHAHRASANAHALI (B1) | NO STATION AFFECTED                      | 10:45   | 12:50     | 02:05    | LINE CLEAR AVAIED |
| 2445  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2            | NO STATION AFFECTED                      | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED |
| 2446  | 19-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220        | NO STATION AFFECTED                      | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT  |
| 2447  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - GURUVINAPURA - V R DODDI  | GURUVINAPURA, BV HALLI                   | 08:18   | 08:32     | 00:14    | LINE CLEAR AVAIED |
| 2448  | 19-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - GURUVINAPURA - V R DODDI  | GURUVINAPURA, BV HALLI                   | 12:46   | 12:52     | 00:06    | LINE CLEAR AVAIED |
| 2449  | 19-Sep-24 | BENGALURU | 220     | LINE        | TK HALLI 220 - HEBBANI 1                      | NO STATION AFFECTED                      | 15:03   | 23:59     | 08:56    | LINE CLEAR AVAIED |
| 2450  | 19-Sep-24 | BENGALURU | 220     | LINE        | TK HALLI 220 - HEBBANI 2                      | NO STATION AFFECTED                      | 15:03   | 23:59     | 08:56    | LINE CLEAR AVAIED |
| 2451  | 19-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                        | NO STATION AFFECTED                      | 15:18   | 18:15     | 02:57    | LINE CLEAR AVAIED |
| 2452  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV ABBIGERE - ATTURU - MANYATA DG-3         | ABBIGERE, WELCAST                        | 15:39   | 15:52     | 00:13    | TRIPPED ON FAULT  |
| 2453  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - KANASWADI             | KANASWADI                                | 08:18   | 08:28     | 00:10    | TRIPPED ON FAULT  |
| 2454  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | VIJAYANAGARA                             | 22:05   | 22:13     | 00:08    | LINE CLEAR AVAIED |
| 2455  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | VIJAYANAGARA                             | 22:05   | 22:13     | 00:08    | LINE CLEAR AVAIED |
| 2456  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV WELCAST STEEL - ABBIGERE                 | ABBIGERE                                 | 18:36   | 18:40     | 00:04    | LINE CLEAR AVAIED |
| 2457  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BYADARAHALLI            | BYADARAHALLI, SRIGANDAKAVALU, KODIGEHALI | 08:13   | 09:18     | 01:05    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                              | Station_Name                        | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------------------------------|-------------------------------------|---------|-----------|----------|--------------------|
| 2458  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - WELCAST STEEL DG-3                                                          | WELCAST                             | 22:06   | 22:10     | 00:04    | LINE CLEAR AVAILED |
| 2459  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - GTP                                                                    | DEVARABISANAHALLI, GLOBAL TECH PARK | 10:30   | 15:20     | 04:50    | LINE CLEAR AVAILED |
| 2460  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - PRIMAL                                                                 | PRIMAL                              | 10:30   | 15:20     | 04:50    | LINE CLEAR AVAILED |
| 2461  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW                                           | SHOBHA FOREST VIEW                  | 10:05   | 14:30     | 04:25    | LINE CLEAR AVAILED |
| 2462  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - AUDUGODI-1                                                                 | NO STATION AFFECTED                 | 18:45   | 23:14     | 04:29    | TRIPPED ON FAULT   |
| 2463  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                                               | NO STATION AFFECTED                 | 22:50   | 23:15     | 00:25    | LINE CLEAR AVAILED |
| 2464  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | AREHALLI                            | 15:35   | 15:40     | 00:05    | LINE CLEAR AVAILED |
| 2465  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | KHODAYS 220                         | 07:39   | 07:50     | 00:11    | TRIPPED ON FAULT   |
| 2466  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | CHANNARAYAPATNA                     | 15:40   | 16:00     | 00:20    | TRIPPED ON FAULT   |
| 2467  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220_DG4 | GRINDWELL NORTON(EHT)               | 09:46   | 10:41     | 00:55    | TRIPPED ON FAULT   |
| 2468  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                               | KONDASAPURA                         | 10:00   | 16:20     | 06:20    | LINE CLEAR AVAILED |
| 2469  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | KONDASAPURA                         | 10:00   | 16:20     | 06:20    | LINE CLEAR AVAILED |
| 2470  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KONDASPURA (SAFAL) - NTT GLOBAL DATA NETMAGIC 66/11KV EHT                                    | NO STATION AFFECTED                 | 10:00   | 16:30     | 06:30    | LINE CLEAR AVAILED |
| 2471  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - RAJANKUNTE                                                                | RAJANKUNTE                          | 10:55   | 11:00     | 00:05    | LINE CLEAR AVAILED |
| 2472  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA                                                                     | CHEEMANGALA, TALAGAWARA             | 11:05   | 11:10     | 00:05    | LINE CLEAR AVAILED |
| 2473  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                                                        | CHEEMANGALA, TALAGAWARA             | 18:20   | 18:26     | 00:06    | LINE CLEAR AVAILED |
| 2474  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | IRAGAMPALLI                         | 08:30   | 09:00     | 00:30    | TRIPPED ON FAULT   |
| 2475  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | IRAGAMPALLI                         | 11:35   | 11:47     | 00:12    | TRIPPED ON FAULT   |
| 2476  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | NANDIGANAHALLI                      | 15:35   | 15:40     | 00:05    | LINE CLEAR AVAILED |
| 2477  | 20-Sep-24 | BENGALURU | 400     | LINE        | ICT 3                                                                                             | DEVANAHALLI HARDWARE PARK 400       | 08:29   | 18:31     | 10:02    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                               | Station_Name                                                  | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------|---------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2478  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - VIJAYAPURA                  | VIJAYAPURA, JANGAMKOTE, MELUR                                 | 05:59   | 06:04     | 00:05    | LINE CLEAR AVAIED |
| 2479  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - VIJAYAPURA                  | VIJAYAPURA, JANGAMKOTE, MELUR                                 | 22:40   | 22:44     | 00:04    | LINE CLEAR AVAIED |
| 2480  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | DODDABELAVANGALA                                              | 23:05   | 23:15     | 00:10    | TRIPPED ON FAULT  |
| 2481  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - MANCHENAHALLI - GUNDAMGERE | GUNDAMGERE, SASALU                                            | 09:55   | 10:05     | 00:10    | LINE CLEAR AVAIED |
| 2482  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | KUNDANA                                                       | 14:00   | 14:40     | 00:40    | LINE CLEAR AVAIED |
| 2483  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - D PALYA                    | DPALYA, GUDIBANDE, MANDIKAL, MANCHENAHALLI                    | 06:53   | 07:06     | 00:13    | LOAD CURTAILMENT  |
| 2484  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - D PALYA                    | DPALYA, GUDIBANDE, MANDIKAL, MANCHENAHALLI                    | 15:02   | 15:12     | 00:10    | TRIPPED ON FAULT  |
| 2485  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUDUMULAKUNTE - THERIYUR                      | THERIYUR                                                      | 02:47   | 03:00     | 00:13    | TRIPPED ON FAULT  |
| 2486  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR                | GUNDLU KOTTUR                                                 | 22:40   | 22:50     | 00:10    | TRIPPED ON FAULT  |
| 2487  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | ADDAGAL                                                       | 16:00   | 16:50     | 00:50    | LINE CLEAR AVAIED |
| 2488  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI                             | NO STATION AFFECTED                                           | 13:43   | 16:07     | 02:24    | TRIPPED ON FAULT  |
| 2489  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV DRDO - T D HALLI (MALLASANDRA)                | MALLASANDRA                                                   | 12:35   | 12:40     | 00:05    | LINE CLEAR AVAIED |
| 2490  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | LAKKUR                                                        | 16:20   | 17:45     | 01:25    | LINE CLEAR AVAIED |
| 2491  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | LAKKUR                                                        | 16:50   | 17:45     | 00:55    | LINE CLEAR AVAIED |
| 2492  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV LAKKUR - DEVANAGUNDHI                         | DEVANAGUNDHI                                                  | 17:25   | 17:45     | 00:20    | LINE CLEAR AVAIED |
| 2493  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | MAASTHI                                                       | 11:35   | 11:40     | 00:05    | LINE CLEAR AVAIED |
| 2494  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | MAASTHI                                                       | 12:40   | 12:50     | 00:10    | LINE CLEAR AVAIED |
| 2495  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MASTHI                            | MAASTHI                                                       | 14:15   | 14:25     | 00:10    | LINE CLEAR AVAIED |
| 2496  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                | HUKUNDA                                                       | 09:40   | 09:45     | 00:05    | TRIPPED ON FAULT  |
| 2497  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - KUNUR                        | KUNUR, HAROBELE, HUKUNDA, KODIHALLI, BIJAHALLI, HUNASENAHALLI | 17:22   | 17:34     | 00:12    | TRIPPED ON FAULT  |
| 2498  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                | MARALAWADI                                                    | 13:30   | 14:50     | 01:20    | LINE CLEAR AVAIED |
| 2499  | 20-Sep-24 | BENGALURU | 66      | LINE        | 66KV NELAMANGALA 66 - ALUR                         | NO STATION AFFECTED                                           | 12:50   | 13:30     | 00:40    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                    | Station_Name        | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------|---------------------|---------|-----------|----------|---------------------|
| 2500  | 20-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2      | NO STATION AFFECTED | 23:58   | 23:59     | 00:01    | LINE CLEAR AVAIED   |
| 2501  | 20-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220  | NO STATION AFFECTED | 23:58   | 23:59     | 00:01    | LOAD CURTAILMENT    |
| 2502  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | CHANNAPATNA 220     | 16:33   | 16:45     | 00:12    | LINE CLEAR AVAIED   |
| 2503  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | TK HALLI 220        | 15:39   | 16:21     | 00:42    | LINE CLEAR AVAIED   |
| 2504  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | DASHAVARA           | 20:45   | 20:55     | 00:10    | TRIPPED ON FAULT    |
| 2505  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | KUMBARANAHALLI      | 16:46   | 16:58     | 00:12    | TRIPPED ON FAULT    |
| 2506  | 20-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | YARANDANAHALLI 220  | 09:28   | 09:33     | 00:05    | TRIPPED ON FAULT    |
| 2507  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | BANASAWADI          | 12:54   | 13:35     | 00:41    | MAIN SUPPLY FAILURE |
| 2508  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | BANASAWADI          | 15:02   | 15:06     | 00:04    | LINE CLEAR AVAIED   |
| 2509  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SAHAKARNAGAR 220 - SAHAKARNAGAR 66 | SAHAKARNAGAR 66     | 13:36   | 15:46     | 02:10    | LINE CLEAR AVAIED   |
| 2510  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | SAHAKARINAGAR 66    | 10:57   | 15:53     | 04:56    | LINE CLEAR AVAIED   |
| 2511  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | SAHAKARINAGAR 66    | 11:57   | 15:53     | 03:56    | LINE CLEAR AVAIED   |
| 2512  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                     | SAHAKARINAGAR 66    | 13:36   | 15:53     | 02:17    | LINE CLEAR AVAIED   |
| 2513  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV A STATION 220 - NRS 220           | A STATION 220       | 09:52   | 10:21     | 00:29    | MAIN SUPPLY FAILURE |
| 2514  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV A STATION 220 - EDC 220           | A STATION 220       | 09:52   | 10:30     | 00:38    | MAIN SUPPLY FAILURE |
| 2515  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | A STATION 66        | 09:52   | 10:30     | 00:38    | MAIN SUPPLY FAILURE |
| 2516  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                     | A STATION 66        | 09:52   | 10:24     | 00:32    | MAIN SUPPLY FAILURE |
| 2517  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                     | A STATION 66        | 09:52   | 10:24     | 00:32    | MAIN SUPPLY FAILURE |
| 2518  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV SRS PEENYA 220 - NRS 220          | NRS 220             | 09:52   | 10:18     | 00:26    | TRIPPED ON FAULT    |
| 2519  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                     | NRS 220             | 09:52   | 10:18     | 00:26    | MAIN SUPPLY FAILURE |
| 2520  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                     | NRS 220             | 09:52   | 10:21     | 00:29    | MAIN SUPPLY FAILURE |
| 2521  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - TELECOM LAYOUT 2         | TELECOM LAYOUT      | 09:52   | 10:28     | 00:36    | MAIN SUPPLY FAILURE |
| 2522  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - BRIGADE GATEWAY          | BRIGADE GATEWAY     | 09:52   | 10:26     | 00:34    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name        | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|---------------------|---------|-----------|----------|---------------------|
| 2523  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR                    | VIJAYANAGARA        | 09:52   | 10:26     | 00:34    | MAIN SUPPLY FAILURE |
| 2524  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                      | PALLADIUM           | 09:52   | 10:26     | 00:34    | MAIN SUPPLY FAILURE |
| 2525  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | NRS 220             | 09:52   | 10:30     | 00:38    | MAIN SUPPLY FAILURE |
| 2526  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | NRS 220             | 09:52   | 10:22     | 00:30    | MAIN SUPPLY FAILURE |
| 2527  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                           | NRS 220             | 09:52   | 10:22     | 00:30    | MAIN SUPPLY FAILURE |
| 2528  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                           | NRS 220             | 09:52   | 10:22     | 00:30    | MAIN SUPPLY FAILURE |
| 2529  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV5                                           | NRS 220             | 09:52   | 10:22     | 00:30    | MAIN SUPPLY FAILURE |
| 2530  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - TELECOM LAYOUT 2               | TELECOM LAYOUT      | 09:52   | 10:28     | 00:36    | TRIPPED ON FAULT    |
| 2531  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR                    | VIJAYANAGARA        | 11:09   | 11:17     | 00:08    | TRIPPED ON FAULT    |
| 2532  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - VIJAYANAGAR                    | VIJAYANAGARA        | 10:41   | 10:47     | 00:06    | TRIPPED ON FAULT    |
| 2533  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - A.R.CIRCLE STATION (A2)        | NO STATION AFFECTED | 15:40   | 15:47     | 00:07    | TRIPPED ON FAULT    |
| 2534  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - SHOBHA INDRAPRASTHA (A1) | SHOBHA INDRAPRASTHA | 09:52   | 10:32     | 00:40    | MAIN SUPPLY FAILURE |
| 2535  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT        | SIR MV LAYOUT       | 10:25   | 16:10     | 05:45    | LINE CLEAR AVAILED  |
| 2536  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - VICTORIA HOSPITAL        | VICTORIA HOSPITAL   | 09:52   | 10:32     | 00:40    | MAIN SUPPLY FAILURE |
| 2537  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - BANASHANKARI         | BANASHANKARI        | 10:19   | 12:38     | 02:19    | LINE CLEAR AVAILED  |
| 2538  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - REMCO                | REMCO               | 10:19   | 17:14     | 06:55    | LINE CLEAR AVAILED  |
| 2539  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                           | VRISHABHAVATHI 220  | 12:35   | 13:13     | 00:38    | LINE CLEAR AVAILED  |
| 2540  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                           | VRISHABHAVATHI 220  | 13:13   | 14:35     | 01:22    | LINE CLEAR AVAILED  |
| 2541  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | VRISHABHAVATHI 220  | 10:48   | 16:33     | 05:45    | LINE CLEAR AVAILED  |
| 2542  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | VRISHABHAVATHI 220  | 10:48   | 16:34     | 05:46    | LINE CLEAR AVAILED  |
| 2543  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - BRINDAVAN HTLS          | NO STATION AFFECTED | 11:31   | 18:00     | 06:29    | LINE CLEAR AVAILED  |
| 2544  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | SOLADEVANAHALLI     | 11:10   | 11:11     | 00:01    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                       | Station_Name                                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------|--------------------------------------------------|---------|-----------|----------|---------------------|
| 2545  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                        | SOLADEVANAHALLI                                  | 12:25   | 12:26     | 00:01    | LINE CLEAR AVAILED  |
| 2546  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - B STATION                                   | B STATION                                        | 09:05   | 17:12     | 08:07    | LINE CLEAR AVAILED  |
| 2547  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV CESSNA BUSINESS PARK 220 - EXORA 66                   | EXORA 66, CESSNA, KALYANI TECH PARK, CESSNA(EHT) | 20:50   | 20:58     | 00:08    | LINE CLEAR AVAILED  |
| 2548  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - AUSTIN TOWN                                 | AUSTIN TOWN                                      | 09:51   | 10:24     | 00:33    | MAIN SUPPLY FAILURE |
| 2549  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - BMTC                                        | BMTC                                             | 09:51   | 10:24     | 00:33    | MAIN SUPPLY FAILURE |
| 2550  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                        | EAST DIVISION COMPOUND 220                       | 09:51   | 10:20     | 00:29    | MAIN SUPPLY FAILURE |
| 2551  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                        | EAST DIVISION COMPOUND 220                       | 09:51   | 10:20     | 00:29    | MAIN SUPPLY FAILURE |
| 2552  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV EPIP 220 - HSR LAYOUT 220                            | NO STATION AFFECTED                              | 09:48   | 19:00     | 09:12    | TRIPPED ON FAULT    |
| 2553  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV EDC 220 - HAL 220                                    | EAST DIVISION COMPOUND 220                       | 09:48   | 10:17     | 00:29    | TRIPPED ON FAULT    |
| 2554  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HOSKOTE 66                                | HOSKOTE 66                                       | 10:00   | 18:00     | 08:00    | LINE CLEAR AVAILED  |
| 2555  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                        | ITI 220                                          | 10:03   | 10:05     | 00:02    | LINE CLEAR AVAILED  |
| 2556  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                        | ITI 220                                          | 12:08   | 12:10     | 00:02    | LINE CLEAR AVAILED  |
| 2557  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)                   | BANASAWADI(HV2)                                  | 12:49   | 13:35     | 00:46    | TRIPPED ON FAULT    |
| 2558  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - BANASAWADI (ITI-HEBBAL-1)                   | NO STATION AFFECTED                              | 14:15   | 15:03     | 00:48    | LINE CLEAR AVAILED  |
| 2559  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - POTTERY ROAD                                | NO STATION AFFECTED                              | 14:47   | 15:03     | 00:16    | LINE CLEAR AVAILED  |
| 2560  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                        | NGEF                                             | 17:44   | 18:26     | 00:42    | TRIPPED ON FAULT    |
| 2561  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV PRESTIGE SHANTHINIKETHAN - DARSHITHA EHT              | NO STATION AFFECTED                              | 11:23   | 12:38     | 01:15    | LINE CLEAR AVAILED  |
| 2562  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN                  | PRESTIGE SHANTINIKETHAN                          | 12:40   | 15:25     | 02:45    | LINE CLEAR AVAILED  |
| 2563  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                        | PRESTIGE SHANTINIKETHAN                          | 12:40   | 12:42     | 00:02    | LINE CLEAR AVAILED  |
| 2564  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                        | PRESTIGE SHANTINIKETHAN                          | 13:38   | 14:56     | 01:18    | LINE CLEAR AVAILED  |
| 2565  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR LAYOUT 220 - DEVARABISANAHALLI - GLOBAL TECH PARK | DEVARABISANAHALLI, GLOBAL TECH PARK              | 09:48   | 10:06     | 00:18    | TRIPPED ON FAULT    |
| 2566  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - PRIMAL                          | PRIMAL                                           | 09:55   | 10:00     | 00:05    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                                       | Station_Name             | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------------------------------------------------------|--------------------------|---------|-----------|----------|-------------------|
| 2567  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ<br>ECO WORLD ADARSHA PALM<br>VILLA RETREAT                                  | RMZ                      | 20:45   | 20:50     | 00:05    | LINE CLEAR AVAIED |
| 2568  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 -<br>PRIMAL                                                                       | PRIMAL                   | 20:45   | 20:50     | 00:05    | LINE CLEAR AVAIED |
| 2569  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - ADUGODI                                                                                     | ADUGODI                  | 09:48   | 10:08     | 00:20    | TRIPPED ON FAULT  |
| 2570  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                        | NAGANATHPURA 220         | 10:03   | 10:09     | 00:06    | LINE CLEAR AVAIED |
| 2571  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                        | NAGANATHPURA 220         | 13:23   | 13:26     | 00:03    | LINE CLEAR AVAIED |
| 2572  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                                                                        | NAGANATHPURA 220         | 14:17   | 14:24     | 00:07    | LINE CLEAR AVAIED |
| 2573  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR LAYOUT 220 - SHOBHA<br>JASMINE APARTMENT                                                          | SHOBHA JASMINE APARTMENT | 09:48   | 10:18     | 00:30    | TRIPPED ON FAULT  |
| 2574  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV EDC 220 - NIMHANS 220                                                                                | NO STATION AFFECTED      | 09:47   | 12:14     | 02:27    | TRIPPED ON FAULT  |
| 2575  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                                                                        | SOMANAHALLI 220          | 11:33   | 14:10     | 02:37    | LINE CLEAR AVAIED |
| 2576  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 -<br>MYLASANDRA 1                                                                    | NO STATION AFFECTED      | 10:52   | 12:30     | 01:38    | TRIPPED ON FAULT  |
| 2577  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - HSR<br>LAYOUT 1                                                                     | NO STATION AFFECTED      | 14:54   | 19:03     | 04:09    | LINE CLEAR AVAIED |
| 2578  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - BG<br>ROAD - ANJANAPURA (JIGANI 2)                                                  | ANJANAPURA               | 11:22   | 11:27     | 00:05    | LINE CLEAR AVAIED |
| 2579  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KHODAYS 220 -<br>ANJANAPURA                                                                           | ANJANAPURA               | 14:53   | 14:58     | 00:05    | LINE CLEAR AVAIED |
| 2580  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                        | BANASHANKARI             | 17:51   | 18:15     | 00:24    | TRIPPED ON FAULT  |
| 2581  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                        | BANASHANKARI             | 17:51   | 18:15     | 00:24    | TRIPPED ON FAULT  |
| 2582  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV RBI - ELITA PROMENADE                                                                                 | ELITA PROMENENDE         | 11:28   | 11:34     | 00:06    | LINE CLEAR AVAIED |
| 2583  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                        | HOSKOTE 220              | 09:05   | 09:20     | 00:15    | TRIPPED ON FAULT  |
| 2584  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK<br>220 - VIDYANAGAR - 12 POLE -<br>GRINDWILL - HOSKOTE 66 -<br>EKARAJPURA 220_DG4 | GRINDWELL NORTON(EHT)    | 10:12   | 12:18     | 02:06    | LINE CLEAR AVAIED |
| 2585  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA -<br>CHEEMANGALA                                                                           | CHEEMANGALA, TALAGAWARA  | 11:03   | 11:11     | 00:08    | LINE CLEAR AVAIED |
| 2586  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                                                                 | CHEEMANGALA, TALAGAWARA  | 18:32   | 18:38     | 00:06    | LINE CLEAR AVAIED |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                            | Station_Name                                   | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------|------------------------------------------------|---------|-----------|----------|---------------------|
| 2587  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - D CROSS 2                | AIR(EHT), GUNDAMGERE, SASALU, DODDABELAVANGALA | 20:43   | 21:04     | 00:21    | TRIPPED ON FAULT    |
| 2588  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3 | AIR(EHT), GUNDAMGERE, SASALU, DODDABELAVANGALA | 20:43   | 21:04     | 00:21    | TRIPPED ON FAULT    |
| 2589  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV GUNDAMGERE - SASALU                        | SASALU                                         | 07:15   | 07:20     | 00:05    | LINE CLEAR AVAIED   |
| 2590  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - ALIPURA                 | ALIPURA, THONDEBHAVI                           | 07:25   | 08:56     | 01:31    | LINE CLEAR AVAIED   |
| 2591  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - KODIGENAHALLI           | ID HALLI, KODIGENAHALLI                        | 20:30   | 20:40     | 00:10    | TRIPPED ON FAULT    |
| 2592  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR             | GUNDLU KOTTUR                                  | 23:20   | 23:25     | 00:05    | TRIPPED ON FAULT    |
| 2593  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - KOLAR 1                 | KOLAR 220                                      | 19:25   | 20:57     | 01:32    | TRIPPED ON FAULT    |
| 2594  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - KOLAR 2                 | KOLAR 220                                      | 19:25   | 20:57     | 01:32    | MAIN SUPPLY FAILURE |
| 2595  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - KOLAR 1                 | KOLAR 220                                      | 20:57   | 23:06     | 02:09    | MAIN SUPPLY FAILURE |
| 2596  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - KOLAR 2                 | KOLAR 220                                      | 20:57   | 23:07     | 02:10    | MAIN SUPPLY FAILURE |
| 2597  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOLAR 220 - BANGARPET TRACTION 1          | BANGARPETE RAILWAY TRACTION 1                  | 19:25   | 23:36     | 04:11    | MAIN SUPPLY FAILURE |
| 2598  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOLAR 220 - BANGARPET TRACTION 2          | BANGARPETE RAILWAY TRACTION 2                  | 19:25   | 23:36     | 04:11    | MAIN SUPPLY FAILURE |
| 2599  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOLAR 220 - MALUR 1                       | MALUR 220                                      | 19:25   | 23:32     | 04:07    | MAIN SUPPLY FAILURE |
| 2600  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOLAR 220 - MALUR 3                       | MALUR 220                                      | 19:25   | 23:32     | 04:07    | MAIN SUPPLY FAILURE |
| 2601  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                             | KOLAR 220                                      | 19:25   | 23:09     | 03:44    | MAIN SUPPLY FAILURE |
| 2602  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                             | KOLAR 220                                      | 19:25   | 23:08     | 03:43    | MAIN SUPPLY FAILURE |
| 2603  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                             | KOLAR 220                                      | 19:25   | 23:08     | 03:43    | MAIN SUPPLY FAILURE |
| 2604  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - NARASAPURA 2                   | NO STATION AFFECTED                            | 18:19   | 19:14     | 00:55    | TRIPPED ON FAULT    |
| 2605  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - BANGARPET 1                    | NO STATION AFFECTED                            | 19:25   | 23:44     | 04:19    | MAIN SUPPLY FAILURE |
| 2606  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - KEMBODI                        | KEMBODI                                        | 19:25   | 23:10     | 03:45    | MAIN SUPPLY FAILURE |
| 2607  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TAMAKA - DRDO                  | DRDO                                           | 19:25   | 23:32     | 04:07    | MAIN SUPPLY FAILURE |
| 2608  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI                          | NO STATION AFFECTED                            | 19:25   | 23:44     | 04:19    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                | Station_Name                  | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------------|-------------------------------|---------|-----------|----------|---------------------|
| 2609  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TAMAKA                             | TAMAKA                        | 19:25   | 20:50     | 01:25    | MAIN SUPPLY FAILURE |
| 2610  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - BANGARPET 2                        | BANGARPETE                    | 19:25   | 20:27     | 01:02    | MAIN SUPPLY FAILURE |
| 2611  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TALAGUNDA                          | VEMGAL, KYALANUR, TALAGUNDA   | 19:25   | 20:05     | 00:40    | MAIN SUPPLY FAILURE |
| 2612  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA   | SUGUTUR, PGCIL, KC VALLEY     | 19:25   | 20:37     | 01:12    | MAIN SUPPLY FAILURE |
| 2613  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - NARASAPURA 1                       | NARASAPURA                    | 19:25   | 23:43     | 04:18    | MAIN SUPPLY FAILURE |
| 2614  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - NARASAPURA 2                       | NARASAPURA                    | 19:25   | 23:10     | 03:45    | MAIN SUPPLY FAILURE |
| 2615  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - VOKKALERI                          | VOKKALERI, KC VALLEY          | 19:25   | 23:10     | 03:45    | MAIN SUPPLY FAILURE |
| 2616  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                 | KOLAR 220                     | 19:25   | 23:10     | 03:45    | MAIN SUPPLY FAILURE |
| 2617  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | KOLAR 220                     | 19:25   | 23:10     | 03:45    | MAIN SUPPLY FAILURE |
| 2618  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                 | KOLAR 220                     | 19:25   | 23:45     | 04:20    | MAIN SUPPLY FAILURE |
| 2619  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                          | KYALANUR, TALAGUNDA, VEMGAL   | 23:14   | 23:22     | 00:08    | LINE CLEAR AVAIED   |
| 2620  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MUDIYANUR - H GOLAHALLI     | MUDIYANUR, H GOLLAHALLI       | 08:55   | 18:00     | 09:05    | LINE CLEAR AVAIED   |
| 2621  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - MULBAGAL - BYRAKUR - NANGLI | BYRAKUR, NANGLI               | 08:55   | 18:08     | 09:13    | LINE CLEAR AVAIED   |
| 2622  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                 | SUGUTUR                       | 12:20   | 12:45     | 00:25    | LINE CLEAR AVAIED   |
| 2623  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA   | SUGUTUR, KC VALLEY            | 23:15   | 23:20     | 00:05    | LINE CLEAR AVAIED   |
| 2624  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - THAYALUR                    | THAYALUR, NG HULKUR, MN HALLI | 06:29   | 06:50     | 00:21    | TRIPPED ON FAULT    |
| 2625  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - THAYALUR                    | THAYALUR, NG HULKUR, MN HALLI | 08:55   | 18:05     | 09:10    | LINE CLEAR AVAIED   |
| 2626  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - ANDERSONPET                 | ANDERSONPETE                  | 08:55   | 18:15     | 09:20    | LINE CLEAR AVAIED   |
| 2627  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - BANGARPET - KGF 2                  | BANGARPETE                    | 23:49   | 23:50     | 00:01    | LINE CLEAR AVAIED   |
| 2628  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - KGF 1                       | KGF, BEML, KAMASAMUDRA        | 08:55   | 18:03     | 09:08    | LINE CLEAR AVAIED   |
| 2629  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - KGF 2                       | KGF, BEML, KAMASAMUDRA        | 08:55   | 18:03     | 09:08    | LINE CLEAR AVAIED   |
| 2630  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - KYASAMBALLI                 | KYASAMBALLI, DODDAKARI        | 08:55   | 18:00     | 09:05    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                      | Station_Name                          | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------|---------------------------------------|---------|-----------|----------|---------------------|
| 2631  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - LAKKUR                                                   | LAKKUR, DEVANAGUNDHI                  | 19:25   | 20:25     | 01:00    | MAIN SUPPLY FAILURE |
| 2632  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MASTHI                                                   | MASTHI                                | 19:25   | 20:25     | 01:00    | MAIN SUPPLY FAILURE |
| 2633  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                       | MALUR 220                             | 19:25   | 20:21     | 00:56    | MAIN SUPPLY FAILURE |
| 2634  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                       | MALUR 220                             | 19:25   | 20:21     | 00:56    | MAIN SUPPLY FAILURE |
| 2635  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV MALUR 220 - SARJAPURA<br>220 - VIKAS TECH PARK 220 -<br>EXORA 220 2 | SARJAPURA 220                         | 19:25   | 19:55     | 00:30    | MAIN SUPPLY FAILURE |
| 2636  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR TOWN                                               | MALUR 66                              | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2637  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MASTHI                                                   | MASTHI                                | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2638  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR I/A                                                | MALUR IND AREA                        | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2639  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - TEKAL - KGF 1                                            | TEKAL, BUDIKOTE, THORALAKKI           | 19:25   | 20:30     | 01:05    | MAIN SUPPLY FAILURE |
| 2640  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - BANGARPET -<br>KGF 2                                     | NO STATION AFFECTED                   | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2641  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR I/A -<br>JADIGENAHALLI (HOSKOTE -1)                | MALUR IND AREA, BEST STEEL,ADL<br>IPP | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2642  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - VOKKALERI 1 -<br>HOSKOTE 2                               | JADIGENAHALLI                         | 19:25   | 20:23     | 00:58    | MAIN SUPPLY FAILURE |
| 2643  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | MALUR IND AREA                        | 09:15   | 09:34     | 00:19    | LINE CLEAR AVAIED   |
| 2644  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - T<br>GOLLAHALLI 1                                 | T GOLLAHALLI                          | 09:51   | 17:51     | 08:00    | LINE CLEAR AVAIED   |
| 2645  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV PGCIL KOLAR 400 - T<br>GOLLAHALLI 2                                 | T GOLLAHALLI                          | 09:51   | 17:51     | 08:00    | LINE CLEAR AVAIED   |
| 2646  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                       | T GOLLAHALLI                          | 09:49   | 17:52     | 08:03    | LINE CLEAR AVAIED   |
| 2647  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                       | T GOLLAHALLI                          | 09:49   | 17:52     | 08:03    | LINE CLEAR AVAIED   |
| 2648  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | T GOLLAHALLI                          | 09:49   | 17:58     | 08:09    | LINE CLEAR AVAIED   |
| 2649  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV T GOLLAHALLI 220 - AVANI                                             | AVANI, MULBAGAL                       | 08:56   | 17:58     | 09:02    | LINE CLEAR AVAIED   |
| 2650  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HANUMANTHANAGARA -<br>YEDAMADU                                       | HANUMANTHANAGARA                      | 10:07   | 10:12     | 00:05    | LINE CLEAR AVAIED   |
| 2651  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HAROHALLI 220 -<br>SANJEEVANADODDI                             | SANJEEVANADODDI,<br>RANGANADODDI      | 10:45   | 11:09     | 00:24    | TRIPPED ON FAULT    |
| 2652  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV HANUMANTHANAGARA -<br>YEDAMADU                                       | YEDUMADU                              | 14:31   | 14:43     | 00:12    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name                                | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|---------------------------------------------|---------|-----------|----------|---------------------|
| 2653  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV NELAMANGALA 66 - ALUR                    | ALUR                                        | 10:00   | 15:30     | 05:30    | LINE CLEAR AVAIED   |
| 2654  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | HULLENAHALLI                                | 19:35   | 19:45     | 00:10    | LINE CLEAR AVAIED   |
| 2655  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - BIDADI 220 -1           | NO STATION AFFECTED                         | 10:30   | 12:58     | 02:28    | LINE CLEAR AVAIED   |
| 2656  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI | KEMPANAHALLI, MELEHALLI, URAGAHALLI         | 12:03   | 12:13     | 00:10    | LINE CLEAR AVAIED   |
| 2657  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - KEMPANAHALLI                | KEMPANAHALLI, MELEHALLI, URAGAHALLI         | 16:52   | 17:02     | 00:10    | LINE CLEAR AVAIED   |
| 2658  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV TUBINAKERE 220 - KOTHIPURA 2            | NO STATION AFFECTED                         | 23:59   | 11:14     | 12:45    | LINE CLEAR AVAIED   |
| 2659  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                           | KOTHIPURA 220                               | 11:53   | 13:39     | 01:46    | LINE CLEAR AVAIED   |
| 2660  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - MELEHALLI - KEMPANAHALLI | NO STATION AFFECTED                         | 12:38   | 16:30     | 03:52    | LINE CLEAR AVAIED   |
| 2661  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | KOTHIPURA 220                               | 15:00   | 16:50     | 01:50    | LINE CLEAR AVAIED   |
| 2662  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV JALAMANGALA - MATHIKERE                  | JALAMANGALA, KUTAGALLU, MELEHALLI           | 16:37   | 16:42     | 00:05    | LINE CLEAR AVAIED   |
| 2663  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR   | BEVOOR, DASHAVARA, SANKALGERE, VANDARAGUPPE | 11:17   | 11:23     | 00:06    | TRIPPED ON FAULT    |
| 2664  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV CHANNAPATNA 220 - TUBINAKERE 220        | NO STATION AFFECTED                         | 23:59   | 12:05     | 11:54    | LOAD CURTAILMENT    |
| 2665  | 21-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                        | NO STATION AFFECTED                         | 09:13   | 17:51     | 08:38    | LINE CLEAR AVAIED   |
| 2666  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                 | ATTIBELE                                    | 10:00   | 10:18     | 00:18    | LINE CLEAR AVAIED   |
| 2667  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                 | ATTIBELE                                    | 15:00   | 15:18     | 00:18    | LINE CLEAR AVAIED   |
| 2668  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                 | ATTIBELE                                    | 19:25   | 20:02     | 00:37    | MAIN SUPPLY FAILURE |
| 2669  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | CHANDAPURA                                  | 10:00   | 15:00     | 05:00    | LINE CLEAR AVAIED   |
| 2670  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | CHANDAPURA                                  | 10:00   | 15:00     | 05:00    | LINE CLEAR AVAIED   |
| 2671  | 21-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - DOMMASANDRA              | DOMMASANDRA                                 | 10:00   | 10:45     | 00:45    | LINE CLEAR AVAIED   |
| 2672  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | DOMMASANDRA                                 | 10:05   | 12:05     | 02:00    | LINE CLEAR AVAIED   |
| 2673  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | DOMMASANDRA                                 | 10:05   | 12:05     | 02:00    | LINE CLEAR AVAIED   |
| 2674  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | HUSKUR                                      | 18:40   | 19:05     | 00:25    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                      | Station_Name                                   | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------|------------------------------------------------|---------|-----------|----------|---------------------|
| 2675  | 21-Sep-24 | BENGALURU | 220     | LINE        | 220KV MALUR 220 - SARJAPURA<br>220 - VIKAS TECH PARK 220 -<br>EXORA 220 2 | SARJAPURA 220                                  | 10:00   | 15:18     | 05:18    | LINE CLEAR AVAIED   |
| 2676  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                       | SARJAPURA 220                                  | 10:00   | 15:18     | 05:18    | LINE CLEAR AVAIED   |
| 2677  | 21-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                       | SARJAPURA 220                                  | 10:00   | 16:28     | 06:28    | LINE CLEAR AVAIED   |
| 2678  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | SARJAPURA 220                                  | 10:00   | 16:28     | 06:28    | LINE CLEAR AVAIED   |
| 2679  | 21-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                       | SARJAPURA 220                                  | 10:00   | 16:28     | 06:28    | LINE CLEAR AVAIED   |
| 2680  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - BIDADI<br>220 -2                                    | NO STATION AFFECTED                            | 10:14   | 12:10     | 01:56    | LINE CLEAR AVAIED   |
| 2681  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                       | BIDADI 220                                     | 10:07   | 17:32     | 07:25    | LINE CLEAR AVAIED   |
| 2682  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                                       | BIDADI 220                                     | 10:09   | 13:25     | 03:16    | LINE CLEAR AVAIED   |
| 2683  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - TTIPL (EHT)                                             | TTIPL(EHT)                                     | 10:12   | 14:33     | 04:21    | LINE CLEAR AVAIED   |
| 2684  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - BOSCH (EHT)                                             | BOSCH(EHT)                                     | 10:12   | 14:42     | 04:30    | LINE CLEAR AVAIED   |
| 2685  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - COCA COLA<br>(EHT)                                      | COCO COLA(EHT)                                 | 10:12   | 14:46     | 04:34    | LINE CLEAR AVAIED   |
| 2686  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | BIDADI 220                                     | 17:50   | 18:45     | 00:55    | LINE CLEAR AVAIED   |
| 2687  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANAHALLI<br>- HEJJALA 1                              | HEJJALA                                        | 10:00   | 16:15     | 06:15    | LINE CLEAR AVAIED   |
| 2688  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 -<br>KOTHIPURA 2 - BEVOOR                            | BEVOOR, DASHAVARA,<br>SANKALGERE, VANDARAGUPPE | 09:02   | 09:10     | 00:08    | TRIPPED ON FAULT    |
| 2689  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - IGGALURU                                              | IGGALUR                                        | 05:53   | 06:36     | 00:43    | MAIN SUPPLY FAILURE |
| 2690  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                       | TK HALLI 220                                   | 05:58   | 06:22     | 00:24    | TRIPPED ON FAULT    |
| 2691  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                       | TK HALLI 220                                   | 05:58   | 06:36     | 00:38    | TRIPPED ON FAULT    |
| 2692  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                                       | TK HALLI 220                                   | 05:58   | 06:40     | 00:42    | TRIPPED ON FAULT    |
| 2693  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 1                                               | TK HALLI 220                                   | 05:58   | 06:25     | 00:27    | MAIN SUPPLY FAILURE |
| 2694  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 2                                               | TK HALLI 220                                   | 05:58   | 06:25     | 00:27    | MAIN SUPPLY FAILURE |
| 2695  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 3                                               | TK HALLI 220                                   | 05:58   | 06:25     | 00:27    | MAIN SUPPLY FAILURE |
| 2696  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 4                                               | TK HALLI 220                                   | 05:58   | 06:25     | 00:27    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                         | Station_Name                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|----------------------------------------------|----------------------------------|---------|-----------|----------|---------------------|
| 2697  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - AKKURMOLE                | AKKURMOLE                        | 05:58   | 06:38     | 00:40    | MAIN SUPPLY FAILURE |
| 2698  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - IGGALURU                 | IGGALUR, YETHAMBADI, K HONALGERE | 05:58   | 06:38     | 00:40    | MAIN SUPPLY FAILURE |
| 2699  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - MANDYA 1                      | KK DODDI, KM DODDI, KIADB        | 05:58   | 06:38     | 00:40    | MAIN SUPPLY FAILURE |
| 2700  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - MANDYA 2                      | THALAGAVADI, TUMBGERE            | 05:58   | 06:38     | 00:40    | MAIN SUPPLY FAILURE |
| 2701  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                       | NO STATION AFFECTED              | 05:58   | 06:55     | 00:57    | MAIN SUPPLY FAILURE |
| 2702  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - LIMBAVALLI                    | NO STATION AFFECTED              | 05:58   | 06:46     | 00:48    | MAIN SUPPLY FAILURE |
| 2703  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - GURUVINAPURA - V R DODDI | GURUVINAPURA, BV HALLI           | 05:58   | 06:39     | 00:41    | MAIN SUPPLY FAILURE |
| 2704  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | TK HALLI 220                     | 05:58   | 06:22     | 00:24    | MAIN SUPPLY FAILURE |
| 2705  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | TK HALLI 220                     | 05:58   | 06:37     | 00:39    | MAIN SUPPLY FAILURE |
| 2706  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - GURUVINAPURA - V R DODDI | GURUVINAPURA, BV HALLI           | 06:39   | 07:32     | 00:53    | TRIPPED ON FAULT    |
| 2707  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                       | NO STATION AFFECTED              | 09:04   | 18:09     | 09:05    | LINE CLEAR AVAIED   |
| 2708  | 22-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                       | NO STATION AFFECTED              | 15:14   | 16:05     | 00:51    | LINE CLEAR AVAIED   |
| 2709  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                   | SURYA CITY                       | 10:12   | 14:39     | 04:27    | LINE CLEAR AVAIED   |
| 2710  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE                | ATTIBELE                         | 10:00   | 15:32     | 05:32    | LINE CLEAR AVAIED   |
| 2711  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - ATTIBELE                       | ATTIBELE                         | 10:00   | 15:36     | 05:36    | LINE CLEAR AVAIED   |
| 2712  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | BOMMASANDRA I/A                  | 08:10   | 08:15     | 00:05    | LINE CLEAR AVAIED   |
| 2713  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | BOMMASANDRA I/A                  | 13:30   | 17:00     | 03:30    | LINE CLEAR AVAIED   |
| 2714  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                          | JIGANI 220                       | 13:56   | 14:53     | 00:57    | LINE CLEAR AVAIED   |
| 2715  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | SARJAPURA 220                    | 10:17   | 10:22     | 00:05    | LINE CLEAR AVAIED   |
| 2716  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                          | SARJAPURA 220                    | 10:17   | 18:18     | 08:01    | LINE CLEAR AVAIED   |
| 2717  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | SURYA CITY                       | 15:01   | 16:45     | 01:44    | LINE CLEAR AVAIED   |
| 2718  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                          | YARANDANAHALLI 220               | 10:26   | 10:58     | 00:32    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                             | Station_Name                                  | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------------|-----------------------------------------------|---------|-----------|----------|-------------------|
| 2719  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                              | YARANDANAHALLI 220                            | 17:30   | 17:45     | 00:15    | LINE CLEAR AVAIED |
| 2720  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR LAYOUT 220 -<br>DEVARABISANAHALLI - GLOBAL<br>TECH PARK | GLOBAL TECH PARK                              | 11:05   | 11:09     | 00:04    | LINE CLEAR AVAIED |
| 2721  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - GTP                                   | GLOBAL TECH PARK                              | 17:01   | 17:04     | 00:03    | LINE CLEAR AVAIED |
| 2722  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 -<br>PRIMAL                             | PRIMAL                                        | 11:08   | 11:18     | 00:10    | LINE CLEAR AVAIED |
| 2723  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 -<br>DODDERI - CHANDRAPPA CIRCLE            | DODDERI, CHANDRAPPA CIRCLE                    | 10:00   | 18:15     | 08:15    | LINE CLEAR AVAIED |
| 2724  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - KHB DG-1                                   | NO STATION AFFECTED                           | 06:26   | 09:50     | 03:24    | TRIPPED ON FAULT  |
| 2725  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - BMTC                                              | BMTC                                          | 21:19   | 21:35     | 00:16    | TRIPPED ON FAULT  |
| 2726  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV NATIONAL COLLEGE - BMTC                                     | NO STATION AFFECTED                           | 21:19   | 23:59     | 02:40    | TRIPPED ON FAULT  |
| 2727  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>APPAREL PARK - D CROSS 3               | NO STATION AFFECTED                           | 07:44   | 07:55     | 00:11    | TRIPPED ON FAULT  |
| 2728  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA -<br>GUNDLU KOTHUR                           | GUNDLU KOTTUR                                 | 13:45   | 13:55     | 00:10    | TRIPPED ON FAULT  |
| 2729  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV PATHPALYA -<br>THIMMAMPALLI                                 | THIMMAMPALLI SUBSTATION                       | 15:35   | 15:50     | 00:15    | TRIPPED ON FAULT  |
| 2730  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - SOLURU<br>(GUEMARNAHALLI)                      | GM HALLI                                      | 07:50   | 08:05     | 00:15    | TRIPPED ON FAULT  |
| 2731  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 -<br>KOTHIPURA 2 - BEVOOR                   | BEVOOR,SANKALAGERE,<br>DASHAVARA,VANDARAGUPPE | 09:02   | 09:10     | 00:08    | TRIPPED ON FAULT  |
| 2732  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | HENNUR CROSS                                  | 04:02   | 04:08     | 00:06    | TRIPPED ON FAULT  |
| 2733  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - KHB DG-1                                   | NO STATION AFFECTED                           | 09:18   | 09:50     | 00:32    | LINE CLEAR AVAIED |
| 2734  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - A STATION<br>66/11KV (A1)                   | A STATION 66                                  | 10:53   | 16:37     | 05:44    | LINE CLEAR AVAIED |
| 2735  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - A STATION<br>66/11KV (A2)                   | A STATION 66                                  | 10:37   | 14:32     | 03:55    | LINE CLEAR AVAIED |
| 2736  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUMBALAGODU 220 -<br>KENGARI SATELLITE TOWN 2               | KENGARI SATELLITE TOWN                        | 09:05   | 09:09     | 00:04    | LINE CLEAR AVAIED |
| 2737  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KENGARI SATELLITE TOWN -<br>SIR MV LAYOUT                   | KENGARI SATELLITE TOWN                        | 15:22   | 15:26     | 00:04    | LINE CLEAR AVAIED |
| 2738  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | REMCO                                         | 09:10   | 09:12     | 00:02    | LINE CLEAR AVAIED |
| 2739  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV REMCO - VIJAYANAGAR                                         | VIJAYANAGAR                                   | 18:41   | 18:48     | 00:07    | LINE CLEAR AVAIED |
| 2740  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                              | BYADARAHALLI                                  | 10:20   | 10:25     | 00:05    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                                 | Station_Name              | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------------------------------------------------------|---------------------------|---------|-----------|----------|--------------------|
| 2741  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOKULA - BEL EHT                                                                                | BEL(EHT)                  | 07:02   | 18:35     | 11:33    | LINE CLEAR AVAILED |
| 2742  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV HEBBAL 220 - IISC                                                                               | IISC                      | 10:15   | 15:00     | 04:45    | LINE CLEAR AVAILED |
| 2743  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - IISC                                                                                  | NO STATION AFFECTED       | 10:15   | 15:25     | 05:10    | LINE CLEAR AVAILED |
| 2744  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KADUGODI - ARMY WELFARE HOUSING ORGANISATION - ALLEMBIC GLASS FACTORY [TAP]                     | ARMY WELFARE ORGANISATION | 07:40   | 08:15     | 00:35    | LINE CLEAR AVAILED |
| 2745  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV ARMY WELFARE HOUSING ORGANISATION - KONDASAPURA (SAFAL)                                         | ARMY WELFARE ORGANISATION | 10:01   | 10:04     | 00:03    | LINE CLEAR AVAILED |
| 2746  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EPIP 220 - KADUGODI                                                                             | NO STATION AFFECTED       | 07:55   | 09:50     | 01:55    | LINE CLEAR AVAILED |
| 2747  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 220 - BIAL BEGUR 220                                                                     | NO STATION AFFECTED       | 10:20   | 15:28     | 05:08    | LINE CLEAR AVAILED |
| 2748  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                                                                  | ITI 220                   | 10:05   | 12:05     | 02:00    | LINE CLEAR AVAILED |
| 2749  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV PRESTIGE SHANTHINIKETHAN - DARSHITHA EHT                                                        | PRESTIGE SHANTHINIKETHAN  | 16:02   | 16:10     | 00:08    | LINE CLEAR AVAILED |
| 2750  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT                                                       | SHOBHA JASMINE APARTMENT  | 11:19   | 11:28     | 00:09    | LINE CLEAR AVAILED |
| 2751  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR LAYOUT 220 - SHOBHA JASMINE APARTMENT                                                       | SHOBHA JASMINE APARTMENT  | 17:16   | 17:24     | 00:08    | LINE CLEAR AVAILED |
| 2752  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                                                  | HSR LAYOUT 220            | 11:34   | 13:45     | 02:11    | LINE CLEAR AVAILED |
| 2753  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV MYLASANDRA 400 - HSR LAYOUT 2                                                                  | NO STATION AFFECTED       | 16:34   | 17:48     | 01:14    | LINE CLEAR AVAILED |
| 2754  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - MYLASANDRA 2                                                                 | NO STATION AFFECTED       | 09:15   | 15:58     | 06:43    | LINE CLEAR AVAILED |
| 2755  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV SOMANAHALLI 220 - KHODAYS 220                                                                  | NO STATION AFFECTED       | 11:02   | 15:55     | 04:53    | LINE CLEAR AVAILED |
| 2756  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - SAINT GOBIN - BHURUKA GAS - ORCHID LAMINTES 1 - AO SMITH - ORCHID LAMINATES-2 | NO STATION AFFECTED       | 10:01   | 13:01     | 03:00    | LINE CLEAR AVAILED |
| 2757  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - PADMANABHA NAGAR - AREHALLI                                                | AREHALLI                  | 10:30   | 10:36     | 00:06    | LINE CLEAR AVAILED |
| 2758  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV AREHALLI - BANASHANKARI                                                                         | AREHALLI                  | 16:27   | 16:40     | 00:13    | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                 | Station_Name      | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|------------------------------------------------------|-------------------|---------|-----------|----------|--------------------|
| 2759  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BTM 4TH PHASE - SAUDELA (HIRANANDANI APARTMENT) | SOUDELLA,DLF      | 11:05   | 11:08     | 00:03    | LINE CLEAR AVAILED |
| 2760  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                  | BTM 4TH PHASE     | 11:15   | 11:20     | 00:05    | LINE CLEAR AVAILED |
| 2761  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                  | BTM 4TH PHASE     | 12:50   | 12:54     | 00:04    | LINE CLEAR AVAILED |
| 2762  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66          | SUBRAMANYAPURA 66 | 10:54   | 10:58     | 00:04    | LINE CLEAR AVAILED |
| 2763  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66 - ISKCON | SUBRAMANYAPURA 66 | 16:23   | 16:28     | 00:05    | LINE CLEAR AVAILED |
| 2764  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV AERO SPACE 220 - BIAL BEGUR 220                | AERO SPACE 220    | 09:33   | 18:55     | 09:22    | LINE CLEAR AVAILED |
| 2765  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP 220 - AERO SPACE 220      | AERO SPACE 220    | 10:32   | 19:17     | 08:45    | LINE CLEAR AVAILED |
| 2766  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                  | AERO SPACE 220    | 10:13   | 18:57     | 08:44    | LINE CLEAR AVAILED |
| 2767  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                  | AERO SPACE 220    | 09:38   | 18:58     | 09:20    | LINE CLEAR AVAILED |
| 2768  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV AERO SPACE 220 - BOEING (EHT)                   | AERO SPACE 220    | 10:06   | 19:00     | 08:54    | LINE CLEAR AVAILED |
| 2769  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                  | AERO SPACE 220    | 09:48   | 19:14     | 09:26    | LINE CLEAR AVAILED |
| 2770  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                  | AERO SPACE 220    | 10:12   | 19:16     | 09:04    | LINE CLEAR AVAILED |
| 2771  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 1        | BIAL BEGUR 220    | 10:25   | 18:54     | 08:29    | LINE CLEAR AVAILED |
| 2772  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP 220 - BIAL BEGUR 2        | BIAL BEGUR 220    | 10:25   | 18:54     | 08:29    | LINE CLEAR AVAILED |
| 2773  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 220 - BIAL BEGUR 220                     | BIAL BEGUR 220    | 10:20   | 15:35     | 05:15    | LINE CLEAR AVAILED |
| 2774  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV NRS DB PURA 220 - BIAL BEGUR 220               | BIAL BEGUR 220    | 10:20   | 19:03     | 08:43    | LINE CLEAR AVAILED |
| 2775  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                  | BIAL BEGUR 220    | 10:22   | 17:34     | 07:12    | LINE CLEAR AVAILED |
| 2776  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                  | BIAL BEGUR 220    | 10:22   | 17:34     | 07:12    | LINE CLEAR AVAILED |
| 2777  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                  | BIAL BEGUR 220    | 10:02   | 15:35     | 05:33    | LINE CLEAR AVAILED |
| 2778  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - BIAL 1 (EHT)                   | AIRPORT           | 10:02   | 15:37     | 05:35    | LINE CLEAR AVAILED |
| 2779  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - BIAL 2 (EHT)                   | AIRPORT           | 10:02   | 15:37     | 05:35    | LINE CLEAR AVAILED |
| 2780  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                  | BIAL BEGUR 220    | 10:24   | 17:45     | 07:21    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                                | Station_Name                           | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------------------------------------------------------------|----------------------------------------|---------|-----------|----------|-------------------|
| 2781  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                 | BIAL BEGUR 220                         | 10:21   | 17:45     | 07:24    | LINE CLEAR AVAIED |
| 2782  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - VIDYANAGAR                                                                    | VIDYANAGAR                             | 09:15   | 17:48     | 08:33    | LINE CLEAR AVAIED |
| 2783  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - 66 KV ITC AIRPORT ROAD (EHT)                                                  | ITC(EHT)                               | 10:12   | 17:51     | 07:39    | LINE CLEAR AVAIED |
| 2784  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - BUDIGERE                                                                      | BUDIGERE                               | 10:07   | 18:40     | 08:33    | LINE CLEAR AVAIED |
| 2785  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BIAL BEGUR 220                                                               | BIAL BEGUR 220                         | 10:05   | 18:57     | 08:52    | LINE CLEAR AVAIED |
| 2786  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP 220 - EKARAJAPURA 1                                                      | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2787  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP 220 - EKARAJAPURA 2                                                      | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2788  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                                                 | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2789  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                                                 | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2790  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BIAL BEGUR 220                                                               | BIAL BEGUR 220                         | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2791  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA (SAFAL)                                      | KONADASAPURA                           | 10:00   | 19:25     | 09:25    | LINE CLEAR AVAIED |
| 2792  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJAPURA 220 _DG4 | VIDYANAGAR, GRINDWELL(EHT), HOSKOTE 66 | 10:00   | 19:20     | 09:20    | LINE CLEAR AVAIED |
| 2793  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA                                                                   | PILLAGUMPA                             | 10:00   | 19:10     | 09:10    | LINE CLEAR AVAIED |
| 2794  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - PILLAGUMPA - VOLVO - NANDAGUDI                                               | NANDAGUDI, VOLVO                       | 10:00   | 19:10     | 09:10    | LINE CLEAR AVAIED |
| 2795  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - SULIBELE                                                                     | SULIBELE, CHANNARAYAPATNA              | 10:00   | 19:10     | 09:10    | LINE CLEAR AVAIED |
| 2796  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BUDIGERE                                                                     | NO STATION AFFECTED                    | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2797  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                 | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2798  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                 | EKARAJAPURA 220                        | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2799  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 1                                                  | KIADB HARDWARE PARK 220                | 10:34   | 19:15     | 08:41    | LINE CLEAR AVAIED |
| 2800  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - KIADB DEVANAHALLI HP 2                                                  | KIADB HARDWARE PARK 220                | 10:34   | 19:15     | 08:41    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                                        | Station_Name                              | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------------------------------------------------------------------|-------------------------------------------|---------|-----------|----------|-------------------|
| 2801  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP<br>220 - BIAL BEGUR 1                                                            | BIAL BEGUR 220                            | 10:28   | 18:55     | 08:27    | LINE CLEAR AVAIED |
| 2802  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP<br>220 - BIAL BEGUR 2                                                            | BIAL BEGUR 220                            | 10:28   | 18:55     | 08:27    | LINE CLEAR AVAIED |
| 2803  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP<br>220 - EKARAJPURA 1                                                            | EKARAJPURA 220                            | 10:19   | 18:59     | 08:40    | LINE CLEAR AVAIED |
| 2804  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV KIADB DEVANAHALLI HP<br>220 - EKARAJPURA 2                                                            | EKARAJPURA 220                            | 10:19   | 18:59     | 08:40    | LINE CLEAR AVAIED |
| 2805  | 22-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                                                                         | KIADB HARDWARE PARK 220                   | 10:00   | 18:59     | 08:59    | LINE CLEAR AVAIED |
| 2806  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                         | KIADB HARDWARE PARK 220                   | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2807  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK<br>220 - 66KV SHELL EHT                                                            | SHELL EHT                                 | 09:55   | 19:03     | 09:08    | LINE CLEAR AVAIED |
| 2808  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK<br>220 - 66KV BHP MINI IRRIGATION<br>EHT                                           | BHP MINI IRRIGATION EHT                   | 09:50   | 19:03     | 09:13    | LINE CLEAR AVAIED |
| 2809  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK<br>220 - VIDYANAGAR - 12 POLE -<br>GRINDWILL - HOSKOTE 66 -<br>EKARAJPURA 220 _DG4 | VIDYANAGAR, GRINDWELL(EHT),<br>HOSKOTE 66 | 10:01   | 19:26     | 09:25    | LINE CLEAR AVAIED |
| 2810  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 220 -<br>TALAGAWARA                                                                         | TALAGAWARA, CHEEMANGALA                   | 12:00   | 12:10     | 00:10    | LINE CLEAR AVAIED |
| 2811  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                                                                  | TALAGAWARA, CHEEMANGALA                   | 19:10   | 19:15     | 00:05    | LINE CLEAR AVAIED |
| 2812  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 66 - RAILWAY<br>TRACTION 66/25KV                                                            | RAILWAY TRACTION 66/25KV                  | 10:40   | 18:40     | 08:00    | LINE CLEAR AVAIED |
| 2813  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | GANJIGUNTE                                | 00:09   | 00:15     | 00:06    | TRIPPED ON FAULT  |
| 2814  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIJAYAPURA -<br>JANGAMKOTE - MELUR                                                                     | MELUR                                     | 09:00   | 09:05     | 00:05    | LINE CLEAR AVAIED |
| 2815  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV SIDDALAGHATTA - MELUR                                                                                  | MELUR                                     | 19:35   | 19:45     | 00:10    | LINE CLEAR AVAIED |
| 2816  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS -<br>NRS DB PURA 220 1                                                            | NO STATION AFFECTED                       | 10:40   | 19:22     | 08:42    | LINE CLEAR AVAIED |
| 2817  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS -<br>NRS DB PURA 220 2                                                            | NO STATION AFFECTED                       | 10:40   | 19:22     | 08:42    | LINE CLEAR AVAIED |
| 2818  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV GUNDAMGERE - D CROSS                                                                                   | GUNDAMGERE AND SASLU                      | 09:50   | 09:55     | 00:05    | LINE CLEAR AVAIED |
| 2819  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 -<br>MANCHENAHALLI -<br>GUNDAMGERE                                                    | GUNDAMGERE AND SASLU                      | 19:33   | 19:38     | 00:05    | LINE CLEAR AVAIED |
| 2820  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                         | MANCHENAHALLI                             | 23:05   | 23:20     | 00:15    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                              | Station_Name                                               | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------------------------|------------------------------------------------------------|---------|-----------|----------|-------------------|
| 2821  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                               | THONDEBHAVI                                                | 02:15   | 02:25     | 00:10    | TRIPPED ON FAULT  |
| 2822  | 22-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | HUKUNDHA                                                   | 14:05   | 14:10     | 00:05    | TRIPPED ON FAULT  |
| 2823  | 22-Sep-24 | BENGALURU | 66      | LINE        | 220KV NELAMANGALA 400 - DABASPETE 220 (B3)                        | DABASPETE 220                                              | 10:08   | 19:04     | 08:56    | LINE CLEAR AVAIED |
| 2824  | 22-Sep-24 | BENGALURU | 66      | LINE        | 220KV DABASPETE 220 - KADUR 220                                   | NO STATION AFFECTED                                        | 10:08   | 19:04     | 08:56    | LINE CLEAR AVAIED |
| 2825  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - NELAMANGALA CKT 1                            | NELAMANGALA 66                                             | 10:15   | 18:50     | 08:35    | LINE CLEAR AVAIED |
| 2826  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2) | T BEGUR, TYMAGONDLU, RAILWAYS                              | 10:00   | 19:00     | 09:00    | LINE CLEAR AVAIED |
| 2827  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - HIREHALLI                                    | HIREHALLI                                                  | 10:08   | 19:04     | 08:56    | LINE CLEAR AVAIED |
| 2828  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - AVERAHALLI                                   | AVERAHALLI                                                 | 10:00   | 17:00     | 07:00    | LINE CLEAR AVAIED |
| 2829  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - SK STEEL                                     | SK STEEL                                                   | 10:08   | 19:04     | 08:56    | LINE CLEAR AVAIED |
| 2830  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2) | T BEGUR, TYMAGONDLU, RAILWAYS                              | 21:12   | 22:50     | 01:38    | LINE CLEAR AVAIED |
| 2831  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - MAGADI 66 - HOSPALYA - ANCHEPALYA               | HULLENALLI, KUDUR, SRIGIRIPURA, HOSPALYA CIRCLE, MAGADI 66 | 10:06   | 18:53     | 08:47    | LINE CLEAR AVAIED |
| 2832  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - VG DODDI - TG HALLI                             | VG DODDI, TG HALLI, BWSSB TG HALLI , TAVAREKER, KODIGEHALI | 10:05   | 18:30     | 08:25    | LINE CLEAR AVAIED |
| 2833  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE                           | AGALKOTE, MATHIKERE                                        | 10:00   | 18:45     | 08:45    | LINE CLEAR AVAIED |
| 2834  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - SOLURU (GUDEMARNAHALLI)                         | GUDEMARAHALLI                                              | 10:05   | 18:30     | 08:25    | LINE CLEAR AVAIED |
| 2835  | 22-Sep-24 | BENGALURU | 66      | LINE        | 220KV NELAMANGALA 400 - MAGADI CKT 2                              | MAGADI 220                                                 | 10:23   | 18:21     | 07:58    | LINE CLEAR AVAIED |
| 2836  | 22-Sep-24 | BENGALURU | 66      | LINE        | 220KV MAGADI 220 - ANCHEPALYA CKT 2                               | ANCHEPALYA 220                                             | 10:12   | 18:48     | 08:36    | LINE CLEAR AVAIED |
| 2837  | 22-Sep-24 | BENGALURU | 66      | LINE        | 66KV TAVAREKERE - KODIGEHALI                                      | TAVAREKERE                                                 | 19:31   | 19:33     | 00:02    | LINE CLEAR AVAIED |
| 2838  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - DABASPETE 220 (B3)                        | NO STATION AFFECTED                                        | 10:50   | 18:14     | 07:24    | LINE CLEAR AVAIED |
| 2839  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - MAGADI CKT 2                              | NO STATION AFFECTED                                        | 10:23   | 18:21     | 07:58    | LINE CLEAR AVAIED |
| 2840  | 22-Sep-24 | BENGALURU | 220     | LINE        | 220KV MAGADI 220 - ANCHEPALYA CKT 2                               | NO STATION AFFECTED                                        | 10:15   | 12:09     | 01:54    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                     | Station_Name            | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------------------------|-------------------------|---------|-----------|----------|--------------------|
| 2841  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4      | HENNUR ROAD, PURVANKARA | 18:38   | 18:54     | 00:16    | TRIPPED ON FAULT   |
| 2842  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                      | HENNUR CROSS            | 11:00   | 15:15     | 04:15    | LINE CLEAR AVAILED |
| 2843  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                      | HENNUR CROSS            | 12:20   | 15:15     | 02:55    | LINE CLEAR AVAILED |
| 2844  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV HBR LAYOUT 220 - SHOBHA CITY (TAP) - HENNUR (GEDDALAHALLI)_DG4      | HENNUR ROAD             | 13:25   | 15:15     | 01:50    | LINE CLEAR AVAILED |
| 2845  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV HENNUR (GEDDALAHALLI) - PURAVANKARA PALM BEACH                      | PURVANKARA PALM BEACH   | 13:21   | 13:24     | 00:03    | LINE CLEAR AVAILED |
| 2846  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV HENNUR (GEDDALAHALLI) - PURAVANKARA PALM BEACH                      | PURVANKARA PALM BEACH   | 15:15   | 15:18     | 00:03    | LINE CLEAR AVAILED |
| 2847  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                                                 | PALLADIUM               | 13:05   | 13:49     | 00:44    | LINE CLEAR AVAILED |
| 2848  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP) | K&C VALLEY              | 07:10   | 07:16     | 00:06    | LINE CLEAR AVAILED |
| 2849  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - K & C VALLEY (TAP) - GOLF LINK - AMARJYOTHI (TAP) | K&C VALLEY              | 08:29   | 10:51     | 02:22    | LINE CLEAR AVAILED |
| 2850  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                      | NO STATION AFFECTED     | 06:35   | 10:51     | 04:16    | TRIPPED ON FAULT   |
| 2851  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                      | GOLF LINK HAL-1         | 07:09   | 07:14     | 00:05    | LINE CLEAR AVAILED |
| 2852  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - AUDUGODI-1                                        | NO STATION AFFECTED     | 07:06   | 10:56     | 03:50    | LINE CLEAR AVAILED |
| 2853  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - ADUGODI-2                                         | NO STATION AFFECTED     | 07:06   | 10:56     | 03:50    | LINE CLEAR AVAILED |
| 2854  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KORAMANGALA 220 - GOLF LINK - AMARJYOTHI (TAP)                      | GOLF LINK HAL-1         | 08:29   | 10:50     | 02:21    | LINE CLEAR AVAILED |
| 2855  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KHODAYS 220 - FALCON CITY                                           | PRESTIGE FALCON CITY    | 10:05   | 14:10     | 04:05    | LINE CLEAR AVAILED |
| 2856  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                      | KONDASAPURA             | 06:13   | 06:18     | 00:05    | LINE CLEAR AVAILED |
| 2857  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                      | KONDASAPURA             | 06:13   | 06:18     | 00:05    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                   | Station_Name                                   | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|----------------------------------------|------------------------------------------------|---------|-----------|----------|--------------------|
| 2858  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIAL BEGUR 220 - VIDYANAGAR       | VIDYANAGAR                                     | 12:00   | 12:05     | 00:05    | LINE CLEAR AVAILED |
| 2859  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA          | CHEEMANGALA, TALAGAWARA                        | 11:00   | 11:12     | 00:12    | LINE CLEAR AVAILED |
| 2860  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA             | CHEEMANGALA, TALAGAWARA                        | 18:37   | 18:45     | 00:08    | LINE CLEAR AVAILED |
| 2861  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHINTAMANI 220 - K RAGHUTTAHALLI  | K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE | 09:56   | 10:02     | 00:06    | TRIPPED ON FAULT   |
| 2862  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                    | DIBBURAHALLI                                   | 17:20   | 17:35     | 00:15    | LINE CLEAR AVAILED |
| 2863  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB DB PURA - HIMAT SINGH (EHT) | NO STATION AFFECTED                            | 10:24   | 14:44     | 04:20    | LINE CLEAR AVAILED |
| 2864  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - D PALYA        | D PALYA, GUDIBANDE, MANDIKAL                   | 23:20   | 23:59     | 00:39    | TRIPPED ON FAULT   |
| 2865  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV BAGEPALLI - GULUR                 | GULUR(ZERO LOAD)                               | 06:45   | 06:55     | 00:10    | TRIPPED ON FAULT   |
| 2866  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                    | MANCHENAHALLI                                  | 00:20   | 00:30     | 00:10    | TRIPPED ON FAULT   |
| 2867  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                    | ADDAGAL                                        | 14:20   | 14:45     | 00:25    | LINE CLEAR AVAILED |
| 2868  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TAMAKA - DRDO         | DRDO                                           | 18:19   | 18:41     | 00:22    | TRIPPED ON FAULT   |
| 2869  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)      | KC VALLEY(EHT)                                 | 12:54   | 23:59     | 11:05    | TRIPPED ON FAULT   |
| 2870  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                    | KYASAMBALLI                                    | 14:10   | 14:20     | 00:10    | LINE CLEAR AVAILED |
| 2871  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                    | KYASAMBALLI                                    | 16:35   | 16:50     | 00:15    | LINE CLEAR AVAILED |
| 2872  | 23-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                 | NO STATION AFFECTED                            | 08:20   | 08:40     | 00:20    | TRIPPED ON FAULT   |
| 2873  | 23-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                 | NO STATION AFFECTED                            | 10:06   | 16:22     | 06:16    | LINE CLEAR AVAILED |
| 2874  | 23-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                 | NO STATION AFFECTED                            | 10:45   | 16:45     | 06:00    | LINE CLEAR AVAILED |
| 2875  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                    | ANEKAL                                         | 12:45   | 12:51     | 00:06    | TRIPPED ON FAULT   |
| 2876  | 23-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE          | ATTIBELE                                       | 09:52   | 09:57     | 00:05    | LINE CLEAR AVAILED |
| 2877  | 23-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                    | SARJAPURA 220                                  | 09:53   | 10:03     | 00:10    | LINE CLEAR AVAILED |
| 2878  | 23-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                    | SARJAPURA 220                                  | 10:26   | 16:44     | 06:18    | LINE CLEAR AVAILED |
| 2879  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                    | BYATARAYANAPURA                                | 10:59   | 12:09     | 01:10    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                    | Station_Name                 | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------|------------------------------|---------|-----------|----------|--------------------|
| 2880  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | BYATARAYANAPURA              | 12:15   | 12:20     | 00:05    | LINE CLEAR AVAILED |
| 2881  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                     | BYATARAYANAPURA              | 14:02   | 14:07     | 00:05    | LINE CLEAR AVAILED |
| 2882  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - GOKULA 1                          | NO STATION AFFECTED          | 00:58   | 03:51     | 02:53    | LINE CLEAR AVAILED |
| 2883  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV SHOBHA DREAMS 220 - SORAHUNASE                     | SORAHUNASE                   | 16:37   | 17:00     | 00:23    | LINE CLEAR AVAILED |
| 2884  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV SHOBHA DREAMS 220 - SORAHUNASE                     | SORAHUNASE                   | 13:20   | 14:10     | 00:50    | LINE CLEAR AVAILED |
| 2885  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV KAGGALIPURA (BRIGADE MEADOWS) - SHOBHA FOREST VIEW | SHOBHA FOREST                | 23:23   | 23:59     | 00:36    | TRIPPED ON FAULT   |
| 2886  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | PADMANABHANAGARA             | 10:40   | 11:30     | 00:50    | LINE CLEAR AVAILED |
| 2887  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | PADMANABHANAGARA             | 16:48   | 16:50     | 00:02    | LINE CLEAR AVAILED |
| 2888  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | RR NAGAR                     | 13:08   | 13:10     | 00:02    | LINE CLEAR AVAILED |
| 2889  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA                           | CHEEMANGALA, TALAGAWARA      | 11:02   | 11:07     | 00:05    | LINE CLEAR AVAILED |
| 2890  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                              | CHEEMANGALA, TALAGAWARA      | 18:47   | 18:51     | 00:04    | LINE CLEAR AVAILED |
| 2891  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | K RAGHUTTAHALLI              | 17:10   | 17:25     | 00:15    | LINE CLEAR AVAILED |
| 2892  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - D PALYA                         | D PALYA, GUDIBANDE, MANDIKAL | 23:59   | 00:20     | 23:39    | TRIPPED ON FAULT   |
| 2893  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV MANDIKAL - PERESANDRA                              | GUDIBANDE, MANDIKAL          | 07:42   | 07:58     | 00:16    | LINE CLEAR AVAILED |
| 2894  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TAMAKA                                 | TAMAKA                       | 18:51   | 19:14     | 00:23    | TRIPPED ON FAULT   |
| 2895  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                       | KC VALLEY(EHT)               | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT   |
| 2896  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | SUGUTUR                      | 18:35   | 18:40     | 00:05    | LINE CLEAR AVAILED |
| 2897  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - MALUR I/A - JADIGENAHALLI (HOSKOTE -1) | NO STATION AFFECTED          | 12:50   | 13:27     | 00:37    | LINE CLEAR AVAILED |
| 2898  | 24-Sep-24 | BENGALURU | 66      | LINE        | 66KV SK STEEL - KOLALA                                  | KOLALA                       | 13:40   | 16:06     | 02:26    | LINE CLEAR AVAILED |
| 2899  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | HEJJALA                      | 03:00   | 04:05     | 01:05    | TRIPPED ON FAULT   |
| 2900  | 24-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                                  | NO STATION AFFECTED          | 08:43   | 09:15     | 00:32    | TRIPPED ON FAULT   |
| 2901  | 24-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                                  | NO STATION AFFECTED          | 06:22   | 08:43     | 02:21    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                   | Station_Name                      | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|--------------------------------------------------------|-----------------------------------|---------|-----------|----------|--------------------|
| 2902  | 24-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | ANEKAL                            | 12:36   | 12:41     | 00:05    | TRIPPED ON FAULT   |
| 2903  | 24-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                    | SARJAPURA 220                     | 10:24   | 17:36     | 07:12    | LINE CLEAR AVAILED |
| 2904  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | BYATARAYANAPURA                   | 03:05   | 03:24     | 00:19    | TRIPPED ON FAULT   |
| 2905  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV HENNUR (GEDDALAHALLI) -<br>PURAVANKARA PALM BEACH | PURAVANKARA PALM BEACH            | 15:50   | 16:35     | 00:45    | LINE CLEAR AVAILED |
| 2906  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | PURAVANKARA PALM BEACH            | 11:25   | 11:35     | 00:10    | LINE CLEAR AVAILED |
| 2907  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | PURAVANKARA PALM BEACH            | 12:55   | 13:05     | 00:10    | LINE CLEAR AVAILED |
| 2908  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 -<br>CHANDRA LAYOUT             | CHANDRA LAYOUT                    | 10:07   | 14:43     | 04:36    | LINE CLEAR AVAILED |
| 2909  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                    | CHANDRA LAYOUT                    | 10:07   | 16:10     | 06:03    | LINE CLEAR AVAILED |
| 2910  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | CHANDRA LAYOUT                    | 10:07   | 16:10     | 06:03    | LINE CLEAR AVAILED |
| 2911  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | EMBASSY TECH PARK                 | 12:35   | 12:40     | 00:05    | LINE CLEAR AVAILED |
| 2912  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                    | EMBASSY TECH PARK                 | 13:37   | 13:42     | 00:05    | LINE CLEAR AVAILED |
| 2913  | 25-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                    | ITI 220                           | 11:05   | 11:55     | 00:50    | LINE CLEAR AVAILED |
| 2914  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 -<br>ISKCON                       | ISKCON                            | 10:30   | 13:49     | 03:19    | LINE CLEAR AVAILED |
| 2915  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | SOMANAHALLI 220                   | 15:05   | 15:07     | 00:02    | LINE CLEAR AVAILED |
| 2916  | 25-Sep-24 | BENGALURU | 400     | TRANSFORMER | HV1                                                    | MYLASANDRA 400                    | 10:02   | 16:40     | 06:38    | LINE CLEAR AVAILED |
| 2917  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                    | JADIGENAHALLI                     | 14:28   | 14:35     | 00:07    | TRIPPED ON FAULT   |
| 2918  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA -<br>CHEEMANGALA                       | CHEEMANGALA, TALAGAWARA           | 11:01   | 11:09     | 00:08    | LINE CLEAR AVAILED |
| 2919  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                             | CHEEMANGALA, TALAGAWARA           | 18:45   | 18:51     | 00:06    | LINE CLEAR AVAILED |
| 2920  | 25-Sep-24 | BENGALURU | 400     | LINE        | DEVANAHALLI HARDWARE PARK<br>400 - PAVAGADA 2          | NO STATION AFFECTED               | 14:57   | 23:59     | 09:02    | TRIPPED ON FAULT   |
| 2921  | 25-Sep-24 | BENGALURU | 400     | LINE        | DEVANAHALLI HARDWARE PARK<br>400 - PAVAGADA 2          | NO STATION AFFECTED               | 14:57   | 23:59     | 09:02    | LINE CLEAR AVAILED |
| 2922  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>VIJAYAPURA                   | VIJAYAPURA, JANGAMAKOTE,<br>MELUR | 05:55   | 06:07     | 00:12    | TRIPPED ON FAULT   |
| 2923  | 25-Sep-24 | BENGALURU | 220     | LINE        | 220KV NRS DB PURA 220 - KIADB<br>DB PURA 220           | NO STATION AFFECTED               | 10:47   | 13:16     | 02:29    | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                 | Station_Name        | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|--------------------------------------|---------------------|---------|-----------|----------|--------------------|
| 2924  | 25-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - MITTEMARI 1 | MITTEMARI 220       | 14:05   | 15:01     | 00:56    | LINE CLEAR AVAILED |
| 2925  | 25-Sep-24 | BENGALURU | 220     | LINE        | 220KV GOWRIBIDANUR 220 - MITTEMARI 2 | MITTEMARI 220       | 15:15   | 15:50     | 00:35    | LINE CLEAR AVAILED |
| 2926  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                  | SOMENAHALLI         | 16:20   | 16:25     | 00:05    | LINE CLEAR AVAILED |
| 2927  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | SOMENAHALLI         | 18:15   | 18:30     | 00:15    | LINE CLEAR AVAILED |
| 2928  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIDHURASHWATHA - GUNDLU KOTHUR  | GUNDLU KOTTUR       | 21:45   | 21:50     | 00:05    | TRIPPED ON FAULT   |
| 2929  | 25-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)    | KC VALLEY(EHT)      | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT   |
| 2930  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                  | SUGUTUR             | 09:52   | 09:55     | 00:03    | LINE CLEAR AVAILED |
| 2931  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | LAKKUR              | 02:15   | 02:25     | 00:10    | TRIPPED ON FAULT   |
| 2932  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | LAKKUR              | 06:15   | 07:15     | 01:00    | LINE CLEAR AVAILED |
| 2933  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | ALLIMARADANAHALLI   | 17:20   | 17:50     | 00:30    | LINE CLEAR AVAILED |
| 2934  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | CHIKKENAHALLI       | 17:30   | 17:43     | 00:13    | LINE CLEAR AVAILED |
| 2935  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                  | CHIKKENAHALLI       | 18:02   | 18:17     | 00:15    | LINE CLEAR AVAILED |
| 2936  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | TG HALLI            | 03:20   | 03:35     | 00:15    | TRIPPED ON FAULT   |
| 2937  | 25-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - BIDADI 220 -1  | NO STATION AFFECTED | 05:57   | 07:02     | 01:05    | TRIPPED ON FAULT   |
| 2938  | 25-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - BIDADI 220 -2  | NO STATION AFFECTED | 05:57   | 11:39     | 05:42    | TRIPPED ON FAULT   |
| 2939  | 25-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                  | BIDADI 220          | 05:57   | 07:10     | 01:13    | TRIPPED ON FAULT   |
| 2940  | 25-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | TK HALLI 220        | 11:08   | 12:48     | 01:40    | LINE CLEAR AVAILED |
| 2941  | 25-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                  | SARJAPURA 220       | 07:47   | 18:45     | 10:58    | LINE CLEAR AVAILED |
| 2942  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV HBR LAYOUT 220 - LR BANDE       | LR BANDE            | 11:18   | 13:40     | 02:22    | LINE CLEAR AVAILED |
| 2943  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - RAJANKUNTE   | RAJANUKUNTE         | 10:06   | 16:37     | 06:31    | LINE CLEAR AVAILED |
| 2944  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                  | YELAHANKA 220       | 10:13   | 11:19     | 01:06    | LINE CLEAR AVAILED |
| 2945  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                  | YELAHANKA 220       | 11:25   | 12:43     | 01:18    | LINE CLEAR AVAILED |
| 2946  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                  | YELAHANKA 220       | 12:52   | 14:22     | 01:30    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                          | Station_Name            | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-----------------------------------------------|-------------------------|---------|-----------|----------|---------------------|
| 2947  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | YELAHANKA 220           | 12:45   | 15:31     | 02:46    | LINE CLEAR AVAILED  |
| 2948  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                           | YELAHANKA 220           | 15:33   | 17:15     | 01:42    | LINE CLEAR AVAILED  |
| 2949  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | LR BANDE                | 11:15   | 13:40     | 02:25    | LINE CLEAR AVAILED  |
| 2950  | 26-Sep-24 | BENGALURU | 220     | LINE        | 220KV NRS 220 -<br>VRUSHABHAVATI 220          | NO STATION AFFECTED     | 13:21   | 14:16     | 00:55    | LINE CLEAR AVAILED  |
| 2951  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 -<br>BRINDAVAN HTLS       | NO STATION AFFECTED     | 17:34   | 18:05     | 00:31    | LINE CLEAR AVAILED  |
| 2952  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | BRIGADE UTOPIA          | 11:05   | 11:55     | 00:50    | LINE CLEAR AVAILED  |
| 2953  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | BRIGADE UTOPIA          | 12:05   | 12:55     | 00:50    | LINE CLEAR AVAILED  |
| 2954  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                           | HOODY 220               | 15:28   | 15:54     | 00:26    | TRIPPED ON FAULT    |
| 2955  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                           | HOODY 220               | 15:28   | 16:09     | 00:41    | TRIPPED ON FAULT    |
| 2956  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - PRESTIGE<br>SHANTHINIKETHAN  | PRESTIGE SHANTINIKETHAN | 15:28   | 16:12     | 00:44    | MAIN SUPPLY FAILURE |
| 2957  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - BHORUKA -<br>GRAPHITE INDIA  | GRAPHITE INDIA          | 15:28   | 16:12     | 00:44    | MAIN SUPPLY FAILURE |
| 2958  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HP EHT                       | HP(EHT)                 | 15:28   | 16:12     | 00:44    | MAIN SUPPLY FAILURE |
| 2959  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HOSKOTE 66                   | HOSKOTE 66              | 15:28   | 16:05     | 00:37    | MAIN SUPPLY FAILURE |
| 2960  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | HOODY 220               | 15:28   | 16:12     | 00:44    | MAIN SUPPLY FAILURE |
| 2961  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                           | PRESTIGE SHANTINIKETHAN | 12:38   | 12:55     | 00:17    | TRIPPED ON FAULT    |
| 2962  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV NIMHANS 220 -<br>JAYANAGAR GIS           | JAYANAGARA              | 13:59   | 14:06     | 00:07    | TRIPPED ON FAULT    |
| 2963  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                           | BANASHANKARI            | 16:14   | 16:17     | 00:03    | LINE CLEAR AVAILED  |
| 2964  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                           | BANASHANKARI            | 11:59   | 12:05     | 00:06    | LINE CLEAR AVAILED  |
| 2965  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                           | KUMBALAGODU 220         | 10:40   | 16:59     | 06:19    | LINE CLEAR AVAILED  |
| 2966  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA -<br>CHEEMANGALA              | CHEEMANGALA, TALAGAWARA | 11:01   | 11:06     | 00:05    | LINE CLEAR AVAILED  |
| 2967  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                    | CHEEMANGALA, TALAGAWARA | 18:27   | 18:32     | 00:05    | LINE CLEAR AVAILED  |
| 2968  | 26-Sep-24 | BENGALURU | 400     | LINE        | DEVANAHALLI HARDWARE PARK<br>400 - PAVAGADA 2 | NO STATION AFFECTED     | 00:14   | 06:13     | 05:59    | LINE CLEAR AVAILED  |
| 2969  | 26-Sep-24 | BENGALURU | 400     | LINE        | DEVANAHALLI HARDWARE PARK<br>400 - PAVAGADA 2 | NO STATION AFFECTED     | 07:00   | 12:10     | 05:10    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                              | Station_Name                                | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------------------------|---------------------------------------------|---------|-----------|----------|-------------------|
| 2970  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                               | RAMADEVARAGUDI                              | 08:53   | 11:53     | 03:00    | TRIPPED ON FAULT  |
| 2971  | 26-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - DB PURA 1                                 | NO STATION AFFECTED                         | 10:42   | 15:03     | 04:21    | LINE CLEAR AVAIED |
| 2972  | 26-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - DB PURA 2                                 | NO STATION AFFECTED                         | 15:10   | 19:18     | 04:08    | LINE CLEAR AVAIED |
| 2973  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - APPAREL PARK - D CROSS 3                   | DODDABELAVANGALA, GUNDAMGERE, SASLU         | 10:08   | 10:16     | 00:08    | LINE CLEAR AVAIED |
| 2974  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                                 | KC VALLEY(EHT)                              | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT  |
| 2975  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | TAMAKA                                      | 10:15   | 10:50     | 00:35    | LINE CLEAR AVAIED |
| 2976  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                               | LAKKUR                                      | 07:10   | 07:40     | 00:30    | TRIPPED ON FAULT  |
| 2977  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV DABASPETE 220 - THYAMAGONDLU - T BEGUR - NELAMANGALA (CKT-2) | THYAMAGONDLU                                | 13:25   | 14:30     | 01:05    | LINE CLEAR AVAIED |
| 2978  | 26-Sep-24 | BENGALURU | 220     | LINE        | 220KV KOTHIPURA 220 - CHANNAPATNA 220                             | NO STATION AFFECTED                         | 12:20   | 14:49     | 02:29    | LINE CLEAR AVAIED |
| 2979  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | RAMANAGARA                                  | 09:13   | 09:38     | 00:25    | TRIPPED ON FAULT  |
| 2980  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | RAMANAGARA                                  | 16:17   | 16:19     | 00:02    | TRIPPED ON FAULT  |
| 2981  | 26-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHANNAPATNA 220 - KOTHIPURA 2 - BEVOOR                       | BEVOOR, VANDARAGUPPE, SANKALGERE, DASHAVARA | 06:28   | 06:33     | 00:05    | TRIPPED ON FAULT  |
| 2982  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                               | CHANNAPATNA 220                             | 10:00   | 14:56     | 04:56    | LINE CLEAR AVAIED |
| 2983  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                               | CHANNAPATNA 220                             | 10:00   | 14:56     | 04:56    | LINE CLEAR AVAIED |
| 2984  | 26-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                                            | NO STATION AFFECTED                         | 09:01   | 16:13     | 07:12    | LINE CLEAR AVAIED |
| 2985  | 26-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                                            | NO STATION AFFECTED                         | 09:12   | 16:09     | 06:57    | LINE CLEAR AVAIED |
| 2986  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | ANEKAL                                      | 12:41   | 12:46     | 00:05    | TRIPPED ON FAULT  |
| 2987  | 26-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                               | CHANDAPURA                                  | 02:28   | 02:46     | 00:18    | TRIPPED ON FAULT  |
| 2988  | 26-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                               | SARJAPURA 220                               | 09:00   | 18:55     | 09:55    | LINE CLEAR AVAIED |
| 2989  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV ABBIGERE - ATTURU - MANYATA DG-3                             | ABBIGERE, WELCAST                           | 11:41   | 11:52     | 00:11    | LINE CLEAR AVAIED |
| 2990  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV PUTTENAHALLI 220 - RAILWHEEL AND AXLE SECORTES - ATTURU DG3  | ABBIGERE, WELCAST, WHEEL & AXIL, ESCORTS    | 11:41   | 11:50     | 00:09    | TRIPPED ON FAULT  |
| 2991  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                                               | A STATION 66                                | 18:35   | 18:52     | 00:17    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                              | Station_Name                                                            | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 2992  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV WELCAST STEEL - ABBIGERE                                                                     | ABBIGERE                                                                | 14:50   | 14:54     | 00:04    | LINE CLEAR AVAIED   |
| 2993  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - SOLADEVANAHALLI TAP TO BIEC AND ALUR DG - II                                | BIEC, ALUR                                                              | 21:02   | 21:14     | 00:12    | LINE CLEAR AVAIED   |
| 2994  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - WELCAST STEEL DG-3                                                          | WELCAST                                                                 | 18:33   | 18:37     | 00:04    | LINE CLEAR AVAIED   |
| 2995  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                               | BRIGADE TECH GARDEN                                                     | 11:47   | 11:55     | 00:08    | LINE CLEAR AVAIED   |
| 2996  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - PRESTIGE SHANTHINIKETHAN                                                         | PRESTIGE SHANTINIKETHAN                                                 | 19:00   | 19:40     | 00:40    | MAIN SUPPLY FAILURE |
| 2997  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KHODAYS 220 - ELITA PROMENADE                                                                | ELITA PROMENENDE                                                        | 10:45   | 13:20     | 02:35    | LINE CLEAR AVAIED   |
| 2998  | 27-Sep-24 | BENGALURU | 220     | TRANSFORMER | LV2                                                                                               | HOODY 220                                                               | 19:00   | 19:14     | 00:14    | TRIPPED ON FAULT    |
| 2999  | 27-Sep-24 | BENGALURU | 220     | TRANSFORMER | LV3                                                                                               | HOODY 220                                                               | 19:00   | 19:14     | 00:14    | TRIPPED ON FAULT    |
| 3000  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HOSKOTE 66                                                                       | HOSKOTE 66                                                              | 19:00   | 19:30     | 00:30    | MAIN SUPPLY FAILURE |
| 3001  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220_DG4 | HOSKOTE 66                                                              | 21:20   | 21:25     | 00:05    | LINE CLEAR AVAIED   |
| 3002  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA                                                                     | CHEEMANGALA, TALAGAWARA                                                 | 11:04   | 11:12     | 00:08    | LINE CLEAR AVAIED   |
| 3003  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                                                        | CHEEMANGALA, TALAGAWARA                                                 | 18:31   | 18:37     | 00:06    | LINE CLEAR AVAIED   |
| 3004  | 27-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 1                                                     | NO STATION AFFECTED                                                     | 12:00   | 13:06     | 01:06    | LINE CLEAR AVAIED   |
| 3005  | 27-Sep-24 | BENGALURU | 220     | LINE        | 220KV DEVANAHALLI 400 GIS - NRS DB PURA 220 2                                                     | NO STATION AFFECTED                                                     | 13:00   | 14:09     | 01:09    | LINE CLEAR AVAIED   |
| 3006  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRINIVASAPURA 220 - YELDUR - DALASANUR                                                       | DALASANUR, YELDUR, MALLASANDRA                                          | 06:52   | 07:13     | 00:21    | TRIPPED ON FAULT    |
| 3007  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - TAMAKA                                                                           | TAMAKA                                                                  | 11:22   | 11:25     | 00:03    | LINE CLEAR AVAIED   |
| 3008  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - AVANI                                                                            | NO STATION AFFECTED                                                     | 11:31   | 12:50     | 01:19    | LINE CLEAR AVAIED   |
| 3009  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - NARASAPURA 1                                                                     | NO STATION AFFECTED                                                     | 13:05   | 13:15     | 00:10    | LINE CLEAR AVAIED   |
| 3010  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - VOKKALERI                                                                        | VOKKALERI, KC VALLEY PUMP HOUSE                                         | 15:05   | 16:22     | 01:17    | LINE CLEAR AVAIED   |
| 3011  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRINIVASAPURA 220 - LAKSHMIPURA 3                                                            | LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLI, SOMAYAJANAHALLI, SOLAR IPP | 06:30   | 06:45     | 00:15    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                          | Station_Name                         | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------|--------------------------------------|---------|-----------|----------|--------------------|
| 3012  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | MALLASANDRA                          | 10:45   | 11:45     | 01:00    | LINE CLEAR AVAILED |
| 3013  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                             | KC VALLEY(EHT)                       | 23:58   | 23:59     | 00:01    | TRIPPED ON FAULT   |
| 3014  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | RAYALPADU                            | 11:50   | 14:00     | 02:10    | LINE CLEAR AVAILED |
| 3015  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | RAYALPADU                            | 14:05   | 16:00     | 01:55    | LINE CLEAR AVAILED |
| 3016  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | VOKKALERI                            | 16:22   | 17:30     | 01:08    | LINE CLEAR AVAILED |
| 3017  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | VOKKALERI                            | 17:35   | 17:55     | 00:20    | LINE CLEAR AVAILED |
| 3018  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | YELDUR                               | 07:13   | 07:30     | 00:17    | TRIPPED ON FAULT   |
| 3019  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV TEKAL - BUDIKOTE                                         | BUDIKOTE                             | 10:00   | 12:25     | 02:25    | LINE CLEAR AVAILED |
| 3020  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | MAASTHI                              | 11:25   | 12:05     | 00:40    | LINE CLEAR AVAILED |
| 3021  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | MAASTHI                              | 12:05   | 12:38     | 00:33    | LINE CLEAR AVAILED |
| 3022  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                           | TEKAL                                | 14:20   | 14:55     | 00:35    | LINE CLEAR AVAILED |
| 3023  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | TEKAL                                | 13:32   | 14:00     | 00:28    | LINE CLEAR AVAILED |
| 3024  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - CHATHRA - MANIYAMBAL - HANUMANTHANAGARA | CHATRA, MARALWADI, GODUR, MANIYAMBAL | 13:52   | 14:00     | 00:08    | LINE CLEAR AVAILED |
| 3025  | 27-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                                        | NO STATION AFFECTED                  | 09:08   | 23:59     | 14:51    | LINE CLEAR AVAILED |
| 3026  | 27-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                                        | NO STATION AFFECTED                  | 09:58   | 11:08     | 01:10    | LINE CLEAR AVAILED |
| 3027  | 27-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                                        | NO STATION AFFECTED                  | 15:57   | 22:01     | 06:04    | LINE CLEAR AVAILED |
| 3028  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | ATTIBELE                             | 08:25   | 09:25     | 01:00    | LINE CLEAR AVAILED |
| 3029  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | ATTIBELE                             | 09:25   | 09:30     | 00:05    | LINE CLEAR AVAILED |
| 3030  | 27-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                           | ATTIBELE                             | 17:10   | 17:23     | 00:13    | LINE CLEAR AVAILED |
| 3031  | 27-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                           | SARJAPURA 220                        | 09:30   | 16:28     | 06:58    | LINE CLEAR AVAILED |
| 3032  | 27-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                           | SARJAPURA 220                        | 17:12   | 17:20     | 00:08    | LINE CLEAR AVAILED |
| 3033  | 27-Sep-24 | BENGALURU | 66      | LINE        | 66KV BIDADI 220 - SOMANAHALLI - HEJJALA 1                     | NO STATION AFFECTED                  | 18:30   | 23:59     | 05:29    | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                    | Station_Name                                   | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------|------------------------------------------------|---------|-----------|----------|---------------------|
| 3034  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | IISc                                           | 13:42   | 13:51     | 00:09    | LINE CLEAR AVAILED  |
| 3035  | 28-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                                     | HSR LAYOUT 220                                 | 11:13   | 12:44     | 01:31    | LINE CLEAR AVAILED  |
| 3036  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - JAKKASANDRA                              | JAKKASANDRA                                    | 11:03   | 11:11     | 00:08    | LINE CLEAR AVAILED  |
| 3037  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV HSR 220 - JAKKASANDRA                              | JAKKASANDRA                                    | 12:50   | 12:56     | 00:06    | LINE CLEAR AVAILED  |
| 3038  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - ISKCON                           | ISKCON                                         | 22:09   | 22:56     | 00:47    | TRIPPED ON FAULT    |
| 3039  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV KHODAYS 220 - ELITA PROMENADE                      | ELITA PROMENENDE                               | 11:50   | 11:55     | 00:05    | LINE CLEAR AVAILED  |
| 3040  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - KUMBALAGODU 220                  | NO STATION AFFECTED                            | 10:18   | 12:11     | 01:53    | TRIPPED ON FAULT    |
| 3041  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - HOSKOTE 66                             | HOSKOTE 66                                     | 16:30   | 16:50     | 00:20    | MAIN SUPPLY FAILURE |
| 3042  | 28-Sep-24 | BENGALURU | 220     | TRANSFORMER | LV2                                                     | HOODY 220                                      | 16:29   | 16:40     | 00:11    | TRIPPED ON FAULT    |
| 3043  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV HOODY 220 - BHORUKA - GRAPHITE INDIA               | GRAPHITE INDIA                                 | 11:15   | 18:17     | 07:02    | LINE CLEAR AVAILED  |
| 3044  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                     | KONDASAPURA                                    | 17:44   | 17:54     | 00:10    | TRIPPED ON FAULT    |
| 3045  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | NANDAGUDI                                      | 23:29   | 23:37     | 00:08    | TRIPPED ON FAULT    |
| 3046  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA                           | CHEEMANGALA, TALAGAWARA                        | 11:00   | 11:07     | 00:07    | LINE CLEAR AVAILED  |
| 3047  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                              | CHEEMANGALA, TALAGAWARA                        | 17:55   | 18:00     | 00:05    | LINE CLEAR AVAILED  |
| 3048  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                     | NALLIMARADANAHALLI                             | 16:00   | 16:10     | 00:10    | TRIPPED ON FAULT    |
| 3049  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                       | KC VALLEY(EHT)                                 | 23:59   | 19:20     | 04:39    | TRIPPED ON FAULT    |
| 3050  | 28-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                                     | KANAKAPURA 220                                 | 01:36   | 01:55     | 00:19    | TRIPPED ON FAULT    |
| 3051  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV KANAKAPURA 220 - ALLIMARADANAHALLI - CHIKKENAHALLI | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI | 01:36   | 01:57     | 00:21    | TRIPPED ON FAULT    |
| 3052  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - RAMANAGARA                         | RAMANAGARA                                     | 10:03   | 16:01     | 05:58    | LINE CLEAR AVAILED  |
| 3053  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOTHIPURA 220 - RAMANAGARA                         | RAMANAGARA                                     | 10:03   | 16:08     | 06:05    | LINE CLEAR AVAILED  |
| 3054  | 28-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                                  | NO STATION AFFECTED                            | 23:59   | 08:44     | 15:15    | LINE CLEAR AVAILED  |
| 3055  | 28-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                                  | NO STATION AFFECTED                            | 15:31   | 16:04     | 00:33    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                            | Station_Name        | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-------------------------------------------------|---------------------|---------|-----------|----------|---------------------|
| 3056  | 28-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                          | NO STATION AFFECTED | 14:48   | 16:08     | 01:20    | LINE CLEAR AVAILED  |
| 3057  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTIBELE            | 00:50   | 01:25     | 00:35    | LINE CLEAR AVAILED  |
| 3058  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTIBELE            | 01:25   | 02:20     | 00:55    | LINE CLEAR AVAILED  |
| 3059  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTIBELE            | 07:20   | 08:10     | 00:50    | LINE CLEAR AVAILED  |
| 3060  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTIBELE            | 08:15   | 10:35     | 02:20    | LINE CLEAR AVAILED  |
| 3061  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTIBELE            | 10:50   | 11:10     | 00:20    | LINE CLEAR AVAILED  |
| 3062  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                             | KUMBARANAHALLI      | 17:15   | 17:21     | 00:06    | TRIPPED ON FAULT    |
| 3063  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                             | SARJAPURA 220       | 12:19   | 12:22     | 00:03    | LINE CLEAR AVAILED  |
| 3064  | 28-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | SARJAPURA 220       | 12:19   | 12:22     | 00:03    | LINE CLEAR AVAILED  |
| 3065  | 28-Sep-24 | BENGALURU | 220     | LINE        | 220KV YARANDANAHALLI 220 - HOSUR 220            | YARANDANAHALLI 220  | 23:08   | 23:52     | 00:44    | TRIPPED ON FAULT    |
| 3066  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - SURYA CITY            | SURYA CITY, ANEKAL  | 23:08   | 23:54     | 00:46    | MAIN SUPPLY FAILURE |
| 3067  | 28-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2              | ATTIBELE            | 23:08   | 23:54     | 00:46    | MAIN SUPPLY FAILURE |
| 3068  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ATTURU - PLATINUM CITY - SAHAKARNAGAR DG-4 | ATTUR YELAHANKA     | 11:02   | 11:10     | 00:08    | LINE CLEAR AVAILED  |
| 3069  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                             | ATTUR YELAHANKA     | 15:45   | 15:50     | 00:05    | LINE CLEAR AVAILED  |
| 3070  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | ATTUR YELAHANKA     | 15:45   | 15:50     | 00:05    | LINE CLEAR AVAILED  |
| 3071  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | BANASAWADI          | 17:52   | 18:21     | 00:29    | MAIN SUPPLY FAILURE |
| 3072  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV4                                             | A STATION 66        | 10:40   | 10:42     | 00:02    | LINE CLEAR AVAILED  |
| 3073  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV EDC 220 - KANTEERAVA                       | NO STATION AFFECTED | 10:10   | 16:30     | 06:20    | LINE CLEAR AVAILED  |
| 3074  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV A STATION 220 - KANTEERAVA                 | NO STATION AFFECTED | 10:10   | 16:30     | 06:20    | LINE CLEAR AVAILED  |
| 3075  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                        | PALLADIUM           | 02:35   | 11:50     | 09:15    | LINE CLEAR AVAILED  |
| 3076  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VRUSHBHAVATHI 220 - SIR MV LAYOUT          | SIR MV LAYOUT       | 20:28   | 21:33     | 01:05    | TRIPPED ON FAULT    |
| 3077  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                             | VRISHABHAVATHI 220  | 07:51   | 08:26     | 00:35    | TRIPPED ON FAULT    |
| 3078  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                             | BRINDAVANA 220      | 07:12   | 09:07     | 01:55    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                | Station_Name                                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------|--------------------------------------------------|---------|-----------|----------|---------------------|
| 3079  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                 | BRINDAVANA 220                                   | 11:02   | 12:52     | 01:50    | LINE CLEAR AVAILED  |
| 3080  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                                                 | BRINDAVANA 220                                   | 09:16   | 10:50     | 01:34    | LINE CLEAR AVAILED  |
| 3081  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                 | MATHIKERE                                        | 01:55   | 02:42     | 00:47    | LINE CLEAR AVAILED  |
| 3082  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - PLATINUM CITY DG-4                            | PLATINUM CITY                                    | 10:58   | 11:10     | 00:12    | LINE CLEAR AVAILED  |
| 3083  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SRS PEENYA 220 - GOKULA 1                                      | GOKULA                                           | 01:02   | 01:06     | 00:04    | LINE CLEAR AVAILED  |
| 3084  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV WIDIA - PRESTIGE JINDAL CITY                                   | NO STATION AFFECTED                              | 09:15   | 09:19     | 00:04    | LINE CLEAR AVAILED  |
| 3085  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                 | ARMY WELFARE ORGANISATION                        | 13:45   | 13:56     | 00:11    | TRIPPED ON FAULT    |
| 3086  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                 | CESSNA                                           | 11:44   | 12:25     | 00:41    | LINE CLEAR AVAILED  |
| 3087  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                 | CESSNA                                           | 12:31   | 12:45     | 00:14    | LINE CLEAR AVAILED  |
| 3088  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV CESSNA BUSINESS PARK 220 - EXORA 66                            | CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT) | 17:51   | 18:14     | 00:23    | MAIN SUPPLY FAILURE |
| 3089  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 1                                | EMBASSY TECH PARK                                | 17:53   | 18:06     | 00:13    | MAIN SUPPLY FAILURE |
| 3090  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 2                                | EMBASSY TECH PARK                                | 17:53   | 18:06     | 00:13    | MAIN SUPPLY FAILURE |
| 3091  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 1                                | EMBASSY TECH PARK                                | 19:08   | 19:23     | 00:15    | LINE CLEAR AVAILED  |
| 3092  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 2                                | EMBASSY TECH PARK                                | 19:08   | 19:23     | 00:15    | LINE CLEAR AVAILED  |
| 3093  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV HAL 220 - AMARJYOTHI 1 - LEELAVENTURE (TAP)                    | LEELA VENTURE                                    | 00:28   | 01:10     | 00:42    | TRIPPED ON FAULT    |
| 3094  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                 | HOODY 220                                        | 07:38   | 09:20     | 01:42    | TRIPPED ON FAULT    |
| 3095  | 29-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 400 - SHOBHA DREAMS 220                                 | NO STATION AFFECTED                              | 11:02   | 13:41     | 02:39    | TRIPPED ON FAULT    |
| 3096  | 29-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 220 - ITI 220                                           | ITI 220                                          | 17:50   | 17:58     | 00:08    | MAIN SUPPLY FAILURE |
| 3097  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - NGEF                                                 | NGEF                                             | 17:50   | 17:58     | 00:08    | MAIN SUPPLY FAILURE |
| 3098  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - DRDO (EHT)                                           | DRDO(EHT)                                        | 17:50   | 17:58     | 00:08    | MAIN SUPPLY FAILURE |
| 3099  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NGEF - BAIYAPPANAHALLI BMRCL EHT                               | BMRCL                                            | 01:42   | 02:03     | 00:21    | LINE CLEAR AVAILED  |
| 3100  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ ECO WORLD ADARSHA PALM VILLA RETREAT | RMZ                                              | 17:50   | 18:07     | 00:17    | MAIN SUPPLY FAILURE |



| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                      | Station_Name                     | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------------------------------|----------------------------------|---------|-----------|----------|-------------------|
| 3101  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ<br>ECO WORLD ADARSHA PALM<br>VILLA RETREAT | RMZ                              | 19:11   | 19:25     | 00:14    | LINE CLEAR AVAIED |
| 3102  | 29-Sep-24 | BENGALURU | 66      | LINE        | 220KV SOMANAHALLI 220 -<br>MYLASANDRA 2                                   | NO STATION AFFECTED              | 13:46   | 14:34     | 00:48    | TRIPPED ON FAULT  |
| 3103  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 -<br>PADMANABHA NAGAR -<br>AREHALLI               | AREHALLI                         | 11:11   | 11:18     | 00:07    | LINE CLEAR AVAIED |
| 3104  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV AREHALLI - BANASHANKARI                                              | AREHALLI                         | 15:14   | 15:20     | 00:06    | LINE CLEAR AVAIED |
| 3105  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 -<br>PADMANABHA NAGAR -<br>AREHALLI               | PADMANABHANAGARA                 | 11:09   | 11:13     | 00:04    | LINE CLEAR AVAIED |
| 3106  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SUBRAMANYAPURA 220 -<br>PADMANABHA NAGAR -<br>AREHALLI               | PADMANABHANAGARA                 | 14:32   | 14:35     | 00:03    | LINE CLEAR AVAIED |
| 3107  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 -<br>PILLAGUMPA                                      | PILLAGUMPA                       | 18:32   | 18:51     | 00:19    | TRIPPED ON FAULT  |
| 3108  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA -<br>CHEEMANGALA                                          | CHEEMANGALA, TALAGAWARA          | 11:02   | 11:08     | 00:06    | LINE CLEAR AVAIED |
| 3109  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                                                | CHEEMANGALA, TALAGAWARA          | 18:06   | 18:14     | 00:08    | LINE CLEAR AVAIED |
| 3110  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                       | CHEEMANGALA                      | 19:15   | 19:30     | 00:15    | TRIPPED ON FAULT  |
| 3111  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | G KODIHALLI                      | 07:43   | 07:51     | 00:08    | TRIPPED ON FAULT  |
| 3112  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV GANJIGUNTE - PALLICHERLU                                             | PALLICHERLU                      | 01:40   | 02:07     | 00:27    | TRIPPED ON FAULT  |
| 3113  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | APPAREL PARK                     | 02:10   | 02:15     | 00:05    | TRIPPED ON FAULT  |
| 3114  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                       | RAMADEVARAGUDI                   | 15:30   | 16:30     | 01:00    | LINE CLEAR AVAIED |
| 3115  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV CB PURA I/A - CB PURA<br>URBAN                                       | CHIKKABALLAPURA URBAN            | 02:58   | 03:45     | 00:47    | TRIPPED ON FAULT  |
| 3116  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NANDI (MUDDENAHALLI) -<br>CB PURA I/A                                | NO STATION AFFECTED              | 02:05   | 03:55     | 01:50    | TRIPPED ON FAULT  |
| 3117  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - NANDI<br>(MUDDENAHALLI)                            | NANDI                            | 02:05   | 02:31     | 00:26    | TRIPPED ON FAULT  |
| 3118  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>DEVANAHALLI 2                                   | NO STATION AFFECTED              | 01:43   | 02:14     | 00:31    | TRIPPED ON FAULT  |
| 3119  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 -<br>VIJAYAPURA                                      | VIJAYAPURA, JANGAMKOTE,<br>MELUR | 15:10   | 15:30     | 00:20    | TRIPPED ON FAULT  |
| 3120  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV CHELUR - CHAKAVELU                                                   | CHAKAVELU                        | 05:55   | 06:20     | 00:25    | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                      | Station_Name                     | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|-------------------------------------------|----------------------------------|---------|-----------|----------|---------------------|
| 3121  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV YENNIGADALE - SOMANATHAPURA - CHELUR | CHAKAVELU, CHELUR                | 06:20   | 06:40     | 00:20    | TRIPPED ON FAULT    |
| 3122  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                       | GOWRIBIDANUR 220                 | 12:45   | 12:55     | 00:10    | TRIPPED ON FAULT    |
| 3123  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                       | HOSUR RAMAPURA                   | 05:20   | 05:40     | 00:20    | TRIPPED ON FAULT    |
| 3124  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                       | PERESANDRA                       | 06:15   | 06:40     | 00:25    | TRIPPED ON FAULT    |
| 3125  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                       | SOMANATHPURA                     | 06:25   | 07:05     | 00:40    | TRIPPED ON FAULT    |
| 3126  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                       | TAMAKA                           | 05:40   | 05:55     | 00:15    | TRIPPED ON FAULT    |
| 3127  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYASAMBALLI - DODDAKARI              | DODDAKARI, KYASAMBALLI           | 06:25   | 06:50     | 00:25    | TRIPPED ON FAULT    |
| 3128  | 29-Sep-24 | BENGALURU | 220     | LINE        | 220KV HOODY 220 - MALUR 220               | VIKAS TECH PARK 220, EXORA 220   | 17:50   | 18:12     | 00:22    | TRIPPED ON FAULT    |
| 3129  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV AGALAKOTE - KEMPANAHALLI TMK         | KEMPANAHALLI                     | 09:50   | 09:55     | 00:05    | LINE CLEAR AVAIED   |
| 3130  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV MAGADI 220 - AGALAKOTE - MATHIKERE   | KEMPANAHALLI                     | 16:45   | 16:50     | 00:05    | LINE CLEAR AVAIED   |
| 3131  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SK STEEL - KOLALA                    | NO STATION AFFECTED              | 05:21   | 09:28     | 04:07    | TRIPPED ON FAULT    |
| 3132  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANCHEPALYA 220 - HULLENAHALLI        | HULLENAHALLI, KUDUR, SRIGIRIPURA | 09:40   | 16:50     | 07:10    | LINE CLEAR AVAIED   |
| 3133  | 29-Sep-24 | BENGALURU | 220     | LINE        | 220KV NELAMANGALA 400 - ANCHEPALYA CKT 1  | NO STATION AFFECTED              | 10:53   | 18:15     | 07:22    | LINE CLEAR AVAIED   |
| 3134  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                       | SANKALGERE                       | 06:42   | 06:47     | 00:05    | TRIPPED ON FAULT    |
| 3135  | 29-Sep-24 | BENGALURU | 220     | LINE        | TK HALLI 220 - VAJAMANGALA 220            | TK HALLI 220                     | 04:27   | 07:45     | 03:18    | TRIPPED ON FAULT    |
| 3136  | 29-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                       | TK HALLI 220                     | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3137  | 29-Sep-24 | BENGALURU | 220     | LINE        | TK HALLI 220 - VAJAMANGALA 220            | NO STATION AFFECTED              | 07:45   | 10:26     | 02:41    | LINE CLEAR AVAIED   |
| 3138  | 29-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                       | TK HALLI 220                     | 04:27   | 04:55     | 00:28    | MAIN SUPPLY FAILURE |
| 3139  | 29-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV3                                       | TK HALLI 220                     | 04:27   | 04:49     | 00:22    | MAIN SUPPLY FAILURE |
| 3140  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                       | TK HALLI 220                     | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3141  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                       | TK HALLI 220                     | 04:27   | 04:50     | 00:23    | MAIN SUPPLY FAILURE |
| 3142  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 1               | BWSSB(EHT)                       | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3143  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 2               | BWSSB(EHT)                       | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                         | Station_Name                                    | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|----------------------------------------------|-------------------------------------------------|---------|-----------|----------|---------------------|
| 3144  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 3                  | BWSSB(EHT)                                      | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3145  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - BWSSB 4                  | BWSSB(EHT)                                      | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3146  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - AKKURMOLE                | AKKURMOLE                                       | 04:27   | 04:50     | 00:23    | MAIN SUPPLY FAILURE |
| 3147  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - IGGALURU                 | YATHAMBADI, HONALGERE, IGGALURU                 | 04:15   | 05:03     | 00:48    | TRIPPED ON FAULT    |
| 3148  | 29-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - MANDYA 1                      | KM DODDI, KK DODDI, TALAGAVADI, KIADB, TUMBGERE | 04:27   | 04:50     | 00:23    | MAIN SUPPLY FAILURE |
| 3149  | 29-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - MANDYA 2                      | KM DODDI, KK DODDI, TALAGAVADI, KIADB, TUMBGERE | 04:27   | 04:50     | 00:23    | MAIN SUPPLY FAILURE |
| 3150  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - GURUVINAPURA - V R DODDI | BV HALLI, GURUVINAPURA                          | 04:27   | 04:50     | 00:23    | MAIN SUPPLY FAILURE |
| 3151  | 29-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - LIMBAVALI IPP                 | LIMBAVALI IPP                                   | 04:27   | 04:41     | 00:14    | MAIN SUPPLY FAILURE |
| 3152  | 29-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - SHIMSHA                       | NO STATION AFFECTED                             | 04:27   | 06:20     | 01:53    | TRIPPED ON FAULT    |
| 3153  | 29-Sep-24 | BENGALURU | 66      | LINE        | TK HALLI 220 - HEBBANI                       | NO STATION AFFECTED                             | 02:52   | 06:15     | 03:23    | TRIPPED ON FAULT    |
| 3154  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - ATTIBELE                       | ANEKAL                                          | 10:11   | 14:53     | 04:42    | LINE CLEAR AVAILED  |
| 3155  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV YARANDANAHALLI 220 - ANEKAL 2           | ANEKAL, ATTIBELE, SAMANDURU                     | 16:15   | 16:25     | 00:10    | LINE CLEAR AVAILED  |
| 3156  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - ATTIBELE                       | ATTIBELE                                        | 09:40   | 09:45     | 00:05    | LINE CLEAR AVAILED  |
| 3157  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - DOMMASANDRA             | DOMMASANDRA                                     | 08:40   | 23:59     | 15:19    | LINE CLEAR AVAILED  |
| 3158  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV KACHAMARANAHALLI - DOMMASANDRA          | DOMMASANDRA                                     | 09:02   | 18:24     | 09:22    | LINE CLEAR AVAILED  |
| 3159  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | JIGANI 66                                       | 16:15   | 16:45     | 00:30    | LINE CLEAR AVAILED  |
| 3160  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                          | JIGANI 66                                       | 22:20   | 22:55     | 00:35    | LINE CLEAR AVAILED  |
| 3161  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV3                                          | JIGANI 66                                       | 09:40   | 09:50     | 00:10    | LINE CLEAR AVAILED  |
| 3162  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - SAMANDURU                      | SAMANDURU                                       | 10:12   | 14:55     | 04:43    | LINE CLEAR AVAILED  |
| 3163  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV ANEKAL - SAMANDURU                      | SAMANDURU                                       | 16:15   | 16:23     | 00:08    | LINE CLEAR AVAILED  |
| 3164  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                   | SURYA CITY                                      | 10:14   | 14:35     | 04:21    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                                                                               | Station_Name                    | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|-----------|---------|-------------|----------------------------------------------------------------------------------------------------|---------------------------------|---------|-----------|----------|---------------------|
| 3165  | 29-Sep-24 | BENGALURU | 66      | LINE        | 66KV SURYA CITY - ANEKAL 1                                                                         | SURYA CITY                      | 16:16   | 16:21     | 00:05    | LINE CLEAR AVAIED   |
| 3166  | 29-Sep-24 | BENGALURU | 220     | LINE        | 220KV YARANDANAHALLI 220 - HOSUR 220                                                               | NO STATION AFFECTED             | 23:59   | 16:05     | 07:54    | TRIPPED ON FAULT    |
| 3167  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                | YARANDANAHALLI 220              | 03:30   | 03:40     | 00:10    | TRIPPED ON FAULT    |
| 3168  | 29-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                | YARANDANAHALLI 220              | 16:37   | 16:45     | 00:08    | TRIPPED ON FAULT    |
| 3169  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS 220 - PALLADIUM                                                                           | PALLADIUM                       | 01:23   | 02:00     | 00:37    | TRIPPED ON FAULT    |
| 3170  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                | REMCO                           | 09:17   | 09:19     | 00:02    | LINE CLEAR AVAIED   |
| 3171  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                | HOODY 220                       | 08:44   | 09:10     | 00:26    | TRIPPED ON FAULT    |
| 3172  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV ITI 220 - DRDO (EHT)                                                                          | DRDO(EHT)                       | 10:46   | 11:28     | 00:42    | TRIPPED ON FAULT    |
| 3173  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ<br>ECO WORLD ADARSHA PALM<br>VILLA RETREAT                          | RMZ                             | 02:42   | 02:55     | 00:13    | LINE CLEAR AVAIED   |
| 3174  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - RMZ<br>ECO WORLD ADARSHA PALM<br>VILLA RETREAT                          | RMZ                             | 17:07   | 18:00     | 00:53    | TRIPPED ON FAULT    |
| 3175  | 30-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                                                                                | VIKAS TECH PARK 220             | 17:10   | 17:40     | 00:30    | TRIPPED ON FAULT    |
| 3176  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 1                                                               | EMBASSY TECH PARK               | 17:10   | 17:40     | 00:30    | MAIN SUPPLY FAILURE |
| 3177  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - EMBASSY 2                                                               | EMBASSY TECH PARK               | 17:10   | 17:40     | 00:30    | MAIN SUPPLY FAILURE |
| 3178  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 1                                                  | CESSNA                          | 17:10   | 17:40     | 00:30    | MAIN SUPPLY FAILURE |
| 3179  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIKAS TECH PARK 220 - CESSNA BUSINESS PARK 2                                                  | CESSNA                          | 17:10   | 17:40     | 00:30    | MAIN SUPPLY FAILURE |
| 3180  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                                                                                | VIKAS TECH PARK 220             | 17:10   | 17:40     | 00:30    | MAIN SUPPLY FAILURE |
| 3181  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV SOMANAHALLI 220 - KUMBALAGODU 220                                                             | NO STATION AFFECTED             | 11:24   | 14:44     | 03:20    | LINE CLEAR AVAIED   |
| 3182  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV EKARAJAPURA 220 - BELL CERAMIC (EHT) - KONDASPURA (SAFAL)                                     | KONDASAPURA, BELL CERAMICS(EHT) | 21:43   | 22:16     | 00:33    | TRIPPED ON FAULT    |
| 3183  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV KIADB HARDWARE PARK 220 - VIDYANAGAR - 12 POLE - GRINDWILL - HOSKOTE 66 - EKARAJPURA 220 _DG4 | VIDYANAGARA                     | 08:55   | 09:00     | 00:05    | LINE CLEAR AVAIED   |
| 3184  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                                                                                | CHEEMANGALA                     | 00:57   | 01:09     | 00:12    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                              | Station_Name             | Open_At | Closed_At | Duration | REMARKS           |
|-------|-----------|-----------|---------|-------------|---------------------------------------------------|--------------------------|---------|-----------|----------|-------------------|
| 3185  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV TALAGAWARA - CHEEMANGALA                     | CHEEMANGALA, TALAGAWARA  | 11:05   | 11:17     | 00:12    | LINE CLEAR AVAIED |
| 3186  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                               | CHEEMANGALA              | 14:17   | 14:45     | 00:28    | TRIPPED ON FAULT  |
| 3187  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                               | CHEEMANGALA              | 14:45   | 14:47     | 00:02    | TRIPPED ON FAULT  |
| 3188  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV KYALANUR - TALAGAWARA                        | CHEEMANGALA, TALAGAWARA  | 17:40   | 17:43     | 00:03    | LINE CLEAR AVAIED |
| 3189  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                               | JANGAMAKOTE              | 10:41   | 10:50     | 00:09    | LINE CLEAR AVAIED |
| 3190  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV VIJAYAPURA - JANGAMKOTE - MELUR              | MELUR                    | 10:35   | 10:55     | 00:20    | LINE CLEAR AVAIED |
| 3191  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                               | SIDLAGHATTA              | 16:35   | 16:36     | 00:01    | LINE CLEAR AVAIED |
| 3192  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV RAMADEVARAGUDI - NALLIMARADANAHALLI          | RAMADEVARAGUDI           | 11:10   | 14:10     | 03:00    | LINE CLEAR AVAIED |
| 3193  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV NANDI (MUDDENAHALLI) - CB PURA I/A           | NO STATION AFFECTED      | 16:00   | 16:15     | 00:15    | TRIPPED ON FAULT  |
| 3194  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV NRS DB PURA 220 - NANDI (MUDDENAHALLI)       | NANDI                    | 16:00   | 16:15     | 00:15    | TRIPPED ON FAULT  |
| 3195  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - KUDUMULAKUNTE             | KUDUMULAKUNTE, THERIYURU | 18:44   | 19:07     | 00:23    | LOAD CURTAILMENT  |
| 3196  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV GOWRIBIDANUR 220 - KODIGENAHALLI             | KODIGENAHALLI, ID HALLI  | 18:44   | 19:07     | 00:23    | LOAD CURTAILMENT  |
| 3197  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV KUDUMULAKUNTE - THERIYUR                     | THERIYUR, VENKATAPURA    | 18:23   | 19:12     | 00:49    | TRIPPED ON FAULT  |
| 3198  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - BANGARPET 2                      | BANGARPETE               | 11:05   | 14:33     | 03:28    | LINE CLEAR AVAIED |
| 3199  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV PGCIL AUX - SUGUTUR - KOLAR 220 - SM MANGALA | SUGUTUR, KC VALLEY       | 15:37   | 17:23     | 01:46    | LINE CLEAR AVAIED |
| 3200  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV KOLAR 220 - BANGARPET 2                      | BANGARPETE               | 18:45   | 19:05     | 00:20    | LOAD CURTAILMENT  |
| 3201  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                               | MULBAGAL                 | 09:47   | 09:57     | 00:10    | TRIPPED ON FAULT  |
| 3202  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV NARASAPURA - KC VALLEY (EHT)                 | ARASAPURA, KC VALLEY     | 09:45   | 23:59     | 14:14    | TRIPPED ON FAULT  |
| 3203  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - LAKKUR                           | LAKKUR, DEVANAGUNDHI     | 05:55   | 06:10     | 00:15    | TRIPPED ON FAULT  |
| 3204  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - BANGARPET - KGF 2                | NO STATION AFFECTED      | 10:51   | 14:46     | 03:55    | LINE CLEAR AVAIED |
| 3205  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV MALUR 220 - TEKAL - KGF 1                    | TEKAL                    | 11:25   | 11:45     | 00:20    | LINE CLEAR AVAIED |
| 3206  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                               | TEKAL                    | 11:25   | 12:05     | 00:40    | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE   | Voltage | LINE/TRNS   | Line                                    | Station_Name          | Open_At            | Closed_At | Duration | REMARKS            |
|-------|-----------|-----------|---------|-------------|-----------------------------------------|-----------------------|--------------------|-----------|----------|--------------------|
| 3207  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV TEKAL - THORALAKKI                 | THORALAKKI            | 11:25              | 12:35     | 01:10    | LINE CLEAR AVAILED |
| 3208  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV TEKAL - BUDIKOTE                   | BUDIKOTE              | 11:25              | 12:25     | 01:00    | LINE CLEAR AVAILED |
| 3209  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | THORALAKKI            | 11:25              | 12:33     | 01:08    | LINE CLEAR AVAILED |
| 3210  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | THORALAKKI            | 12:33              | 13:20     | 00:47    | LINE CLEAR AVAILED |
| 3211  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | CHATRA                | 13:55              | 14:36     | 00:41    | LINE CLEAR AVAILED |
| 3212  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - KIADB HAROHALLI 220 | NO STATION AFFECTED   | 12:58              | 17:54     | 04:56    | LINE CLEAR AVAILED |
| 3213  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV TK HALLI 220 - IGGALURU            | IGGALURU              | 12:01              | 12:10     | 00:09    | LINE CLEAR AVAILED |
| 3214  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - DOMMASANDRA        | DOMMASANDRA           | 16:41              | 16:57     | 00:16    | LINE CLEAR AVAILED |
| 3215  | 30-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV1                                     | SARJAPURA 220         | 16:39              | 18:58     | 02:19    | LINE CLEAR AVAILED |
| 3216  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV1                                     | SARJAPURA 220         | 16:39              | 16:41     | 00:02    | LINE CLEAR AVAILED |
| 3217  | 30-Sep-24 | BENGALURU | 220     | TRANSFORMER | HV2                                     | SARJAPURA 220         | 16:37              | 16:58     | 00:21    | LINE CLEAR AVAILED |
| 3218  | 30-Sep-24 | BENGALURU | 66      | LINE        | 66KV SARJAPURA 220 - ATTIBELE           | ATTIBELE              | 16:37              | 16:58     | 00:21    | LINE CLEAR AVAILED |
| 3219  | 30-Sep-24 | BENGALURU | 66      | TRANSFORMER | HV2                                     | SARJAPURA 220         | 16:37              | 16:58     | 00:21    | LINE CLEAR AVAILED |
| 3220  | 1-Sep-24  | MYSORE    | 66      | TRANSFORMER | HV2                                     | HOOTAGALLY 220        | 13:15              | 15:21     | 02:05    | LINE CLEAR AVAILED |
| 3221  | 1-Sep-24  | MYSORE    | 66      | LINE        | HEBBANI-SATHEGALA                       | SATHEGALA 66          | 18:43              | 18:57     | 00:14    | TRIPPED ON FAULT   |
| 3222  | 1-Sep-24  | MYSORE    | 220     | LINE        | KADAKOLA-KOZIKODE                       | NO STATIONS EFFECTED  | 10:07              | 11:02     | 00:54    | TRIPPED ON FAULT   |
| 3223  | 1-Sep-24  | MYSORE    | 220     | LINE        | KADAKOLA-KOZIKODE                       | NO STATIONS EFFECTED  | 11:18              | 11:23     | 00:05    | LINE CLEAR AVAILED |
| 3224  | 1-Sep-24  | MYSORE    | 66      | LINE        | PERIYAPATNA-HANAGODU-PONNAMPETE         | NO STATIONS EFFECTED  | 10:43              | 17:26     | 06:42    | LINE CLEAR AVAILED |
| 3225  | 1-Sep-24  | MYSORE    | 220     | LINE        | VAJMANGALA -TK HALLI                    | NO STATIONS EFFECTED  | 06:47              | 18:30     | 11:43    | LINE CLEAR AVAILED |
| 3226  | 1-Sep-24  | MYSORE    | 66      | TRANSFORMER | HV1                                     | YARAHALLI HANDPOST 66 | 12:08              | 12:13     | 00:05    | TRIPPED ON FAULT   |
| 3227  | 1-Sep-24  | MYSORE    | 66      | TRANSFORMER | HV1                                     | YARAHALLI HANDPOST 66 | 13:16              | 13:21     | 00:05    | TRIPPED ON FAULT   |
| 3228  | 1-Sep-24  | MYSORE    | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR               | NO STATIONS EFFECTED  | 17:40 (26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3229  | 1-Sep-24  | MYSORE    | 66      | LINE        | HOOTAGALLI-BELAGOLA                     | NO STATIONS EFFECTED  | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAILED |
| 3230  | 1-Sep-24  | MYSORE    | 66      | LINE        | HULLAHALLI-CHANDRAWADI                  | NO STATIONS EFFECTED  | 17:29 (26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3231  | 1-Sep-24  | MYSORE    | 66      | LINE        | MYSORE SOUTH-KADAKOLA                   | NO STATIONS EFFECTED  | 8:23 (26/08/2024)  |           |          | LINE CLEAR AVAILED |
| 3232  | 1-Sep-24  | MYSORE    | 220     | LINE        | KADAKOLA-HOOTAGALLY                     | NO STATIONS EFFECTED  | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT   |
| 3233  | 1-Sep-24  | MYSORE    | 66      | LINE        | BILIKERE-GV GUDI                        | NO STATIONS EFFECTED  | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAILED |
| 3234  | 1-Sep-24  | MYSORE    | 66      | TRANSFORMER | HV1                                     | SFC SIVA 66           | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT   |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                            | Station_Name                                                            | Open_At            | Closed_At             | Duration   | REMARKS            |
|-------|----------|---------|---------|-------------|---------------------------------|-------------------------------------------------------------------------|--------------------|-----------------------|------------|--------------------|
| 3235  | 1-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE    | NO STATIONS EFFECTED                                                    | 14:42 (05/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3236  | 1-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA-HANAGODU-PONNAMPETE | NO STATIONS EFFECTED                                                    | 20:06 (1/09/2024)  |                       |            | TRIPPED ON FAULT   |
| 3237  | 2-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | HANNUR_66                                                               | 06:14              | 06:50                 | 00:35      | TRIPPED ON FAULT   |
| 3238  | 2-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DOORA                  | DOORA_66 HULLAHALLI_66                                                  | 09:08              | 09:15                 | 00:07      | TRIPPED ON FAULT   |
| 3239  | 2-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAYAPURA               | HAMPAPURA(K)_66 JAIPUR_66                                               | 09:08              | 09:15                 | 00:07      | TRIPPED ON FAULT   |
| 3240  | 2-Sep-24 | MYSORE  | 220     | LINE        | KR PETE 220-ANCHEPALYA 1        | NO STATIONS EFFECTED                                                    | 19:29              | 22:06                 | 02:37      | LINE CLEAR AVAILED |
| 3241  | 2-Sep-24 | MYSORE  | 220     | LINE        | KR PETE 220-ANCHEPALYA 2        | NO STATIONS EFFECTED                                                    | 19:30              | 22:07                 | 02:37      | LINE CLEAR AVAILED |
| 3242  | 2-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                             | KRPET_220                                                               | 19:16              | 22:10                 | 02:54      | LINE CLEAR AVAILED |
| 3243  | 2-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                             | KRPET_220                                                               | 19:16              | 22:10                 | 02:54      | LINE CLEAR AVAILED |
| 3244  | 2-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-KALSON             | NO STATIONS EFFECTED                                                    | 16:13              | 16:22                 | 00:08      | LINE CLEAR AVAILED |
| 3245  | 2-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-HAMPAPURA          | YARAHALLI HANDPOST_66<br>ANTHARSANTHE_66 HDKOTE_66                      | 07:30              | 07:42                 | 00:12      | TRIPPED ON FAULT   |
| 3246  | 2-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PGL                    | NO STATIONS EFFECTED                                                    | 06:50              | 07:03                 | 00:13      | TRIPPED ON FAULT   |
| 3247  | 2-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | THANDYA_66                                                              | 09:10              | 09:15                 | 00:05      | TRIPPED ON FAULT   |
| 3248  | 2-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-VAJMANGALA              | GARGESHWARI_66 THUMBLA_66<br>VYASRAJPURA_66                             | 05:52              | 06:01                 | 00:09      | TRIPPED ON FAULT   |
| 3249  | 2-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | HARADANAHALLI_66                                                        | 14:30              | 15:30                 | 01:00      | LINE CLEAR AVAILED |
| 3250  | 2-Sep-24 | MYSORE  | 66      | LINE        | HULLAHALLI-CHANDRAWADI          | NO STATIONS EFFECTED                                                    | 17:29 (26/08/2024) | 11:39<br>(02/09/2024) | 162:09 Hrs | LINE CLEAR AVAILED |
| 3251  | 2-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA-HANAGODU-PONNAMPETE | NO STATIONS EFFECTED                                                    | 20:06 (1/09/2024)  | 16:45<br>(02/09/2024) | 20:39 Hrs  | TRIPPED ON FAULT   |
| 3252  | 2-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR       | NO STATIONS EFFECTED                                                    | 17:40 (26/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3253  | 2-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA             | NO STATIONS EFFECTED                                                    | 7:53 (26/08/2024)  |                       |            | LINE CLEAR AVAILED |
| 3254  | 2-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA           | NO STATIONS EFFECTED                                                    | 8:23 (26/08/2024)  |                       |            | LINE CLEAR AVAILED |
| 3255  | 2-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY             | NO STATIONS EFFECTED                                                    | 17:04 (24/08/2024) |                       |            | TRIPPED ON FAULT   |
| 3256  | 2-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                | NO STATIONS EFFECTED                                                    | 11:54 (09/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3257  | 2-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | SFC SIVA_66                                                             | 7:01 (15/02/2024)  |                       |            | TRIPPED ON FAULT   |
| 3258  | 2-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE    | NO STATIONS EFFECTED                                                    | 14:42 (05/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3259  | 2-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA-TK HALLI             | NO STATIONS EFFECTED                                                    | 7:50 (2/09/2024)   |                       |            | LINE CLEAR AVAILED |
| 3260  | 3-Sep-24 | MYSORE  | 66      | LINE        | AJJIPURA-COWDALLI               | BANDALLI_66 COWDALLI_66                                                 | 14:50              | 17:00                 | 02:10      | LINE CLEAR AVAILED |
| 3261  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | AJJIPURA_66                                                             | 10:00              | 17:00                 | 07:00      | LINE CLEAR AVAILED |
| 3262  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | BANDALLI_66                                                             | 10:20              | 17:35                 | 07:15      | LINE CLEAR AVAILED |
| 3263  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | BANDALLI_66                                                             | 10:20              | 17:35                 | 07:15      | LINE CLEAR AVAILED |
| 3264  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-AJJIPURA                 | AJJIPURA_66 BANDALLI_66<br>COWDALLI_66 MARTAHALLI_66<br>RAMAPURA_MYS_66 | 14:48              | 17:00                 | 02:12      | LINE CLEAR AVAILED |
| 3265  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-ECOREN_WIND              | NO STATIONS EFFECTED                                                    | 15:20              | 17:00                 | 01:40      | LINE CLEAR AVAILED |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name                                | Open_At            | Closed_At            | Duration  | REMARKS            |
|-------|----------|---------|---------|-------------|------------------------------|---------------------------------------------|--------------------|----------------------|-----------|--------------------|
| 3266  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-GAMESH_SOLAR          | NO STATIONS EFFECTED                        | 15:20              | 17:00                | 01:40     | LINE CLEAR AVAILED |
| 3267  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-ASIAN FAB             | NO STATIONS EFFECTED                        | 15:20              | 17:00                | 01:40     | LINE CLEAR AVAILED |
| 3268  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HANNUR_66                                   | 10:10              | 17:08                | 06:57     | LINE CLEAR AVAILED |
| 3269  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HANNUR_66                                   | 10:11              | 17:08                | 06:56     | LINE CLEAR AVAILED |
| 3270  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-MADHUVANAHALLI- 1     | NO STATIONS EFFECTED                        | 12:41              | 14:10                | 01:29     | LINE CLEAR AVAILED |
| 3271  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-MADHUVANAHALLI- 2     | NO STATIONS EFFECTED                        | 11:12              | 12:40                | 01:28     | LINE CLEAR AVAILED |
| 3272  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-MADHUVANAHALLI- 1     | HANNUR_66                                   | 15:20              | 17:11                | 01:51     | LINE CLEAR AVAILED |
| 3273  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-MADHUVANAHALLI- 2     | HANNUR_66                                   | 15:20              | 17:11                | 01:51     | LINE CLEAR AVAILED |
| 3274  | 3-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-KOTHANUR              | NO STATIONS EFFECTED                        | 14:48              | 16:58                | 02:09     | LINE CLEAR AVAILED |
| 3275  | 3-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAPA-1    | NO STATIONS EFFECTED                        | 12:31              | 13:57                | 01:25     | LINE CLEAR AVAILED |
| 3276  | 3-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAPA-2    | NO STATIONS EFFECTED                        | 14:06              | 14:13                | 00:07     | LINE CLEAR AVAILED |
| 3277  | 3-Sep-24 | MYSORE  | 66      | LINE        | KARYA -HEMMARGALA            | DEVANOORNGUDU_66<br>HEMMARGALA_66 SUTTUR_66 | 18:49              | 18:58                | 00:09     | TRIPPED ON FAULT   |
| 3278  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KIKKERI_66                                  | 11:32              | 18:34                | 07:01     | LINE CLEAR AVAILED |
| 3279  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | KIKKERI_66                                  | 16:05              | 18:16                | 02:11     | LINE CLEAR AVAILED |
| 3280  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                          | KIKKERI_66                                  | 10:36              | 18:25                | 07:49     | LINE CLEAR AVAILED |
| 3281  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                          | KIKKERI_66                                  | 06:48              | 06:57                | 00:09     | TRIPPED ON FAULT   |
| 3282  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                          | KIKKERI_66                                  | 07:08              | 07:24                | 00:16     | TRIPPED ON FAULT   |
| 3283  | 3-Sep-24 | MYSORE  | 66      | LINE        | KR PETE-KIKKERI              | KIKKERI_66                                  | 16:14              | 18:07                | 01:53     | LINE CLEAR AVAILED |
| 3284  | 3-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-BANNARI IPP          | NO STATIONS EFFECTED                        | 06:00              | 06:10                | 00:10     | TRIPPED ON FAULT   |
| 3285  | 3-Sep-24 | MYSORE  | 66      | LINE        | VADAKEPURA-KIRUGAVLU         | KIRUGAVALU_66 MALIYURU_66                   | 04:17              | 04:27                | 00:10     | TRIPPED ON FAULT   |
| 3286  | 3-Sep-24 | MYSORE  | 66      | LINE        | VAJAMANGALA-KADAKOLA-1       | AYRALLI_66 MARADIHUNDI_66                   | 06:01              | 06:14                | 00:13     | TRIPPED ON FAULT   |
| 3287  | 3-Sep-24 | MYSORE  | 66      | LINE        | VAJAMANGALA-KADAKOLA-2       | HAMPAPURA(K)_66 JAIPUR_66                   | 06:01              | 06:14                | 00:13     | TRIPPED ON FAULT   |
| 3288  | 3-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR    | NO STATIONS EFFECTED                        | 17:40 (26/08/2024) |                      |           | LINE CLEAR AVAILED |
| 3289  | 3-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED                        | 7:53 (26/08/2024)  |                      |           | LINE CLEAR AVAILED |
| 3290  | 3-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED                        | 8:23 (26/08/2024)  |                      |           | LINE CLEAR AVAILED |
| 3291  | 3-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY          | NO STATIONS EFFECTED                        | 17:04 (24/08/2024) |                      |           | TRIPPED ON FAULT   |
| 3292  | 3-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED                        | 11:54 (09/08/2024) |                      |           | LINE CLEAR AVAILED |
| 3293  | 3-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                                 | 7:01 (15/02/2024)  |                      |           | TRIPPED ON FAULT   |
| 3294  | 3-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED                        | 14:42 (05/08/2024) |                      |           | LINE CLEAR AVAILED |
| 3295  | 3-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA-TK HALLI          | NO STATIONS EFFECTED                        | 7:50 (2/09/2024)   | 18:15<br>(3/09/2024) | 34:25 Hrs | LINE CLEAR AVAILED |
| 3296  | 4-Sep-24 | MYSORE  | 66      | LINE        | BETTADAPURA-CHUNCHANAKATTE   | KITTUR_66 RAVANDUR_66                       | 18:35              | 18:50                | 00:15     | TRIPPED ON FAULT   |



| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                                        | Station_Name                                                        | Open_At | Closed_At | Duration | REMARKS            |
|-------|----------|---------|---------|-------------|---------------------------------------------|---------------------------------------------------------------------|---------|-----------|----------|--------------------|
| 3297  | 4-Sep-24 | MYSORE  | 66      | LINE        | CHUNCHANAKATTE-GAVADGERE-GRAPHITE INDIA IPP | CHUNCHUNKATTE_66                                                    | 18:35   | 18:55     | 00:20    | TRIPPED ON FAULT   |
| 3298  | 4-Sep-24 | MYSORE  | 66      | LINE        | CHIKKAMANDYA-MANDYA                         | NO STATIONS EFFECTED                                                | 11:35   | 17:09     | 05:34    | LINE CLEAR AVAILED |
| 3299  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-CHANDAKAWADI                      | CHANDAKAVADI_66                                                     | 12:55   | 13:14     | 00:18    | LINE CLEAR AVAILED |
| 3300  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-DR PETE 1                         | NO STATIONS EFFECTED                                                | 12:55   | 13:07     | 00:11    | LINE CLEAR AVAILED |
| 3301  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-DR PETE 2                         | NO STATIONS EFFECTED                                                | 12:55   | 13:07     | 00:12    | LINE CLEAR AVAILED |
| 3302  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-BADANGUPPE 1                      | BADANAGUPPE_66                                                      | 12:55   | 13:11     | 00:16    | LINE CLEAR AVAILED |
| 3303  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-BADANGUPPE 2                      | BADANAGUPPE_66                                                      | 12:55   | 13:11     | 00:16    | LINE CLEAR AVAILED |
| 3304  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-SOMWARPETE                        | SOMWARPETE_66<br>ATTIGULIPURA_66<br>HONNALY_MYS_66<br>ARKALAWADI_66 | 12:55   | 13:18     | 00:23    | LINE CLEAR AVAILED |
| 3305  | 4-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-HONGANUR                          | NO STATIONS EFFECTED                                                | 12:55   | 13:12     | 00:16    | LINE CLEAR AVAILED |
| 3306  | 4-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(N'GUD)-KADAKOLA                      | DEVANOORNGUDU_66                                                    | 10:02   | 17:38     | 07:36    | LINE CLEAR AVAILED |
| 3307  | 4-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(N'GUD)-PANYADAHUNDI                  | NO STATIONS EFFECTED                                                | 10:02   | 17:37     | 07:34    | LINE CLEAR AVAILED |
| 3308  | 4-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(N'GUD)-SUTTUR                        | SUTTUR_66                                                           | 10:02   | 17:37     | 07:34    | LINE CLEAR AVAILED |
| 3309  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | HANGLA_66                                                           | 10:51   | 11:00     | 00:08    | TRIPPED ON FAULT   |
| 3310  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                         | HARVEY_66                                                           | 13:05   | 13:14     | 00:08    | LINE CLEAR AVAILED |
| 3311  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | HARVEY_66                                                           | 13:05   | 13:14     | 00:08    | LINE CLEAR AVAILED |
| 3312  | 4-Sep-24 | MYSORE  | 66      | LINE        | JAIPURA-HAMPAPURA                           | HAMPAPURA(K)_66                                                     | 10:18   | 16:27     | 06:09    | LINE CLEAR AVAILED |
| 3313  | 4-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA1                         | DOORA_66 NANJANGUDU_66<br>THANDYA_66                                | 12:53   | 13:17     | 00:24    | TRIPPED ON FAULT   |
| 3314  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                         | KADAKOLA_220                                                        | 12:55   | 13:30     | 00:34    | LINE CLEAR AVAILED |
| 3315  | 4-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                                         | KADAKOLA_220                                                        | 12:55   | 13:25     | 00:29    | LINE CLEAR AVAILED |
| 3316  | 4-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                                         | KADAKOLA_220                                                        | 12:54   | 13:25     | 00:31    | LINE CLEAR AVAILED |
| 3317  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | KADAKOLA_220                                                        | 12:55   | 13:30     | 00:34    | LINE CLEAR AVAILED |
| 3318  | 4-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-GOLUR                              | NO STATIONS EFFECTED                                                | 11:16   | 14:19     | 03:03    | LINE CLEAR AVAILED |
| 3319  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                         | KIADBMANDYA_66                                                      | 12:55   | 13:05     | 00:10    | LINE CLEAR AVAILED |
| 3320  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | KIADBMANDYA_66                                                      | 12:55   | 13:05     | 00:10    | LINE CLEAR AVAILED |
| 3321  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | KMDODDI_66                                                          | 10:36   | 14:29     | 03:53    | LINE CLEAR AVAILED |
| 3322  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                         | KMDODDI_66                                                          | 14:32   | 16:39     | 02:07    | LINE CLEAR AVAILED |
| 3323  | 4-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-MADHUVANAHALLI                      | KUNTHUR_66                                                          | 15:07   | 15:10     | 00:03    | TRIPPED ON FAULT   |
| 3324  | 4-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-HAMPAPURA                      | ANTHARSANTHE_66HDKOTE_66YE<br>REHALLIHANDPOST_66                    | 10:25   | 16:45     | 06:20    | LINE CLEAR AVAILED |
| 3325  | 4-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-KABINI 2                       | NO STATIONS EFFECTED                                                | 12:55   | 13:20     | 00:25    | TRIPPED ON FAULT   |
| 3326  | 4-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-BPCL                              | NO STATIONS EFFECTED                                                | 10:01   | 14:57     | 04:55    | LINE CLEAR AVAILED |
| 3327  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | SATHEGALA_66                                                        | 10:01   | 18:48     | 08:46    | LINE CLEAR AVAILED |
| 3328  | 4-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-KOLLEGALA                         | SATHEGALA_66                                                        | 10:01   | 12:54     | 02:53    | LINE CLEAR AVAILED |
| 3329  | 4-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-HEBBANI                           | NO STATIONS EFFECTED                                                | 10:01   | 12:52     | 02:51    | LINE CLEAR AVAILED |
| 3330  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | SHIVALLY_66                                                         | 10:25   | 16:25     | 06:00    | LINE CLEAR AVAILED |
| 3331  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | SHIVALLY_66                                                         | 17:50   | 18:25     | 00:35    | LINE CLEAR AVAILED |
| 3332  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                         | SHIVALLY_66                                                         | 19:10   | 19:45     | 00:35    | LINE CLEAR AVAILED |
| 3333  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                         | SINDHUVALLI_66                                                      | 15:46   | 16:31     | 00:44    | LINE CLEAR AVAILED |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                             | Station_Name                                          | Open_At            | Closed_At | Duration | REMARKS             |
|-------|----------|---------|---------|-------------|----------------------------------|-------------------------------------------------------|--------------------|-----------|----------|---------------------|
| 3334  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-G UKKADE               | NO STATIONS EFFECTED                                  | 11:34              | 12:04     | 00:29    | LINE CLEAR AVAILED  |
| 3335  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-PANDAVAPURA            | NO STATIONS EFFECTED                                  | 10:43              | 11:33     | 00:50    | LINE CLEAR AVAILED  |
| 3336  | 4-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                              | TUBINAKERE_220                                        | 13:05              | 13:25     | 00:19    | LINE CLEAR AVAILED  |
| 3337  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | TUBINAKERE_220                                        | 13:40              | 14:44     | 01:04    | LINE CLEAR AVAILED  |
| 3338  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | TUBINAKERE_220                                        | 14:37              | 14:55     | 00:18    | LINE CLEAR AVAILED  |
| 3339  | 4-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                              | TUBINAKERE_220                                        | 13:26              | 13:49     | 00:23    | LINE CLEAR AVAILED  |
| 3340  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-ARAKERE                | ARAKERE_66GAMANAHALLY_66TA<br>RIPURA_66CHAMPLAPURA_66 | 12:47              | 12:59     | 00:12    | LINE CLEAR AVAILED  |
| 3341  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-JAKKANAHALLI           | NO STATIONS EFFECTED                                  | 10:23              | 11:21     | 00:58    | LINE CLEAR AVAILED  |
| 3342  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-MANDYA 2               | NO STATIONS EFFECTED                                  | 12:06              | 12:28     | 00:21    | LINE CLEAR AVAILED  |
| 3343  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-MANDYA 4               | NO STATIONS EFFECTED                                  | 12:28              | 12:49     | 00:21    | LINE CLEAR AVAILED  |
| 3344  | 4-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-NAGAMANGALA 2          | NO STATIONS EFFECTED                                  | 10:37              | 11:23     | 00:46    | LINE CLEAR AVAILED  |
| 3345  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | KOLKARANADODDI_66                                     | 12:54              | 13:10     | 00:16    | LINE CLEAR AVAILED  |
| 3346  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | KOLKARANADODDI_66                                     | 12:54              | 13:10     | 00:16    | LINE CLEAR AVAILED  |
| 3347  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | BESAGARAHALLI_66                                      | 11:25              | 12:30     | 01:05    | LINE CLEAR AVAILED  |
| 3348  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | BESAGARAHALLI_66                                      | 11:30              | 14:50     | 03:20    | LINE CLEAR AVAILED  |
| 3349  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | TUMBEKERE_66                                          | 12:53              | 12:56     | 00:03    | LINE CLEAR AVAILED  |
| 3350  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | TUMBEKERE_66                                          | 12:53              | 12:56     | 00:03    | LINE CLEAR AVAILED  |
| 3351  | 4-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA-TK HALLI              | NO STATIONS EFFECTED                                  | 07:20              | 18:55     | 11:35    | LINE CLEAR AVAILED  |
| 3352  | 4-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR        | NO STATIONS EFFECTED                                  | 17:40 (26/08/2024) |           |          | LINE CLEAR AVAILED  |
| 3353  | 4-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA              | NO STATIONS EFFECTED                                  | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAILED  |
| 3354  | 4-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA            | NO STATIONS EFFECTED                                  | 8:23 (26/08/2024)  |           |          | LINE CLEAR AVAILED  |
| 3355  | 4-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY              | NO STATIONS EFFECTED                                  | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT    |
| 3356  | 4-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                 | NO STATIONS EFFECTED                                  | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAILED  |
| 3357  | 4-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | SFC SIVA_66                                           | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT    |
| 3358  | 4-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-<br>MUTHINAMULSOGE | NO STATIONS EFFECTED                                  | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAILED  |
| 3359  | 4-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2              | NO STATIONS EFFECTED                                  | 12:54 (04/09/2024) |           |          | TRIPPED ON FAULT    |
| 3360  | 5-Sep-24 | MYSORE  | 66      | LINE        | BANNUR-VAJAMANGALA               | NO STATIONS EFFECTED                                  | 09:22              | 17:32     | 08:10    | LINE CLEAR AVAILED  |
| 3361  | 5-Sep-24 | MYSORE  | 66      | LINE        | BEGUR 220-SARAGUR                | NO STATIONS EFFECTED                                  | 15:50              | 15:55     | 00:05    | TRIPPED ON FAULT    |
| 3362  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | BETTADHAPURA_66                                       | 16:09              | 16:53     | 00:43    | LINE CLEAR AVAILED  |
| 3363  | 5-Sep-24 | MYSORE  | 66      | LINE        | CHUNCHUNKATTE-GAVADGERE          | NO STATIONS EFFECTED                                  | 08:36              | 12:09     | 03:32    | LINE CLEAR AVAILED  |
| 3364  | 5-Sep-24 | MYSORE  | 220     | LINE        | CR NAGARA-MADHUVANAHALLI<br>1    | NO STATIONS EFFECTED                                  | 10:46              | 15:10     | 04:24    | LINE CLEAR AVAILED  |
| 3365  | 5-Sep-24 | MYSORE  | 220     | LINE        | CR NAGARA-MADHUVANAHALLI<br>2    | NO STATIONS EFFECTED                                  | 15:27              | 17:10     | 01:42    | LINE CLEAR AVAILED  |
| 3366  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | HANGLA_66                                             | 10:33              | 10:58     | 00:24    | TRIPPED ON FAULT    |
| 3367  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | HANGLA_66                                             | 14:41              | 14:46     | 00:05    | TRIPPED ON FAULT    |
| 3368  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                              | HALAGUR_66                                            | 15:44              | 16:40     | 00:56    | MAIN SUPPLY FAILURE |
| 3369  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                              | HALAGUR_66                                            | 15:44              | 16:40     | 00:56    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name              | Open_At            | Closed_At | Duration | REMARKS             |
|-------|----------|---------|---------|-------------|------------------------------|---------------------------|--------------------|-----------|----------|---------------------|
| 3370  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HALAGUR_66                | 18:25              | 18:35     | 00:10    | MAIN SUPPLY FAILURE |
| 3371  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HALAGUR_66                | 18:25              | 18:35     | 00:10    | MAIN SUPPLY FAILURE |
| 3372  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HUNSUR_66                 | 16:06              | 17:24     | 01:17    | LINE CLEAR AVAIED   |
| 3373  | 5-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR-GAVADGERE-YELWALA     | ELAVALA_66                | 18:49              | 19:09     | 00:19    | TRIPPED ON FAULT    |
| 3374  | 5-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR 220-GAVADGERE         | NO STATIONS EFFECTED      | 18:50              | 19:03     | 00:13    | TRIPPED ON FAULT    |
| 3375  | 5-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DOORA               | DOORA_66                  | 09:42              | 09:50     | 00:08    | TRIPPED ON FAULT    |
| 3376  | 5-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAIPURA             | HAMPAPURA(K)_66 JAIPUR_66 | 09:42              | 09:48     | 00:06    | TRIPPED ON FAULT    |
| 3377  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KIRUGAVALU_66             | 10:32              | 12:55     | 02:23    | LINE CLEAR AVAIED   |
| 3378  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | KIRUGAVALU_66             | 12:58              | 14:37     | 01:39    | LINE CLEAR AVAIED   |
| 3379  | 5-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | MADHUVANAHALLI_220        | 13:53              | 15:47     | 01:54    | LINE CLEAR AVAIED   |
| 3380  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | MADHUVANAHALLI_220        | 12:01              | 14:49     | 02:48    | LINE CLEAR AVAIED   |
| 3381  | 5-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANAHALLI-KOLLEGALA 1   | NO STATIONS EFFECTED      | 13:29              | 16:34     | 03:04    | LINE CLEAR AVAIED   |
| 3382  | 5-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA      | NO STATIONS EFFECTED      | 09:26              | 17:34     | 08:07    | LINE CLEAR AVAIED   |
| 3383  | 5-Sep-24 | MYSORE  | 66      | LINE        | PANDAVAPURA-ATRIA 2          | NO STATIONS EFFECTED      | 13:28              | 13:33     | 00:04    | TRIPPED ON FAULT    |
| 3384  | 5-Sep-24 | MYSORE  | 66      | LINE        | SANTHE SARAGUR-BEGUR 220     | NO STATIONS EFFECTED      | 16:51              | 16:59     | 00:08    | TRIPPED ON FAULT    |
| 3385  | 5-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARASANTHE-YESSLUR      | NO STATIONS EFFECTED      | 07:35              | 08:18     | 00:42    | TRIPPED ON FAULT    |
| 3386  | 5-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARASANTHE-YESSLUR      | NO STATIONS EFFECTED      | 09:05              | 09:25     | 00:19    | TRIPPED ON FAULT    |
| 3387  | 5-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARASANTHE-YESSLUR      | NO STATIONS EFFECTED      | 13:10              | 14:07     | 00:57    | LINE CLEAR AVAIED   |
| 3388  | 5-Sep-24 | MYSORE  | 66      | LINE        | SHIVALLI-NAGAMANGALA         | NAGAMANGALA_66            | 18:40              | 18:47     | 00:06    | TRIPPED ON FAULT    |
| 3389  | 5-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | VAJAMANGALA_220           | 09:20              | 13:42     | 04:22    | LINE CLEAR AVAIED   |
| 3390  | 5-Sep-24 | MYSORE  | 220     | TRANSFORMER | VAJAMANGALA-HV2              | VAJAMANGALA_220           | 13:44              | 17:28     | 03:44    | LINE CLEAR AVAIED   |
| 3391  | 5-Sep-24 | MYSORE  | 220     | LINE        | VAJAMANGALA-TK HALLI         | NO STATIONS EFFECTED      | 08:11              | 19:10     | 10:59    | LINE CLEAR AVAIED   |
| 3392  | 5-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR    | NO STATIONS EFFECTED      | 17:40 (26/08/2024) |           |          | LINE CLEAR AVAIED   |
| 3393  | 5-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED      | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAIED   |
| 3394  | 5-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED      | 8:23 (26/08/2024)  |           |          | LINE CLEAR AVAIED   |
| 3395  | 5-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY          | NO STATIONS EFFECTED      | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT    |
| 3396  | 5-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED      | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAIED   |
| 3397  | 5-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66               | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT    |
| 3398  | 5-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED      | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAIED   |
| 3399  | 5-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2          | NO STATIONS EFFECTED      | 12:54 (04/09/2024) |           |          | TRIPPED ON FAULT    |
| 3400  | 6-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | COWDALLI_66               | 11:08              | 11:17     | 00:08    | TRIPPED ON FAULT    |
| 3401  | 6-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-CHANDAKAWADI       | CHANDAKAVADI_66           | 09:05              | 09:19     | 00:13    | TRIPPED ON FAULT    |
| 3402  | 6-Sep-24 | MYSORE  | 220     | LINE        | CR NAGARA-BEGUR 1            | NO STATIONS EFFECTED      | 17:09              | 18:02     | 00:53    | LINE CLEAR AVAIED   |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                                | Station_Name                                                      | Open_At            | Closed_At | Duration | REMARKS           |
|-------|----------|---------|---------|-------------|-------------------------------------|-------------------------------------------------------------------|--------------------|-----------|----------|-------------------|
| 3403  | 6-Sep-24 | MYSORE  | 220     | LINE        | CR NAGARA-BEGUR 2                   | NO STATIONS EFFECTED                                              | 13:51              | 17:06     | 03:15    | LINE CLEAR AVAIED |
| 3404  | 6-Sep-24 | MYSORE  | 66      | LINE        | G UKKADA-PANDAVAPURA                | NO STATIONS EFFECTED                                              | 08:27              | 08:45     | 00:17    | TRIPPED ON FAULT  |
| 3405  | 6-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                 | GUNDULPET_66                                                      | 11:31              | 11:42     | 00:10    | TRIPPED ON FAULT  |
| 3406  | 6-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 1                  | NO STATIONS EFFECTED                                              | 09:16              | 20:16     | 11:00    | LINE CLEAR AVAIED |
| 3407  | 6-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 2                  | NO STATIONS EFFECTED                                              | 09:16              | 20:16     | 11:00    | LINE CLEAR AVAIED |
| 3408  | 6-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR 220-KAMPLAPURA               | NO STATIONS EFFECTED                                              | 21:08              | 21:20     | 00:12    | TRIPPED ON FAULT  |
| 3409  | 6-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR 220-KAMPLAPURA               | NO STATIONS EFFECTED                                              | 23:18              | 23:30     | 00:12    | TRIPPED ON FAULT  |
| 3410  | 6-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-PANDAVAPURA               | BANANGADI_66BELAGOLA_66DOD<br>DABYADARAHALLI_66PANDAVAPU<br>RA_66 | 08:26              | 08:36     | 00:10    | TRIPPED ON FAULT  |
| 3411  | 6-Sep-24 | MYSORE  | 66      | LINE        | THANDYA-ITC                         | NO STATIONS EFFECTED                                              | 16:22              | 17:05     | 00:43    | TRIPPED ON FAULT  |
| 3412  | 6-Sep-24 | MYSORE  | 66      | LINE        | THANDYA-ITC                         | NO STATIONS EFFECTED                                              | 22:50              | 22:55     | 00:05    | LINE CLEAR AVAIED |
| 3413  | 6-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-HAMPAPURA              | ANTHARSANTHE_66HDKOTE_66YE<br>REHALLIHANDPOST_66                  | 18:44              | 18:54     | 00:10    | TRIPPED ON FAULT  |
| 3414  | 6-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-VAJAMANGALA 2              | NO STATIONS EFFECTED                                              | 12:22              | 13:49     | 01:27    | LINE CLEAR AVAIED |
| 3415  | 6-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR           | NO STATIONS EFFECTED                                              | 17:40 (26/08/2024) |           |          | LINE CLEAR AVAIED |
| 3416  | 6-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA                 | NO STATIONS EFFECTED                                              | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAIED |
| 3417  | 6-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA               | NO STATIONS EFFECTED                                              | 8:23 (26/08/2024)  |           |          | LINE CLEAR AVAIED |
| 3418  | 6-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY                 | NO STATIONS EFFECTED                                              | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT  |
| 3419  | 6-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                    | NO STATIONS EFFECTED                                              | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAIED |
| 3420  | 6-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                 | SFC SIVA_66                                                       | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT  |
| 3421  | 6-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-<br>MUTHINAMULSOGE    | NO STATIONS EFFECTED                                              | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAIED |
| 3422  | 6-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2                 | NO STATIONS EFFECTED                                              | 12:54 (04/09/2024) |           |          | TRIPPED ON FAULT  |
| 3423  | 7-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-GUNDLUPETE 2              | TERAKANAMBE_66                                                    | 10:20              | 10:27     | 00:06    | TRIPPED ON FAULT  |
| 3424  | 7-Sep-24 | MYSORE  | 66      | LINE        | 220KV HUNSUR-KAMPLAPURA             | NO STATIONS EFFECTED                                              | 00:13              | 07:33     | 07:20    | TRIPPED ON FAULT  |
| 3425  | 7-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-BG PURA-CHIDRAVALLI         | BGPURA_66CHIDRAVALLI_66                                           | 05:57              | 06:13     | 00:16    | TRIPPED ON FAULT  |
| 3426  | 7-Sep-24 | MYSORE  | 220     | LINE        | 220KV NAGAMANGALA -<br>ANCHEPALYA 2 | NO STATIONS EFFECTED                                              | 15:01 (7/09/2024)  |           |          | TRIPPED ON FAULT  |
| 3427  | 7-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR           | NO STATIONS EFFECTED                                              | 17:40 (26/08/2024) |           |          | LINE CLEAR AVAIED |
| 3428  | 7-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA                 | NO STATIONS EFFECTED                                              | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAIED |
| 3429  | 7-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA               | NO STATIONS EFFECTED                                              | 8:23(26/08/2024)   |           |          | LINE CLEAR AVAIED |
| 3430  | 7-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY                 | NO STATIONS EFFECTED                                              | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT  |
| 3431  | 7-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                    | NO STATIONS EFFECTED                                              | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAIED |
| 3432  | 7-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                 | SFC SIVA_66                                                       | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT  |
| 3433  | 7-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-<br>MUTHINAMULSOGE    | NO STATIONS EFFECTED                                              | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAIED |

| SL NO | Dinanka  | Tr_ZONE | Voltage | LINE/TRNS   | Line                                   | Station_Name                                                    | Open_At            | Closed_At             | Duration  | REMARKS            |
|-------|----------|---------|---------|-------------|----------------------------------------|-----------------------------------------------------------------|--------------------|-----------------------|-----------|--------------------|
| 3434  | 7-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2                    | NO STATIONS EFFECTED                                            | 12:54 (04/09/2024) |                       |           | TRIPPED ON FAULT   |
| 3435  | 8-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | DKMAIDANA_66                                                    | 22:42              | 22:50                 | 00:07     | TRIPPED ON FAULT   |
| 3436  | 8-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DOORA                         | DOORA_66                                                        | 16:03              | 16:11                 | 00:08     | TRIPPED ON FAULT   |
| 3437  | 8-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAIPURA                       | HAMPAPURA(K)_66 JAIPUR_66                                       | 16:03              | 16:12                 | 00:08     | TRIPPED ON FAULT   |
| 3438  | 8-Sep-24 | MYSORE  | 66      | LINE        | KARYA-HEMMARGALA                       | DEVANOORNGUDU_66,<br>HEMMARGALA_66, KARYA_66                    | 18:35              | 18:45                 | 00:10     | TRIPPED ON FAULT   |
| 3439  | 8-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                    | THANDYA_66                                                      | 16:05              | 16:10                 | 00:05     | TRIPPED ON FAULT   |
| 3440  | 8-Sep-24 | MYSORE  | 220     | LINE        | 220KV NAGAMANGALA -<br>ANCHEPALYA 2    | NO STATIONS EFFECTED                                            | 15:01 (7/09/2024)  | 15:39<br>(08/09/2024) | 24:38 HRs | TRIPPED ON FAULT   |
| 3441  | 8-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR              | NO STATIONS EFFECTED                                            | 17:40 (26/08/2024) |                       |           | LINE CLEAR AVAILED |
| 3442  | 8-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA                    | NO STATIONS EFFECTED                                            | 7:53(26/08/2024)   |                       |           | LINE CLEAR AVAILED |
| 3443  | 8-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA                  | NO STATIONS EFFECTED                                            | 8:23 (26/08/2024)  |                       |           | LINE CLEAR AVAILED |
| 3444  | 8-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY                    | NO STATIONS EFFECTED                                            | 17:04 (24/08/2024) |                       |           | TRIPPED ON FAULT   |
| 3445  | 8-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                       | NO STATIONS EFFECTED                                            | 11:54 (09/08/2024) |                       |           | LINE CLEAR AVAILED |
| 3446  | 8-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | SFC SIVA_66                                                     | 7:01 (15/02/2024)  |                       |           | TRIPPED ON FAULT   |
| 3447  | 8-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-<br>MUTHINAMULSOGE       | NO STATIONS EFFECTED                                            | 14:42 (05/08/2024) |                       |           | LINE CLEAR AVAILED |
| 3448  | 8-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2                    | NO STATIONS EFFECTED                                            | 12:54 (04/09/2024) |                       |           | TRIPPED ON FAULT   |
| 3449  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | BANNIMANTAP_66                                                  | 07:17              | 22:02                 | 14:45     | LINE CLEAR AVAILED |
| 3450  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | HULLAHALLI_66                                                   | 07:14              | 07:52                 | 00:38     | TRIPPED ON FAULT   |
| 3451  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                    | HULLAHALLI_66                                                   | 07:14              | 07:52                 | 00:38     | TRIPPED ON FAULT   |
| 3452  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                    | KADAKOLA_220                                                    | 08:04              | 08:08                 | 00:04     | TRIPPED ON FAULT   |
| 3453  | 9-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DOORA                         | DOORA_66                                                        | 08:04              | 08:14                 | 00:10     | TRIPPED ON FAULT   |
| 3454  | 9-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAYAPURA                      | HAMPAPURA(K)_66JAIPUR_66                                        | 08:04              | 08:16                 | 00:12     | TRIPPED ON FAULT   |
| 3455  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | KMDODDI_66                                                      | 19:05              | 19:10                 | 00:05     | LINE CLEAR AVAILED |
| 3456  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                    | MANDYA_66                                                       | 09:05              | 09:34                 | 00:28     | TRIPPED ON FAULT   |
| 3457  | 9-Sep-24 | MYSORE  | 66      | LINE        | 220 KV NAGAMANGALA -<br>GUDDENAHALLI   | GUDDENAHALLI_66BOGADHI<br>MANDYA_66                             | 18:27              | 18:33                 | 00:06     | TRIPPED ON FAULT   |
| 3458  | 9-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA -MARADIHUNDI-<br>KADAKOLA 1 | AYRALLI_66<br>MARADIHUNDI_66HAMPAPURA(K)<br>66JAIPUR_66GOLUR_66 | 18:37              | 18:56                 | 00:19     | TRIPPED ON FAULT   |
| 3459  | 9-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA -KADAKOLA 2                 | NO STATIONS EFFECTED                                            | 18:37              | 18:56                 | 00:19     | TRIPPED ON FAULT   |
| 3460  | 9-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA -TK HALLI                   | NO STATIONS EFFECTED                                            | 06:42              | 10:47                 | 04:05     | LINE CLEAR AVAILED |
| 3461  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                    | SANTHEBACHALLI_66                                               | 15:05              | 16:20                 | 01:15     | LINE CLEAR AVAILED |
| 3462  | 9-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                    | BEGUR_66                                                        | 12:00              | 14:10                 | 02:10     | LINE CLEAR AVAILED |
| 3463  | 9-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR              | NO STATIONS EFFECTED                                            | 17:40 (26/08/2024) |                       |           | LINE CLEAR AVAILED |
| 3464  | 9-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA                    | NO STATIONS EFFECTED                                            | 7:53 (26/08/2024)  |                       |           | LINE CLEAR AVAILED |
| 3465  | 9-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA                  | NO STATIONS EFFECTED                                            | 8:23(26/08/2024)   |                       |           | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                    | Open_At            | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------------------------|---------------------------------|--------------------|-----------|----------|--------------------|
| 3466  | 9-Sep-24  | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY                        | NO STATIONS EFFECTED            | 17:04 (24/08/2024) |           |          | TRIPPED ON FAULT   |
| 3467  | 9-Sep-24  | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                           | NO STATIONS EFFECTED            | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAILED |
| 3468  | 9-Sep-24  | MYSORE  | 66      | TRANSFORMER | HV1                                        | SFC SIVA_66                     | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT   |
| 3469  | 9-Sep-24  | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE               | NO STATIONS EFFECTED            | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAILED |
| 3470  | 9-Sep-24  | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2                        | NO STATIONS EFFECTED            | 12:54 (04/09/2024) |           |          | TRIPPED ON FAULT   |
| 3471  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | COWDALLI_66                     | 09:50              | 09:55     | 00:04    | TRIPPED ON FAULT   |
| 3472  | 10-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI                           | NO STATIONS EFFECTED            | 18:29              | 18:40     | 00:11    | TRIPPED ON FAULT   |
| 3473  | 10-Sep-24 | MYSORE  | 66      | LINE        | K HONNALAGERE-IGLOOR                       | NO STATIONS EFFECTED            | 11:53              | 13:16     | 01:22    | LINE CLEAR AVAILED |
| 3474  | 10-Sep-24 | MYSORE  | 66      | LINE        | KIRUGAVLU-MALIYUR                          | MALIYURU_66                     | 10:37              | 16:06     | 05:29    | LINE CLEAR AVAILED |
| 3475  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | KOLKARANADODDI_66               | 11:52              | 13:14     | 01:22    | LINE CLEAR AVAILED |
| 3476  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | KOLKARANADODDI_66               | 10:00              | 12:00     | 02:00    | LINE CLEAR AVAILED |
| 3477  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | KOLLEGALA_66                    | 10:15              | 10:26     | 00:10    | LINE CLEAR AVAILED |
| 3478  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-EDCL IPP                 | NO STATIONS EFFECTED            | 11:50              | 11:58     | 00:08    | TRIPPED ON FAULT   |
| 3479  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-KARADILAKKANAKERE        | ALUR SIDDAPURA_66<br>KANAGAL_66 | 11:50              | 11:58     | 00:08    | TRIPPED ON FAULT   |
| 3480  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-MADIKERI                 | NO STATIONS EFFECTED            | 11:50              | 11:58     | 00:08    | TRIPPED ON FAULT   |
| 3481  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-PERIYAPATNA-1            | NO STATIONS EFFECTED            | 11:47              | 11:55     | 00:08    | TRIPPED ON FAULT   |
| 3482  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-PERIYAPATNA-2- BYLUKUPPE | NO STATIONS EFFECTED            | 11:50              | 11:58     | 00:08    | TRIPPED ON FAULT   |
| 3483  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-SUNTIKOPPA               | NO STATIONS EFFECTED            | 11:50              | 11:58     | 00:08    | TRIPPED ON FAULT   |
| 3484  | 10-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                                        | MADHUVANAHALLI_220              | 10:56              | 17:20     | 06:24    | LINE CLEAR AVAILED |
| 3485  | 10-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANAHALLI-HEBBANI                     | NO STATIONS EFFECTED            | 12:04              | 13:05     | 01:00    | LINE CLEAR AVAILED |
| 3486  | 10-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-CLEAN SOLAR                          | NO STATIONS EFFECTED            | 13:30              | 14:22     | 00:52    | LINE CLEAR AVAILED |
| 3487  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | MUGUR_66                        | 10:00              | 17:36     | 07:36    | LINE CLEAR AVAILED |
| 3488  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | MUGUR_66                        | 10:00              | 17:36     | 07:36    | LINE CLEAR AVAILED |
| 3489  | 10-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-CR NAGARA-KOLLEGALA                  | MUGUR_66                        | 13:30              | 14:21     | 00:51    | LINE CLEAR AVAILED |
| 3490  | 10-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-THAYURU                              | THAYURU_66                      | 10:10              | 17:55     | 07:45    | LINE CLEAR AVAILED |
| 3491  | 10-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-JANNUR                               | JANNUR_66                       | 13:30              | 14:25     | 00:55    | LINE CLEAR AVAILED |
| 3492  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | SINDHUVALLI_66                  | 12:55              | 13:05     | 00:10    | TRIPPED ON FAULT   |
| 3493  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | TNARASIPURA_66                  | 10:00              | 18:00     | 08:00    | LINE CLEAR AVAILED |
| 3494  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | TNARASIPURA_66                  | 10:00              | 18:00     | 08:00    | LINE CLEAR AVAILED |
| 3495  | 10-Sep-24 | MYSORE  | 66      | LINE        | TN PURA-THAYURU                            | TNARASIPURA_66                  | 10:01              | 17:58     | 07:56    | LINE CLEAR AVAILED |
| 3496  | 10-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                                        | TUBINAKERE_220                  | 11:00              | 16:10     | 05:10    | LINE CLEAR AVAILED |
| 3497  | 10-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA                        | NO STATIONS EFFECTED            | 16:47 (10/09/2024) |           |          | LINE CLEAR AVAILED |
| 3498  | 10-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                                        | KADAKOLA_220                    | 3:51 (10/09/2024)  |           |          | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                           | Station_Name         | Open_At              | Closed_At             | Duration   | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------------|----------------------|----------------------|-----------------------|------------|--------------------|
| 3499  | 10-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR      | NO STATIONS EFFECTED | 17:40 (26/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3500  | 10-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA            | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3501  | 10-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA          | NO STATIONS EFFECTED | 8:23 (26/08/2024)    |                       |            | LINE CLEAR AVAILED |
| 3502  | 10-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLY            | NO STATIONS EFFECTED | 17:04 (24/08/2024)   | 17:27<br>(10/09/2024) | 408:23 Hrs | TRIPPED ON FAULT   |
| 3503  | 10-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI               | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3504  | 10-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | SFC SIVA_66          | 7:01<br>(15/02/2024) |                       |            | TRIPPED ON FAULT   |
| 3505  | 10-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE   | NO STATIONS EFFECTED | 14:42 (05/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3506  | 10-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2            | NO STATIONS EFFECTED | 12:54 (04/09/2024)   |                       |            | TRIPPED ON FAULT   |
| 3507  | 11-Sep-24 | MYSORE  | 66      | LINE        | BG PURA-CHANDALLI              | CHANDALLI_66         | 15:05                | 17:21                 | 02:16      | LINE CLEAR AVAILED |
| 3508  | 11-Sep-24 | MYSORE  | 66      | LINE        | CHANDALLI-TALAKADU             | THALAKADU_66         | 15:10                | 17:25                 | 02:15      | LINE CLEAR AVAILED |
| 3509  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | CHANDALLI_66         | 10:35                | 17:30                 | 06:55      | LINE CLEAR AVAILED |
| 3510  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                            | CHANDALLI_66         | 10:35                | 17:30                 | 06:55      | LINE CLEAR AVAILED |
| 3511  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | HANNUR_66            | 11:02                | 14:13                 | 03:11      | LINE CLEAR AVAILED |
| 3512  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | HANNUR_66            | 14:26                | 14:40                 | 00:13      | LINE CLEAR AVAILED |
| 3513  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                            | HANNUR_66            | 14:15                | 17:15                 | 03:00      | LINE CLEAR AVAILED |
| 3514  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                            | HANNUR_66            | 17:15                | 17:32                 | 00:17      | TRIPPED ON FAULT   |
| 3515  | 11-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR-BANNIKUPPE              | BANNIKUPPE_66        | 10:30                | 16:19                 | 05:49      | LINE CLEAR AVAILED |
| 3516  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                            | HUNSUR_66            | 16:06                | 21:00                 | 04:53      | LINE CLEAR AVAILED |
| 3517  | 11-Sep-24 | MYSORE  | 66      | LINE        | JYOTHINAGARA-FTS 1             | NO STATIONS EFFECTED | 01:39                | 01:49                 | 00:10      | TRIPPED ON FAULT   |
| 3518  | 11-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-VAJMANGALA 2          | NO STATIONS EFFECTED | 16:35                | 17:50                 | 01:15      | TRIPPED ON FAULT   |
| 3519  | 11-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-GOLUR                 | GOLUR_66             | 16:45                | 16:51                 | 00:06      | TRIPPED ON FAULT   |
| 3520  | 11-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-KOPPA                 | NO STATIONS EFFECTED | 17:22                | 17:33                 | 00:11      | TRIPPED ON FAULT   |
| 3521  | 11-Sep-24 | MYSORE  | 66      | LINE        | KOLLEGALA-PARINAMIPURA         | PARINAMIPURA_66      | 10:28                | 18:04                 | 07:36      | LINE CLEAR AVAILED |
| 3522  | 11-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANAHALLI-HEBBANI         | NO STATIONS EFFECTED | 12:21                | 13:45                 | 01:23      | LINE CLEAR AVAILED |
| 3523  | 11-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA-TUBINKERE          | NO STATIONS EFFECTED | 10:50                | 14:08                 | 03:18      | LINE CLEAR AVAILED |
| 3524  | 11-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA-HANGODU-PONNAMPETE | NO STATIONS EFFECTED | 04:01                | 04:07                 | 00:06      | TRIPPED ON FAULT   |
| 3525  | 11-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA-HANGODU-PONNAMPETE | PONNAMPET_66         | 09:42                | 17:10                 | 07:28      | LINE CLEAR AVAILED |
| 3526  | 11-Sep-24 | MYSORE  | 66      | LINE        | PONNAMPETE-VIRAJPET            | VIRAJPETE_66         | 10:12                | 17:10                 | 06:58      | LINE CLEAR AVAILED |
| 3527  | 11-Sep-24 | MYSORE  | 66      | LINE        | PONNAMPETE-SRIMANGALA          | SRIMANGALA_66        | 10:10                | 17:10                 | 07:00      | LINE CLEAR AVAILED |
| 3528  | 11-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-HEBBANI              | NO STATIONS EFFECTED | 12:07                | 13:32                 | 01:24      | LINE CLEAR AVAILED |
| 3529  | 11-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR         | HETHUR_66YESSLUR_66  | 12:14                | 12:21                 | 00:07      | LINE CLEAR AVAILED |
| 3530  | 11-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR         | HETHUR_66YESSLUR_66  | 16:27                | 16:35                 | 00:08      | LINE CLEAR AVAILED |
| 3531  | 11-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-HEBBANI 8             | NO STATIONS EFFECTED | 12:15                | 13:40                 | 01:25      | LINE CLEAR AVAILED |
| 3532  | 11-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-HEBBANI 9             | NO STATIONS EFFECTED | 12:15                | 13:40                 | 01:25      | LINE CLEAR AVAILED |
| 3533  | 11-Sep-24 | MYSORE  | 66      | LINE        | TALAKADU-ADANI                 | NO STATIONS EFFECTED | 10:15                | 18:12                 | 07:57      | LINE CLEAR AVAILED |
| 3534  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | THALAKADU_66         | 10:15                | 17:30                 | 07:15      | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name         | Open_At              | Closed_At             | Duration   | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|----------------------|----------------------|-----------------------|------------|--------------------|
| 3535  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | THALAKADU_66         | 10:15                | 17:30                 | 07:15      | LINE CLEAR AVAILED |
| 3536  | 11-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | TUBINAKERE_220       | 11:10                | 13:44                 | 02:34      | LINE CLEAR AVAILED |
| 3537  | 11-Sep-24 | MYSORE  | 66      | LINE        | 220KV NAGAMANGALA-KASALGERE  | KESLAGERE_66         | 17:22                | 17:30                 | 00:08      | TRIPPED ON FAULT   |
| 3538  | 11-Sep-24 | MYSORE  | 66      | LINE        | LOKKANAHALLI-PG PALYA        | PGPALYA_66           | 18:20                | 18:25                 | 00:05      | TRIPPED ON FAULT   |
| 3539  | 11-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-TK HALLI             | NO STATIONS EFFECTED | 18:29                | 18:40                 | 00:11      | TRIPPED ON FAULT   |
| 3540  | 11-Sep-24 | MYSORE  | 66      | LINE        | HOSUR GATE-HUNSUR-BANNIKUPPE | BANNIKUPPE_66        | 10:30                | 16:00                 | 05:30      | LINE CLEAR AVAILED |
| 3541  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HARADANAHALLI_66     | 11:15                | 17:00                 | 05:45      | LINE CLEAR AVAILED |
| 3542  | 11-Sep-24 | MYSORE  | 66      | LINE        | HARADANAHALLI-SOMANAHALLI    | HARADANAHALLI_66     | 11:15                | 11:35                 | 00:20      | LINE CLEAR AVAILED |
| 3543  | 11-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED | 16:47 (10/09/2024)   |                       |            | LINE CLEAR AVAILED |
| 3544  | 11-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220         | 3:51(10/09/2024)     | 16:10<br>(11/09/2024) | 36:18 HRs  | LINE CLEAR AVAILED |
| 3545  | 11-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR    | NO STATIONS EFFECTED | 17:40 (26/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3546  | 11-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |                       |            | LINE CLEAR AVAILED |
| 3547  | 11-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED | 8:23 (26/08/2024)    |                       |            | LINE CLEAR AVAILED |
| 3548  | 11-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3549  | 11-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66          | 7:01<br>(15/02/2024) |                       |            | TRIPPED ON FAULT   |
| 3550  | 11-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED | 14:42 (05/08/2024)   |                       |            | LINE CLEAR AVAILED |
| 3551  | 11-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA2          | NO STATIONS EFFECTED | 12:54 (04/09/2024)   | 8:54<br>(11/09/2024)  | 115:59 HRs | TRIPPED ON FAULT   |
| 3552  | 12-Sep-24 | MYSORE  | 66      | LINE        | BG PURA-HEBBANI              | NO STATIONS EFFECTED | 10:14                | 15:24                 | 05:10      | LINE CLEAR AVAILED |
| 3553  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | DODDINADUVADI_66     | 04:20                | 06:30                 | 02:09      | LINE CLEAR AVAILED |
| 3554  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | DODDINADUVADI_66     | 03:09                | 03:24                 | 00:14      | TRIPPED ON FAULT   |
| 3555  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | DODDINADUVADI_66     | 04:20                | 06:32                 | 02:11      | LINE CLEAR AVAILED |
| 3556  | 12-Sep-24 | MYSORE  | 66      | LINE        | FTS-BANNIMANTAPA2            | NO STATIONS EFFECTED | 16:57                | 17:13                 | 00:15      | TRIPPED ON FAULT   |
| 3557  | 12-Sep-24 | MYSORE  | 66      | LINE        | FTS-VIJAYANAGARA             | NO STATIONS EFFECTED | 16:57                | 17:14                 | 00:16      | TRIPPED ON FAULT   |
| 3558  | 12-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-CR NAGARA 2       | TERAKANAMBE_66       | 17:23                | 17:34                 | 00:10      | TRIPPED ON FAULT   |
| 3559  | 12-Sep-24 | MYSORE  | 66      | LINE        | HD KOTE-TARAKA               | ANTHARSANTHE_66      | 13:33                | 14:04                 | 00:30      | LINE CLEAR AVAILED |
| 3560  | 12-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA-JAIPURA            | JAIPUR_66            | 09:43                | 14:08                 | 04:24      | LINE CLEAR AVAILED |
| 3561  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | JAIPUR_66            | 10:07                | 18:49                 | 08:42      | LINE CLEAR AVAILED |
| 3562  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | JAIPUR_66            | 10:01                | 18:53                 | 08:51      | LINE CLEAR AVAILED |
| 3563  | 12-Sep-24 | MYSORE  | 66      | LINE        | JAIPURA-KADAKOLA             | JAIPUR_66            | 10:07                | 14:05                 | 03:58      | LINE CLEAR AVAILED |
| 3564  | 12-Sep-24 | MYSORE  | 66      | LINE        | JAIPURA-KADAKOLA             | JAIPUR_66            | 15:06                | 18:00                 | 02:54      | LINE CLEAR AVAILED |
| 3565  | 12-Sep-24 | MYSORE  | 66      | LINE        | JAIPURA-HAMPAPURA            | NO STATIONS EFFECTED | 14:48                | 18:00                 | 03:12      | LINE CLEAR AVAILED |
| 3566  | 12-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DK MAIDANA          | NO STATIONS EFFECTED | 13:15                | 14:20                 | 01:05      | LINE CLEAR AVAILED |
| 3567  | 12-Sep-24 | MYSORE  | 66      | LINE        | KOLKARANA DODDI-KM DODDI     | KOLKARANADODDI_66    | 09:22                | 15:04                 | 05:42      | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name                     | Open_At            | Closed_At          | Duration   | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|----------------------------------|--------------------|--------------------|------------|--------------------|
| 3568  | 12-Sep-24 | MYSORE  | 66      | LINE        | KOLKARANA DODDI-KIADB MANDYA | NO STATIONS EFFECTED             | 09:22              | 15:04              | 05:42      | LINE CLEAR AVAILED |
| 3569  | 12-Sep-24 | MYSORE  | 220     | LINE        | MADHUVANAHALLI-TK HALLI1     | NO STATIONS EFFECTED             | 06:28              | 07:52              | 01:24      | LINE CLEAR AVAILED |
| 3570  | 12-Sep-24 | MYSORE  | 220     | LINE        | MADHUVANAHALLI-TK HALLI 2    | NO STATIONS EFFECTED             | 06:28              | 07:52              | 01:24      | LINE CLEAR AVAILED |
| 3571  | 12-Sep-24 | MYSORE  | 66      | LINE        | RK NAGARA-MANTAGALLI         | NO STATIONS EFFECTED             | 11:05              | 14:26              | 03:20      | LINE CLEAR AVAILED |
| 3572  | 12-Sep-24 | MYSORE  | 66      | LINE        | TUMBLA-HEBBANI               | THUMBLA_66                       | 10:15              | 17:03              | 06:48      | LINE CLEAR AVAILED |
| 3573  | 12-Sep-24 | MYSORE  | 66      | LINE        | TUMBLA-VYSARAJAPURA          | VYASRAJUPURA_66                  | 10:15              | 17:03              | 06:48      | LINE CLEAR AVAILED |
| 3574  | 12-Sep-24 | MYSORE  | 66      | LINE        | HONNALLI-ATTIGULIPURA        | ATTIGULIPURA_66                  | 10:00              | 15:45              | 05:45      | LINE CLEAR AVAILED |
| 3575  | 12-Sep-24 | MYSORE  | 66      | LINE        | HONNALLI-ARAKALWADI          | ARKALVADI_66                     | 10:00              | 16:30              | 06:30      | LINE CLEAR AVAILED |
| 3576  | 12-Sep-24 | MYSORE  | 66      | LINE        | HONNALLI-CR NAGARA           | HONNALY_MYS_66                   | 10:00              | 15:15              | 05:15      | LINE CLEAR AVAILED |
| 3577  | 12-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED             | 11:33 (12/09/2024) |                    |            | LINE CLEAR AVAILED |
| 3578  | 12-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED             | 16:47 (10/09/2024) |                    |            | LINE CLEAR AVAILED |
| 3579  | 12-Sep-24 | MYSORE  | 66      | LINE        | HAMPAPURA(K)-SANTHESARGUR    | NO STATIONS EFFECTED             | 17:40 (26/08/2024) | 14:46 (12/09/2024) | 405:06 Hrs | LINE CLEAR AVAILED |
| 3580  | 12-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED             | 7:53 (26/08/2024)  |                    |            | LINE CLEAR AVAILED |
| 3581  | 12-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED             | 8:23 (26/08/2024)  |                    |            | LINE CLEAR AVAILED |
| 3582  | 12-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED             | 11:54 (09/08/2024) |                    |            | LINE CLEAR AVAILED |
| 3583  | 12-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                      | 7:01 (15/02/2024)  |                    |            | TRIPPED ON FAULT   |
| 3584  | 12-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED             | 14:42 (05/08/2024) |                    |            | LINE CLEAR AVAILED |
| 3585  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | ARAKERE_66                       | 10:48              | 18:22              | 07:34      | LINE CLEAR AVAILED |
| 3586  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | ARAKERE_66                       | 10:48              | 18:22              | 07:34      | LINE CLEAR AVAILED |
| 3587  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BANANGADI_66                     | 11:25              | 14:20              | 02:55      | LINE CLEAR AVAILED |
| 3588  | 13-Sep-24 | MYSORE  | 66      | LINE        | BEGUR -B MATTGERE            | B MATKERE_66                     | 15:35              | 17:45              | 02:10      | LINE CLEAR AVAILED |
| 3589  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BOOKANAKERE_66                   | 12:26              | 13:30              | 01:04      | LINE CLEAR AVAILED |
| 3590  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | BOOKANAKERE_66                   | 12:26              | 13:30              | 01:04      | LINE CLEAR AVAILED |
| 3591  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | CHAMLAPURA_66                    | 10:00              | 17:00              | 07:00      | LINE CLEAR AVAILED |
| 3592  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | CHAMLAPURA_66                    | 10:00              | 17:00              | 07:00      | LINE CLEAR AVAILED |
| 3593  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | CHUNCHUNKATTE_66                 | 11:55              | 12:00              | 00:05      | TRIPPED ON FAULT   |
| 3594  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | CHINAKURALI_66                   | 11:20              | 11:40              | 00:20      | LINE CLEAR AVAILED |
| 3595  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | GAMANAHALLY_66                   | 10:00              | 17:50              | 07:50      | LINE CLEAR AVAILED |
| 3596  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | GAMANAHALLY_66                   | 10:00              | 17:50              | 07:50      | LINE CLEAR AVAILED |
| 3597  | 13-Sep-24 | MYSORE  | 66      | LINE        | GAMANAHALLI-CHAMALAPURA      | GAMANAHALLI STATION INTERRUPTED. | 11:30              | 14:10              | 02:40      | LINE CLEAR AVAILED |
| 3598  | 13-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-BASTIPURA-1         | NO STATIONS EFFECTED             | 07:14              | 10:54              | 03:39      | LINE CLEAR AVAILED |
| 3599  | 13-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-GOLLUR              | NO STATIONS EFFECTED             | 13:26              | 15:47              | 02:21      | LINE CLEAR AVAILED |
| 3600  | 13-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAIPURA             | NO STATIONS EFFECTED             | 16:05              | 18:46              | 02:40      | LINE CLEAR AVAILED |
| 3601  | 13-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MANDAKALLI          | NO STATIONS EFFECTED             | 10:58              | 16:16              | 05:18      | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name              | Open_At            | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|---------------------------|--------------------|-----------|----------|--------------------|
| 3602  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | MADHUVANAHALLI_220        | 16:12              | 16:24     | 00:12    | LINE CLEAR AVAILED |
| 3603  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | MALAVALLI_66              | 15:34              | 17:08     | 01:33    | LINE CLEAR AVAILED |
| 3604  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | MEGALAPURA_66             | 10:03              | 17:35     | 07:31    | LINE CLEAR AVAILED |
| 3605  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | MEGALAPURA_66             | 10:05              | 17:34     | 07:29    | LINE CLEAR AVAILED |
| 3606  | 13-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA      | MEGALAPURA_66             | 10:19              | 17:33     | 07:14    | LINE CLEAR AVAILED |
| 3607  | 13-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-THAYURU                | TNARASIPURA_66 THAYURU_66 | 06:08              | 06:13     | 00:05    | TRIPPED ON FAULT   |
| 3608  | 13-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-KESALAGERE   | NO STATIONS EFFECTED      | 12:34              | 13:21     | 00:47    | LINE CLEAR AVAILED |
| 3609  | 13-Sep-24 | MYSORE  | 66      | LINE        | SANTHE SARAGUR-B MATTGERE    | B MATKERE_66              | 15:23              | 17:36     | 02:13    | LINE CLEAR AVAILED |
| 3610  | 13-Sep-24 | MYSORE  | 66      | LINE        | SANTHEMARAHALLI-D.R PETE     | NO STATIONS EFFECTED      | 10:32              | 10:41     | 00:09    | TRIPPED ON FAULT   |
| 3611  | 13-Sep-24 | MYSORE  | 66      | LINE        | TARIPURA-TUBINAKERE          | TARIPURA_66               | 11:10              | 12:25     | 01:15    | LINE CLEAR AVAILED |
| 3612  | 13-Sep-24 | MYSORE  | 66      | LINE        | TARIPURA-TUBINAKERE          | TARIPURA_66               | 12:40              | 12:45     | 00:05    | LINE CLEAR AVAILED |
| 3613  | 13-Sep-24 | MYSORE  | 66      | LINE        | THUMBLA-HEBBANI-MEGHALAPURA  | MEGALAPURA_66             | 13:20              | 16:03     | 02:43    | LINE CLEAR AVAILED |
| 3614  | 13-Sep-24 | MYSORE  | 66      | LINE        | TUBINAKERE-MANDYA M4         | NO STATIONS EFFECTED      | 12:42              | 12:44     | 00:01    | LINE CLEAR AVAILED |
| 3615  | 13-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220              | 12:06 (13/09/2024) |           |          | TRIPPED ON FAULT   |
| 3616  | 13-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED      | 11:33 (12/09/2024) |           |          | LINE CLEAR AVAILED |
| 3617  | 13-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED      | 16:47 (10/09/2024) |           |          | LINE CLEAR AVAILED |
| 3618  | 13-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED      | 7:53 (26/08/2024)  |           |          | LINE CLEAR AVAILED |
| 3619  | 13-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED      | 8:23 (26/08/2024)  |           |          | LINE CLEAR AVAILED |
| 3620  | 13-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED      | 11:54 (09/08/2024) |           |          | LINE CLEAR AVAILED |
| 3621  | 13-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66               | 7:01 (15/02/2024)  |           |          | TRIPPED ON FAULT   |
| 3622  | 13-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED      | 14:42 (05/08/2024) |           |          | LINE CLEAR AVAILED |
| 3623  | 14-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-CHANDAKAWADI       | CHANDAKAVADI_66           | 09:49              | 18:40     | 08:50    | LINE CLEAR AVAILED |
| 3624  | 14-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-DR PETE 1          | DODDARAYAPET_66           | 10:09              | 16:54     | 06:44    | LINE CLEAR AVAILED |
| 3625  | 14-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-DR PETE 2          | NO STATIONS EFFECTED      | 10:09              | 16:54     | 06:45    | LINE CLEAR AVAILED |
| 3626  | 14-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HARVEY_66                 | 15:08              | 15:13     | 00:04    | TRIPPED ON FAULT   |
| 3627  | 14-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HARVEY_66                 | 14:56              | 15:08     | 00:11    | TRIPPED ON FAULT   |
| 3628  | 14-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-SANTHEMARALLI        | SANTHEMARAHALLI_66        | 12:41              | 15:05     | 02:24    | LINE CLEAR AVAILED |
| 3629  | 14-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KUNTHUR_66                | 10:00              | 15:50     | 05:50    | LINE CLEAR AVAILED |
| 3630  | 14-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | KUNTHUR_66                | 10:00              | 15:50     | 05:50    | LINE CLEAR AVAILED |
| 3631  | 14-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-MADHUVANAHALLI       | KUNTHUR_66                | 12:30              | 15:00     | 02:30    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name                                     | Open_At              | Closed_At             | Duration                   | REMARKS           |
|-------|-----------|---------|---------|-------------|------------------------------|--------------------------------------------------|----------------------|-----------------------|----------------------------|-------------------|
| 3632  | 14-Sep-24 | MYSORE  | 66      | LINE        | SANTHEMARALLI-DR PETE        | SANTHEMARAHALLI_66                               | 10:02                | 16:52                 | 06:50                      | LINE CLEAR AVAIED |
| 3633  | 14-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-JANNUR                 | JANNUR_66                                        | 10:00                | 16:40                 | 06:40                      | LINE CLEAR AVAIED |
| 3634  | 14-Sep-24 | MYSORE  | 66      | LINE        | MAMBALLI-YELANDUR            | YELANDUR_66                                      | 11:01                | 18:00                 | 06:58                      | LINE CLEAR AVAIED |
| 3635  | 14-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220                                     | 12:06 (13/09/2024)   |                       |                            | TRIPPED ON FAULT  |
| 3636  | 14-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED                             | 11:33 (12/09/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3637  | 14-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED                             | 16:47 (10/09/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3638  | 14-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED                             | 7:53<br>(26/08/2024) |                       |                            | LINE CLEAR AVAIED |
| 3639  | 14-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED                             | 8:23 (26/08/2024)    |                       |                            | LINE CLEAR AVAIED |
| 3640  | 14-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED                             | 11:54 (09/08/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3641  | 14-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                                      | 7:01<br>(15/02/2024) |                       |                            | TRIPPED ON FAULT  |
| 3642  | 14-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA-MUTHINAMULSOGE | NO STATIONS EFFECTED                             | 14:42 (05/08/2024)   | 11:53<br>(14/09/2024) | 933:11                     | LINE CLEAR AVAIED |
| 3643  | 15-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220                                     | 12:06 (13/09/2024)   |                       |                            | TRIPPED ON FAULT  |
| 3644  | 15-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED                             | 11:33 (12/09/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3645  | 15-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED                             | 16:47 (10/09/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3646  | 15-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED                             | 7:53<br>(26/08/2024) |                       |                            | LINE CLEAR AVAIED |
| 3647  | 15-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA        | NO STATIONS EFFECTED                             | 8:23 (26/08/2024)    | 11:33                 | ,411:09:03<br>(12/09/2024) | LINE CLEAR AVAIED |
| 3648  | 15-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED                             | 11:54 (09/08/2024)   |                       |                            | LINE CLEAR AVAIED |
| 3649  | 15-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                                      | 7:01<br>(15/02/2024) |                       |                            | TRIPPED ON FAULT  |
| 3650  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BGPURA_66                                        | 10:21                | 10:55                 | 00:33                      | LINE CLEAR AVAIED |
| 3651  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BGPURA_66                                        | 14:00                | 14:26                 | 00:26                      | TRIPPED ON FAULT  |
| 3652  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BGPURA_66                                        | 14:37                | 14:47                 | 00:09                      | TRIPPED ON FAULT  |
| 3653  | 16-Sep-24 | MYSORE  | 66      | LINE        | FTS-VIJAYANAGAR              | NO STATIONS EFFECTED                             | 10:39                | 14:35                 | 03:56                      | LINE CLEAR AVAIED |
| 3654  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HDKOTE_66                                        | 09:58                | 10:20                 | 00:21                      | TRIPPED ON FAULT  |
| 3655  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HOTAGALLY_66                                     | 10:01                | 10:06                 | 00:05                      | LINE CLEAR AVAIED |
| 3656  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | HOTAGALLY_66                                     | 10:01                | 10:05                 | 00:03                      | LINE CLEAR AVAIED |
| 3657  | 16-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-KOLLEGALA          | NO STATIONS EFFECTED                             | 12:09                | 12:18                 | 00:08                      | TRIPPED ON FAULT  |
| 3658  | 16-Sep-24 | MYSORE  | 66      | LINE        | THALAKADU-CHANDALLI          | NO STATIONS EFFECTED                             | 05:35                | 05:47                 | 00:12                      | TRIPPED ON FAULT  |
| 3659  | 16-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-VAJAMANGALA          | THUMBLA_66<br>VYASARAJAPURA_66<br>GARGESHWARI_66 | 16:29                | 16:37                 | 00:08                      | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                            | Station_Name         | Open_At              | Closed_At | Duration | REMARKS           |
|-------|-----------|---------|---------|-------------|---------------------------------|----------------------|----------------------|-----------|----------|-------------------|
| 3660  | 16-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-T K HALLI 1             | NO STATIONS EFFECTED | 14:35                | 17:09     | 02:34    | LINE CLEAR AVAIED |
| 3661  | 16-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-T K HALLI 2             | NO STATIONS EFFECTED | 14:35                | 17:09     | 02:34    | LINE CLEAR AVAIED |
| 3662  | 16-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                             | KADAKOLA_220         | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT  |
| 3663  | 16-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH           | NO STATIONS EFFECTED | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAIED |
| 3664  | 16-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA             | NO STATIONS EFFECTED | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAIED |
| 3665  | 16-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA             | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAIED |
| 3666  | 16-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAIED |
| 3667  | 16-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | SFC SIVA_66          | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT  |
| 3668  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | BGPURA_66            | 14:03                | 14:08     | 00:05    | TRIPPED ON FAULT  |
| 3669  | 17-Sep-24 | MYSORE  | 66      | LINE        | DK MAIDANA-JYOTHINAGARA         | DKMAIDANA_66         | 10:03                | 17:46     | 07:43    | LINE CLEAR AVAIED |
| 3670  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | ELAVALA_66           | 10:22                | 10:57     | 00:34    | LINE CLEAR AVAIED |
| 3671  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | ELAVALA_66           | 10:55                | 11:45     | 00:50    | LINE CLEAR AVAIED |
| 3672  | 17-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BARC1                | NO STATIONS EFFECTED | 09:40                | 13:20     | 03:39    | LINE CLEAR AVAIED |
| 3673  | 17-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-KAGGERE<br>HAMPAPURA | NO STATIONS EFFECTED | 12:00                | 13:15     | 01:15    | LINE CLEAR AVAIED |
| 3674  | 17-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DKMAIDANA              | DKMAIDANA_66         | 10:01                | 17:41     | 07:39    | LINE CLEAR AVAIED |
| 3675  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | KIKKERI_66           | 11:25                | 14:06     | 02:40    | LINE CLEAR AVAIED |
| 3676  | 17-Sep-24 | MYSORE  | 66      | LINE        | KOPPA-KASALGERE                 | NO STATIONS EFFECTED | 06:58                | 13:25     | 06:27    | TRIPPED ON FAULT  |
| 3677  | 17-Sep-24 | MYSORE  | 66      | LINE        | KOPPA-NAGAMANGALA 220           | NO STATIONS EFFECTED | 11:32                | 13:25     | 01:53    | LINE CLEAR AVAIED |
| 3678  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | MALAVALLI_66         | 16:19                | 17:15     | 00:55    | LINE CLEAR AVAIED |
| 3679  | 17-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA-KAMPLAPURA          | KAMPLAPURA_66        | 10:25                | 15:54     | 05:29    | LINE CLEAR AVAIED |
| 3680  | 17-Sep-24 | MYSORE  | 66      | LINE        | RK NAGARA-MANDAKALLI            | MANDAKALLI_66        | 10:04                | 16:05     | 06:01    | LINE CLEAR AVAIED |
| 3681  | 17-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR          | YESSLUR_66HETHUR_66  | 13:25                | 13:31     | 00:06    | LINE CLEAR AVAIED |
| 3682  | 17-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR          | YESSLUR_66HETHUR_66  | 16:25                | 16:35     | 00:10    | LINE CLEAR AVAIED |
| 3683  | 17-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PGL                    | NO STATIONS EFFECTED | 06:15                | 06:40     | 00:24    | LINE CLEAR AVAIED |
| 3684  | 17-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA -BANNUR              | BANNUR_66            | 10:23                | 18:06     | 07:43    | LINE CLEAR AVAIED |
| 3685  | 17-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA -TK HALLI            | NO STATIONS EFFECTED | 10:13                | 14:22     | 04:09    | LINE CLEAR AVAIED |
| 3686  | 17-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR 220-KAMPLAPURA           | KAMPLAPURA_66        | 10:32                | 15:37     | 05:05    | LINE CLEAR AVAIED |
| 3687  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | GUNDULPET_66         | 08:55                | 10:05     | 01:10    | LINE CLEAR AVAIED |
| 3688  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | GUNDULPET_66         | 08:30                | 10:15     | 01:45    | LINE CLEAR AVAIED |
| 3689  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                             | GUNDULPET_66         | 08:30                | 18:25     | 09:55    | LINE CLEAR AVAIED |
| 3690  | 17-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                             | KADAKOLA_220         | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT  |
| 3691  | 17-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH           | NO STATIONS EFFECTED | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAIED |
| 3692  | 17-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA             | NO STATIONS EFFECTED | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAIED |
| 3693  | 17-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA             | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name         | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|----------------------|----------------------|-----------|----------|--------------------|
| 3694  | 17-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 3695  | 17-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66          | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 3696  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BGPURA_66            | 14:42                | 14:47     | 00:04    | TRIPPED ON FAULT   |
| 3697  | 18-Sep-24 | MYSORE  | 66      | LINE        | HANAGODU-HUNSURU             | HANAGODU_66          | 10:04                | 19:00     | 08:55    | LINE CLEAR AVAILED |
| 3698  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HANGLA_66            | 19:05                | 19:10     | 00:05    | TRIPPED ON FAULT   |
| 3699  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | JAIPUR_66            | 10:32                | 10:37     | 00:05    | TRIPPED ON FAULT   |
| 3700  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | JAIPUR_66            | 13:19                | 13:24     | 00:05    | TRIPPED ON FAULT   |
| 3701  | 18-Sep-24 | MYSORE  | 66      | LINE        | KOLLEG-CHNAGARA              | NO STATIONS EFFECTED | 11:00                | 11:20     | 00:20    | LINE CLEAR AVAILED |
| 3702  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | MALAVALLI_66         | 10:02                | 12:20     | 02:17    | LINE CLEAR AVAILED |
| 3703  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | MALAVALLI_66         | 11:56                | 14:08     | 02:12    | LINE CLEAR AVAILED |
| 3704  | 18-Sep-24 | MYSORE  | 66      | LINE        | ADDIHALLI                    | NO STATIONS EFFECTED | 10:23                | 18:30     | 08:07    | TRIPPED ON FAULT   |
| 3705  | 18-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-BG<br>NAGARA | NO STATIONS EFFECTED | 17:16                | 18:24     | 01:08    | LINE CLEAR AVAILED |
| 3706  | 18-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-VC FARM      | NO STATIONS EFFECTED | 15:45                | 18:04     | 02:19    | LINE CLEAR AVAILED |
| 3707  | 18-Sep-24 | MYSORE  | 66      | LINE        | HARADANAHALLI                | HARADANAHALLI_66     | 17:04                | 18:10     | 01:06    | LINE CLEAR AVAILED |
| 3708  | 18-Sep-24 | MYSORE  | 66      | LINE        | PERIAPATNA-KUSHALNAGARA 1    | PERIYAPATNA_66       | 09:55                | 17:10     | 07:15    | LINE CLEAR AVAILED |
| 3709  | 18-Sep-24 | MYSORE  | 66      | LINE        | PERIAPATNA-KUSHALNAGARA 2    | PERIYAPATNA_66       | 10:00                | 17:10     | 07:10    | LINE CLEAR AVAILED |
| 3710  | 18-Sep-24 | MYSORE  | 66      | LINE        | PERIAPATNA-KAMPLAPURA        | PERIYAPATNA_66       | 10:45                | 15:20     | 04:35    | LINE CLEAR AVAILED |
| 3711  | 18-Sep-24 | MYSORE  | 66      | LINE        | PERIYAPATNA                  | NO STATIONS EFFECTED | 09:49                | 15:25     | 05:36    | LINE CLEAR AVAILED |
| 3712  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | YELANDUR_66          | 14:14                | 14:20     | 00:05    | LINE CLEAR AVAILED |
| 3713  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | YELANDUR_66          | 14:03                | 14:13     | 00:09    | LINE CLEAR AVAILED |
| 3714  | 18-Sep-24 | MYSORE  | 220     | LINE        | TK HALLI 2                   | NO STATIONS EFFECTED | 09:45                | 11:29     | 01:44    | LINE CLEAR AVAILED |
| 3715  | 18-Sep-24 | MYSORE  | 220     | LINE        | TK HALLI 1                   | NO STATIONS EFFECTED | 11:31                | 14:00     | 02:29    | LINE CLEAR AVAILED |
| 3716  | 18-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | NO STATIONS EFFECTED | 12:19                | 13:19     | 01:00    | LINE CLEAR AVAILED |
| 3717  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HAMPAPURA(K)_66      | 12:13                | 12:18     | 00:05    | TRIPPED ON FAULT   |
| 3718  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HAMPAPURA(K)_66      | 12:26                | 12:43     | 00:17    | TRIPPED ON FAULT   |
| 3719  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | HAMPAPURA(K)_66      | 14:43                | 15:00     | 00:17    | TRIPPED ON FAULT   |
| 3720  | 18-Sep-24 | MYSORE  | 66      | LINE        | LOKKANAHALLI                 | PGPALYA_66           | 10:15                | 16:00     | 05:45    | LINE CLEAR AVAILED |
| 3721  | 18-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220         | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 3722  | 18-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3723  | 18-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3724  | 18-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3725  | 18-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 3726  | 18-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66          | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 3727  | 19-Sep-24 | MYSORE  | 66      | LINE        | BANNIMANTAPA-FTS-1           | FTS_66               | 10:11                | 17:39     | 07:28    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                                                    | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------------------------|-----------------------------------------------------------------|---------|-----------|----------|--------------------|
| 3728  | 19-Sep-24 | MYSORE  | 66      | LINE        | BANNIMANTAPA-FTS-2                         | FTS_66                                                          | 10:11   | 17:39     | 07:28    | LINE CLEAR AVAILED |
| 3729  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | BYLUKUPPE_66                                                    | 11:30   | 17:50     | 06:20    | LINE CLEAR AVAILED |
| 3730  | 19-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-HARVEY                           | HARVEY STATION INTERRUPTED.                                     | 10:07   | 12:34     | 02:27    | LINE CLEAR AVAILED |
| 3731  | 19-Sep-24 | MYSORE  | 66      | LINE        | CHUNCHUNKATTE-GAVADGERE-GRAPHITE INDIA IPP | CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66                          | 11:45   | 12:00     | 00:15    | TRIPPED ON FAULT   |
| 3732  | 19-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-RAJEEV NAGARA                  | RAJEEVNAGARA_66                                                 | 09:49   | 18:04     | 08:14    | LINE CLEAR AVAILED |
| 3733  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | DEVANOORMYS_66                                                  | 10:06   | 17:15     | 07:09    | LINE CLEAR AVAILED |
| 3734  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | DEVANOORMYS_66                                                  | 10:06   | 17:15     | 07:09    | LINE CLEAR AVAILED |
| 3735  | 19-Sep-24 | MYSORE  | 66      | LINE        | FTS-BANNIMANTAPA-1                         | FTS_66                                                          | 10:05   | 17:39     | 07:33    | LINE CLEAR AVAILED |
| 3736  | 19-Sep-24 | MYSORE  | 66      | LINE        | FTS-BANNIMANTAPA-2                         | FTS_66                                                          | 10:03   | 17:39     | 07:35    | LINE CLEAR AVAILED |
| 3737  | 19-Sep-24 | MYSORE  | 66      | LINE        | FTS-JYOTHINAGARA                           | NO STATIONS EFFECTED                                            | 08:07   | 19:27     | 11:20    | LINE CLEAR AVAILED |
| 3738  | 19-Sep-24 | MYSORE  | 66      | LINE        | FTS-RAJEEV NAGARA                          | RAJEEVNAGARA_66                                                 | 10:05   | 18:13     | 08:07    | LINE CLEAR AVAILED |
| 3739  | 19-Sep-24 | MYSORE  | 66      | LINE        | FTS-VIJAYANAGARA                           | NO STATIONS EFFECTED                                            | 08:20   | 20:18     | 11:57    | LINE CLEAR AVAILED |
| 3740  | 19-Sep-24 | MYSORE  | 66      | LINE        | GAVADGERE-KR NAGARA                        | BILIKERE_66 KRNAGARA_66                                         | 11:45   | 12:10     | 00:25    | TRIPPED ON FAULT   |
| 3741  | 19-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-KABBAHALLI                      | KABHALLY_66                                                     | 16:14   | 17:49     | 01:34    | LINE CLEAR AVAILED |
| 3742  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | HANAGODU_66                                                     | 09:32   | 09:35     | 00:03    | TRIPPED ON FAULT   |
| 3743  | 19-Sep-24 | MYSORE  | 66      | LINE        | HARVEY-KABBAHALLI                          | KABHALLY_66                                                     | 16:05   | 17:45     | 01:39    | LINE CLEAR AVAILED |
| 3744  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | HARVEY_66                                                       | 10:02   | 18:16     | 08:13    | LINE CLEAR AVAILED |
| 3745  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | HARVEY_66                                                       | 10:02   | 18:16     | 08:13    | LINE CLEAR AVAILED |
| 3746  | 19-Sep-24 | MYSORE  | 66      | LINE        | HARVEY-BEGUR 220                           | NO STATIONS EFFECTED                                            | 12:45   | 15:15     | 02:30    | LINE CLEAR AVAILED |
| 3747  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | HUNSUR (THAMADANAHALLI)_220                                     | 10:19   | 10:29     | 00:10    | TRIPPED ON FAULT   |
| 3748  | 19-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAPA-1                  | NO STATIONS EFFECTED                                            | 12:25   | 13:11     | 00:46    | LINE CLEAR AVAILED |
| 3749  | 19-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAPA-2                  | NO STATIONS EFFECTED                                            | 10:24   | 12:24     | 01:59    | LINE CLEAR AVAILED |
| 3750  | 19-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-DATTAGALLI                      | DATTAGALLY_66                                                   | 10:12   | 13:01     | 02:49    | LINE CLEAR AVAILED |
| 3751  | 19-Sep-24 | MYSORE  | 66      | LINE        | KABBAHALLI-ATRIA SOLAR                     | NO STATIONS EFFECTED                                            | 15:55   | 17:55     | 02:00    | LINE CLEAR AVAILED |
| 3752  | 19-Sep-24 | MYSORE  | 66      | LINE        | KABBAHALLI-CLEAN SOLAR                     | NO STATIONS EFFECTED                                            | 15:55   | 18:00     | 02:05    | LINE CLEAR AVAILED |
| 3753  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | KABHALLY_66                                                     | 10:05   | 17:55     | 07:50    | LINE CLEAR AVAILED |
| 3754  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | KABHALLY_66                                                     | 10:05   | 17:55     | 07:50    | LINE CLEAR AVAILED |
| 3755  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | KADAKOLA_220                                                    | 19:33   | 19:39     | 00:05    | TRIPPED ON FAULT   |
| 3756  | 19-Sep-24 | MYSORE  | 66      | LINE        | KARYA-HEMMARGALA                           | DEVANOORNGUDU_66, GOLURU(GEEKALLI)_66, HEMMARGALA_66, SUTTUR_66 | 03:50   | 04:00     | 00:10    | TRIPPED ON FAULT   |
| 3757  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | KIADBMANDYA_66                                                  | 09:35   | 14:00     | 04:25    | LINE CLEAR AVAILED |
| 3758  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                        | KIADBMANDYA_66                                                  | 09:35   | 14:00     | 04:25    | LINE CLEAR AVAILED |
| 3759  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | KIKKERI_66                                                      | 11:00   | 14:45     | 03:45    | LINE CLEAR AVAILED |
| 3760  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                        | KUSHALANAGARA_66                                                | 11:51   | 12:07     | 00:16    | TRIPPED ON FAULT   |
| 3761  | 19-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                                        | KUSHALNAGARA_220                                                | 11:47   | 12:30     | 00:43    | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS | Line                                       | Station_Name                                                                                                                                                                                                                                                            | Open_At | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-----------|--------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|-----------|----------|--------------------|
| 3762  | 19-Sep-24 | MYSORE  | 220     | LINE      | KUSHALANAGARA 220-HUNSUR(THAMADANAHALLI)-1 | ALUR SIDDAPURA_66<br>BETTADHAPURA_66 BHERYA_66<br>BILIKERE_66 BYLUKUPPE_66<br>CHUNCHUNKATTE_66 KITTUR_66<br>KANAGAL_66 KRNAGARA_66<br>KUSHALNAGARA_220<br>MADIKERI_66 MIRLE_66<br>PERIYAPATNA_66 PONNAMPET_66<br>RAVANDUR_66 SRIMANGALA_66<br>SUNTIKOPPA_66 VIRAJPET_66 | 11:46   | 11:55     | 00:09    | TRIPPED ON FAULT   |
| 3763  | 19-Sep-24 | MYSORE  | 220     | LINE      | KUSHALANAGARA 220-HUNSUR(THAMADANAHALLI)-2 | ALUR SIDDAPURA_66<br>BETTADHAPURA_66 BHERYA_66<br>BILIKERE_66 BYLUKUPPE_66<br>CHUNCHUNKATTE_66 KITTUR_66<br>KANAGAL_66 KRNAGARA_66<br>KUSHALNAGARA_220<br>MADIKERI_66 MIRLE_66<br>PERIYAPATNA_66 PONNAMPET_66<br>RAVANDUR_66 SRIMANGALA_66<br>SUNTIKOPPA_66 VIRAJPET_66 | 11:46   | 11:55     | 00:09    | TRIPPED ON FAULT   |
| 3764  | 19-Sep-24 | MYSORE  | 220     | LINE      | KUSHALANAGARA 220-HARANGI(EDCL)            | NO STATIONS EFFECTED                                                                                                                                                                                                                                                    | 11:48   | 12:01     | 00:13    | LINE CLEAR AVAILED |
| 3765  | 19-Sep-24 | MYSORE  | 66      | LINE      | MADIKERI-SUNTIKOPPA                        | SUNTIKOPPA_66                                                                                                                                                                                                                                                           | 11:48   | 12:13     | 00:25    | LINE CLEAR AVAILED |
| 3766  | 19-Sep-24 | MYSORE  | 66      | LINE      | NANJANAGUDU-SINDUVALIPURA-AT&S             | NO STATIONS EFFECTED                                                                                                                                                                                                                                                    | 10:25   | 10:40     | 00:14    | TRIPPED ON FAULT   |
| 3767  | 19-Sep-24 | MYSORE  | 66      | LINE      | PERIYAPATNA-KAMPALAPURA                    | PERIYAPATNA_66                                                                                                                                                                                                                                                          | 11:44   | 11:54     | 00:10    | TRIPPED ON FAULT   |
| 3768  | 19-Sep-24 | MYSORE  | 66      | LINE      | PERIYAPATNA-KUSHALANAGARA-1                | MADIKERI_66 SUNTIKOPPA_66<br>PERIYAPATNA_66 PONNAMPET_66<br>SRIMANGALA_66 VIRAJPET_66                                                                                                                                                                                   | 11:45   | 12:35     | 00:50    | TRIPPED ON FAULT   |
| 3769  | 19-Sep-24 | MYSORE  | 66      | LINE      | PERIYAPATNA-KUSHALANAGARA-2                | MADIKERI_66 SUNTIKOPPA_66<br>PERIYAPATNA_66 PONNAMPET_66<br>SRIMANGALA_66 VIRAJPET_66                                                                                                                                                                                   | 11:45   | 12:25     | 00:40    | TRIPPED ON FAULT   |
| 3770  | 19-Sep-24 | MYSORE  | 66      | LINE      | RK NAGARA-DATTAGALLI                       | DATTAGALLY_66                                                                                                                                                                                                                                                           | 10:05   | 13:09     | 03:04    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                            | Station_Name                                                   | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|---------------------------------|----------------------------------------------------------------|----------------------|-----------|----------|--------------------|
| 3771  | 19-Sep-24 | MYSORE  | 66      | LINE        | SANTHE SARAGUR-HAMPAPURA(K)     | ANTHARSANTHE_66 HDKOTE_66 YERALLI HAND POST_66                 | 06:04                | 06:09     | 00:05    | TRIPPED ON FAULT   |
| 3772  | 19-Sep-24 | MYSORE  | 66      | LINE        | SUNTIKOPPA-KUSHALANAGARA        | NO STATIONS EFFECTED                                           | 10:45                | 12:29     | 01:44    | LINE CLEAR AVAILED |
| 3773  | 19-Sep-24 | MYSORE  | 66      | LINE        | VAJAMANGALA-KADAKOLA-2          | NO STATIONS EFFECTED                                           | 18:30                | 18:41     | 00:11    | TRIPPED ON FAULT   |
| 3774  | 19-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                             | KADAKOLA_220                                                   | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 3775  | 19-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH           | NO STATIONS EFFECTED                                           | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3776  | 19-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA             | NO STATIONS EFFECTED                                           | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3777  | 19-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA             | NO STATIONS EFFECTED                                           | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3778  | 19-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                | NO STATIONS EFFECTED                                           | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 3779  | 19-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | SFC SIVA_66                                                    | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 3780  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | BGPURA_66                                                      | 07:30                | 13:14     | 05:44    | LINE CLEAR AVAILED |
| 3781  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | BGPURA_66                                                      | 10:32                | 13:14     | 02:41    | LINE CLEAR AVAILED |
| 3782  | 20-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-CHANDAKAWADI          | CHANDAKAVADI_66                                                | 17:05                | 17:12     | 00:07    | TRIPPED ON FAULT   |
| 3783  | 20-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-GUNDLUPETE 2          | TERAKANAMBE_66                                                 | 09:13                | 17:35     | 08:22    | LINE CLEAR AVAILED |
| 3784  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | HANAGODU_66                                                    | 12:30                | 12:35     | 00:05    | TRIPPED ON FAULT   |
| 3785  | 20-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BARC 2               | NO STATIONS EFFECTED                                           | 10:25                | 14:10     | 03:45    | LINE CLEAR AVAILED |
| 3786  | 20-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-KHB                  | KHBCOLONY_66DMG_HALLI_66GO<br>LLANABIDU                        | 10:28                | 17:01     | 06:32    | LINE CLEAR AVAILED |
| 3787  | 20-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-KAGGERE<br>HAMPAPURA | KAGGEREHAMPAPURA_66                                            | 10:08                | 15:11     | 05:03    | LINE CLEAR AVAILED |
| 3788  | 20-Sep-24 | MYSORE  | 66      | LINE        | HEMMARGALA -KARYA               | HEMMARGALA_66KARYA_66DEVA<br>NOORNGUDU_66SUTTUR_66GOLU<br>R_66 | 11:12                | 11:37     | 00:25    | TRIPPED ON FAULT   |
| 3789  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | KIRUGAVALU_66                                                  | 09:52                | 12:28     | 02:35    | LINE CLEAR AVAILED |
| 3790  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | KMDODDI_66                                                     | 09:30                | 17:00     | 07:30    | LINE CLEAR AVAILED |
| 3791  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | KMDODDI_66                                                     | 09:30                | 14:35     | 05:05    | LINE CLEAR AVAILED |
| 3792  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | MANDYA_66                                                      | 13:00                | 14:45     | 01:44    | LINE CLEAR AVAILED |
| 3793  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | MANDYA_66                                                      | 10:50                | 12:53     | 02:03    | LINE CLEAR AVAILED |
| 3794  | 20-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA           | MYSORESOUTH_66                                                 | 09:52                | 18:36     | 08:44    | LINE CLEAR AVAILED |
| 3795  | 20-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR          | YESSLUR_66HETHUR_66                                            | 13:19                | 13:33     | 00:13    | LINE CLEAR AVAILED |
| 3796  | 20-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARSANTHE-YESSLUR          | YESSLUR_66HETHUR_66                                            | 14:58                | 15:05     | 00:07    | LINE CLEAR AVAILED |
| 3797  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                             | HALAGUR_66                                                     | 14:05                | 16:02     | 01:57    | LINE CLEAR AVAILED |
| 3798  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                             | AYRALLI_66                                                     | 15:05                | 15:10     | 00:05    | TRIPPED ON FAULT   |
| 3799  | 20-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                             | KADAKOLA_220                                                   | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 3800  | 20-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH           | NO STATIONS EFFECTED                                           | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                        | Station_Name               | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|-----------------------------|----------------------------|----------------------|-----------|----------|--------------------|
| 3801  | 20-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA         | NO STATIONS EFFECTED       | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3802  | 20-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA         | NO STATIONS EFFECTED       | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3803  | 20-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI            | NO STATIONS EFFECTED       | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 3804  | 20-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                         | SFC SIVA_66                | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 3805  | 20-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 1          | NO STATIONS EFFECTED       | 15:06 (20/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3806  | 20-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 2          | NO STATIONS EFFECTED       | 15:06 (20/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3807  | 21-Sep-24 | MYSORE  | 66      | LINE        | BEGUR 220-SINDHUVALIPURA    | SINDHUVALLI_66             | 16:15                | 17:16     | 01:01    | LINE CLEAR AVAILED |
| 3808  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | BANANGADI_66               | 08:10                | 08:30     | 00:20    | TRIPPED ON FAULT   |
| 3809  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                         | BOGADHI MANDYA_66          | 09:03                | 09:23     | 00:20    | TRIPPED ON FAULT   |
| 3810  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | CHIKKA_MANDYA_66           | 23:00                | 23:12     | 00:12    | TRIPPED ON FAULT   |
| 3811  | 21-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-NANJANGUDU         | NO STATIONS EFFECTED       | 12:24                | 12:41     | 00:17    | LINE CLEAR AVAILED |
| 3812  | 21-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-THANDYA            | NO STATIONS EFFECTED       | 12:24                | 12:41     | 00:17    | LINE CLEAR AVAILED |
| 3813  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | KMDODDI_66                 | 15:21                | 18:06     | 02:45    | LINE CLEAR AVAILED |
| 3814  | 21-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                         | KUSHALNAGARA_220           | 16:07                | 16:45     | 00:38    | LINE CLEAR AVAILED |
| 3815  | 21-Sep-24 | MYSORE  | 66      | LINE        | KUSHALANAGARA 220-MERCERA-1 | MADIKERI_66                | 09:50                | 16:24     | 06:34    | LINE CLEAR AVAILED |
| 3816  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                         | MADDUR_66                  | 09:37                | 17:09     | 07:32    | LINE CLEAR AVAILED |
| 3817  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | MADDUR_66                  | 09:37                | 17:03     | 07:26    | LINE CLEAR AVAILED |
| 3818  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                         | MADIKERI_66                | 10:00                | 16:20     | 06:20    | LINE CLEAR AVAILED |
| 3819  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | MADIKERI_66                | 10:00                | 16:20     | 06:20    | LINE CLEAR AVAILED |
| 3820  | 21-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-KOLLEGALA         | NO STATIONS EFFECTED       | 05:57                | 06:19     | 00:22    | TRIPPED ON FAULT   |
| 3821  | 21-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARASANTHE-YESSLUR     | NO STATIONS EFFECTED       | 10:39                | 10:45     | 00:06    | LINE CLEAR AVAILED |
| 3822  | 21-Sep-24 | MYSORE  | 66      | LINE        | SHANIVARASANTHE-YESSLUR     | NO STATIONS EFFECTED       | 16:25                | 16:33     | 00:08    | LINE CLEAR AVAILED |
| 3823  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                         | SINDHUVALLI_66             | 10:20                | 17:30     | 07:10    | LINE CLEAR AVAILED |
| 3824  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                         | SINDHUVALLI_66             | 10:20                | 17:30     | 07:10    | LINE CLEAR AVAILED |
| 3825  | 21-Sep-24 | MYSORE  | 66      | LINE        | SUNTIKOPPA-MADIKERI         | MADIKERI_66                | 10:11                | 16:20     | 06:09    | LINE CLEAR AVAILED |
| 3826  | 21-Sep-24 | MYSORE  | 66      | LINE        | TUBINAKERE-VC FARM          | NAGAMANGALA_66 SHIVALLY_66 | 06:01                | 06:11     | 00:10    | TRIPPED ON FAULT   |
| 3827  | 21-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA     | NO STATIONS EFFECTED       | 10:54 (21/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3828  | 21-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-1          | NO STATIONS EFFECTED       | 9:08 (21/09/2024)    |           |          | LINE CLEAR AVAILED |
| 3829  | 21-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-2          | NO STATIONS EFFECTED       | 9:08 (21/09/2024)    |           |          | LINE CLEAR AVAILED |
| 3830  | 21-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                         | KADAKOLA_220               | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 3831  | 21-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH       | NO STATIONS EFFECTED       | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                     | Station_Name         | Open_At              | Closed_At            | Duration  | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------|----------------------|----------------------|----------------------|-----------|--------------------|
| 3832  | 21-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA      | NO STATIONS EFFECTED | 16:47 (10/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 3833  | 21-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA      | NO STATIONS EFFECTED | 7:53<br>(26/08/2024) |                      |           | LINE CLEAR AVAILED |
| 3834  | 21-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI         | NO STATIONS EFFECTED | 11:54 (09/08/2024)   |                      |           | LINE CLEAR AVAILED |
| 3835  | 21-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | SFC SIVA_66          | 7:01<br>(15/02/2024) |                      |           | TRIPPED ON FAULT   |
| 3836  | 21-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 1       | NO STATIONS EFFECTED | 15:06 (20/09/2024)   | 8:02<br>(21/09/2024) | 16:56 HRs | LINE CLEAR AVAILED |
| 3837  | 21-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 2       | NO STATIONS EFFECTED | 15:06 (20/09/2024)   | 8:02<br>(21/09/2024) | 16:56 HRs | LINE CLEAR AVAILED |
| 3838  | 22-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                      | ADAKANAHALLI_220     | 12:20                | 14:00                | 01:40     | LINE CLEAR AVAILED |
| 3839  | 22-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV2                      | ADAKANAHALLI_220     | 14:15                | 14:25                | 00:10     | TRIPPED ON FAULT   |
| 3840  | 22-Sep-24 | MYSORE  | 66      | LINE        | CRNAGAR-HONGANUR         | HONAGANURU_66        | 12:40                | 16:03                | 03:23     | LINE CLEAR AVAILED |
| 3841  | 22-Sep-24 | MYSORE  | 66      | LINE        | CRNAGAR-BADANGUPPE 1     | BADANAGUPPE_66       | 11:11                | 18:01                | 06:50     | LINE CLEAR AVAILED |
| 3842  | 22-Sep-24 | MYSORE  | 66      | LINE        | CRNAGAR-BADANGUPPE 2     | BADANAGUPPE_66       | 12:16                | 18:01                | 05:45     | LINE CLEAR AVAILED |
| 3843  | 22-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(N'GUD)-HEMARGALA  | NO STATIONS EFFECTED | 10:43                | 11:07                | 00:24     | LINE CLEAR AVAILED |
| 3844  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | HEBBAL_66            | 14:18                | 16:21                | 02:02     | LINE CLEAR AVAILED |
| 3845  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | HEMMARGALA_66        | 10:05                | 17:00                | 06:55     | LINE CLEAR AVAILED |
| 3846  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | HEMMARGALA_66        | 10:05                | 17:00                | 06:55     | LINE CLEAR AVAILED |
| 3847  | 22-Sep-24 | MYSORE  | 66      | LINE        | HOTAGALLI-HEBBAL IA      | HEBBAL-INDUSTRIAL_66 | 10:03                | 15:50                | 05:46     | LINE CLEAR AVAILED |
| 3848  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | KARYA_66             | 10:00                | 14:30                | 04:30     | LINE CLEAR AVAILED |
| 3849  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | KARYA_66             | 10:00                | 14:30                | 04:30     | LINE CLEAR AVAILED |
| 3850  | 22-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOTGLY          | NO STATIONS EFFECTED | 11:12                | 17:12                | 06:00     | LINE CLEAR AVAILED |
| 3851  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | KADAKOLA_220         | 10:04                | 14:29                | 04:24     | LINE CLEAR AVAILED |
| 3852  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | KOLKARANADODDI_66    | 05:55                | 06:39                | 00:43     | TRIPPED ON FAULT   |
| 3853  | 22-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-BANNARIIPP       | NO STATIONS EFFECTED | 06:02                | 06:10                | 00:08     | TRIPPED ON FAULT   |
| 3854  | 22-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANAHALLI-MAMBALLI  | MAMBALLI_66          | 10:25                | 12:26                | 02:00     | LINE CLEAR AVAILED |
| 3855  | 22-Sep-24 | MYSORE  | 66      | LINE        | PANYADUNDI-KEREHALLI LIS | NO STATIONS EFFECTED | 06:00                | 06:10                | 00:10     | TRIPPED ON FAULT   |
| 3856  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | PANDYADAHUNDI_66     | 10:00                | 14:00                | 04:00     | LINE CLEAR AVAILED |
| 3857  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | PANDYADAHUNDI_66     | 10:00                | 14:00                | 04:00     | LINE CLEAR AVAILED |
| 3858  | 22-Sep-24 | MYSORE  | 66      | LINE        | SANVA-YESSLUR            | NO STATIONS EFFECTED | 11:56                | 12:21                | 00:24     | LINE CLEAR AVAILED |
| 3859  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | SINDHUVALLI_66       | 11:50                | 12:00                | 00:10     | TRIPPED ON FAULT   |
| 3860  | 22-Sep-24 | MYSORE  | 66      | LINE        | YELANDUR-MADHUVANAHALLI  | MAMBALLI_66          | 10:18                | 12:34                | 02:16     | LINE CLEAR AVAILED |
| 3861  | 22-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA  | NO STATIONS EFFECTED | 10:54 (21/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 3862  | 22-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-1       | NO STATIONS EFFECTED | 9:08 (21/09/2024)    |                      |           | LINE CLEAR AVAILED |
| 3863  | 22-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-2       | NO STATIONS EFFECTED | 9:08 (21/09/2024)    |                      |           | LINE CLEAR AVAILED |
| 3864  | 22-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                      | KADAKOLA_220         | 12:06 (13/09/2024)   |                      |           | TRIPPED ON FAULT   |
| 3865  | 22-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH    | NO STATIONS EFFECTED | 11:33 (12/09/2024)   |                      |           | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                               | Station_Name                                                    | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------------|-----------------------------------------------------------------|----------------------|-----------|----------|--------------------|
| 3866  | 22-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA                | NO STATIONS EFFECTED                                            | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3867  | 22-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA                | NO STATIONS EFFECTED                                            | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3868  | 22-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI                   | NO STATIONS EFFECTED                                            | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 3869  | 22-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                | SFC SIVA_66                                                     | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 3870  | 23-Sep-24 | MYSORE  | 66      | LINE        | AJJIPURA-COWDALLI                  | COWDALLI_66 MARTAHALLI_66<br>RAMAPURA_MYS_66                    | 12:35                | 12:50     | 00:15    | TRIPPED ON FAULT   |
| 3871  | 23-Sep-24 | MYSORE  | 66      | LINE        | BANNIMANTAPA-FTS-2                 | NO STATIONS EFFECTED                                            | 09:55                | 10:04     | 00:09    | TRIPPED ON FAULT   |
| 3872  | 23-Sep-24 | MYSORE  | 66      | LINE        | BANNIMANTAPA-HOOTAGALLI-2          | NO STATIONS EFFECTED                                            | 10:15                | 10:25     | 00:10    | TRIPPED ON FAULT   |
| 3873  | 23-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-SFC-3                      | NO STATIONS EFFECTED                                            | 10:51                | 12:05     | 01:14    | LINE CLEAR AVAILED |
| 3874  | 23-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-SFC-4                      | NO STATIONS EFFECTED                                            | 10:51                | 12:05     | 01:14    | LINE CLEAR AVAILED |
| 3875  | 23-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-SFC-5                      | NO STATIONS EFFECTED                                            | 10:51                | 12:05     | 01:14    | LINE CLEAR AVAILED |
| 3876  | 23-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-VIJAYANAGARA            | VIJAYANAGRAMYS_66                                               | 10:15                | 11:39     | 01:23    | TRIPPED ON FAULT   |
| 3877  | 23-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DK MAIDANA                | NO STATIONS EFFECTED                                            | 12:49                | 13:29     | 00:39    | LINE CLEAR AVAILED |
| 3878  | 23-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MANDAKALLI                | NO STATIONS EFFECTED                                            | 09:25                | 13:55     | 04:30    | LINE CLEAR AVAILED |
| 3879  | 23-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                | KOLKARANADODDI_66                                               | 13:46                | 14:15     | 00:28    | LINE CLEAR AVAILED |
| 3880  | 23-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                | KOLKARANADODDI_66                                               | 11:20                | 12:55     | 01:35    | LINE CLEAR AVAILED |
| 3881  | 23-Sep-24 | MYSORE  | 66      | LINE        | KOLLEGALA-CR NAGARA                | NO STATIONS EFFECTED                                            | 11:37                | 11:58     | 00:21    | LINE CLEAR AVAILED |
| 3882  | 23-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                                | KOLLEGALA_66                                                    | 12:05                | 12:30     | 00:24    | LINE CLEAR AVAILED |
| 3883  | 23-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                                | KOLLEGALA_66                                                    | 12:27                | 12:44     | 00:16    | LINE CLEAR AVAILED |
| 3884  | 23-Sep-24 | MYSORE  | 66      | LINE        | KOLLEGALA-PARINAMIPURA             | NO STATIONS EFFECTED                                            | 16:45                | 16:58     | 00:13    | TRIPPED ON FAULT   |
| 3885  | 23-Sep-24 | MYSORE  | 66      | LINE        | MYSORE SOUTH-KADAKOLA              | NO STATIONS EFFECTED                                            | 09:12                | 13:50     | 04:37    | LINE CLEAR AVAILED |
| 3886  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-BASARALU           | HAMPAPURA_66 BASARALU_66                                        | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3887  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-BG NAGARA          | ADICHUNCHANAGIRI_66<br>BGNAGARA_66 KADABALLY_66<br>VADERALLI_66 | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3888  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-GUDDENAHALLI       | BOGADHI MANDYA_66<br>GUDDENAHALLI_66                            | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3889  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-HARADANAHALLI(JAK) | HARADANAHALLI(JAK)_66                                           | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3890  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-KESALAGERE         | KESLAGERE_66                                                    | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3891  | 23-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-KOPPA              | BESAGARAHALLI_66,<br>DUNDANAHALLI_66 KOPPA_66                   | 11:06                | 11:11     | 00:05    | TRIPPED ON FAULT   |
| 3892  | 23-Sep-24 | MYSORE  | 66      | LINE        | SATHEGALA-KOLLEGALA                | NO STATIONS EFFECTED                                            | 11:16                | 11:32     | 00:16    | LINE CLEAR AVAILED |
| 3893  | 23-Sep-24 | MYSORE  | 66      | LINE        | SANTHEMARAHALLI-KUNTHUR            | NO STATIONS EFFECTED                                            | 13:52                | 14:14     | 00:21    | TRIPPED ON FAULT   |
| 3894  | 23-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PGL                       | NO STATIONS EFFECTED                                            | 10:48                | 12:06     | 01:17    | LINE CLEAR AVAILED |
| 3895  | 23-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PPCL                      | NO STATIONS EFFECTED                                            | 10:47                | 12:06     | 01:18    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                           | Station_Name                                             | Open_At              | Closed_At            | Duration  | REMARKS           |
|-------|-----------|---------|---------|-------------|--------------------------------|----------------------------------------------------------|----------------------|----------------------|-----------|-------------------|
| 3896  | 23-Sep-24 | MYSORE  | 66      | LINE        | SR PATNA-G UKKADA              | SR PATNA                                                 | 17:05                | 17:15                | 00:10     | TRIPPED ON FAULT  |
| 3897  | 23-Sep-24 | MYSORE  | 220     | LINE        | TUBINAKERE-BASTIPURA           | NO STATIONS EFFECTED                                     | 11:07                | 22:09                | 11:02     | LINE CLEAR AVAIED |
| 3898  | 23-Sep-24 | MYSORE  | 66      | LINE        | VAJAMANGALA-KADAKOLA-1         | AYRALLI_66 MARADIHUNDI_66                                | 05:50                | 06:03                | 00:13     | TRIPPED ON FAULT  |
| 3899  | 23-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BEML                | HEBBAL-INDUSTRIAL_66                                     | 23:59 (23/09/2024)   |                      |           | TRIPPED ON FAULT  |
| 3900  | 23-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA        | NO STATIONS EFFECTED                                     | 11:34 (23/09/2024)   |                      |           | LINE CLEAR AVAIED |
| 3901  | 23-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA        | NO STATIONS EFFECTED                                     | 10:54 (21/09/2024)   |                      |           | LINE CLEAR AVAIED |
| 3902  | 23-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-1             | NO STATIONS EFFECTED                                     | 9:08 (21/09/2024)    | 8:25<br>(23/09/2024) | 47:17 HRs | LINE CLEAR AVAIED |
| 3903  | 23-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI-2             | NO STATIONS EFFECTED                                     | 9:08 (21/09/2024)    | 8:25<br>(23/09/2024) | 47:17 HRs | LINE CLEAR AVAIED |
| 3904  | 23-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                            | KADAKOLA_220                                             | 12:06 (13/09/2024)   |                      |           | TRIPPED ON FAULT  |
| 3905  | 23-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH          | NO STATIONS EFFECTED                                     | 11:33 (12/09/2024)   |                      |           | LINE CLEAR AVAIED |
| 3906  | 23-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA            | NO STATIONS EFFECTED                                     | 16:47 (10/09/2024)   |                      |           | LINE CLEAR AVAIED |
| 3907  | 23-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA            | NO STATIONS EFFECTED                                     | 7:53<br>(26/08/2024) |                      |           | LINE CLEAR AVAIED |
| 3908  | 23-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI               | NO STATIONS EFFECTED                                     | 11:54 (09/08/2024)   |                      |           | LINE CLEAR AVAIED |
| 3909  | 23-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | SFC SIVA_66                                              | 7:01<br>(15/02/2024) |                      |           | TRIPPED ON FAULT  |
| 3910  | 24-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-BEGUR 1             | NO STATIONS EFFECTED                                     | 12:37                | 14:31                | 01:53     | LINE CLEAR AVAIED |
| 3911  | 24-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-BEGUR 2             | NO STATIONS EFFECTED                                     | 12:40                | 14:30                | 01:50     | LINE CLEAR AVAIED |
| 3912  | 24-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-BOMMALAPURA         | BOMMALAPURA_66                                           | 10:15                | 18:17                | 08:01     | LINE CLEAR AVAIED |
| 3913  | 24-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-HANGLA              | BHARGI_66HANGLA_66                                       | 12:33                | 13:44                | 01:10     | LINE CLEAR AVAIED |
| 3914  | 24-Sep-24 | MYSORE  | 66      | LINE        | GUNDLUPETE-HANGLA              | BHARGI_66HANGLA_66                                       | 17:14                | 17:30                | 00:15     | LINE CLEAR AVAIED |
| 3915  | 24-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | GUNDULPET_66                                             | 10:15                | 18:17                | 08:01     | LINE CLEAR AVAIED |
| 3916  | 24-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                            | GUNDULPET_66                                             | 17:30                | 18:10                | 00:40     | LINE CLEAR AVAIED |
| 3917  | 24-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                            | GUNDULPET_66                                             | 10:15                | 18:10                | 07:55     | LINE CLEAR AVAIED |
| 3918  | 24-Sep-24 | MYSORE  | 66      | LINE        | HANGALA-GUNDLUPETE             | BHARGI_66HANGLA_66                                       | 10:01                | 13:45                | 03:43     | LINE CLEAR AVAIED |
| 3919  | 24-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-MADHUVANAHALLI 1        | NO STATIONS EFFECTED                                     | 10:27                | 14:38                | 04:11     | LINE CLEAR AVAIED |
| 3920  | 24-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLI            | NO STATIONS EFFECTED                                     | 13:24                | 15:49                | 02:25     | LINE CLEAR AVAIED |
| 3921  | 24-Sep-24 | MYSORE  | 66      | LINE        | KR NAGARA-BILIKERE             | BILIKERE_66                                              | 10:27                | 17:16                | 06:49     | LINE CLEAR AVAIED |
| 3922  | 24-Sep-24 | MYSORE  | 66      | LINE        | KR NAGARA-KUSHALNAGARA         | NO STATIONS EFFECTED                                     | 12:33                | 17:00                | 04:26     | LINE CLEAR AVAIED |
| 3923  | 24-Sep-24 | MYSORE  | 66      | LINE        | KR NAGARA-GAVADGERE            | KRNAGARA_66                                              | 12:35                | 16:50                | 04:15     | LINE CLEAR AVAIED |
| 3924  | 24-Sep-24 | MYSORE  | 66      | LINE        | KUSHALNAGARA-<br>RAMANATHAPURA | ALUR<br>SIDDAPUR_66KANAGAL_66RUDRA<br>PATNA_66CBHALLI_66 | 05:55                | 06:09                | 00:14     | TRIPPED ON FAULT  |
| 3925  | 24-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA-SHIVALLI           | NO STATIONS EFFECTED                                     | 10:33                | 12:11                | 01:38     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                           | Station_Name             | Open_At            | Closed_At         | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------------|--------------------------|--------------------|-------------------|----------|--------------------|
| 3926  | 24-Sep-24 | MYSORE  | 66      | LINE        | PONNAMPETE-VIRAJPET            | VIRAJPETE_66             | 10:02              | 17:06             | 07:03    | LINE CLEAR AVAILED |
| 3927  | 24-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV5                            | SFC SIVA_66              | 06:02              | 06:46             | 00:44    | TRIPPED ON FAULT   |
| 3928  | 24-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-HEBBANI 8             | NO STATIONS EFFECTED     | 06:05              | 06:15             | 00:10    | TRIPPED ON FAULT   |
| 3929  | 24-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-5MW                   | NO STATIONS EFFECTED     | 06:05              | 06:20             | 00:15    | TRIPPED ON FAULT   |
| 3930  | 24-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-10MW                  | NO STATIONS EFFECTED     | 06:05              | 06:20             | 00:15    | TRIPPED ON FAULT   |
| 3931  | 24-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PGL                   | NO STATIONS EFFECTED     | 06:02              | 06:22             | 00:20    | TRIPPED ON FAULT   |
| 3932  | 24-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220KV-BG NAGARA    | NO STATIONS EFFECTED     | 12:15              | 12:53             | 00:38    | LINE CLEAR AVAILED |
| 3933  | 24-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220KV-ADDIHALLI    | NO STATIONS EFFECTED     | 10:41              | 12:14             | 01:33    | LINE CLEAR AVAILED |
| 3934  | 24-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220KV-SHIVALLI     | NO STATIONS EFFECTED     | 10:36              | 12:08             | 01:32    | LINE CLEAR AVAILED |
| 3935  | 24-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BEML                | HEBBAL-INDUSTRIAL_66     | 23:59 (23/09/2024) | 0:18 (24/09/2024) | 00:19    | TRIPPED ON FAULT   |
| 3936  | 24-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA        | NO STATIONS EFFECTED     | 11:34 (23/09/2024) |                   |          | LINE CLEAR AVAILED |
| 3937  | 24-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA        | NO STATIONS EFFECTED     | 10:54 (21/09/2024) |                   |          | LINE CLEAR AVAILED |
| 3938  | 24-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                            | KADAKOLA_220             | 12:06 (13/09/2024) |                   |          | TRIPPED ON FAULT   |
| 3939  | 24-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH          | NO STATIONS EFFECTED     | 11:33 (12/09/2024) |                   |          | LINE CLEAR AVAILED |
| 3940  | 24-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA            | NO STATIONS EFFECTED     | 16:47 (10/09/2024) |                   |          | LINE CLEAR AVAILED |
| 3941  | 24-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA            | NO STATIONS EFFECTED     | 7:53 (26/08/2024)  |                   |          | LINE CLEAR AVAILED |
| 3942  | 24-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI               | NO STATIONS EFFECTED     | 11:54 (09/08/2024) |                   |          | LINE CLEAR AVAILED |
| 3943  | 24-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | SFC SIVA_66              | 7:01 (15/02/2024)  |                   |          | TRIPPED ON FAULT   |
| 3944  | 24-Sep-24 | MYSORE  | 66      | LINE        | BG PURA-CHANDALLI              | NO STATIONS EFFECTED     | 11:53 (24/09/2024) |                   |          | LINE CLEAR AVAILED |
| 3945  | 25-Sep-24 | MYSORE  | 66      | LINE        | CHUNCHUNKATTE-MAREGOWDANAHALLI | CHUNCHUNKATTE_66         | 10:00              | 17:33             | 07:33    | LINE CLEAR AVAILED |
| 3946  | 25-Sep-24 | MYSORE  | 66      | LINE        | DKMAIDANA-VAJMANGALA           | NO STATIONS EFFECTED     | 10:35              | 17:25             | 06:50    | LINE CLEAR AVAILED |
| 3947  | 25-Sep-24 | MYSORE  | 66      | LINE        | GUDDENAHALLI-NAGAMANGALA 220   | GUDDENAHALLI_66          | 14:52              | 15:18             | 00:25    | LINE CLEAR AVAILED |
| 3948  | 25-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-AMP SOLAR               | NO STATIONS EFFECTED     | 18:14              | 21:32             | 03:18    | LINE CLEAR AVAILED |
| 3949  | 25-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR-BANNIKUPPE              | BANNIKUPPE_6 GVGUDI_66   | 07:13              | 07:22             | 00:09    | TRIPPED ON FAULT   |
| 3950  | 25-Sep-24 | MYSORE  | 66      | LINE        | JAIPUR-HAMPAPURA               | HAMPAPURA_66             | 18:28              | 18:39             | 00:11    | TRIPPED ON FAULT   |
| 3951  | 25-Sep-24 | MYSORE  | 66      | LINE        | JYOTHINAGARA-VAJMANGALA        | JYOTHINAGARA_66          | 10:19              | 17:32             | 07:13    | LINE CLEAR AVAILED |
| 3952  | 25-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DKMAIDANA             | NO STATIONS EFFECTED     | 10:29              | 10:34             | 00:05    | LINE CLEAR AVAILED |
| 3953  | 25-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-JAYAPURA              | HAMPAPURA_66 JAYAPURA_66 | 18:30              | 18:34             | 00:04    | TRIPPED ON FAULT   |
| 3954  | 25-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                            | KIAD MANDYA_66           | 06:18              | 06:24             | 00:06    | TRIPPED ON FAULT   |
| 3955  | 25-Sep-24 | MYSORE  | 66      | LINE        | KRNAGAR-CHUNCHUNKATTE          | CHUNCHUNKATTE_66         | 11:20              | 13:04             | 01:43    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                      | Station_Name                                                                                               | Open_At              | Closed_At             | Duration  | REMARKS           |
|-------|-----------|---------|---------|-------------|---------------------------|------------------------------------------------------------------------------------------------------------|----------------------|-----------------------|-----------|-------------------|
| 3956  | 25-Sep-24 | MYSORE  | 66      | LINE        | KRPETE 220-KR PETE1       | NO STATIONS EFFECTED                                                                                       | 12:22                | 14:10                 | 01:48     | LINE CLEAR AVAIED |
| 3957  | 25-Sep-24 | MYSORE  | 66      | LINE        | KRPETE 220-KR PETE2       | NO STATIONS EFFECTED                                                                                       | 14:12                | 15:23                 | 01:11     | LINE CLEAR AVAIED |
| 3958  | 25-Sep-24 | MYSORE  | 66      | LINE        | KRPETE 220-KRISHNAPURA    | NO STATIONS EFFECTED                                                                                       | 12:50                | 14:40                 | 01:50     | LINE CLEAR AVAIED |
| 3959  | 25-Sep-24 | MYSORE  | 66      | LINE        | KUSHALNAGARA-RAMANTHAPURA | KANAGALU_66<br>ALURSIDDAPURA_66<br>CHIKKABOMMANAHALLI_66<br>RUDRAPATNA_66                                  | 16:16                | 17:03                 | 00:46     | LINE CLEAR AVAIED |
| 3960  | 25-Sep-24 | MYSORE  | 66      | LINE        | KUSHALNAGARA-MYSORE 1     | NO STATIONS EFFECTED                                                                                       | 11:11                | 13:01                 | 01:50     | LINE CLEAR AVAIED |
| 3961  | 25-Sep-24 | MYSORE  | 66      | LINE        | KUSHALNAGARA-SUNTIKOPPA   | NO STATIONS EFFECTED                                                                                       | 01:20                | 09:55                 | 08:35     | TRIPPED ON FAULT  |
| 3962  | 25-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                       | MANDYA_66                                                                                                  | 11:07                | 13:44                 | 02:37     | LINE CLEAR AVAIED |
| 3963  | 25-Sep-24 | MYSORE  | 66      | LINE        | RAVANDUR-KITTUR           | KITTUR_66 RAVANDURU_66<br>BETTADAPURA_66                                                                   | 11:10                | 13:03                 | 01:53     | LINE CLEAR AVAIED |
| 3964  | 25-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA   | NO STATIONS EFFECTED                                                                                       | 11:34 (23/09/2024)   |                       |           | LINE CLEAR AVAIED |
| 3965  | 25-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA   | NO STATIONS EFFECTED                                                                                       | 10:54 (21/09/2024)   |                       |           | LINE CLEAR AVAIED |
| 3966  | 25-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                       | KADAKOLA_220                                                                                               | 12:06 (13/09/2024)   |                       |           | TRIPPED ON FAULT  |
| 3967  | 25-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH     | NO STATIONS EFFECTED                                                                                       | 11:33 (12/09/2024)   |                       |           | LINE CLEAR AVAIED |
| 3968  | 25-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA       | NO STATIONS EFFECTED                                                                                       | 16:47 (10/09/2024)   |                       |           | LINE CLEAR AVAIED |
| 3969  | 25-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA       | NO STATIONS EFFECTED                                                                                       | 7:53<br>(26/08/2024) |                       |           | LINE CLEAR AVAIED |
| 3970  | 25-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI          | NO STATIONS EFFECTED                                                                                       | 11:54 (09/08/2024)   |                       |           | LINE CLEAR AVAIED |
| 3971  | 25-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                       | SFC SIVA_66                                                                                                | 7:01<br>(15/02/2024) |                       |           | TRIPPED ON FAULT  |
| 3972  | 25-Sep-24 | MYSORE  | 66      | LINE        | BG PURA-CHANDALLI         | NO STATIONS EFFECTED                                                                                       | 11:53 (24/09/2024)   | 17:42<br>(25/09/2024) | 29:49 HRs | LINE CLEAR AVAIED |
| 3973  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                       | BANNIMANTAP_66                                                                                             | 10:00                | 17:47                 | 07:47     | LINE CLEAR AVAIED |
| 3974  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                       | BANNIMANTAP_66                                                                                             | 10:00                | 17:47                 | 07:47     | LINE CLEAR AVAIED |
| 3975  | 26-Sep-24 | MYSORE  | 66      | LINE        | BEGUR 220-SARGUR          | SANTHESARAGUR_66HDKOTE_66A<br>NTHARSANTHE_66YEREHALLIHAN<br>DPOST_66CHANDRAVADI_66HULL<br>AHALLI_66HURA_66 | 13:47                | 13:52                 | 00:05     | TRIPPED ON FAULT  |
| 3976  | 26-Sep-24 | MYSORE  | 66      | LINE        | BEGUR-B MATTAKERE         | B MATKERE_66                                                                                               | 13:47                | 13:52                 | 00:05     | TRIPPED ON FAULT  |
| 3977  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                       | DKMAIDANA_66                                                                                               | 10:38                | 15:06                 | 04:27     | LINE CLEAR AVAIED |
| 3978  | 26-Sep-24 | MYSORE  | 66      | LINE        | FTS-BANNIMANTAP 1         | NO STATIONS EFFECTED                                                                                       | 16:23                | 17:53                 | 01:29     | LINE CLEAR AVAIED |
| 3979  | 26-Sep-24 | MYSORE  | 66      | LINE        | FTS-BANNIMANTAP 2         | NO STATIONS EFFECTED                                                                                       | 16:23                | 17:53                 | 01:29     | LINE CLEAR AVAIED |
| 3980  | 26-Sep-24 | MYSORE  | 66      | LINE        | G UKKADA-PANDAVAPURA      | NO STATIONS EFFECTED                                                                                       | 12:45                | 13:50                 | 01:04     | LINE CLEAR AVAIED |
| 3981  | 26-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAP 1  | BANNIMANTAP_66                                                                                             | 16:11                | 17:43                 | 01:32     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                     | Station_Name                                                           | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------------|------------------------------------------------------------------------|----------------------|-----------|----------|--------------------|
| 3982  | 26-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BANNIMANTAP 2 | BANNIMANTAP_66                                                         | 16:11                | 17:43     | 01:32    | LINE CLEAR AVAILED |
| 3983  | 26-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-SFC 2            | NO STATIONS EFFECTED                                                   | 18:18                | 18:33     | 00:15    | TRIPPED ON FAULT   |
| 3984  | 26-Sep-24 | MYSORE  | 66      | LINE        | HULLALLI-CHANDRAWADI     | HULLAHALLI_66                                                          | 18:27                | 18:36     | 00:09    | TRIPPED ON FAULT   |
| 3985  | 26-Sep-24 | MYSORE  | 66      | LINE        | KOTHANUR-DODDINADUWADI   | NO STATIONS EFFECTED                                                   | 01:40                | 01:45     | 00:05    | TRIPPED ON FAULT   |
| 3986  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | KIAD MANDYA_66                                                         | 13:44                | 16:48     | 03:04    | LINE CLEAR AVAILED |
| 3987  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                      | KIKKERI_66                                                             | 17:27                | 17:56     | 00:28    | LINE CLEAR AVAILED |
| 3988  | 26-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-BANNARI IPP      | NO STATIONS EFFECTED                                                   | 06:15                | 06:25     | 00:10    | TRIPPED ON FAULT   |
| 3989  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | MEGALAPURA_66                                                          | 13:21                | 13:43     | 00:21    | LINE CLEAR AVAILED |
| 3990  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV5                      | SFC SIVA_66                                                            | 18:18                | 18:57     | 00:39    | TRIPPED ON FAULT   |
| 3991  | 26-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-PGL             | NO STATIONS EFFECTED                                                   | 18:18                | 18:27     | 00:08    | TRIPPED ON FAULT   |
| 3992  | 26-Sep-24 | MYSORE  | 220     | LINE        | TUBINKERE-CHANNAPATNA    | NO STATIONS EFFECTED                                                   | 12:20                | 15:03     | 02:43    | LINE CLEAR AVAILED |
| 3993  | 26-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA  | NO STATIONS EFFECTED                                                   | 11:34 (23/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3994  | 26-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA  | NO STATIONS EFFECTED                                                   | 10:54 (21/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3995  | 26-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                      | KADAKOLA_220                                                           | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 3996  | 26-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH    | NO STATIONS EFFECTED                                                   | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3997  | 26-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA      | NO STATIONS EFFECTED                                                   | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 3998  | 26-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA      | NO STATIONS EFFECTED                                                   | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 3999  | 26-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI         | NO STATIONS EFFECTED                                                   | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 4000  | 26-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                      | SFC SIVA_66                                                            | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 4001  | 26-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-5MW             | NO STATIONS EFFECTED                                                   | 18:15 (26/09/2024)   |           |          | TRIPPED ON FAULT   |
| 4002  | 26-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-10MW            | NO STATIONS EFFECTED                                                   | 18:15 (26/09/2024)   |           |          | TRIPPED ON FAULT   |
| 4003  | 27-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                      | NAGAMANGALA_220                                                        | 11:12                | 11:47     | 00:35    | LINE CLEAR AVAILED |
| 4004  | 27-Sep-24 | MYSORE  | 66      | LINE        | HANNUR-AMP SOLAR         | NO STATIONS EFFECTED                                                   | 18:23                | 18:37     | 00:13    | TRIPPED ON FAULT   |
| 4005  | 27-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BARC2         | NO STATIONS EFFECTED                                                   | 16:09                | 17:25     | 01:15    | TRIPPED ON FAULT   |
| 4006  | 27-Sep-24 | MYSORE  | 66      | LINE        | JAIPURA-HAMPAPURA        | HAMPAPURA_66                                                           | 06:02                | 06:07     | 00:05    | TRIPPED ON FAULT   |
| 4007  | 27-Sep-24 | MYSORE  | 220     | LINE        | KADAKOLA-HOOTAGALLI      | NO STATIONS EFFECTED                                                   | 10:59                | 12:08     | 01:08    | LINE CLEAR AVAILED |
| 4008  | 27-Sep-24 | MYSORE  | 66      | LINE        | VADKEPURA-KIRUGAVALU     | KIRUGAVALU_66MALIYURU_66                                               | 06:12                | 06:18     | 00:06    | TRIPPED ON FAULT   |
| 4009  | 27-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                      | PONNAMPET_66                                                           | 14:47                | 14:56     | 00:09    | LINE CLEAR AVAILED |
| 4010  | 27-Sep-24 | MYSORE  | 66      | LINE        | MAMBALLI-YELANDUR        | YELANDUR_66                                                            | 15:33                | 15:38     | 00:05    | TRIPPED ON FAULT   |
| 4011  | 27-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-MEGALAPURA       | BGPURA_66CHANDALLI_66THALAK<br>ADU_66PARINAMIPURA_66CHIDR<br>AVALLI_66 | 13:09                | 13:19     | 00:10    | TRIPPED ON FAULT   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                    | Station_Name                                                                                                     | Open_At              | Closed_At            | Duration  | REMARKS            |
|-------|-----------|---------|---------|-------------|-------------------------|------------------------------------------------------------------------------------------------------------------|----------------------|----------------------|-----------|--------------------|
| 4012  | 27-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA | NO STATIONS EFFECTED                                                                                             | 11:34 (23/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 4013  | 27-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA | NO STATIONS EFFECTED                                                                                             | 10:54 (21/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 4014  | 27-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                     | KADAKOLA_220                                                                                                     | 12:06 (13/09/2024)   |                      |           | TRIPPED ON FAULT   |
| 4015  | 27-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH   | NO STATIONS EFFECTED                                                                                             | 11:33 (12/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 4016  | 27-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA     | NO STATIONS EFFECTED                                                                                             | 16:47 (10/09/2024)   |                      |           | LINE CLEAR AVAILED |
| 4017  | 27-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA     | NO STATIONS EFFECTED                                                                                             | 7:53<br>(26/08/2024) |                      |           | LINE CLEAR AVAILED |
| 4018  | 27-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI        | NO STATIONS EFFECTED                                                                                             | 11:54 (09/08/2024)   |                      |           | LINE CLEAR AVAILED |
| 4019  | 27-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                     | SFC SIVA_66                                                                                                      | 7:01<br>(15/02/2024) |                      |           | TRIPPED ON FAULT   |
| 4020  | 27-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-5MW            | NO STATIONS EFFECTED                                                                                             | 18:15 (26/09/2024)   | 5:55<br>(27/09/2024) | 11:40 HRs | TRIPPED ON FAULT   |
| 4021  | 27-Sep-24 | MYSORE  | 66      | LINE        | SFC SIVA-10MW           | NO STATIONS EFFECTED                                                                                             | 18:15 (26/09/2024)   | 6:10<br>(27/09/2024) | 11:55 HRs | TRIPPED ON FAULT   |
| 4022  | 28-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                     | BEGUR_66                                                                                                         | 12:30                | 12:55                | 00:25     | TRIPPED ON FAULT   |
| 4023  | 28-Sep-24 | MYSORE  | 66      | LINE        | BEGURU-B MATKERE        | B MATKERE_66                                                                                                     | 11:15                | 12:19                | 01:03     | TRIPPED ON FAULT   |
| 4024  | 28-Sep-24 | MYSORE  | 66      | LINE        | CHIKAMANDYA-MANDYA      | MANDYA_66                                                                                                        | 09:26                | 16:12                | 06:45     | LINE CLEAR AVAILED |
| 4025  | 28-Sep-24 | MYSORE  | 66      | LINE        | HUNSUR-HUNSUR 2         | NO STATIONS EFFECTED                                                                                             | 11:49                | 12:43                | 00:53     | LINE CLEAR AVAILED |
| 4026  | 28-Sep-24 | MYSORE  | 66      | LINE        | KUNTHUR-BANNARIIPP      | NO STATIONS EFFECTED                                                                                             | 12:51                | 18:27                | 05:36     | TRIPPED ON FAULT   |
| 4027  | 28-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANALLI-SFC        | NO STATIONS EFFECTED                                                                                             | 23:34                | 23:41                | 00:07     | TRIPPED ON FAULT   |
| 4028  | 28-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                     | MANDYA_66                                                                                                        | 09:20                | 16:35                | 07:15     | LINE CLEAR AVAILED |
| 4029  | 28-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                     | MANDYA_66                                                                                                        | 09:20                | 16:00                | 06:40     | LINE CLEAR AVAILED |
| 4030  | 28-Sep-24 | MYSORE  | 66      | LINE        | MANDYA-MADDUR           | NO STATIONS EFFECTED                                                                                             | 09:01                | 16:10                | 07:08     | LINE CLEAR AVAILED |
| 4031  | 28-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                     | PONNAMPET_66                                                                                                     | 15:56                | 18:10                | 02:13     | LINE CLEAR AVAILED |
| 4032  | 28-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-MANDYA2       | MANDYA_66                                                                                                        | 09:40                | 15:48                | 06:07     | LINE CLEAR AVAILED |
| 4033  | 28-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-MANDYA4       | MANDYA_66                                                                                                        | 09:40                | 15:48                | 06:08     | LINE CLEAR AVAILED |
| 4034  | 28-Sep-24 | MYSORE  | 66      | LINE        | VADKEPURA-KIRUGAVALU    | KIRUGAVALU_66 MALIYURU_66                                                                                        | 12:32                | 12:40                | 00:08     | TRIPPED ON FAULT   |
| 4035  | 28-Sep-24 | MYSORE  | 66      | LINE        | SARGURU-BEGURU          | SANTHESARAGUR_66 HDKOTE_66<br>ANTHARSANTHE_66<br>YEREHALLIHANDPOST_66<br>CHANDRAVADI_66 HULLAHALLI_66<br>HURA_66 | 11:17                | 11:22                | 00:05     | TRIPPED ON FAULT   |
| 4036  | 28-Sep-24 | MYSORE  | 66      | LINE        | SARGURU-BEGURU          | SANTHESARAGUR_66 HDKOTE_66<br>ANTHARSANTHE_66<br>YEREHALLIHANDPOST_66<br>CHANDRAVADI_66 HULLAHALLI_66<br>HURA_66 | 11:26                | 11:34                | 00:08     | TRIPPED ON FAULT   |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name                                     | Open_At              | Closed_At | Duration | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|--------------------------------------------------|----------------------|-----------|----------|--------------------|
| 4037  | 28-Sep-24 | MYSORE  | 66      | LINE        | SHIVALLI-NAGAMANAGALA        | NAGAMANGALA_66                                   | 23:45                | 23:59     | 00:15    | TRIPPED ON FAULT   |
| 4038  | 28-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA      | NO STATIONS EFFECTED                             | 11:34 (23/09/2024)   |           |          | LINE CLEAR AVAILED |
| 4039  | 28-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA      | NO STATIONS EFFECTED                             | 10:54 (21/09/2024)   |           |          | LINE CLEAR AVAILED |
| 4040  | 28-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220                                     | 12:06 (13/09/2024)   |           |          | TRIPPED ON FAULT   |
| 4041  | 28-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED                             | 11:33 (12/09/2024)   |           |          | LINE CLEAR AVAILED |
| 4042  | 28-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED                             | 16:47 (10/09/2024)   |           |          | LINE CLEAR AVAILED |
| 4043  | 28-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED                             | 7:53<br>(26/08/2024) |           |          | LINE CLEAR AVAILED |
| 4044  | 28-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED                             | 11:54 (09/08/2024)   |           |          | LINE CLEAR AVAILED |
| 4045  | 28-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                                      | 7:01<br>(15/02/2024) |           |          | TRIPPED ON FAULT   |
| 4046  | 29-Sep-24 | MYSORE  | 66      | LINE        | BANNIMANTAPA-FTS 2           | FTS_66 RAJEEVNAGARA_66                           | 17:21                | 17:31     | 00:09    | TRIPPED ON FAULT   |
| 4047  | 29-Sep-24 | MYSORE  | 66      | LINE        | BESAGARAHALLI-DUNDANAHALLI   | DUNDANAHALLI_66 NIDASALE_66                      | 01:28                | 01:54     | 00:26    | TRIPPED ON FAULT   |
| 4048  | 29-Sep-24 | MYSORE  | 66      | LINE        | HEMARGALA-DEVNUR(N'GUD)      | DEVNUR(N'GUD)_66 SUTTUR_66<br>GOLURU_66          | 18:33                | 18:40     | 00:07    | TRIPPED ON FAULT   |
| 4049  | 29-Sep-24 | MYSORE  | 66      | LINE        | GUNDALPETE-HANGLA            | HANGALA_66 BHARGI_66                             | 02:22                | 02:33     | 00:10    | TRIPPED ON FAULT   |
| 4050  | 29-Sep-24 | MYSORE  | 66      | LINE        | HEBBAL-HOOTGALLY             | HEBBAL_66 METAGALLY_66                           | 10:08                | 17:27     | 07:18    | LINE CLEAR AVAILED |
| 4051  | 29-Sep-24 | MYSORE  | 220     | LINE        | HEBBANI-TK HALLI 2           | NO STATIONS EFFECTED                             | 02:50                | 03:13     | 00:23    | TRIPPED ON FAULT   |
| 4052  | 29-Sep-24 | MYSORE  | 66      | LINE        | HEBBANI-VAJMANGALA           | THUMBLA_66<br>VYASARAJAPURA_66<br>GARGESHWARI_66 | 04:18                | 04:37     | 00:19    | TRIPPED ON FAULT   |
| 4053  | 29-Sep-24 | MYSORE  | 66      | LINE        | HOTAGALLY-RBI                | NO STATIONS EFFECTED                             | 10:03                | 14:43     | 04:39    | LINE CLEAR AVAILED |
| 4054  | 29-Sep-24 | MYSORE  | 66      | LINE        | JAKKANAHALLI-NAGMANGLA       | GMALLIGERE_66                                    | 01:39                | 01:50     | 00:11    | TRIPPED ON FAULT   |
| 4055  | 29-Sep-24 | MYSORE  | 66      | LINE        | JAKKANAHALLI-NAGMANGLA       | GMALLIGERE_66                                    | 02:34                | 02:41     | 00:06    | TRIPPED ON FAULT   |
| 4056  | 29-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-DOORA               | DOORA_66                                         | 14:52                | 14:57     | 00:05    | TRIPPED ON FAULT   |
| 4057  | 29-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-VAJMANGALA 2        | NO STATIONS EFFECTED                             | 22:09                | 22:27     | 00:18    | TRIPPED ON FAULT   |
| 4058  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                          | KIKKERI_66                                       | 12:48                | 12:53     | 00:05    | LINE CLEAR AVAILED |
| 4059  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KIKKERI_66                                       | 13:13                | 14:39     | 01:25    | LINE CLEAR AVAILED |
| 4060  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV3                          | KIKKERI_66                                       | 13:35                | 13:43     | 00:08    | LINE CLEAR AVAILED |
| 4061  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | KRPETE_66                                        | 13:05                | 14:17     | 01:12    | LINE CLEAR AVAILED |
| 4062  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KRPETE_66                                        | 11:06                | 13:00     | 01:53    | LINE CLEAR AVAILED |
| 4063  | 29-Sep-24 | MYSORE  | 66      | LINE        | MADHUVANAHALLI-DODDINDUVADI  | DODDINADUVADI_66                                 | 18:20                | 18:41     | 00:20    | TRIPPED ON FAULT   |
| 4064  | 29-Sep-24 | MYSORE  | 66      | LINE        | MUGUR-THAYUR                 | THAYUR_66 TNARSIPURA_66                          | 04:10                | 04:15     | 00:05    | TRIPPED ON FAULT   |
| 4065  | 29-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-GUDDENAHALLI | GUDDENAHALLI_66                                  | 01:31                | 01:44     | 00:13    | TRIPPED ON FAULT   |
| 4066  | 29-Sep-24 | MYSORE  | 66      | LINE        | NAGAMANGALA 220-HARDANAHALLI | HARADANAHALLI(JAK)_66                            | 03:13                | 03:20     | 00:07    | TRIPPED ON FAULT   |
| 4067  | 29-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | NAGAMANGALA_220                                  | 15:21                | 15:23     | 00:02    | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name                                                                                                    | Open_At                  | Closed_At               | Duration  | REMARKS            |
|-------|-----------|---------|---------|-------------|------------------------------|-----------------------------------------------------------------------------------------------------------------|--------------------------|-------------------------|-----------|--------------------|
| 4068  | 29-Sep-24 | MYSORE  | 220     | LINE        | NAGAMANGALA 220-ANCHEPALYA 2 | NO STATIONS EFFECTED                                                                                            | 15:31                    | 18:10                   | 02:39     | LINE CLEAR AVAILED |
| 4069  | 29-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-HAMPAPURA       | YEREHALLIHANDPOST_66<br>ANTARSANTE_66 HDKOTE_66                                                                 | 19:48                    | 19:58                   | 00:10     | TRIPPED ON FAULT   |
| 4070  | 29-Sep-24 | MYSORE  | 66      | LINE        | SANTHESARGUR-CHANDRAWADI     | CHANDRAWADI_66 HURA_66<br>HULLALLI_66                                                                           | 19:48                    | 19:58                   | 00:10     | TRIPPED ON FAULT   |
| 4071  | 29-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-JAKKANAHALLI       | NO STATIONS EFFECTED                                                                                            | 01:38                    | 01:45                   | 00:07     | TRIPPED ON FAULT   |
| 4072  | 29-Sep-24 | MYSORE  | 66      | LINE        | TUBINKERE-JAKKANAHALLI       | NO STATIONS EFFECTED                                                                                            | 02:33                    | 06:06                   | 03:33     | TRIPPED ON FAULT   |
| 4073  | 29-Sep-24 | MYSORE  | 220     | LINE        | TUBINKERE-GOPALPURA          | NO STATIONS EFFECTED                                                                                            | 05:57                    | 06:07                   | 00:10     | TRIPPED ON FAULT   |
| 4074  | 29-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA-BANNUR            | BANNUR_66                                                                                                       | 03:50                    | 03:58                   | 00:08     | TRIPPED ON FAULT   |
| 4075  | 29-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA-BANNUR            | BANNUR_66                                                                                                       | 04:01                    | 04:04                   | 00:03     | TRIPPED ON FAULT   |
| 4076  | 29-Sep-24 | MYSORE  | 66      | LINE        | VAJMANGALA-BANNUR            | BANNUR_66                                                                                                       | 04:15                    | 04:17                   | 00:02     | TRIPPED ON FAULT   |
| 4077  | 29-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA-TK HALLI          | KIADBMANDYA_66 KMDODDI_66<br>KOLKARANADODDI_66<br>TUMBEKERE_66<br>THALAGAWADI_66<br>KHONALGERE_66 YETTAMBADI_66 | 04:25                    | 04:47                   | 00:22     | TRIPPED ON FAULT   |
| 4078  | 29-Sep-24 | MYSORE  | 220     | LINE        | VAJMANGALA-TK HALLI          | NO STATIONS EFFECTED                                                                                            | 07:46                    | 10:24                   | 02:38     | LINE CLEAR AVAILED |
| 4079  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | KOLKARANADODDI_66                                                                                               | 05:07                    | 05:17                   | 00:10     | TRIPPED ON FAULT   |
| 4080  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | YETTAMBADI_66                                                                                                   | 03:00                    | 03:07                   | 00:07     | TRIPPED ON FAULT   |
| 4081  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BEGUR_66                                                                                                        | 10:00                    | 15:20                   | 05:20     | LINE CLEAR AVAILED |
| 4082  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | BEGUR_66                                                                                                        | 10:00                    | 15:20                   | 05:20     | LINE CLEAR AVAILED |
| 4083  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | BEGUR_220                                                                                                       | 10:05                    | 15:05                   | 05:00     | LINE CLEAR AVAILED |
| 4084  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | GAMANAHALLI_66                                                                                                  | 02:53                    | 03:15                   | 00:22     | TRIPPED ON FAULT   |
| 4085  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV2                          | MAHADESHWARAPURA_66                                                                                             | 07:30                    | 08:05                   | 00:35     | TRIPPED ON FAULT   |
| 4086  | 29-Sep-24 | MYSORE  | 220     | LINE        | TUBINKERE-GOPALPURA          | NO STATIONS EFFECTED                                                                                            | 16:14:00<br>(29/09/2024) |                         |           | TRIPPED ON FAULT   |
| 4087  | 29-Sep-24 | MYSORE  | 66      | LINE        | MEGHALAPURA-VAJAMANGALA      | NO STATIONS EFFECTED                                                                                            | 11:34 (23/09/2024)       | 17:15:00<br>(25/9/2024) | 77:40 HRs | LINE CLEAR AVAILED |
| 4088  | 29-Sep-24 | MYSORE  | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA      | NO STATIONS EFFECTED                                                                                            | 10:54 (21/09/2024)       |                         |           | LINE CLEAR AVAILED |
| 4089  | 29-Sep-24 | MYSORE  | 220     | TRANSFORMER | HV1                          | KADAKOLA_220                                                                                                    | 12:06 (13/09/2024)       |                         |           | TRIPPED ON FAULT   |
| 4090  | 29-Sep-24 | MYSORE  | 66      | LINE        | KADAKOLA-MYSORE SOUTH        | NO STATIONS EFFECTED                                                                                            | 11:33 (12/09/2024)       |                         |           | LINE CLEAR AVAILED |
| 4091  | 29-Sep-24 | MYSORE  | 220     | LINE        | HOOTAGALLI-KADAKOLA          | NO STATIONS EFFECTED                                                                                            | 16:47 (10/09/2024)       |                         |           | LINE CLEAR AVAILED |
| 4092  | 29-Sep-24 | MYSORE  | 66      | LINE        | HOOTAGALLI-BELAGOLA          | NO STATIONS EFFECTED                                                                                            | 7:53<br>(26/08/2024)     |                         |           | LINE CLEAR AVAILED |
| 4093  | 29-Sep-24 | MYSORE  | 66      | LINE        | BILIKERE-GV GUDI             | NO STATIONS EFFECTED                                                                                            | 11:54 (09/08/2024)       |                         |           | LINE CLEAR AVAILED |
| 4094  | 29-Sep-24 | MYSORE  | 66      | TRANSFORMER | HV1                          | SFC SIVA_66                                                                                                     | 7:01<br>(15/02/2024)     |                         |           | TRIPPED ON FAULT   |
| 4095  | 30-Sep-24 | MYSORE  | 66      | LINE        | CR NAGARA-GUNDLUPETE         | TERAKANAMBE_66                                                                                                  | 14:09                    | 14:15                   | 00:05     | TRIPPED ON FAULT   |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                          | Station_Name                                                         | Open_At                  | Closed_At            | Duration  | REMARKS             |
|-------|------------|----------|---------|-------------|-------------------------------|----------------------------------------------------------------------|--------------------------|----------------------|-----------|---------------------|
| 4096  | 30-Sep-24  | MYSORE   | 66      | LINE        | CR NAGARA-HONGANURU           | HONAGANURU_66                                                        | 18:03                    | 18:10                | 00:06     | TRIPPED ON FAULT    |
| 4097  | 30-Sep-24  | MYSORE   | 66      | LINE        | DEVNUR(N'GUD)-HEMMARGALA      | DEVANOORNGUDU_66,<br>GOLURU(GEEKALLI)_66,<br>SUTTUR_66               | 06:12                    | 06:18                | 00:06     | TRIPPED ON FAULT    |
| 4098  | 30-Sep-24  | MYSORE   | 66      | LINE        | KARYA-HEMMARGALA              | DEVANOORNGUDU_66,<br>GOLURU(GEEKALLI)_66,<br>HEMMARGALA_66,SUTTUR_66 | 06:11                    | 06:17                | 00:06     | TRIPPED ON FAULT    |
| 4099  | 30-Sep-24  | MYSORE   | 66      | TRANSFORMER | HV3                           | KIKKERI_66                                                           | 07:59                    | 08:03                | 00:04     | LINE CLEAR AVAIED   |
| 4100  | 30-Sep-24  | MYSORE   | 66      | LINE        | KUNTHUR-BANNARI IPP           | NO STATIONS EFFECTED                                                 | 18:18                    | 18:23                | 00:05     | TRIPPED ON FAULT    |
| 4101  | 30-Sep-24  | MYSORE   | 66      | LINE        | KUSHALANAGARA 220-SUNTIKOPPPA | NO STATIONS EFFECTED                                                 | 11:47                    | 13:13                | 01:26     | LINE CLEAR AVAIED   |
| 4102  | 30-Sep-24  | MYSORE   | 66      | LINE        | MADHUVANAHALLI-KUNTHUR        | NO STATIONS EFFECTED                                                 | 06:04                    | 06:08                | 00:04     | TRIPPED ON FAULT    |
| 4103  | 30-Sep-24  | MYSORE   | 66      | LINE        | MADHUVANAHALLI-KUNTHUR        | NO STATIONS EFFECTED                                                 | 10:17                    | 12:05                | 01:48     | LINE CLEAR AVAIED   |
| 4104  | 30-Sep-24  | MYSORE   | 66      | TRANSFORMER | HV2                           | PONNAMPET_66                                                         | 17:02                    | 19:58                | 02:55     | LINE CLEAR AVAIED   |
| 4105  | 30-Sep-24  | MYSORE   | 66      | LINE        | SHANIVARASANTHE-YESSLURU      | NO STATIONS EFFECTED                                                 | 11:39                    | 11:51                | 00:12     | LINE CLEAR AVAIED   |
| 4106  | 30-Sep-24  | MYSORE   | 220     | LINE        | TUBINKERE-GOPALPURA           | NO STATIONS EFFECTED                                                 | 16:14:00<br>(29/09/2024) | 8:38<br>(30/09/2024) | 16:24 Hrs | TRIPPED ON FAULT    |
| 4107  | 30-Sep-24  | MYSORE   | 66      | LINE        | DEVNUR(MYS)-VAJAMANGALA       | NO STATIONS EFFECTED                                                 | 10:54 (21/09/2024)       |                      |           | LINE CLEAR AVAIED   |
| 4108  | 30-Sep-24  | MYSORE   | 220     | TRANSFORMER | HV1                           | KADAKOLA_220                                                         | 12:06 (13/09/2024)       |                      |           | TRIPPED ON FAULT    |
| 4109  | 30-Sep-24  | MYSORE   | 66      | LINE        | KADAKOLA-MYSORE SOUTH         | NO STATIONS EFFECTED                                                 | 11:33 (12/09/2024)       |                      |           | LINE CLEAR AVAIED   |
| 4110  | 30-Sep-24  | MYSORE   | 220     | LINE        | HOOTAGALLI-KADAKOLA           | NO STATIONS EFFECTED                                                 | 16:47 (10/09/2024)       |                      |           | LINE CLEAR AVAIED   |
| 4111  | 30-Sep-24  | MYSORE   | 66      | LINE        | HOOTAGALLI-BELAGOLA           | NO STATIONS EFFECTED                                                 | 7:53<br>(26/08/2024)     |                      |           | LINE CLEAR AVAIED   |
| 4112  | 30-Sep-24  | MYSORE   | 66      | LINE        | BILIKERE-GV GUDI              | NO STATIONS EFFECTED                                                 | 11:54 (09/08/2024)       |                      |           | LINE CLEAR AVAIED   |
| 4113  | 30-Sep-24  | MYSORE   | 66      | TRANSFORMER | HV1                           | SFC SIVA_66                                                          | 7:01<br>(15/02/2024)     |                      |           | TRIPPED ON FAULT    |
| 4114  | 1-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR              | NEELGUNDA_220                                                        | 9:21(21.05.2024)         |                      |           | LINE CLEAR AVAIED   |
| 4115  | 1-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD1&2           | KAPNOOR_220                                                          | 03:16                    | 05:02                | 01:46     | LINE CLEAR AVAIED   |
| 4116  | 1-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-SHAHABAD              | KAPNOOR_220                                                          | 03:16                    | 04:04                | 00:48     | MAIN SUPPLY FAILURE |
| 4117  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-NIMBARGA1           | NIMBARGA_220                                                         | 03:42                    | 04:31                | 00:49     | LINE CLEAR AVAIED   |
| 4118  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-NIMBARGA2           | NIMBARGA_220                                                         | 03:42                    | 04:31                | 00:49     | LINE CLEAR AVAIED   |
| 4119  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR2           | SHAHAPUR_220                                                         | 03:42                    | 06:27                | 02:45     | LINE CLEAR AVAIED   |
| 4120  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR1           | SHAHAPUR_220                                                         | 03:42                    | 04:35                | 00:53     | LINE CLEAR AVAIED   |
| 4121  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SEDAM               | SHAHAPUR_220                                                         | 03:42                    | 04:08                | 00:26     | LINE CLEAR AVAIED   |
| 4122  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-KAPNOOR             | KAPNOOR_220                                                          | 03:42                    | 04:10                | 00:28     | LINE CLEAR AVAIED   |
| 4123  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-NIMBARGA1           | NIMBARGA_220                                                         | 15:53                    | 23:59                | 08:06     | LINE CLEAR AVAIED   |
| 4124  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR2           | SHAHAPUR_220                                                         | 15:11                    | 23:59                | 08:48     | LINE CLEAR AVAIED   |
| 4125  | 1-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR2           | SHAHAPUR_220                                                         | 15:20                    | 16:39                | 01:19     | LINE CLEAR AVAIED   |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                  | Station_Name                            | Open_At          | Closed_At | Duration | REMARKS             |
|-------|------------|----------|---------|-------------|-----------------------|-----------------------------------------|------------------|-----------|----------|---------------------|
| 4126  | 1-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-SEDAM1&2     | SEDAM_220                               | 03:10            | 04:56     | 01:46    | LINE CLEAR AVAIED   |
| 4127  | 1-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-KAPNOOR1&2   | KAPNOOR_220                             | 03:10            | 04:56     | 01:46    | LINE CLEAR AVAIED   |
| 4128  | 1-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                   | KURUGODU_110                            | 09:40            | 09:50     | 00:10    | TRIPPED ON FAULT    |
| 4129  | 1-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                   | KURUGODU_110                            | 10:50            | 11:00     | 00:10    | TRIPPED ON FAULT    |
| 4130  | 1-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                   | KURUGODU_110                            | 11:55            | 12:05     | 00:10    | TRIPPED ON FAULT    |
| 4131  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-AFZALPUR     | AFZALPUR_110,KARAJAGI_110               | 07:42            | 08:04     | 00:22    | MAIN SUPPLY FAILURE |
| 4132  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-KARAJAGI     | AFZALPUR_110,KARAJAGI_110               | 07:42            | 08:04     | 00:22    | MAIN SUPPLY FAILURE |
| 4133  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-CHOWDAPUR    | CHOWDAPUR_110,SAGNOOR_110               | 00:45            | 01:45     | 01:00    | MAIN SUPPLY FAILURE |
| 4134  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-CHOWDAPUR    | CHOWDAPUR_110,SAGNOOR_110               | 02:15            | 13:00     | 10:45    | LINE CLEAR AVAIED   |
| 4135  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-CHOWDAPUR    | CHOWDAPUR_110,SAGNOOR_110               | 00:45            | 01:45     | 01:00    | MAIN SUPPLY FAILURE |
| 4136  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-CHOWDAPUR    | CHOWDAPUR_110,SAGNOOR_110               | 02:15            | 13:00     | 10:45    | LINE CLEAR AVAIED   |
| 4137  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-NALWAR       | NALWAR_110                              | 03:15            | 03:43     | 00:28    | MAIN SUPPLY FAILURE |
| 4138  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-NALWAR       | NALWAR_110                              | 03:47            | 04:10     | 00:23    | MAIN SUPPLY FAILURE |
| 4139  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-CHITAPUR     | CHITAPUR_110                            | 04:50            | 04:55     | 00:05    | MAIN SUPPLY FAILURE |
| 4140  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SGHAHABAD-KORWAR      | KORWAR_110                              | 03:48            | 04:10     | 00:22    | MAIN SUPPLY FAILURE |
| 4141  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-MANDEWAL     | MANDEWAL_110                            | 03:18            | 03:43     | 00:25    | MAIN SUPPLY FAILURE |
| 4142  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-YADRAMI      | YADRAMI_110                             | 03:18            | 03:43     | 00:25    | MAIN SUPPLY FAILURE |
| 4143  | 1-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2    | GUGAL_110,GABBUR_110                    | 18:38            | 18:44     | 00:06    | TRIPPED ON FAULT    |
| 4144  | 1-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-BHALKI       | BHALKI_110,LADHA_110                    | 06:27            | 06:45     | 00:18    | MAIN SUPPLY FAILURE |
| 4145  | 1-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-BHALKI       | BHALKI_110,LADHA_110                    | 03:18            | 05:50     | 02:32    | MAIN SUPPLY FAILURE |
| 4146  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR2    | SHAHAPUR_110,JEWARGI_110                | 03:47            | 04:54     | 01:07    | LOAD CURTAILMENT    |
| 4147  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR1    | SHAHAPUR_110,JEWARGI_110                | 03:47            | 04:10     | 00:23    | LOAD CURTAILMENT    |
| 4148  | 1-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-NAGANOOR     | NAGANOOR_110                            | 06:01            | 06:09     | 00:08    | TRIPPED ON FAULT    |
| 4149  | 1-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                   | NEELGUNDA_220                           | 06:50            | 07:05     | 00:15    | TRIPPED ON FAULT    |
| 4150  | 1-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                   | NEELGUNDA_220                           | 07:25            | 07:35     | 00:10    | TRIPPED ON FAULT    |
| 4151  | 1-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HUVINAHADAGALI | HOLAGUNDI_66,HUVINAHADAGALI_66          | 18:44            | 18:59     | 00:15    | TRIPPED ON FAULT    |
| 4152  | 1-Sep-2024 | GULBARGA | 66      | LINE        | MUNIRABAD-UP HALLI    | MM HALLI_66, UP HALLI_66, VENKATAPUR_66 | 17:38            | 19:21     | 01:43    | TRIPPED ON FAULT    |
| 4153  | 2-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR      | NEELGUNDA_220                           | 9:21(21.05.2024) |           |          | LINE CLEAR AVAIED   |
| 4154  | 2-Sep-2024 | GULBARGA | 220     | LINE        | MALLAT-RTPS           | RTPS                                    | 03:08            | 11:16     | 08:08    | TRIPPED ON FAULT    |
| 4155  | 2-Sep-2024 | GULBARGA | 220     | LINE        | MALLAT-RTPS           | RTPS                                    | 03:56            | 11:16     | 07:20    | LINE CLEAR AVAIED   |
| 4156  | 2-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                   | HALBARGA_220                            | 11:26            | 11:50     | 00:24    | TRIPPED ON FAULT    |
| 4157  | 2-Sep-2024 | GULBARGA | 220     | LINE        | HALAWARTHI-DHONI-1    | DHONI_220                               | 11:40            | 12:43     | 01:03    | TRIPPED ON FAULT    |
| 4158  | 2-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-SREE CEMENT     | SEDAM_220                               | 04:57            | 11:52     | 06:55    | TRIPPED ON FAULT    |
| 4159  | 2-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-SREE CEMENT     | SEDAM_220                               | 22:25            | 23:59     | 01:35    | LINE CLEAR AVAIED   |
| 4160  | 2-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                   | SHAHABAD_220                            | 11:45            | 12:00     | 00:15    | TRIPPED ON FAULT    |
| 4161  | 2-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR2   | SHAHAPUR_220                            | 23:59            | 09:06     | 14:53    | LINE CLEAR AVAIED   |
| 4162  | 2-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-SHAHAPUR1   | SHAHAPUR_220                            | 23:59            | 09:00     | 14:59    | LINE CLEAR AVAIED   |
| 4163  | 2-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2     | KAPNOOR_220                             | 23:59            | 09:08     | 14:51    | LINE CLEAR AVAIED   |
| 4164  | 2-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2     | KAPNOOR_220                             | 22:11            | 23:59     | 01:48    | LINE CLEAR AVAIED   |
| 4165  | 2-Sep-2024 | GULBARGA | 220     | LINE        | LINGAPUR-JVSL2        | LINGAPUR_220                            | 14:39            | 18:30     | 03:51    | LINE CLEAR AVAIED   |
| 4166  | 2-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-SHAHAPUR       | YADGIR_110                              | 03:15            | 22:40     | 19:25    | MAIN SUPPLY FAILURE |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                         | Station_Name                                      | Open_At           | Closed_At | Duration | REMARKS             |
|-------|------------|----------|---------|-------------|------------------------------|---------------------------------------------------|-------------------|-----------|----------|---------------------|
| 4167  | 2-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | YADGIR_110                                        | 17:15             | 20:20     | 03:05    | LINE CLEAR AVAILED  |
| 4168  | 2-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI             | SANOTHI_110                                       | 05:35             | 05:58     | 00:23    | TRIPPED ON FAULT    |
| 4169  | 2-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI             | SANOTHI_110                                       | 22:08             | 22:20     | 00:12    | TRIPPED ON FAULT    |
| 4170  | 2-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI             | SANOTHI_110                                       | 23:55             | 23:59     | 00:04    | TRIPPED ON FAULT    |
| 4171  | 2-Sep-2024 | GULBARGA | 110     | LINE        | WADI-SHAHABAD                | WADI_110                                          | 11:55             | 12:05     | 00:10    | MAIN SUPPLY FAILURE |
| 4172  | 2-Sep-2024 | GULBARGA | 110     | LINE        | KORWAR-SHAHABAD              | KORWAR_110                                        | 06:40             | 07:14     | 00:34    | TRIPPED ON FAULT    |
| 4173  | 2-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-DEVAPUR             | DEVAPUR_110, SHORAPUR_110                         | 05:39             | 05:45     | 00:06    | TRIPPED ON FAULT    |
| 4174  | 2-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-SCHINCHOLI-2           | CHINCHOLI_110                                     | 08:36             | 08:46     | 00:10    | TRIPPED ON FAULT    |
| 4175  | 2-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-WALABALLARI       | WALABALLARI_110,<br>JAWALGERA_110                 | 21:33             | 21:50     | 00:17    | TRIPPED ON FAULT    |
| 4176  | 2-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | YERAGERA_110                                      | 13:45             | 17:20     | 03:35    | TRIPPED ON FAULT    |
| 4177  | 2-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | APMC_110                                          | 00:25             | 00:30     | 00:05    | TRIPPED ON FAULT    |
| 4178  | 2-Sep-2024 | GULBARGA | 110     | LINE        | GABBUR-RAICHUR               | GABBUR_110,GUGAL_110                              | 01:48             | 01:53     | 00:05    | MAIN SUPPLY FAILURE |
| 4179  | 2-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                          | KUDLIGI_66                                        | 21:53             | 22:08     | 00:15    | TRIPPED ON FAULT    |
| 4180  | 2-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                          | GUDEKOTE_66                                       | 11:00             | 12:20     | 01:20    | LOAD CURTAILMENT    |
| 4181  | 2-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI220-KUDLIGI           | KUDLIGI_66,HANSI_66,KOGALI_66,<br>CHILANAKATTI_66 | 06:10             | 06:35     | 00:25    | TRIPPED ON FAULT    |
| 4182  | 2-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                          | HARAPPANAHALLI_66                                 | 16:58             | 17:05     | 00:07    | TRIPPED ON FAULT    |
| 4183  | 3-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR             | NEELGUNDA_220                                     | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAILED  |
| 4184  | 3-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2          | FIROZABAD_220                                     | 21:58(03.09.2024) |           |          | LINE CLEAR AVAILED  |
| 4185  | 3-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2         | NIMBARGA_220                                      | 22:06(3.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 4186  | 3-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2            | KAPNOOR_220                                       | 21:03(3.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 4187  | 3-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                          | SHAHABAD_220                                      | 10:45             | 13:20     | 02:35    | TRIPPED ON FAULT    |
| 4188  | 3-Sep-2024 | GULBARGA | 220     | LINE        | KUDLIGI-CYCLI ENERGY I/C IPP | KUDLIGI_220                                       | 05:05             | 05:45     | 00:40    | TRIPPED ON FAULT    |
| 4189  | 3-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2             | LINGASUGUR_220                                    | 22:38             | 22:57     | 00:19    | TRIPPED ON FAULT    |
| 4190  | 3-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2         | NIMBARGA_220                                      | 04:20             | 07:50     | 03:30    | LINE CLEAR AVAILED  |
| 4191  | 3-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD1          | FIROZABAD_220                                     | 04:02             | 07:46     | 03:44    | LINE CLEAR AVAILED  |
| 4192  | 3-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | VADAVATTI_110                                     | 06:30             | 12:45     | 06:15    | TRIPPED ON FAULT    |
| 4193  | 3-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | VADAVATTI_110                                     | 14:00             | 18:50     | 04:50    | TRIPPED ON FAULT    |
| 4194  | 3-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | MANDEWAL_110                                      | 23:58             | 23:59     | 00:01    | LINE CLEAR AVAILED  |
| 4195  | 3-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | SIRIGERICROSS_110                                 | 15:28             | 15:38     | 00:10    | TRIPPED ON FAULT    |
| 4196  | 3-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | ALIPUR_220                                        | 14:55             | 15:34     | 00:39    | LINE CLEAR AVAILED  |
| 4197  | 3-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI          | YAPALDINI_110                                     | 10:10             | 10:20     | 00:10    | TRIPPED ON FAULT    |
| 4198  | 3-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-MADALAPUR             | MADALAPUR_110,MANVI_110,AD<br>AV                  | 10:24             | 10:28     | 00:04    | TRIPPED ON FAULT    |
| 4199  | 3-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-KAVITAL-1             | KAVITAL_110                                       | 18:14             | 18:19     | 00:05    | TRIPPED ON FAULT    |
| 4200  | 3-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-KAVITAL-2             | KAVITAL_110                                       | 18:14             | 18:19     | 00:05    | TRIPPED ON FAULT    |
| 4201  | 3-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-MORATAGI            | MANDEWAL_110                                      | 06:02             | 06:29     | 00:27    | TRIPPED ON FAULT    |
| 4202  | 3-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-SANTHPUR            | SANTHPUR_110                                      | 05:38             | 05:43     | 00:05    | TRIPPED ON FAULT    |
| 4203  | 3-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2           | GUGAL_110,GABBUR_110                              | 01:50             | 01:55     | 00:05    | TRIPPED ON FAULT    |
| 4204  | 3-Sep-2024 | GULBARGA | 110     | LINE        | VALA BELLARY-JAWALGERA       | JAWALGERA_110                                     | 06:04             | 06:14     | 00:10    | TRIPPED ON FAULT    |
| 4205  | 3-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                          | CHORNUR_66                                        | 11:20             | 12:40     | 01:20    | LINE CLEAR AVAILED  |
| 4206  | 3-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-HOSAHALLI           | HOSAHALLI_66,HUDEM_66                             | 06:05             | 06:20     | 00:15    | TRIPPED ON FAULT    |
| 4207  | 3-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-UJJINI               | UJJINI_66,SOKKE_66,NIMBALAGER<br>A_66,PALLAGATTE  | 15:20             | 16:42     | 01:22    | LINE CLEAR AVAILED  |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                                                          | Open_At           | Closed_At           | Duration | REMARKS             |
|-------|------------|----------|---------|-------------|--------------------------|---------------------------------------------------------------------------------------|-------------------|---------------------|----------|---------------------|
| 4208  | 3-Sep-2024 | GULBARGA | 66      | LINE        | NEELAGUNDA-HARAPANAHALLI | HARAPANAHALLI_66,IPP<br>SUZLONN,NICHAPURA_66                                          | 06:06             | 06:12               | 00:06    | TRIPPED ON FAULT    |
| 4209  | 3-Sep-2024 | GULBARGA | 66      | LINE        | MUNIRABAD-UPHALLI        | UPANAYAKANAHALLI_66,VENKATA<br>PUR_66                                                 | 10:01             | 13:09               | 03:08    | LINE CLEAR AVAILED  |
| 4210  | 4-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                                                         | 9:21(21.05.2024)  |                     |          | LINE CLEAR AVAILED  |
| 4211  | 4-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | FIROZABAD_220                                                                         | 21:58(03.09.2024) | 7:20(04.092024<br>) | 9:22HRS  | LINE CLEAR AVAILED  |
| 4212  | 4-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                                                           | 21:03(3.09.2024)  | 7:43(4.09.2024)     | 10:39:00 | LINE CLEAR AVAILED  |
| 4213  | 4-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2     | NIMBARGA_220                                                                          | 22:06(3.09.2024)  | 7:14(4.09.2024)     | 09:08    | LINE CLEAR AVAILED  |
| 4214  | 4-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2     | NIMBARGA_220                                                                          | 22:56(4.09.2024)  |                     |          | LINE CLEAR AVAILED  |
| 4215  | 4-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | FIROZABAD_220                                                                         | 01:00             | 7:20:00             | 06:20    | LINE CLEAR AVAILED  |
| 4216  | 4-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | FIROZABAD_220                                                                         | 22:58             | 24:00:00            | 01:02    | LINE CLEAR AVAILED  |
| 4217  | 4-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | KALABURGI(UNIVERSITY)_110                                                             | 11:30             | 13:30               | 02:00    | LINE CLEAR AVAILED  |
| 4218  | 4-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | KONKAL_110                                                                            | 15:56             | 16:06               | 00:10    | LINE CLEAR AVAILED  |
| 4219  | 4-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | MANDEWAL_110                                                                          | 23:58             | 23:59               | 00:01    | LINE CLEAR AVAILED  |
| 4220  | 4-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | KURUGODU_110                                                                          | 06:35             | 06:40               | 00:05    | TRIPPED ON FAULT    |
| 4221  | 4-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | HALAWARTHI_220                                                                        | 09:22             | 09:28               | 00:06    | TRIPPED ON FAULT    |
| 4222  | 4-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA       | YADGIR_110                                                                            | 13:42             | 14:20               | 00:38    | LINE CLEAR AVAILED  |
| 4223  | 4-Sep-2024 | GULBARGA | 110     | LINE        | KONKAL-RAMASAMUDRA       | KONKAL_110                                                                            | 07:50             | 10:38               | 02:48    | LINE CLEAR AVAILED  |
| 4224  | 4-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI         | KHANAPUR_110                                                                          | 00:40             | 00:45               | 00:05    | TRIPPED ON FAULT    |
| 4225  | 4-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-CHITAPUR           | CHITAPUR_110                                                                          | 04:35             | 04:44               | 00:09    | TRIPPED ON FAULT    |
| 4226  | 4-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-NALWAR            | NALWAR_110                                                                            | 19:50             | 20:10               | 00:20    | TRIPPED ON FAULT    |
| 4227  | 4-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR- SHAHAPUR 2      | GUGAL_66,GABBUR_66                                                                    | 01:25             | 01:30               | 00:05    | TRIPPED ON FAULT    |
| 4228  | 4-Sep-2024 | GULBARGA | 110     | LINE        | GABBUR-RAICHUR           | GABBUR_66,GUGAL_66                                                                    | 22:04             | 22:09               | 00:05    | TRIPPED ON FAULT    |
| 4229  | 4-Sep-2024 | GULBARGA | 110     | LINE        | SIRIGUPPA-NSL SUGAR_IPP  | SIRIGUPPA_110                                                                         | 09:50             | 21:50               | 12:00    | LINE CLEAR AVAILED  |
| 4230  | 4-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-KAMTHANA        | KAMATHANA_110                                                                         | 10:20             | 13:40               | 03:20    | LINE CLEAR AVAILED  |
| 4231  | 4-Sep-2024 | GULBARGA | 110     | LINE        | VENKATAGIRI-MUNIRABAD    | VENKATAGIRI_110                                                                       | 13:25             | 13:30               | 00:05    | MAIN SUPPLY FAILURE |
| 4232  | 4-Sep-2024 | GULBARGA | 110     | LINE        | GANGAVATHI-SULEKAL       | GANGAVATHI_110                                                                        | 13:25             | 13:30               | 00:05    | MAIN SUPPLY FAILURE |
| 4233  | 4-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-HOSAHALLI       | HOSAHALLI_66,HUDEM_66                                                                 | 06:00             | 06:15               | 00:15    | TRIPPED ON FAULT    |
| 4234  | 4-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | KOGALI_66                                                                             | 10:00             | 10:45               | 00:45    | LINE CLEAR AVAILED  |
| 4235  | 4-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | NEELAGUNDA_220                                                                        | 12:45             | 12:55               | 00:10    | TRIPPED ON FAULT    |
| 4236  | 4-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 2    | SOVENAHALLI_66,TBPCL_66                                                               | 10:00             | 16:38               | 06:38    | LINE CLEAR AVAILED  |
| 4237  | 4-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-T B HALLI         | MOREGERA_66,TB<br>HALLI_66,HAMPASAGARA_66                                             | 10:00             | 16:47               | 06:47    | LINE CLEAR AVAILED  |
| 4238  | 4-Sep-2024 | GULBARGA | 66      | LINE        | NEELAGUNDA-HARAPANAHALLI | HARAPANAHALLI_66,IPP<br>SUZLONN,NICHAPURA_66                                          | 06:10             | 06:20               | 00:10    | TRIPPED ON FAULT    |
| 4239  | 4-Sep-2024 | GULBARGA | 66      | LINE        | NEELAGUNDA-PUNABGHATA    | PUNABGHATA_66,UCHANGIDURG<br>A_66,BILCHOD_66,PALLAGATTA_6<br>6,SUZLON_66,ARASIKERE_66 | 15:52             | 16:00               | 00:08    | TRIPPED ON FAULT    |
| 4240  | 5-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                                                         | 9:21(21.05.2024)  |                     |          | LINE CLEAR AVAILED  |
| 4241  | 5-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2     | NIMBARGA_220                                                                          | 22:56(4.09.2024)  | 7:35(5.09.2024)     | 08:39    | LINE CLEAR AVAILED  |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name                                                                                                       | Open_At          | Closed_At | Duration | REMARKS             |
|-------|------------|----------|---------|-------------|-----------------------------------|--------------------------------------------------------------------------------------------------------------------|------------------|-----------|----------|---------------------|
| 4242  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SINDHNOOR-SULEKAL                 | SINDHNOOR_110,<br>GANDHINAGAR_110,WALABELLARI_110,DHADESUGUR_110,<br>SRERAMNAGAR_110,MARALIHALL A 110              | 03:06            | 03:33     | 00:27    | TRIPPED ON FAULT    |
| 4243  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SINDHNOOR-LINGSUGUR               | SINDHNOOR_110,<br>GANDHINAGAR_110,WALABELLARI_110,DHADESUGUR_110,<br>SRERAMNAGAR_110,MARALIHALL A 110,MUKKUNDA 110 | 03:06            | 03:27     | 00:21    | TRIPPED ON FAULT    |
| 4244  | 5-Sep-2024 | GULBARGA | 220     | LINE        | HALAWARTHI-DHRUVDESH              | DHRUVDESH 220                                                                                                      | 12:10            | 14:15     | 02:05    | LINE CLEAR AVAIED   |
| 4245  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2               | SHAHAPUR 220                                                                                                       | 23:59            | 07:03     | 16:56    | LINE CLEAR AVAIED   |
| 4246  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2               | SHAHAPUR 220                                                                                                       | 22:57            | 23:59     | 01:02    | LINE CLEAR AVAIED   |
| 4247  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-SHAHABAD                 | SHAHABAD 220                                                                                                       | 23:31            | 23:59     | 00:28    | LINE CLEAR AVAIED   |
| 4248  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2               | SHAHAPUR 220                                                                                                       | 22:57            | 23:59     | 01:02    | TRIPPED ON FAULT    |
| 4249  | 5-Sep-2024 | GULBARGA | 220     | LINE        | SULEKAL-KUSHTAGI                  | KUSHTAGI 220                                                                                                       | 17:03            | 17:50     | 00:47    | TRIPPED ON FAULT    |
| 4250  | 5-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | CHICKSUGUR 110                                                                                                     | 11:17            | 12:50     | 01:33    | LINE CLEAR AVAIED   |
| 4251  | 5-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                               | KURUGODU 110                                                                                                       | 16:40            | 17:20     | 00:40    | TRIPPED ON FAULT    |
| 4252  | 5-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1,HV2                           | MADALAPUR 110                                                                                                      | 09:05            | 17:50     | 08:45    | LINE CLEAR AVAIED   |
| 4253  | 5-Sep-2024 | GULBARGA | 110     | LINE        | HATTI-LINGSUGUR                   | HATTI 110                                                                                                          | 18:50            | 19:17     | 00:27    | TRIPPED ON FAULT    |
| 4254  | 5-Sep-2024 | GULBARGA | 110     | LINE        | GABBUR-RAICHUR                    | GABBUR 66                                                                                                          | 18:51            | 19:04     | 00:13    | TRIPPED ON FAULT    |
| 4255  | 5-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1 AND HV2                       | MADLAPUR 110                                                                                                       | 09:05            | 17:50     | 08:45    | LINE CLEAR AVAIED   |
| 4256  | 5-Sep-2024 | GULBARGA | 110     | LINE        | KALABURGI(UNIVERSITY)-SOUTHCKT-II | KALABURGI(UNIVERSITY)_110                                                                                          | 11:20            | 16:25     | 05:05    | LINE CLEAR AVAIED   |
| 4257  | 5-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD-2                | KAPNOOR 220                                                                                                        | 23:58            | 23:59     | 00:01    | LINE CLEAR AVAIED   |
| 4258  | 5-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD-2                | KAPNOOR 220                                                                                                        | 16:40            | 23:59     | 07:19    | LINE CLEAR AVAIED   |
| 4259  | 5-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA                | YADGIR 110                                                                                                         | 14:20            | 23:59     | 09:40    | LINE CLEAR AVAIED   |
| 4260  | 5-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-RAILWAY                  | KHANAPUR 110                                                                                                       | 23:17            | 23:25     | 00:08    | TRIPPED ON FAULT    |
| 4261  | 5-Sep-2024 | GULBARGA | 110     | LINE        | M.KOLLUR-DEODURGA                 | DEODURGA 110                                                                                                       | 05:31            | 05:37     | 00:06    | TRIPPED ON FAULT    |
| 4262  | 5-Sep-2024 | GULBARGA | 110     | LINE        | WADI-SHAHABAD                     | WADI 110                                                                                                           | 19:58            | 20:36     | 00:38    | TRIPPED ON FAULT    |
| 4263  | 5-Sep-2024 | GULBARGA | 110     | LINE        | YADRAMI-SHAHABAD                  | YADRAMI 110                                                                                                        | 19:58            | 20:55     | 00:57    | TRIPPED ON FAULT    |
| 4264  | 5-Sep-2024 | GULBARGA | 110     | LINE        | MANDEWAL-SHAHABAD                 | MANDEWAL 110                                                                                                       | 19:58            | 20:55     | 00:57    | TRIPPED ON FAULT    |
| 4265  | 5-Sep-2024 | GULBARGA | 110     | LINE        | SOMASAMUNDRA-BELLARY NORTH        | BELLARY NORTH 110                                                                                                  | 18:30            | 19:00     | 00:30    | TRIPPED ON FAULT    |
| 4266  | 5-Sep-2024 | GULBARGA | 110     | LINE        | SIRIGUPPA-TEKKALKOTE              | TEKKALKOTE 110,                                                                                                    | 05:37            | 05:50     | 00:13    | MAIN SUPPLY FAILURE |
| 4267  | 5-Sep-2024 | GULBARGA | 110     | LINE        | HALAWARTHI-KOPPAL1                | KOPPAL 110                                                                                                         | 09:16            | 16:04     | 06:48    | LINE CLEAR AVAIED   |
| 4268  | 5-Sep-2024 | GULBARGA | 110     | LINE        | HALAWARTHI-KOPPAL2                | KOPPAL 110                                                                                                         | 09:16            | 16:07     | 06:51    | LINE CLEAR AVAIED   |
| 4269  | 5-Sep-2024 | GULBARGA | 110     | LINE        | PD_HALLI_ALIPUR                   | PD_HALLI 110, MOKA 110                                                                                             | 09:55            | 16:35     | 06:40    | LINE CLEAR AVAIED   |
| 4270  | 5-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-DUBALGUNDI                 | DUBALGUNDI 110                                                                                                     | 23:59            | 10:10     | 13:49    | LINE CLEAR AVAIED   |
| 4271  | 5-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-DUBALGUNDI                 | DUBALGUNDI 110                                                                                                     | 16:30            | 23:59     | 07:29    | LINE CLEAR AVAIED   |
| 4272  | 5-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-CHITGUPPA1&2             | CHITGUPPA 110                                                                                                      | 18:50            | 19:10     | 00:20    | TRIPPED ON FAULT    |
| 4273  | 5-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                               | KUDLIGI 66                                                                                                         | 07:15            | 07:50     | 00:35    | LINE CLEAR AVAIED   |
| 4274  | 5-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                               | GUDEKOTE 66                                                                                                        | 07:30            | 08:10     | 00:40    | TRIPPED ON FAULT    |
| 4275  | 5-Sep-2024 | GULBARGA | 66      | LINE        | NEELAGUNDA-HARAPANAHALLI          | HARAPANAHALLI_66,IPP<br>SUZLONN,NICHAPURA 66                                                                       | 02:36            | 02:42     | 00:06    | TRIPPED ON FAULT    |
| 4276  | 5-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-ITTAGI 2                  | KUDLIGI 66                                                                                                         | 05:40            | 06:15     | 00:35    | TRIPPED ON FAULT    |
| 4277  | 6-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR                  | NEELGUNDA 220                                                                                                      | 9:21(21.05.2024) |           |          | LINE CLEAR AVAIED   |

| SL NO | Dinanka    | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                 | Open_At           | Closed_At        | Duration  | REMARKS             |
|-------|------------|----------|---------|-------------|--------------------------|----------------------------------------------|-------------------|------------------|-----------|---------------------|
| 4278  | 6-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                      | HALVARTHY_220                                | 13:07             | 14:05            | 00:58     | TRIPPED ON FAULT    |
| 4279  | 6-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS 2        | LINGASUGUR_220                               | 02:41             | 03:11            | 00:30     | TRIPPED ON FAULT    |
| 4280  | 6-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                  | 21:20(06.09.2024) |                  |           | LINE CLEAR AVAILED  |
| 4281  | 6-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | SHAHAPUR_220                                 | 23:59             | 07:30            | 16:29     | LINE CLEAR AVAILED  |
| 4282  | 6-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-RTPS-1          | HUMNABAD_220                                 | 03:40             | 06:13            | 02:33     | LINE CLEAR AVAILED  |
| 4283  | 6-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-SHAHABAD        | SHAHABAD_220                                 | 23:59             | 06:01            | 17:58     | LINE CLEAR AVAILED  |
| 4284  | 6-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-SEDAM2          | HUMNABAD_220                                 | 21:43             | 23:59            | 02:16     | LINE CLEAR AVAILED  |
| 4285  | 6-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-HANUMSAGAR      | HANUMSAGAR_110,HANUMNAL_110,HIREGONNAGAR_110 | 10:56             | 17:03            | 06:07     | LINE CLEAR AVAILED  |
| 4286  | 6-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-BYAGAWAT1         | BYAGAWAT_110,VALKAMDINNI_110                 | 04:48             | 04:54            | 00:06     | TRIPPED ON FAULT    |
| 4287  | 6-Sep-2024 | GULBARGA | 110     | LINE        | WALABALLARI-SINDHNOOR    | JAVALLGERA_110,WALABALLARI_110               | 09:50             | 14:40            | 04:50     | LINE CLEAR AVAILED  |
| 4288  | 6-Sep-2024 | GULBARGA | 110     | LINE        | MUNIRABAD-EMMIGANOOR     | EMMIGANOOR_110                               | 21:00             | 21:40            | 00:40     | MAIN SUPPLY FAILURE |
| 4289  | 6-Sep-2024 | GULBARGA | 110     | LINE        | MUNIRABAD-DONIMALAI      | DONIMALAI_110, RAYAKERE_110                  | 18:40             | 18:50            | 00:10     | LINE CLEAR AVAILED  |
| 4290  | 6-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-DUBALGUNDI      | DUBALGUNDI_110                               | 20:15             | 23:59            | 03:44     | TRIPPED ON FAULT    |
| 4291  | 6-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-DEVAPUR         | DEVAPUR_110                                  | 20:48             | 21:02            | 00:14     | TRIPPED ON FAULT    |
| 4292  | 6-Sep-2024 | GULBARGA | 66      | LINE        | BANAVIKAL-ABRSL WIND IPP | BANAVIKAL_66                                 | 14:35             | 14:50            | 00:15     | TRIPPED ON FAULT    |
| 4293  | 6-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HUDEM_66                                     | 16:10             | 16:20            | 00:10     | LINE CLEAR AVAILED  |
| 4294  | 6-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HB HALLI          | HB HALLI_66,BG HALLI_66                      | 09:30             | 13:50            | 04:20     | LINE CLEAR AVAILED  |
| 4295  | 6-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-RENEW 1 AND 2     | ITTAGI_220                                   | 08:45             | 09:00            | 00:15     | TRIPPED ON FAULT    |
| 4296  | 6-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-RENEW 1 AND 2     | ITTAGI_220                                   | 18:50             | 19:17            | 00:27     | TRIPPED ON FAULT    |
| 4297  | 7-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                | 9:21(21.05.2024)  |                  |           | LINE CLEAR AVAILED  |
| 4298  | 7-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2     | NIMBARGA_220                                 | 21:32(7.09.204)   |                  |           | LINE CLEAR AVAILED  |
| 4299  | 7-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                  | 21:20(06.09.2024) | 7:52(7.09.2024)  | 11:32 HRS | LINE CLEAR AVAILED  |
| 4300  | 7-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                  | 21:33(07.09.2024) |                  |           | LINE CLEAR AVAILED  |
| 4301  | 7-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-SEDAM2          | HUMNABAD_220                                 | 23:59             | 07:52            | 16:07     | LINE CLEAR AVAILED  |
| 4302  | 7-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-SEDAM2          | HUMNABAD_220                                 | 21:33             | 23:59            | 02:26     | LINE CLEAR AVAILED  |
| 4303  | 7-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-DUBALGUNDI      | DUBALGUNDI_110                               | 23:59             | 11:15            | 12:44     | TRIPPED ON FAULT    |
| 4304  | 7-Sep-2024 | GULBARGA | 110     | LINE        | RAMASAMUDRA-YADGIR       | YADGIR_110                                   | 13:03             | 13:20            | 00:17     | TRIPPED ON FAULT    |
| 4305  | 7-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR2        | GUGAL_110,GABBUR_66                          | 22:16             | 22:21            | 00:05     | TRIPPED ON FAULT    |
| 4306  | 7-Sep-2024 | GULBARGA | 66      | LINE        | HIREHADAGALI-ITTAGGI1    | HIREHADAGALLI_66,GIRIYAPURA_66               | 01:50             | 02:10            | 00:20     | TRIPPED ON FAULT    |
| 4307  | 7-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HOSAHALLI_66                                 | 11:20             | 11:25            | 00:05     | TRIPPED ON FAULT    |
| 4308  | 7-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | KUDLIGI_66                                   | 13:35             | 14:35            | 01:00     | LINE CLEAR AVAILED  |
| 4309  | 7-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | PUNABHAGATTA_66                              | 10:30             | 10:35            | 00:05     | TRIPPED ON FAULT    |
| 4310  | 8-Sep-2024 | GULBARGA | 400     | LINE        | FEROZABAD- SHAHAPUR 2    | NIMBARGA_220                                 | 21:31(08.09.2024) |                  |           | LINE CLEAR AVAILED  |
| 4311  | 8-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                      | SHAHAPUR_220                                 | 15:04             | 15:50            | 00:46     | LINE CLEAR AVAILED  |
| 4312  | 8-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                      | SHAHAPUR_220                                 | 16:25             | 18:10            | 01:45     | LINE CLEAR AVAILED  |
| 4313  | 8-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                | 9:21(21.05.2024)  |                  |           | LINE CLEAR AVAILED  |
| 4314  | 8-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS 2        | LINGASUGUR_220                               | 04:39             | 04:47            | 00:08     | TRIPPED ON FAULT    |
| 4315  | 8-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                  | 21:33(07.09.2024) | 7:05(08.09.2024) | 9:32 HRS  | LINE CLEAR AVAILED  |
| 4316  | 8-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                  | 20:55(08.09.2024) |                  |           | LINE CLEAR AVAILED  |



| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                     | Open_At           | Closed_At        | Duration  | REMARKS             |
|-------|-------------|----------|---------|-------------|--------------------------|--------------------------------------------------|-------------------|------------------|-----------|---------------------|
| 4317  | 8-Sep-2024  | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD 2     | NIMBARGA_220                                     | 21:32(7.09.204)   | 8:30(08.09.2024) | 10:58 HRS | LINE CLEAR AVAILED  |
| 4318  | 8-Sep-2024  | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | SHAHAPUR_220                                     | 23:59             | 08:30            | 15:29     | LINE CLEAR AVAILED  |
| 4319  | 8-Sep-2024  | GULBARGA | 110     | TRANSFORMER | HV3                      | SOMASAMUNDRA_110                                 | 14:45             | 15:03            | 00:18     | TRIPPED ON FAULT    |
| 4320  | 8-Sep-2024  | GULBARGA | 110     | LINE        | JAVALAGERA-WALABALLARI   | JAVALAGERA_110,WALABALLARI_110                   | 03:30             | 03:45            | 00:15     | MAIN SUPPLY FAILURE |
| 4321  | 8-Sep-2024  | GULBARGA | 110     | LINE        | GABBUR-RAICHUR           | GABBUR_110,GUGAL_110                             | 05:44             | 05:50            | 00:06     | TRIPPED ON FAULT    |
| 4322  | 8-Sep-2024  | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR2        | GUGAL                                            | 18:29             | 18:36            | 00:07     | TRIPPED ON FAULT    |
| 4323  | 8-Sep-2024  | GULBARGA | 110     | LINE        | HALBARGA-SANTHPUR        | SANTHPUR_110                                     | 20:10             | 20:55            | 00:45     | TRIPPED ON FAULT    |
| 4324  | 8-Sep-2024  | GULBARGA | 110     | LINE        | SHAHAPUR-YADGIR          | YADGIR_110                                       | 17:15             | 19:35            | 02:20     | LINE CLEAR AVAILED  |
| 4325  | 8-Sep-2024  | GULBARGA | 110     | LINE        | SHAHAPUR-KEMBHAVI        | KEMBHAVI_110                                     | 01:57             | 02:15            | 00:18     | TRIPPED ON FAULT    |
| 4326  | 8-Sep-2024  | GULBARGA | 110     | LINE        | SHAHAPUR-KEMBHAVI        | KEMBHAVI_110                                     | 03:40             | 03:47            | 00:07     | TRIPPED ON FAULT    |
| 4327  | 8-Sep-2024  | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI         | SANOTHI_110                                      | 02:40             | 02:45            | 00:05     | TRIPPED ON FAULT    |
| 4328  | 8-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV2                      | NEELGUNDA_220                                    | 13:05             | 13:15            | 00:10     | TRIPPED ON FAULT    |
| 4329  | 8-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV2                      | HARAPANAHALLI_66                                 | 16:10             | 16:15            | 00:05     | TRIPPED ON FAULT    |
| 4330  | 9-Sep-2024  | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                      | 20:55(08.09.2024) | 7:46(09.09.2024) | 10:51HRS  | LINE CLEAR AVAILED  |
| 4331  | 9-Sep-2024  | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                    | 9:21(21.05.2024)  |                  |           | LINE CLEAR AVAILED  |
| 4332  | 9-Sep-2024  | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                      | 23:59             | 07:46            | 16:13     | LINE CLEAR AVAILED  |
| 4333  | 9-Sep-2024  | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                      | 21:05             | 23:59            | 02:54     | LINE CLEAR AVAILED  |
| 4334  | 9-Sep-2024  | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD2      | SHAHAPUR_220                                     | 12:03             | 16:11            | 04:08     | LINE CLEAR AVAILED  |
| 4335  | 9-Sep-2024  | GULBARGA | 220     | LINE        | SEDAM-HUMNABAD 2         | HUMNABAD_220                                     | 21:09(9.08.2024)  |                  |           | LINE CLEAR AVAILED  |
| 4336  | 9-Sep-2024  | GULBARGA | 110     | TRANSFORMER | HV1&HV3                  | KALBURGI UNIVERSITY_110                          | 16:05             | 20:45            | 04:40     | TRIPPED ON FAULT    |
| 4337  | 9-Sep-2024  | GULBARGA | 110     | LINE        | HUMNABAD-CHITAGUPPA2     | CHITAGUPPA_110                                   | 15:50             | 17:05            | 01:15     | LINE CLEAR AVAILED  |
| 4338  | 9-Sep-2024  | GULBARGA | 110     | LINE        | RAMASAMUDRA-KONKAL       | KONKAL_110                                       | 21:53             | 22:06            | 00:13     | TRIPPED ON FAULT    |
| 4339  | 9-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV2                      | HALAVAGALU_66                                    | 13:05             | 14:00            | 00:55     | LINE CLEAR AVAILED  |
| 4340  | 9-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV1                      | KOTTUR_66                                        | 11:20             | 11:30            | 00:10     | LINE CLEAR AVAILED  |
| 4341  | 9-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV1                      | CHORNUR_66                                       | 14:35             | 14:40            | 00:05     | TRIPPED ON FAULT    |
| 4342  | 9-Sep-2024  | GULBARGA | 66      | TRANSFORMER | HV1                      | CHORNUR_66                                       | 15:40             | 15:45            | 00:05     | TRIPPED ON FAULT    |
| 4343  | 9-Sep-2024  | GULBARGA | 66      | LINE        | NEELGUNDA-HALAVAGALU     | HALAVAGALU_66, HARVI_66                          | 20:16             | 20:21            | 00:05     | TRIPPED ON FAULT    |
| 4344  | 9-Sep-2024  | GULBARGA | 66      | LINE        | KUDLIGI 220-KUDLIGI66    | KUDLIGI_66,HANSI_66,CHILAKANA HATTI_66,KOGALI_66 | 06:30             | 07:00            | 00:30     | TRIPPED ON FAULT    |
| 4345  | 10-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                    | 9:21(21.05.2024)  |                  |           | LINE CLEAR AVAILED  |
| 4346  | 10-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                      | 23:59             | 07:50            | 16:09     | LINE CLEAR AVAILED  |
| 4347  | 10-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD 2       | KAPNOOR_220                                      | 21:50             | 23:59            | 02:09     | LINE CLEAR AVAILED  |
| 4348  | 10-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS1         | LINGASUGUR_220                                   | 12:09             | 12:25            | 00:16     | TRIPPED ON FAULT    |
| 4349  | 10-Sep-2024 | GULBARGA | 220     | LINE        | LINGAPUR-GUDDADHALLI2    | LINGAPUR_220                                     | 16:34             | 20:33            | 03:59     | LINE CLEAR AVAILED  |
| 4350  | 10-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | ALAND_110                                        | 17:35             | 18:35            | 01:00     | LINE CLEAR AVAILED  |
| 4351  | 10-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | BENNEHALLI_66                                    | 06:30             | 06:50            | 00:20     | TRIPPED ON FAULT    |
| 4352  | 10-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-GULBARGA WEST2   | GULBARGA WEST_110                                | 11:08             | 12:45            | 01:37     | LINE CLEAR AVAILED  |
| 4353  | 10-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-GANAGAPUR        | MADIYAL_110, CHOWDAPUR_110                       | 23:42             | 23:59            | 00:17     | LINE CLEAR AVAILED  |
| 4354  | 10-Sep-2024 | GULBARGA | 110     | LINE        | WALABALLARI-JAWALGERA    | JAWALGERA_110                                    | 09:36             | 13:30            | 03:54     | LINE CLEAR AVAILED  |
| 4355  | 10-Sep-2024 | GULBARGA | 110     | LINE        | CHILAKANAHATTI-MUNIRABAD | CHILAKANAHATTI_110                               | 07:05             | 07:20            | 00:15     | TRIPPED ON FAULT    |
| 4356  | 10-Sep-2024 | GULBARGA | 110     | LINE        | DUBALGUNDI-HUMNABAD      | DUBALGUNDI_110                                   | 21:45             | 24:00:00         | 02:15     | LINE CLEAR AVAILED  |
| 4357  | 10-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-RAICHUR1        | JEWARGI_110, NALWAR_110                          | 22:21(10.09.2024) |                  |           | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                   | Open_At           | Closed_At        | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|--------------------------|--------------------------------|-------------------|------------------|----------|---------------------|
| 4358  | 10-Sep-2024 | GULBARGA | 110     | LINE        | CHITTAPUR-KORWARTEMPLE   | KORWARTEMPLE_110               | 22:30             | 22:40            | 00:10    | MAIN SUPPLY FAILURE |
| 4359  | 10-Sep-2024 | GULBARGA | 110     | LINE        | MANDEWAL-SHAHABAD        | MANDEWAL_110,YEDRAMI_110       | 22:30             | 22:40            | 00:10    | MAIN SUPPLY FAILURE |
| 4360  | 10-Sep-2024 | GULBARGA | 110     | LINE        | BENNEHALLI-KOTTUR        | KOTTUR_66,UJJANI_66            | 05:10             | 07:45            | 02:35    | TRIPPED ON FAULT    |
| 4361  | 10-Sep-2024 | GULBARGA | 110     | LINE        | RAMASAMUDRA-KONKAL       | KONKAL_110                     | 01:35             | 01:53            | 00:18    | TRIPPED ON FAULT    |
| 4362  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HANSI_66                       | 06:30             | 06:40            | 00:10    | TRIPPED ON FAULT    |
| 4363  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | KOGALI_66                      | 09:00             | 09:10            | 00:10    | LINE CLEAR AVAILED  |
| 4364  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                      | KUDLIGI_66                     | 17:15             | 17:30            | 00:15    | TRIPPED ON FAULT    |
| 4365  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                      | KUDLIGI_66                     | 15:50             | 16:00            | 00:10    | TRIPPED ON FAULT    |
| 4366  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HANSI_66                       | 06:30             | 06:40            | 00:10    | TRIPPED ON FAULT    |
| 4367  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | GUDEKOTE_66                    | 21:35             | 21:40            | 00:05    | TRIPPED ON FAULT    |
| 4368  | 10-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | CHORNUR_66                     | 18:00             | 18:15            | 00:15    | TRIPPED ON FAULT    |
| 4369  | 10-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-HOSAHALLI       | HOSAHALLI_66,HUDEM_66          | 09:30             | 09:55            | 00:25    | TRIPPED ON FAULT    |
| 4370  | 10-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-HANSI            | HANSI_66,CHILAKANAHATTI_66     | 07:08             | 07:18            | 00:10    | TRIPPED ON FAULT    |
| 4371  | 10-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 1    | HIREHADAGALI_66,GIRIYAPUR_66   | 16:53             | 17:03            | 00:10    | LINE CLEAR AVAILED  |
| 4372  | 11-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                      | KUSHTAGI_220                   | 12:10             | 12:50            | 00:40    | TRIPPED ON FAULT    |
| 4373  | 11-Sep-2024 | GULBARGA | 220     | LINE        | RAMASAMUDRA-RTPS2        | RTPS_220                       | 04:26             | 04:50            | 00:24    | TRIPPED ON FAULT    |
| 4374  | 11-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                  | 9:21(21.05.2024)  |                  |          | LINE CLEAR AVAILED  |
| 4375  | 11-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                    | 23:59             | 07:24            | 16:35    | LINE CLEAR AVAILED  |
| 4376  | 11-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS1         | LINGASUGUR_220                 | 16:19             | 17:40            | 01:21    | TRIPPED ON FAULT    |
| 4377  | 11-Sep-2024 | GULBARGA | 220     | LINE        | FEROZABAD-NIMBARGA       | NIMBARGA_220                   | 00:25             | 08:45            | 08:20    | LINE CLEAR AVAILED  |
| 4378  | 11-Sep-2024 | GULBARGA | 220     | LINE        | KUSHTAGI-SULEKAL         | SULEKAL_220                    | 12:10             | 12:31            | 00:21    | TRIPPED ON FAULT    |
| 4379  | 11-Sep-2024 | GULBARGA | 220     | LINE        | KUSHTAGI-SULEKAL         | SULEKAL_220                    | 12:31             | 12:48            | 00:17    | TRIPPED ON FAULT    |
| 4380  | 11-Sep-2024 | GULBARGA | 220     | LINE        | LINGAPUR-BTPS            | LINGAPUR_220                   | 09:34             | 16:15            | 06:41    | LINE CLEAR AVAILED  |
| 4381  | 11-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | MADLAPUR_110                   | 17:55             | 18:05            | 00:10    | TRIPPED ON FAULT    |
| 4382  | 11-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-RAICHUR1        | JEWARGI_110, NALWAR_110        | 22:21(10.09.2024) | 9:04(11.09.2024) | 10:43HRS | TRIPPED ON FAULT    |
| 4383  | 11-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA       | YADGIR_110                     | 10:10             | 19:15            | 09:05    | LINE CLEAR AVAILED  |
| 4384  | 11-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SIRWAL          | SIRWAL_110                     | 05:35             | 05:41            | 00:06    | TRIPPED ON FAULT    |
| 4385  | 11-Sep-2024 | GULBARGA | 110     | LINE        | NALWAR-SHAHAPUR          | NALWAR_110                     | 03:45             | 06:00            | 02:15    | MAIN SUPPLY FAILURE |
| 4386  | 11-Sep-2024 | GULBARGA | 110     | LINE        | YEDRAMI-MANDEWAL         | YEDRAMI_110                    | 02:07             | 02:20            | 00:13    | MAIN SUPPLY FAILURE |
| 4387  | 11-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-GULBARGA WEST 1  | GULBARGA WEST_110              | 02:31             | 02:50            | 00:19    | LINE CLEAR AVAILED  |
| 4388  | 11-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-GULBARGA WEST 1  | GULBARGA WEST_110              | 11:50             | 14:45            | 02:55    | LINE CLEAR AVAILED  |
| 4389  | 11-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-KOPPAL 1&2     | KOPPAL_110                     | 14:50             | 14:55            | 00:05    | LINE CLEAR AVAILED  |
| 4390  | 11-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-MARALIHALLA       | YARADONA_110, BENNUR_110       | 22:30             | 22:40            | 00:10    | LINE CLEAR AVAILED  |
| 4391  | 11-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-SULEKAL           | HANWAL_110                     | 22:30             | 22:35            | 00:05    | LINE CLEAR AVAILED  |
| 4392  | 11-Sep-2024 | GULBARGA | 110     | LINE        | MUNIRABAD-HAREKRISHNA    | MUNIRABAD_220                  | 10:12             | 11:49            | 01:37    | LINE CLEAR AVAILED  |
| 4393  | 11-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | CHORNUR_66                     | 15:00             | 15:10            | 00:10    | TRIPPED ON FAULT    |
| 4394  | 11-Sep-2024 | GULBARGA | 66      | LINE        | MUNIRABAD-CHILAKANAHATTI | CHILAKANAHATTI_66              | 06:05             | 06:23            | 00:18    | MAIN SUPPLY FAILURE |
| 4395  | 11-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI | HARAPPANAHALLI_66, SUZALON_IPP | 03:28             | 04:11            | 00:43    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                       | Station_Name                                                        | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|----------------------------|---------------------------------------------------------------------|-------------------|-----------|----------|---------------------|
| 4396  | 11-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI   | HARAPPANAHALLI_66,<br>SUZALON IPP                                   | 12:15             | 13:55     | 01:40    | LINE CLEAR AVAILED  |
| 4397  | 12-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR           | NEELGUNDA_220                                                       | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAILED  |
| 4398  | 12-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD           | HUMNABAD_220                                                        | 21:53             | 24:00:00  | 02:07    | LINE CLEAR AVAILED  |
| 4399  | 12-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS1           | LINGASUGUR_220                                                      | 04:08             | 4:22:00   | 00:14    | TRIPPED ON FAULT    |
| 4400  | 12-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS1           | LINGASUGUR_220                                                      | 04:40             | 9:05:00   | 04:25    | TRIPPED ON FAULT    |
| 4401  | 12-Sep-2024 | GULBARGA | 220     | LINE        | KUSHTAGI-SULEKAL           | SULEKAL_220                                                         | 07:04             | 9:29:00   | 02:25    | LINE CLEAR AVAILED  |
| 4402  | 12-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1&HV2                    | YAPALDANI_110                                                       | 10:20             | 14:50     | 04:30    | LINE CLEAR AVAILED  |
| 4403  | 12-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | GUGAL_110                                                           | 12:00             | 13:35     | 01:35    | LINE CLEAR AVAILED  |
| 4404  | 12-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | DONIMALAI_110                                                       | 10:00             | 14:02     | 04:02    | LINE CLEAR AVAILED  |
| 4405  | 12-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | MANDEWAL_110                                                        | 17:55             | 18:37     | 00:42    | LINE CLEAR AVAILED  |
| 4406  | 12-Sep-2024 | GULBARGA | 110     | LINE        | FARTHABAD-KALBURGI SOUTH   | FARTHABAD_110                                                       | 20:20             | 20:30     | 00:10    | TRIPPED ON FAULT    |
| 4407  | 12-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-WALABALLARI     | WALABALLARI_110                                                     | 09:45             | 14:35     | 04:50    | LINE CLEAR AVAILED  |
| 4408  | 12-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-NIRLOOTI        | SINDHANOOR_220                                                      | 20:32             | 20:42     | 00:10    | TRIPPED ON FAULT    |
| 4409  | 12-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-KOPPAL1          | KOPPAL_110                                                          | 12:46             | 13:00     | 00:14    | TRIPPED ON FAULT    |
| 4410  | 12-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-KOPPAL2          | KOPPAL_110                                                          | 12:46             | 13:10     | 00:24    | TRIPPED ON FAULT    |
| 4411  | 12-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-MADALPUR            | MADLAPUR_110, MANVI_110,<br>ADVI AMARESHWAR_110                     | 00:23             | 00:39     | 00:16    | TRIPPED ON FAULT    |
| 4412  | 12-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-ALKOD               | ALKOD_110, GALAG_110                                                | 08:26             | 09:11     | 00:45    | LINE CLEAR AVAILED  |
| 4413  | 12-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-DEVAPUR           | DEVAPUR_110, SHORAPUR_110                                           | 03:26             | 03:32     | 00:06    | TRIPPED ON FAULT    |
| 4414  | 12-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                        | HUDEM_66                                                            | 08:15             | 08:25     | 00:10    | TRIPPED ON FAULT    |
| 4415  | 12-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                        | PUNABGHATA_66                                                       | 12:05             | 12:10     | 00:05    | TRIPPED ON FAULT    |
| 4416  | 12-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                        | PUNABGHATA_66                                                       | 12:20             | 12:25     | 00:05    | TRIPPED ON FAULT    |
| 4417  | 12-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                        | HAGARIBOMMAHALLI_66                                                 | 11:15(12.09.2024) |           |          | LINE CLEAR AVAILED  |
| 4418  | 12-Sep-2024 | GULBARGA | 66      | LINE        | BADALADAKU-KUDALGI         | KOGALI_66, HANSI_66,<br>CHILAKANHATTI_66,<br>KUDALGI_66,CHORNOOR_66 | 09:25             | 18:15     | 08:50    | LINE CLEAR AVAILED  |
| 4419  | 12-Sep-2024 | GULBARGA | 66      | LINE        | BADALADAKU-CHORNOOR        | CHORNOOR_66                                                         | 09:25             | 17:25     | 08:00    | LINE CLEAR AVAILED  |
| 4420  | 12-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGGI-KUDLIGI(IDLE LINE) | KUDLIGI_66,CHORNOOR_66,GUDE<br>KOTE_66,BANVIKAL_66                  | 09:00             | 17:49     | 08:49    | LINE CLEAR AVAILED  |
| 4421  | 13-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR           | NEELGUNDA_220                                                       | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAILED  |
| 4422  | 13-Sep-2024 | GULBARGA | 220     | LINE        | HALWARTHY-MSPL2            | HALWARTHY_220                                                       | 10:24             | 12:38     | 02:14    | LINE CLEAR AVAILED  |
| 4423  | 13-Sep-2024 | GULBARGA | 220     | LINE        | LINGAPUR-GUDDADHALLI1      | LINGAPUR_220                                                        | 09:52             | 13:10     | 03:18    | LINE CLEAR AVAILED  |
| 4424  | 13-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-HUMNABAD2            | SEDAM_220                                                           | 21:38             | 23:59     | 02:21    | LINE CLEAR AVAILED  |
| 4425  | 13-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2          | KAPNOOR_220                                                         | 21:35             | 23:59     | 02:24    | LINE CLEAR AVAILED  |
| 4426  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SOMASAMUDRA_110                                                     | 19:47             | 20:07     | 00:20    | LINE CLEAR AVAILED  |
| 4427  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SOMASAMUDRA_110                                                     | 20:27             | 20:41     | 00:14    | LINE CLEAR AVAILED  |
| 4428  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SOMASAMUDRA_110                                                     | 09:29             | 19:35     | 10:06    | LINE CLEAR AVAILED  |
| 4429  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2 & HV3                  | SOMASAMUDRA_110                                                     | 09:29             | 18:40     | 09:11    | LINE CLEAR AVAILED  |
| 4430  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | CHICKSUGUR_110                                                      | 14:25             | 14:40     | 00:15    | TRIPPED ON FAULT    |
| 4431  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SIRWAR_110                                                          | 12:30             | 15:30     | 03:00    | LINE CLEAR AVAILED  |
| 4432  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                        | SIRWAR_110                                                          | 15:00             | 18:20     | 03:20    | LINE CLEAR AVAILED  |
| 4433  | 13-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | WALKAMDINNI_110                                                     | 13:05             | 18:40     | 05:35    | LINE CLEAR AVAILED  |
| 4434  | 13-Sep-2024 | GULBARGA | 110     | LINE        | ALAND-KAPNOOR              | ALAND_110                                                           | 06:00             | 06:10     | 00:10    | MAIN SUPPLY FAILURE |
| 4435  | 13-Sep-2024 | GULBARGA | 110     | LINE        | KAMPLI-MALLAPUR            | MALLAPUR_110                                                        | 10:05             | 14:35     | 04:30    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                 | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|--------------------------|----------------------------------------------|-------------------|-----------|----------|---------------------|
| 4436  | 13-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI      | YAPALDINI_110                                | 19:30             | 19:40     | 00:10    | TRIPPED ON FAULT    |
| 4437  | 13-Sep-2024 | GULBARGA | 110     | LINE        | SOMASAMUDRA-ALLIPUR      | SOMASAMUDRA_110                              | 11:39             | 13:00     | 01:21    | LINE CLEAR AVAIED   |
| 4438  | 13-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-NAGNOOR         | NAGNOOR_110                                  | 01:19             | 01:26     | 00:07    | TRIPPED ON FAULT    |
| 4439  | 13-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-KEMBHAVI        | KEMBHAVI_110                                 | 03:10             | 03:16     | 00:06    | TRIPPED ON FAULT    |
| 4440  | 13-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1      | SINDHANUR_110                                | 04:41             | 04:45     | 00:04    | TRIPPED ON FAULT    |
| 4441  | 13-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1      | SINDHANUR_110                                | 05:20             | 05:23     | 00:03    | TRIPPED ON FAULT    |
| 4442  | 13-Sep-2024 | GULBARGA | 110     | LINE        | GHATTARGA-MORATAGI       | GHATTARGA_110                                | 23:42             | 23:56     | 00:14    | MAIN SUPPLY FAILURE |
| 4443  | 13-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                      | HB HALLI_66                                  | 23:59             | 13:40     | 10:19    | LINE CLEAR AVAIED   |
| 4444  | 13-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                      | NEELGUNDA_220                                | 09:15             | 09:25     | 00:10    | TRIPPED ON FAULT    |
| 4445  | 13-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                      | KUDLIGI_66                                   | 11:10             | 11:50     | 00:40    | LINE CLEAR AVAIED   |
| 4446  | 13-Sep-2024 | GULBARGA | 66      | LINE        | BANAVIKAL-KUDLIGI        | BANAVIKAL_66,ABRSL WIND_66                   | 09:45             | 11:15     | 01:30    | LINE CLEAR AVAIED   |
| 4447  | 14-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAIED   |
| 4448  | 14-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                  | 23:59             | 06:39     | 17:20    | LINE CLEAR AVAIED   |
| 4449  | 14-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                  | 22:20             | 23:59     | 01:39    | LINE CLEAR AVAIED   |
| 4450  | 14-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2         | LINGASUGUR_220                               | 02:57             | 03:14     | 00:17    | TRIPPED ON FAULT    |
| 4451  | 14-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-HUMNABAD2          | SEDAM_220                                    | 23:59             | 06:42     | 17:17    | LINE CLEAR AVAIED   |
| 4452  | 14-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | SOMASAMUDRA_110                              | 10:48             | 11:00     | 00:12    | LINE CLEAR AVAIED   |
| 4453  | 14-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                      | MUNIRABAD_220                                | 09:01             | 16:50     | 07:49    | LINE CLEAR AVAIED   |
| 4454  | 14-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                      | MUNIRABAD_220                                | 17:53             | 18:02     | 00:09    | LINE CLEAR AVAIED   |
| 4455  | 14-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | BYAGWAT_110                                  | 10:15             | 17:00     | 06:45    | LINE CLEAR AVAIED   |
| 4456  | 14-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-TEKKALKOTE      | TEKKALKOTE_110                               | 03:55             | 04:00     | 00:05    | MAIN SUPPLY FAILURE |
| 4457  | 14-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-DUBALGUNDI        | DUBALGUNDI_110                               | 23:59             | 09:00     | 14:59    | LINE CLEAR AVAIED   |
| 4458  | 14-Sep-2024 | GULBARGA | 110     | LINE        | CHICKSUGUR-SHAKTINAGAR   | SHAKTINAGAR_110                              | 00:14             | 00:20     | 00:06    | TRIPPED ON FAULT    |
| 4459  | 14-Sep-2024 | GULBARGA | 110     | LINE        | CHICKSUGUR-SHAKTINAGAR   | SHAKTINAGAR_110                              | 02:42             | 02:45     | 00:03    | TRIPPED ON FAULT    |
| 4460  | 14-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1      | SINDHANUR_110                                | 10:21             | 15:25     | 05:04    | LINE CLEAR AVAIED   |
| 4461  | 14-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2       | GUGAL_110,GABBUR_110                         | 18:37             | 18:42     | 00:05    | TRIPPED ON FAULT    |
| 4462  | 14-Sep-2024 | GULBARGA | 110     | LINE        | NALWAR-SHAHABAD          | NALWAR_110                                   | 19:00             | 19:28     | 00:28    | MAIN SUPPLY FAILURE |
| 4463  | 14-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HUDEM_66                                     | 16:05             | 16:15     | 00:10    | LINE CLEAR AVAIED   |
| 4464  | 14-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | PUNABHAGATTA_66                              | 14:15             | 14:20     | 00:05    | TRIPPED ON FAULT    |
| 4465  | 14-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI      | HIREHADAGALI_66                              | 06:00             | 06:13     | 00:13    | TRIPPED ON FAULT    |
| 4466  | 14-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA    | PUNABGHATTA_66,<br>UCCHANGIDURGA_66          | 13:00             | 13:05     | 00:05    | TRIPPED ON FAULT    |
| 4467  | 14-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI | HARAPPANAHALLI_66                            | 01:42             | 02:00     | 00:18    | TRIPPED ON FAULT    |
| 4468  | 15-Sep-2024 | GULBARGA | 220     | LINE        | SHAHABAD-KAPNOOR         | KAPNOOR_220                                  | 22:55(15.09.2024) |           |          | LINE CLEAR AVAIED   |
| 4469  | 15-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAIED   |
| 4470  | 15-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                  | 23:59             | 06:16     | 17:43    | LINE CLEAR AVAIED   |
| 4471  | 15-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                  | 22:06             | 23:59     | 01:53    | LINE CLEAR AVAIED   |
| 4472  | 15-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | ALAND_110                                    | 11:35             | 12:30     | 00:55    | LINE CLEAR AVAIED   |
| 4473  | 15-Sep-2024 | GULBARGA | 110     | LINE        | MOKA-BALLARI NORTH       | MOKA_110                                     | 10:20             | 10:50     | 00:30    | LINE CLEAR AVAIED   |
| 4474  | 15-Sep-2024 | GULBARGA | 110     | LINE        | TEKKALKOTE-SIRGUPPA      | TEKKALKOTE_110                               | 03:53             | 04:01     | 00:08    | MAIN SUPPLY FAILURE |
| 4475  | 15-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR        | SINDHANUR_110                                | 03:25             | 03:30     | 00:05    | TRIPPED ON FAULT    |
| 4476  | 15-Sep-2024 | GULBARGA | 110     | LINE        | AFZALPUR-MORATAGI        | GHATTARAGA_110,KARAJAGI_110,<br>AFZALPUR_110 | 03:21             | 03:38     | 00:17    | MAIN SUPPLY FAILURE |
| 4477  | 15-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | BANAVIKAL_66                                 | 08:00             | 08:15     | 00:15    | TRIPPED ON FAULT    |
| 4478  | 15-Sep-2024 | GULBARGA | 66      | LINE        | HIREHADAGALI-ITTAGI1     | HIREHADAGALI_66                              | 04:04             | 04:09     | 00:05    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                   | Station_Name                   | Open_At           | Closed_At        | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|------------------------|--------------------------------|-------------------|------------------|----------|---------------------|
| 4479  | 15-Sep-2024 | GULBARGA | 66      | LINE        | TELGI-OBJ HALLI        | OBJ HALLI_66                   | 23:40             | 24:00:00         | 00:20    | TRIPPED ON FAULT    |
| 4480  | 16-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR       | NEELGUNDA_220                  | 9:21(21.05.2024)  |                  |          | LINE CLEAR AVAIED   |
| 4481  | 16-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                    | 23:59             | 06:25            | 17:34    | LINE CLEAR AVAIED   |
| 4482  | 16-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                    | 20:12             | 23:59            | 03:47    | LINE CLEAR AVAIED   |
| 4483  | 16-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2       | LINGASUGUR_220                 | 04:26             | 04:48            | 00:22    | TRIPPED ON FAULT    |
| 4484  | 16-Sep-2024 | GULBARGA | 220     | LINE        | SHAHABAD-KAPNOOR       | KAPNOOR_220                    | 22:55(15.09.2024) | 6:21(16.09.2024) | 07:26    | LINE CLEAR AVAIED   |
| 4485  | 16-Sep-2024 | GULBARGA | 110     | LINE        | GABBUR-RAICHUR         | GABBUR_110,GUGAL_110           | 21:45             | 21:50            | 00:05    | TRIPPED ON FAULT    |
| 4486  | 16-Sep-2024 | GULBARGA | 110     | LINE        | NALWAR-SHAHABAD        | NALWAR_110                     | 03:20             | 03:30            | 00:10    | MAIN SUPPLY FAILURE |
| 4487  | 16-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | HOSAHALLI_66                   | 12:40             | 12:50            | 00:10    | TRIPPED ON FAULT    |
| 4488  | 16-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | HOSAHALLI_66                   | 12:40             | 12:50            | 00:10    | TRIPPED ON FAULT    |
| 4489  | 16-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-HANSI          | HANSI_66,CHILAKANAHATTI_66     | 13:20             | 13:30            | 00:10    | MAIN SUPPLY FAILURE |
| 4490  | 16-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HUVINAHADAGALI  | HUVINAHADAGALI_66,HOLAGUNDI_66 | 01:47             | 01:57            | 00:10    | TRIPPED ON FAULT    |
| 4491  | 16-Sep-2024 | GULBARGA | 66      | LINE        | TELGI-OBJ HALLI        | OBJ HALLI_66                   | 05:35             | 5:45:00          | 00:10    | TRIPPED ON FAULT    |
| 4492  | 17-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                    | ITTAGI_220                     | 09:08             | 18:10            | 09:02    | LINE CLEAR AVAIED   |
| 4493  | 17-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                    | ITTAGI_220                     | 13:45             | 13:55            | 00:10    | TRIPPED ON FAULT    |
| 4494  | 17-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR       | NEELGUNDA_220                  | 9:21(21.05.2024)  |                  |          | LINE CLEAR AVAIED   |
| 4495  | 17-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                    | 23:59             | 06:25            | 17:34    | LINE CLEAR AVAIED   |
| 4496  | 17-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                    | 21:34             | 23:59            | 02:25    | LINE CLEAR AVAIED   |
| 4497  | 17-Sep-2024 | GULBARGA | 220     | LINE        | HALWARTHY-MSPL2        | HALWARTHY_220                  | 11:25             | 15:26            | 04:01    | LINE CLEAR AVAIED   |
| 4498  | 17-Sep-2024 | GULBARGA | 220     | LINE        | HUMNABAD-SEDAM1        | HUMNABAD_220                   | 18:50             | 19:43            | 00:53    | TRIPPED ON FAULT    |
| 4499  | 17-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                    | VENKATAGIRI_110                | 09:55             | 10:00            | 00:05    | LINE CLEAR AVAIED   |
| 4500  | 17-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                    | VENKATAGIRI_110                | 10:00             | 10:50            | 00:50    | LINE CLEAR AVAIED   |
| 4501  | 17-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                    | VENKATAGIRI_110                | 15:25             | 16:40            | 01:15    | LINE CLEAR AVAIED   |
| 4502  | 17-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1    | SINDHANUR_110                  | 01:10             | 01:15            | 00:05    | TRIPPED ON FAULT    |
| 4503  | 17-Sep-2024 | GULBARGA | 110     | LINE        | CHITTAPUR-SEDAM        | CHITTAPUR_110                  | 18:50             | 19:05            | 00:15    | MAIN SUPPLY FAILURE |
| 4504  | 17-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1    | SINDHANUR_110                  | 05:05             | 05:13            | 00:08    | TRIPPED ON FAULT    |
| 4505  | 17-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR2 | SINDHANOOR_110                 | 20:34             | 20:44            | 00:10    | TRIPPED ON FAULT    |
| 4506  | 17-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SUZALON     | SINDHANOOR_220                 | 22:02             | 22:17            | 00:15    | TRIPPED ON FAULT    |
| 4507  | 17-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SUZALON     | SINDHANOOR_220                 | 22:39             | 23:04            | 00:25    | TRIPPED ON FAULT    |
| 4508  | 17-Sep-2024 | GULBARGA | 110     | LINE        | KANAKAGIRI-NAVALI      | NAVALI_110                     | 00:40             | 00:50            | 00:10    | TRIPPED ON FAULT    |
| 4509  | 17-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-GINIGERA     | GINIGERA_110                   | 13:09             | 13:20            | 00:11    | LINE CLEAR AVAIED   |
| 4510  | 17-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-LINGAPUR2    | HALWARTHY_220                  | 10:42             | 16:24            | 05:42    | LINE CLEAR AVAIED   |
| 4511  | 17-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-MARALIHALLA     | YARADONA_110, BENNUR_110       | 19:45             | 19:55            | 00:10    | TRIPPED ON FAULT    |
| 4512  | 17-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-HALBARGA        | BHALKI_110                     | 05:43             | 05:55            | 00:12    | TRIPPED ON FAULT    |
| 4513  | 17-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-ITTAGI 2       | KUDLIGI_66                     | 05:35             | 05:40            | 00:05    | TRIPPED ON FAULT    |
| 4514  | 17-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | GUDEKOTE_66                    | 06:20             | 06:30            | 00:10    | TRIPPED ON FAULT    |
| 4515  | 17-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | CHORNUR_66                     | 17:05             | 17:15            | 00:10    | TRIPPED ON FAULT    |
| 4516  | 18-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR       | NEELGUNDA_220                  | 9:21(21.05.2024)  |                  |          | LINE CLEAR AVAIED   |
| 4517  | 18-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                    | 23:59             | 06:30            | 17:29    | LINE CLEAR AVAIED   |
| 4518  | 18-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                    | GABBUR_110                     | 08:30             | 17:20            | 08:50    | TRIPPED ON FAULT    |
| 4519  | 18-Sep-2024 | GULBARGA | 110     | LINE        | ALAND-KADAGANCHI       | KADAGANCHI_110                 | 18:50             | 19:40            | 00:50    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                 | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|--------------------------|----------------------------------------------|------------------|-----------|----------|---------------------|
| 4520  | 18-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-GANDHINAGAR   | GANDHINAGAR_110                              | 10:15            | 13:18     | 03:03    | LINE CLEAR AVAILED  |
| 4521  | 18-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR3   | SINDHANOOR_110                               | 11:20            | 13:05     | 01:45    | LINE CLEAR AVAILED  |
| 4522  | 18-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-HIRESINDHOGI   | HIRESINDHOGI_110                             | 10:49            | 17:06     | 06:17    | LINE CLEAR AVAILED  |
| 4523  | 18-Sep-2024 | GULBARGA | 110     | LINE        | KAMPLI-MALLAPUR          | MALLAPUR_110                                 | 18:20            | 19:04     | 00:44    | MAIN SUPPLY FAILURE |
| 4524  | 18-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-MADLAPUR          | MADLAPUR_110, MANVI_110, ADAVIAMARESHWAR_110 | 00:17            | 00:30     | 00:13    | TRIPPED ON FAULT    |
| 4525  | 18-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-BAGEWADI2       | AFZALPUR_110, KARAJAGI_110                   | 19:36            | 19:38     | 00:02    | MAIN SUPPLY FAILURE |
| 4526  | 18-Sep-2024 | GULBARGA | 110     | LINE        | APMC-RAICHUR 2           | APMC_110,CHICKSUGUR_110,SHA KTINAGAR_110     | 10:45            | 16:13     | 05:28    | LINE CLEAR AVAILED  |
| 4527  | 18-Sep-2024 | GULBARGA | 110     | LINE        | APMC-RAICHUR 2           | APMC_110,CHICKSUGUR_110,SHA KTINAGAR_110     | 19:23            | 19:50     | 00:27    | LINE CLEAR AVAILED  |
| 4528  | 18-Sep-2024 | GULBARGA | 110     | LINE        | KOLLUR-DEODURGA          | KOLLUR_110                                   | 16:27            | 17:02     | 00:35    | LINE CLEAR AVAILED  |
| 4529  | 18-Sep-2024 | GULBARGA | 110     | LINE        | KOLLUR-SHAHAPUR 1        | KOLLUR_110                                   | 17:10            | 17:38     | 00:28    | LINE CLEAR AVAILED  |
| 4530  | 18-Sep-2024 | GULBARGA | 110     | LINE        | KOLLUR-SHAHAPUR 1        | KOLLUR_110                                   | 18:17            | 18:33     | 00:16    | TRIPPED ON FAULT    |
| 4531  | 18-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | CHORNUR_66                                   | 11:15            | 11:40     | 00:25    | TRIPPED ON FAULT    |
| 4532  | 18-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | CHORNUR_66                                   | 16:05            | 16:25     | 00:20    | TRIPPED ON FAULT    |
| 4533  | 18-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HUVINAHADAGALI    | HUVINAHADAGALI_66                            | 18:48            | 18:52     | 00:04    | TRIPPED ON FAULT    |
| 4534  | 18-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 1    | HIREHADAGALI_66,GIRIYAPUR_66                 | 11:40            | 13:28     | 01:48    | LINE CLEAR AVAILED  |
| 4535  | 18-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI | HARAPPANAHALLI_66                            | 05:55            | 05:59     | 00:04    | TRIPPED ON FAULT    |
| 4536  | 18-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HALVAGALU      | HALAVAGALU_66, HARVI_66                      | 18:23            | 18:30     | 00:07    | TRIPPED ON FAULT    |
| 4537  | 19-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                      | ITTAGI_220                                   | 14:03            | 14:16     | 00:13    | TRIPPED ON FAULT    |
| 4538  | 19-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                | 9:21(21.05.2024) |           |          | LINE CLEAR AVAILED  |
| 4539  | 19-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                  | 23:59            | 06:30     | 17:29    | LINE CLEAR AVAILED  |
| 4540  | 19-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD       | NIMBARGA_220                                 | 17:15            | 19:04     | 01:49    | LINE CLEAR AVAILED  |
| 4541  | 19-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                      | APMC_110                                     | 10:00            | 13:10     | 03:10    | LINE CLEAR AVAILED  |
| 4542  | 19-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | APMC_110                                     | 10:00            | 17:00     | 07:00    | LINE CLEAR AVAILED  |
| 4543  | 19-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | YADGIR_110                                   | 22:15            | 22:20     | 00:05    | TRIPPED ON FAULT    |
| 4544  | 19-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | KURUGODU_110                                 | 11:37            | 11:55     | 00:18    | LINE CLEAR AVAILED  |
| 4545  | 19-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | YADGIR_110                                   | 22:15            | 22:20     | 00:05    | TRIPPED ON FAULT    |
| 4546  | 19-Sep-2024 | GULBARGA | 110     | LINE        | APMC-RAICHUR 2           | APMC_110,CHICKSUGUR_110,SHA KTINAGAR_110     | 10:50            | 13:20     | 02:30    | LINE CLEAR AVAILED  |
| 4547  | 19-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-DUBALGUNDI        | DUBALGUNDI_110                               | 04:08            | 04:18     | 00:10    | TRIPPED ON FAULT    |
| 4548  | 19-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA       | YADGIR_110                                   | 23:59            | 10:05     | 13:54    | LINE CLEAR AVAILED  |
| 4549  | 19-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-MARALIHALLA   | MUKUNDA_110                                  | 10:15            | 15:15     | 05:00    | LINE CLEAR AVAILED  |
| 4550  | 19-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | CHORNUR_66                                   | 13:30            | 13:35     | 00:05    | TRIPPED ON FAULT    |
| 4551  | 19-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | PUNABHAGATTA_66                              | 08:20            | 08:30     | 00:10    | TRIPPED ON FAULT    |
| 4552  | 19-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | BENNEHALLI_66                                | 14:30            | 16:20     | 01:50    | LINE CLEAR AVAILED  |
| 4553  | 19-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | BENNEHALLI_66                                | 14:30            | 16:50     | 02:20    | LINE CLEAR AVAILED  |
| 4554  | 19-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI_CJ HALLI         | CJ HALLI_66,HOSAHALLI_66,HUDEM_66            | 15:20            | 18:30     | 03:10    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                                                           | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|--------------------------|------------------------------------------------------------------------|------------------|-----------|----------|---------------------|
| 4555  | 19-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI_CJ HALLI         | CJ<br>HALLI_66,HOSAHALLI_66,HUDEM_66                                   | 18:35            | 18:40     | 00:05    | LINE CLEAR AVAIED   |
| 4556  | 19-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 1    | HIREHADAGALI_66,GIRIYAPUR_66                                           | 14:03            | 14:45     | 00:42    | TRIPPED ON FAULT    |
| 4557  | 19-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 2    | SOVENAHALLI_66,TUNGABHADRA_66,MAGALA_66                                | 14:03            | 14:18     | 00:15    | TRIPPED ON FAULT    |
| 4558  | 19-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA    | PUNABGHATTA_66,<br>ARASIKERE_66,<br>UCCHANGIDURGA_66,<br>PALLAGATTE_66 | 15:06            | 15:15     | 00:09    | TRIPPED ON FAULT    |
| 4559  | 20-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                      | ITTAGI_220                                                             | 11:18            | 11:31     | 00:13    | TRIPPED ON FAULT    |
| 4560  | 20-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                                                          | 9:21(21.05.2024) |           |          | LINE CLEAR AVAIED   |
| 4561  | 20-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                                                            | 21:28            | 23:59     | 02:31    | LINE CLEAR AVAIED   |
| 4562  | 20-Sep-2024 | GULBARGA | 220     | LINE        | NIMBARGA-FEROZABAD2      | NIMBARGA_220                                                           | 16:10            | 17:30     | 01:20    | LINE CLEAR AVAIED   |
| 4563  | 20-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-KUSHTAGI      | KUSHTAGI_220                                                           | 11:20            | 17:27     | 06:07    | LINE CLEAR AVAIED   |
| 4564  | 20-Sep-2024 | GULBARGA | 220     | LINE        | HALWARTHY-X-INDIA_IPP    | HALWARTHY_220                                                          | 10:52            | 16:10     | 05:18    | LINE CLEAR AVAIED   |
| 4565  | 20-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-ORIENT CEMENT      | SEDAM_220                                                              | 11:00            | 13:10     | 02:10    | LINE CLEAR AVAIED   |
| 4566  | 20-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | CHICKSUGUR_110                                                         | 15:11            | 15:44     | 00:33    | TRIPPED ON FAULT    |
| 4567  | 20-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | MARGUTTI_110                                                           | 11:42            | 11:47     | 00:05    | TRIPPED ON FAULT    |
| 4568  | 20-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | DONIMALAI_110                                                          | 09:05            | 15:25     | 06:20    | LINE CLEAR AVAIED   |
| 4569  | 20-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | SHAHAPUR_220                                                           | 15:38            | 15:48     | 00:10    | TRIPPED ON FAULT    |
| 4570  | 20-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-CHINCHOLI 1        | CHINCHOLI_110                                                          | 14:58            | 16:38     | 01:40    | LINE CLEAR AVAIED   |
| 4571  | 20-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2       | GUGAL_110,GABBUR_110                                                   | 21:40            | 21:45     | 00:05    | TRIPPED ON FAULT    |
| 4572  | 20-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-MAHAGOAN         | MAHAGOAN_110, MARGUTTI_110                                             | 20:31            | 20:46     | 00:15    | TRIPPED ON FAULT    |
| 4573  | 20-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-DHADESUGUR    | DHADESUGUR_110                                                         | 06:22            | 06:32     | 00:10    | TRIPPED ON FAULT    |
| 4574  | 20-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR2   | SINDHANOOR_110                                                         | 18:34            | 18:47     | 00:13    | TRIPPED ON FAULT    |
| 4575  | 20-Sep-2024 | GULBARGA | 110     | LINE        | LINGASUGUR-HATTI         | HATTI_110                                                              | 19:09            | 19:40     | 00:31    | LINE CLEAR AVAIED   |
| 4576  | 20-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL2          | ILKAL_110                                                              | 18:06            | 18:25     | 00:19    | TRIPPED ON FAULT    |
| 4577  | 20-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL2          | ILKAL_110                                                              | 18:36            | 18:43     | 00:07    | TRIPPED ON FAULT    |
| 4578  | 20-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-HAREKRISHNA    | HAREKRISHNA_110                                                        | 16:36            | 16:58     | 00:22    | LINE CLEAR AVAIED   |
| 4579  | 20-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-MARALIHALLA       | YARDONA_110, BENNUR_110                                                | 14:57            | 15:07     | 00:10    | TRIPPED ON FAULT    |
| 4580  | 20-Sep-2024 | GULBARGA | 110     | LINE        | SHORAPUR-SHAHAPUR        | SHORAPUR_110                                                           | 20:34            | 20:39     | 00:05    | TRIPPED ON FAULT    |
| 4581  | 20-Sep-2024 | GULBARGA | 110     | LINE        | TEKKALKOTE-SIRGUPPA      | TEKKALKOTE_110                                                         | 06:20            | 06:34     | 00:14    | MAIN SUPPLY FAILURE |
| 4582  | 20-Sep-2024 | GULBARGA | 110     | LINE        | TEKKALKOTE-SIRGUPPA      | TEKKALKOTE_110                                                         | 10:31            | 15:20     | 04:49    | LINE CLEAR AVAIED   |
| 4583  | 20-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-MANEKHALLI      | MANEKHALLI_110                                                         | 23:16            | 23:23     | 00:07    | TRIPPED ON FAULT    |
| 4584  | 20-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-SHAHAPUR          | YADGIR_110                                                             | 23:59            | 13:40     | 10:19    | LINE CLEAR AVAIED   |
| 4585  | 20-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-SHAHAPUR          | YADGIR_110                                                             | 19:20            | 23:59     | 04:39    | LINE CLEAR AVAIED   |
| 4586  | 20-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | UCCHANGIDURGA_66                                                       | 09:20            | 09:25     | 00:05    | TRIPPED ON FAULT    |
| 4587  | 20-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | PUNABHAGATTA_66                                                        | 09:15            | 09:20     | 00:05    | TRIPPED ON FAULT    |
| 4588  | 20-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI | HARAPPANAHALLI_110                                                     | 06:00            | 06:06     | 00:06    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                       | Station_Name                                                           | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|----------------------------|------------------------------------------------------------------------|------------------|-----------|----------|---------------------|
| 4589  | 20-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HARAPPANAHALLI   | HARAPPANAHALLI_110                                                     | 08:45            | 16:40     | 07:55    | LINE CLEAR AVAILED  |
| 4590  | 20-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA      | PUNABGHATTA_66,<br>ARASIKERE_66,<br>UCCHANGIDURGA_66,<br>PALLAGATTE_66 | 13:09            | 13:37     | 00:28    | TRIPPED ON FAULT    |
| 4591  | 20-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-KUDLIGI           | CJ<br>HALLI_66,HOSAHALLI_66,HUDEM_66                                   | 11:05            | 12:15     | 01:10    | LINE CLEAR AVAILED  |
| 4592  | 20-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-KUDLIGI           | CJ<br>HALLI_66,HOSAHALLI_66,HUDEM_66                                   | 12:25            | 12:30     | 00:05    | LINE CLEAR AVAILED  |
| 4593  | 20-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-HOSAHALLI         | HOSAHALLI_66,HUDEM_66                                                  | 14:25            | 14:35     | 00:10    | TRIPPED ON FAULT    |
| 4594  | 20-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-HOSAHALLI         | HOSAHALLI_66,HUDEM_66                                                  | 14:45            | 17:45     | 03:00    | LINE CLEAR AVAILED  |
| 4595  | 20-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-REVIEW SOLAR 1      | ITTAGI_66                                                              | 18:35            | 18:52     | 00:17    | TRIPPED ON FAULT    |
| 4596  | 20-Sep-2024 | GULBARGA | 66      | LINE        | UCCHANGIDURGA-BILCHODU     | BILCHODU_66                                                            | 13:10            | 14:10     | 01:00    | TRIPPED ON FAULT    |
| 4597  | 20-Sep-2024 | GULBARGA | 66      | LINE        | UCCHANGIDURGA-PUNABHAGATTA | UCCHANGIDURGA_66                                                       | 15:00            | 15:10     | 00:10    | TRIPPED ON FAULT    |
| 4598  | 20-Sep-2024 | GULBARGA | 66      | LINE        | PUNABHAGATTA-NEELAGUNDA    | PUNABHAGATTA_66,UCCHANGIDURGA_66                                       | 12:50            | 12:55     | 00:05    | TRIPPED ON FAULT    |
| 4599  | 21-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR           | NEELGUNDA_220                                                          | 9:21(21.05.2024) |           |          | LINE CLEAR AVAILED  |
| 4600  | 21-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                        | KUSHTAGI_220                                                           | 08:40            | 14:40     | 06:00    | LINE CLEAR AVAILED  |
| 4601  | 21-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                        | KUSHTAGI_220                                                           | 02:27            | 08:40     | 06:13    | TRIPPED ON FAULT    |
| 4602  | 21-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2          | KAPNOOR_220                                                            | 23:59            | 06:25     | 17:34    | LINE CLEAR AVAILED  |
| 4603  | 21-Sep-2024 | GULBARGA | 220     | LINE        | RAMASAMUDRA-SEDAM          | RAMASAMUDRA_220                                                        | 10:30            | 14:54     | 04:24    | LINE CLEAR AVAILED  |
| 4604  | 21-Sep-2024 | GULBARGA | 220     | LINE        | HALWARTHY-DONI1            | HALWARTHY_220                                                          | 11:07            | 14:45     | 03:38    | LINE CLEAR AVAILED  |
| 4605  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | KALBURGI NORTH_110                                                     | 11:01            | 14:11     | 03:10    | LINE CLEAR AVAILED  |
| 4606  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV4                        | ALLIPUR_220                                                            | 20:32            | 20:42     | 00:10    | TRIPPED ON FAULT    |
| 4607  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                        | SHAKTINAGAR_110                                                        | 08:16            | 09:20     | 01:04    | TRIPPED ON FAULT    |
| 4608  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                        | SHAKTINAGAR_110                                                        | 09:20            | 19:49     | 10:29    | LINE CLEAR AVAILED  |
| 4609  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SIRWAR_110                                                             | 08:25            | 09:30     | 01:05    | TRIPPED ON FAULT    |
| 4610  | 21-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                        | SIRWAR_110                                                             | 20:45            | 22:05     | 01:20    | TRIPPED ON FAULT    |
| 4611  | 21-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-NIRLOOTI_IPP    | SINDHANOOR_220                                                         | 21:33            | 21:43     | 00:10    | TRIPPED ON FAULT    |
| 4612  | 21-Sep-2024 | GULBARGA | 110     | LINE        | JAWALGERA-VALABALLARI      | JAWALGERA_110                                                          | 09:40            | 14:20     | 04:40    | LINE CLEAR AVAILED  |
| 4613  | 21-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL 1&2         | ILKAL_110                                                              | 10:05            | 16:30     | 06:25    | LINE CLEAR AVAILED  |
| 4614  | 21-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL 1&2         | ILKAL_110                                                              | 10:10            | 16:30     | 06:20    | LINE CLEAR AVAILED  |
| 4615  | 21-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL 1&2         | ILKAL_110                                                              | 22:45            | 23:10     | 00:25    | TRIPPED ON FAULT    |
| 4616  | 21-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-MUNIRABAD        | MUNIRABAD_110 (HAREKRISHNA)                                            | 14:23            | 14:54     | 00:31    | TRIPPED ON FAULT    |
| 4617  | 21-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-DHADESUGUR        | TEKKALKOTE_110                                                         | 16:45            | 17:01     | 00:16    | MAIN SUPPLY FAILURE |
| 4618  | 21-Sep-2024 | GULBARGA | 110     | LINE        | BISILHALLI-BALLARI NORTH   | BALLARI NORTH_110                                                      | 11:54            | 18:32     | 06:38    | LINE CLEAR AVAILED  |
| 4619  | 21-Sep-2024 | GULBARGA | 110     | LINE        | MUNIRABAD-MALLAPUR         | KEREHALLI_110                                                          | 10:01            | 14:14     | 04:13    | LINE CLEAR AVAILED  |
| 4620  | 21-Sep-2024 | GULBARGA | 110     | LINE        | DONGARGAON-AURAD           | AURAD_110                                                              | 06:20            | 06:30     | 00:10    | TRIPPED ON FAULT    |
| 4621  | 21-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-KEMBHAVI          | KEMBHAVI_110                                                           | 04:27            | 04:40     | 00:13    | TRIPPED ON FAULT    |
| 4622  | 21-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR2         | SHAHAPUR_110                                                           | 09:49            | 16:37     | 06:48    | LINE CLEAR AVAILED  |



| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                  | Station_Name                                    | Open_At           | Closed_At         | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|-----------------------|-------------------------------------------------|-------------------|-------------------|----------|---------------------|
| 4623  | 21-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR1    | SHAHAPUR_110                                    | 11:08             | 16:52             | 05:44    | LINE CLEAR AVAILED  |
| 4624  | 21-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI      | SANOTHI_110                                     | 20:29             | 20:34             | 00:05    | TRIPPED ON FAULT    |
| 4625  | 21-Sep-2024 | GULBARGA | 110     | LINE        | ALKOD-MALLAT          | ALKOD_110                                       | 20:28             | 20:38             | 00:10    | TRIPPED ON FAULT    |
| 4626  | 21-Sep-2024 | GULBARGA | 110     | LINE        | DONGARGAON-AURAD      | AURAD_110                                       | 06:20             | 06:30             | 00:10    | TRIPPED ON FAULT    |
| 4627  | 21-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI      | KHANAPUR_110                                    | 20:29             | 20:34             | 00:05    | TRIPPED ON FAULT    |
| 4628  | 21-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-SANTHPUR     | SANTHPUR_110                                    | 06:19             | 09:15             | 02:56    | LINE CLEAR AVAILED  |
| 4629  | 21-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                   | KUDLIGI_66                                      | 19:12(21.09.2024) |                   |          | LINE CLEAR AVAILED  |
| 4630  | 21-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                   | HALAVAGALU_66                                   | 08:10             | 08:15             | 00:05    | TRIPPED ON FAULT    |
| 4631  | 22-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR      | NEELGUNDA_220                                   | 9:21(21.05.2024)  |                   |          | LINE CLEAR AVAILED  |
| 4632  | 22-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                   | VENKATAGIRI_110                                 | 15:40             | 15:45             | 00:05    | TRIPPED ON FAULT    |
| 4633  | 22-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV4                   | ALLIPUR_220                                     | 18:31             | 18:45             | 00:14    | TRIPPED ON FAULT    |
| 4634  | 22-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                   | SIRWAR_110                                      | 01:25             | 02:05             | 00:40    | TRIPPED ON FAULT    |
| 4635  | 22-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                   | SHAKTINAGAR_110                                 | 12:36             | 13:15             | 00:39    | LINE CLEAR AVAILED  |
| 4636  | 22-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-DHADESUGUR | DHADESUGUR_110,<br>SIRGUPPA_110, TEKKALKOTE_110 | 22:39             | 22:49             | 00:10    | TRIPPED ON FAULT    |
| 4637  | 22-Sep-2024 | GULBARGA | 110     | LINE        | WALABALLARI-JAWALGERA | JAWALGERA_110                                   | 22:25             | 22:30             | 00:05    | TRIPPED ON FAULT    |
| 4638  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-SULEKAL        | HANWAL_110                                      | 19:40             | 19:45             | 00:05    | TRIPPED ON FAULT    |
| 4639  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-SULEKAL        | HANWAL_110                                      | 20:27             | 20:32             | 00:05    | TRIPPED ON FAULT    |
| 4640  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-MARALIHALLA    | YARADONA_110, BENNUR_110                        | 19:40             | 19:51             | 00:11    | TRIPPED ON FAULT    |
| 4641  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HANWAL-MARALIHALLA    | YARADONA_110, BENNUR_110                        | 20:27             | 20:38             | 00:11    | TRIPPED ON FAULT    |
| 4642  | 22-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-DHADESUGUR   | TEKKALKOTE_110                                  | 00:15             | 00:22             | 00:07    | TRIPPED ON FAULT    |
| 4643  | 22-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-DHADESUGUR   | TEKKALKOTE_110                                  | 03:09             | 03:19             | 00:10    | TRIPPED ON FAULT    |
| 4644  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-CHITGUPPA2   | CHITGUPPA_110                                   | 06:15             | 06:40             | 00:25    | TRIPPED ON FAULT    |
| 4645  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-ALAND        | ALAND_110                                       | 06:15             | 06:36             | 00:21    | TRIPPED ON FAULT    |
| 4646  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HUMNABAD-MANEKHELLI   | MANEKHELLI_110                                  | 06:15             | 06:34             | 00:19    | TRIPPED ON FAULT    |
| 4647  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-BHALKI       | BHALKI_110                                      | 05:42             | 05:55             | 00:13    | TRIPPED ON FAULT    |
| 4648  | 22-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-SANTHPUR     | SANTHPUR_110                                    | 05:56             | 06:15             | 00:19    | TRIPPED ON FAULT    |
| 4649  | 22-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-KEMBHAVI     | KEMBHAVI_110                                    | 20:40             | 20:58             | 00:18    | TRIPPED ON FAULT    |
| 4650  | 22-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI      | SANOTHI_110                                     | 03:30             | 03:35             | 00:05    | TRIPPED ON FAULT    |
| 4651  | 22-Sep-2024 | GULBARGA | 110     | LINE        | YEDRAMI-MANDEWAL      | MANDEWAL_110                                    | 19:54             | 20:09             | 00:15    | MAIN SUPPLY FAILURE |
| 4652  | 22-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2    | GUGAL_110,GABBUR_110                            | 17:59             | 18:05             | 00:06    | TRIPPED ON FAULT    |
| 4653  | 22-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1   | SINDHANUR_110                                   | 20:25             | 20:31             | 00:06    | TRIPPED ON FAULT    |
| 4654  | 22-Sep-2024 | GULBARGA | 110     | LINE        | ALKOD-MALLAT          | ALKOD_110                                       | 07:06             | 07:15             | 00:09    | TRIPPED ON FAULT    |
| 4655  | 22-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI      | KHANAPUR_110                                    | 03:30             | 03:35             | 00:05    | TRIPPED ON FAULT    |
| 4656  | 22-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                   | KUDLIGI_66                                      | 19:12(21.09.2024) | 13:00(22.09.2024) | 17:48    | LINE CLEAR AVAILED  |
| 4657  | 22-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                   | KOGALI_66                                       | 08:25             | 08:30             | 00:05    | TRIPPED ON FAULT    |
| 4658  | 22-Sep-2024 | GULBARGA | 66      | LINE        | TELGI-YARGUNTA        | OBJ HALLI_66                                    | 14:15             | 15:40             | 01:25    | TRIPPED ON FAULT    |
| 4659  | 22-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                   | CHICKSUGUR_110                                  | 11:40             | 12:34             | 00:54    | TRIPPED ON FAULT    |
| 4660  | 23-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR      | NEELGUNDA_220                                   | 9:21(21.05.2024)  |                   |          | LINE CLEAR AVAILED  |
| 4661  | 23-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD1     | KAPNOOR_220                                     | 12:47             | 14:55             | 02:08    | LINE CLEAR AVAILED  |
| 4662  | 23-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2     | KAPNOOR_220                                     | 22:41             | 23:59             | 01:18    | LINE CLEAR AVAILED  |
| 4663  | 23-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2      | LINGASUGUR_220                                  | 05:29             | 05:55             | 00:26    | TRIPPED ON FAULT    |
| 4664  | 23-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-SHAHAPUR   | SHAHAPUR_220                                    | 12:34             | 14:20             | 01:46    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                         | Station_Name                | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|------------------------------|-----------------------------|------------------|-----------|----------|---------------------|
| 4665  | 23-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                          | LINGASUGUR_220              | 15:26            | 17:35     | 02:09    | LINE CLEAR AVAILED  |
| 4666  | 23-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR- B BAGEWADI2      | LINGASUGUR_220              | 10:44            | 17:48     | 07:04    | LINE CLEAR AVAILED  |
| 4667  | 23-Sep-2024 | GULBARGA | 110     | LINE        | SOUTH-FARTHABAD              | FARTHABAD_110               | 17:18            | 17:40     | 00:22    | TRIPPED ON FAULT    |
| 4668  | 23-Sep-2024 | GULBARGA | 110     | LINE        | KALBURGI UNIVERSITY-NANDLOOR | NANDLOOR_110                | 17:30            | 23:59     | 06:29    | TRIPPED ON FAULT    |
| 4669  | 23-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | MAHAGOAN_110                | 10:00            | 14:10     | 04:10    | LINE CLEAR AVAILED  |
| 4670  | 23-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-DADESUGUR         | DADESUGUR_110, SIRGUPPA_110 | 00:12            | 00:22     | 00:10    | TRIPPED ON FAULT    |
| 4671  | 23-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-DADESUGUR         | DADESUGUR_110, SIRGUPPA_110 | 03:08            | 03:18     | 00:10    | TRIPPED ON FAULT    |
| 4672  | 23-Sep-2024 | GULBARGA | 110     | LINE        | LINGASUGUR-MUDGAL            | MUDGAL_110                  | 12:05            | 12:38     | 00:33    | TRIPPED ON FAULT    |
| 4673  | 23-Sep-2024 | GULBARGA | 110     | LINE        | CHILAKMUKHI-BEVOOR           | CHILAKMUKHI_110             | 16:05            | 16:15     | 00:10    | MAIN SUPPLY FAILURE |
| 4674  | 23-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | MOKA_110                    | 06:50            | 07:00     | 00:10    | TRIPPED ON FAULT    |
| 4675  | 23-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | MOKA_110                    | 07:10            | 07:25     | 00:15    | TRIPPED ON FAULT    |
| 4676  | 23-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | BISILHALLI_110              | 05:33            | 06:24     | 00:51    | TRIPPED ON FAULT    |
| 4677  | 23-Sep-2024 | GULBARGA | 110     | LINE        | RAMASAMUDRA-YADGIR           | YADGIR_110                  | 11:50            | 12:15     | 00:25    | TRIPPED ON FAULT    |
| 4678  | 23-Sep-2024 | GULBARGA | 110     | LINE        | KOLLUR-DEVDURGA              | KOLLUR_110                  | 03:25            | 03:30     | 00:05    | TRIPPED ON FAULT    |
| 4679  | 23-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHORAPUR            | SHORAPUR_110                | 19:45            | 20:01     | 00:16    | TRIPPED ON FAULT    |
| 4680  | 23-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-KURKUNTA               | KURKUNTA_110                | 10:08            | 16:58     | 06:50    | LINE CLEAR AVAILED  |
| 4681  | 23-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR            | SINDHANUR_110               | 01:45            | 01:50     | 00:05    | TRIPPED ON FAULT    |
| 4682  | 23-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR            | SINDHANUR_110               | 03:05            | 03:10     | 00:05    | TRIPPED ON FAULT    |
| 4683  | 23-Sep-2024 | GULBARGA | 110     | LINE        | BYAGWAT-WALKAMDINNI          | WALKAMDINNI_110             | 19:35            | 19:45     | 00:10    | TRIPPED ON FAULT    |
| 4684  | 23-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-BHALKI              | BHALKI_110                  | 05:50            | 06:00     | 00:10    | TRIPPED ON FAULT    |
| 4685  | 23-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-KOLHAR              | KOLHAR_110                  | 17:48            | 18:24     | 00:36    | TRIPPED ON FAULT    |
| 4686  | 23-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | MANDEWAL_110                | 06:29            | 06:52     | 00:23    | TRIPPED ON FAULT    |
| 4687  | 23-Sep-2024 | GULBARGA | 110     | LINE        | YEDRAMI-MANDEWAL             | YEDRAMI_110                 | 19:00            | 19:10     | 00:10    | MAIN SUPPLY FAILURE |
| 4688  | 23-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                          | KOGALI_66                   | 02:20            | 02:30     | 00:10    | TRIPPED ON FAULT    |
| 4689  | 23-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                          | KOGALI_66                   | 04:50            | 05:00     | 00:10    | TRIPPED ON FAULT    |
| 4690  | 23-Sep-2024 | GULBARGA | 66      | LINE        | TELGI-YARGUNTA               | OBJ HALLI_66                | 11:50            | 12:00     | 00:10    | TRIPPED ON FAULT    |
| 4691  | 24-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR             | NEELGUNDA_220               | 9:21(21.05.2024) |           |          | LINE CLEAR AVAILED  |
| 4692  | 24-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV3                          | KUSHTAGI_220                | 06:31            | 19:05     | 12:34    | LINE CLEAR AVAILED  |
| 4693  | 24-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2            | KAPNOOR_220                 | 23:59            | 07:08     | 16:51    | LINE CLEAR AVAILED  |
| 4694  | 24-Sep-2024 | GULBARGA | 220     | LINE        | KUSHTAGI-SUZALON1            | KUSHTAGI_220                | 07:13            | 19:20     | 12:07    | LINE CLEAR AVAILED  |
| 4695  | 24-Sep-2024 | GULBARGA | 220     | LINE        | KUSHTAGI-SUZALON2            | KUSHTAGI_220                | 07:20            | 19:05     | 11:45    | LINE CLEAR AVAILED  |
| 4696  | 24-Sep-2024 | GULBARGA | 220     | LINE        | KUDLIGI-HIREMALLANAHOLE      | KUDLIGI_220                 | 11:10            | 15:30     | 04:20    | LINE CLEAR AVAILED  |
| 4697  | 24-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1&HV2                      | VENKATAGIRI_110             | 12:05            | 17:40     | 05:35    | LINE CLEAR AVAILED  |
| 4698  | 24-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV4                          | ALLIPUR_220                 | 11:06            | 17:34     | 06:28    | LINE CLEAR AVAILED  |
| 4699  | 24-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                          | CHICKSUGUR_110              | 10:15            | 17:28     | 07:13    | LINE CLEAR AVAILED  |
| 4700  | 24-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                          | APMC_110                    | 12:30            | 16:38     | 04:08    | LINE CLEAR AVAILED  |
| 4701  | 24-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR2       | SINDHANOOR_110              | 10:43            | 13:55     | 03:12    | LINE CLEAR AVAILED  |
| 4702  | 24-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-NIRLOOTI_IPP      | SINDHANOOR_220              | 12:05            | 17:05     | 05:00    | LINE CLEAR AVAILED  |
| 4703  | 24-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR2       | SINDHANOOR_110              | 20:45            | 20:55     | 00:10    | TRIPPED ON FAULT    |
| 4704  | 24-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-ILKAL2              | ILKAL_110                   | 11:50            | 13:42     | 01:52    | LINE CLEAR AVAILED  |
| 4705  | 24-Sep-2024 | GULBARGA | 110     | LINE        | VENKATAGIRI-GANGAVATI        | VENKATAGIRI_110             | 09:35            | 12:05     | 02:30    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                             | Station_Name                                                                   | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|----------------------------------|--------------------------------------------------------------------------------|-------------------|-----------|----------|---------------------|
| 4706  | 24-Sep-2024 | GULBARGA | 110     | LINE        | YERAGERA-RAICHUR                 | YERAGERA_110                                                                   | 06:16             | 06:37     | 00:21    | MAIN SUPPLY FAILURE |
| 4707  | 24-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA               | YADGIR_110                                                                     | 06:00             | 07:30     | 01:30    | TRIPPED ON FAULT    |
| 4708  | 24-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-KBJNL                     | KBJNL_110                                                                      | 07:00             | 07:35     | 00:35    | TRIPPED ON FAULT    |
| 4709  | 24-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SHAHAPUR 1&2            | KHANAPUR_110,KADECHUR_110,<br>WADAGERA_110,SIRWAL_110,RAI<br>LWAY TRACTION_110 | 11:42             | 13:15     | 01:33    | LINE CLEAR AVAIED   |
| 4710  | 24-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-KADECHUR                | KADECHUR_110                                                                   | 10:10             | 17:17     | 07:07    | LINE CLEAR AVAIED   |
| 4711  | 24-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-CHITTAPUR                  | CHITTAPUR_110,KORWAR<br>TEMPLE_110                                             | 10:55             | 12:37     | 01:42    | LINE CLEAR AVAIED   |
| 4712  | 24-Sep-2024 | GULBARGA | 110     | LINE        | YEDRAMI-MANDEWAL                 | MANDEWAL_110                                                                   | 06:25             | 06:45     | 00:20    | MAIN SUPPLY FAILURE |
| 4713  | 24-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-KOLHAR1                 | KOLHAR_110                                                                     | 05:08             | 05:20     | 00:12    | TRIPPED ON FAULT    |
| 4714  | 24-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-KOLHAR2                 | KOLHAR_110                                                                     | 05:08             | 05:20     | 00:12    | TRIPPED ON FAULT    |
| 4715  | 24-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-CLEANMAX SOLAR 1 AND<br>2 | ITTAGI_66                                                                      | 13:18             | 13:22     | 00:04    | TRIPPED ON FAULT    |
| 4716  | 24-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-CLEANMAX SOLAR 2          | ITTAGI_66                                                                      | 13:24             | 16:34     | 03:10    | TRIPPED ON FAULT    |
| 4717  | 24-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HALAVAGALU             | HALAVAGALU_66, HARVI_66                                                        | 21:17             | 21:26     | 00:09    | TRIPPED ON FAULT    |
| 4718  | 25-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                              | RAMASAMUDRA_220                                                                | 12:20             | 14:45     | 02:25    | LINE CLEAR AVAIED   |
| 4719  | 25-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                              | SEDAM_220                                                                      | 11:11             | 13:20     | 02:09    | LINE CLEAR AVAIED   |
| 4720  | 25-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS2                   | RTPS_220                                                                       | 00:28             | 00:54     | 00:26    | TRIPPED ON FAULT    |
| 4721  | 25-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2                | KAPNOOR_220                                                                    | 01:05             | 06:38     | 05:33    | LINE CLEAR AVAIED   |
| 4722  | 25-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD1                | KAPNOOR_220                                                                    | 10:07             | 10:15     | 00:08    | TRIPPED ON FAULT    |
| 4723  | 25-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2                 | LINGASUGUR_220                                                                 | 01:56             | 02:14     | 00:18    | TRIPPED ON FAULT    |
| 4724  | 25-Sep-2024 | GULBARGA | 220     | LINE        | ITTAGI-VESTAS IPP                | ITTAGI_220                                                                     | 11:13             | 16:43     | 05:30    | LINE CLEAR AVAIED   |
| 4725  | 25-Sep-2024 | GULBARGA | 220     | LINE        | ITTAGI- LINGAPUR                 | ITTAGI_220                                                                     | 11:26             | 11:55     | 00:29    | TRIPPED ON FAULT    |
| 4726  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                              | NANDUR_110                                                                     | 19:30             | 20:15     | 00:45    | TRIPPED ON FAULT    |
| 4727  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                              | BALLARI NORTH_110                                                              | 09:50             | 17:13     | 07:23    | LINE CLEAR AVAIED   |
| 4728  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                              | BALLARI NORTH_110                                                              | 09:50             | 16:32     | 06:42    | LINE CLEAR AVAIED   |
| 4729  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV4                              | BALLARI NORTH_110                                                              | 11:08             | 17:04     | 05:56    | LINE CLEAR AVAIED   |
| 4730  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                              | APMC_110                                                                       | 11:10             | 13:30     | 02:20    | LINE CLEAR AVAIED   |
| 4731  | 25-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                              | CHINCHOLI_110                                                                  | 07:24             | 07:38     | 00:14    | TRIPPED ON FAULT    |
| 4732  | 25-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR2               | JEWARGI_110                                                                    | 04:33             | 04:41     | 00:08    | TRIPPED ON FAULT    |
| 4733  | 25-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-BHALKESHWAR_IPP           | BHALKI_110                                                                     | 10:25(25.09.2024) |           |          | LINE CLEAR AVAIED   |
| 4734  | 25-Sep-2024 | GULBARGA | 110     | LINE        | MADIYAL-CHOWDAPUR                | CHOWDAPUR_110, SAGNOOR_110                                                     | 18:20             | 18:35     | 00:15    | MAIN SUPPLY FAILURE |
| 4735  | 25-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-HUMNABAD                | HUMNABAD_110                                                                   | 03:15             | 03:29     | 00:14    | TRIPPED ON FAULT    |
| 4736  | 25-Sep-2024 | GULBARGA | 110     | LINE        | KALBURGI UNIVERSITY-NANDUR       | NANDUR_110                                                                     | 19:40             | 23:59     | 04:19    | TRIPPED ON FAULT    |
| 4737  | 25-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-MADIYAL                  | MADIYAL_110                                                                    | 18:20             | 18:33     | 00:13    | TRIPPED ON FAULT    |
| 4738  | 25-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-SOLAR IPP               | KUSHTAGI_220                                                                   | 10:40             | 17:25     | 06:45    | LINE CLEAR AVAIED   |
| 4739  | 25-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-KALALBANDI              | KUSHTAGI_220                                                                   | 11:30             | 14:06     | 02:36    | LINE CLEAR AVAIED   |
| 4740  | 25-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-HIRESINDHOGI           | HIRESINDHOGI_110                                                               | 15:13             | 18:28     | 03:15    | LINE CLEAR AVAIED   |
| 4741  | 25-Sep-2024 | GULBARGA | 110     | LINE        | YAPALDINI-VADAVATTI              | VADAVATTI_110                                                                  | 13:20             | 14:45     | 01:25    | LINE CLEAR AVAIED   |
| 4742  | 25-Sep-2024 | GULBARGA | 110     | LINE        | SOMASAMUDRA-BALLARI NORTH        | SOMASAMUDRA_110                                                                | 11:20             | 13:59     | 02:39    | LINE CLEAR AVAIED   |
| 4743  | 25-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1              | SINDHANUR_110                                                                  | 01:40             | 01:44     | 00:04    | TRIPPED ON FAULT    |
| 4744  | 25-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1              | SINDHANUR_110                                                                  | 20:02             | 20:03     | 00:01    | TRIPPED ON FAULT    |
| 4745  | 25-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2               | GUGAL_110,GABBUR_110                                                           | 01:45             | 01:49     | 00:04    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                   | Station_Name                  | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|------------------------|-------------------------------|-------------------|-----------|----------|---------------------|
| 4746  | 25-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2     | GUGAL_110,GABBUR_110          | 18:58             | 19:03     | 00:05    | TRIPPED ON FAULT    |
| 4747  | 25-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | HOSAHALLI_66                  | 07:10             | 07:15     | 00:05    | TRIPPED ON FAULT    |
| 4748  | 25-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | KOGALI_66                     | 13:45             | 14:00     | 00:15    | TRIPPED ON FAULT    |
| 4749  | 25-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 1  | GIRIYAPURA_66,HIREHADAGALI_66 | 05:50             | 05:57     | 00:07    | TRIPPED ON FAULT    |
| 4750  | 25-Sep-2024 | GULBARGA | 66      | LINE        | HIREHADAGALI-MAGLA     | MAGLA_66, GIRIYAPUR_66        | 10:18             | 10:35     | 00:17    | TRIPPED ON FAULT    |
| 4751  | 25-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-HALAVAGALU   | HALAVAGALU_66, HARVI_66       | 06:14             | 06:24     | 00:10    | TRIPPED ON FAULT    |
| 4752  | 26-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR       | NEELGUNDA_220                 | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAILED  |
| 4753  | 26-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1 & HV2              | SHAHAPUR_220                  | 12:56             | 13:08     | 00:12    | TRIPPED ON FAULT    |
| 4754  | 26-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2      | KAPNOOR_220                   | 22:15             | 23:59     | 01:44    | LINE CLEAR AVAILED  |
| 4755  | 26-Sep-2024 | GULBARGA | 220     | LINE        | HATTIGUDUR-RTPS1       | RTPS_220                      | 10:38             | 11:54     | 01:16    | LINE CLEAR AVAILED  |
| 4756  | 26-Sep-2024 | GULBARGA | 220     | LINE        | SEDAM-FEROZABAD        | SEDAM_220                     | 11:45             | 14:47     | 03:02    | LINE CLEAR AVAILED  |
| 4757  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1 & HV2              | GHATTARGA_110                 | 09:06             | 15:55     | 06:49    | LINE CLEAR AVAILED  |
| 4758  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                    | CHICKSUGUR_110                | 16:10             | 18:35     | 02:25    | LINE CLEAR AVAILED  |
| 4759  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                    | CHICKSUGUR_110                | 10:01             | 15:02     | 05:01    | LINE CLEAR AVAILED  |
| 4760  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1&HV2                | MUNIRABAD_220                 | 09:06             | 13:53     | 04:47    | LINE CLEAR AVAILED  |
| 4761  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                    | MUNIRABAD_220                 | 09:06             | 09:10     | 00:04    | LINE CLEAR AVAILED  |
| 4762  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                    | MUNIRABAD_220                 | 13:48             | 13:53     | 00:05    | LINE CLEAR AVAILED  |
| 4763  | 26-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-BHALKESHWAR_IPP | BHALKI_110                    | 10:25(25.09.2024) |           |          | LINE CLEAR AVAILED  |
| 4764  | 26-Sep-2024 | GULBARGA | 110     | LINE        | HALBARGA-SANTHPUR      | SANTHPUR_110                  | 20:42             | 20:49     | 00:07    | TRIPPED ON FAULT    |
| 4765  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-NAGANOOR      | NAGANOOR_110                  | 06:00             | 06:08     | 00:08    | TRIPPED ON FAULT    |
| 4766  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-DEVAPUR       | DEVAPUR_110, SHORAPUR_110     | 10:15             | 18:10     | 07:55    | LINE CLEAR AVAILED  |
| 4767  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR1     | SHAHAPUR_110                  | 12:41             | 23:59     | 11:18    | LINE CLEAR AVAILED  |
| 4768  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-YADGIR        | YADGIR_110                    | 12:42             | 18:33     | 05:51    | LINE CLEAR AVAILED  |
| 4769  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-RAICHUR2      | GOOGAL_110, GABBUR_110        | 12:44             | 18:13     | 05:29    | LINE CLEAR AVAILED  |
| 4770  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-KHANAPUR1     | KHANAPUR_110                  | 12:45             | 18:25     | 05:40    | LINE CLEAR AVAILED  |
| 4771  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHAHABAD-BAGEWWADI1    | MANDEWAL_110, YEDRAMI_110     | 11:45             | 13:58     | 02:13    | LINE CLEAR AVAILED  |
| 4772  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SAIDAPUR-KHANAPUR      | SAIDAPUR_110,KADECHUR_110     | 12:55             | 13:10     | 00:15    | MAIN SUPPLY FAILURE |
| 4773  | 26-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1    | SIRWAR_110                    | 01:29             | 01:34     | 00:05    | TRIPPED ON FAULT    |
| 4774  | 26-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1    | SIRWAR_110                    | 02:55             | 07:10     | 04:15    | TRIPPED ON FAULT    |
| 4775  | 26-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-MATAMARI       | MATAMARI_110                  | 11:58             | 14:05     | 02:07    | LINE CLEAR AVAILED  |
| 4776  | 26-Sep-2024 | GULBARGA | 110     | LINE        | DEODURGA-RAICHUR       | DEODURGA_110                  | 12:55             | 13:10     | 00:15    | MAIN SUPPLY FAILURE |
| 4777  | 26-Sep-2024 | GULBARGA | 110     | LINE        | GUGAL-RAICHUR          | GUGAL_110,GABBUR_110          | 18:35             | 18:40     | 00:05    | MAIN SUPPLY FAILURE |
| 4778  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SHORAPUR-DEVAPURA      | SHORAPUR_110                  | 10:05             | 18:15     | 08:10    | LINE CLEAR AVAILED  |
| 4779  | 26-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-TAVARGERA     | TAVARGERA_110                 | 10:35             | 15:50     | 05:15    | LINE CLEAR AVAILED  |
| 4780  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SULEKAL-GANGAVATI      | GANGAVATI_110                 | 09:50             | 12:50     | 03:00    | LINE CLEAR AVAILED  |
| 4781  | 26-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1, HV2 & HV3         | GANGAVATI_110                 | 12:50             | 15:30     | 02:40    | LINE CLEAR AVAILED  |
| 4782  | 26-Sep-2024 | GULBARGA | 110     | LINE        | HANAWAL-MARALIHALLA    | YERADONA_110, BENNUR_110      | 10:40             | 10:50     | 00:10    | TRIPPED ON FAULT    |
| 4783  | 26-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SR NAGAR    | KARATAGI_110                  | 10:50             | 17:35     | 06:45    | LINE CLEAR AVAILED  |
| 4784  | 26-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1,HV2                | ITTAGI_220                    | 17:25             | 17:31     | 00:06    | LINE CLEAR AVAILED  |
| 4785  | 26-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | ITTAGI_220                    | 17:32             | 17:35     | 00:03    | LINE CLEAR AVAILED  |
| 4786  | 26-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                    | ITTAGI_220                    | 17:39             | 17:46     | 00:07    | LINE CLEAR AVAILED  |
| 4787  | 26-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | HOSAHALLI_66                  | 19:35             | 19:40     | 00:05    | TRIPPED ON FAULT    |
| 4788  | 26-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | KOTTUR_66                     | 06:50             | 06:55     | 00:05    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                     | Station_Name                           | Open_At           | Closed_At | Duration | REMARKS           |
|-------|-------------|----------|---------|-------------|--------------------------|----------------------------------------|-------------------|-----------|----------|-------------------|
| 4789  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HB HALLI          | HB HALLI_66,UP HALLI_66                | 16:22             | 16:25     | 00:03    | LINE CLEAR AVAIED |
| 4790  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 1    | HIREHADAGALI_66,GIRIYAPUR_66           | 16:30             | 16:31     | 00:01    | LINE CLEAR AVAIED |
| 4791  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI 2    | SOVENAHALLI_66,TUNGABADRA_66,MAGALA_66 | 16:31             | 16:40     | 00:09    | LINE CLEAR AVAIED |
| 4792  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-BENNEHALLI        | BENNEHALLI_66,KOTTUR_66,UJJINI_66      | 16:46             | 16:50     | 00:04    | LINE CLEAR AVAIED |
| 4793  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-RENEW 1 &2        | ITTAGI_220                             | 17:10             | 17:14     | 00:04    | LINE CLEAR AVAIED |
| 4794  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-CLEANMAX 1&2      | ITTAGI_220                             | 17:14             | 17:16     | 00:02    | LINE CLEAR AVAIED |
| 4795  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-TB HALLI          | TB HALLI_66,MAGALA_66,HAMPASAGARA_66   | 17:19             | 17:25     | 00:06    | LINE CLEAR AVAIED |
| 4796  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HUVINAHADAGALI    | HUVINAHADAGALI_66,HOLAGUNDI_66         | 16:41             | 16:45     | 00:04    | LINE CLEAR AVAIED |
| 4797  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-SUZLON 2          | ITTAGI_220                             | 16:52             | 17:05     | 00:13    | LINE CLEAR AVAIED |
| 4798  | 26-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-SUZLON 1          | ITTAGI_220                             | 16:52             | 18:08     | 01:16    | LINE CLEAR AVAIED |
| 4799  | 27-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                          | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAIED |
| 4800  | 27-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2        | KAPNOOR_220                            | 23:59             | 06:30     | 17:29    | LINE CLEAR AVAIED |
| 4801  | 27-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                      | ITTAGI_220                             | 12:40             | 14:48     | 02:08    | LINE CLEAR AVAIED |
| 4802  | 27-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI      | YAPALDINI_110, KIADB YERAMARUS         | 00:01             | 00:09     | 00:08    | TRIPPED ON FAULT  |
| 4803  | 27-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI      | YAPALDINI_110, KIADB YERAMARUS         | 16:32             | 16:51     | 00:19    | TRIPPED ON FAULT  |
| 4804  | 27-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI      | YAPALDINI_110, KIADB YERAMARUS         | 17:02             | 17:11     | 00:09    | TRIPPED ON FAULT  |
| 4805  | 27-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI      | YAPALDINI_110, KIADB YERAMARUS         | 18:48             | 19:09     | 00:21    | TRIPPED ON FAULT  |
| 4806  | 27-Sep-2024 | GULBARGA | 110     | LINE        | BHALKI-BHALKESHWAR IPP   | BHALKI_110                             | 10:25(25.09.2024) |           |          | LINE CLEAR AVAIED |
| 4807  | 27-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                      | HOSAHALLI_66                           | 09:10             | 09:15     | 00:05    | TRIPPED ON FAULT  |
| 4808  | 27-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                      | HUDEM_66                               | 16:10             | 16:20     | 00:10    | LINE CLEAR AVAIED |
| 4809  | 27-Sep-2024 | GULBARGA | 66      | LINE        | BANAVIKAL-ABRSL WIND IPP | BANAVIKAL_66                           | 12:55             | 13:15     | 00:20    | TRIPPED ON FAULT  |
| 4810  | 27-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-KOTTUR           | KOTTUR_66                              | 10:30             | 16:20     | 05:50    | LINE CLEAR AVAIED |
| 4811  | 27-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-SUZLON SOGI 1&2   | ITTAGI_220                             | 10:25             | 16:15     | 05:50    | LINE CLEAR AVAIED |
| 4812  | 27-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-RENEW SOLAR 1&2   | ITTAGI_220                             | 13:30             | 13:45     | 00:15    | LINE CLEAR AVAIED |
| 4813  | 27-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-RENEW SOLAR 1&2   | ITTAGI_220                             | 18:27             | 21:15     | 02:48    | LINE CLEAR AVAIED |
| 4814  | 28-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR         | NEELGUNDA_220                          | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAIED |
| 4815  | 28-Sep-2024 | GULBARGA | 220     | LINE        | ITTAGI-EMBASSY           | ITTAGI_220                             | 13:35             | 17:30     | 03:55    | LINE CLEAR AVAIED |
| 4816  | 28-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-2          | RTPS_220                               | 13:24             | 13:45     | 00:21    | TRIPPED ON FAULT  |
| 4817  | 28-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-2          | RTPS_220                               | 13:48             | 18:30     | 04:42    | LINE CLEAR AVAIED |
| 4818  | 28-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-1          | RTPS_220                               | 17:15             | 17:38     | 00:23    | TRIPPED ON FAULT  |
| 4819  | 28-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-1          | RTPS_220                               | 17:38             | 23:59     | 06:21    | LINE CLEAR AVAIED |
| 4820  | 28-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | SHAKTINAGAR_110                        | 10:20             | 14:14     | 03:54    | LINE CLEAR AVAIED |
| 4821  | 28-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                      | SHAKTINAGAR_110                        | 12:17             | 14:06     | 01:49    | LINE CLEAR AVAIED |
| 4822  | 28-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | HANUMNAL_110                           | 17:10             | 17:45     | 00:35    | LINE CLEAR AVAIED |
| 4823  | 28-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                      | PD_HALLI_110                           | 13:38             | 14:00     | 00:22    | TRIPPED ON FAULT  |
| 4824  | 28-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-DHADESUGUR    | DHADESUGUR_110                         | 02:03             | 02:18     | 00:15    | TRIPPED ON FAULT  |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                   | Station_Name                                                | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|------------------------|-------------------------------------------------------------|------------------|-----------|----------|---------------------|
| 4825  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-VAJARBANDI    | VAJARBANDI_110, YALBURGA_110                                | 11:20            | 17:12     | 05:52    | LINE CLEAR AVAILED  |
| 4826  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KUSHTAGI-KANAKAGIRI    | GANADAL_110                                                 | 23:18            | 23:32     | 00:14    | TRIPPED ON FAULT    |
| 4827  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KAMPLI-MALLAPUR        | MALLAPUR_110                                                | 13:37            | 13:47     | 00:10    | MAIN SUPPLY FAILURE |
| 4828  | 28-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-DHADESUGUR    | SIRGUPPA_110                                                | 10:20            | 10:35     | 00:15    | MAIN SUPPLY FAILURE |
| 4829  | 28-Sep-2024 | GULBARGA | 110     | LINE        | YERAGERA-MALIYABAD     | YERAGERA_110                                                | 10:55            | 18:10     | 07:15    | LINE CLEAR AVAILED  |
| 4830  | 28-Sep-2024 | GULBARGA | 110     | LINE        | CHICKSUGUR-APMC        | CHICKSUGUR_110,SHAKTINAGAR_110,YAPALDINNI_110               | 12:30            | 14:02     | 01:32    | LINE CLEAR AVAILED  |
| 4831  | 28-Sep-2024 | GULBARGA | 110     | LINE        | CHICKSUGUR-SHAKTINAGAR | SHAKTINAGAR_110                                             | 12:30            | 14:03     | 01:33    | LINE CLEAR AVAILED  |
| 4832  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KHANAPUR-SANOTHI       | KHANAPUR_110                                                | 04:09            | 04:19     | 00:10    | TRIPPED ON FAULT    |
| 4833  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KURUGODU-SIRIGERICROSS | KURUGODU_110                                                | 10:00            | 10:10     | 00:10    | MAIN SUPPLY FAILURE |
| 4834  | 28-Sep-2024 | GULBARGA | 110     | LINE        | KURUGODU-SIRIGERICROSS | KURUGODU_110                                                | 10:20            | 10:35     | 00:15    | MAIN SUPPLY FAILURE |
| 4835  | 28-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | HUDEM_66                                                    | 10:40            | 12:30     | 01:50    | LINE CLEAR AVAILED  |
| 4836  | 28-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | HANSI_66                                                    | 18:30            | 18:35     | 00:05    | TRIPPED ON FAULT    |
| 4837  | 28-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                    | UCCHANGIDURGA_66                                            | 19:00            | 19:15     | 00:15    | LINE CLEAR AVAILED  |
| 4838  | 28-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-CLEANMAX 1&2    | ITTAGI_220                                                  | 18:25            | 19:29     | 01:04    | LINE CLEAR AVAILED  |
| 4839  | 28-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HUVINAHADAGALI  | HUVINAHADAGALI_66,HOLAGUNDI_66                              | 16:10            | 16:57     | 00:47    | LINE CLEAR AVAILED  |
| 4840  | 29-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR       | NEELGUNDA_220                                               | 9:21(21.05.2024) |           |          | LINE CLEAR AVAILED  |
| 4841  | 29-Sep-2024 | GULBARGA | 220     | LINE        | LINGASUGUR-RTPS2       | LINGASUGUR_220                                              | 00:43            | 20:31     | 19:48    | TRIPPED ON FAULT    |
| 4842  | 29-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-2        | RTPS_220                                                    | 10:10            | 12:46     | 02:36    | LINE CLEAR AVAILED  |
| 4843  | 29-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-RTPS-1        | RTPS_220                                                    | 23:59            | 12:44     | 11:15    | LINE CLEAR AVAILED  |
| 4844  | 29-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                    | SOMASAMUDRA_110                                             | 18:25            | 18:38     | 00:13    | TRIPPED ON FAULT    |
| 4845  | 29-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                    | CHICKSUGUR_110                                              | 08:02            | 08:13     | 00:11    | TRIPPED ON FAULT    |
| 4846  | 29-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV2                    | CHICKSUGUR_110                                              | 21:37            | 21:41     | 00:04    | TRIPPED ON FAULT    |
| 4847  | 29-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1,HV2,HV3            | SHORAPUR_110                                                | 13:12            | 13:22     | 00:10    | TRIPPED ON FAULT    |
| 4848  | 29-Sep-2024 | GULBARGA | 110     | LINE        | KAPNOOR-ALAND          | ALAND_110                                                   | 00:44            | 01:00     | 00:16    | TRIPPED ON FAULT    |
| 4849  | 29-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR1 | SINDHANOOR_110                                              | 23:22            | 23:47     | 00:25    | TRIPPED ON FAULT    |
| 4850  | 29-Sep-2024 | GULBARGA | 110     | LINE        | LINGASUGUR-HATTI       | HATTI_110                                                   | 04:58            | 05:09     | 00:11    | TRIPPED ON FAULT    |
| 4851  | 29-Sep-2024 | GULBARGA | 110     | LINE        | VADAVATTI-YAPALDINI    | YAPALDINI_110, KIADB YERAMARUS                              | 14:00            | 14:05     | 00:05    | TRIPPED ON FAULT    |
| 4852  | 29-Sep-2024 | GULBARGA | 110     | LINE        | SIRGUPPA-DHADESUGUR    | TEKKALKOTE_110                                              | 02:03            | 02:20     | 00:17    | MAIN SUPPLY FAILURE |
| 4853  | 29-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-SHAHAPUR        | YADGIR_110                                                  | 14:10            | 19:05     | 04:55    | LINE CLEAR AVAILED  |
| 4854  | 29-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-RAMASAMUDRA     | YADGIR_110                                                  | 14:10            | 16:00     | 01:50    | LINE CLEAR AVAILED  |
| 4855  | 29-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-KBJNL           | KBJNL_110                                                   | 14:10            | 18:10     | 04:00    | LINE CLEAR AVAILED  |
| 4856  | 29-Sep-2024 | GULBARGA | 110     | LINE        | KOLLUR-DEODURGA        | M KOLLUR_110                                                | 01:58            | 02:05     | 00:07    | TRIPPED ON FAULT    |
| 4857  | 29-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-MATAMARI       | MATAMARI_110                                                | 09:54            | 09:59     | 00:05    | TRIPPED ON FAULT    |
| 4858  | 29-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-RAICHUR-2     | DEVADURGA_110                                               | 01:56            | 02:03     | 00:07    | TRIPPED ON FAULT    |
| 4859  | 29-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-YADGIR        | YADGIR_110                                                  | 14:36            | 19:04     | 04:28    | LINE CLEAR AVAILED  |
| 4860  | 29-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV3                    | KUDLIGI_66                                                  | 15:15            | 15:30     | 00:15    | TRIPPED ON FAULT    |
| 4861  | 29-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HIREHADAGALI    | SOVENAHALLI_66,TUNGABADRA_66,MAGALA_66                      | 06:06            | 06:23     | 00:17    | TRIPPED ON FAULT    |
| 4862  | 29-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA  | PUNABGHATTA_66, ARASIKERE_66, UCCHANGIDURGA_66, BILCHODU_66 | 00:52            | 01:05     | 00:13    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                              | Station_Name             | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|-----------------------------------|--------------------------|-------------------|-----------|----------|---------------------|
| 4863  | 29-Sep-2024 | GULBARGA | 66      | LINE        | NELGUNDA-HALAVAGALU               | HALAVAGALU_66, HARVI_66  | 16:50             | 16:57     | 00:07    | TRIPPED ON FAULT    |
| 4864  | 30-Sep-2024 | GULBARGA | 220     | LINE        | NEELGUNDA-GUTTUR                  | NEELGUNDA_220            | 9:21(21.05.2024)  |           |          | LINE CLEAR AVAIED   |
| 4865  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                               | SINDHANOOR_220           | 15:40             | 15:46     | 00:06    | TRIPPED ON FAULT    |
| 4866  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                               | NEELAGUNDA_220           | 04:00             | 04:40     | 00:40    | TRIPPED ON FAULT    |
| 4867  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                               | KUSTAGI_220              | 11:37             | 16:30     | 04:53    | LINE CLEAR AVAIED   |
| 4868  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                               | KUSTAGI_220              | 19:54             | 22:03     | 02:09    | LINE CLEAR AVAIED   |
| 4869  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                               | ITTAGI_220               | 16:38             | 16:45     | 00:07    | LINE CLEAR AVAIED   |
| 4870  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                               | ITTAGI_220               | 16:48             | 16:55     | 00:07    | LINE CLEAR AVAIED   |
| 4871  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV1                               | ITTAGI_220               | 18:22             | 18:30     | 00:08    | LINE CLEAR AVAIED   |
| 4872  | 30-Sep-2024 | GULBARGA | 220     | TRANSFORMER | HV2                               | ITTAGI_220               | 18:30             | 18:33     | 00:03    | LINE CLEAR AVAIED   |
| 4873  | 30-Sep-2024 | GULBARGA | 220     | LINE        | ALIPUR-BTPS                       | ALIPUR_220               | 13:18             | 20:27     | 07:09    | TRIPPED ON FAULT    |
| 4874  | 30-Sep-2024 | GULBARGA | 220     | LINE        | LINGAPUR-GANGAVATHI2              | LINGAPUR_220             | 13:41             | 16:42     | 03:01    | LINE CLEAR AVAIED   |
| 4875  | 30-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD1                 | KAPNOOR_220              | 17:22             | 17:40     | 00:18    | LINE CLEAR AVAIED   |
| 4876  | 30-Sep-2024 | GULBARGA | 220     | LINE        | KAPNOOR-HUMNABAD2                 | KAPNOOR_220              | 22:50(30.09.2024) |           |          | LINE CLEAR AVAIED   |
| 4877  | 30-Sep-2024 | GULBARGA | 220     | LINE        | SINDHANOOR-SULEKAL                | SULEKAL_220              | 14:14             | 14:30     | 00:16    | TRIPPED ON FAULT    |
| 4878  | 30-Sep-2024 | GULBARGA | 220     | LINE        | ITTAGI-BADALADUKU 1&2             | ITTAGI_220               | 11:50             | 20:05     | 08:15    | LINE CLEAR AVAIED   |
| 4879  | 30-Sep-2024 | GULBARGA | 220     | LINE        | KUSTAGI-OPDWIND(ASTRO)            | KUSTAGI_220              | 10:44             | 17:09     | 06:25    | LINE CLEAR AVAIED   |
| 4880  | 30-Sep-2024 | GULBARGA | 220     | LINE        | SHAHAPUR-FIROZABAD 1              | SHAHAPUR_220             | 10:18             | 14:35     | 04:17    | LINE CLEAR AVAIED   |
| 4881  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1,HV2                           | ALAND_110                | 10:45             | 18:45     | 08:00    | LINE CLEAR AVAIED   |
| 4882  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | YADGIR_110               | 12:15             | 12:25     | 00:10    | TRIPPED ON FAULT    |
| 4883  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | YADGIR_110               | 17:40             | 17:45     | 00:05    | TRIPPED ON FAULT    |
| 4884  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                               | SIRIGUPPA_110            | 05:56             | 06:09     | 00:13    | TRIPPED ON FAULT    |
| 4885  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | ALIPUR_220               | 01:21             | 01:40     | 00:19    | TRIPPED ON FAULT    |
| 4886  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | ALIPUR_220               | 01:54             | 02:09     | 00:15    | TRIPPED ON FAULT    |
| 4887  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | ALIPUR_220               | 02:10             | 03:04     | 00:54    | TRIPPED ON FAULT    |
| 4888  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | ALIPUR_220               | 07:50             | 08:49     | 00:59    | LINE CLEAR AVAIED   |
| 4889  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV3                               | BELLARY NORTH_110        | 09:35             | 19:40     | 10:05    | LINE CLEAR AVAIED   |
| 4890  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | ALIPUR_220               | 09:57             | 10:11     | 00:14    | TRIPPED ON FAULT    |
| 4891  | 30-Sep-2024 | GULBARGA | 110     | TRANSFORMER | HV1                               | MANDEWAL_110             | 10:42             | 13:30     | 02:48    | LINE CLEAR AVAIED   |
| 4892  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-DEVAPUR                  | DEVAPUR_110,SHORAPUR_110 | 18:35             | 19:34     | 00:59    | LOAD CURTAILMENT    |
| 4893  | 30-Sep-2024 | GULBARGA | 110     | LINE        | DEVAPUR-SHORAPUR                  | SHORAPUR_110             | 05:36             | 05:47     | 00:11    | TRIPPED ON FAULT    |
| 4894  | 30-Sep-2024 | GULBARGA | 110     | LINE        | HALWARTHY-TALAKAL                 | TALAKAL_110              | 19:24             | 19:48     | 00:24    | TRIPPED ON FAULT    |
| 4895  | 30-Sep-2024 | GULBARGA | 110     | LINE        | MALLAT-SIRWAR                     | SIRWAR_110               | 10:28             | 10:48     | 00:20    | TRIPPED ON FAULT    |
| 4896  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-SHAHAPUR 2               | SHAHAPUR_110             | 18:35             | 20:05     | 01:30    | LOAD CURTAILMENT    |
| 4897  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-M.KOLLUR                 | DEVADURGA_110, M.KOLLUR  | 18:35             | 19:10     | 00:35    | LOAD CURTAILMENT    |
| 4898  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SHAHAPUR-RAICHUR 2                | DEVADURGA_110, M.KOLLUR  | 18:35             | 19:38     | 01:03    | LOAD CURTAILMENT    |
| 4899  | 30-Sep-2024 | GULBARGA | 110     | LINE        | GULBARGA UNIVERSITY-SHAHABAD CKT2 | FARTHABAD_110            | 18:30             | 18:40     | 00:10    | LOAD CURTAILMENT    |
| 4900  | 30-Sep-2024 | GULBARGA | 110     | LINE        | DEODURGA-SHAHAPUR 1               | DEODURGA_110             | 18:35             | 19:35     | 01:00    | MAIN SUPPLY FAILURE |
| 4901  | 30-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SHAHAPUR 2                | GUGAL_110,GABBUR_110     | 23:03             | 23:10     | 00:07    | TRIPPED ON FAULT    |
| 4902  | 30-Sep-2024 | GULBARGA | 110     | LINE        | RAICHUR-SINDHANUR 1               | SINDHANUR_110            | 23:18             | 23:22     | 00:04    | TRIPPED ON FAULT    |
| 4903  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SEDAM-CHINCHOLI 1                 | CHINCHOLI_110            | 11:20             | 14:55     | 03:35    | LINE CLEAR AVAIED   |
| 4904  | 30-Sep-2024 | GULBARGA | 110     | LINE        | YADGIR-KBJNL                      | KBJNL_110                | 11:45             | 13:35     | 01:50    | LINE CLEAR AVAIED   |
| 4905  | 30-Sep-2024 | GULBARGA | 110     | LINE        | RAMASAMUDRA-KONKAL                | KONKAL_110               | 17:04             | 17:35     | 00:31    | LINE CLEAR AVAIED   |
| 4906  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-SINDHANOOR3            | SINDHANOOR_110           | 10:50             | 11:20     | 00:30    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE  | Voltage | LINE/TRNS   | Line                                          | Station_Name                                                         | Open_At               | Closed_At          | Duration | REMARKS             |
|-------|-------------|----------|---------|-------------|-----------------------------------------------|----------------------------------------------------------------------|-----------------------|--------------------|----------|---------------------|
| 4907  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-NIRLOOTI                           | SINDHANOOR_220                                                       | 23:57(30.09.2024)     |                    |          | TRIPPED ON FAULT    |
| 4908  | 30-Sep-2024 | GULBARGA | 110     | LINE        | SINDHANOOR-GANDHINAGAR                        | GANDHINAGAR_110,<br>TURVIHAL_110                                     | 17:10                 | 17:20              | 00:10    | TRIPPED ON FAULT    |
| 4909  | 30-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV1                                           | KOTTUR_66                                                            | 03:00                 | 03:10              | 00:10    | TRIPPED ON FAULT    |
| 4910  | 30-Sep-2024 | GULBARGA | 66      | TRANSFORMER | HV2                                           | CJ HALLI_66                                                          | 06:00                 | 06:10              | 00:10    | TRIPPED ON FAULT    |
| 4911  | 30-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA                         | PUNABGHATTA_66,<br>ARASIKERE_66,<br>UCCHANGIDURGA_66,<br>BILCHODU_66 | 04:00                 | 11:20              | 07:20    | TRIPPED ON FAULT    |
| 4912  | 30-Sep-2024 | GULBARGA | 66      | LINE        | NEELGUNDA-PUNABGHATTA                         | PUNABGHATTA_66,<br>ARASIKERE_66,<br>UCCHANGIDURGA_66,<br>BILCHODU_66 | 16:43                 | 17:08              | 00:25    | LINE CLEAR AVAIED   |
| 4913  | 30-Sep-2024 | GULBARGA | 66      | LINE        | HPHALLI-NEELAGUNDA                            | HARAPANAHALLI_66,SUZLON_IPP                                          | 04:00                 | 04:45              | 00:45    | TRIPPED ON FAULT    |
| 4914  | 30-Sep-2024 | GULBARGA | 66      | LINE        | GUDEKOTE-BADALADUKU                           | GUDEKOTE_66                                                          | 09:25                 | 17:05              | 07:40    | LINE CLEAR AVAIED   |
| 4915  | 30-Sep-2024 | GULBARGA | 66      | LINE        | CHORNUR-BADALADUKU                            | CHORNUR_66                                                           | 09:20                 | 10:10              | 00:50    | MAIN SUPPLY FAILURE |
| 4916  | 30-Sep-2024 | GULBARGA | 66      | LINE        | CHORNUR-BADALADUKU                            | CHORNUR_66                                                           | 18:20                 | 18:50              | 00:30    | MAIN SUPPLY FAILURE |
| 4917  | 30-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HB HALLI                               | HB HALLI_66,BJ HALLI_66                                              | 12:51                 | 13:11              | 00:20    | TRIPPED ON FAULT    |
| 4918  | 30-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-HB HALLI                               | HB HALLI_66,BJ HALLI_66                                              | 11:52                 | 12:10              | 00:18    | TRIPPED ON FAULT    |
| 4919  | 30-Sep-2024 | GULBARGA | 66      | LINE        | ITTAGI-SUZLON 1                               | ITTAGI_220                                                           | 11:40                 | 15:05              | 03:25    | LINE CLEAR AVAIED   |
| 4920  | 30-Sep-2024 | GULBARGA | 66      | LINE        | UCCHANGIDURGA-BILCHOD                         | BILCHOD_66                                                           | 10:10                 | 14:05              | 03:55    | LINE CLEAR AVAIED   |
| 4921  | 30-Sep-2024 | GULBARGA | 66      | LINE        | KOTTUR-BADALADUKU                             | KOTTUR_66,KOGALI_66                                                  | 09:25                 | 09:40              | 00:15    | MAIN SUPPLY FAILURE |
| 4922  | 30-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-ITTAGI                                | KUDLIGI_66,HANSI_66,KOGALI_66                                        | 18:18                 | 18:36              | 00:18    | MAIN SUPPLY FAILURE |
| 4923  | 30-Sep-2024 | GULBARGA | 66      | LINE        | KUDLIGI-BADALADUKU                            | CHILAKANAHATTI_66,KUDLIGI_66,<br>HANSI_66                            | 09:20                 | 10:00              | 00:40    | MAIN SUPPLY FAILURE |
| 4924  | 30-Sep-2024 | GULBARGA | 66      | LINE        | CJ HALLI-KUDLIGI                              | CJ<br>HALLI_66,HOSAHALLI_66,HUDEM_66                                 | 09:20                 | 17:00              | 07:40    | LINE CLEAR AVAIED   |
| 4925  | 30-Sep-2024 | GULBARGA | 66      | LINE        | BANAVIKAL-KUDLIGI                             | BANAVIKAL_66,ABRSL WIND,<br>SOLARSYS IPP                             | 10:23                 | 17:55              | 07:32    | LINE CLEAR AVAIED   |
| 4926  | 01-Sep-2024 | TUMKUR   | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                                             | 15:43<br>(30.08.2024) | NOT YET<br>CHARGED | -        | TRIPPED ON FAULT    |
| 4927  | 01-Sep-2024 | TUMKUR   | 220     | LINE        | BENKIKERE 220KV-HONNALLI<br>LINE 2            | BENKIKERE_220                                                        | 22:36<br>(25.08.2024) | NOT YET<br>CHARGED | -        | LINE CLEAR AVAIED   |
| 4928  | 01-Sep-2024 | TUMKUR   | 220     | LINE        | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE) | HOSADURGA_220                                                        | 23:03<br>(25.08.2024) | NOT YET<br>CHARGED | -        | LINE CLEAR AVAIED   |
| 4929  | 01-Sep-2024 | TUMKUR   | 66      | LINE        | MADHUGIRI_220-<br>PULAMAGHATTA_66             | 66KV PULAMAGHATTA                                                    | 18:47                 | 18:53              | 00:06    | TRIPPED ON FAULT    |
| 4930  | 01-Sep-2024 | TUMKUR   | 66      | LINE        | KUKKAWADA_66-<br>DAVANGERE_220 LINE 1         | 66KV KUKKUWADA, SHYAGALE,<br>DSCL, THAVANAGI                         | 15:57                 | 16:10              | 00:13    | TRIPPED ON FAULT    |
| 4931  | 01-Sep-2024 | TUMKUR   | 66      | LINE        | 66KV BILICHODU-66KV<br>PALLAGATTE-66KV SOKKE  | 66KV SOKKE                                                           | 00:55                 | 01:05              | 00:10    | MAIN SUPPLY FAILURE |
| 4932  | 01-Sep-2024 | TUMKUR   | 66      | TRANSFORMER | TR-2(12.5MVA)                                 | SASLUHALLA_66                                                        | 14:02                 | 15:25              | 01:23    | LINE CLEAR AVAIED   |



| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                          | Station_Name                                                  | Open_At               | Closed_At       | Duration | REMARKS            |
|-------|-------------|---------|---------|-------------|-----------------------------------------------|---------------------------------------------------------------|-----------------------|-----------------|----------|--------------------|
| 4933  | 01-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(12.5MVA)                                 | ANCHEPALYA_66                                                 | 16:20                 | 17:05           | 00:45    | LINE CLEAR AVAILED |
| 4934  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                                      | 15:43<br>(30.08.2024) | Not yet charged | -        | TRIPPED ON FAULT   |
| 4935  | 02-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HONNALLI<br>LINE 2            | BENKIKERE_220                                                 | 22:36<br>(25.08.2024) | Not yet charged | -        | LINE CLEAR AVAILED |
| 4936  | 02-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE) | HOSADURGA_220                                                 | 23:03<br>(25.08.2024) | Not yet charged | -        | LINE CLEAR AVAILED |
| 4937  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>KOLALA              | KOLALA_66, URDIGERE_66                                        | 22:52<br>(02.09.2024) | Not yet charged | -        | LINE CLEAR AVAILED |
| 4938  | 02-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA 220KV-<br>NAGAMANGALA 1&2          | ANCHEPALYA_220                                                | 16:06                 | 21:46           | 5:40     | LINE CLEAR AVAILED |
| 4939  | 02-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-3(100MVA)                                  | ANTHARASANAHALLI_220                                          | 17:12                 | 17:16           | 0:04     | LINE CLEAR AVAILED |
| 4940  | 02-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                                  | HIRIYUR_220                                                   | 12:54                 | 13:04           | 0:10     | LINE CLEAR AVAILED |
| 4941  | 02-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-3(100MVA)                                  | HIRIYUR_220                                                   | 12:35                 | 12:53           | 0:18     | LINE CLEAR AVAILED |
| 4942  | 02-Sep-2024 | TUMKUR  | 220     | LINE        | NITTUR 220KV- NELAMANGALA                     | NITTUR_220                                                    | 11:45                 | 16:20           | 4:35     | LINE CLEAR AVAILED |
| 4943  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR                 | 13:31                 | 13:42           | 0:11     | TRIPPED ON FAULT   |
| 4944  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR                 | 14:11                 | 14:35           | 0:24     | TRIPPED ON FAULT   |
| 4945  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR                 | 18:55                 | 19:20           | 0:25     | TRIPPED ON FAULT   |
| 4946  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>ANAGODU LINE          | 66KV ANAGODU,ATTTIGERE                                        | 13:50                 | 14:36           | 0:46     | TRIPPED ON FAULT   |
| 4947  | 02-Sep-2024 | TUMKUR  | 220     | LINE        | 220KV CHITRADURGA- 220KV<br>PGCIL LINE        | CHITRADURGA_220                                               | 11:16                 | 13:16           | 2:00     | TRIPPED ON FAULT   |
| 4948  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV B G<br>NAGAR LINE       | 66KV JIDDIGERE,THIPPUR,YEDIYUR                                | 16:06                 | 21:46           | 5:40     | TRIPPED ON FAULT   |
| 4949  | 02-Sep-2024 | TUMKUR  | 110     | LINE        | 220KV K.B CROSS-110KV<br>HANDANKERE LINE      | 110KV HULIYAR, HANDANKERE,<br>DODDAYENNEGERE                  | 06:05                 | 06:20           | 0:15     | TRIPPED ON FAULT   |
| 4950  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>KOLALA ( DABASPETE) | KOLALA_66, URDIGERE_66                                        | 17:01                 | 18:15           | 1:14     | TRIPPED ON FAULT   |
| 4951  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>CHELUR              | CHELURU_66, HOSAKERE_66,<br>HAGALVADI_66, NANDIHALLI<br>CROSS | 11:32                 | 18:00           | 6:28     | LINE CLEAR AVAILED |
| 4952  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR220KV-BEVINAHALLI                      | JAVAGONDANAHALLI_66,<br>BEVINAHALLI_66                        | 12:32                 | 13:41           | 1:09     | LINE CLEAR AVAILED |
| 4953  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR220KV-P R PURA                         | HARIYABBE_66,PDKOTE_66                                        | 12:32                 | 13:43           | 1:11     | LINE CLEAR AVAILED |
| 4954  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV- SUZLON 2                       | SUZLON1_IPP_66                                                | 05:40                 | 05:55           | 0:15     | TRIPPED ON FAULT   |
| 4955  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                  | BILCHODE_66                                                   | 13:04                 | 13:10           | 0:06     | TRIPPED ON FAULT   |
| 4956  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HARIYABBE-HIRIYUR                             | HARIYABBE_66                                                  | 12:20                 | 12:25           | 0:05     | LINE CLEAR AVAILED |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                          | Station_Name                                  | Open_At             | Closed_At          | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|-----------------------------------------------|-----------------------------------------------|---------------------|--------------------|----------|---------------------|
| 4957  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                  | KOLALA_66                                     | 12:30               | 12:50              | 0:20     | LINE CLEAR AVAILED  |
| 4958  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                  | KOLALA_66                                     | 12:00               | 12:25              | 0:25     | LINE CLEAR AVAILED  |
| 4959  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                  | SANIKERE_66                                   | 07:13               | 07:22              | 0:09     | TRIPPED ON FAULT    |
| 4960  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(8MVA)                                     | THIPPUR_66                                    | 16:50               | 16:55              | 0:05     | LINE CLEAR AVAILED  |
| 4961  | 02-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(8MVA)                                     | THIPPUR_66                                    | 21:55               | 22:00              | 0:05     | LINE CLEAR AVAILED  |
| 4962  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | THIPPUR-ANCHEPALYA220                         | THIPPUR_66                                    | 16:05               | 16:30              | 0:25     | LINE CLEAR AVAILED  |
| 4963  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | THIPPUR-ANCHEPALYA220                         | THIPPUR_66                                    | 19:05               | 22:00              | 2:55     | LINE CLEAR AVAILED  |
| 4964  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | YEDIYUR- ANCHEPALYA220KV                      | YEDIYUR_66                                    | 16:50               | 21:50              | 5:00     | MAIN SUPPLY FAILURE |
| 4965  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HONNENAHALLI-<br>DODDASARANGI LINE            | DODDASARANGI_66                               | 18:15               | 19:20              | 1:05     | TRIPPED ON FAULT    |
| 4966  | 02-Sep-2024 | TUMKUR  | 66      | LINE        | HEBBUR-ANCHEPALYA_220 LINE                    | HEBBUR_66,HONNENAHALLI_66                     | 18:20               | 18:40              | 0:20     | TRIPPED ON FAULT    |
| 4967  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                      | 15:43<br>(30.08.24) | Not yet charged    | -        | TRIPPED ON FAULT    |
| 4968  | 03-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HONNALLI<br>LINE 2            | BENKIKERE_220                                 | 22:36<br>(25.08.24) | Not yet charged    | -        | LINE CLEAR AVAILED  |
| 4969  | 03-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE) | HOSADURGA_220                                 | 23:03<br>(25.08.24) | Not yet charged    | -        | LINE CLEAR AVAILED  |
| 4970  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>KOLALA              | KOLALA_66, URDIGERE_66                        | 22:52<br>(02.09.24) | 11:43<br>(3.09.24) | 12:51    | LINE CLEAR AVAILED  |
| 4971  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR | 10:00               | 10:30              | 0:30     | TRIPPED ON FAULT    |
| 4972  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | KUKKAWADA_66-<br>DAVANGERE_220 LINE 1         | NIL                                           | 00:55               | 01:05              | 0:10     | TRIPPED ON FAULT    |
| 4973  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV_MADHUGIRI-66KV<br>KORATAGERE LINE-1     | 66KV HOLAVANAHALLI                            | 00:56               | 01:05              | 0:09     | TRIPPED ON FAULT    |
| 4974  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV HONNALI<br>LINE            | 66KV HONNALI,KATTIGE                          | 20:39               | 20:51              | 0:12     | TRIPPED ON FAULT    |
| 4975  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV KUNDUR<br>LINE             | 66KV<br>KUNDUR,MALEBENNUR,DEVARBEL<br>AKERE   | 22:02               | 22:14              | 0:12     | TRIPPED ON FAULT    |
| 4976  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV<br>BANUVALLI LINE          | 66KV NANDIGUDI,BANUVALLI,EHT<br>CARGIL        | 13:10               | 13:24              | 0:14     | TRIPPED ON FAULT    |
| 4977  | 03-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA 220KV-<br>NELMANGALA 1             | ANCHEPALYA_220                                | 09:35               | 16:51              | 7:16     | LINE CLEAR AVAILED  |
| 4978  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(12.5MVA)                                 | BEVINAHALLI_66                                | 16:26               | 17:26              | 1:00     | LINE CLEAR AVAILED  |
| 4979  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU-PALLAGATTE                           | BILCHODU_66                                   | 20:30               | 20:50              | 0:20     | TRIPPED ON FAULT    |
| 4980  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2(12.5MVA)                                 | BUKKAPATNA_66                                 | 06:15               | 07:16              | 1:01     | LINE CLEAR AVAILED  |
| 4981  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(8MVA)                                    | LOKIKERE_66                                   | 21:10               | 21:45              | 0:35     | TRIPPED ON FAULT    |
| 4982  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | MELEKOTE-BADDIHALLI                           | BADDIHALLI_66                                 | 14:01               | 14:59              | 0:58     | LINE CLEAR AVAILED  |
| 4983  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(8MVA)                                    | RANGANATHAPURA_66                             | 12:21               | 16:29              | 4:08     | LINE CLEAR AVAILED  |
| 4984  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2(8MVA)                                    | RANGANATHAPURA_66                             | 10:55               | 11:12              | 0:17     | LINE CLEAR AVAILED  |
| 4985  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(12.5MVA)                                 | SAVLANGA_66                                   | 13:33               | 14:06              | 0:33     | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                          | Station_Name                                                | Open_At             | Closed_At           | Duration        | REMARKS             |
|-------|-------------|---------|---------|-------------|-----------------------------------------------|-------------------------------------------------------------|---------------------|---------------------|-----------------|---------------------|
| 4986  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(12.5MVA)                                 | THOVINAKERE_66                                              | 12:15               | 12:45               | 0:30            | LINE CLEAR AVAIED   |
| 4987  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-3(12.5MVA)                                 | ANCHEPALYA_66                                               | 05:35               | 06:35               | 1:00            | TRIPPED ON FAULT    |
| 4988  | 03-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-3(12.5MVA)                                 | ANCHEPALYA_66                                               | 19:10               | 19:20               | 0:10            | TRIPPED ON FAULT    |
| 4989  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | SOKKE-JAGLUR                                  | SOKKE_66                                                    | 16:55               | 17:05               | 0:10            | LINE CLEAR AVAIED   |
| 4990  | 03-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU-PALLAGATTE                           | BILCHODU_66                                                 | 15:20               | 15:35               | 0:15            | MAIN SUPPLY FAILURE |
| 4991  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                                    | 15:43<br>(30.08.24) | Not yet charged     | -               | TRIPPED ON FAULT    |
| 4992  | 04-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HONNALLI<br>LINE 2            | BENKIKERE_220                                               | 22:36<br>(25.08.24) | Not yet charged     | -               | LINE CLEAR AVAIED   |
| 4993  | 04-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE) | HOSADURGA_220                                               | 23:03<br>(25.08.24) | Not yet charged     | -               | LINE CLEAR AVAIED   |
| 4994  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR               | 07:42               | 12:35               | 4:53            | TRIPPED ON FAULT    |
| 4995  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV PANDARAHALLI-66KV<br>HOLALKERE LINE      | 66KV<br>HOLALKERE,CHIKKAJAJUR,SASALU<br>HALLA               | 11:40               | 12:10               | 0:30            | TRIPPED ON FAULT    |
| 4996  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV UCHANGIDURGA-66KV<br>BILICHODU           | 66KV PUNABGHATTA,<br>UCHANGIDURGA, BILICHODU,<br>PALLAGATTE | 15:50               | 16:00               | 0:10            | TRIPPED ON FAULT    |
| 4997  | 04-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                  | ANCHEPALYA_66                                               | 12:25               | 12:30               | 0:05            | TRIPPED ON FAULT    |
| 4998  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-BENKIKERE                     | BENKIKERE_66                                                | 12:35               | 17:35               | 5:00            | LINE CLEAR AVAIED   |
| 4999  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-MALLADIHALLI                  | MALLADIHALLI_66                                             | 10:35               | 16:50               | 6:15            | LINE CLEAR AVAIED   |
| 5000  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE SRS _ MAYAKONDA                     | MAYAKONDA_66,<br>SASALUHALLA_66                             | 12:35               | 13:30               | 0:55            | LINE CLEAR AVAIED   |
| 5001  | 04-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE 220-ANGODU                          | ANGODU_66, ATTIGERE_66                                      | 12:45               | 13:14               | 0:29            | LINE CLEAR AVAIED   |
| 5002  | 05-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                                    | 15:43<br>(30.08.24) | Not yet charged     | -               | TRIPPED ON FAULT    |
| 5003  | 05-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HONNALLI<br>LINE 2            | BENKIKERE_220                                               | 22:36<br>(25.08.24) | 15:28<br>(05.09.24) | 10DAYS<br>17:52 | LINE CLEAR AVAIED   |
| 5004  | 05-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE) | HOSADURGA_220                                               | 23:03<br>(25.08.24) | 15:32<br>(05.09.24) | 10DAYS<br>16:31 | LINE CLEAR AVAIED   |
| 5005  | 05-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV<br>TURUVANUR LINE      | 66KV TURUVANUR, BIDARKERE,<br>MADANAYAKANAHALLI             | 06:18               | 06:28               | 0:10            | TRIPPED ON FAULT    |
| 5006  | 05-Sep-2024 | TUMKUR  | 66      | LINE        | KEREBILCHE-SHYAGLE                            | KEREBILCHE_66,<br>SANTHEBENNUR_66                           | 12:20               | 16:25               | 4:05            | LINE CLEAR AVAIED   |
| 5007  | 05-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(8MVA) HONNENAHALLI_66                    | HONNENAHALLI_66                                             | 11:30               | 11:45               | 0:15            | LINE CLEAR AVAIED   |
| 5008  | 05-Sep-2024 | TUMKUR  | 66      | LINE        | CHIKKAJAJUR-HOLALKERE                         | CHIKKAJAJUR_66                                              | 15:30               | 15:35               | 0:05            | LINE CLEAR AVAIED   |
| 5009  | 05-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA 220kv- MAGADI                      | ANCHEPALYA_220                                              | 11:31               | 19:09               | 7:38            | LINE CLEAR AVAIED   |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS | Line                                            | Station_Name                                           | Open_At             | Closed_At           | Duration | REMARKS           |
|-------|-------------|---------|---------|-----------|-------------------------------------------------|--------------------------------------------------------|---------------------|---------------------|----------|-------------------|
| 5010  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV BENKIKERE-66KV NALLUR                     | 66KV NALLUR,LINGADAHALLI                               | 15:43<br>(30.08.24) | Not yet charged     | -        | TRIPPED ON FAULT  |
| 5011  | 06-Sep-2024 | TUMKUR  | 220     | LINE      | 100MVA TRANSFORMER-1-220KV<br>MADHUGIRI         | 220KV MADHUGIRI                                        | 18:16 (06.09.2024)  |                     |          | TRIPPED ON FAULT  |
| 5012  | 06-Sep-2024 | TUMKUR  | 220     | LINE      | 220KV GOWRIBIDANUR LINE,                        | no station affected                                    | 18:16 (06.09.2024)  |                     |          | TRIPPED ON FAULT  |
| 5013  | 06-Sep-2024 | TUMKUR  | 220     | LINE      | 220KV VPURA LINE-1,                             | NO LOAD AFFECTED                                       | 18:16               | 21:41               | 03:25    | TRIPPED ON FAULT  |
| 5014  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV MADHUGIRI-66KV<br>KORATAGERE LINE1 & 2    | 66KV HOLAVANAHALLI,<br>KORATGERE                       | 20:14               | 21:41               | 01:27    | TRIPPED ON FAULT  |
| 5015  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV MADHUGIRI-66KV<br>PULAMGHATTA             | 66KV PULAMGHATTA                                       | 20:14               | 21:41               | 01:27    | TRIPPED ON FAULT  |
| 5016  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV ANTHARASANAHALLI-<br>66KV KORATAGERE LINE | 66KV BELADHARA,C.T.KERE                                | 18:46               | 18:53               | 00:07    | TRIPPED ON FAULT  |
| 5017  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV BENKIKERE-66KV<br>DEVARAHALLI             | 66KV<br>DEVARAHALLI,SANTHEBENNUR,KE<br>REBILACHI       | 18:38               | 18:48               | 00:10    | TRIPPED ON FAULT  |
| 5018  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV- KUNIGAL                       | KUNIGAL_66                                             | 12:13               | 13:01               | 00:48    | LINE CLEAR AVAIED |
| 5019  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV- AMRUTHUR                      | AMRUTHUR_66,<br>SANTEMAVATTUR_66,<br>YADAVANI_66       | 13:42               | 14:40               | 00:58    | LINE CLEAR AVAIED |
| 5020  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV- BG NAGAR                      | JIDDIGERE_66, YEDIYUR_66,<br>THIPPUR_66, B G NAGARA_66 | 13:03               | 13:41               | 00:38    | LINE CLEAR AVAIED |
| 5021  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV-<br>KEMPANAHALLI               | KEMPANAHALLI_66, AGALKOTE_66                           | 14:02               | 14:34               | 00:32    | LINE CLEAR AVAIED |
| 5022  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV-<br>ANCHEPALYA-1               | ANCHEPALYA 66KV                                        | 14:38               | 15:54               | 01:16    | LINE CLEAR AVAIED |
| 5023  | 06-Sep-2024 | TUMKUR  | 66      | LINE      | ANCHEPALYA 220KV-<br>ANCHEPALYA-2               | ANCHEPALYA 66KV                                        | 14:38               | 15:54               | 01:16    | LINE CLEAR AVAIED |
| 5024  | 06-Sep-2024 | TUMKUR  | 220     | LINE      | BENKIKERE 220KV-HONNALLI<br>LINE 2              | BENKIKERE_220                                          | 19:55<br>(06.09.24) |                     |          | LINE CLEAR AVAIED |
| 5025  | 06-Sep-2024 | TUMKUR  | 220     | LINE      | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE)   | HOSADURGA_220                                          | 19:55<br>(06.09.24) |                     |          | LINE CLEAR AVAIED |
| 5026  | 07-Sep-2024 | TUMKUR  | 220     | LINE      | BENKIKERE 220KV-HONNALLI<br>LINE 2              | BENKIKERE_220                                          | 19:55<br>(06.09.24) | 09:24<br>(07.09.24) | 13:29    | LINE CLEAR AVAIED |
| 5027  | 07-Sep-2024 | TUMKUR  | 220     | LINE      | BENKIKERE 220KV-HOSADURGA<br>LINE 1 (MADHURE)   | HOSADURGA_220                                          | 19:55<br>(06.09.24) | 09:24<br>(07.09.24) | 13:29    | LINE CLEAR AVAIED |
| 5028  | 07-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV BENKIKERE-66KV NALLUR                     | 66KV NALLUR,LINGADAHALLI                               | 15:43<br>(30.08.24) | Not yet charged     | -        | TRIPPED ON FAULT  |
| 5029  | 07-Sep-2024 | TUMKUR  | 220     | LINE      | ANCHEPALYA-NAGAMANGALA-2                        | NO LOAD AFFECTED ( I/C ON<br>NAGAMANGAALA -1 LINE)     | 15:02               | 15:12               | 00:10    | TRIPPED ON FAULT  |
| 5030  | 07-Sep-2024 | TUMKUR  | 220     | LINE      | ANCHEPALYA-NAGAMANGALA-2                        | NO LOAD AFFECTED ( I/C ON<br>NAGAMANGAALA -1 LINE)     | 15:12               | 17:25               | 02:13    | TRIPPED ON FAULT  |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                             | Station_Name                                              | Open_At                | Closed_At          | Duration | REMARKS            |
|-------|-------------|---------|---------|-------------|--------------------------------------------------|-----------------------------------------------------------|------------------------|--------------------|----------|--------------------|
| 5031  | 07-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA-NAGAMANGALA-2                         | NO LOAD AFFECTED ( I/C ON NAGAMANGAALA -1 LINE)           | 17:25:00 ( 07.09.2024) |                    |          | TRIPPED ON FAULT   |
| 5032  | 07-Sep-2024 | TUMKUR  | 220     | LINE        | 100MVA TRANSFORMER-1-220KV MADHUGIRI             | NIL                                                       | 18:16 (06.09.2024)     | 9:05 (07.09.2024)  | 14:49    | TRIPPED ON FAULT   |
| 5033  | 07-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV MAYAKONDA LINE              | 66KV MAYAKONDA,SASALUHALLA                                | 06:05                  | 06:20              | 00:15    | TRIPPED ON FAULT   |
| 5034  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                      | 66KV NALLUR,LINGADAHALLI                                  | 15:43 (30.08.24)       | Not yet charged    | -        | TRIPPED ON FAULT   |
| 5035  | 08-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV GUTTUR -400KV KAIGA LINE 2                 | 400KV GUTTUR                                              | 10:10                  | 17:54              | 07:44    | TRIPPED ON FAULT   |
| 5036  | 08-Sep-2024 | TUMKUR  | 220     | LINE        | 220KV ANCHEPALYA-220KV NAGAMANGALA LINE 2        | 220KV ANCHEPALYA-                                         | 17:25 ( 07.09.2024)    | 14:15 (08.09.2024) | 20:50    | TRIPPED ON FAULT   |
| 5037  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV RAMAGIRI-66KV BAGUR LINE                    | 66KV RAMAGIRI                                             | 17:55                  | 18:10              | 00:15    | TRIPPED ON FAULT   |
| 5038  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV HIRIYUR LINE              | 66KV J N KOTE,AIMANGALA,MALLAPANAHALLI                    | 16:12                  | 16:18              | 00:06    | TRIPPED ON FAULT   |
| 5039  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV MAYAKONDA-66KV SASALUHALLA LINE             | 66KV CHIKKAJAJUR,SASALUHALLA                              | 07:25                  | 07:30              | 00:05    | TRIPPED ON FAULT   |
| 5040  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV HONNALI LINE                  | 66KV HONNALI, KATTIGE                                     | 08:47                  | 08:57              | 00:10    | TRIPPED ON FAULT   |
| 5041  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV HONNALI LINE                  | 66KV HONNALI, KATTIGE                                     | 13:43                  | 13:53              | 00:10    | TRIPPED ON FAULT   |
| 5042  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV KUNDUR LINE                   | 66KV KUNDUR,MALEBENNUR,DEVARABELAKERE                     | 21:53                  | 22:03              | 00:10    | TRIPPED ON FAULT   |
| 5043  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-SIRA(RANGANATHAPURA)               | SIRA_66                                                   | 16:30                  | 17:30              | 01:00    | LINE CLEAR AVAILED |
| 5044  | 08-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-NELMANGALA 1                    | ANCHEPALYA_220                                            | 10:36                  | 14:15              | 03:39    | LINE CLEAR AVAILED |
| 5045  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                      | 66KV NALLUR,LINGADAHALLI                                  | 15:43 (30.08.2024)     | Not yet charged    | -        | TRIPPED ON FAULT   |
| 5046  | 09-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-3-220KV THALLAK               | 66KV P.R PURA, IPP WELSPAN -1 & 2                         | 11:43                  | 11:46              | 00:03    | TRIPPED ON FAULT   |
| 5047  | 09-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-2-220KV ANTHRASANAHALLI 220KV | BELLAVI_66,CHELUR_66,MELEKOTE_66, KORATAGERE_66,KOLALA_66 | 16:20                  | 17:50              | 01:30    | LINE CLEAR AVAILED |
| 5048  | 09-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-1-220KV ANTHRASANAHALLI 220KV | BELLAVI_66,CHELUR_66,MELEKOTE_66, KORATAGERE_66,KOLALA_66 | 16:10                  | 16:22              | 00:12    | LINE CLEAR AVAILED |
| 5049  | 09-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-1-220KV ANTHRASANAHALLI 220KV | BELLAVI_66,CHELUR_66,MELEKOTE_66, KORATAGERE_66,KOLALA_66 | 17:28                  | 17:49              | 00:21    | LINE CLEAR AVAILED |
| 5050  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV PANDARAHALLI LINE 1       | 66KV BHARAMSAGARA,SIRIGERE,VIJAPURA                       | 06:08                  | 06:15              | 00:07    | TRIPPED ON FAULT   |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                        | Station_Name                                              | Open_At            | Closed_At          | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|---------------------------------------------|-----------------------------------------------------------|--------------------|--------------------|----------|---------------------|
| 5051  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV HIRIYUR LINE         | 66KV J N KOTE,AIMANGALA,MALLAPANAHALLI                    | 18:46              | 18:59              | 00:13    | TRIPPED ON FAULT    |
| 5052  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA                                            | 14:25              | 15:06              | 00:41    | TRIPPED ON FAULT    |
| 5053  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA                                            | 15:10              | 16:09              | 00:59    | TRIPPED ON FAULT    |
| 5054  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA                                            | 16:14              | 19:05              | 02:51    | TRIPPED ON FAULT    |
| 5055  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA                                            | 21:59              | 22:12              | 00:13    | TRIPPED ON FAULT    |
| 5056  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV MELLEKATTE          | 66KV MELLEKATTE                                           | 21:48              | 21:58              | 01:13    | TRIPPED ON FAULT    |
| 5057  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA                                            | 23:12 (09.09.2024) | Not yet charged    | -        | TRIPPED ON FAULT    |
| 5058  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE -66KV MELLAKATTE           | 66KV HONNALI,KATTIGE                                      | 21:48              | 21:58              | 00:10    | TRIPPED ON FAULT    |
| 5059  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV HONNALI LINE             | 66KV HONNALI,KATTIGE                                      | 15:10              | 15:20              | 00:10    | TRIPPED ON FAULT    |
| 5060  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV BHARAMASAGARA- KNNL O/G LINE           | KNNL                                                      | 05:59              | 06:28              | 00:29    | TRIPPED ON FAULT    |
| 5061  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- NAYAKANHATTI                 | NAYAKANHATTI_66, HIREMALLANAHOLE_66                       | 11:07              | 11:09              | 00:02    | LINE CLEAR AVAILED  |
| 5062  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- GOWRASAMUDRA                 | GOWRASAMUDRA,KONANSAGARA                                  | 11:24              | 11:26              | 00:02    | LINE CLEAR AVAILED  |
| 5063  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | KEREBILCHI-SANTHEBENNUR                     | SANTHEBENNUR_66                                           | 11:20              | 11:25              | 00:05    | TRIPPED ON FAULT    |
| 5064  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | MALLAPPANAHALLI- HIRIYUR                    | MALLAPPANAHALLI_66                                        | 18:45              | 18:55              | 00:10    | MAIN SUPPLY FAILURE |
| 5065  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- NAYAKANHATTI                 | NAYAKANHATTI_66, HIREMALLANAHOLE_66                       | 11:45              | 11:54              | 00:09    | MAIN SUPPLY FAILURE |
| 5066  | 09-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220-P R PURA                        | PR PURA_66,MYLANAHALLI_66, V V PORA_66, DYAVARANAHALLI_66 | 11:46              | 11:49              | 00:03    | MAIN SUPPLY FAILURE |
| 5067  | 09-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | 100MVA TRANSFORMER-3(LV SIDE) THALLAK_220KV | THALLAK_220KV                                             | 11:43              | 11:47              | 00:04    | TRIPPED ON FAULT    |
| 5068  | 09-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 12.5 MVA                               | ANCHEPALYA_66                                             | 10:30              | 11:15              | 00:45    | LINE CLEAR AVAILED  |
| 5069  | 09-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1 20 MVA                                 | K.B.CROSS_220KV                                           | 18:15              | 18:55              | 00:40    | TRIPPED ON FAULT    |
| 5070  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                 | 66KV NALLUR,LINGADAHALLI                                  | 15:43 (30.08.24)   | Not yet charged    | -        | TRIPPED ON FAULT    |
| 5071  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE    | 66KV KUKKAWADA 1 LINE                                     | 23:12 (09.09.2024) | 14:58 (10.09.2024) | 15:46    | TRIPPED ON FAULT    |
| 5072  | 10-Sep-2024 | TUMKUR  | 220     | LINE        | DAVANGERE SRS- HONNALI LINE 2               | HONNALLI_220                                              | 10:07              | 13:34              | 03:27    | LINE CLEAR AVAILED  |
| 5073  | 10-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA HIRIYUR POWER TR 01 & 03             | HIRIYUR_220KV                                             | 05:35              | 05:40              | 00:05    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                        | Station_Name                                          | Open_At           | Closed_At       | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|---------------------------------------------|-------------------------------------------------------|-------------------|-----------------|----------|---------------------|
| 5074  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA LINE 1    | 66KV KUKKAWADA                                        | 14:59             | 15:42           | 00:43    | TRIPPED ON FAULT    |
| 5075  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA LINE 2    | 66KV KUKKAWADA                                        | 08:35             | 08:45           | 00:10    | TRIPPED ON FAULT    |
| 5076  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV HIRIYUR LINE         | 66KV J N KOTE,AIMANGALA,MALLAPANAHALLI                | 05:56             | 06:10           | 00:14    | TRIPPED ON FAULT    |
| 5077  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HIRIYUR-66KV P.R PURA LINE            | 66KV KALAMARAHALLI, HARIYABBE PDKOTE                  | 05:35             | 08:11           | 02:36    | TRIPPED ON FAULT    |
| 5078  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV B G NAGAR LINE        | 66KV JIDDIGERE,THIPPUR,YEDIYUR                        | 07:44             | 07:54           | 00:10    | TRIPPED ON FAULT    |
| 5079  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 66KV-BHAKTHARAHALLI O/G LINE     | BHAKTHARAHALLI_66                                     | 10:10             | 10:20           | 00:10    | LINE CLEAR AVAIED   |
| 5080  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA LINE 2    | 66KV KUKKAWADA                                        | 11:40             | 15:05           | 03:25    | LINE CLEAR AVAIED   |
| 5081  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-RANGANATHPURA                 | RANGANATHAPURA_66                                     | 05:38             | 05:55           | 00:17    | MAIN SUPPLY FAILURE |
| 5082  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-BEVINAHALLI                   | JAVAGONDANAHALLI_66, BEVINAHALLI_66                   | 05:38             | 05:55           | 00:17    | MAIN SUPPLY FAILURE |
| 5083  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV- MATHOD-1                     | MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66 | 05:38             | 05:46           | 00:08    | MAIN SUPPLY FAILURE |
| 5084  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV- MATHOD-2                     | MATHOD_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66 | 05:38             | 05:43           | 00:05    | MAIN SUPPLY FAILURE |
| 5085  | 10-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-SIRA(RANGANATHAPURA)          | SIRA_66                                               | 05:38             | 05:54           | 00:16    | MAIN SUPPLY FAILURE |
| 5086  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                 | 66KV NALLUR,LINGADAHALLI                              | 15:43 (30.08.24)  | Not yet charged | -        | TRIPPED ON FAULT    |
| 5087  | 11-Sep-2024 | TUMKUR  | 220     | LINE        | NITTUR 220KV- ARASIKERE                     | NITTUR_220                                            | 16:31             | 17:10           | 00:39    | LINE CLEAR AVAIED   |
| 5088  | 11-Sep-2024 | TUMKUR  | 400     | TRANSFORMER | ICT-2 GUTTUR_400KV                          | GUTTUR_400KV                                          | 9:20 (11.09.2024) | Not yet charged | -        | LINE CLEAR AVAIED   |
| 5089  | 11-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-03-220KV THALLAK         | THALLAK_220KV                                         | 10:39             | 10:57           | 00:18    | TRIPPED ON FAULT    |
| 5090  | 11-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-03-220KV THALLAK         | THALLAK_220KV                                         | 11:28             | 11:44           | 00:16    | TRIPPED ON FAULT    |
| 5091  | 11-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA LINE- 1 (MADHURE) | HOSADURGA_220                                         | 18:10             | 19:00           | 00:50    | LINE CLEAR AVAIED   |
| 5092  | 11-Sep-2024 | TUMKUR  | 220     | LINE        | BENKIKERE 220KV-HOSADURGA LINE -2 (MADHURE) | HOSADURGA_220                                         | 17:00             | 17:58           | 00:58    | LINE CLEAR AVAIED   |
| 5093  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV66KV MAYAKONDA LINE  | 66KV MAYAKONDA,SASALUHALLA,CHIKK AJAJUR               | 15:10             | 15:20           | 00:10    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                      | Station_Name                                              | Open_At              | Closed_At          | Duration            | REMARKS             |
|-------|-------------|---------|---------|-------------|-------------------------------------------|-----------------------------------------------------------|----------------------|--------------------|---------------------|---------------------|
| 5094  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA 1 LINE  | 66KV KUKKAWADA,SHYGALE,TYAVANGI                           | 12:48                | 13:18              | 00:30               | TRIPPED ON FAULT    |
| 5095  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV BILICHODU-66KV PALLAGATTE            | 66KV BILICHODU, PALLAGATTE, SOKKE                         | 03:30                | 04:10              | 00:40               | MAIN SUPPLY FAILURE |
| 5096  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NYAMATHI LINE          | 66KV NYAMATHI,SAVALANGA,CHILUR                            | 04:16                | 04:25              | 00:09               | TRIPPED ON FAULT    |
| 5097  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- NAYAKANHATTI               | NAYAKANHATTI_66, HIREMALLANAHOLE_66                       | 10:39                | 10:58              | 00:19               | MAIN SUPPLY FAILURE |
| 5098  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- NAYAKANHATTI               | NAYAKANHATTI_66, HIREMALLANAHOLE_66                       | 11:28                | 11:41              | 00:13               | MAIN SUPPLY FAILURE |
| 5099  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220-P R PURA                      | PR PURA_66,MYLANAHALLI_66, V V PURA_66, DYAVARANAHALLI_66 | 10:39                | 10:57              | 00:18               | MAIN SUPPLY FAILURE |
| 5100  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220-P R PURA                      | PR PURA_66,MYLANAHALLI_66, V V PURA_66, DYAVARANAHALLI_66 | 11:28                | 11:44              | 00:16               | MAIN SUPPLY FAILURE |
| 5101  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- CHALLAKERE LINE-2          | CHALLAKERE_66, SANIKERE_66                                | 12:52                | 12:57              | 00:05               | TRIPPED ON FAULT    |
| 5102  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV B G NAGAR LINE      | 66KV JIDDIGERE,THIPPUR,YEDIYUR                            | 12:42                | 13:33              | 00:51               | LINE CLEAR AVAIED   |
| 5103  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV- KEMPANAHALLI            | KEMPANAHALLI_66, AGALKOTE_66                              | 14:44                | 14:56              | 00:12               | LINE CLEAR AVAIED   |
| 5104  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV- CHELUR             | CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS   | 09:08                | 18:13              | 09:05               | LINE CLEAR AVAIED   |
| 5105  | 11-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV KUKKAWADA LINE 1  | 66KV KUKKAWADA,SHYGALE,TYAVANGI                           | 10:50                | 12:44              | 01:54               | LINE CLEAR AVAIED   |
| 5106  | 11-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2 (20MVA) 220KV DAVANAGERE             | 220KV DAVANAGERE                                          | 10:05                | 13:36              | 03:31               | LINE CLEAR AVAIED   |
| 5107  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR               | 66KV NALLUR,LINGADAHALLI                                  | 15:43 (30.08.24)     | Not yet charged    | -                   | TRIPPED ON FAULT    |
| 5108  | 12-Sep-2024 | TUMKUR  | 400     | TRANSFORMER | ICT-2 GUTTUR_400KV                        | GUTTUR_400KV                                              | 9:20 (11.09.2024)    | 19:09 (12.09.2024) | 1DAY, 10HR,49 MINTS | LINE CLEAR AVAIED   |
| 5109  | 12-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV HIREMALLANAHOLE-220KV CHITRADURGA-1 | 400KV HIREMALLANAHOLE                                     | 15:18                | 19:38              | 04:20               | TRIPPED ON FAULT    |
| 5110  | 12-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV HIREMALLANAHOLE-220KV CHITRADURGA-2 | 400KV HIREMALLANAHOLE                                     | 15:18:00(12.09.2024) |                    |                     | TRIPPED ON FAULT    |
| 5111  | 12-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                              | KIADB V.N. PURA220KV                                      | 12:00                | 12:12              | 00:12               | LINE CLEAR AVAIED   |
| 5112  | 12-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-2 (100 MVA)                            | KIADB V.N. PURA220KV                                      | 11:48                | 11:54              | 00:06               | LINE CLEAR AVAIED   |



| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                                                           | Open_At                 | Closed_At          | Duration | REMARKS            |
|-------|-------------|---------|---------|-------------|--------------------------------------------|------------------------------------------------------------------------|-------------------------|--------------------|----------|--------------------|
| 5113  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | CHITRADURGA 220KV-TURUVANUR                | MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66 | 18:22                   | 19:10              | 00:48    | LINE CLEAR AVAILED |
| 5114  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 66KV-BHAKTHARAHALLI O/G LINE    | BHAKTHARAHALLI_66                                                      | 10:30                   | 17:45              | 07:15    | LINE CLEAR AVAILED |
| 5115  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-KOLALA ( DABASPETE)  | KOLALA_66, URDIGERE_66                                                 | 13:28                   | 14:29              | 01:01    | LINE CLEAR AVAILED |
| 5116  | 12-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-3(20 MVA)                               | ANTHRASANAHALLI_220                                                    | 19:09                   | 19:17              | 00:08    | TRIPPED ON FAULT   |
| 5117  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-DEVARAHALLI                | DEVARAHALLI_66, SANTEBENNUR_66, KERECHILCHI_66                         | 06:31                   | 06:43              | 00:12    | TRIPPED ON FAULT   |
| 5118  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-SIRA(RANGANATHAPURA)         | SIRA_66                                                                | 15:25                   | 16:18              | 00:53    | LINE CLEAR AVAILED |
| 5119  | 12-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANAGERE 220KV-HONNALI LINE1             | HONNALI_220                                                            | 23:41                   | 00:20              | 00:39    | TRIPPED ON FAULT   |
| 5120  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                                               | 15:43 (30.08.24)        | Not yet charged    | -        | TRIPPED ON FAULT   |
| 5121  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 400KV HIREMALLANAHOLE-220KV CHITRADURGA-2  | 400KV HIREMALLANAHOLE                                                  | 3:18:00 PM (12.09.2024) | 08:45 (13.09.2024) | 17:22    | TRIPPED ON FAULT   |
| 5122  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE --66KV66KV MAYAKONDA LINE | 66KV MAYAKONDA,SASALUHALLA,CHIKK AJAJUR                                | 14:50                   | 15:00              | 00:10    | TRIPPED ON FAULT   |
| 5123  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | KUKKAWADA_66-BASAVAPATNA_66                | 66KV THYAVANAGI                                                        | 06:55                   | 07:10              | 00:15    | TRIPPED ON FAULT   |
| 5124  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV B G NAGAR LINE       | 66KV JIDDIGERE,THIPPUR,YEDIYUR                                         | 07:26                   | 07:36              | 00:10    | TRIPPED ON FAULT   |
| 5125  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NYAMATHI LINE           | 66KV NYAMATHI,SAVALANGA,CHILUR                                         | 04:16                   | 04:25              | 00:09    | TRIPPED ON FAULT   |
| 5126  | 13-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-220KV HONNALI LINE 1       | NILL                                                                   | 23:59                   | 00:22              | 23:37    | TRIPPED ON FAULT   |
| 5127  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | CHITRADURGA 220KV-HIREMALLANAHOLE 1_220    | CHITRADURGA_220                                                        | 06:32                   | 08:44              | 02:12    | LINE CLEAR AVAILED |
| 5128  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | CHITRADURGA 220KV-HIREMALLANAHOLE 2_220    | CHITRADURGA_220                                                        | 23:59                   | 08:45              | 15:14    | LINE CLEAR AVAILED |
| 5129  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | HONNALLI 220KV-DAVANAGERE 2                | HONNALLI_220                                                           | 12:09                   | 13:24              | 01:15    | LINE CLEAR AVAILED |
| 5130  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | HONNALLI 220K-BENKIKERE-1                  | BENKIKERE_220                                                          | 10:45                   | 11:29              | 00:44    | LINE CLEAR AVAILED |
| 5131  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | HONNALLI 220K-BENKIKERE-2                  | BENKIKERE_220                                                          | 11:39                   | 12:08              | 00:29    | LINE CLEAR AVAILED |
| 5132  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | 220KV HONNALLI 1 - BASAVAPATNA_66          | BASAVAPATNA_66, SANTEBENNUR_66, TYAVANAGI_66, KUKKAWADA_66             | 10:50                   | 11:35              | 00:45    | LINE CLEAR AVAILED |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                                               | Open_At                | Closed_At            | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|--------------------------------------------|------------------------------------------------------------|------------------------|----------------------|----------|---------------------|
| 5133  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | 220KV HONNALLI 2 - BASAVAPATNA_66          | BASAVAPATNA_66, SANTEBENNUR_66, TYAVANAGI_66, KUKKAWADA_66 | 11:43                  | 12:08                | 00:25    | LINE CLEAR AVAILED  |
| 5134  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | DAVANGERE SRS- KUKKAWADA 1                 | KUKKAWADA_66, TYAVANAGI_66, SHYAGALE66                     | 10:15                  | 10:39                | 00:24    | LINE CLEAR AVAILED  |
| 5135  | 13-Sep-2024 | TUMKUR  | 220     | LINE        | MADANAYAKANAHALLI-TURUVANUR                | MADANAYAKANAHALLI_66,                                      | 06:35                  | 08:35                | 02:00    | LINE CLEAR AVAILED  |
| 5136  | 13-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1(20MVA)                                | KBCROSS_110                                                | 14:48                  | 15:45                | 00:57    | LINE CLEAR AVAILED  |
| 5137  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                                   | 15:43<br>(30.08.24)    | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5138  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV SOKKE-66KV PALLAGATTE LINE            | 66KV PALLAGATTE                                            | 22:45                  | 22:55                | 00:10    | TRIPPED ON FAULT    |
| 5139  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV BILICHODU-66KV PALLAGATTE LINE        | 66KV BILICHODU,PALLAGATTE                                  | 13:05                  | 13:20                | 00:15    | MAIN SUPPLY FAILURE |
| 5140  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV BILICHODU-66KV PALLAGATTE LINE        | 66KV BILICHODU,PALLAGATTE                                  | 14:20                  | 14:45                | 00:25    | MAIN SUPPLY FAILURE |
| 5141  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV MADHURE-66KV BAGUR LINE              | BAGUR_66                                                   | 05:00                  | 08:05                | 03:05    | TRIPPED ON FAULT    |
| 5142  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV PANDARAHALLI LINE 2 | 66KV HIREGUNTNR                                            | 06:06                  | 06:18                | 00:12    | TRIPPED ON FAULT    |
| 5143  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220-GULIGENAHALLI                      | GULIGENAHALLI_66                                           | 12:30                  | 17:51                | 05:21    | LINE CLEAR AVAILED  |
| 5144  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220-TAVAREKERE                         | TAVAREKERE_66                                              | 10:27                  | 16:13                | 05:46    | LINE CLEAR AVAILED  |
| 5145  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- CHALLAKERE 1                | CHALLAKERE_66, SANIKERE_66                                 | 10:32                  | 17:11                | 06:39    | LINE CLEAR AVAILED  |
| 5146  | 14-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE SRS- HARIHARA(YARAGUNTA)         | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66  | 11:15                  | 12:42                | 01:27    | LINE CLEAR AVAILED  |
| 5147  | 15-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                                   | 15:43<br>(30.08.24)    | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5148  | 15-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE-66KV MAYAKONDA LINE       | 66KV MAYAKONADA,SASLUHALLA, CHIKKAJAJURU                   | 14:00                  | 14:25                | 00:25    | TRIPPED ON FAULT    |
| 5149  | 15-Sep-2024 | TUMKUR  | 66      | LINE        |                                            | 66KV MAYAKONADA,SASLUHALLA, CHIKKAJAJURU                   | 17:00                  | 17:20                | 00:20    | TRIPPED ON FAULT    |
| 5150  | 15-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV RAMAGIRI-66KV BAGURU LINE             | BAGUR_66                                                   | 18:35                  | 18:45                | 00:10    | TRIPPED ON FAULT    |
| 5151  | 15-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV MADHUGIRI-66KV PULAMAGHATTA          | PULAMAGHATTA_66KV                                          | 05:35                  | 05:44                | 00:09    | TRIPPED ON FAULT    |
| 5152  | 15-Sep-2024 | TUMKUR  | 220     | LINE        | SIRA220-GOWRIBIDANUR220                    | SIRA_220                                                   | 10:24                  | 18:36                | 08:12    | LINE CLEAR AVAILED  |
| 5153  | 16-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                                   | 15:43<br>(30.08.24)    | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5154  | 16-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANTHARASANAHALLI-66KV TUMKUR LINE    | 66KV TUMKUR                                                | 22:54:00<br>(16.09.24) | Line Not yet Charged | -        | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                    | Station_Name                                             | Open_At             | Closed_At            | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|-----------------------------------------|----------------------------------------------------------|---------------------|----------------------|----------|---------------------|
| 5155  | 16-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER 3-220KV K B CROSS    | 110KV MAYASANDRA,KADEHALLI,THALKE RE, HANDANKERE,HULIYAR | 12:35               | 12:40                | 00:05    | TRIPPED ON FAULT    |
| 5156  | 16-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV MAYAKONDA-66KV CHIKKAJAJUR LINE    | 66KV CHIKKAJAJUR,SASALUHALLA                             | 16:20               | 16:25                | 00:05    | TRIPPED ON FAULT    |
| 5157  | 16-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NYAMATHI LINE        | 66KV NYAMATHI,SAVALANGA,CHILUR                           | 06:18               | 06:33                | 00:15    | TRIPPED ON FAULT    |
| 5158  | 16-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2(12.5MVA)                           | ANCHEPALYA_66                                            | 11:25               | 12:00                | 00:35    | LINE CLEAR AVAIED   |
| 5159  | 17-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR             | 66KV NALLUR,LINGADAHALLI                                 | 15:43<br>(30.08.24) | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5160  | 17-Sep-2024 | TUMKUR  | 66      | LINE        | 220kv ANTHARASANAHALLI-66kv TUMKUR LINE | 66kv TUMKUR                                              | 22:54<br>(16.09.24) | 12:22<br>(17.09.24)  | 13:28    | TRIPPED ON FAULT    |
| 5161  | 17-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV GUTTUR-400kv BEERANAHALLI LINE 1  | BEERANAHALLI1                                            | 14:02               | 15:59                | 01:57    | TRIPPED ON FAULT    |
| 5162  | 17-Sep-2024 | TUMKUR  | 66      | LINE        | 66kv MAYAKONDA-66kv CHIKKAJAJURU LINE   | 66kv CHIKKAJAJUR,SASALUHALLA                             | 18:40               | 18:50                | 00:10    | TRIPPED ON FAULT    |
| 5163  | 17-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE SRS- MELLEKATTE_66            | MELLEKATTE_66, KADAJJI_66                                | 10:49               | 12:40                | 01:51    | LINE CLEAR AVAIED   |
| 5164  | 18-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR             | 66KV NALLUR,LINGADAHALLI                                 | 15:43<br>(30.08.24) | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5165  | 18-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV Guttur-400kv Kaiga LINE 1         | GUTUR_400KV                                              | 06:28:00 (18.09.24) | Not yet charged      |          | TRIPPED ON FAULT    |
| 5166  | 18-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALLI-66KV NALLUR LINE         | 66KV NALLUR,BASAVAPATNA,TYAVANA GI                       | 18:30               | 18:40                | 00:10    | TRIPPED ON FAULT    |
| 5167  | 18-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANAGERE-66KV ANAGODU LINE      | 66KV ANAGODU,ATTIGERE                                    | 08:41               | 08:51                | 00:10    | TRIPPED ON FAULT    |
| 5168  | 18-Sep-2024 | TUMKUR  | 110     | LINE        | KB CROSS 220kv- MAYASANDRA              | MAYASANDRA_110,KADEHALLI_110                             | 11:15               | 12:30                | 01:15    | LINE CLEAR AVAIED   |
| 5169  | 18-Sep-2024 | TUMKUR  | 220     | LINE        | ANTHRASANAHALLI 220kv- SHIMOGA          | ANTHRASANAHALLI_220                                      | 10:12               | 13:41                | 03:29    | LINE CLEAR AVAIED   |
| 5170  | 19-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR             | 66KV NALLUR,LINGADAHALLI                                 | 15:43<br>(30.08.24) | Not yet charged      | -        | TRIPPED ON FAULT    |
| 5171  | 19-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV GUTTUR-400KV KAIGA LINE 1         | GUTUR_400KV                                              | 6:28<br>(18.09.24)  | Line not yet charged |          | TRIPPED ON FAULT    |
| 5172  | 19-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV GUTTUR-400KV KAIGA LINE 2         | GUTUR_400KV                                              | 11:51<br>(19.09.24) | Line not yet charged |          | LINE CLEAR AVAIED   |
| 5173  | 19-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV SOKKE-66KV UJJINI LINE             | 66KV SOKKE,PALLAGATTE,JAGALUR                            | 15:05               | 15:35                | 00:30    | MAIN SUPPLY FAILURE |
| 5174  | 19-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV GUTTUR-66KV HALASABALU LINE       | 66KV GUTTUR 66KV HARIHAR HOSPETE POLY FIBER              | 06:20               | 06:32                | 00:12    | TRIPPED ON FAULT    |
| 5175  | 19-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV HONNALI LINE         | 66KV HONNALI,KATTIGE                                     | 17:17               | 17:27                | 00:10    | TRIPPED ON FAULT    |
| 5176  | 19-Sep-2024 | TUMKUR  | 110     | LINE        | NITTUR 220KV- KG TEMPLE                 | KGTEMPLE_110, UNGRA_110                                  | 11:16               | 12:38                | 01:22    | LINE CLEAR AVAIED   |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS | Line                                      | Station_Name                                                           | Open_At             | Closed_At           | Duration         | REMARKS             |
|-------|-------------|---------|---------|-----------|-------------------------------------------|------------------------------------------------------------------------|---------------------|---------------------|------------------|---------------------|
| 5177  | 19-Sep-2024 | TUMKUR  | 110     | LINE      | SAMPIGE- DODDAGUNI                        | DODDAGUNI_110,AMMASANDRA_110,SAMPIGE_110                               | 12:05               | 12:20               | 00:15            | MAIN SUPPLY FAILURE |
| 5178  | 19-Sep-2024 | TUMKUR  | 110     | LINE      | KB CROSS 220KV-CHIKKANAYAKANAHALLI        | CHIKKANAYAKANAHALLI_110, SHETYKERE_110,                                | 01:25               | 06:05               | 04:40            | TRIPPED ON FAULT    |
| 5179  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | SAMPIGE- DODDAGUNI                        | DODDAGUNI_110,AMMASANDRA_110SAMPIGE_110                                | 17:25               | 17:35               | 00:10            | MAIN SUPPLY FAILURE |
| 5180  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | BILCHODU-PALLAGATTE                       | BILCHODU_66                                                            | 19:15               | 19:30               | 00:15            | LINE CLEAR AVAILED  |
| 5181  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | SOKKE-UJJINI                              | SOKKE_66                                                               | 19:15               | 19:30               | 00:15            | LINE CLEAR AVAILED  |
| 5182  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE SRS- GUTTUR66                   | GUTTUR_66                                                              | 10:15               | 14:40               | 04:25            | LINE CLEAR AVAILED  |
| 5183  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | BENKIKERE 220KV-GOPPENAHALLI              | TAVAREKERE_66, GOPPENAHALLI_66                                         | 10:30               | 14:45               | 04:15            | LINE CLEAR AVAILED  |
| 5184  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE SRS-HARIHARA(YARAGUNTA)         | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66              | 10:37               | 12:40               | 02:03            | LINE CLEAR AVAILED  |
| 5185  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE SRS-HARIHARA(YARAGUNTA)         | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66              | 12:40               | 14:41               | 02:01            | LINE CLEAR AVAILED  |
| 5186  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 66KV-PANDARAHALLI 1 LINE      | PANDARAHALLI_66                                                        | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5187  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 66KV-PANDARAHALLI 2 LINE      | CHITRAHALLI,H.D. PURA_66                                               | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5188  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-CHALLAKERE(BALENAHALLI) | BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66                             | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5189  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-TURUVANUR               | MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66 | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5190  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-HIRIYUR_66              | SANEKERE_66, CHALKERE_66, IMANGALA_66                                  | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5191  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-CHITRADURGA 1           | CHITRADURGA_220                                                        | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5192  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-CHITRADURGA2            | CHITRADURGA_220                                                        | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5193  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-CHITRADURGA 3           | CHITRADURGA_220                                                        | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5194  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV-CHITRADURGA 4           | CHITRADURGA_220                                                        | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5195  | 19-Sep-2024 | TUMKUR  | 66      | LINE      | CHITRADURGA 220KV--THALLAK_220KV          | CHITRADURGA 220KV                                                      | 10:10               | 18:40               | 08:30            | LINE CLEAR AVAILED  |
| 5196  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV BENKIKERE-66KV NALLUR               | 66KV NALLUR,LINGADAHALLI                                               | 15:43<br>(30.08.24) | Not yet charged     | -                | TRIPPED ON FAULT    |
| 5197  | 20-Sep-2024 | TUMKUR  | 400     | LINE      | 400KV GUTTUR-400KV KAIGA LINE 2           | GUTUR_400KV                                                            | 11:51<br>(19.09.24) | 21:34<br>(20.09.24) | 1 Days<br>9:43HR | LINE CLEAR AVAILED  |
| 5198  | 20-Sep-2024 | TUMKUR  | 400     | LINE      | 400KV GUTTUR-400KV KAIGA LINE 1           | GUTUR_400KV                                                            | 6:28<br>(18.09.24)  | 10:20<br>(20.09.24) | 2 Days<br>3:52Hr | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS | Line                                                      | Station_Name                                                                | Open_At | Closed_At | Duration | REMARKS             |
|-------|-------------|---------|---------|-----------|-----------------------------------------------------------|-----------------------------------------------------------------------------|---------|-----------|----------|---------------------|
| 5199  | 20-Sep-2024 | TUMKUR  | 220     | LINE      | GUTTUR 400- CHITRADURGA 220                               | CHITRADURGA_220                                                             | 12:30   | 13:52     | 01:22    | LINE CLEAR AVAILED  |
| 5200  | 20-Sep-2024 | TUMKUR  | 220     | LINE      | DAVANGERE SRS- GUTTUR-1                                   | DAVANGERE_SRS_220                                                           | 06:40   | 07:25     | 00:45    | LOAD CURTAILMENT    |
| 5201  | 20-Sep-2024 | TUMKUR  | 110     | LINE      | 220KV K B CROSS-110KV C N HALLI LINE                      | 110KV C N HALLI,SHETTIKERE                                                  | 01:25   | 06:05     | 04:40    | TRIPPED ON FAULT    |
| 5202  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 66KV HANGAL - 66KV THALLAK LINE 1                         | 66KV HANGAL,NAGASAMUDRA,RAMPUR A                                            | 02:14   | 02:30     | 00:16    | TRIPPED ON FAULT    |
| 5203  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 66KV HANGAL - 66KV THALLAK LINE 2                         | 66KV HANGAL,NAGASAMUDRA,RAMPUR A                                            | 02:14   | 02:30     | 00:16    | TRIPPED ON FAULT    |
| 5204  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV THALLAK-66KV B.G KERE LINE-2                        | 66KV HANGAL,NAGASAMUDRA,RAMPUR A                                            | 02:17   | 02:41     | 00:24    | TRIPPED ON FAULT    |
| 5205  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 66KV HARIYABBE-66KV KALAMARANAHALLI LINE                  | 66KV HARIYABBE,P D KOTE                                                     | 15:01   | 15:08     | 00:07    | TRIPPED ON FAULT    |
| 5206  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV HONNALI-66KV SASVEHALLI LIFT IRRIGATION SYSTEM LINE | 66KV SASVEHALLI LIS                                                         | 13:15   | 13:24     | 00:09    | TRIPPED ON FAULT    |
| 5207  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 220KV HONNALI-66KV NALLUR LINE                            | 66KV NALLUR, BASAVAPATNA,TYAVANGI                                           | 13:48   | 13:55     | 00:07    | TRIPPED ON FAULT    |
| 5208  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 66KV KUKKAWADA-66KV BASAVAPATNA LINE                      | 66KV THAVANAGI                                                              | 09:50   | 10:00     | 00:10    | TRIPPED ON FAULT    |
| 5209  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | 66KV GARAGA-66KV PANCHANAHALLI LINE                       | 66KV PANCHANAHALLI                                                          | 02:30   | 02:45     | 00:15    | TRIPPED ON FAULT    |
| 5210  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | HINDASGHATTA66- HIRIYUR220KV                              | HINDASGHATTA_66                                                             | 15:05   | 16:50     | 01:45    | MAIN SUPPLY FAILURE |
| 5211  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | HIREHALLI - DABASPET                                      | HIREHALLI_66                                                                | 14:20   | 14:35     | 00:15    | MAIN SUPPLY FAILURE |
| 5212  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | THALLAK 220KV- SEI DIAMOND SOLAR IPP_66                   | MYLANAHALLI_66, DYAVARANAHALLI_66                                           | 18:47   | 20:50     | 02:03    | LINE CLEAR AVAILED  |
| 5213  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | THALLAK 220KV- SEI VENUS DIAMOND IPP_66                   | VENUS DIAMOND_IPP_66                                                        | 18:47   | 20:54     | 02:07    | LINE CLEAR AVAILED  |
| 5214  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | THALLAK 220KV - BGKERE 2                                  | BGKERE_66                                                                   | 11:15   | 16:51     | 05:36    | LINE CLEAR AVAILED  |
| 5215  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE SRS- HARIHARA(YARAGUNTA)                        | HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66                  | 06:43   | 07:19     | 00:36    | LOAD CURTAILMENT    |
| 5216  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE SRS- MELLEKATTE_66                              | MELLEKATTE_66, KADAJJI_66                                                   | 06:40   | 07:17     | 00:37    | LOAD CURTAILMENT    |
| 5217  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | DAVANGERE 220-ANGODU                                      | ANGODU_66, ATTIGE_66                                                        | 06:41   | 07:18     | 00:37    | LOAD CURTAILMENT    |
| 5218  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | MATHOD- PANCHANAHALLI                                     | PANCHANAHALLI_66, GARAGA_66                                                 | 14:20   | 17:15     | 02:55    | LINE CLEAR AVAILED  |
| 5219  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | MATHOD_66KV- HIRIYUR                                      | HALRAMESWARA_66,MADADKERE_66,RAMGIRI_66,BAGUR_66,HOSA DURGA_66,NEERGUNDA_66 | 14:45   | 16:50     | 02:05    | LINE CLEAR AVAILED  |
| 5220  | 20-Sep-2024 | TUMKUR  | 66      | LINE      | KANCHIPURA-MATHOD 66                                      | KANCHIPURA_66                                                               | 14:45   | 16:55     | 02:10    | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                     | Station_Name                                                 | Open_At             | Closed_At       | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|------------------------------------------|--------------------------------------------------------------|---------------------|-----------------|----------|---------------------|
| 5221  | 20-Sep-2024 | TUMKUR  | 66      | LINE        | HALURAMESWARA- GUTTUR LINE               | HALURAMESWARA_66                                             | 11:27               | 13:28           | 02:01    | LINE CLEAR AVAILED  |
| 5222  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR              | 66KV NALLUR,LINGADAHALLI                                     | 15:43<br>(30.08.24) | Not yet charged | -        | TRIPPED ON FAULT    |
| 5223  | 21-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100 MVA TR-2<br>ANTHRASANAHALLI 220KV    | ANTHRASANAHALLI 220KV                                        | 13:11               | 14:50           | 01:39    | LINE CLEAR AVAILED  |
| 5224  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | GUTTUR 400KV- KAIGA 1KV                  | GUTUR_400                                                    | 11:52               | 20:20           | 08:28    | LINE CLEAR AVAILED  |
| 5225  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | BUS REACTOR-2                            | JUGALUR_400KV                                                | 10:30               | 21:35           | 11:05    | LINE CLEAR AVAILED  |
| 5226  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>KORATAGERE     | CHIKKATOTLUKERE_66,<br>BELADARA_66, KORATAGERE_66            | 10:03               | 17:40           | 07:37    | LINE CLEAR AVAILED  |
| 5227  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>MELEKOTE       | MELKOTE_66, BADDIHALI_66                                     | 10:09               | 15:00           | 04:51    | LINE CLEAR AVAILED  |
| 5228  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>URDIGERE       | URDIGERE_66                                                  | 12:48               | 13:40           | 00:52    | LINE CLEAR AVAILED  |
| 5229  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | CHITRADURGA 220KV-<br>CHITRADURGA 3      | CHITRADURGA_3 LINE                                           | 12:56 (21.09.2024)  | Not yet charged | -        | TRIPPED ON FAULT    |
| 5230  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NALLUR<br>LINE        | 66KV NALLUR,<br>BASAVAPATNA,TYAVANGI                         | 23:24               | 23:34           | 00:10    | TRIPPED ON FAULT    |
| 5231  | 21-Sep-2024 | TUMKUR  | 110     | LINE        | K.B.CROSS_220KV-<br>THURUVEKERE_110      | 110KV THURUVEKERE,<br>NONAVINAKERE,<br>GVUNGURUMALE,THANDAGA | 08:44               | 08:52           | 00:08    | TRIPPED ON FAULT    |
| 5232  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | MADHUGIRI_220-<br>KORATAGERE_66-2 LINE   | KORATAGERE_66                                                | 06:06               | 06:30           | 00:24    | TRIPPED ON FAULT    |
| 5233  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | MADHUGIRI_220-<br>PULAMAGHATTA_66        | 66KV PULUMGHATTA                                             | 21:31               | 21:45           | 00:14    | TRIPPED ON FAULT    |
| 5234  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV<br>DEVARAHALLI LINE | 66KV<br>DEVARAHALLI,SANTHEBENNUR,KE<br>REBILACHI             | 05:57               | 06:05           | 00:08    | TRIPPED ON FAULT    |
| 5235  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- CHALLAKERE 1              | CHALLAKERE_66, SANIKERE_66                                   | 14:33               | 17:34           | 03:01    | LINE CLEAR AVAILED  |
| 5236  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV - BARC 1                   | BARC 1                                                       | 14:53               | 16:49           | 01:56    | LINE CLEAR AVAILED  |
| 5237  | 21-Sep-2024 | TUMKUR  | 66      | LINE        | KEREBILCHI- BENKIKERE_220KV              | KEREBILCHI_66                                                | 05:57               | 06:05           | 00:08    | MAIN SUPPLY FAILURE |
| 5238  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR              | 66KV NALLUR,LINGADAHALLI                                     | 15:43<br>(30.08.24) | Not yet charged | -        | TRIPPED ON FAULT    |
| 5239  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | CHITRADURGA 220KV-<br>CHITRADURGA 3      | CHITRADURGA_3 LINE                                           | 12:56 (21.09.2024)  | Not yet charged | -        | TRIPPED ON FAULT    |
| 5240  | 22-Sep-2024 | TUMKUR  | 400     | LINE        | 400KV GUTTUR-400KV BTPS LINE             | 400KV GUTTUR                                                 | 01:55               | 16:47           | 14:52    | TRIPPED ON FAULT    |
| 5241  | 22-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400-<br>DONI 400(GUDDADAHALLI)    | GUDDADAHALLI_400                                             | 10:37               | 16:26           | 05:49    | LINE CLEAR AVAILED  |
| 5242  | 22-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA 220KV- MAGADI<br>220KV        | ANCHEPALYA_220                                               | 10:20               | 18:48           | 08:28    | LINE CLEAR AVAILED  |
| 5243  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV B G<br>NAGAR LINE  | 66KV JIDDIGERE,THIPPUR,YEDIYUR                               | 06:01               | 06:11           | 00:10    | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                    | Station_Name                                                              | Open_At            | Closed_At          | Duration     | REMARKS             |
|-------|-------------|---------|---------|-------------|-----------------------------------------|---------------------------------------------------------------------------|--------------------|--------------------|--------------|---------------------|
| 5244  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV KUNIGAL LINE      | 66KV KUNIGAL                                                              | 07:06              | 07:17              | 00:11        | TRIPPED ON FAULT    |
| 5245  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV ANCHEPALYA LINE 2 | 66KV HULLENAHALLI,KUDUR,SRIGIRIPUR A                                      | 07:06              | 07:17              | 00:11        | TRIPPED ON FAULT    |
| 5246  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV BILICHODU-66KV UCHANGIDURGA        | BILICHODU_66KV                                                            | 02:20              | 02:35              | 00:15        | TRIPPED ON FAULT    |
| 5247  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NYAMATHI LINE        | 66KV NYAMATHI,SAVALANGA,CHILUR                                            | 14:29              | 14:39              | 00:10        | TRIPPED ON FAULT    |
| 5248  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV SASVEHALLI LINE      | 66KV SASVEHALLI                                                           | 15:24              | 15:34              | 00:10        | TRIPPED ON FAULT    |
| 5249  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NALLUR LINE          | 66KV NALLUR, BASAVAPATNA,TYAVANGI                                         | 14:50              | 15:01              | 00:11        | TRIPPED ON FAULT    |
| 5250  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV DEVARAHALLI        | 66KV DEVARAHALLI,SANTHEBENNUR,KE REBILACHI                                | 12:42              | 12:55              | 00:13        | TRIPPED ON FAULT    |
| 5251  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV MELLEKATTE LINE    | 66KV MELLEKATTE,KADAJJI                                                   | 13:17              | 13:51              | 00:34        | TRIPPED ON FAULT    |
| 5252  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV MELLEKATTE LINE    | 66KV MELLEKATTE,KADAJJI                                                   | 14:03              | 14:30              | 00:27        | TRIPPED ON FAULT    |
| 5253  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV MAYAKONDA LINE     | 66KV MAYAKONDA,SASALUHALLA,CHIKK AJAJUR                                   | 22:46              | 22:56              | 00:10        | TRIPPED ON FAULT    |
| 5254  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV MAYAKONDA-66KV SASLUHALLA LINE     | 66KV SASALUHALLA,CHIKKAJAJUR                                              | 18:40              | 18:55              | 00:15        | TRIPPED ON FAULT    |
| 5255  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV MADHUGIRI-66KV KORATAGERE LINE 2  | 66KV KORATAGERE                                                           | 04:25              | 04:30              | 00:05        | TRIPPED ON FAULT    |
| 5256  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV MADHUGIRI-66KV PULAMGHATTA LINE   | 66KV PULAMGHATTA                                                          | 01:36              | 01:43              | 00:07        | TRIPPED ON FAULT    |
| 5257  | 22-Sep-2024 | TUMKUR  | 66      | LINE        | KEREBILCHI- BENKIKERE_220KV             | KEREBILCHI_66                                                             | 12:45              | 12:55              | 00:10        | MAIN SUPPLY FAILURE |
| 5258  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR             | 66KV NALLUR,LINGADAHALLI                                                  | 15:43 (30.08.24)   | Not yet charged    | -            | TRIPPED ON FAULT    |
| 5259  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | CHITRADURGA 220KV- CHITRADURGA 3        | CHITRADURGA_3 LINE                                                        | 12:56 (21.09.2024) | 16:00 (23.09.2024) | 2Days 3:04HR | TRIPPED ON FAULT    |
| 5260  | 23-Sep-2024 | TUMKUR  | 400     | LINE        | 315 MVA ICT-2 LV SIDE-400KV GUTTUR      | 400KV GUTTUR                                                              | 04:57              | 05:36              | 00:39        | TRIPPED ON FAULT    |
| 5261  | 23-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-3-220KV K B CROSS    | 110KV HULIYAR, HANDANKERE, DODDAYENNEGERE,MAYASANDRA , THALKERE,KADEHALLI | 17:30              | 17:50              | 00:20        | TRIPPED ON FAULT    |
| 5262  | 23-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-2-220KV SIRA         | SIRA_220KV                                                                | 14:57              | 15:53              | 00:56        | LINE CLEAR AVAILED  |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                     | Station_Name                                             | Open_At | Closed_At | Duration | REMARKS            |
|-------|-------------|---------|---------|-------------|------------------------------------------|----------------------------------------------------------|---------|-----------|----------|--------------------|
| 5263  | 23-Sep-2024 | TUMKUR  | 110     | LINE        | 220KV K B CROSS-110KV THIMMANAHALLI LINE | 110KV THIMMANAHALLI,KATHRIKEHAL                          | 06:08   | 06:18     | 00:10    | TRIPPED ON FAULT   |
| 5264  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV GUTTUR - 66KV HALASABALU LINE      | 66KV GUTTUR, 66KV HARIHAR HOSPETE, 66KV POLY FIBERS      | 20:35   | 20:47     | 00:12    | TRIPPED ON FAULT   |
| 5265  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV KUKKAWADA LINE 1    | 66KV KUKKAWADA                                           | 11:37   | 12:02     | 00:25    | TRIPPED ON FAULT   |
| 5266  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV J N KOTE-66KV MALLAPANAHALLI LINE   | 66KV AIMANGALA,MALLAPANAHALLI                            | 18:38   | 18:46     | 00:08    | TRIPPED ON FAULT   |
| 5267  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NALLUR LINE           | 66KV NALLUR, BASAVAPATNA,TYAVANGI                        | 08:47   | 08:57     | 00:10    | TRIPPED ON FAULT   |
| 5268  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV KUNDUR LINE           | 66KV KUNDUR,MALEBENNUR,DEVARABE LAKERE                   | 20:57   | 21:09     | 00:12    | TRIPPED ON FAULT   |
| 5269  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALI 220KV-KORATAGERE          | CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66           | 15:03   | 17:38     | 02:35    | LINE CLEAR AVAILED |
| 5270  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220-P R PURA                     | PR PURA_66,MYLANAHALLI_66, V V PORA_66, DYAVARANAHALI_66 | 10:07   | 16:38     | 06:31    | LINE CLEAR AVAILED |
| 5271  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV - BGKERE 2                 | BGKERE_66                                                | 15:38   | 18:22     | 02:44    | LINE CLEAR AVAILED |
| 5272  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV-GOWRASAMUDRA               | GOWRASAMUDRA,KONANSAGARA                                 | 17:23   | 18:34     | 01:11    | LINE CLEAR AVAILED |
| 5273  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | PAVAGADA220-NAGALMADIKE                  | NAGALMADIKE_66                                           | 10:55   | 11:00     | 00:05    | TRIPPED ON FAULT   |
| 5274  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | MADHUGIRI 220KV-PULAMAGATTA              | PULAMGATTA_66                                            | 06:08   | 06:15     | 00:07    | TRIPPED ON FAULT   |
| 5275  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220 - BUKKAPATNA                     | BUKKAPATNA_66                                            | 14:55   | 15:00     | 00:05    | LINE CLEAR AVAILED |
| 5276  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220 - BUKKAPATNA                     | BUKKAPATNA_66                                            | 15:55   | 16:00     | 00:05    | LINE CLEAR AVAILED |
| 5277  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220-TAVAREKERE                       | TAVAREKERE_66                                            | 18:02   | 18:04     | 00:02    | LINE CLEAR AVAILED |
| 5278  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | HANAGAL- THALLAK_66                      | HANGAL_66                                                | 15:38   | 18:20     | 02:42    | LINE CLEAR AVAILED |
| 5279  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2 8MVA                                | HONNALLI_66                                              | 14:15   | 14:40     | 00:25    | LINE CLEAR AVAILED |
| 5280  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 8MVA                                | LINGADAHALLI_66                                          | 20:55   | 21:45     | 00:50    | TRIPPED ON FAULT   |
| 5281  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 8MVA                                | KORA_66                                                  | 13:30   | 14:30     | 01:00    | LINE CLEAR AVAILED |
| 5282  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2 20MVA                               | KORA_66                                                  | 13:45   | 14:30     | 00:45    | LINE CLEAR AVAILED |
| 5283  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | KORA- BRAHMASANDRA                       | KORA_66, BRAHMASANDRA_66, THOVINAKERE_66                 | 13:15   | 14:30     | 01:15    | LINE CLEAR AVAILED |
| 5284  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-3 20MVA                               | KORA_66                                                  | 13:50   | 14:30     | 00:40    | LINE CLEAR AVAILED |
| 5285  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | KORA- ANTHRASANAHALI                     | KORA_66                                                  | 13:50   | 14:30     | 00:40    | LINE CLEAR AVAILED |
| 5286  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2 12.5MVA                             | RAMAPURA_66                                              | 09:45   | 09:55     | 00:10    | TRIPPED ON FAULT   |
| 5287  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | SANIKERE- HIRIYUR                        | SANIKERE_66                                              | 11:29   | 11:31     | 00:02    | LINE CLEAR AVAILED |
| 5288  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1                                     | SANIKERE_66                                              | 13:25   | 13:33     | 00:08    | LINE CLEAR AVAILED |
| 5289  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2                                     | SANIKERE_66                                              | 18:03   | 18:15     | 00:12    | LINE CLEAR AVAILED |



| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                     | Station_Name                               | Open_At             | Closed_At       | Duration | REMARKS           |
|-------|-------------|---------|---------|-------------|------------------------------------------|--------------------------------------------|---------------------|-----------------|----------|-------------------|
| 5290  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2                                     | SANIKERE_66                                | 19:10               | 19:25           | 00:15    | LINE CLEAR AVAIED |
| 5291  | 23-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 & 2                                 | SASALUHALLA_66                             | 09:05               | 15:10           | 06:05    | LINE CLEAR AVAIED |
| 5292  | 23-Sep-2024 | TUMKUR  | 66      | LINE        | SASALUHALLA-MAYAKONDA                    | SASALUHALLA_66                             | 09:05               | 15:10           | 06:05    | LINE CLEAR AVAIED |
| 5293  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | SANIKERE- HIRIYUR                        | SANIKERE_66                                | 11:56               | 12:00           | 00:04    | LINE CLEAR AVAIED |
| 5294  | 24-Sep-2024 | TUMKUR  | 110     | LINE        | NITTUR 220KV- GUBBI                      | GUBBI_110, BIDARE_110                      | 04:15               | 04:38           | 00:23    | TRIPPED ON FAULT  |
| 5295  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR              | 66KV NALLUR,LINGADAHALLI                   | 15:43<br>(30.08.24) | Not yet charged | -        | TRIPPED ON FAULT  |
| 5296  | 24-Sep-2024 | TUMKUR  | 400     | LINE        | JAGALUR 400KV-KODLIGI2                   | JAGALUR 400KV                              | 10:38               | 15:32           | 04:54    | LINE CLEAR AVAIED |
| 5297  | 24-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400-<br>DONI_400(GUDDADAHALLI)    | GUDDADAHALLI_400                           | 10:29               | 17:35           | 07:06    | LINE CLEAR AVAIED |
| 5298  | 24-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV GUTTUR-<br>220KVRANEENNUR LINE     | 220KV RANEENNUR                            | 05:37               | 06:47           | 01:10    | TRIPPED ON FAULT  |
| 5299  | 24-Sep-2024 | TUMKUR  | 110     | LINE        | 220KV NITTUR-110KV GUBBI LINE            | 110KV GUBBI,BIDARE                         | 04:15               | 04:38           | 00:23    | TRIPPED ON FAULT  |
| 5300  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREILACHI-66KV<br>SHYGALE LINE     | WATER SUPPLY                               | 11:40               | 11:45           | 00:05    | TRIPPED ON FAULT  |
| 5301  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREILACHI-66KV<br>SANTHEENNUR LINE | 66KV KEREILACHI,SHYGALE                    | 11:40               | 11:45           | 00:05    | TRIPPED ON FAULT  |
| 5302  | 24-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV GUTTUR-<br>220KVRANEENNUR LINE     | 220KV RANEENNUR                            | 05:37               | 06:47           | 01:10    | TRIPPED ON FAULT  |
| 5303  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>KUKKAWADA LINE 1 | 66KV KUKKAWADA                             | 14:32               | 15:02           | 00:30    | TRIPPED ON FAULT  |
| 5304  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-220KV<br>DAVANGERE LINE 1 | 66KV KUKKAWADA                             | 14:32               | 15:22           | 00:50    | TRIPPED ON FAULT  |
| 5305  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>KUKKAWADA LINE 2 | 66KV KUKKAWADA, SHYAGALE,<br>THAVANAGI     | 15:14               | 15:21           | 00:07    | TRIPPED ON FAULT  |
| 5306  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-220KV<br>DAVANGERE LINE 1 | no station affected                        | 10:50               | 11:00           | 00:10    | TRIPPED ON FAULT  |
| 5307  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-66KV<br>BASAVAPATNA LINE  | 66KV THAVANAGI                             | 10:50               | 11:20           | 00:30    | TRIPPED ON FAULT  |
| 5308  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV KUNDUR<br>LINE        | 66KV<br>KUNDUR,MALEENNUR,DEVARBEL<br>AKERE | 20:57               | 21:09           | 00:12    | TRIPPED ON FAULT  |
| 5309  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>HULIYURDURGA        | HULIYURDURGA_66,<br>CHOWDANAKUPPE_66       | 13:38               | 13:45           | 00:07    | LINE CLEAR AVAIED |
| 5310  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>AMRUTHUR_66         | AMRUTHUR_66                                | 11:53               | 12:53           | 01:00    | LINE CLEAR AVAIED |
| 5311  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | HONNALLI 220KV- NALLUR_66                | NALLUR_66, BASAVAPATNA_66                  | 08:08               | 08:18           | 00:10    | TRIPPED ON FAULT  |
| 5312  | 24-Sep-2024 | TUMKUR  | 66      | LINE        | HONNALLI 220KV- NALLUR_66                | NALLUR_66, BASAVAPATNA_66                  | 11:04               | 11:15           | 00:11    | TRIPPED ON FAULT  |
| 5313  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR              | 66KV NALLUR,LINGADAHALLI                   | 15:43<br>(30.08.24) | Not yet charged | -        | TRIPPED ON FAULT  |
| 5314  | 25-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV-<br>CHITRADURGA_220KV       | GUTTUR_400                                 | 07:46               | 08:49           | 01:03    | TRIPPED ON FAULT  |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                                          | Open_At            | Closed_At                 | Duration       | REMARKS            |
|-------|-------------|---------|---------|-------------|--------------------------------------------|-------------------------------------------------------|--------------------|---------------------------|----------------|--------------------|
| 5315  | 25-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV-<br>CHITRADURGA_220KV         | GUTTUR_400                                            | 08:51              | 13:23                     | 04:32          | TRIPPED ON FAULT   |
| 5316  | 25-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV- BTPS LINE                    | GUTTUR_400                                            | 23:15 (25.09.2024) | Not yet charged           |                | LINE CLEAR AVAILED |
| 5317  | 25-Sep-2024 | TUMKUR  | 220     | LINE        | 100MVA TR-2 BENKIKERE_220KV                | BENNIKERE_220KV                                       | 12:10 (25.09.2024) | Not yet charged           |                | LINE CLEAR AVAILED |
| 5318  | 25-Sep-2024 | TUMKUR  | 220     | LINE        | CHITRADURGA 220KV--<br>THALLAK_220KV       | CHITRADURGA 220KV                                     | 15:43              | 16:57                     | 01:14          | LINE CLEAR AVAILED |
| 5319  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV<br>HULIYURDURGA LINE | 66KV<br>HULIYURDURGA,CHOWDANKUPPE,<br>HULIYAR,NIDSALE | 05:55              | 06:05                     | 00:10          | TRIPPED ON FAULT   |
| 5320  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NYAMATHI<br>LINE        | 66KV<br>NYAMATHI,SAVALANGA,CHILUR                     | 16:27              | 16:37                     | 00:10          | TRIPPED ON FAULT   |
| 5321  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV KUNDUR<br>LINE          | 66KV<br>KUNDUR,MALEBENNUR,DEVARBEL<br>AKERE           | 16:23              | 16:36                     | 00:13          | TRIPPED ON FAULT   |
| 5322  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV PANDARAHALLI-66KV<br>HOLALKERE LINE   | 66KV HOLALKERE                                        | 08:58              | 09:10                     | 00:12          | TRIPPED ON FAULT   |
| 5323  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | THALLAK 220KV- NAYAKANHATTI                | NAYAKANHATTI_66,<br>HIREMALLANAHOLE_66                | 10:06              | 14:08                     | 04:02          | TRIPPED ON FAULT   |
| 5324  | 25-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220-SIRA 1                             | SIRA_66                                               | 11:03              | 11:07                     | 00:04          | LINE CLEAR AVAILED |
| 5325  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1 MATHOD_66                              | MATHOD_66                                             | 15:15              | 15:20                     | 00:05          | TRIPPED ON FAULT   |
| 5326  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1 MELEKATTE_66                           | MELEKATTE_66                                          | 13:15              | 13:30                     | 00:15          | LINE CLEAR AVAILED |
| 5327  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1 MELEKATTE_66                           | MELEKATTE_66                                          | 15:30              | 15:40                     | 00:10          | LINE CLEAR AVAILED |
| 5328  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 MELEKATTE_66                           | MELEKATTE_66                                          | 17:15              | 17:20                     | 00:05          | LINE CLEAR AVAILED |
| 5329  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 MELEKATTE_66                           | MELEKATTE_66                                          | 12:50              | 13:05                     | 00:15          | TRIPPED ON FAULT   |
| 5330  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 MELEKATTE_66                           | MELEKATTE_66                                          | 13:10              | 13:15                     | 00:05          | LINE CLEAR AVAILED |
| 5331  | 25-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 & 2 TURUVANUR_66                      | TURUVANUR_66                                          | 16:40              | 16:45                     | 00:05          | LINE CLEAR AVAILED |
| 5332  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                              | 15:43 (30.08.2024) | NOT YET<br>CHARGED        | —              | TRIPPED ON FAULT   |
| 5333  | 26-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV- BTPS LINE                    | GUTTUR_400                                            | 23:15 (25.09.2024) | 09:48                     | 10:33          | LINE CLEAR AVAILED |
| 5334  | 26-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV- BTPS LINE                    | GUTTUR_400                                            | 09:48              | 17:56                     | 08:08          | LINE CLEAR AVAILED |
| 5335  | 26-Sep-2024 | TUMKUR  | 220     | LINE        | CHITRADURGA 220KV--<br>THALLAK_220KV       | CHITRADURGA 220KV                                     | 10:48              | 19:36                     | 08:48          | LINE CLEAR AVAILED |
| 5336  | 26-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-1-220KV<br>SIRA_220KV   | SIRA_220KV                                            | 06:34              | 07:21                     | 00:47          | TRIPPED ON FAULT   |
| 5337  | 26-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-1-220KV<br>BENKIKERE    | 220KV BENKIKERE                                       | 12:14              | 12:28                     | 00:14          | TRIPPED ON FAULT   |
| 5338  | 26-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TRANSFORMER-2-220KV<br>BENKIKERE    | 220KV BENKIKERE                                       | 12:10 (25.09.2024) | 15:50:00 (<br>26.09.2024) | 1DAY<br>3:40HR | TRIPPED ON FAULT   |
| 5339  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV<br>GOPPENAHALLI LINE  | 66KV GOPPENAHALLI,TAVAREKERE                          | 12:14              | 13:20                     | 01:06          | TRIPPED ON FAULT   |
| 5340  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-BENKIKERE                  | BENKIKERE_66                                          | 12:14              | 12:28                     | 00:14          | LINE CLEAR AVAILED |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                               | Station_Name                                      | Open_At | Closed_At | Duration | REMARKS            |
|-------|-------------|---------|---------|-------------|----------------------------------------------------|---------------------------------------------------|---------|-----------|----------|--------------------|
| 5341  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-MALLADIHALLI                       | MALLADIHALLI_66                                   | 12:14   | 12:28     | 00:14    | LINE CLEAR AVAILED |
| 5342  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-DEVARAHALLI                        | DEVARAHALLI_66,<br>SANTEBENNUR_66, KERECHILCHI_66 | 12:14   | 12:28     | 00:14    | LINE CLEAR AVAILED |
| 5343  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-CHANNAGIRI                         | LINGADAHALLI_66,<br>CHANNAGIRI_66                 | 12:14   | 12:28     | 00:14    | LINE CLEAR AVAILED |
| 5344  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BENKIKERE 220KV-<br>GOPPENAHALLI                   | TAVAREKERE_66,<br>GOPPENAHALLI_66                 | 12:14   | 12:28     | 00:14    | LINE CLEAR AVAILED |
| 5345  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV<br>GOPPENAHALLI LINE          | 66KV GOPPENAHALLI,TAVAREKERE                      | 16:30   | 16:42     | 00:12    | LINE CLEAR AVAILED |
| 5346  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV UCHANGIDURGA-66KV<br>BILICHODU LINE           | 66KV BILICHODU                                    | 17:05   | 17:10     | 00:05    | TRIPPED ON FAULT   |
| 5347  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>HARIHAR HOSPET LINE        | 66KV HARIHARA NEW                                 | 14:48   | 14:57     | 00:09    | TRIPPED ON FAULT   |
| 5348  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV MATHOD-66KV GARAGA<br>PANCHANAHALLI LINE      | 66KV GARAGA PANCHANAHALLI                         | 01:15   | 01:25     | 00:10    | TRIPPED ON FAULT   |
| 5349  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV<br>TURUVANUR LINE           | 66KV<br>TURUVANUR,MADANAYAKANAHALLI               | 15:14   | 15:26     | 00:12    | TRIPPED ON FAULT   |
| 5350  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SHYLAPURA-PAVAGADA                                 | SHYLAPURA_66                                      | 06:30   | 06:45     | 00:15    | TRIPPED ON FAULT   |
| 5351  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SHYLAPURA-MAGALAWADA_66                            | SHYLAPURA_66                                      | 06:30   | 06:45     | 00:15    | TRIPPED ON FAULT   |
| 5352  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU-UCHANGIDURGA                              | BILCHODU_66                                       | 17:05   | 17:10     | 00:05    | TRIPPED ON FAULT   |
| 5353  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SOKKE-JAGLUR                                       | SOKKE_66                                          | 15:25   | 15:35     | 00:10    | TRIPPED ON FAULT   |
| 5354  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | HONNALLI 220KV- NALLUR_66                          | NALLUR_66, BASAVAPATNA_66                         | 12:23   | 12:33     | 00:10    | TRIPPED ON FAULT   |
| 5355  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220 - BUKKAPATNA                               | BUKKAPATNA_66                                     | 06:34   | 07:24     | 00:50    | LINE CLEAR AVAILED |
| 5356  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA66 - KALLAMBELLA                               | KALLAMBELLA_66(ALTERNATIVE)                       | 06:34   | 07:24     | 00:50    | LINE CLEAR AVAILED |
| 5357  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | SIRA220-TAVAREKERE                                 | TAVAREKERE_66                                     | 06:34   | 07:25     | 00:51    | LINE CLEAR AVAILED |
| 5358  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | CHANNAGIRI-BINKIKERE_220KV                         | CHANNAGIRI_66                                     | 11:00   | 17:30     | 06:30    | LINE CLEAR AVAILED |
| 5359  | 26-Sep-2024 | TUMKUR  | 66      | LINE        | UNGRA_110KV - O/G LINE<br>SHETTAGONDANAHALLI_110KV | UNGRA_110KV                                       | 15:40   | 16:25     | 00:45    | LINE CLEAR AVAILED |
| 5360  | 26-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 & TR-2 ,20MVA                                 | CHANNAGIRI_66                                     | 11:00   | 17:30     | 06:30    | LINE CLEAR AVAILED |
| 5361  | 26-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1 ,20MVA                                        | UNGRA_110_KV                                      | 15:25   | 16:10     | 00:45    | LINE CLEAR AVAILED |
| 5362  | 26-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-2,20MVA                                         | UNGRA_110_KV                                      | 15:10   | 15:45     | 00:35    | LINE CLEAR AVAILED |
| 5363  | 26-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1 & TR-2 ,20MVA                                 | KADEHALLI_110KV                                   | 16:40   | 17:00     | 00:20    | LINE CLEAR AVAILED |
| 5364  | 26-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 12.5MVA, CHALLAKERE_66                        | CHALLAKERE_66                                     | 10:05   | 10:57     | 00:52    | LINE CLEAR AVAILED |
| 5365  | 26-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 12.5MVA,<br>HALURAMESWARA_66                  | HALURAMESWARA_66                                  | 13:00   | 15:00     | 02:00    | LINE CLEAR AVAILED |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                          | Station_Name                                  | Open_At            | Closed_At          | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|-----------------------------------------------|-----------------------------------------------|--------------------|--------------------|----------|---------------------|
| 5366  | 26-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 12.5MVA,<br>HULIYURDURGA_66              | HULIYURDURGA_66                               | 14:15              | 15:05              | 00:50    | LINE CLEAR AVAILED  |
| 5367  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                      | 15:43 (30.08.2024) | NOT YET<br>CHARGED | —        | TRIPPED ON FAULT    |
| 5368  | 27-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV GUTTUR-220KV<br>RANEENNUR LINE          | OTHER ZONE                                    | 4:40               | 7:27               | 2:47     | TRIPPED ON FAULT    |
| 5369  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREILACHI-66KV<br>SHYGALE LINE          | WATER SUPPLY                                  | 10:45              | 10:50              | 0:05     | TRIPPED ON FAULT    |
| 5370  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREILACHI-66KV<br>SANTHEENNUR LINE      | 66KV KEREILACHI,SHYGALE                       | 10:45              | 10:50              | 0:05     | TRIPPED ON FAULT    |
| 5371  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV SOKKE-66KV UJJINI LINE                   | 66KV PALLAGATTE,SOKKE                         | 18:25              | 18:40              | 0:15     | MAIN SUPPLY FAILURE |
| 5372  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE        | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR | 5:50               | 5:59               | 0:09     | TRIPPED ON FAULT    |
| 5373  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV CHITRADURGA-66KV<br>PANDARAHALLI LINE 1 | 66KV BARAMASAGARA,<br>SIRIGERE,VIJAPURA       | 6:15               | 6:23               | 0:08     | TRIPPED ON FAULT    |
| 5374  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV<br>SASVEHALLI LIS LINE     | 66KV SASVEHALLI LIS                           | 9:16               | 9:26               | 0:10     | TRIPPED ON FAULT    |
| 5375  | 27-Sep-2024 | TUMKUR  | 220     | LINE        | CHITRADURGA 220KV--<br>THALLAK_220KV          | CHITRADURGA 220KV                             | 11:52              | 16:17              | 4:25     | LINE CLEAR AVAILED  |
| 5376  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE SRS- KUKKAWADA 1                    | KUKKAWADA_66, TYAVANAGI_66,<br>SHYAGALE66     | 12:17              | 12:37              | 0:20     | LINE CLEAR AVAILED  |
| 5377  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | DAVANGERE SRS- KUKKAWADA 2                    | KUKKAWADA_66, TYAVANAGI_66,<br>SHYAGALE66     | 12:17              | 12:37              | 0:20     | LINE CLEAR AVAILED  |
| 5378  | 27-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                                  | SIRA_220                                      | 0:48               | 1:08               | 0:20     | TRIPPED ON FAULT    |
| 5379  | 27-Sep-2024 | TUMKUR  | 220     | LINE        | SIRA220-PATNAYAKANAHALLI 1                    | PATNAYAKANAHALLI 1                            | 0:48               | 1:08               | 0:20     | TRIPPED ON FAULT    |
| 5380  | 27-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                                  | HONNALLI_220                                  | 11:38              | 14:23              | 2:45     | LINE CLEAR AVAILED  |
| 5381  | 27-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-2(100MVA)                                  | HONNALLI_220                                  | 14:25              | 16:13              | 1:48     | LINE CLEAR AVAILED  |
| 5382  | 27-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(20MVA)                                   | BELLAVI_66                                    | 6:00               | 7:10               | 1:10     | LINE CLEAR AVAILED  |
| 5383  | 27-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1(12.5MVA)                                 | BHARANASAGARA_66                              | 6:20               | 6:25               | 0:05     | MAIN SUPPLY FAILURE |
| 5384  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | HARIYABBE-HIRIYUR                             | HARIYABBE_66                                  | 16:36              | 18:34              | 1:58     | LINE CLEAR AVAILED  |
| 5385  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV-CHALLAKERE                      | CHALLAKERE_66, SANIKERE_66                    | 15:18              | 18:12              | 2:54     | LINE CLEAR AVAILED  |
| 5386  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | HIRIYUR 220KV- RKP 1                          | RKP1 IPP_66                                   | 17:40              | 18:08              | 0:28     | LINE CLEAR AVAILED  |
| 5387  | 27-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                  | TURUVANUR_66                                  | 19:29              | 19:49              | 0:20     | TRIPPED ON FAULT    |
| 5388  | 27-Sep-2024 | TUMKUR  | 66      | LINE        | RAMAGIRI_66-CHANNAGIRI_66                     | RAMAGIRI_66                                   | 17:35              | 17:45              | 0:10     | TRIPPED ON FAULT    |
| 5389  | 27-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                  | THOVINAKERE_66                                | 10:35              | 14:30              | 3:55     | LINE CLEAR AVAILED  |
| 5390  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                   | 66KV NALLUR,LINGADAHALLI                      | 15:43 (30.08.2024) | NOT YET<br>CHARGED | —        | TRIPPED ON FAULT    |
| 5391  | 28-Sep-2024 | TUMKUR  | 220     | LINE        | ANTHRASANAHALLI 220KV-<br>VASANTHNARASAPURA 1 | VASANTHNARASAPURA KDB_220                     | 16:19              | 18:35              | 2:16     | LINE CLEAR AVAILED  |
| 5392  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV THALLAK-66KV<br>CHALLAKERE LINE 2       | 66KV CHALLAKERE                               | 9:17               | 9:24               | 0:07     | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                         | Station_Name                                                     | Open_At            | Closed_At             | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|----------------------------------------------|------------------------------------------------------------------|--------------------|-----------------------|----------|---------------------|
| 5393  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MAYAKONDA LINE       | 66KV<br>MAYAKONDA,SASALUHALLA,CHIKK<br>AJAJUR                    | 6:29               | 6:40                  | 0:11     | TRIPPED ON FAULT    |
| 5394  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>KUKKAWADA LINE 1     | KUKKAWADA_66, TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66 | 18:01              | 18:11                 | 0:10     | TRIPPED ON FAULT    |
| 5395  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV- KORA                  | KORA_66, THOVINAKERE_66                                          | 10:32              | 16:41                 | 6:09     | LINE CLEAR AVAIED   |
| 5396  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV-<br>TUMKUR             | TUMKUR_66                                                        | 10:08              | 14:17                 | 4:09     | LINE CLEAR AVAIED   |
| 5397  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(8MVA)                                    | BEVINAHALLI_66                                                   | 10:03              | 16:11                 | 6:08     | MAIN SUPPLY FAILURE |
| 5398  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(8MVA)                                    | BEVINAHALLI_66                                                   | 10:03              | 16:11                 | 6:08     | MAIN SUPPLY FAILURE |
| 5399  | 28-Sep-2024 | TUMKUR  | 66      | LINE        | BEVINAHALLI-<br>JAVAGONDANAHALLI             | BEVINAHALLI_66                                                   | 10:03              | 16:11                 | 6:08     | MAIN SUPPLY FAILURE |
| 5400  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                 | KKKAWADA_66                                                      | 10:15              | 10:25                 | 0:10     | TRIPPED ON FAULT    |
| 5401  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                 | TURUVANUR_66                                                     | 19:03              | 19:13                 | 0:10     | TRIPPED ON FAULT    |
| 5402  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                 | TURUVANUR_66                                                     | 22:00              | 22:15                 | 0:15     | TRIPPED ON FAULT    |
| 5403  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                                 | PULAMAGAHATTA_66                                                 | 10:28              | 16:22                 | 5:54     | MAIN SUPPLY FAILURE |
| 5404  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                 | PULAMAGAHATTA_66                                                 | 10:28              | 16:22                 | 5:54     | MAIN SUPPLY FAILURE |
| 5405  | 28-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(12.5MVA)                                 | THOVINAKERE_66                                                   | 8:42               | 9:17                  | 0:35     | LINE CLEAR AVAIED   |
| 5406  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                  | 66KV NALLUR,LINGADAHALLI                                         | 15:43 (30.08.2024) | NOT YET<br>CHARGED    | —        | TRIPPED ON FAULT    |
| 5407  | 29-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | 100MVA TR2 (HV & LV SIDE)                    | ANTHARASANAHALLI_220                                             | 5:29               | 8:54                  | 3:25     | LINE CLEAR AVAIED   |
| 5408  | 29-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV GUTTUR-220KV<br>RANEBENNUR LINE        | OTHER ZONE                                                       | 1:08               | 6:21                  | 5:13     | TRIPPED ON FAULT    |
| 5409  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANTHARASANAHALLI-<br>66KV BELLAVI LINE | 66KV BELLAVI,<br>MALLASANDRA,HEGGERE,<br>DODDASARANGI            | 8:17               | 8:51                  | 0:34     | TRIPPED ON FAULT    |
| 5410  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREABILACHI-66KV<br>SHYGALE LINE       | WATER SUPPLY                                                     | 10:20              | 10:25                 | 0:05     | TRIPPED ON FAULT    |
| 5411  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KEREABILACHI-66KV<br>SANTHEBENNUR LINE  | 66KV KEREABILACHI,SHYGALE                                        | 10:20              | 10:25                 | 0:05     | TRIPPED ON FAULT    |
| 5412  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV MADHUGIRI-66KV<br>PULAMGHATTA LINE     | 66KV PULAMGHATTA                                                 | 23:57 (29.09.2024) | 00:05<br>(30.09.2024) | 0:08     | TRIPPED ON FAULT    |
| 5413  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV UCHANGIDURGA-66KV<br>BILICHODU LINE     | 66KV BILICHODU                                                   | 0:50               | 1:05                  | 0:15     | MAIN SUPPLY FAILURE |
| 5414  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV THALLAK-66KV<br>GOWRASAMUDRA LINE      | 66 KV<br>GOWRASAMUDRA,KONASAGARA                                 | 3:47               | 3:58                  | 0:11     | TRIPPED ON FAULT    |
| 5415  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV GUTTUR-66KV<br>HALASABALU LINE         | 66KV GUTTUR 66KV HARIHAR<br>HOSPETE POLY FIBER                   | 15:41              | 15:53                 | 0:12     | TRIPPED ON FAULT    |
| 5416  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV<br>BANUVALLI LINE         | 66KV NANDIGUDI,BANUVALLI,EHT<br>CARGIL                           | 18:24              | 18:33                 | 0:09     | TRIPPED ON FAULT    |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                     | Station_Name                                                     | Open_At | Closed_At | Duration | REMARKS           |
|-------|-------------|---------|---------|-------------|------------------------------------------|------------------------------------------------------------------|---------|-----------|----------|-------------------|
| 5417  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MELLEKATTE LINE  | 66KV MELLEKATTE,KADAJJI                                          | 10:38   | 10:48     | 0:10     | TRIPPED ON FAULT  |
| 5418  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV<br>MELLEKATTE LINE  | 66KV MELLEKATTE,KADAJJI                                          | 11:20   | 11:55     | 0:35     | TRIPPED ON FAULT  |
| 5419  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-220KV<br>DAVANGERE LINE 1 | KUKKAWADA_66, TYAVANAGI_66,<br>BASAVAPATNA_66,<br>SANTEBENNUR_66 | 7:25    | 7:30      | 0:05     | TRIPPED ON FAULT  |
| 5420  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-66KV<br>BASAVAPATNA LINE  | 66KV THAVANAGI                                                   | 7:25    | 7:40      | 0:15     | TRIPPED ON FAULT  |
| 5421  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV TURUVANUR-220KV<br>CHITRADURGA LINE | 66KV TURUVANUR,BIDARKERE                                         | 18:28   | 18:38     | 0:10     | TRIPPED ON FAULT  |
| 5422  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV PAVAGADA-66KV<br>MADHUGIRI LINE    | 66KV KILARANAHALLI                                               | 7:55    | 8:45      | 0:50     | TRIPPED ON FAULT  |
| 5423  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV PAVAGADA-66KV<br>PAVAGADA LINE 1   | 66KV PAVAGADA                                                    | 7:25    | 8:15      | 0:50     | TRIPPED ON FAULT  |
| 5424  | 29-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                             | ANCHEPALYA_220                                                   | 9:41    | 16:29     | 6:48     | LINE CLEAR AVAIED |
| 5425  | 29-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-2(100MVA)                             | ANCHEPALYA_220                                                   | 9:41    | 16:30     | 6:49     | LINE CLEAR AVAIED |
| 5426  | 29-Sep-2024 | TUMKUR  | 220     | LINE        | ANCHEPALYA 220KV-<br>NELMANGALA 1        | ANCHEPALYA_220                                                   | 15:31   | 18:09     | 2:38     | LINE CLEAR AVAIED |
| 5427  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV- KUNIGAL                | KUNIGAL_66                                                       | 9:41    | 16:33     | 6:52     | LINE CLEAR AVAIED |
| 5428  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>ANCHEPALYA1         | ANCHEPALYA_66,<br>BHAKTARAHALLI_66,<br>THIMMASANDRA_66           | 9:41    | 16:37     | 6:56     | LINE CLEAR AVAIED |
| 5429  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>ANCHEPALYA-2        | ANCHEPALYA 66KV                                                  | 9:41    | 16:35     | 6:54     | LINE CLEAR AVAIED |
| 5430  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV- AMRUTHUR               | AMRUTHUR_66,<br>SANTEMAVATTUR_66,<br>YADAVANI_66                 | 9:41    | 16:38     | 6:57     | LINE CLEAR AVAIED |
| 5431  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220- HEBBUR                   | HEBBUR_66, HONNENAHALLI_66,<br>THIMMASANDRA_66                   | 9:41    | 16:31     | 6:50     | LINE CLEAR AVAIED |
| 5432  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV- VIJAYA<br>STEEL        | VIJAYA STEEL                                                     | 9:41    | 16:43     | 7:02     | LINE CLEAR AVAIED |
| 5433  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>KEMPANAHALLI        | KEMPANAHALLI_66, AGALKOTE_66                                     | 9:41    | 17:01     | 7:20     | LINE CLEAR AVAIED |
| 5434  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV- BG NAGAR               | JIDDIGERE_66, YEDIYUR_66,<br>THIPPUR_66, B G NAGARA_66           | 9:41    | 17:57     | 8:16     | LINE CLEAR AVAIED |
| 5435  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | ANCHEPALYA 220KV-<br>HULIYURDURGA        | HULIYURDURGA_66,<br>CHOWDANAKUPPE_66                             | 9:41    | 17:53     | 8:12     | LINE CLEAR AVAIED |
| 5436  | 29-Sep-2024 | TUMKUR  | 220     | TRANSFORMER | TR-1(100MVA)                             | ANTHARASANAHALLI_220                                             | 5:28    | 8:49      | 3:21     | LINE CLEAR AVAIED |
| 5437  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | YEDIYUR- ANCHEPALYA220KV                 | YADIYUR_66                                                       | 9:40    | 10:00     | 0:20     | LINE CLEAR AVAIED |
| 5438  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | YEDIYUR- ANCHEPALYA220KV                 | YADIYUR_66                                                       | 17:45   | 17:50     | 0:05     | LINE CLEAR AVAIED |
| 5439  | 29-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(20MVA)                               | KUNIGAL_66                                                       | 9:43    | 16:48     | 7:05     | LINE CLEAR AVAIED |
| 5440  | 29-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2(20MVA)                               | KUNIGAL_66                                                       | 9:43    | 16:48     | 7:05     | LINE CLEAR AVAIED |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                                       | Station_Name                                            | Open_At            | Closed_At       | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|--------------------------------------------|---------------------------------------------------------|--------------------|-----------------|----------|---------------------|
| 5441  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | TURUVANUR66-JAGALUR                        | TURUVANUR_66                                            | 18:28              | 18:36           | 0:08     | MAIN SUPPLY FAILURE |
| 5442  | 29-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR1(12.5MVA)                               | NAYAKANAHATTI_66                                        | 9:41               | 12:29           | 2:48     | LINE CLEAR AVAIED   |
| 5443  | 29-Sep-2024 | TUMKUR  | 66      | LINE        | NIDASALE 66 - DUNDANAHALLI 66              | DUNDANAHALLI_66                                         | 1:30               | 1:55            | 0:25     | MAIN SUPPLY FAILURE |
| 5444  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV BENKIKERE-66KV NALLUR                | 66KV NALLUR,LINGADAHALLI                                | 15:43 (30.08.2024) | NOT YET CHARGED | —        | TRIPPED ON FAULT    |
| 5445  | 30-Sep-2024 | TUMKUR  | 400     | LINE        | JAGALUR 400KV-KODLIGI1                     | JAGALUR 400KV                                           | 11:11              | 15:37           | 04:26    | LINE CLEAR AVAIED   |
| 5446  | 30-Sep-2024 | TUMKUR  | 400     | LINE        | JAGALUR 400KV-KODLIGI2                     | JAGALUR 400KV                                           | 11:11              | 17:20           | 06:09    | LINE CLEAR AVAIED   |
| 5447  | 30-Sep-2024 | TUMKUR  | 400     | LINE        | GUTTUR 400KV- KAIGA 2KV                    | GUTUR_400                                               | 02:45              | 06:47           | 04:02    | LINE CLEAR AVAIED   |
| 5448  | 30-Sep-2024 | TUMKUR  | 220     | LINE        | JAGALUR 400KV-CHITRADURGA-2 220KV          | JAGALUR 400KV                                           | 14:43              | 17:05           | 02:22    | LINE CLEAR AVAIED   |
| 5449  | 30-Sep-2024 | TUMKUR  | 220     | LINE        | 400KV GUTTUR-220KV DAVANGERE LINE 1        | 400KV GUTTUR-                                           | 04:32              | 11:54           | 07:22    | TRIPPED ON FAULT    |
| 5450  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | ANTHRASANAHALLI 220KV- CHELUR              | CHELURU_66, HOSAKERE_66, HAGALVADI_66, NANDIHALLI CROSS | 19:04              | 19:42           | 00:38    | LOAD CURTAILMENT    |
| 5451  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV ANCHEPALYA LINE 1    | 66KV ANCHEPLAYA,BHAKTHARAHALLI                          | 08:10              | 08:21           | 00:11    | TRIPPED ON FAULT    |
| 5452  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV ANCHEPALYA-66KV ANCHEPALYA LINE 1    | 66KV ANCHEPLAYA,BHAKTHARAHALLI                          | 15:17              | 15:23           | 00:06    | TRIPPED ON FAULT    |
| 5453  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HIRIYUR-66KV BEVINAHALLI LINE        | 66KV DASUDI,K R HALLI,J G HALLI,BEVINAHALLI             | 00:28              | 01:10           | 00:42    | TRIPPED ON FAULT    |
| 5454  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV GUTTUR-66KV DITTUR LINE              | KNNL DITTUR,KNNL HALASABALU                             | 04:26              | 06:01           | 01:35    | TRIPPED ON FAULT    |
| 5455  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV DAVANGERE-66KV ANAGODU LINE          | 66KV ANAGODU,ATTIGERE                                   | 16:23              | 16:34           | 00:11    | TRIPPED ON FAULT    |
| 5456  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV KUKKAWADA-66KV BASAVAPATNA LINE       | 66KV THYAVANAGI                                         | 11:30              | 11:40           | 00:10    | TRIPPED ON FAULT    |
| 5457  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV MATHOD-66KV GARAGA PANCHANAHALLI LINE | 66KV GARAGA PANCHANAHALLI                               | 00:10              | 00:20           | 00:10    | TRIPPED ON FAULT    |
| 5458  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV TURUVANUR-220KV CHITRADURGA LINE      | 66KV TURUVANUR,BIDARKERE                                | 03:32              | 03:47           | 00:15    | TRIPPED ON FAULT    |
| 5459  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 66KV TURUVANUR-220KV CHITRADURGA LINE      | 66KV TURUVANUR,BIDARKERE                                | 05:59              | 06:06           | 00:07    | TRIPPED ON FAULT    |
| 5460  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | TURUVANUR66-JAGALUR_66                     | TURUVANUR_66                                            | 05:59              | 06:09           | 00:10    | TRIPPED ON FAULT    |
| 5461  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NALLUR LINE             | 66KV NALLUR, BASAVAPATNA,TYAVANGI                       | 13:48              | 13:58           | 00:10    | TRIPPED ON FAULT    |
| 5462  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | 220KV HONNALI-66KV NALLUR LINE             | 66KV NALLUR, BASAVAPATNA,TYAVANGI                       | 14:10              | 14:28           | 00:18    | TRIPPED ON FAULT    |
| 5463  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU66-NEELAGUBDA_220                  | PALLAGATTE_66, BILCHODE_66                              | 09:40              | 14:05           | 04:25    | LINE CLEAR AVAIED   |
| 5464  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | BILICHODU_66- PALLAGATTE 66KV LINE-2       | PALLAGATTE_66KV                                         | 09:40              | 14:05           | 04:25    | LINE CLEAR AVAIED   |

| SL NO | Dinanka     | Tr_ZONE | Voltage | LINE/TRNS   | Line                         | Station_Name               | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-------------|---------|---------|-------------|------------------------------|----------------------------|-------------------|-----------|----------|---------------------|
| 5465  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU66-NEELAGUBDA_220    | PALLAGATTE_66, BILCHODE_66 | 16:45             | 17:10     | 00:25    | MAIN SUPPLY FAILURE |
| 5466  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | PALLAGATTE66KV-BILICHODU_66  | PALLAGATTE_66              | 17:55             | 18:00     | 00:05    | LINE CLEAR AVAILED  |
| 5467  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU-SOKKE               | BILCHODU_66, PALLAGATTE_66 | 01:50             | 02:05     | 00:15    | LINE CLEAR AVAILED  |
| 5468  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | BILCHODU-SOKKE               | BILCHODU_66, PALLAGATTE_66 | 09:25             | 15:00     | 05:35    | LINE CLEAR AVAILED  |
| 5469  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | SOKKE-JAGLUR                 | SOKKE_66                   | 17:55             | 18:00     | 00:05    | LINE CLEAR AVAILED  |
| 5470  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | SOKKE-JAGLUR                 | SOKKE_66                   | 09:25             | 15:00     | 05:35    | LINE CLEAR AVAILED  |
| 5471  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | SOKKE-UJJINI                 | SOKKE_66                   | 01:50             | 02:05     | 00:15    | TRIPPED ON FAULT    |
| 5472  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | HEGGERE- MALLASANDRA         | HEGGERE_66                 | 04:15             | 04:50     | 00:35    | TRIPPED ON FAULT    |
| 5473  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | LOKIKERE-KUKKAWADA_66        | LOKIKERE_66                | 18:40             | 19:10     | 00:30    | MAIN SUPPLY FAILURE |
| 5474  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | NAGALAMADIKE-PAVAGADA_LINE-2 | NAGALMADIKE_66             | 11:55             | 12:55     | 01:00    | LINE CLEAR AVAILED  |
| 5475  | 30-Sep-2024 | TUMKUR  | 66      | LINE        | NAGALAMADIKE-PAVAGADA_LINE-1 | NAGALMADIKE_66             | 12:55             | 13:05     | 00:10    | TRIPPED ON FAULT    |
| 5476  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1&TR-2 (12.5MVA)          | BILCHODU_66,               | 09:40             | 14:05     | 04:25    | LINE CLEAR AVAILED  |
| 5477  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 8MVA                    | CHITRAHALLI_66             | 04:40             | 04:45     | 00:05    | TRIPPED ON FAULT    |
| 5478  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 (12.5MVA)                | HALURAMESWARA_66           | 16:25             | 16:45     | 00:20    | TRIPPED ON FAULT    |
| 5479  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-1 8MVA                    | MAVINAKATTE_66             | 18:25             | 19:00     | 00:35    | TRIPPED ON FAULT    |
| 5480  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 (12.5MVA)                | SANIKERE_66                | 01:34             | 01:44     | 00:10    | TRIPPED ON FAULT    |
| 5481  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR2 (12.5MVA)                | SANIKERE_66                | 14:14             | 14:26     | 00:12    | TRIPPED ON FAULT    |
| 5482  | 30-Sep-2024 | TUMKUR  | 66      | TRANSFORMER | TR-2(12.5MVA)                | HARIYABBE_66               | 05:08             | 05:13     | 00:05    | TRIPPED ON FAULT    |
| 5483  | 30-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1 ,10MVA                  | HANDANKERE_110             | 12:05             | 13:00     | 00:55    | LINE CLEAR AVAILED  |
| 5484  | 30-Sep-2024 | TUMKUR  | 110     | TRANSFORMER | TR-1 ,10MVA                  | HANDANKERE_110             | 14:50             | 16:25     | 01:35    | LINE CLEAR AVAILED  |
| 5485  | 01-Sep-24   | HASSAN  | 110     | TRANSFORMER | HV1                          | ALKOLA_110                 | 13:45             | 14:07     | 00:22    | LINE CLEAR AVAILED  |
| 5486  | 01-Sep-24   | HASSAN  | 110     | LINE        | MRSSHM-NANDHIKUR1            | KEMAR_220                  | 20:15             | 21:28     | 01:13    | LINE CLEAR AVAILED  |
| 5487  | 01-Sep-24   | HASSAN  | 110     | TRANSFORMER | HV1                          | SAGARA_110                 | 10:07             | 14:00     | 03:53    | LINE CLEAR AVAILED  |
| 5488  | 01-Sep-24   | HASSAN  | 110     | TRANSFORMER | HV2                          | SAGARA_110                 | 10:07             | 14:00     | 03:53    | LINE CLEAR AVAILED  |
| 5489  | 02-Sep-24   | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE             | MRSMSG_220                 | 9:09 (2.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 5490  | 02-Sep-24   | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI              | MRSMSG_220                 | 9:09 (2.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 5491  | 02-Sep-24   | HASSAN  | 220     | LINE        | MRSSHM-VARAH1                | MRSMSG_220                 | 9:51(02.09.2024)  |           |          | TRIPPED ON FAULT    |
| 5492  | 02-Sep-24   | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 1             | gen_sharavathy             | 22:21(2.09.2024)  |           |          | TRIPPED ON FAULT    |
| 5493  | 02-Sep-24   | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 2             | gen_sharavathy             | 22:21(2.09.2024)  |           |          | TRIPPED ON FAULT    |
| 5494  | 02-Sep-24   | HASSAN  | 220     | LINE        | TALAGU-STRP2                 | TALAGUPPA_400              | 22:21(02.09.2024) |           |          | TRIPPED ON FAULT    |
| 5495  | 02-Sep-24   | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1              | gen_varahi                 | 9:51(02.09.2024)  |           |          | TRIPPED ON FAULT    |
| 5496  | 02-Sep-24   | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA2             | gen_gersopa                | 22:21(02.09.2024) |           |          | TRIPPED ON FAULT    |
| 5497  | 02-Sep-24   | HASSAN  | 220     | LINE        | GOPALAP-HSN400               | GOPALAP                    | 12:40             | 18:02     | 05:22    | LINE CLEAR AVAILED  |
| 5498  | 02-Sep-24   | HASSAN  | 220     | LINE        | HASSAN4-C R PATNA            | HASSAN4                    | 12:40             | 18:02     | 05:22    | LINE CLEAR AVAILED  |
| 5499  | 02-Sep-24   | HASSAN  | 220     | LINE        | HASSAN4-GOPALPURA            | HASSAN4                    | 12:40             | 18:02     | 05:22    | LINE CLEAR AVAILED  |
| 5500  | 02-Sep-24   | HASSAN  | 220     | LINE        | MRSSHM-VARAH12               | MRSMSG_220                 | 03:52             | 10:39     | 06:47    | TRIPPED ON FAULT    |
| 5501  | 02-Sep-24   | HASSAN  | 220     | TRANSFORMER | HV1                          | MSEZ_220                   | 10:30             | 13:25     | 02:55    | LINE CLEAR AVAILED  |
| 5502  | 02-Sep-24   | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA2              | gen_varahi                 | 03:52             | 10:39     | 06:47    | TRIPPED ON FAULT    |
| 5503  | 02-Sep-24   | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA2              | gen_varahi                 | 12:17             | 12:42     | 00:25    | TRIPPED ON FAULT    |
| 5504  | 02-Sep-24   | HASSAN  | 220     | LINE        | VARAHI-SHMG3                 | gen_varahi                 | 09:49             | 10:39     | 00:50    | TRIPPED ON FAULT    |
| 5505  | 02-Sep-24   | HASSAN  | 110     | LINE        | GAJNUR-IPP IC LINE           | GAJNUR_110                 | 09:49             | 09:55     | 00:06    | TRIPPED ON FAULT    |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line               | Station_Name         | Open_At           | Closed_At         | Duration  | REMARKS            |
|-------|-----------|---------|---------|-------------|--------------------|----------------------|-------------------|-------------------|-----------|--------------------|
| 5506  | 02-Sep-24 | HASSAN  | 110     | LINE        | GAJNUR-IPP IC LINE | GAJNUR_110           | 12:15             | 12:20             | 00:05     | TRIPPED ON FAULT   |
| 5507  | 02-Sep-24 | HASSAN  | 110     | LINE        | GURUVA-KEMAR2      | GURUVAYANKERE_110    | 06:11             | 06:29             | 00:18     | TRIPPED ON FAULT   |
| 5508  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Guruvykere2  | KEMAR_220            | 11:40             | 11:58             | 00:18     | LINE CLEAR AVAILED |
| 5509  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Manipal1     | KEMAR_220            | 10:23             | 11:39             | 01:16     | LINE CLEAR AVAILED |
| 5510  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1   | KEMAR_220            | 10:24             | 12:09             | 01:45     | LINE CLEAR AVAILED |
| 5511  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR2   | KEMAR_220            | 12:17             | 13:40             | 01:23     | LINE CLEAR AVAILED |
| 5512  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-KEMAR1       | MANIPAL_110          | 10:24             | 11:39             | 01:15     | LINE CLEAR AVAILED |
| 5513  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-KEMAR2       | NANDIKUR_110         | 12:17             | 13:40             | 01:23     | LINE CLEAR AVAILED |
| 5514  | 02-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NDKR-SUZLON  | NANDIKUR_110         | 06:40             | 06:57             | 00:17     | TRIPPED ON FAULT   |
| 5515  | 02-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                | BALEHONNUR_66        | 03:05             | 04:05             | 01:00     | TRIPPED ON FAULT   |
| 5516  | 02-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | HANGARAHALLI_66      | 15:40             | 16:02             | 00:22     | LINE CLEAR AVAILED |
| 5517  | 02-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2        | HNPURA_220           | 00:31             | 00:41             | 00:10     | TRIPPED ON FAULT   |
| 5518  | 02-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2        | HNPURA_220           | 02:00             | 02:08             | 00:08     | TRIPPED ON FAULT   |
| 5519  | 02-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS1        | HNPURA_220           | 15:38             | 15:58             | 00:20     | LINE CLEAR AVAILED |
| 5520  | 02-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2        | HNPURA_220           | 00:31             | 00:41             | 00:10     | TRIPPED ON FAULT   |
| 5521  | 02-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2        | HNPURA_220           | 02:00             | 02:08             | 00:08     | TRIPPED ON FAULT   |
| 5522  | 02-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | KALASAPURA_66        | 11:30             | 12:15             | 00:45     | LINE CLEAR AVAILED |
| 5523  | 02-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONALI     | TAVARECHATNAHALLI_66 | 08:55             | 09:20             | 00:25     | TRIPPED ON FAULT   |
| 5524  | 03-Sep-24 | HASSAN  | 220     | TRANSFORMER | MRSSHM-VARAH1      | MRSMG_220            | 9:51(02.09.2024)  | 11:35(3.09.2024)  | 25:43 hrs | LINE CLEAR AVAILED |
| 5525  | 03-Sep-24 | HASSAN  | 220     | LINE        | TALAGU-STRP2       | TALAGUPPA_400        | 22:21(02.09.2024) | 12:45(3.09.2024)  | 14:23 hrs | LINE CLEAR AVAILED |
| 5526  | 03-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1    | gen_varahi           | 9:51(02.09.2024)  | 11:36(3.09.2024)  | 15:44 hrs | LINE CLEAR AVAILED |
| 5527  | 03-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA2   | gen_gersoppa         | 22:21(02.09.2024) | 12:44(03.09.2024) | 14:23 hrs | LINE CLEAR AVAILED |
| 5528  | 03-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 1   | gen_sharavathy       | 22:21(2.09.2024)  |                   |           | TRIPPED ON FAULT   |
| 5529  | 03-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 2   | gen_sharavathy       | 22:21(2.09.2024)  |                   |           | TRIPPED ON FAULT   |
| 5530  | 03-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE   | MRSMG_220            | 9:09 (2.09.2024)  |                   |           | LINE CLEAR AVAILED |
| 5531  | 03-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI    | MRSMG_220            | 9:09 (2.09.2024)  |                   |           | LINE CLEAR AVAILED |
| 5532  | 03-Sep-24 | HASSAN  | 400     | LINE        | TALAGU-NELAMANG2   | TALAGUPPA_400        | 05:56             | 10:14             | 04:18     | TRIPPED ON FAULT   |
| 5533  | 03-Sep-24 | HASSAN  | 220     | LINE        | HGUNJE-KEMAR       | HEGGUNJE_220         | 09:41             | 14:29             | 04:48     | LINE CLEAR AVAILED |
| 5534  | 03-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-Varahi3      | KEMAR_220            | 09:42             | 14:29             | 04:47     | LINE CLEAR AVAILED |
| 5535  | 03-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-VARAH1      | MRSMG_220            | 11:46             | 16:26             | 04:40     | TRIPPED ON FAULT   |
| 5536  | 03-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-VARAH1      | MRSMG_220            | 20:01             | 22:36             | 02:35     | LINE CLEAR AVAILED |
| 5537  | 03-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1    | gen_varahi           | 01:46             | 16:26             | 14:40     | TRIPPED ON FAULT   |
| 5538  | 03-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA2    | gen_varahi           | 11:20             | 12:08             | 00:48     | TRIPPED ON FAULT   |
| 5539  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | ANANDAPURA_110       | 10:28             | 18:55             | 08:27     | LINE CLEAR AVAILED |
| 5540  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | ANANDAPURA_110       | 10:28             | 19:02             | 08:34     | LINE CLEAR AVAILED |
| 5541  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | BANTWALA_110         | 10:21             | 20:33             | 10:12     | LINE CLEAR AVAILED |
| 5542  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                | BANTWALA_110         | 10:21             | 20:33             | 10:12     | LINE CLEAR AVAILED |
| 5543  | 03-Sep-24 | HASSAN  | 110     | LINE        | BANTWA-KAVOOR      | BANTWALA_110         | 10:21             | 20:33             | 10:12     | LINE CLEAR AVAILED |
| 5544  | 03-Sep-24 | HASSAN  | 110     | LINE        | BANTWA-SALATTUR    | BANTWALA_110         | 10:21             | 20:33             | 10:12     | LINE CLEAR AVAILED |
| 5545  | 03-Sep-24 | HASSAN  | 110     | LINE        | HGUNJE-HALADY      | HEGGUNJE_220         | 10:03             | 15:51             | 05:48     | LINE CLEAR AVAILED |
| 5546  | 03-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HALDY       | HOSANGADI_110        | 10:11             | 16:01             | 05:50     | LINE CLEAR AVAILED |
| 5547  | 03-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Manipal1     | KEMAR_220            | 10:42             | 13:00             | 02:18     | LINE CLEAR AVAILED |
| 5548  | 03-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1   | KEMAR_220            | 10:40             | 13:02             | 02:22     | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                   | Station_Name         | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|------------------------|----------------------|------------------|-----------|----------|---------------------|
| 5549  | 03-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-MANJESWARG      | KONAJE_110           | 11:04            | 11:10     | 00:06    | LINE CLEAR AVAILED  |
| 5550  | 03-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-MANJESWARG      | KONAJE_110           | 13:54            | 13:59     | 00:05    | LINE CLEAR AVAILED  |
| 5551  | 03-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-SALATHUR        | KONAJE_110           | 11:05            | 13:56     | 02:51    | LINE CLEAR AVAILED  |
| 5552  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                    | MANIPAL_110          | 19:17            | 19:23     | 00:06    | TRIPPED ON FAULT    |
| 5553  | 03-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-KEMAR1         | MANIPAL_110          | 10:42            | 13:00     | 02:18    | LINE CLEAR AVAILED  |
| 5554  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | MOODABIDRE_110       | 10:02            | 16:26     | 06:24    | LINE CLEAR AVAILED  |
| 5555  | 03-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | MOODABIDRE_110       | 10:02            | 16:26     | 06:24    | LINE CLEAR AVAILED  |
| 5556  | 03-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-BNTWAL         | SALATHUR_110         | 11:05            | 13:41     | 02:36    | LINE CLEAR AVAILED  |
| 5557  | 03-Sep-24 | HASSAN  | 66      | LINE        | BANDISH-RAMNATHPURA    | BANDISHETTIHALLI_66  | 07:10            | 07:20     | 00:10    | TRIPPED ON FAULT    |
| 5558  | 03-Sep-24 | HASSAN  | 66      | LINE        | BYARAPU-BAGUR          | BYARAPURA_66         | 11:30            | 12:20     | 00:50    | TRIPPED ON FAULT    |
| 5559  | 03-Sep-24 | HASSAN  | 66      | LINE        | CRPATNA-KIKKERI        | CRPATNA_66           | 06:18            | 18:42     | 12:24    | LINE CLEAR AVAILED  |
| 5560  | 03-Sep-24 | HASSAN  | 66      | LINE        | CRPATNA-MATTANAVILE    | CRPATNA_66           | 08:51            | 09:01     | 00:10    | TRIPPED ON FAULT    |
| 5561  | 03-Sep-24 | HASSAN  | 66      | LINE        | LIGDAHL-BADRA          | LINGADAHALLI_66      | 12:39            | 12:56     | 00:17    | LINE CLEAR AVAILED  |
| 5562  | 03-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2            | MRSMSG_220           | 14:14            | 16:41     | 02:27    | TRIPPED ON FAULT    |
| 5563  | 03-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | SIGEBAGE_66          | 15:00            | 16:42     | 01:42    | LINE CLEAR AVAILED  |
| 5564  | 03-Sep-24 | HASSAN  | 66      | LINE        | SMG-DVG2               | SIGEBAGE_66          | 14:15            | 16:40     | 02:25    | MAIN SUPPLY FAILURE |
| 5565  | 03-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONALI         | TAVARECHATNAHALLI_66 | 20:50            | 21:08     | 00:18    | TRIPPED ON FAULT    |
| 5566  | 03-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | YESLUR_66            | 19:10            | 19:30     | 00:20    | LINE CLEAR AVAILED  |
| 5567  | 04-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE       | MRSMSG_220           | 9:09 (2.09.2024) |           |          | LINE CLEAR AVAILED  |
| 5568  | 04-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI        | MRSMSG_220           | 9:09 (2.09.2024) |           |          | LINE CLEAR AVAILED  |
| 5569  | 04-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-GAJNUR          | MRSMSG_220           | 8:45(4.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 5570  | 04-Sep-24 | HASSAN  | 110     | LINE        | GAJNUR-SHIMOGA IC LINE | GAJNUR_110           | 8:45(4.09.2024)  |           |          | LINE CLEAR AVAILED  |
| 5571  | 04-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                    | KEMAR_220            | 12:38            | 18:14     | 05:36    | LINE CLEAR AVAILED  |
| 5572  | 04-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-KARKALA          | KEMAR_220            | 10:03            | 11:35     | 01:32    | LINE CLEAR AVAILED  |
| 5573  | 04-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-MOBBIDRE         | KEMAR_220            | 10:30            | 11:03     | 00:33    | LINE CLEAR AVAILED  |
| 5574  | 04-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1       | KEMAR_220            | 09:52            | 11:35     | 01:43    | LINE CLEAR AVAILED  |
| 5575  | 04-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 1       | gen_sharavathy       | 10:10            | 17:29     | 07:19    | LINE CLEAR AVAILED  |
| 5576  | 04-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SIRISI 2       | gen_sharavathy       | 10:10            | 17:29     | 08:19    | LINE CLEAR AVAILED  |
| 5577  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | BELAGUMBA_110        | 08:30            | 09:36     | 09:19    | LINE CLEAR AVAILED  |
| 5578  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | ESSUR_110            | 10:35            | 10:58     | 10:19    | TRIPPED ON FAULT    |
| 5579  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | ESSUR_110            | 15:39            | 16:30     | 11:19    | LINE CLEAR AVAILED  |
| 5580  | 04-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-KEMAR           | HIRIYADKA_110        | 09:49            | 11:40     | 12:19    | LINE CLEAR AVAILED  |
| 5581  | 04-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG1           | HOSANGADI_110        | 11:45            | 14:04     | 13:19    | LINE CLEAR AVAILED  |
| 5582  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                    | KADUR_220            | 12:38            | 18:14     | 14:19    | LINE CLEAR AVAILED  |
| 5583  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NERELEKERE       | KADUR_220            | 12:02            | 13:00     | 15:19    | TRIPPED ON FAULT    |
| 5584  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NERELEKERE       | KADUR_220            | 15:20            | 15:34     | 16:19    | TRIPPED ON FAULT    |
| 5585  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL            | KADUR_220            | 12:02            | 13:00     | 17:19    | TRIPPED ON FAULT    |
| 5586  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL            | KADUR_220            | 15:20            | 15:33     | 18:19    | TRIPPED ON FAULT    |
| 5587  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-TNGL             | KADUR_220            | 12:02            | 13:00     | 19:19    | TRIPPED ON FAULT    |
| 5588  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-TNGL             | KADUR_220            | 15:20            | 15:34     | 20:19    | TRIPPED ON FAULT    |
| 5589  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-YGTI             | KADUR_220            | 12:02            | 13:00     | 21:19    | TRIPPED ON FAULT    |
| 5590  | 04-Sep-24 | HASSAN  | 110     | LINE        | KADUR-YGTI             | KADUR_220            | 15:20            | 15:30     | 22:19    | TRIPPED ON FAULT    |
| 5591  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | MUTHINKOPPA_110      | 10:15            | 17:30     | 23:19    | LINE CLEAR AVAILED  |
| 5592  | 04-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | KULASHEKARA_110      | 12:08            | 12:55     | 00:19    | TRIPPED ON FAULT    |
| 5593  | 04-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-KEMAR           | MOODABIDRE_66        | 10:30            | 11:37     | 01:19    | LINE CLEAR AVAILED  |
| 5594  | 04-Sep-24 | HASSAN  | 66      | LINE        | ARAKAL-HASSAN          | ARAKALGUD_66         | 10:00            | 17:40     | 02:19    | LINE CLEAR AVAILED  |
| 5595  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | ARAKALGUD_66         | 10:00            | 17:40     | 03:19    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                   | Station_Name    | Open_At          | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|------------------------|-----------------|------------------|-----------|----------|---------------------|
| 5596  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | ARAKALGUD_66    | 10:00            | 17:40     | 04:19    | LINE CLEAR AVAIED   |
| 5597  | 04-Sep-24 | HASSAN  | 66      | LINE        | ARAKAL-MALLIPATNA      | ARAKALGUD_66    | 10:00            | 17:40     | 05:19    | LINE CLEAR AVAIED   |
| 5598  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | BALLUPETE_66    | 12:12            | 12:56     | 06:19    | LINE CLEAR AVAIED   |
| 5599  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | BYRAPURA_66     | 13:17            | 14:13     | 07:19    | LINE CLEAR AVAIED   |
| 5600  | 04-Sep-24 | HASSAN  | 66      | LINE        | GORUR-HASSAN           | GORUR_66        | 17:30            | 17:40     | 08:19    | LINE CLEAR AVAIED   |
| 5601  | 04-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-ARAKALGUD      | HASSAN_220      | 11:33            | 13:58     | 09:19    | LINE CLEAR AVAIED   |
| 5602  | 04-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2            | HNPURA_220      | 10:37            | 13:54     | 10:19    | LINE CLEAR AVAIED   |
| 5603  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | LAKKAVALLI_66   | 12:26            | 12:56     | 11:19    | LINE CLEAR AVAIED   |
| 5604  | 04-Sep-24 | HASSAN  | 66      | LINE        | MALALI-CRPATNA         | MALALI_66       | 10:41            | 13:56     | 12:19    | LINE CLEAR AVAIED   |
| 5605  | 04-Sep-24 | HASSAN  | 66      | LINE        | MALALI-HASSAN          | MALALI_66       | 10:41            | 13:56     | 13:19    | LINE CLEAR AVAIED   |
| 5606  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | MALALI_66       | 10:06            | 15:00     | 14:19    | LINE CLEAR AVAIED   |
| 5607  | 04-Sep-24 | HASSAN  | 66      | LINE        | SALAGAM-HIREMANGLUR    | SALAGAME_66     | 10:14            | 15:15     | 15:19    | LINE CLEAR AVAIED   |
| 5608  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | SALAGAME_66     | 10:14            | 15:25     | 16:19    | LINE CLEAR AVAIED   |
| 5609  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | SALAGAME_66     | 10:14            | 15:25     | 17:19    | LINE CLEAR AVAIED   |
| 5610  | 04-Sep-24 | HASSAN  | 66      | LINE        | SALAGAM-UDURKOPPLU     | SALAGAME_66     | 10:14            | 15:13     | 18:19    | LINE CLEAR AVAIED   |
| 5611  | 04-Sep-24 | HASSAN  | 66      | LINE        | SHANTHI-UDYAPURA       | SHANTHIGRAMA_66 | 10:35            | 14:52     | 19:19    | MAIN SUPPLY FAILURE |
| 5612  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | UDAYAPURA_66    | 15:11            | 15:20     | 20:19    | TRIPPED ON FAULT    |
| 5613  | 04-Sep-24 | HASSAN  | 66      | LINE        | UDDURKO-CHIKMANGLUR    | UDDURKOPPLU_66  | 10:17            | 15:10     | 21:19    | LINE CLEAR AVAIED   |
| 5614  | 04-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | YESLUR_66       | 11:05            | 15:00     | 22:19    | LINE CLEAR AVAIED   |
| 5615  | 04-Sep-24 | HASSAN  | 66      | LINE        | YESLUR-SNVRSNT         | YESLUR_66       | 11:05            | 15:00     | 23:19    | LINE CLEAR AVAIED   |
| 5616  | 05-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE       | MRSMSG_220      | 9:09 (2.09.2024) |           |          | LINE CLEAR AVAIED   |
| 5617  | 05-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI        | MRSMSG_220      | 9:09 (2.09.2024) |           |          | LINE CLEAR AVAIED   |
| 5618  | 05-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-GAJNUR          | MRSMSG_220      | 8:45(4.09.2024)  |           |          | LINE CLEAR AVAIED   |
| 5619  | 05-Sep-24 | HASSAN  | 110     | LINE        | GAJNUR-SHIMOGA IC LINE | GAJNUR_110      | 8:45(4.09.2024)  |           |          | LINE CLEAR AVAIED   |
| 5620  | 05-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP1           | MRSMSG_220      | 2:28(05.09.2024) |           |          | TRIPPED ON FAULT    |
| 5621  | 05-Sep-24 | HASSAN  | 220     | LINE        | GERUSOPA-SHIMOGA1      | gen_gersoppa    | 2:28(05.09.2024) |           |          | TRIPPED ON FAULT    |
| 5622  | 05-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-HANBAL          | SAKALESHPURA_66 | 17:20(5.09.2024) |           |          | LINE CLEAR AVAIED   |
| 5623  | 05-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                    | KEMAR_220       | 09:57            | 11:51     | 01:54    | LINE CLEAR AVAIED   |
| 5624  | 05-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                    | KEMAR_220       | 09:57            | 11:51     | 01:54    | LINE CLEAR AVAIED   |
| 5625  | 05-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1       | KEMAR_220       | 09:54            | 11:47     | 01:53    | LINE CLEAR AVAIED   |
| 5626  | 05-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | ARASIKERE_110   | 10:56            | 11:07     | 00:11    | TRIPPED ON FAULT    |
| 5627  | 05-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-MANJESWARG      | KONAJE_110      | 09:52            | 13:51     | 03:59    | LINE CLEAR AVAIED   |
| 5628  | 05-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-SALATHUR        | KONAJE_110      | 10:00            | 10:07     | 00:07    | LINE CLEAR AVAIED   |
| 5629  | 05-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-SALATHUR        | KONAJE_110      | 13:19            | 13:24     | 00:05    | LINE CLEAR AVAIED   |
| 5630  | 05-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-GSS32             | MSEZ_220        | 09:53            | 12:52     | 02:59    | LINE CLEAR AVAIED   |
| 5631  | 05-Sep-24 | HASSAN  | 110     | LINE        | NDKR-SUZLON            | NANDIKUR_110    | 07:06            | 07:20     | 00:14    | TRIPPED ON FAULT    |
| 5632  | 05-Sep-24 | HASSAN  | 110     | LINE        | PUTTUR-PUTUR 2         | PUTTUR_220      | 10:06            | 13:20     | 03:14    | LINE CLEAR AVAIED   |
| 5633  | 05-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-BNTWAL         | SALATHUR_110    | 10:06            | 10:07     | 00:01    | MAIN SUPPLY FAILURE |
| 5634  | 05-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-BNTWAL         | SALATHUR_110    | 13:18            | 13:20     | 00:02    | MAIN SUPPLY FAILURE |
| 5635  | 05-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-NTMDNOR        | SALATHUR_110    | 10:06            | 13:20     | 03:14    | LINE CLEAR AVAIED   |
| 5636  | 05-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | VITTALA_110     | 10:17            | 13:20     | 03:03    | LINE CLEAR AVAIED   |
| 5637  | 05-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | VITTALA_110     | 10:17            | 13:20     | 03:03    | LINE CLEAR AVAIED   |
| 5638  | 05-Sep-24 | HASSAN  | 110     | LINE        | VITTAL-PUTR_SLTUR      | VITTALA_110     | 10:06            | 13:20     | 03:14    | LINE CLEAR AVAIED   |
| 5639  | 05-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | DUDDA_66        | 16:04            | 17:05     | 01:01    | LINE CLEAR AVAIED   |
| 5640  | 05-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | GORUR_66        | 10:30            | 15:56     | 05:26    | LINE CLEAR AVAIED   |
| 5641  | 05-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | UDAYAPURA_66    | 11:16            | 11:21     | 00:05    | TRIPPED ON FAULT    |
| 5642  | 05-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | UDAYAPURA_66    | 13:01            | 13:04     | 00:03    | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                   | Station_Name         | Open_At           | Closed_At            | Duration  | REMARKS             |
|-------|-----------|---------|---------|-------------|------------------------|----------------------|-------------------|----------------------|-----------|---------------------|
| 5643  | 05-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | UDAYAPURA_66         | 14:01             | 14:06                | 00:05     | TRIPPED ON FAULT    |
| 5644  | 06-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-GAJNUR          | MRSMSG_220           | 8:45(4.09.2024)   | 13:43(6.09.2024)     | 52:57 hrs | LINE CLEAR AVAIED   |
| 5645  | 06-Sep-24 | HASSAN  | 110     | LINE        | GAJNUR-SHIMOGA IC LINE | GAJNUR_110           | 8:45(4.09.2024)   | 13:47(6.09.2024)     | 53:01 hrs | LINE CLEAR AVAIED   |
| 5646  | 06-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-HANBAL          | SAKALESH PURA_66     | 17:20(5.09.2024)  | 16:35<br>(6.09.2024) | 23:14 hrs | LINE CLEAR AVAIED   |
| 5647  | 06-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE       | MRSMSG_220           | 9:09 (2.09.2024)  |                      |           | LINE CLEAR AVAIED   |
| 5648  | 06-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI        | MRSMSG_220           | 9:09 (2.09.2024)  |                      |           | LINE CLEAR AVAIED   |
| 5649  | 06-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                    | KEMAR_220            | 10:08             | 12:14                | 02:06     | LINE CLEAR AVAIED   |
| 5650  | 06-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV3                    | KEMAR_220            | 10:08             | 12:14                | 02:06     | LINE CLEAR AVAIED   |
| 5651  | 06-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1       | KEMAR_220            | 10:08             | 12:14                | 02:06     | LINE CLEAR AVAIED   |
| 5652  | 06-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                    | MSEZ_220             | 10:16             | 13:50                | 03:34     | LINE CLEAR AVAIED   |
| 5653  | 06-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                    | MSEZ_220             | 10:16             | 13:50                | 03:34     | LINE CLEAR AVAIED   |
| 5654  | 06-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                    | SHIRALKOPPA_220      | 11:22             | 12:15                | 00:53     | LINE CLEAR AVAIED   |
| 5655  | 06-Sep-24 | HASSAN  | 220     | LINE        | SHRLKP-RANIBENUR       | SHIRALKOPPA_220      | 16:16             | 19:27                | 03:11     | TRIPPED ON FAULT    |
| 5656  | 06-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-BARANG          | SHIRALKOPPA_220      | 10:23             | 15:33                | 05:10     | LINE CLEAR AVAIED   |
| 5657  | 06-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIKARIPURA     | SHIRALKOPPA_220      | 11:56             | 15:37                | 03:41     | LINE CLEAR AVAIED   |
| 5658  | 06-Sep-24 | HASSAN  | 66      | LINE        | GENDEHA-HASSAN         | GENDEHALLI_66        | 12:35             | 13:20                | 00:45     | LINE CLEAR AVAIED   |
| 5659  | 06-Sep-24 | HASSAN  | 66      | LINE        | GENDEHA-HASSAN         | GENDEHALLI_66        | 14:05             | 14:35                | 00:30     | LINE CLEAR AVAIED   |
| 5660  | 06-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | GENDEHALLI_66        | 12:35             | 13:20                | 00:45     | LINE CLEAR AVAIED   |
| 5661  | 06-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | GENDEHALLI_66        | 14:05             | 14:35                | 00:30     | LINE CLEAR AVAIED   |
| 5662  | 06-Sep-24 | HASSAN  | 66      | LINE        | GENDEHA-MUDIGERE       | GENDEHALLI_66        | 12:35             | 13:20                | 00:45     | LINE CLEAR AVAIED   |
| 5663  | 06-Sep-24 | HASSAN  | 66      | LINE        | GENDEHA-MUDIGERE       | GENDEHALLI_66        | 14:05             | 14:35                | 00:30     | LINE CLEAR AVAIED   |
| 5664  | 06-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS3            | HNPURA_220           | 16:17             | 19:00                | 02:43     | LINE CLEAR AVAIED   |
| 5665  | 06-Sep-24 | HASSAN  | 66      | LINE        | MOSALEH-HNPRA          | MOSALEHOSAHALLI_66   | 15:48             | 19:14                | 03:26     | LINE CLEAR AVAIED   |
| 5666  | 06-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONNALLI       | TAVARECHATNAHALLI_66 | 07:05             | 07:26                | 00:21     | TRIPPED ON FAULT    |
| 5667  | 07-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA1       | gen_gersoppa         | 2:28(05.09.2024)  | 15:18<br>(7.09.2024) | 60:49 hrs | LINE CLEAR AVAIED   |
| 5668  | 07-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP1           | MRSMSG_220           | 2:28(05.09.2024)  | 15:18<br>(7.09.2024) | 60:49 hrs | LINE CLEAR AVAIED   |
| 5669  | 07-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE       | MRSMSG_220           | 9:09 (2.09.2024)  |                      |           | LINE CLEAR AVAIED   |
| 5670  | 07-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI        | MRSMSG_220           | 9:09 (2.09.2024)  |                      |           | LINE CLEAR AVAIED   |
| 5671  | 07-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA1       | gen_gersoppa         | 15:57(7.09.2024)  |                      |           | TRIPPED ON FAULT    |
| 5672  | 07-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP1           | MRSMSG_220           | 15:57(7.09.2024)  |                      |           | TRIPPED ON FAULT    |
| 5673  | 07-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHMG3           | gen_varahi           | 19:27(07.09.2024) |                      |           | TRIPPED ON FAULT    |
| 5674  | 07-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HALDY           | HOSANGADI_110        | 13:05(7.09.2024)  |                      |           | TRIPPED ON FAULT    |
| 5675  | 07-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2            | MRSMSG_220           | 16:21             | 16:50                | 00:29     | TRIPPED ON FAULT    |
| 5676  | 07-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-HOLUR           | MRSMSG_220           | 16:21             | 16:50                | 00:29     | TRIPPED ON FAULT    |
| 5677  | 07-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-ARSKR            | ARSIKERE_220         | 10:51             | 11:08                | 00:17     | TRIPPED ON FAULT    |
| 5678  | 07-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-BANAVARA         | ARSIKERE_220         | 10:51             | 11:08                | 00:17     | TRIPPED ON FAULT    |
| 5679  | 07-Sep-24 | HASSAN  | 110     | LINE        | HALADY1-HOSANGADI      | HALADY_110           | 13:13             | 13:31                | 00:18     | LINE CLEAR AVAIED   |
| 5680  | 07-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HULIKAL         | HOSANGADI_110        | 13:05             | 13:36                | 00:31     | MAIN SUPPLY FAILURE |
| 5681  | 07-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | HOSANGADI_110        | 13:05             | 13:38                | 00:33     | MAIN SUPPLY FAILURE |
| 5682  | 07-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | HOSANGADI_110        | 13:05             | 13:45                | 00:40     | MAIN SUPPLY FAILURE |
| 5683  | 07-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG1           | HOSANGADI_110        | 13:05             | 13:44                | 00:39     | MAIN SUPPLY FAILURE |
| 5684  | 07-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG2           | HOSANGADI_110        | 13:05             | 13:45                | 00:40     | MAIN SUPPLY FAILURE |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                 | Station_Name         | Open_At           | Closed_At            | Duration   | REMARKS             |
|-------|-----------|---------|---------|-------------|----------------------|----------------------|-------------------|----------------------|------------|---------------------|
| 5685  | 07-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NERELEKERE     | KADUR_220            | 16:21             | 16:45                | 00:24      | TRIPPED ON FAULT    |
| 5686  | 07-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL          | KADUR_220            | 16:21             | 16:45                | 00:24      | TRIPPED ON FAULT    |
| 5687  | 07-Sep-24 | HASSAN  | 110     | LINE        | KADUR-TNGL           | KADUR_220            | 16:21             | 16:45                | 00:24      | TRIPPED ON FAULT    |
| 5688  | 07-Sep-24 | HASSAN  | 110     | LINE        | KADUR-YGTI           | KADUR_220            | 16:21             | 16:45                | 00:24      | TRIPPED ON FAULT    |
| 5689  | 07-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-SHMGA 1       | gen_bhadra           | 21:20             | 21:35                | 00:15      | TRIPPED ON FAULT    |
| 5690  | 07-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONNALLI     | TAVARECHATNAHALLI_66 | 16:20             | 16:54                | 00:34      | MAIN SUPPLY FAILURE |
| 5691  | 08-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE     | MRSMSG_220           | 9:09 (2.09.2024)  | 15:41<br>(8.09.2024) | 150:31 hrs | LINE CLEAR AVAIED   |
| 5692  | 08-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-HONNALLI      | MRSMSG_220           | 9:09 (2.09.2024)  | 15:41<br>(8.09.2024) | 150:31 hrs | LINE CLEAR AVAIED   |
| 5693  | 08-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA1     | gen_gersoppa         | 15:57(7.09.2024)  | 17:46(8.09.2024)     | 25:48 hrs  | LINE CLEAR AVAIED   |
| 5694  | 08-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP1         | MRSMSG_220           | 15:57(7.09.2024)  | 17:46(8.09.2024)     | 25:48 hrs  | LINE CLEAR AVAIED   |
| 5695  | 08-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHMG3         | gen_varahi           | 19:27(07.09.2024) | 17:44(8.09.2024)     | 22:16 hrs  | LINE CLEAR AVAIED   |
| 5696  | 09-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HALDY         | HOSANGADI_110        | 13:05(7.09.2024)  | 16:25<br>(9.9.2024)  | 27:19 hrs  | LINE CLEAR AVAIED   |
| 5697  | 09-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                  | MSEZ_220             | 10:12             | 13:05                | 02:53      | LINE CLEAR AVAIED   |
| 5698  | 09-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                  | MSEZ_220             | 10:12             | 13:05                | 02:53      | LINE CLEAR AVAIED   |
| 5699  | 09-Sep-24 | HASSAN  | 110     | LINE        | AJAMPU-KADUR         | AJAMPURA_110         | 17:03             | 17:24                | 00:21      | TRIPPED ON FAULT    |
| 5700  | 09-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-BANAVARA       | ARSIKERE_220         | 11:40             | 11:48                | 00:08      | TRIPPED ON FAULT    |
| 5701  | 09-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | BANAVARA_110         | 17:45             | 18:30                | 00:45      | LINE CLEAR AVAIED   |
| 5702  | 09-Sep-24 | HASSAN  | 110     | LINE        | BANAVA-LINE          | BANAVARA_110         | 11:40             | 11:58                | 00:18      | TRIPPED ON FAULT    |
| 5703  | 09-Sep-24 | HASSAN  | 110     | LINE        | HALADY1-HOSANGADI    | HALADY_110           | 10:51             | 16:11                | 05:20      | LINE CLEAR AVAIED   |
| 5704  | 09-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HULIKAL       | HOSANGADI_110        | 14:44             | 14:49                | 00:05      | TRIPPED ON FAULT    |
| 5705  | 09-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG1         | HOSANGADI_110        | 14:44             | 14:49                | 00:05      | TRIPPED ON FAULT    |
| 5706  | 09-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG2         | HOSANGADI_110        | 14:44             | 14:49                | 00:05      | TRIPPED ON FAULT    |
| 5707  | 09-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-KLSKR2        | KAVOOR_220           | 11:58             | 13:12                | 01:14      | LINE CLEAR AVAIED   |
| 5708  | 09-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1     | KEMAR_220            | 11:33             | 13:39                | 02:06      | LINE CLEAR AVAIED   |
| 5709  | 09-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-BELMAN         | KEMAR_220            | 11:14             | 13:29                | 02:15      | LINE CLEAR AVAIED   |
| 5710  | 09-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-JAPPU         | KONAJE_110           | 11:45             | 13:15                | 01:30      | LINE CLEAR AVAIED   |
| 5711  | 09-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KAVOOR 2      | KULASHEKARA_110      | 11:58             | 13:12                | 01:14      | LINE CLEAR AVAIED   |
| 5712  | 09-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-KEMAR         | MOODABIDRE_110       | 11:30             | 13:46                | 02:16      | LINE CLEAR AVAIED   |
| 5713  | 09-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | PUTTUR_110           | 03:10             | 03:43                | 00:33      | TRIPPED ON FAULT    |
| 5714  | 09-Sep-24 | HASSAN  | 66      | LINE        | CRPATNA-MATTANAVILE  | CRPATTANA_220        | 12:47             | 12:50                | 00:03      | LINE CLEAR AVAIED   |
| 5715  | 09-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-CHIKAMAGLUR2 | HASSAN_220           | 12:15             | 13:20                | 01:05      | LINE CLEAR AVAIED   |
| 5716  | 09-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-MALLALI      | HASSAN_220           | 12:15             | 13:20                | 01:05      | LINE CLEAR AVAIED   |
| 5717  | 09-Sep-24 | HASSAN  | 66      | TRANSFORMER | MRSSHM-66 LV4        | MRSMSG_220           | 13:25             | 13:35                | 00:10      | LINE CLEAR AVAIED   |
| 5718  | 09-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE       | SIGEBAGE_66          | 08:25             | 08:45                | 00:20      | TRIPPED ON FAULT    |
| 5719  | 10-Sep-24 | HASSAN  | 220     | LINE        | HGUNJE-KMR           | HEGGUNJE_220         | 11:36             | 14:29                | 02:53      | LINE CLEAR AVAIED   |
| 5720  | 10-Sep-24 | HASSAN  | 220     | LINE        | KADUR-DABUSET        | KADUR_220            | 11:06             | 18:05                | 06:59      | LINE CLEAR AVAIED   |
| 5721  | 10-Sep-24 | HASSAN  | 220     | LINE        | KADUR-SHIMOGA        | KADUR_220            | 18:03             | 18:05                | 00:02      | LINE CLEAR AVAIED   |
| 5722  | 10-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL          | KADUR_220            | 03:56             | 04:08                | 00:12      | TRIPPED ON FAULT    |
| 5723  | 10-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-KEMR1         | KAVOOR_220           | 09:55             | 17:45                | 07:50      | LINE CLEAR AVAIED   |
| 5724  | 10-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | KEMAR_220            | 11:24             | 16:11                | 04:47      | LINE CLEAR AVAIED   |
| 5725  | 10-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                  | KEMAR_220            | 16:23             | 16:32                | 00:09      | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                    | Station_Name           | Open_At            | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|-------------------------|------------------------|--------------------|-----------|----------|---------------------|
| 5726  | 10-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTUR1            | KEMAR_220              | 09:52              | 15:11     | 05:19    | LINE CLEAR AVAILED  |
| 5727  | 10-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-HEGGUNJE          | KEMAR_220              | 11:36              | 14:29     | 02:53    | LINE CLEAR AVAILED  |
| 5728  | 10-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-HIRIYADKA         | KEMAR_220              | 11:47              | 14:45     | 02:58    | LINE CLEAR AVAILED  |
| 5729  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                     | KEMAR_220              | 11:24              | 16:11     | 04:47    | LINE CLEAR AVAILED  |
| 5730  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV3                     | KEMAR_220              | 16:23              | 16:32     | 00:09    | LINE CLEAR AVAILED  |
| 5731  | 10-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Manipal2          | KEMAR_220              | 10:26              | 11:23     | 00:57    | LINE CLEAR AVAILED  |
| 5732  | 10-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1        | KEMAR_220              | 10:18              | 16:10     | 05:52    | LINE CLEAR AVAILED  |
| 5733  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | ARASIKERE_110          | 12:12              | 13:13     | 01:01    | LINE CLEAR AVAILED  |
| 5734  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | BANAVARA_110           | 12:37              | 14:20     | 01:43    | LINE CLEAR AVAILED  |
| 5735  | 10-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-MADHUVANA        | HIRIYADKA_110          | 10:00              | 14:27     | 04:27    | LINE CLEAR AVAILED  |
| 5736  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2 CB                  | JADE_110               | 01:00              | 02:00     | 01:00    | TRIPPED ON FAULT    |
| 5737  | 10-Sep-24 | HASSAN  | 110     | LINE        | JOG-JST1                | gen_mghe               | 10:20              | 16:15     | 05:55    | LINE CLEAR AVAILED  |
| 5738  | 10-Sep-24 | HASSAN  | 110     | LINE        | KARKLA-L1 CBreaker      | KARKLA_110             | 11:42              | 14:46     | 03:04    | LINE CLEAR AVAILED  |
| 5739  | 10-Sep-24 | HASSAN  | 110     | LINE        | KARKLA-L2 CBreaker      | KARKLA_110             | 11:32              | 11:47     | 00:15    | LINE CLEAR AVAILED  |
| 5740  | 10-Sep-24 | HASSAN  | 110     | LINE        | KARKLA-L2 CBreaker      | KARKLA_110             | 14:47              | 15:06     | 00:19    | LINE CLEAR AVAILED  |
| 5741  | 10-Sep-24 | HASSAN  | 110     | LINE        | MADHUV-BRK_HRD CBreaker | MADHUVANA_110          | 10:01              | 14:27     | 04:26    | LINE CLEAR AVAILED  |
| 5742  | 10-Sep-24 | HASSAN  | 110     | LINE        | MADHUV-BRK_HRD CBreaker | MADHUVANA_110          | 10:01              | 14:27     | 04:26    | LINE CLEAR AVAILED  |
| 5743  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | MADHUVANA_110          | 10:01              | 14:38     | 04:37    | MAIN SUPPLY FAILURE |
| 5744  | 10-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR1          | NANDIKUR_110           | 10:22              | 16:05     | 05:43    | LINE CLEAR AVAILED  |
| 5745  | 10-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | NAVUNDA_110            | 15:20              | 15:25     | 00:05    | LINE CLEAR AVAILED  |
| 5746  | 10-Sep-24 | HASSAN  | 66      | LINE        | SAGARA-JST1             | SAGARA_110             | 10:37              | 16:15     | 05:38    | LINE CLEAR AVAILED  |
| 5747  | 10-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-R R NAGAR       | HASSAN_220             | 10:46              | 12:25     | 01:39    | LINE CLEAR AVAILED  |
| 5748  | 10-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-UDDURKOPLU      | HASSAN_220             | 10:40              | 12:10     | 01:30    | LINE CLEAR AVAILED  |
| 5749  | 10-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | RAMNATHPURA_66         | 18:40              | 19:16     | 00:36    | MAIN SUPPLY FAILURE |
| 5750  | 10-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | RAMNATHPURA_66         | 18:40              | 19:16     | 00:36    | MAIN SUPPLY FAILURE |
| 5751  | 10-Sep-24 | HASSAN  | 66      | LINE        | KATTEPURA_MINIH         | RAMNATHPURA_66         | 18:40              | 19:16     | 00:36    | MAIN SUPPLY FAILURE |
| 5752  | 10-Sep-24 | HASSAN  | 66      | LINE        | TVARECH-HONALI          | TAVARECHETTANAHALLY_66 | 04:40              | 05:10     | 00:30    | TRIPPED ON FAULT    |
| 5753  | 10-Sep-24 | HASSAN  | 66      | LINE        | UDDURKPLU-UDDUR         | UDDURKOPPLU_66         | 10:58              | 11:15     | 00:17    | TRIPPED ON FAULT    |
| 5754  | 10-Sep-24 | HASSAN  | 66      | LINE        | UDDURKPLU-NITTUR1       | UDDURKOPPLU_66         | 10:58              | 12:10     | 01:12    | TRIPPED ON FAULT    |
| 5755  | 10-Sep-24 | HASSAN  | 66      | LINE        | UDDURKPLU-SUZLON1       | UDDURKOPPLU_66         | 10:55              | 12:10     | 01:15    | LINE CLEAR AVAILED  |
| 5756  | 10-Sep-24 | HASSAN  | 66      | LINE        | UDDURKPLU-NITTUR2       | UDDURKOPPLU_66         | 10:58              | 11:29     | 00:31    | TRIPPED ON FAULT    |
| 5757  | 11-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KAVOOR 2         | KULASHEKARA_110        | 20:59 (11.09.2024) |           |          | MAIN SUPPLY FAILURE |
| 5758  | 11-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-KLSKR2           | KAVOOR_220             | 20:59(11.09.2024)  |           |          | TRIPPED ON FAULT    |
| 5759  | 11-Sep-24 | HASSAN  | 220     | LINE        | ARSK2-HSN               | ARSIKERE_220           | 16:31              | 17:10     | 00:39    | LINE CLEAR AVAILED  |
| 5760  | 11-Sep-24 | HASSAN  | 220     | LINE        | KADUR-DABUSET           | KADUR_220              | 12:20              | 15:47     | 03:27    | LINE CLEAR AVAILED  |
| 5761  | 11-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                     | KAVOOR_220             | 11:55              | 13:22     | 01:27    | LINE CLEAR AVAILED  |
| 5762  | 11-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-KEMAR3           | KAVOOR_220             | 09:46              | 15:55     | 06:09    | LINE CLEAR AVAILED  |
| 5763  | 11-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-GURUPURA         | KAVOOR_220             | 10:40              | 10:47     | 00:07    | LINE CLEAR AVAILED  |
| 5764  | 11-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                     | KAVOOR_220             | 11:55              | 13:22     | 01:27    | LINE CLEAR AVAILED  |
| 5765  | 11-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                     | KEMAR_220              | 10:52              | 12:03     | 01:11    | LINE CLEAR AVAILED  |
| 5766  | 11-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-KAVR3             | KEMAR_220              | 09:46              | 16:00     | 06:14    | LINE CLEAR AVAILED  |
| 5767  | 11-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV3                     | KEMAR_220              | 10:52              | 12:03     | 01:11    | LINE CLEAR AVAILED  |
| 5768  | 11-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1        | KEMAR_220              | 10:32              | 12:13     | 01:41    | LINE CLEAR AVAILED  |
| 5769  | 11-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                     | SHRALKOPPA_220         | 12:30              | 14:01     | 01:31    | LINE CLEAR AVAILED  |
| 5770  | 11-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-KITTADAHALLI     | SHRALKOPPA_220         | 10:50              | 14:01     | 03:11    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line               | Station_Name      | Open_At            | Closed_At             | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|--------------------|-------------------|--------------------|-----------------------|----------|---------------------|
| 5771  | 11-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                | SHRALKOPPA_220    | 12:30              | 14:01                 | 01:31    | LINE CLEAR AVAILED  |
| 5772  | 11-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | BARANGI_110       | 11:40              | 21:40                 | 10:00    | LINE CLEAR AVAILED  |
| 5773  | 11-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-KEMAR       | HIRIYADKA_110     | 10:38              | 10:41                 | 00:03    | LINE CLEAR AVAILED  |
| 5774  | 11-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-KEMAR       | HIRIYADKA_110     | 13:48              | 13:53                 | 00:05    | LINE CLEAR AVAILED  |
| 5775  | 11-Sep-24 | HASSAN  | 110     | LINE        | L1 CBreaker        | KARKLA_110        | 13:48              | 13:53                 | 00:05    | LINE CLEAR AVAILED  |
| 5776  | 11-Sep-24 | HASSAN  | 110     | TRANSFORMER | L2                 | KARKLA_110        | 13:48              | 13:53                 | 00:05    | LINE CLEAR AVAILED  |
| 5777  | 11-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-MPM         | MRSMSG_220        | 16:19              | 17:41                 | 01:22    | LINE CLEAR AVAILED  |
| 5778  | 11-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-BD-1        | MRSMSG_220        | 11:02              | 14:04                 | 03:02    | LINE CLEAR AVAILED  |
| 5779  | 11-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-BD-2        | MRSMSG_220        | 14:43              | 17:29                 | 02:46    | LINE CLEAR AVAILED  |
| 5780  | 11-Sep-24 | HASSAN  | 66      | LINE        | GORUR-HASSAN       | GORUR_66          | 11:00              | 11:35                 | 00:35    | MAIN SUPPLY FAILURE |
| 5781  | 11-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-HNPURA    | HASSAN_220        | 10:35              | 12:55                 | 02:20    | LINE CLEAR AVAILED  |
| 5782  | 11-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-ARKALGUD2 | HASSAN_220        | 10:58              | 11:33                 | 00:35    | LINE CLEAR AVAILED  |
| 5783  | 11-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1 CB             | HETTUR_66         | 12:15              | 16:35                 | 04:20    | LINE CLEAR AVAILED  |
| 5784  | 11-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | SOMNHALLY_66      | 12:00              | 16:40                 | 04:40    | LINE CLEAR AVAILED  |
| 5785  | 11-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                | SOMNHALLY_66      | 12:00              | 16:40                 | 04:40    | LINE CLEAR AVAILED  |
| 5786  | 12-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-KLSKR2      | KAVOOR_220        | 20:59(11.9.2024)   | 0:48(12.09.2024)      | 4:49HRS  | LINE CLEAR AVAILED  |
| 5787  | 12-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KAVOOR 2    | KULASHEKARA_110   | 20:59 (11.09.2024) | 0:48(12.09.2024)      | 4:49HRS  | LINE CLEAR AVAILED  |
| 5788  | 12-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-MANIPAL     | HIRIYADKA_110     | 9:55(12.09.2024)   | 12:10<br>(13.09.2024) | 26:15HRS | LINE CLEAR AVAILED  |
| 5789  | 12-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-HIRIYADKA  | MANIPAL_110       | 9:55(12.09.2024)   |                       |          | LINE CLEAR AVAILED  |
| 5790  | 12-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-ARAKALGUD | HASSAN_220        | 16:19              | 17:19                 | 01:00    | LINE CLEAR AVAILED  |
| 5791  | 12-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-BELUR     | HASSAN_220        | 16:19              | 17:20                 | 01:01    | LINE CLEAR AVAILED  |
| 5792  | 12-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-HN PURA   | HASSAN_220        | 11:33              | 14:11                 | 02:38    | LINE CLEAR AVAILED  |
| 5793  | 12-Sep-24 | HASSAN  | 220     | LINE        | KADUR-DABUSET      | KADUR_220         | 16:22              | 17:13                 | 00:51    | LINE CLEAR AVAILED  |
| 5794  | 12-Sep-24 | HASSAN  | 220     | LINE        | KADUR-SHIMOGA      | KADUR_220         | 12:20              | 15:26                 | 03:06    | LINE CLEAR AVAILED  |
| 5795  | 12-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-KADUR       | MRSMSG_220        | 12:20              | 15:26                 | 03:06    | LINE CLEAR AVAILED  |
| 5796  | 12-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                | PUTTUR_220        | 09:27              | 13:24                 | 03:57    | LINE CLEAR AVAILED  |
| 5797  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                | PUTTUR_220        | 09:27              | 13:24                 | 03:57    | LINE CLEAR AVAILED  |
| 5798  | 12-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR             | BANTWALA_110      | 12:29              | 12:53                 | 00:24    | MAIN SUPPLY FAILURE |
| 5799  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | BARANGI_110       | 10:49              | 12:35                 | 01:46    | LINE CLEAR AVAILED  |
| 5800  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | BARANGI_110       | 15:20              | 17:30                 | 02:10    | LINE CLEAR AVAILED  |
| 5801  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | ESSUR_110         | 16:35              | 17:45                 | 01:10    | LINE CLEAR AVAILED  |
| 5802  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | GERUMARA_110      | 10:19              | 15:27                 | 05:08    | LINE CLEAR AVAILED  |
| 5803  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | GERUMARA_110      | 10:19              | 15:27                 | 05:08    | LINE CLEAR AVAILED  |
| 5804  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | GURUVAYANKERE-110 | 11:40              | 11:53                 | 00:13    | TRIPPED ON FAULT    |
| 5805  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                | GURUVAYANKERE-110 | 11:40              | 11:53                 | 00:13    | TRIPPED ON FAULT    |
| 5806  | 12-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG2       | HOSANGADI_110     | 12:01              | 13:05                 | 01:04    | LINE CLEAR AVAILED  |
| 5807  | 12-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-AMR         | KAVOOR_220        | 12:29              | 16:10                 | 03:41    | TRIPPED ON FAULT    |
| 5808  | 12-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-BAIKAMPADI  | KAVOOR_220        | 16:31              | 18:47                 | 02:16    | TRIPPED ON FAULT    |
| 5809  | 12-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                | KEMAR_220         | 10:52              | 12:00                 | 01:08    | LINE CLEAR AVAILED  |
| 5810  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV3                | KEMAR_220         | 10:52              | 12:00                 | 01:08    | LINE CLEAR AVAILED  |
| 5811  | 12-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1   | KEMAR_220         | 10:50              | 12:00                 | 01:10    | LINE CLEAR AVAILED  |
| 5812  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | KULASHEKARA_110   | 10:06              | 13:47                 | 03:41    | LINE CLEAR AVAILED  |
| 5813  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | KULASHEKARA_110   | 10:06              | 14:01                 | 03:55    | LINE CLEAR AVAILED  |
| 5814  | 12-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                | KULASHEKARA_110   | 10:06              | 14:06                 | 04:00    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                 | Station_Name      | Open_At          | Closed_At             | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|----------------------|-------------------|------------------|-----------------------|----------|---------------------|
| 5815  | 12-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KAVOOR 2      | KULASHEKARA_110   | 10:08            | 13:46                 | 03:38    | LINE CLEAR AVAILED  |
| 5816  | 12-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-KAVOOR          | MSEZ_220          | 10:02            | 14:23                 | 04:21    | LINE CLEAR AVAILED  |
| 5817  | 12-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-BAIKAMPADY      | MSEZ_220          | 10:11            | 13:36                 | 03:25    | LINE CLEAR AVAILED  |
| 5818  | 12-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                  | GORUR_66          | 12:10            | 12:42                 | 00:32    | LINE CLEAR AVAILED  |
| 5819  | 12-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS3          | HNPURA_220        | 10:53            | 13:38                 | 02:45    | LINE CLEAR AVAILED  |
| 5820  | 12-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | SHANTHIGRAMA_66   | 12:12            | 12:26                 | 00:14    | TRIPPED ON FAULT    |
| 5821  | 12-Sep-24 | HASSAN  | 66      | LINE        | SOMNHL-GDNEHALI      | SOMNHALLY_66      | 20:45            | 21:11                 | 00:26    | MAIN SUPPLY FAILURE |
| 5822  | 12-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | UDAYAPURA_66      | 07:52            | 11:22                 | 03:30    | TRIPPED ON FAULT    |
| 5823  | 13-Sep-24 | HASSAN  | 110     | LINE        | HIRIYA-MANIPAL       | HIRIYADKA_110     | 9:55(12.09.2024) | 12:10<br>(13.09.2024) | 26:15HRS | LINE CLEAR AVAILED  |
| 5824  | 13-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-HIRIYADKA    | MANIPAL_110       | 9:55(12.09.2024) | 12:10<br>(13.09.2024) | 26:15HRS | LINE CLEAR AVAILED  |
| 5825  | 13-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | CRPATNA_220       | 10:34            | 18:17                 | 07:43    | LINE CLEAR AVAILED  |
| 5826  | 13-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | HASSAN_220        | 11:15            | 12:00                 | 00:45    | LINE CLEAR AVAILED  |
| 5827  | 13-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | HASSAN_220        | 16:28            | 16:57                 | 00:29    | LINE CLEAR AVAILED  |
| 5828  | 13-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | ESSUR_110         | 16:00            | 16:40                 | 00:40    | LINE CLEAR AVAILED  |
| 5829  | 13-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | GURUVAYANKERE_110 | 09:45            | 09:50                 | 00:05    | LINE CLEAR AVAILED  |
| 5830  | 13-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NERELEKERE     | KADUR_220         | 12:53            | 13:20                 | 00:27    | TRIPPED ON FAULT    |
| 5831  | 13-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL          | KADUR_220         | 12:53            | 13:20                 | 00:27    | TRIPPED ON FAULT    |
| 5832  | 13-Sep-24 | HASSAN  | 110     | LINE        | KADUR-TNGL           | KADUR_220         | 12:53            | 13:20                 | 00:27    | TRIPPED ON FAULT    |
| 5833  | 13-Sep-24 | HASSAN  | 110     | LINE        | KADUR-YGTI           | KADUR_220         | 12:53            | 13:20                 | 00:27    | TRIPPED ON FAULT    |
| 5834  | 13-Sep-24 | HASSAN  | 110     | LINE        | SAGARA-SORABA        | SAGARA_110        | 14:35            | 16:30                 | 01:55    | LINE CLEAR AVAILED  |
| 5835  | 13-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-ARSKR          | ARSIKERE_220      | 07:23            | 07:28                 | 00:05    | TRIPPED ON FAULT    |
| 5836  | 13-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-ARSKR          | ARSIKERE_220      | 07:23            | 07:29                 | 00:06    | TRIPPED ON FAULT    |
| 5837  | 13-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-BANAVARA       | ARSIKERE_220      | 07:23            | 07:46                 | 00:23    | TRIPPED ON FAULT    |
| 5838  | 13-Sep-24 | HASSAN  | 110     | LINE        | KAVOORGURUPURA       | KAVOOR_220        | 10:04            | 15:54                 | 05:50    | LINE CLEAR AVAILED  |
| 5839  | 13-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-MPM           | MRSMSG_220        | 11:01            | 14:21                 | 03:20    | LINE CLEAR AVAILED  |
| 5840  | 13-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG1          | MRSMSG_220        | 12:53            | 13:08                 | 00:15    | TRIPPED ON FAULT    |
| 5841  | 13-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2          | MRSMSG_220        | 12:53            | 13:04                 | 00:11    | TRIPPED ON FAULT    |
| 5842  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                  | DUDDA_66          | 10:09            | 10:19                 | 00:10    | TRIPPED ON FAULT    |
| 5843  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | HASSAN_66         | 10:52            | 12:02                 | 01:10    | LINE CLEAR AVAILED  |
| 5844  | 13-Sep-24 | HASSAN  | 220     | LINE        | HASSN22-NITTUR       | HASSAN_220        | 10:11            | 17:57                 | 07:46    | LINE CLEAR AVAILED  |
| 5845  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-ARAKALGUD    | HASSAN_220        | 12:00            | 12:05                 | 00:05    | LINE CLEAR AVAILED  |
| 5846  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-CHIKAMAGLUR2 | HASSAN_220        | 12:00            | 12:05                 | 00:05    | LINE CLEAR AVAILED  |
| 5847  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-CHIKAMAGLUR2 | HASSAN_220        | 16:28            | 16:54                 | 00:26    | LINE CLEAR AVAILED  |
| 5848  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-HSN66        | HASSAN_220        | 12:00            | 12:05                 | 00:05    | LINE CLEAR AVAILED  |
| 5849  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-HSN66        | HASSAN_220        | 16:28            | 16:49                 | 00:21    | LINE CLEAR AVAILED  |
| 5850  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV2                  | HASSAN_220        | 11:15            | 12:00                 | 00:45    | LINE CLEAR AVAILED  |
| 5851  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV2                  | HASSAN_220        | 16:28            | 16:48                 | 00:20    | LINE CLEAR AVAILED  |
| 5852  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-UDDURKOPLU   | HASSAN_220        | 12:00            | 12:05                 | 00:05    | LINE CLEAR AVAILED  |
| 5853  | 13-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-UDDURKOPLU   | HASSAN_220        | 16:28            | 16:52                 | 00:24    | LINE CLEAR AVAILED  |
| 5854  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                  | RAMPURA_66        | 10:31            | 15:03                 | 04:32    | LINE CLEAR AVAILED  |
| 5855  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | RAMPURA_66        | 10:31            | 15:03                 | 04:32    | LINE CLEAR AVAILED  |
| 5856  | 13-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-HASSAN2       | SAKALESHPURA_66   | 11:05            | 11:15                 | 00:10    | TRIPPED ON FAULT    |
| 5857  | 13-Sep-24 | HASSAN  | 66      | LINE        | SAKALEHASSAN1        | SAKALESHPURA_66   | 11:05            | 11:15                 | 00:10    | TRIPPED ON FAULT    |
| 5858  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                  | UDAYAPURA_66      | 10:30            | 17:11                 | 06:41    | LINE CLEAR AVAILED  |
| 5859  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | UDAYAPURA_66      | 10:30            | 17:11                 | 06:41    | LINE CLEAR AVAILED  |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line              | Station_Name        | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|-------------------|---------------------|---------|-----------|----------|---------------------|
| 5860  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | UDAYAPURA_66        | 07:50   | 08:00     | 00:10    | LINE CLEAR AVAILED  |
| 5861  | 13-Sep-24 | HASSAN  | 66      | LINE        | UDAYAP-CRP1       | UDAYAPURA_66        | 10:30   | 17:11     | 06:41    | LINE CLEAR AVAILED  |
| 5862  | 13-Sep-24 | HASSAN  | 66      | LINE        | UDAYAP-CRP1       | UDAYAPURA_66        | 10:30   | 17:11     | 06:41    | LINE CLEAR AVAILED  |
| 5863  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | BAGUR_66            | 10:33   | 17:21     | 06:48    | LINE CLEAR AVAILED  |
| 5864  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | BAGUR_66            | 10:33   | 17:11     | 06:38    | LINE CLEAR AVAILED  |
| 5865  | 13-Sep-24 | HASSAN  | 66      | LINE        | BAGUR-RAMAPUR     | BAGUR_66            | 10:33   | 17:12     | 06:39    | LINE CLEAR AVAILED  |
| 5866  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV2               | CRPATNA_220         | 10:34   | 18:18     | 07:44    | LINE CLEAR AVAILED  |
| 5867  | 13-Sep-24 | HASSAN  | 66      | LINE        | BYARAPU-BAGUR     | KBYARAPURA_66       | 10:31   | 17:12     | 06:41    | LINE CLEAR AVAILED  |
| 5868  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | KBYARAPURA_66       | 10:31   | 17:13     | 06:42    | LINE CLEAR AVAILED  |
| 5869  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | KBYARAPURA_66       | 10:31   | 17:13     | 06:42    | LINE CLEAR AVAILED  |
| 5870  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHANNAR-SHETHLLY  | CHANNARAYAPATNA_66  | 10:15   | 17:15     | 07:00    | LINE CLEAR AVAILED  |
| 5871  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | CHANNARAYAPATNA_66  | 10:30   | 16:20     | 05:50    | LINE CLEAR AVAILED  |
| 5872  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | CHANNARAYAPATNA_66  | 10:30   | 17:00     | 06:30    | LINE CLEAR AVAILED  |
| 5873  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHANNAR-CRP1      | CHANNARAYAPATNA_66  | 10:30   | 16:20     | 05:50    | LINE CLEAR AVAILED  |
| 5874  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHANNAR-CRP2      | CHANNARAYAPATNA_66  | 10:30   | 16:20     | 05:50    | LINE CLEAR AVAILED  |
| 5875  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHANNAR-UDAYPURA1 | CHANNARAYAPATNA_66  | 10:30   | 17:00     | 06:30    | LINE CLEAR AVAILED  |
| 5876  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHANNAR-UDAYPURA2 | CHANNARAYAPATNA_66  | 10:30   | 17:00     | 06:30    | LINE CLEAR AVAILED  |
| 5877  | 13-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | CHIKABOMENAHALLY_66 | 10:20   | 10:40     | 00:20    | LINE CLEAR AVAILED  |
| 5878  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHIKKAK-DUDDA     | CHIKKAKONDAGOLA_66  | 11:10   | 12:22     | 01:12    | MAIN SUPPLY FAILURE |
| 5879  | 13-Sep-24 | HASSAN  | 66      | LINE        | CHIKKAK-DUDDA     | CHIKKAKONDAGOLA_66  | 16:28   | 16:57     | 00:29    | MAIN SUPPLY FAILURE |
| 5880  | 14-Sep-24 | HASSAN  | 110     | LINE        | SHIRAL-SHKARPURA  | SHIRALKOPPA_110     | 16:50   | 18:30     | 01:40    | TRIPPED ON FAULT    |
| 5881  | 14-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | BYARAPURA_66        | 04:08   | 04:13     | 00:05    | TRIPPED ON FAULT    |
| 5882  | 14-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS3       | HNPUA_220           | 12:30   | 12:40     | 00:10    | TRIPPED ON FAULT    |
| 5883  | 14-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS3       | HNPUA_220           | 13:18   | 14:50     | 01:32    | LINE CLEAR AVAILED  |
| 5884  | 14-Sep-24 | HASSAN  | 66      | LINE        | KUDLIGE-ANVRPP    | KUDLIGERE_66        | 09:35   | 16:30     | 06:55    | MAIN SUPPLY FAILURE |
| 5885  | 14-Sep-24 | HASSAN  | 66      | LINE        | MOSALEH-HNPRA     | MOSALEHOSHALLY_66   | 12:30   | 12:40     | 00:10    | MAIN SUPPLY FAILURE |
| 5886  | 14-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2       | MRSMSG_220          | 09:35   | 12:51     | 03:16    | LINE CLEAR AVAILED  |
| 5887  | 14-Sep-24 | HASSAN  | 66      | LINE        | UDDURKO-SUZLON1   | UDDURKOPPLU_66      | 11:45   | 14:45     | 03:00    | TRIPPED ON FAULT    |
| 5888  | 14-Sep-24 | HASSAN  | 66      | LINE        | UDDURKO-SUZLON2   | UDDURKOPPLU_66      | 11:45   | 12:17     | 00:32    | TRIPPED ON FAULT    |
| 5889  | 14-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | SIGEBAGI_66         | 09:35   | 12:55     | 03:20    | MAIN SUPPLY FAILURE |
| 5890  | 14-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | SIGEBAGI_66         | 09:35   | 12:55     | 03:20    | MAIN SUPPLY FAILURE |
| 5891  | 14-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE    | SIGEBAGI_66         | 09:35   | 12:55     | 03:20    | MAIN SUPPLY FAILURE |
| 5892  | 14-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-SMG-DVG2  | SIGEBAGI_66         | 09:35   | 12:57     | 03:22    | MAIN SUPPLY FAILURE |
| 5893  | 14-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2               | UDAYAPURA_66        | 07:20   | 07:35     | 00:15    | TRIPPED ON FAULT    |
| 5894  | 14-Sep-24 | HASSAN  | 66      | LINE        | CHIKKAK-DUDDA     | CHIKKAKONDAGOLA_66  | 10:35   | 10:57     | 00:22    | TRIPPED ON FAULT    |
| 5895  | 15-Sep-24 | HASSAN  | 220     | LINE        | SHARAVTY-SHIMOGA1 | gen_sharavathy      | 13:32   | 16:13     | 02:41    | TRIPPED ON FAULT    |
| 5896  | 15-Sep-24 | HASSAN  | 110     | LINE        | JOG-JLT4          | gen_mghe            | 14:22   | 15:55     | 01:33    | TRIPPED ON FAULT    |
| 5897  | 15-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL       | KADUR_220           | 06:12   | 06:47     | 00:35    | TRIPPED ON FAULT    |
| 5898  | 15-Sep-24 | HASSAN  | 110     | LINE        | LPH-MGHE 2        | gen_lph             | 14:22   | 15:57     | 01:35    | TRIPPED ON FAULT    |
| 5899  | 15-Sep-24 | HASSAN  | 66      | LINE        | CHIKKAK-DUDDA     | CHIKKAKONDAGOLA_66  | 09:37   | 10:03     | 00:26    | TRIPPED ON FAULT    |
| 5900  | 15-Sep-24 | HASSAN  | 66      | LINE        | CRPATNA-SBELAGOLA | CRPATNA_66          | 06:14   | 06:30     | 00:16    | TRIPPED ON FAULT    |
| 5901  | 15-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE    | SIGEBAGE_66         | 09:18   | 09:40     | 00:22    | TRIPPED ON FAULT    |
| 5902  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1               | BYARAPURA_66        | 13:13   | 14:29     | 01:16    | TRIPPED ON FAULT    |
| 5903  | 16-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2               | ANAVATTI_110        | 14:59   | 17:17     | 02:18    | LINE CLEAR AVAILED  |
| 5904  | 16-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3               | BAIKAMPADY_110      | 12:00   | 12:43     | 00:43    | LINE CLEAR AVAILED  |
| 5905  | 16-Sep-24 | HASSAN  | 110     | LINE        | BAIKAM-KAVOOR     | BAIKAMPADY_110      | 15:42   | 15:43     | 00:01    | LINE CLEAR AVAILED  |
| 5906  | 16-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1               | MOODABIDRE_110      | 11:52   | 12:49     | 00:57    | LINE CLEAR AVAILED  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                | Station_Name         | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|---------------------|----------------------|---------|-----------|----------|---------------------|
| 5907  | 16-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | MOODABIDRE_110       | 11:52   | 12:48     | 00:56    | LINE CLEAR AVAIED   |
| 5908  | 16-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-GURUPURA     | MOODABIDRE_110       | 11:47   | 12:48     | 01:01    | LINE CLEAR AVAIED   |
| 5909  | 16-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-KEMAR        | MOODABIDRE_110       | 11:54   | 12:48     | 00:54    | LINE CLEAR AVAIED   |
| 5910  | 16-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-SOHAM1       | MOODABIDRE_110       | 11:52   | 12:48     | 00:56    | LINE CLEAR AVAIED   |
| 5911  | 16-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                 | CHIKKANAGARA_220     | 11:19   | 11:48     | 00:29    | TRIPPED ON FAULT    |
| 5912  | 16-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                 | CHIKKANAGARA_220     | 11:19   | 11:49     | 00:30    | TRIPPED ON FAULT    |
| 5913  | 16-Sep-24 | HASSAN  | 66      | LINE        | CHKNGR-KADAGARAHALY | CHIKKANAGARA_220     | 11:19   | 13:05     | 01:46    | TRIPPED ON FAULT    |
| 5914  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV1                 | CHIKKANAGARA_220     | 11:19   | 11:51     | 00:32    | TRIPPED ON FAULT    |
| 5915  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV2                 | CHIKKANAGARA_220     | 11:19   | 11:54     | 00:35    | TRIPPED ON FAULT    |
| 5916  | 16-Sep-24 | HASSAN  | 66      | LINE        | DODDAKA-HNPURA      | DODDAKADNUR_66       | 17:40   | 18:00     | 00:20    | MAIN SUPPLY FAILURE |
| 5917  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DODDAKADNUR_66       | 17:40   | 18:00     | 00:20    | MAIN SUPPLY FAILURE |
| 5918  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | DODDAKADNUR_66       | 17:40   | 18:00     | 00:20    | MAIN SUPPLY FAILURE |
| 5919  | 16-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-MYSOR2        | HNPURA_220           | 17:39   | 17:47     | 00:08    | TRIPPED ON FAULT    |
| 5920  | 16-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-RNPR2         | HNPURA_220           | 07:11   | 07:28     | 00:17    | TRIPPED ON FAULT    |
| 5921  | 16-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | SAKALESHPURA_66      | 19:57   | 20:08     | 00:11    | LINE CLEAR AVAIED   |
| 5922  | 16-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONALI      | TAVARECHATNAHALLI_66 | 03:45   | 03:55     | 00:10    | TRIPPED ON FAULT    |
| 5923  | 17-Sep-24 | HASSAN  | 220     | LINE        | HASSN220-Shomoga    | HASSAN_220           | 10:23   | 15:19     | 04:56    | LINE CLEAR AVAIED   |
| 5924  | 17-Sep-24 | HASSAN  | 220     | LINE        | HGUNJE-KMR          | HEGGUNJE_220         | 09:45   | 14:17     | 04:32    | LINE CLEAR AVAIED   |
| 5925  | 17-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-KEMR1        | KAVOOR_220           | 10:30   | 13:33     | 03:03    | LINE CLEAR AVAIED   |
| 5926  | 17-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-HEGGUNJE      | KEMAR_220            | 09:45   | 14:17     | 04:32    | LINE CLEAR AVAIED   |
| 5927  | 17-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-CHMLR        | MRSMSG_220           | 10:22   | 15:12     | 04:50    | LINE CLEAR AVAIED   |
| 5928  | 17-Sep-24 | HASSAN  | 220     | LINE        | MSEZ-KAVOOR1        | MSEZ_220             | 10:30   | 13:33     | 03:03    | LINE CLEAR AVAIED   |
| 5929  | 17-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                 | PUTTUR_220           | 11:06   | 15:08     | 04:02    | LINE CLEAR AVAIED   |
| 5930  | 17-Sep-24 | HASSAN  | 220     | LINE        | MRS                 | ARSIKERE_220         | 12:45   | 13:35     | 00:50    | LINE CLEAR AVAIED   |
| 5931  | 17-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                 | ARSIKERE_220         | 16:22   | 16:36     | 00:14    | LINE CLEAR AVAIED   |
| 5932  | 17-Sep-24 | HASSAN  | 110     | LINE        | KADUR-TNGL          | KADUR_220            | 11:00   | 15:36     | 04:36    | LINE CLEAR AVAIED   |
| 5933  | 17-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-KARKALA       | KEMAR_220            | 14:42   | 17:47     | 03:05    | LINE CLEAR AVAIED   |
| 5934  | 17-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-KARKALA       | KEMAR_220            | 14:43   | 17:47     | 03:04    | LINE CLEAR AVAIED   |
| 5935  | 17-Sep-24 | HASSAN  | 110     | LINE        | KULASHEK-KAVOOR 2   | KULASHEKARA_110      | 10:16   | 14:04     | 03:48    | LINE CLEAR AVAIED   |
| 5936  | 17-Sep-24 | HASSAN  | 110     | LINE        | LPHLST3             | gen lph              | 15:58   | 18:45     | 02:47    | LINE CLEAR AVAIED   |
| 5937  | 17-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                 | PUTTUR_220           | 11:06   | 15:22     | 04:16    | LINE CLEAR AVAIED   |
| 5938  | 17-Sep-24 | HASSAN  | 110     | LINE        | SAGARA-LST3         | SAGARA_110           | 15:58   | 18:45     | 02:47    | TRIPPED ON FAULT    |
| 5939  | 17-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | THANGLI_110          | 09:00   | 17:42     | 08:42    | LINE CLEAR AVAIED   |
| 5940  | 17-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | THANGLI_110          | 09:00   | 17:42     | 08:42    | LINE CLEAR AVAIED   |
| 5941  | 17-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | BALEHONNUR_66        | 17:00   | 18:07     | 01:07    | LINE CLEAR AVAIED   |
| 5942  | 17-Sep-24 | HASSAN  | 66      | LINE        | DODDAHA-HOOTGALLI   | DODDAHALLI_66        | 11:28   | 11:41     | 00:13    | LINE CLEAR AVAIED   |
| 5943  | 17-Sep-24 | HASSAN  | 66      | LINE        | HOOTGALLI           | DODDAHALLI_66        | 13:20   | 13:25     | 00:05    | LINE CLEAR AVAIED   |
| 5944  | 17-Sep-24 | HASSAN  | 66      | LINE        | HNPURA              | DODDAKADNUR_66       | 00:10   | 09:59     | 09:49    | LINE CLEAR AVAIED   |
| 5945  | 17-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DODDAKADNUR_66       | 00:10   | 09:59     | 09:49    | LINE CLEAR AVAIED   |
| 5946  | 17-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DODDAKADNUR_66       | 00:10   | 09:59     | 09:49    | LINE CLEAR AVAIED   |
| 5947  | 17-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | DODDAMAGGE_66        | 12:10   | 13:00     | 00:50    | LINE CLEAR AVAIED   |
| 5948  | 17-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DODDAMAGGE_66        | 13:10   | 13:41     | 00:31    | LINE CLEAR AVAIED   |
| 5949  | 17-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE      | SIGEBAGE_66          | 09:06   | 09:20     | 00:14    | TRIPPED ON FAULT    |
| 5950  | 18-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                 | HNPURA_220           | 10:21   | 11:55     | 01:34    | LINE CLEAR AVAIED   |
| 5951  | 18-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                 | HNPURA_220           | 12:20   | 14:11     | 01:51    | LINE CLEAR AVAIED   |
| 5952  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS1         | HNPURA_220           | 10:32   | 16:05     | 05:33    | LINE CLEAR AVAIED   |
| 5953  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS3         | HNPURA_220           | 10:34   | 10:41     | 00:07    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                | Station_Name       | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|---------------------|--------------------|-------------------|-----------|----------|---------------------|
| 5954  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HNPR1         | HNPURA_220         | 10:25             | 13:04     | 02:39    | LINE CLEAR AVAIED   |
| 5955  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | Lv1                 | HNPURA_220         | 10:21             | 11:56     | 01:35    | LINE CLEAR AVAIED   |
| 5956  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | Lv2                 | HNPURA_220         | 12:20             | 14:11     | 01:51    | LINE CLEAR AVAIED   |
| 5957  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-RNPR1         | HNPURA_220         | 11:02             | 14:24     | 03:22    | LINE CLEAR AVAIED   |
| 5958  | 18-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-KEMR2        | KAVOOR_220         | 10:15             | 13:10     | 02:55    | LINE CLEAR AVAIED   |
| 5959  | 18-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-ANTRSNH      | MRSMSG_220         | 10:11             | 13:41     | 03:30    | LINE CLEAR AVAIED   |
| 5960  | 18-Sep-24 | HASSAN  | 220     | LINE        | MSEZ-KAVOOR1        | MSEZ_220           | 10:15             | 13:10     | 02:55    | LINE CLEAR AVAIED   |
| 5961  | 18-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-TALAGUPPA 2 | gen_sharavathy     | 07:55             | 17:51     | 09:56    | TRIPPED ON FAULT    |
| 5962  | 18-Sep-24 | HASSAN  | 220     | LINE        | TALAGU-SGS2         | TALAGUPPA_400      | 07:55             | 17:51     | 09:56    | TRIPPED ON FAULT    |
| 5963  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | BHADRAVATHI_110    | 09:13             | 14:41     | 05:28    | LINE CLEAR AVAIED   |
| 5964  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | BHADRAVATHI_110    | 09:14             | 14:14     | 05:00    | LINE CLEAR AVAIED   |
| 5965  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                 | BHADRAVATHI_110    | 09:13             | 14:15     | 05:02    | LINE CLEAR AVAIED   |
| 5966  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | ESSUR_110          | 16:15             | 17:10     | 00:55    | LINE CLEAR AVAIED   |
| 5967  | 18-Sep-24 | HASSAN  | 110     | LINE        | KADUR-YGTI          | KADUR_220          | 10:05             | 18:31     | 08:26    | LINE CLEAR AVAIED   |
| 5968  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | KONAJE_110         | 02:35             | 04:13     | 01:38    | MAIN SUPPLY FAILURE |
| 5969  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | KONAJE_110         | 05:43             | 08:08     | 02:25    | LINE CLEAR AVAIED   |
| 5970  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | KONAJE_110         | 02:35             | 02:50     | 00:15    | MAIN SUPPLY FAILURE |
| 5971  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | MANCHENAHALLI_110  | 09:14             | 15:31     | 06:17    | LINE CLEAR AVAIED   |
| 5972  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | MANCHENAHALLI_110  | 09:14             | 15:31     | 06:17    | LINE CLEAR AVAIED   |
| 5973  | 18-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-BADRAVATY3   | MRSMSG_220         | 09:13             | 14:05     | 04:52    | LINE CLEAR AVAIED   |
| 5974  | 18-Sep-24 | HASSAN  | 110     | LINE        | PUTTUR-SULIA        | PUTTUR_220         | 10:07             | 15:44     | 05:37    | LINE CLEAR AVAIED   |
| 5975  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | SINGATGERE_110     | 10:20             | 18:39     | 08:19    | LINE CLEAR AVAIED   |
| 5976  | 18-Sep-24 | HASSAN  | 110     | LINE        | SINGATG-YAGATI      | SINGATGERE_110     | 10:20             | 18:39     | 08:19    | LINE CLEAR AVAIED   |
| 5977  | 18-Sep-24 | HASSAN  | 220     | LINE        | ARSK2-BANAVARA      | ARSIKERE_220       | 04:25             | 04:32     | 00:07    | TRIPPED ON FAULT    |
| 5978  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | TARIKERE_110       | 18:04             | 18:20     | 00:16    | TRIPPED ON FAULT    |
| 5979  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | YAGATI_110         | 10:00             | 18:35     | 08:35    | LINE CLEAR AVAIED   |
| 5980  | 18-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | YAGATI_110         | 10:00             | 18:35     | 08:35    | LINE CLEAR AVAIED   |
| 5981  | 18-Sep-24 | HASSAN  | 110     | LINE        | YAGATI-SINGERI      | YAGATI_110         | 10:00             | 18:35     | 08:35    | LINE CLEAR AVAIED   |
| 5982  | 18-Sep-24 | HASSAN  | 66      | LINE        | ALDUR-CHIKKAMAGLUR  | ALDUR_66           | 13:29             | 14:03     | 00:34    | TRIPPED ON FAULT    |
| 5983  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPURA              | BYACHANAHALLI_66   | 11:45             | 12:00     | 00:15    | TRIPPED ON FAULT    |
| 5984  | 18-Sep-24 | HASSAN  | 66      | LINE        | BYACHAN-HNPURA      | BYACHANAHALLI_66   | 12:10             | 12:20     | 00:10    | TRIPPED ON FAULT    |
| 5985  | 18-Sep-24 | HASSAN  | 66      | LINE        | HADAVAN-HNPURA      | HADAVANAHALLI_66   | 10:02             | 17:10     | 07:08    | LINE CLEAR AVAIED   |
| 5986  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | HADAVANAHALLI_66   | 10:02             | 17:10     | 07:08    | LINE CLEAR AVAIED   |
| 5987  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | HANGARAHALLI_66    | 10:06             | 16:24     | 06:18    | LINE CLEAR AVAIED   |
| 5988  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | HANGARAHALLI_66    | 10:06             | 16:24     | 06:18    | LINE CLEAR AVAIED   |
| 5989  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPURA-HASSAN       | HNPURA_66          | 10:21             | 18:03     | 07:42    | LINE CLEAR AVAIED   |
| 5990  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | HNPURA_66          | 10:12             | 18:00     | 07:48    | LINE CLEAR AVAIED   |
| 5991  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | HNPURA_66          | 10:12             | 18:00     | 07:48    | LINE CLEAR AVAIED   |
| 5992  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPURA-RAMNATHPURA  | HNPURA_66          | 10:17             | 18:00     | 07:43    | LINE CLEAR AVAIED   |
| 5993  | 18-Sep-24 | HASSAN  | 66      | LINE        | HNPURA-SOMANAHALLI  | HNPURA_66          | 10:17             | 18:00     | 07:43    | LINE CLEAR AVAIED   |
| 5994  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | ARAKALGUD_66       | 12:45             | 13:00     | 00:15    | TRIPPED ON FAULT    |
| 5995  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | LINGADAHALLI_66    | 12:50             | 16:50     | 04:00    | TRIPPED ON FAULT    |
| 5996  | 18-Sep-24 | HASSAN  | 66      | LINE        | MOSALEH-HNPRA       | MOSALEHOSAHALLI_66 | 10:20             | 16:10     | 05:50    | MAIN SUPPLY FAILURE |
| 5997  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | SINGAPURA_66       | 13:00             | 16:53     | 03:53    | LINE CLEAR AVAIED   |
| 5998  | 18-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | SINGAPURA_66       | 11:46             | 13:41     | 01:55    | LINE CLEAR AVAIED   |
| 5999  | 18-Sep-24 | HASSAN  | 66      | LINE        | SOMNHL-GDNEHALI     | SOMANAHALLI_66     | 10:26             | 13:07     | 02:41    | LINE CLEAR AVAIED   |
| 6000  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV4                 | KAVOOR_220         | 19:05(19.09.2024) |           |          | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                   | Station_Name      | Open_At           | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|------------------------|-------------------|-------------------|-----------|----------|---------------------|
| 6001  | 19-Sep-24 | HASSAN  | 400     | LINE        | TALAGU-NELAMANGALA#2   | TALAGUPPA_400     | 18:13             | 22:34     | 04:21    | TRIPPED ON FAULT    |
| 6002  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | ARASIKERE_110     | 11:20             | 13:55     | 02:35    | LINE CLEAR AVAIED   |
| 6003  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | ARASIKERE_110     | 13:55             | 19:41     | 05:46    | LINE CLEAR AVAIED   |
| 6004  | 19-Sep-24 | HASSAN  | 110     | LINE        | ARSK2-GANDASI          | ARASIKERE_220     | 16:00             | 18:00     | 02:00    | LINE CLEAR AVAIED   |
| 6005  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | ARASIKERE_220     | 13:10             | 14:40     | 01:30    | LINE CLEAR AVAIED   |
| 6006  | 19-Sep-24 | HASSAN  | 110     | LINE        | BLGMB-A                | BELAGUMBA_110     | 16:13             | 18:07     | 01:54    | LINE CLEAR AVAIED   |
| 6007  | 19-Sep-24 | HASSAN  | 110     | LINE        | GANDAS-KADUR           | GANDASI_110       | 16:00             | 18:00     | 02:00    | LINE CLEAR AVAIED   |
| 6008  | 19-Sep-24 | HASSAN  | 110     | LINE        | DMKURK-HONNAVALLI      | DMKURKE_110       | 10:21             | 22:17     | 11:56    | LINE CLEAR AVAIED   |
| 6009  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | DMKURKE_110       | 10:21             | 22:17     | 11:56    | LINE CLEAR AVAIED   |
| 6010  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | DMKURKE_110       | 10:21             | 17:51     | 07:30    | LINE CLEAR AVAIED   |
| 6011  | 19-Sep-24 | HASSAN  | 110     | LINE        | HALADY1-HOSANGADI      | HALADY_110        | 13:27             | 14:27     | 01:00    | LINE CLEAR AVAIED   |
| 6012  | 19-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HALDY           | HOSANGADI_110     | 10:06             | 19:19     | 09:13    | LINE CLEAR AVAIED   |
| 6013  | 19-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-HULIKAL         | HOSANGADI_110     | 10:04             | 19:19     | 09:15    | LINE CLEAR AVAIED   |
| 6014  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | HOSANGADI_110     | 10:04             | 19:19     | 09:15    | LINE CLEAR AVAIED   |
| 6015  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | HOSANGADI_110     | 10:04             | 19:19     | 09:15    | LINE CLEAR AVAIED   |
| 6016  | 19-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG1           | HOSANGADI_110     | 10:06             | 19:19     | 09:13    | LINE CLEAR AVAIED   |
| 6017  | 19-Sep-24 | HASSAN  | 110     | LINE        | HOSNGD-VTRG2           | HOSANGADI_110     | 10:06             | 19:19     | 09:13    | LINE CLEAR AVAIED   |
| 6018  | 19-Sep-24 | HASSAN  | 110     | LINE        | HULICA-KVR             | HULICAL_110       | 13:29             | 14:28     | 00:59    | LINE CLEAR AVAIED   |
| 6019  | 19-Sep-24 | HASSAN  | 110     | LINE        | KADUR-BANVR            | KADUR_220         | 15:55             | 17:55     | 02:00    | LINE CLEAR AVAIED   |
| 6020  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | KADUR_220         | 13:27             | 15:16     | 01:49    | LINE CLEAR AVAIED   |
| 6021  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | KADUR_220         | 09:50             | 16:58     | 07:08    | LINE CLEAR AVAIED   |
| 6022  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                    | KADUR_220         | 09:50             | 16:58     | 07:08    | LINE CLEAR AVAIED   |
| 6023  | 19-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NGNHL            | KADUR_220         | 10:03             | 17:36     | 07:33    | LINE CLEAR AVAIED   |
| 6024  | 19-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-KAVOOR          | KONAJE_110        | 10:06             | 14:37     | 04:31    | LINE CLEAR AVAIED   |
| 6025  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | KONDENALU_110     | 16:00             | 16:23     | 00:23    | MAIN SUPPLY FAILURE |
| 6026  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | KONDENALU_110     | 16:10             | 16:23     | 00:13    | MAIN SUPPLY FAILURE |
| 6027  | 19-Sep-24 | HASSAN  | 110     | LINE        | KONDENA-KADUR-ARSIKERE | KONDENALU_110     | 16:10             | 18:08     | 01:58    | MAIN SUPPLY FAILURE |
| 6028  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | MOODABIDRE_110    | 10:51             | 11:24     | 00:33    | LINE CLEAR AVAIED   |
| 6029  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                    | MSEZ_220          | 10:05             | 13:37     | 03:32    | LINE CLEAR AVAIED   |
| 6030  | 19-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | MSEZ_220          | 09:59             | 13:54     | 03:55    | LINE CLEAR AVAIED   |
| 6031  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | ARAKALKOPPA_66    | 10:30             | 10:40     | 00:10    | TRIPPED ON FAULT    |
| 6032  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | ARAKALGUD_66      | 11:00             | 11:10     | 00:10    | TRIPPED ON FAULT    |
| 6033  | 19-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-SHMGA 2         | gen_bhadra        | 16:35             | 20:19     | 03:44    | LINE CLEAR AVAIED   |
| 6034  | 19-Sep-24 | HASSAN  | 66      | LINE        | DODDAMA-ARKALGUD       | DODDAMAGGE_66     | 10:25             | 10:35     | 00:10    | TRIPPED ON FAULT    |
| 6035  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | DODDAMAGGE_66     | 16:08             | 16:48     | 00:40    | LINE CLEAR AVAIED   |
| 6036  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | DODDAMAGGE_66     | 10:25             | 10:35     | 00:10    | MAIN SUPPLY FAILURE |
| 6037  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | DODDAMAGGE_66     | 10:25             | 10:35     | 00:10    | MAIN SUPPLY FAILURE |
| 6038  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | HALLIMYSORE_66    | 08:39             | 12:58     | 04:19    | LINE CLEAR AVAIED   |
| 6039  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                    | HALLIMYSORE_66    | 08:39             | 12:58     | 04:19    | LINE CLEAR AVAIED   |
| 6040  | 19-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                    | SINGAPURA_66      | 12:40             | 13:30     | 00:50    | LINE CLEAR AVAIED   |
| 6041  | 19-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-MYSOR1           | HNPURA_220        | 12:49             | 14:06     | 01:17    | LINE CLEAR AVAIED   |
| 6042  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV4                    | KAVOOR_220        | 19:05(19.09.2024) |           |          | LINE CLEAR AVAIED   |
| 6043  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                    | BANAVARA_110      | 12:30             | 12:51     | 00:21    | TRIPPED ON FAULT    |
| 6044  | 20-Sep-24 | HASSAN  | 110     | LINE        | GURUVA-KEMAR2          | GURUVAYANKERE_110 | 09:13             | 18:27     | 09:14    | LINE CLEAR AVAIED   |
| 6045  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV5                    | KAVOOR_220        | 08:00             | 08:50     | 00:50    | LINE CLEAR AVAIED   |
| 6046  | 20-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-KLSKR2          | KAVOOR_220        | 10:10             | 16:17     | 06:07    | LINE CLEAR AVAIED   |
| 6047  | 20-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-BEJAI           | KAVOOR_220        | 10:07             | 15:58     | 05:51    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                | Station_Name         | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|---------------------|----------------------|---------|-----------|----------|---------------------|
| 6048  | 20-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTUR2        | KEMAR_220            | 10:44   | 18:26     | 07:42    | LINE CLEAR AVAIED   |
| 6049  | 20-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Guruvykere2   | KEMAR_220            | 09:13   | 18:27     | 09:14    | LINE CLEAR AVAIED   |
| 6050  | 20-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-BELMAN        | KEMAR_220            | 14:38   | 19:05     | 04:27    | LINE CLEAR AVAIED   |
| 6051  | 20-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR2    | KEMAR_220            | 13:37   | 15:23     | 01:46    | LINE CLEAR AVAIED   |
| 6052  | 20-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-SS2          | MRSMSG_220           | 10:01   | 13:25     | 03:24    | LINE CLEAR AVAIED   |
| 6053  | 20-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-SS1          | MRSMSG_220           | 13:35   | 14:35     | 01:00    | LINE CLEAR AVAIED   |
| 6054  | 20-Sep-24 | HASSAN  | 220     | LINE        | PUTTUR-KEMAR2       | PUTTUR_220           | 10:44   | 18:26     | 07:42    | LINE CLEAR AVAIED   |
| 6055  | 20-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA3    | gen_sharavathy       | 10:49   | 16:41     | 05:52    | LINE CLEAR AVAIED   |
| 6056  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | GAJNUR_110           | 10:25   | 11:47     | 01:22    | LINE CLEAR AVAIED   |
| 6057  | 20-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                 | SHIRALKOPPA_220      | 12:24   | 12:34     | 00:10    | LINE CLEAR AVAIED   |
| 6058  | 20-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                 | SHIRALKOPPA_220      | 12:24   | 12:34     | 00:10    | LINE CLEAR AVAIED   |
| 6059  | 20-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                 | SHIRALKOPPA_220      | 12:24   | 16:30     | 04:06    | LINE CLEAR AVAIED   |
| 6060  | 20-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-BARANG       | SHIRALKOPPA_220      | 12:24   | 12:34     | 00:10    | LINE CLEAR AVAIED   |
| 6061  | 20-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220      | 12:24   | 13:35     | 01:11    | LINE CLEAR AVAIED   |
| 6062  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                 | SHIRALKOPPA_220      | 12:24   | 12:34     | 00:10    | LINE CLEAR AVAIED   |
| 6063  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                 | SHIRALKOPPA_220      | 12:24   | 12:34     | 00:10    | LINE CLEAR AVAIED   |
| 6064  | 20-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIKARIPURA  | SHIRALKOPPA_220      | 12:24   | 13:35     | 01:11    | LINE CLEAR AVAIED   |
| 6065  | 20-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIRALKOPPA  | SHIRALKOPPA_220      | 12:24   | 13:35     | 01:11    | LINE CLEAR AVAIED   |
| 6066  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | SHIRALKOPPA_220      | 12:24   | 13:35     | 01:11    | LINE CLEAR AVAIED   |
| 6067  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | SHIRALKOPPA_220      | 12:24   | 13:35     | 01:11    | LINE CLEAR AVAIED   |
| 6068  | 20-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KAVOOR 2     | KULASHEKARA_110      | 10:08   | 16:18     | 06:10    | LINE CLEAR AVAIED   |
| 6069  | 20-Sep-24 | HASSAN  | 110     | LINE        | KULASH-KERKNJ       | KULASHEKARA_110      | 10:08   | 16:18     | 06:10    | LINE CLEAR AVAIED   |
| 6070  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | NANDIKUR_110         | 14:02   | 15:24     | 01:22    | MAIN SUPPLY FAILURE |
| 6071  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | NANDIKUR_110         | 14:02   | 15:24     | 01:22    | MAIN SUPPLY FAILURE |
| 6072  | 20-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-ISTR        | NANDIKUR_110         | 14:02   | 15:27     | 01:25    | MAIN SUPPLY FAILURE |
| 6073  | 20-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-BELMAN      | NANDIKUR_110         | 10:47   | 12:53     | 02:06    | LINE CLEAR AVAIED   |
| 6074  | 20-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR1      | NANDIKUR_110         | 14:02   | 15:27     | 01:25    | MAIN SUPPLY FAILURE |
| 6075  | 20-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR2      | NANDIKUR_110         | 13:35   | 15:23     | 01:48    | LINE CLEAR AVAIED   |
| 6076  | 20-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-NDKR-SUZLON | NANDIKUR_110         | 14:02   | 15:27     | 01:25    | MAIN SUPPLY FAILURE |
| 6077  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | NITTUR_110           | 10:00   | 14:07     | 04:07    | LINE CLEAR AVAIED   |
| 6078  | 20-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | NITTUR_110           | 14:46   | 16:19     | 01:33    | LINE CLEAR AVAIED   |
| 6079  | 20-Sep-24 | HASSAN  | 110     | LINE        | SORABA-SHR220       | SORABA_110           | 12:25   | 12:50     | 00:25    | TRIPPED ON FAULT    |
| 6080  | 20-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-RAMAPUR      | BAGUR_66             | 07:06   | 07:09     | 00:03    | TRIPPED ON FAULT    |
| 6081  | 20-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-SHMG2        | gen_bhadra           | 13:20   | 17:07     | 03:47    | LINE CLEAR AVAIED   |
| 6082  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV                  | CHIKABOMMENAHALLI_66 | 10:00   | 10:10     | 00:10    | TRIPPED ON FAULT    |
| 6083  | 20-Sep-24 | HASSAN  | 66      | LINE        | DODDAKA-HNPURA      | DODDAKADANUR_66      | 13:08   | 15:15     | 02:07    | TRIPPED ON FAULT    |
| 6084  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DODDAKADANUR_66      | 13:08   | 15:15     | 02:07    | TRIPPED ON FAULT    |
| 6085  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | DODDAMAGGE_66        | 09:55   | 10:00     | 00:05    | TRIPPED ON FAULT    |
| 6086  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | DUDDA_66             | 09:02   | 09:08     | 00:06    | TRIPPED ON FAULT    |
| 6087  | 20-Sep-24 | HASSAN  | 66      | LINE        | HNPUR2-HASS2        | HNPURA_220           | 12:00   | 12:30     | 00:30    | TRIPPED ON FAULT    |
| 6088  | 20-Sep-24 | HASSAN  | 66      | LINE        | HNPUR2-HNPUR1       | HNPURA_220           | 06:10   | 06:21     | 00:11    | TRIPPED ON FAULT    |
| 6089  | 20-Sep-24 | HASSAN  | 66      | LINE        | HNPURA-SOMANAHALLI  | HNPURA_66            | 06:10   | 06:36     | 00:26    | TRIPPED ON FAULT    |
| 6090  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | KANDLI_66            | 10:00   | 17:02     | 07:02    | LINE CLEAR AVAIED   |
| 6091  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | KANDLI_66            | 10:00   | 17:02     | 07:02    | LINE CLEAR AVAIED   |
| 6092  | 20-Sep-24 | HASSAN  | 66      | LINE        | MALALI-CRPATNA      | MALALI_66            | 12:00   | 12:30     | 00:30    | MAIN SUPPLY FAILURE |
| 6093  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | MALALI_66            | 12:00   | 12:30     | 00:30    | MAIN SUPPLY FAILURE |
| 6094  | 20-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                 | RAMPURA_66           | 10:17   | 12:24     | 02:07    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                  | Station_Name    | Open_At           | Closed_At         | Duration  | REMARKS           |
|-------|-----------|---------|---------|-------------|-----------------------|-----------------|-------------------|-------------------|-----------|-------------------|
| 6095  | 20-Sep-24 | HASSAN  | 66      | LINE        | SHANTHI-RMSWRNGR      | SHANTHIGRAMA_66 | 10:05             | 15:45             | 05:40     | LINE CLEAR AVAIED |
| 6096  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV4                   | KAVOOR_220      | 19:05(19.09.2024) | 18:37(21.09.2024) | 47:31 hrs | LINE CLEAR AVAIED |
| 6097  | 21-Sep-24 | HASSAN  | 110     | LINE        | LPH-MGHE 2            | gen_lph         | 10:22             | 13:35             | 03:13     | TRIPPED ON FAULT  |
| 6098  | 21-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-HNPUR21       | GOPALAPURA_220  | 10:25             | 12:00             | 01:35     | LINE CLEAR AVAIED |
| 6099  | 21-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-HNPUR22       | GOPALAPURA_220  | 12:15             | 13:49             | 01:34     | LINE CLEAR AVAIED |
| 6100  | 21-Sep-24 | HASSAN  | 220     | LINE        | HGUNJE-VRHI           | HEGGUNJE_220    | 13:31             | 14:57             | 01:26     | LINE CLEAR AVAIED |
| 6101  | 21-Sep-24 | HASSAN  | 220     | LINE        | HNPR2-GPLPR1          | HNPURA_220      | 10:25             | 12:00             | 01:35     | LINE CLEAR AVAIED |
| 6102  | 21-Sep-24 | HASSAN  | 220     | LINE        | HNPR2-GPLPR2          | HNPURA_220      | 12:15             | 13:49             | 01:34     | LINE CLEAR AVAIED |
| 6103  | 21-Sep-24 | HASSAN  | 220     | LINE        | PUTTUR-KEMAR2         | PUTTUR_220      | 10:28             | 18:50             | 08:22     | LINE CLEAR AVAIED |
| 6104  | 21-Sep-24 | HASSAN  | 220     | LINE        | KADUR-DABUSET         | KADUR_220       | 10:00             | 18:52             | 08:52     | LINE CLEAR AVAIED |
| 6105  | 21-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA1      | gen_sharavathy  | 11:12             | 11:41             | 00:29     | TRIPPED ON FAULT  |
| 6106  | 21-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA3      | gen_sharavathy  | 02:24             | 12:17             | 09:53     | TRIPPED ON FAULT  |
| 6107  | 21-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1       | gen_varahi      | 14:44             | 15:01             | 00:17     | TRIPPED ON FAULT  |
| 6108  | 21-Sep-24 | HASSAN  | 110     | LINE        | KADUR-AJAMPURA        | KADUR_220       | 10:12             | 16:10             | 05:58     | LINE CLEAR AVAIED |
| 6109  | 21-Sep-24 | HASSAN  | 110     | LINE        | KADUR-NERLEKERE       | KADUR_220       | 10:00             | 16:50             | 06:50     | LINE CLEAR AVAIED |
| 6110  | 21-Sep-24 | HASSAN  | 110     | LINE        | KADUR--TNGL           | KADUR_220       | 13:30             | 14:30             | 01:00     | LINE CLEAR AVAIED |
| 6111  | 21-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTUR2          | KEMAR_220       | 10:26             | 18:50             | 08:24     | LINE CLEAR AVAIED |
| 6112  | 21-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Guruvykere2     | KEMAR_220       | 10:35             | 18:52             | 08:17     | LINE CLEAR AVAIED |
| 6113  | 21-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR2      | KEMAR_220       | 10:36             | 11:31             | 00:55     | LINE CLEAR AVAIED |
| 6114  | 21-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-SHARAVATHY3    | MRSMSG_220      | 02:24             | 12:17             | 09:53     | TRIPPED ON FAULT  |
| 6115  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV5                   | MRSMSG_220      | 09:55             | 17:50             | 07:55     | LINE CLEAR AVAIED |
| 6116  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                   | AJJAMPURA_110   | 10:34             | 18:26             | 07:52     | LINE CLEAR AVAIED |
| 6117  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                   | AJJAMPURA_110   | 10:34             | 18:26             | 07:52     | LINE CLEAR AVAIED |
| 6118  | 21-Sep-24 | HASSAN  | 110     | LINE        | AJAMPU-SHIVANI        | AJJAMPURA_110   | 10:17             | 16:40             | 06:23     | LINE CLEAR AVAIED |
| 6119  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                   | BIRUR_110       | 10:01             | 17:37             | 07:36     | LINE CLEAR AVAIED |
| 6120  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                   | BIRUR_110       | 10:01             | 17:38             | 07:37     | LINE CLEAR AVAIED |
| 6121  | 21-Sep-24 | HASSAN  | 110     | LINE        | ANANDA-SHIMOGA        | ANANDAPURA_110  | 10:01             | 12:55             | 02:54     | LINE CLEAR AVAIED |
| 6122  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                   | GAJNUR_110      | 10:03             | 15:14             | 05:11     | LINE CLEAR AVAIED |
| 6123  | 21-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR2        | NANDIKUR_110    | 10:36             | 11:31             | 00:55     | LINE CLEAR AVAIED |
| 6124  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                   | SHIRALKOPPA_110 | 10:10             | 19:00             | 08:50     | LINE CLEAR AVAIED |
| 6125  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                   | SHIRALKOPPA_110 | 10:15             | 19:00             | 08:45     | LINE CLEAR AVAIED |
| 6126  | 21-Sep-24 | HASSAN  | 110     | LINE        | SHIRAL-SHKARPURA      | SHIRALKOPPA_110 | 10:15             | 19:00             | 08:45     | LINE CLEAR AVAIED |
| 6127  | 21-Sep-24 | HASSAN  | 110     | LINE        | SHIVAPU-BIRUR         | SHIVAPURA_110   | 10:02             | 18:12             | 08:10     | LINE CLEAR AVAIED |
| 6128  | 21-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                   | SHIVAPURA_110   | 10:02             | 18:12             | 08:10     | LINE CLEAR AVAIED |
| 6129  | 21-Sep-24 | HASSAN  | 110     | LINE        | SHIVAPU-NERLEKERE     | SHIVAPURA_110   | 10:02             | 18:12             | 08:10     | LINE CLEAR AVAIED |
| 6130  | 21-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIRALKOPPA    | SHIRALKOPPA_220 | 10:28             | 18:45             | 08:17     | LINE CLEAR AVAIED |
| 6131  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                   | BALLUPETE_66    | 10:00             | 17:00             | 07:00     | LINE CLEAR AVAIED |
| 6132  | 21-Sep-24 | HASSAN  | 66      | LINE        | BALLUPE-KANDLI        | BALLUPETE_66    | 11:15             | 13:50             | 02:35     | LINE CLEAR AVAIED |
| 6133  | 21-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-LINGADAHALLI   | gen_bhadra      | 10:04             | 18:14             | 08:10     | LINE CLEAR AVAIED |
| 6134  | 21-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-SHMGA 2        | gen_bhadra      | 10:53             | 20:23             | 09:30     | LINE CLEAR AVAIED |
| 6135  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                   | DODDAKADNUR_66  | 15:10             | 17:35             | 02:25     | LINE CLEAR AVAIED |
| 6136  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                   | HANGARAHALLY_55 | 15:35             | 15:51             | 00:16     | TRIPPED ON FAULT  |
| 6137  | 21-Sep-24 | HASSAN  | 66      | LINE        | HIREMAN-CHIKAMANGALUR | HIREMANGLUR_66  | 10:34             | 13:30             | 02:56     | LINE CLEAR AVAIED |
| 6138  | 21-Sep-24 | HASSAN  | 66      | LINE        | KANDLI-SAKLESHPUR     | KANDLI_66       | 11:25             | 11:30             | 00:05     | LINE CLEAR AVAIED |
| 6139  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                   | MAGGE_66        | 10:08             | 14:32             | 04:24     | LINE CLEAR AVAIED |
| 6140  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                   | RAMPURA_66      | 17:01             | 21:17             | 04:16     | LINE CLEAR AVAIED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                    | Station_Name         | Open_At           | Closed_At         | Duration  | REMARKS            |
|-------|-----------|---------|---------|-------------|-------------------------|----------------------|-------------------|-------------------|-----------|--------------------|
| 6141  | 21-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-SKPURA1         | HASSAN_220           | 11:19             | 13:52             | 02:33     | LINE CLEAR AVAILED |
| 6142  | 21-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-HASSAN           | SAKALESHPURA_66      | 11:13             | 13:55             | 02:42     | LINE CLEAR AVAILED |
| 6143  | 21-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-HASSAN1          | SAKALESHPURA_66      | 11:13             | 13:55             | 02:42     | LINE CLEAR AVAILED |
| 6144  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | SAKALESHPURA_66      | 10:00             | 17:15             | 07:15     | LINE CLEAR AVAILED |
| 6145  | 21-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | SAKALESHPURA_66      | 10:00             | 17:15             | 07:15     | LINE CLEAR AVAILED |
| 6146  | 21-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-IPCL1            | SAKALESHPURA_66      | 11:12             | 13:56             | 02:44     | LINE CLEAR AVAILED |
| 6147  | 21-Sep-24 | HASSAN  | 66      | LINE        | SAKALE-IPCL2            | SAKALESHPURA_66      | 11:12             | 13:56             | 02:44     | LINE CLEAR AVAILED |
| 6148  | 22-Sep-24 | HASSAN  | 220     | LINE        | KADUR-DABUSET           | KADUR_220            | 10:45             | 18:25             | 07:40     | LINE CLEAR AVAILED |
| 6149  | 22-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-ALAGUPPA1       | gen_sharavaty        | 21:51(22.09.2024) |                   |           | TRIPPED ON FAULT   |
| 6150  | 22-Sep-24 | HASSAN  | 220     | LINE        | TALAGU-SGS1             | TALAGUPPA_400        | 21:51(22.09.2024) |                   |           | TRIPPED ON FAULT   |
| 6151  | 22-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | ANAVATTI_110         | 10:01             | 18:07             | 08:06     | LINE CLEAR AVAILED |
| 6152  | 22-Sep-24 | HASSAN  | 110     | LINE        | KMS110-MRS-ANDPR        | KUMSI_110            | 10:01             | 12:55             | 02:54     | LINE CLEAR AVAILED |
| 6153  | 22-Sep-24 | HASSAN  | 110     | LINE        | KMS110-MRS-ANDPR        | KUMSI_110            | 10:01             | 18:05             | 08:04     | LINE CLEAR AVAILED |
| 6154  | 22-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | KAVOOR_220           | 09:25             | 12:46             | 03:21     | LINE CLEAR AVAILED |
| 6155  | 22-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-AMR              | KAVOOR_220           | 00:44             | 11:04             | 10:20     | TRIPPED ON FAULT   |
| 6156  | 22-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | NANDIKUR_110         | 10:49             | 10:57             | 00:08     | TRIPPED ON FAULT   |
| 6157  | 22-Sep-24 | HASSAN  | 110     | LINE        | SHKARPURA               | SHIRALKoppa_110      | 10:25             | 18:40             | 08:15     | LINE CLEAR AVAILED |
| 6158  | 22-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV4                     | BALEHONNUR_66        | 15:31             | 15:43             | 00:12     | TRIPPED ON FAULT   |
| 6159  | 22-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONALI          | TAVARECHATNAHALLI_66 | 04:05             | 04:35             | 00:30     | TRIPPED ON FAULT   |
| 6160  | 23-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-VARAH12          | MRSMG_220            | 11:30             | 12:33             | 01:03     | LINE CLEAR AVAILED |
| 6161  | 23-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-TALAGUPPA1      | gen_sharavathy       | 21:51(22.09.2024) | 12:19(23.09.2024) | 14:27 hrs | LINE CLEAR AVAILED |
| 6162  | 23-Sep-24 | HASSAN  | 220     | LINE        | TALAGU-SGS1             | TALAGUPPA_400        | 21:51(22.09.2024) | 12:19(23.09.2024) | 14:27 hrs | LINE CLEAR AVAILED |
| 6163  | 23-Sep-24 | HASSAN  | 220     | LINE        | VARAH1-SHIMOGA2         | gen_varahi           | 11:30             | 12:33             | 01:03     | LINE CLEAR AVAILED |
| 6164  | 23-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-GSS32              | MSEZ_220             | 09:06             | 13:14             | 04:08     | LINE CLEAR AVAILED |
| 6165  | 23-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | ARASIKERE_110        | 16:48             | 21:13             | 04:25     | TRIPPED ON FAULT   |
| 6166  | 23-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | ARASIKERE_110        | 16:48             | 17:07             | 00:19     | TRIPPED ON FAULT   |
| 6167  | 23-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | KAVOOR_220           | 10:24             | 10:40             | 00:16     | LINE CLEAR AVAILED |
| 6168  | 23-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                     | KEMAR_220            | 12:37             | 12:40             | 00:03     | TRIPPED ON FAULT   |
| 6169  | 23-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                     | KEMAR_220            | 12:37             | 12:40             | 00:03     | TRIPPED ON FAULT   |
| 6170  | 23-Sep-24 | HASSAN  | 110     | LINE        | KUNDAPURA               | MADHUVANAHALLI_110   | 01:15             | 05:44             | 04:29     | TRIPPED ON FAULT   |
| 6171  | 23-Sep-24 | HASSAN  | 66      | LINE        | CHMANGA-MANGALORE1      | CHIKMANGALORE_220    | 10:40             | 16:35             | 05:55     | LINE CLEAR AVAILED |
| 6172  | 23-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | DUDDA_66             | 12:05             | 13:25             | 01:20     | LINE CLEAR AVAILED |
| 6173  | 23-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | GORUR_66             | 11:22             | 12:22             | 01:00     | LINE CLEAR AVAILED |
| 6174  | 23-Sep-24 | HASSAN  | 66      | LINE        | HNPURA2-MYSOR1          | HNPURA_220           | 05:41             | 05:51             | 00:10     | TRIPPED ON FAULT   |
| 6175  | 23-Sep-24 | HASSAN  | 66      | LINE        | LINGADAHALL-BADRA       | LINGADAHALLI_66      | 10:00             | 17:27             | 07:27     | LINE CLEAR AVAILED |
| 6176  | 23-Sep-24 | HASSAN  | 66      | LINE        | LINGADAHALL-CHIKMAGALUR | LINGADAHALLI_66      | 10:00             | 17:27             | 07:27     | LINE CLEAR AVAILED |
| 6177  | 23-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | LINGADAHALLI_66      | 10:00             | 17:27             | 07:27     | LINE CLEAR AVAILED |
| 6178  | 23-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | LINGADAHALLI_66      | 10:00             | 17:27             | 07:27     | LINE CLEAR AVAILED |
| 6179  | 23-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAGE-KDLGRE         | SIGEBAGE_66          | 23:40             | 23:58             | 00:18     | TRIPPED ON FAULT   |
| 6180  | 24-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                     | HASSAN_220           | 11:15             | 13:50             | 02:35     | LINE CLEAR AVAILED |
| 6181  | 24-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                     | HEGGUNJE_220         | 12:14             | 13:07             | 00:53     | LINE CLEAR AVAILED |
| 6182  | 24-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-KEMR2            | KAVOOR_220           | 10:03             | 15:56             | 05:53     | LINE CLEAR AVAILED |
| 6183  | 24-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                     | KEMAR_220            | 11:56             | 13:16             | 01:20     | LINE CLEAR AVAILED |
| 6184  | 24-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTUR2            | KEMAR_220            | 09:48             | 11:54             | 02:06     | LINE CLEAR AVAILED |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line               | Station_Name         | Open_At | Closed_At | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|--------------------|----------------------|---------|-----------|----------|---------------------|
| 6185  | 24-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Guruvykere2  | KEMAR_220            | 09:48   | 14:38     | 04:50    | LINE CLEAR AVAILED  |
| 6186  | 24-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-MOODABIDRE   | KEMAR_220            | 12:25   | 17:09     | 04:44    | LINE CLEAR AVAILED  |
| 6187  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | KEMAR_220            | 11:40   | 17:20     | 05:40    | LINE CLEAR AVAILED  |
| 6188  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV3                | KEMAR_220            | 11:55   | 13:16     | 01:21    | LINE CLEAR AVAILED  |
| 6189  | 24-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1   | KEMAR_220            | 11:16   | 11:17     | 00:01    | LINE CLEAR AVAILED  |
| 6190  | 24-Sep-24 | HASSAN  | 220     | LINE        | MSEZ-KAVOOR2       | MSEZ_220             | 10:03   | 15:56     | 05:53    | LINE CLEAR AVAILED  |
| 6191  | 24-Sep-24 | HASSAN  | 220     | LINE        | KEMAR2             | PUTTUR_220           | 09:48   | 11:54     | 02:06    | LINE CLEAR AVAILED  |
| 6192  | 24-Sep-24 | HASSAN  | 110     | LINE        | MDBDRE             | GURUPURA_110         | 10:08   | 13:25     | 03:17    | LINE CLEAR AVAILED  |
| 6193  | 24-Sep-24 | HASSAN  | 110     | LINE        | KEMAR2             | GURUVAYANKERE_110    | 09:48   | 14:38     | 04:50    | LINE CLEAR AVAILED  |
| 6194  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | HEGGUNJE_220         | 10:51   | 12:06     | 01:15    | LINE CLEAR AVAILED  |
| 6195  | 24-Sep-24 | HASSAN  | 110     | LINE        | HIRIYADKA          | HEGGUNJE_220         | 10:04   | 18:02     | 07:58    | LINE CLEAR AVAILED  |
| 6196  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                | HEGGUNJE_220         | 12:14   | 13:07     | 00:53    | LINE CLEAR AVAILED  |
| 6197  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | HOSANGADI_110        | 10:37   | 12:16     | 01:39    | LINE CLEAR AVAILED  |
| 6198  | 24-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV3                | KADUR_220            | 13:17   | 13:28     | 00:11    | TRIPPED ON FAULT    |
| 6199  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | KUMSI_110            | 10:58   | 13:03     | 02:05    | LINE CLEAR AVAILED  |
| 6200  | 24-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-HIRIYADKA   | MANIPAL              | 10:01   | 18:12     | 08:11    | LINE CLEAR AVAILED  |
| 6201  | 24-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-GURUPURA    | MOODABIDRE_110       | 10:08   | 13:20     | 03:12    | LINE CLEAR AVAILED  |
| 6202  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | MOODABIDRE_110       | 09:53   | 15:02     | 05:09    | LINE CLEAR AVAILED  |
| 6203  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | MOODABIDRE_110       | 09:53   | 17:11     | 07:18    | LINE CLEAR AVAILED  |
| 6204  | 24-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-KEMAR       | MOODABIDRE_110       | 12:20   | 17:09     | 04:49    | LINE CLEAR AVAILED  |
| 6205  | 24-Sep-24 | HASSAN  | 110     | LINE        | MOODAB-SOHAM2      | MOODABIDRE_110       | 12:20   | 13:28     | 01:08    | LINE CLEAR AVAILED  |
| 6206  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                | PUTTUR_110           | 09:25   | 13:06     | 03:41    | LINE CLEAR AVAILED  |
| 6207  | 24-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                | PUTTUR_110           | 09:25   | 13:06     | 03:41    | LINE CLEAR AVAILED  |
| 6208  | 24-Sep-24 | HASSAN  | 66      | LINE        | ALDUR-BALEHONNUR   | ALDUR_66             | 10:33   | 17:59     | 07:26    | LINE CLEAR AVAILED  |
| 6209  | 24-Sep-24 | HASSAN  | 66      | LINE        | ALDUR-CHIKKAMAGLUR | ALDUR_66             | 10:33   | 18:03     | 07:30    | LINE CLEAR AVAILED  |
| 6210  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | ALDUR_66             | 10:33   | 17:59     | 07:26    | LINE CLEAR AVAILED  |
| 6211  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | HOLALUR_66           | 09:50   | 18:35     | 08:45    | LINE CLEAR AVAILED  |
| 6212  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                | HOLALUR_66           | 09:50   | 17:42     | 07:52    | LINE CLEAR AVAILED  |
| 6213  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | HOLEHONNUR_66        | 09:56   | 18:06     | 08:10    | LINE CLEAR AVAILED  |
| 6214  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                | HOLEHONNUR_66        | 09:55   | 18:06     | 08:11    | LINE CLEAR AVAILED  |
| 6215  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | KALASAPURA_66        | 10:09   | 18:22     | 08:13    | LINE CLEAR AVAILED  |
| 6216  | 24-Sep-24 | HASSAN  | 66      | LINE        | KALASAP-UDDRKPL    | KALASAPURA_66        | 10:09   | 18:22     | 08:13    | LINE CLEAR AVAILED  |
| 6217  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | TAVARECHATNAHALLI_66 | 10:00   | 17:30     | 07:30    | LINE CLEAR AVAILED  |
| 6218  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                | TAVARECHATNAHALLI_66 | 10:00   | 17:30     | 07:30    | LINE CLEAR AVAILED  |
| 6219  | 24-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONNALLI   | TAVARECHATNAHALLI_66 | 09:55   | 17:30     | 07:35    | LINE CLEAR AVAILED  |
| 6220  | 24-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-MRS        | TAVARECHATNAHALLI_66 | 09:55   | 17:30     | 07:35    | MAIN SUPPLY FAILURE |
| 6221  | 24-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-HOLUR       | MRSMSG_220           | 09:48   | 15:25     | 05:37    | LINE CLEAR AVAILED  |
| 6222  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                | CRPATNA_220          | 14:44   | 15:39     | 00:55    | LINE CLEAR AVAILED  |
| 6223  | 24-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-BELUR      | HASSAN_220           | 11:06   | 13:51     | 02:45    | LINE CLEAR AVAILED  |
| 6224  | 24-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-HN PURA    | HASSAN_220           | 11:06   | 16:03     | 04:57    | LINE CLEAR AVAILED  |
| 6225  | 24-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-HSN66      | HASSAN_220           | 11:01   | 11:05     | 00:04    | LINE CLEAR AVAILED  |
| 6226  | 24-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV2                | HASSAN_220           | 11:15   | 13:50     | 02:35    | LINE CLEAR AVAILED  |
| 6227  | 24-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-UDDURKOPLU | HASSAN_220           | 11:06   | 11:09     | 00:03    | LINE CLEAR AVAILED  |
| 6228  | 24-Sep-24 | HASSAN  | 66      | LINE        | HASSN22-UDDURKOPLU | HASSAN_220           | 13:46   | 13:51     | 00:05    | LINE CLEAR AVAILED  |
| 6229  | 25-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-Kavoor2      | KEMAR_220            | 15:31   | 19:02     | 03:31    | LINE CLEAR AVAILED  |
| 6230  | 25-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTUR2       | KEMAR_220            | 10:48   | 19:40     | 08:52    | LINE CLEAR AVAILED  |
| 6231  | 25-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                | MRSMSG_220           | 09:10   | 14:35     | 05:25    | LINE CLEAR AVAILED  |



| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                 | Station_Name      | Open_At           | Closed_At | Duration | REMARKS           |
|-------|-----------|---------|---------|-------------|----------------------|-------------------|-------------------|-----------|----------|-------------------|
| 6232  | 25-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                  | MSEZ_220          | 11:06             | 12:12     | 01:06    | TRIPPED ON FAULT  |
| 6233  | 25-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | MSEZ_220          | 11:06             | 12:12     | 01:06    | TRIPPED ON FAULT  |
| 6234  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                  | MSEZ_220          | 11:06             | 12:12     | 01:06    | TRIPPED ON FAULT  |
| 6235  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                  | MSEZ_220          | 11:06             | 12:12     | 01:06    | TRIPPED ON FAULT  |
| 6236  | 25-Sep-24 | HASSAN  | 220     | LINE        | MSEZ-KEMAR2          | MSEZ_220          | 15:31             | 19:02     | 03:31    | LINE CLEAR AVAIED |
| 6237  | 25-Sep-24 | HASSAN  | 220     | LINE        | PUTTUR-KEMAR2        | PUTTUR_220        | 10:48             | 19:40     | 08:52    | LINE CLEAR AVAIED |
| 6238  | 25-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-PUTTR2         | KEMAR_220         | 10:48             | 19:40     | 08:52    | LINE CLEAR AVAIED |
| 6239  | 25-Sep-24 | HASSAN  | 220     | LINE        | KEMAR-KAVR2          | KEMAR_220         | 15:30             | 19:02     | 03:32    | LINE CLEAR AVAIED |
| 6240  | 25-Sep-24 | HASSAN  | 110     | LINE        | BANTWA-SALATTUR      | BANTWALA_110      | 10:52             | 17:15     | 06:23    | LINE CLEAR AVAIED |
| 6241  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV6                  | KAVOOR_220        | 10:02             | 15:10     | 05:08    | LINE CLEAR AVAIED |
| 6242  | 25-Sep-24 | HASSAN  | 110     | LINE        | GURUVA-KEMAR2        | GURUVAYANKERE_110 | 10:45             | 19:37     | 08:52    | LINE CLEAR AVAIED |
| 6243  | 25-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Guruvykere2    | KEMAR_220         | 10:45             | 19:37     | 08:52    | LINE CLEAR AVAIED |
| 6244  | 25-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR2     | KEMAR_220         | 10:35             | 13:47     | 03:12    | LINE CLEAR AVAIED |
| 6245  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                  | KONAJE_110        | 10:02             | 13:00     | 02:58    | LINE CLEAR AVAIED |
| 6246  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | KONAJE_110        | 12:32             | 13:59     | 01:27    | LINE CLEAR AVAIED |
| 6247  | 25-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-BRAMVR       | MANIPAL_110       | 18:01             | 18:03     | 00:02    | LINE CLEAR AVAIED |
| 6248  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                  | MANIPAL_110       | 09:42             | 18:01     | 08:19    | LINE CLEAR AVAIED |
| 6249  | 25-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-KEMAR1       | MANIPAL_110       | 18:01             | 18:03     | 00:02    | LINE CLEAR AVAIED |
| 6250  | 25-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-KEMAR2       | MANIPAL_110       | 18:01             | 18:03     | 00:02    | LINE CLEAR AVAIED |
| 6251  | 25-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-RAILWY TRCTN    | MSEZ_220          | 11:06             | 12:26     | 01:20    | LINE CLEAR AVAIED |
| 6252  | 25-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-BAIKAMPADY      | MSEZ_220          | 11:00             | 12:27     | 01:27    | LINE CLEAR AVAIED |
| 6253  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                  | MSEZ_220          | 06:19             | 06:33     | 00:14    | TRIPPED ON FAULT  |
| 6254  | 25-Sep-24 | HASSAN  | 110     | LINE        | MSEZ-KAVOOR          | MSEZ_220          | 13:11             | 13:56     | 00:45    | TRIPPED ON FAULT  |
| 6255  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                  | PUTTUR_220        | 00:47             | 00:52     | 00:05    | TRIPPED ON FAULT  |
| 6256  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | SHIRALKOPPA_110   | 18:25             | 18:40     | 00:15    | LINE CLEAR AVAIED |
| 6257  | 25-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | SHIRALKOPPA_110   | 18:50             | 19:15     | 00:25    | LINE CLEAR AVAIED |
| 6258  | 25-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR2       | NANDIKU_110       | 10:35             | 13:47     | 03:12    | LINE CLEAR AVAIED |
| 6259  | 25-Sep-24 | HASSAN  | 66      | LINE        | BHADRA-SHMGA 1       | gen_bhadra        | 08:35             | 09:32     | 00:57    | TRIPPED ON FAULT  |
| 6260  | 25-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | DUDDA_66          | 16:05             | 16:25     | 00:20    | LINE CLEAR AVAIED |
| 6261  | 25-Sep-24 | HASSAN  | 66      | LINE        | HASSN220-HSN66       | HASSAN_220        | 09:53             | 17:40     | 07:47    | LINE CLEAR AVAIED |
| 6262  | 25-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                  | HASSAN_66         | 09:39             | 17:41     | 08:02    | LINE CLEAR AVAIED |
| 6263  | 25-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                  | HASSAN_66         | 09:39             | 17:41     | 08:02    | LINE CLEAR AVAIED |
| 6264  | 25-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1 CB               | MNJUNATHPURA_66   | 10:36             | 15:07     | 04:31    | LINE CLEAR AVAIED |
| 6265  | 25-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2 CB               | MNJUNATHPURA_66   | 10:36             | 15:07     | 04:31    | LINE CLEAR AVAIED |
| 6266  | 25-Sep-24 | HASSAN  | 66      | LINE        | L1 CB                | MNJUNATHPURA_66   | 10:36             | 15:07     | 04:31    | LINE CLEAR AVAIED |
| 6267  | 25-Sep-24 | HASSAN  | 66      | LINE        | L2 CB                | MNJUNATHPURA_66   | 10:36             | 15:07     | 04:31    | LINE CLEAR AVAIED |
| 6268  | 26-Sep-24 | HASSAN  | 400     | LINE        | TALAGU-HSN400#1      | TALAGUPPA_400     | 12:10             | 14:49     | 02:39    | TRIPPED ON FAULT  |
| 6269  | 26-Sep-24 | HASSAN  | 400     | LINE        | TALAGU-NELAMANGALA#2 | TALAGUPPA_400     | 12:02             | 15:45     | 03:43    | TRIPPED ON FAULT  |
| 6270  | 26-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | KADUR_220         | 10:31             | 13:45     | 03:14    | LINE CLEAR AVAIED |
| 6271  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                  | KADUR_220         | 10:31             | 13:45     | 03:14    | LINE CLEAR AVAIED |
| 6272  | 26-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV2                  | KEMAR_220         | 09:53             | 16:45     | 06:52    | LINE CLEAR AVAIED |
| 6273  | 26-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE     | MRSMSG_220        | 09:16             | 10:41     | 01:25    | LINE CLEAR AVAIED |
| 6274  | 26-Sep-24 | HASSAN  | 110     | LINE        | ESSUR-BELIGAVI       | ESSUR_110         | 10:06             | 18:40     | 08:34    | LINE CLEAR AVAIED |
| 6275  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                  | ESSUR_110         | 10:06             | 20:30     | 10:24    | LINE CLEAR AVAIED |
| 6276  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                  | ESSUR_110         | 10:06             | 18:40     | 08:34    | LINE CLEAR AVAIED |
| 6277  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                  | HOSANGADI_110     | 06:07             | 06:28     | 00:21    | TRIPPED ON FAULT  |
| 6278  | 26-Sep-24 | HASSAN  | 110     | LINE        | KAVOOR-KONAJE        | KAVOOR_220        | 20:05(26.09.2024) |           |          | TRIPPED ON FAULT  |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                | Station_Name         | Open_At           | Closed_At        | Duration | REMARKS             |
|-------|-----------|---------|---------|-------------|---------------------|----------------------|-------------------|------------------|----------|---------------------|
| 6279  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV7                 | KAVOOR_220           | 10:00             | 13:55            | 03:55    | LINE CLEAR AVAIED   |
| 6280  | 26-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-HIRIYADKA     | KEMAR_220            | 12:37             | 13:17            | 00:40    | LINE CLEAR AVAIED   |
| 6281  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                 | KEMAR_220            | 09:53             | 16:45            | 06:52    | LINE CLEAR AVAIED   |
| 6282  | 26-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR1    | KEMAR_220            | 12:19             | 13:21            | 01:02    | LINE CLEAR AVAIED   |
| 6283  | 26-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR2    | KEMAR_220            | 10:44             | 11:57            | 01:13    | LINE CLEAR AVAIED   |
| 6284  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | KONAJE_110           | 20:03             | 20:26            | 00:23    | MAIN SUPPLY FAILURE |
| 6285  | 26-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-JAPPU        | KONAJE_110           | 20:03(26.09.2024) |                  |          | MAIN SUPPLY FAILURE |
| 6286  | 26-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-NITTUR      | MANIPAL_110          | 10:02             | 14:01            | 03:59    | LINE CLEAR AVAIED   |
| 6287  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | MUTHINKOPPA_110      | 11:05             | 12:36            | 01:31    | LINE CLEAR AVAIED   |
| 6288  | 26-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR2      | NANDIKUR_110         | 10:44             | 11:57            | 01:13    | LINE CLEAR AVAIED   |
| 6289  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | NITTUR_110           | 10:02             | 13:22            | 03:20    | LINE CLEAR AVAIED   |
| 6290  | 26-Sep-24 | HASSAN  | 110     | LINE        | NITUR11-MANIPAL     | NITTUR_110           | 16:02             | 16:09            | 00:07    | LINE CLEAR AVAIED   |
| 6291  | 26-Sep-24 | HASSAN  | 110     | LINE        | NITUR11-MANIPAL     | NITTUR_110           | 18:01             | 18:04            | 00:03    | MAIN SUPPLY FAILURE |
| 6292  | 26-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | SHIRALKOPPA_110      | 08:20             | 08:50            | 00:30    | LINE CLEAR AVAIED   |
| 6293  | 26-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | HOLALUR_66           | 09:25             | 18:40            | 09:15    | LINE CLEAR AVAIED   |
| 6294  | 26-Sep-24 | HASSAN  | 66      | LINE        | MATTNAV-DIDGTHL     | MATTANAVILE_66       | 23:59             | 00:13            | 23:46    | TRIPPED ON FAULT    |
| 6295  | 26-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONALI      | TAVARECHATNAHALLI_66 | 23:35             | 23:57            | 00:22    | TRIPPED ON FAULT    |
| 6296  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | KEMAR_220            | 04:12             | 04:31            | 00:19    | TRIPPED ON FAULT    |
| 6297  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | PUTTUR_220           | 11:10             | 11:57            | 00:47    | LINE CLEAR AVAIED   |
| 6298  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV2                 | PUTTUR_220           | 11:10             | 11:57            | 00:47    | LINE CLEAR AVAIED   |
| 6299  | 27-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONNALI     | TAVARECHATNAHALLI_66 | 14:10             | 14:25            | 00:15    | TRIPPED ON FAULT    |
| 6300  | 27-Sep-24 | HASSAN  | 220     | TRANSFORMER | HV1                 | KADUR_220            | 11:09             | 17:04            | 05:55    | LINE CLEAR AVAIED   |
| 6301  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | LV1                 | KADUR_220            | 11:09             | 17:04            | 05:55    | LINE CLEAR AVAIED   |
| 6302  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | BARANGI_110          | 14:55             | 17:50            | 02:55    | LINE CLEAR AVAIED   |
| 6303  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | BARANGI_110          | 10:20             | 17:45            | 07:25    | LINE CLEAR AVAIED   |
| 6304  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | KITTADAHALLI_110     | 09:20             | 17:00            | 07:40    | LINE CLEAR AVAIED   |
| 6305  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | KITTADAHALLI_110     | 09:20             | 10:20            | 01:00    | LINE CLEAR AVAIED   |
| 6306  | 27-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | KITTADAHALLI_110     | 11:50             | 17:05            | 05:15    | LINE CLEAR AVAIED   |
| 6307  | 27-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-JAPPU        | KONAJE_110           | 20:03(26.09       | 0:38(27.09.2024) | 4:35 hrs | LINE CLEAR AVAIED   |
| 6308  | 27-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SORAB        | SHIRALKOPPA_220      | 10:13             | 15:49            | 05:36    | LINE CLEAR AVAIED   |
| 6309  | 27-Sep-24 | HASSAN  | 110     | LINE        | SORABA-SHR220       | SORABA_110           | 10:13             | 15:57            | 05:44    | LINE CLEAR AVAIED   |
| 6310  | 27-Sep-24 | HASSAN  | 66      | LINE        | BAGUR-RAMAPUR       | BAGUR_66             | 07:41             | 07:51            | 00:10    | TRIPPED ON FAULT    |
| 6311  | 27-Sep-24 | HASSAN  | 66      | LINE        | BAGUR-RAMAPUR       | BAGUR_66             | 09:17             | 09:28            | 00:11    | TRIPPED ON FAULT    |
| 6312  | 27-Sep-24 | HASSAN  | 66      | LINE        | BALEHN-ALDUR        | BALEHONNUR_66        | 11:42             | 12:05            | 00:23    | TRIPPED ON FAULT    |
| 6313  | 27-Sep-24 | HASSAN  | 66      | LINE        | CHIKABO-SIDPR       | CHIKABOMMENAHALLI_66 | 16:55             | 17:25            | 00:30    | TRIPPED ON FAULT    |
| 6314  | 27-Sep-24 | HASSAN  | 66      | LINE        | CRPATNA-MATTANAVILE | CRPATNA_66           | 09:12             | 12:21            | 03:09    | TRIPPED ON FAULT    |
| 6315  | 27-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | HOLALUR_66           | 14:15             | 14:30            | 00:15    | MAIN SUPPLY FAILURE |
| 6316  | 27-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | KANDLI_66            | 11:10             | 12:10            | 01:00    | LINE CLEAR AVAIED   |
| 6317  | 27-Sep-24 | HASSAN  | 66      | LINE        | MATTNAV-CRPATNA     | MATTNAVILE_66        | 09:12             | 12:21            | 03:09    | MAIN SUPPLY FAILURE |
| 6318  | 27-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                 | RAMESHWARNAGARA_66   | 10:47             | 13:00            | 02:13    | LINE CLEAR AVAIED   |
| 6319  | 28-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-DAVANGERE    | MRSMSG_220           | 13:38             | 14:03            | 00:25    | TRIPPED ON FAULT    |
| 6320  | 28-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV4                 | MRSMSG_220           | 09:16             | 13:49            | 04:33    | LINE CLEAR AVAIED   |
| 6321  | 28-Sep-24 | HASSAN  | 110     | LINE        | MRSSHM-TRKER        | MRSMSG_220           | 12:02             | 13:34            | 01:32    | TRIPPED ON FAULT    |
| 6322  | 28-Sep-24 | HASSAN  | 110     | LINE        | PUTTUR-VITLA        | PUTTUR_220           | 09:48             | 09:57            | 00:09    | TRIPPED ON FAULT    |
| 6323  | 28-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                 | JOG_110              | 11:35             | 18:08            | 06:33    | LINE CLEAR AVAIED   |
| 6324  | 28-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                 | JOG_110              | 11:35             | 16:05            | 04:30    | LINE CLEAR AVAIED   |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                    | Station_Name         | Open_At           | Closed_At        | Duration  | REMARKS             |
|-------|-----------|---------|---------|-------------|-------------------------|----------------------|-------------------|------------------|-----------|---------------------|
| 6325  | 28-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-MANJESWARG       | KONAJE_110           | 09:48             | 10:05            | 00:17     | TRIPPED ON FAULT    |
| 6326  | 28-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | MOODABIDRE_110       | 11:40             | 13:13            | 01:33     | LINE CLEAR AVAIED   |
| 6327  | 28-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-BNTWAL          | SALATHUR_110         | 09:48             | 09:58            | 00:10     | MAIN SUPPLY FAILURE |
| 6328  | 28-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-VITLA           | SALATHUR_110         | 09:48             | 09:58            | 00:10     | MAIN SUPPLY FAILURE |
| 6329  | 28-Sep-24 | HASSAN  | 110     | LINE        | ALKOLA-SAGAR            | ALKOLA_110           | 10:20             | 15:40            | 05:20     | LINE CLEAR AVAIED   |
| 6330  | 28-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | HNPURA_66            | 10:00             | 10:10            | 00:10     | TRIPPED ON FAULT    |
| 6331  | 28-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | RAMNATHPURA_66       | 10:00             | 18:45            | 08:45     | LINE CLEAR AVAIED   |
| 6332  | 28-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | RAMNATHPURA_66       | 10:00             | 18:45            | 08:45     | LINE CLEAR AVAIED   |
| 6333  | 28-Sep-24 | HASSAN  | 66      | TRANSFORMER | LV4                     | MRSMSG_220           | 09:16             | 13:49            | 04:33     | LINE CLEAR AVAIED   |
| 6334  | 29-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1         | gen_varahi           | 11:39(29.09.2024) |                  |           | TRIPPED ON FAULT    |
| 6335  | 29-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-BASTIPURA       | GOPALAPURA_220       | 16:16(29.09.2024) |                  |           | TRIPPED ON FAULT    |
| 6336  | 29-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Manipal1          | KEMAR_220            | 16:30             | 17:26            | 00:56     | TRIPPED ON FAULT    |
| 6337  | 29-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-Manipal2          | KEMAR_220            | 16:30             | 17:25            | 00:55     | TRIPPED ON FAULT    |
| 6338  | 29-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-BELMAN            | KEMAR_220            | 16:35             | 17:27            | 00:52     | TRIPPED ON FAULT    |
| 6339  | 29-Sep-24 | HASSAN  | 110     | LINE        | KEMAR-NANDHIKUR         | KEMAR_220            | 16:30             | 17:30            | 01:00     | TRIPPED ON FAULT    |
| 6340  | 29-Sep-24 | HASSAN  | 66      | LINE        | TAVAREC-HONNALI         | TAVARECHATNAHALLI_66 | 16:04             | 16:25            | 00:21     | TRIPPED ON FAULT    |
| 6341  | 29-Sep-24 | HASSAN  | 66      | LINE        | HNPR2-HASS2             | HNPURA_220           | 18:23             | 18:36            | 00:13     | TRIPPED ON FAULT    |
| 6342  | 29-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-BASTIPURA       | GOPALAPURA_220       | 05:57             | 06:15            | 00:18     | TRIPPED ON FAULT    |
| 6343  | 29-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2             | MRSMSG_220           | 11:43             | 12:18            | 00:35     | TRIPPED ON FAULT    |
| 6344  | 29-Sep-24 | HASSAN  | 66      | LINE        | MRSSHM-DVG2             | MRSMSG_220           | 17:33             | 18:07            | 00:34     | TRIPPED ON FAULT    |
| 6345  | 29-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV1                     | ALKOLA_110           | 10:05             | 17:45            | 07:40     | LINE CLEAR AVAIED   |
| 6346  | 29-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | ALKOLA_110           | 10:05             | 17:45            | 07:40     | LINE CLEAR AVAIED   |
| 6347  | 29-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                     | ALKOLA_110           | 10:05             | 17:45            | 07:40     | LINE CLEAR AVAIED   |
| 6348  | 29-Sep-24 | HASSAN  | 110     | LINE        | MADHUV-BRK_MDV CBreaker | MADHUVANA_110        | 03:22             | 03:49            | 00:27     | TRIPPED ON FAULT    |
| 6349  | 29-Sep-24 | HASSAN  | 110     | LINE        | MADHUV-HIRIYADKA        | MADHUVANA_110        | 03:22             | 03:51            | 00:29     | TRIPPED ON FAULT    |
| 6350  | 29-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV3                     | MANIPAL_110          | 17:45             | 18:05            | 00:20     | TRIPPED ON FAULT    |
| 6351  | 29-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-KEMAR1          | MANIPAL_110          | 16:30             | 17:30            | 01:00     | MAIN SUPPLY FAILURE |
| 6352  | 29-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-ISTR1           | NANDIKUR_110         | 16:30             | 17:30            | 01:00     | MAIN SUPPLY FAILURE |
| 6353  | 29-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-KEMAR2          | NANDIKUR_110         | 16:30             | 17:30            | 01:00     | MAIN SUPPLY FAILURE |
| 6354  | 29-Sep-24 | HASSAN  | 110     | LINE        | NANDIKU-NDKR-SUZLON     | NANDIKUR_110         | 16:30             | 17:30            | 01:00     | MAIN SUPPLY FAILURE |
| 6355  | 29-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2                     | SAGARA_110           | 17:11             | 17:51            | 00:40     | LINE CLEAR AVAIED   |
| 6356  | 29-Sep-24 | HASSAN  | 66      | LINE        | ALDUR-BALEHONNUR        | ALDUR_66             | 11:42             | 12:04            | 00:22     | TRIPPED ON FAULT    |
| 6357  | 29-Sep-24 | HASSAN  | 66      | LINE        | ARAKAL-HASSAN           | ARAKALGUD_66         | 10:15             | 10:30            | 00:15     | LINE CLEAR AVAIED   |
| 6358  | 29-Sep-24 | HASSAN  | 66      | LINE        | ARAKAL-HASSAN           | ARAKALGUD_66         | 11:45             | 11:50            | 00:05     | LINE CLEAR AVAIED   |
| 6359  | 29-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | BYRAPURA_66          | 04:18             | 04:23            | 00:05     | TRIPPED ON FAULT    |
| 6360  | 29-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | DIDIGA_66            | 06:15             | 06:30            | 00:15     | TRIPPED ON FAULT    |
| 6361  | 29-Sep-24 | HASSAN  | 66      | LINE        | GORUR-ARAKALGUD         | GORUR_66             | 10:15             | 12:50            | 02:35     | LINE CLEAR AVAIED   |
| 6362  | 29-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | HANGAR_66            | 06:00             | 06:32            | 00:32     | TRIPPED ON FAULT    |
| 6363  | 29-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | KIADB HASSAN_66      | 10:00             | 13:50            | 03:50     | LINE CLEAR AVAIED   |
| 6364  | 29-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV2                     | KIADB HASSAN_66      | 10:00             | 13:50            | 03:50     | LINE CLEAR AVAIED   |
| 6365  | 29-Sep-24 | HASSAN  | 66      | LINE        | MALALI-CRPATNA          | MALALI_66            | 18:20             | 18:40            | 00:20     | MAIN SUPPLY FAILURE |
| 6366  | 29-Sep-24 | HASSAN  | 66      | LINE        | SALAGAM-HIREMANGLUR     | SALAGAME_66          | 12:46             | 13:17            | 00:31     | TRIPPED ON FAULT    |
| 6367  | 29-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE          | SIGEBAGE_66          | 11:43             | 12:33            | 00:50     | TRIPPED ON FAULT    |
| 6368  | 29-Sep-24 | HASSAN  | 66      | LINE        | SIGEBAG-KDLGRE          | SIGEBAGE_66          | 17:35             | 18:20            | 00:45     | TRIPPED ON FAULT    |
| 6369  | 30-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1         | gen_varahi           | 11:39(29.09.2024) | 14:45(30.9.2024) | 27:05 hrs | TRIPPED ON FAULT    |

| SL NO | Dinanka   | Tr_ZONE | Voltage | LINE/TRNS   | Line                    | Station_Name    | Open_At           | Closed_At       | Duration  | REMARKS             |
|-------|-----------|---------|---------|-------------|-------------------------|-----------------|-------------------|-----------------|-----------|---------------------|
| 6370  | 30-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-BASTIPURA       | GOPALAPURA_220  | 16:16(29.09.2024) | 8:0(30.09.2024) | 15:43 hrs | LINE CLEAR AVAILED  |
| 6371  | 30-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-SHARAVATHY1      | MRSMSG_220      | 23:12(30.11.2024) |                 |           | TRIPPED ON FAULT    |
| 6372  | 30-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA1        | gen_gersoppa    | 10:01             | 13:58           | 03:57     | LINE CLEAR AVAILED  |
| 6373  | 30-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA1        | gen_gersoppa    | 14:15             | 17:33           | 03:18     | TRIPPED ON FAULT    |
| 6374  | 30-Sep-24 | HASSAN  | 220     | LINE        | GERSOPA-TALGUPA2        | gen_gersoppa    | 09:53             | 11:14           | 01:21     | LINE CLEAR AVAILED  |
| 6375  | 30-Sep-24 | HASSAN  | 220     | LINE        | GOPALAP-HNPUR22         | GOPALAPURA_220  | 11:02             | 11:22           | 00:20     | TRIPPED ON FAULT    |
| 6376  | 30-Sep-24 | HASSAN  | 110     | LINE        | PUTTUR-PUTUR 1          | PUTTUR_220      | 16:07             | 16:44           | 00:37     | TRIPPED ON FAULT    |
| 6377  | 30-Sep-24 | HASSAN  | 220     | LINE        | KAVOOR-MRPL             | KAVOOR_220      | 10:00             | 13:10           | 03:10     | LINE CLEAR AVAILED  |
| 6378  | 30-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP             | MRSMSG_220      | 10:01             | 13:58           | 03:57     | LINE CLEAR AVAILED  |
| 6379  | 30-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-STRP             | MRSMSG_220      | 14:15             | 17:33           | 03:18     | TRIPPED ON FAULT    |
| 6380  | 30-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-SHARAVATHY1      | MRSMSG_220      | 12:33             | 14:55           | 02:22     | TRIPPED ON FAULT    |
| 6381  | 30-Sep-24 | HASSAN  | 220     | LINE        | MRSSHM-SHARAVATHY1      | MRSMSG_220      | 15:19             | 18:07           | 02:48     | TRIPPED ON FAULT    |
| 6382  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA1        | gen_sharavathy  | 12:35             | 14:55           | 02:20     | TRIPPED ON FAULT    |
| 6383  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA1        | gen_sharavathy  | 15:19             | 18:07           | 02:48     | TRIPPED ON FAULT    |
| 6384  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA3        | gen_sharavathy  | 16:09             | 16:15           | 00:06     | TRIPPED ON FAULT    |
| 6385  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIMOGA4        | gen_sharavathy  | 16:09             | 16:15           | 00:06     | TRIPPED ON FAULT    |
| 6386  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRAVTY-SHIRALKOPPA     | gen_sharavathy  | 11:59             | 16:16           | 04:17     | TRIPPED ON FAULT    |
| 6387  | 30-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA1         | Ggen_varahi     | 16:09             | 16:50           | 00:41     | TRIPPED ON FAULT    |
| 6388  | 30-Sep-24 | HASSAN  | 220     | LINE        | VARAHI-SHIMOGA2         | Ggen_varahi     | 16:09             | 16:50           | 00:41     | TRIPPED ON FAULT    |
| 6389  | 30-Sep-24 | HASSAN  | 220     | LINE        | SHRLKP-SHARAVATHY       | SHIRALKOPPA_220 | 11:58             | 14:02           | 02:04     | TRIPPED ON FAULT    |
| 6390  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-BARANG           | SHIRALKOPPA_220 | 11:58             | 12:20           | 00:22     | MAIN SUPPLY FAILURE |
| 6391  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-KITTADAHALLI     | SHIRALKOPPA_220 | 23:07             | 23:28           | 00:21     | TRIPPED ON FAULT    |
| 6392  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-KITTADAHALLI     | SHIRALKOPPA_220 | 11:58             | 12:15           | 00:17     | MAIN SUPPLY FAILURE |
| 6393  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIKARIPURA      | SHIRALKOPPA_220 | 11:58             | 12:06           | 00:08     | MAIN SUPPLY FAILURE |
| 6394  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SHIRALKOPPA      | SHIRALKOPPA_220 | 11:58             | 12:15           | 00:17     | MAIN SUPPLY FAILURE |
| 6395  | 30-Sep-24 | HASSAN  | 110     | LINE        | SHRLKP-SORAB            | SHIRALKOPPA_220 | 11:58             | 12:14           | 00:16     | MAIN SUPPLY FAILURE |
| 6396  | 30-Sep-24 | HASSAN  | 110     | TRANSFORMER | HV2 CB                  | JADE_110        | 20:25             | 20:50           | 00:25     | TRIPPED ON FAULT    |
| 6397  | 30-Sep-24 | HASSAN  | 110     | LINE        | KONAJE-MANJESWARG       | KONAJE_110      | 04:27             | 04:52           | 00:25     | MAIN SUPPLY FAILURE |
| 6398  | 30-Sep-24 | HASSAN  | 110     | LINE        | MADHUV-BRK_MDV Cbreaker | MADHUVANA_110   | 11:08             | 11:56           | 00:48     | LINE CLEAR AVAILED  |
| 6399  | 30-Sep-24 | HASSAN  | 110     | LINE        | MANIPAL-BRAMVR          | MANIPAL_110     | 09:30             | 12:50           | 03:20     | LINE CLEAR AVAILED  |
| 6400  | 30-Sep-24 | HASSAN  | 110     | LINE        | SALATHU-BNTWAL          | SALATHUR_110    | 04:27             | 04:46           | 00:19     | TRIPPED ON FAULT    |
| 6401  | 30-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1 CB                  | HETTUR_110      | 11:40             | 13:30           | 01:50     | LINE CLEAR AVAILED  |
| 6402  | 30-Sep-24 | HASSAN  | 66      | TRANSFORMER | HV1                     | SOMANAHALLI_66  | 16:11             | 17:36           | 01:25     | LINE CLEAR AVAILED  |
| 6403  | 30-Sep-24 | HASSAN  | 66      | LINE        | UDDURKO-SUZLON1         | UDDURKOPPLU_66  | 10:28             | 12:52           | 02:24     | LINE CLEAR AVAILED  |
| 6404  | 30-Sep-24 | HASSAN  | 66      | LINE        | UDDURKO-SUZLON2         | UDDURKOPPLU_66  | 12:56             | 14:29           | 01:33     | LINE CLEAR AVAILED  |