

400/220/110/66 kV TRANSMISSION INTERRUPTIONS DUE TO FAULTS FOR THE MONTH OF JANUARY-2024

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1	01-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	MUNAVALLI_110	11:05	11:19	00:14	TRIPPED ON FAULT
2	01-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	BILAGI_110	04:00	04:11	00:11	TRIPPED ON FAULT
3	01-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANAGAL_110	11:05	11:24	00:19	TRIPPED ON FAULT
4	01-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	HANAGAL_110	11:05	11:24	00:19	TRIPPED ON FAULT
5	01-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	2:10 (18.12.2023)			LINE CLEAR AVOIDED
6	01-Jan-24	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	11:23	11:32	0:09	LINE CLEAR AVOIDED
7	01-Jan-24	BAGALKOT	110	ATHANI220- BALIGERI	ATHANI_220	20:32	20:45	00:13	TRIPPED ON FAULT
8	01-Jan-24	BAGALKOT	110	ATHANI220- KARIMASUTI	ATHANI_220	21:09	21:11	00:02	LINE CLEAR AVOIDED
9	01-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVOIDED
10	01-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
11	01-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVOIDED
12	01-Jan-24	BAGALKOT	110	HUBLI220- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVOIDED
13	01-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
14	01-Jan-24	BAGALKOT	110	KADANAKOPPA- KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVOIDED
15	01-Jan-24	BAGALKOT	110	KALAGATAGI-HUBLI	KALAGATAGI_110	05:41	06:12	00:31	LINE CLEAR AVOIDED
16	01-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	18:06 (11.10.2023)			LINE CLEAR AVOIDED
17	01-Jan-24	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	KIRUVATTI_110	11:08	12:30	01:22	LINE CLEAR AVOIDED
18	01-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
19	01-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
20	01-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
21	01-Jan-24	BAGALKOT	110	MUGALKHOD220-LN5(ITANAL3)	STATION NOT AFFECTED MUGALKHOD_220	11:22	13:00	01:38	LINE CLEAR AVAILED
22	01-Jan-24	BAGALKOT	110	NAVALGUND-NOKAR BHUMI SOLAR	NAVALGUND_110	15:45	15:46	00:01	LINE CLEAR AVAILED
23	01-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
24	01-Jan-24	BAGALKOT	110	RANEBENNUR220-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	15:36 (15.12.2023)			LINE CLEAR AVAILED
25	01-Jan-24	BAGALKOT	110	SOUDATTI220-MMCL	SOUDATTI_220	16:10	16:15	00:05	LINE CLEAR AVAILED
26	01-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
27	01-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
28	01-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
29	01-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
30	01-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
31	01-Jan-24	BAGALKOT	220	VAJRAMATTI- ENERCON	STATION NOT AFFECTED VAJRAMATTI_220	22:31	22:36	0:05	LINE CLEAR AVAILED
32	01-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
33	01-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	07:24	07:36	00:12	TRIPPED ON FAULT
34	01-Jan-24	BANGALORE	66	HV1	YELAHANAK 220	17:02	17:16	00:14	LINE CLEAR AVAILED
35	01-Jan-24	BANGALORE	66	HV1	MITTEMARI 220	06:40	06:55	00:15	TRIPPED ON FAULT
36	01-Jan-24	BANGALORE	66	HV1	MAASTHI	12:00	12:20	00:20	LINE CLEAR AVAILED
37	01-Jan-24	BANGALORE	66	HV1	MELEHALLI	12:40	12:58	00:18	TRIPPED ON FAULT
38	01-Jan-24	BANGALORE	66	HV2	GANJIGUNTE	15:30	15:35	00:05	TRIPPED ON FAULT
39	01-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPETE 2	BANGARPETE	21:26	21:36	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
40	01-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	16:24	16:29	00:05	LINE CLEAR AVAILED
41	01-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	14:29	14:34	00:05	LINE CLEAR AVAILED
42	01-Jan-24	BANGALORE	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	14:06	14:10	00:04	LINE CLEAR AVAILED
43	01-Jan-24	BANGALORE	66	SRS PEENYA 220 - DG1	NO STATION AFFECTED	10:50	12:45	01:55	TRIPPED ON FAULT
44	01-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	06:23	06:43	00:20	TRIPPED ON FAULT
45	01-Jan-24	GULBARGA	66	HV1	HOSAHALLI_66	12:55	13:00	00:05	TRIPPED ON FAULT
46	01-Jan-24	GULBARGA	66	HV3	HALVAGALU_66	11:30	11:40	00:10	TRIPPED ON FAULT
47	01-Jan-24	GULBARGA	66	KUDLIGI-BANVEKAL	BANVEKAL_66	14:22	14:32	00:10	TRIPPED ON FAULT
48	01-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
49	01-Jan-24	GULBARGA	66	KUDLIGI-UJJANI	KOTTUR_66,UJJANI_66,SOK KE_66	08:35	08:50	00:15	TRIPPED ON FAULT
50	01-Jan-24	GULBARGA	110	BYGWAT-MALLAT	BYGWAT_110	15:58	16:08	00:10	TRIPPED ON FAULT
51	01-Jan-24	GULBARGA	110	KEMBHAVI-HUNASAI	KEMBHAVI_110	03:30	03:35	00:05	TRIPPED ON FAULT
52	01-Jan-24	GULBARGA	110	MADALAPUR-MALLAT	MADALAPUR_110	04:20	04:27	00:07	TRIPPED ON FAULT
53	01-Jan-24	GULBARGA	110	SHAHAPUR-RAICHUR2	NALWAR_110	01:40	01:46	00:06	TRIPPED ON FAULT
54	01-Jan-24	HASSAN	66	HV2	HALEBEEDU_66	11:10	11:40	00:30	LINE CLEAR AVAILED
55	01-Jan-24	HASSAN	66	HV4	BALEHONNUR_66	19:06	19:13	00:07	TRIPPED ON FAULT
56	01-Jan-24	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	22:27	22:46	00:19	LINE CLEAR AVAILED
57	01-Jan-24	HASSAN	66	MATTNAV-DIDGTHL	MATTNAVILE_66	22:27	22:46	00:19	LINE CLEAR AVAILED
58	01-Jan-24	HASSAN	66	TAVAREC-MALLAPURA	TAVARECHETTANAHALLY_66	15:38	15:55	00:17	TRIPPED ON FAULT
59	01-Jan-24	HASSAN	110	MRSSHM-GAJNUR	MRS MG_220	10:09	10:16	00:07	LINE CLEAR AVAILED
60	01-Jan-24	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:02	14:45	01:43	MAIN SUPPLY FAILURE
61	01-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:02	14:45	01:43	MAIN SUPPLY FAILURE
62	01-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:02	14:45	01:43	MAIN SUPPLY FAILURE
63	01-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:02	14:45	01:43	MAIN SUPPLY FAILURE
64	01-Jan-24	HASSAN	110	SORAB	SHIRALKOPPA_220	13:02	14:45	01:43	MAIN SUPPLY FAILURE
65	01-Jan-24	HASSAN	220	SHRAVTY-SHIRALKOPPA	SHRAVTY	13:00	14:42	01:42	TRIPPED ON FAULT
66	01-Jan-24	HASSAN	220	VARAHI-SHMG3	VARAHI	12:46(31.12.2023)	15:52(1.12.2023)		LINE CLEAR AVAILED
67	01-Jan-24	MYSORE	66	CR NAGARA-KOLLEGALA	GARGESHWARI_66 JANNUR_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	06:25	06:32	00:07	TRIPPED ON FAULT
68	01-Jan-24	MYSORE	66	D R PETE-KUNTHUR	SANTHEMARAHALLI_66	05:28	05:35	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
69	01-Jan-24	MYSORE	66	HV1	BOOKANAKERE_66	15:00	16:06	01:06	LINE CLEAR AVOIDED
70	01-Jan-24	MYSORE	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	05:30	05:39	00:09	TRIPPED ON FAULT
71	01-Jan-24	MYSORE	66	PANDAVAPURA-CHINAKURALI	CHINAKURALI_66	18:19	19:30	01:11	TRIPPED ON FAULT
72	01-Jan-24	MYSORE	66	YELANDURU-MAMBALLI	MAMBALLI_66	11:01	11:08	00:06	TRIPPED ON FAULT
73	01-Jan-24	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	11:24	14:38	03:14	LINE CLEAR AVOIDED
74	01-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	18:09	18:19	00:09	TRIPPED ON FAULT
75	01-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	06:25	06:36	00:11	TRIPPED ON FAULT
76	01-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	11:18	11:58	00:40	LINE CLEAR AVOIDED
77	01-Jan-24	TUMKUR	66	BENKIKERE 220KV-GOPPENAHALLI66	GOPPENAHALLI66	11:18	11:55	00:37	LINE CLEAR AVOIDED
78	01-Jan-24	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66	08:35	08:50	00:15	TRIPPED ON FAULT
79	01-Jan-24	TUMKUR	66	CHILLUR66-HONNALLI220	CHILLUR_66	06:44	06:54	00:10	TRIPPED ON FAULT
80	01-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	06:55	06:59	00:04	TRIPPED ON FAULT
81	01-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	8:52(21.11.2023)			LINE CLEAR AVOIDED
82	01-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:08	15:18	00:10	TRIPPED ON FAULT
83	01-Jan-24	TUMKUR	66	HARIYABBE-HIRIYUR_220KV	HARIYABBE_66	06:35	06:50	00:15	MAIN SUPPLY FAILURE
84	01-Jan-24	TUMKUR	66	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66 ,PDKOTE_66	06:35	06:55	00:20	TRIPPED ON FAULT
85	01-Jan-24	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	00:05	00:35	00:30	MAIN SUPPLY FAILURE
86	01-Jan-24	TUMKUR	66	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	06:44	06:54	00:10	TRIPPED ON FAULT
87	01-Jan-24	TUMKUR	66	HOSADURGA220-BAGUR 66	BAGUR_66	12:10	12:26	00:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
88	01-Jan-24	TUMKUR	66	HOSADURGA220-HALURAMESHWARA66	HALURAMESHWARA_66	23:40	23:55	00:15	TRIPPED ON FAULT
89	01-Jan-24	TUMKUR	66	MADADKERE66-220KV MADHURE 220	MADADAKERE_66	23:40	23:58	00:18	MAIN SUPPLY FAILURE
90	01-Jan-24	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66, TURUVANUR_66	06:53	06:59	00:06	MAIN SUPPLY FAILURE
91	01-Jan-24	TUMKUR	66	PDKOTE66-HARIYABBE 66	PD KOTE_66	06:35	06:50	00:15	MAIN SUPPLY FAILURE
92	01-Jan-24	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	08:35	08:50	00:15	TRIPPED ON FAULT
93	01-Jan-24	TUMKUR	66	SOKKE-UJJINI_66	SOKKE_66	08:35	08:50	00:15	TRIPPED ON FAULT
94	01-Jan-24	TUMKUR	66	TAVAREKERE (C)-GOPPENAHALLI	TAVAREKERE_66	11:15	11:55	00:40	MAIN SUPPLY FAILURE
95	01-Jan-24	TUMKUR	66	TR-1	DAVANAGERE_66	8:00(30.12.2023)	16:11(01.01.2024)	2 DAYS 8 HRS 11 MIN	LINE CLEAR AVAILED
96	01-Jan-24	TUMKUR	66	TR-1	BELLAVI_66	12:08	12:30	00:22	LINE CLEAR AVAILED
97	01-Jan-24	TUMKUR	66	TR-1	NYAMATHI_66	09:40	10:03	00:23	TRIPPED ON FAULT
98	01-Jan-24	TUMKUR	66	TR-1	HOLALKERE_66	11:20	14:00	02:40	LINE CLEAR AVAILED
99	01-Jan-24	TUMKUR	66	TR-1	MADHUGIRI_220	08:05	08:17	00:12	TRIPPED ON FAULT
100	01-Jan-24	TUMKUR	66	TR-1(HV SIDE)	DAVANGERE_SRS_220	16:34	17:47	01:13	LINE CLEAR AVAILED
101	01-Jan-24	TUMKUR	66	TR-2	BELLAVI_66	11:43	12:06	00:23	LINE CLEAR AVAILED
102	01-Jan-24	TUMKUR	66	TR-2	HARIYABBE_66	06:35	06:50	00:15	MAIN SUPPLY FAILURE
103	01-Jan-24	TUMKUR	66	TR-2	NYAMATHI_66	07:50	08:00	00:10	LINE CLEAR AVAILED
104	01-Jan-24	TUMKUR	66	TR-2	NYAMATHI_66	16:10	16:15	00:05	LINE CLEAR AVAILED
105	01-Jan-24	TUMKUR	66	TR-2	MADADAKERE_66	16:35	16:40	00:05	TRIPPED ON FAULT
106	01-Jan-24	TUMKUR	66	TR-3	HARIYABBE_66	09:17	09:23	00:06	TRIPPED ON FAULT
107	01-Jan-24	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	12:15	15:21	03:06	LINE CLEAR AVAILED
108	01-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
109	01-Jan-24	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	16:45	17:47	01:02	LINE CLEAR AVAILED
110	01-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVAILED
111	01-Jan-24	TUMKUR	400	GUTUR_400-BEERANAHALLI-1	GUTUR_400	17:19	19:08	01:49	TRIPPED ON FAULT
112	02-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	HIDIKAL_110	15:45	17:15	01:30	LINE CLEAR AVAILED
113	02-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	MATTIHAL_110	14:23	14:28	00:05	LINE CLEAR AVAILED
114	02-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	MATTIHAL_110	14:23	14:28	00:05	LINE CLEAR AVAILED
115	02-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	MATTIHAL_110	13:32	13:37	00:05	LINE CLEAR AVAILED
116	02-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA-HV3)	GOPPANAKOPPA_110	11:08	12:48	01:40	LINE CLEAR AVAILED
117	02-Jan-24	BAGALKOT	110	110/11KV,HV3(10MVA)	MATTIHAL_110	14:23	14:28	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
118	02-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANAGAL_110	16:45	16:58	00:13	TRIPPED ON FAULT
119	02-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	HANAGAL_110	16:45	16:58	00:13	TRIPPED ON FAULT
120	02-Jan-24	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED BELGAUM_220	11:30	12:48	01:18	LINE CLEAR AVOIDED
121	02-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	2:10 (18.12.2023)	12:43 (02.01.2024)	370:33:00	LINE CLEAR AVOIDED
122	02-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	19:53 (02.01.2024)			TRIPPED ON FAULT
123	02-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVOIDED
124	02-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
125	02-Jan-24	BAGALKOT	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	22:37	22:51	00:14	TRIPPED ON FAULT
126	02-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVOIDED
127	02-Jan-24	BAGALKOT	110	HUBLI220- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVOIDED
128	02-Jan-24	BAGALKOT	110	INDI220- LACHYAN	INDI_220	22:00	22:05	00:05	TRIPPED ON FAULT
129	02-Jan-24	BAGALKOT	110	INDI220- ZALKI2	INDI_220	19:25	19:35	00:10	TRIPPED ON FAULT
130	02-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
131	02-Jan-24	BAGALKOT	110	KADANAKOPPA- KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVOIDED
132	02-Jan-24	BAGALKOT	110	KALAGHATAGI-ABS	KALAGHATAGI_110	13:26	13:27	00:01	LINE CLEAR AVOIDED
133	02-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	18:06 (11.10.2023)			LINE CLEAR AVOIDED
134	02-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
135	02-Jan-24	BAGALKOT	110	MAHALINGAPUR220- GSML2	STATION NOT AFFECTED MAHALINGAPUR_220	15:45	17:49	02:04	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
136	02-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
137	02-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
138	02-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
139	02-Jan-24	BAGALKOT	110	RANEBENNUR220-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	15:36 (15.12.2023)			LINE CLEAR AVAILED
140	02-Jan-24	BAGALKOT	110	SHIGGOAN220- SAVANUR	SHIGGOAN_220	14:59	15:09	00:10	TRIPPED ON FAULT
141	02-Jan-24	BAGALKOT	110	SHIGGOAN220- SAVANUR	SHIGGOAN_220	15:37	15:57	00:20	TRIPPED ON FAULT
142	02-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	SIRSI_110	7:55 (31.12.2023)	23:49 (02.01.2024)	63:54:00	LINE CLEAR AVAILED
143	02-Jan-24	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED CHIKKODI_220	12:58	14:10	01:12	LINE CLEAR AVAILED
144	02-Jan-24	BAGALKOT	220	220/110KV, HV2	AMBEWADI_220	11:08 (01.01.2024)			LINE CLEAR AVAILED
145	02-Jan-24	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED BELGAUM_220	11:32	12:47	01:15	LINE CLEAR AVAILED
146	02-Jan-24	BAGALKOT	220	AMBEWADI- NAGJHARI1	STATION NOT AFFECTED AMBEWADI_220	07:49	13:03	05:14	LINE CLEAR AVAILED
147	02-Jan-24	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	07:17	13:03	05:46	TRIPPED ON FAULT
148	02-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
149	02-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
150	02-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
151	02-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
152	02-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
153	02-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
154	02-Jan-24	BANGALORE	66	BRINDAVANA 220 - NRS 2	MAHALAKSHMI LAYOUT	13:19	13:28	00:09	TRIPPED ON FAULT
155	02-Jan-24	BANGALORE	66	BTM 4TH PHASE - SOUTH CITY	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	06:04	06:10	00:06	LINE CLEAR AVOIDED
156	02-Jan-24	BANGALORE	66	DB PURA 220 - KUNDANA	KUNDANA	08:28	08:47	00:19	LINE CLEAR AVOIDED
157	02-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	08:28	08:46	00:18	LINE CLEAR AVOIDED
158	02-Jan-24	BANGALORE	66	HAROHALLI I/A 220 - VR DODDI	VR DODDI	11:40	12:55	01:15	LINE CLEAR AVOIDED
159	02-Jan-24	BANGALORE	66	HBR LAYOUT 66 - DG3	KONDASAPURA	16:15	16:34	00:19	TRIPPED ON FAULT
160	02-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	12:00	12:05	00:05	LINE CLEAR AVOIDED
161	02-Jan-24	BANGALORE	66	HV2	DIBBURAHALLI	16:10	16:18	00:08	LINE CLEAR AVOIDED
162	02-Jan-24	BANGALORE	66	HV2	CHIKKABALLAPURA I/A	16:10	16:13	00:03	LINE CLEAR AVOIDED
163	02-Jan-24	BANGALORE	66	HV2	VOKKALERI	15:20	15:50	00:30	LINE CLEAR AVOIDED
164	02-Jan-24	BANGALORE	66	KIADB DB PURA 220 - APPEAREL PARK	APPEAREL PARK	16:57	17:16	00:19	MAIN SUPPLY FAILURE
165	02-Jan-24	BANGALORE	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	16:57	17:16	00:19	MAIN SUPPLY FAILURE
166	02-Jan-24	BANGALORE	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	16:57	17:16	00:19	MAIN SUPPLY FAILURE
167	02-Jan-24	BANGALORE	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	22:50	23:15	00:25	TRIPPED ON FAULT
168	02-Jan-24	BANGALORE	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	07:14	07:28	00:14	TRIPPED ON FAULT
169	02-Jan-24	BANGALORE	66	NANGLI - T GOLLAHALLI 220	NANGLI	13:13	14:30	01:17	LINE CLEAR AVOIDED
170	02-Jan-24	BANGALORE	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	06:21	06:26	00:05	LINE CLEAR AVOIDED
171	02-Jan-24	BANGALORE	66	YELAHANKA 220 - KHB	KHB	11:39	11:45	00:06	TRIPPED ON FAULT
172	02-Jan-24	BANGALORE	220	DB PURA 220 - KIADB DB PURA 220	KIADB 220	16:57	17:16	00:19	TRIPPED ON FAULT
173	02-Jan-24	BANGALORE	220	GOWRIBIDANUR 220 - MITTEMARI 1	NO STATION AFFECTED	13:59	14:38	00:39	TRIPPED ON FAULT
174	02-Jan-24	BANGALORE	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	NO STATION AFFECTED	16:47	16:53	00:06	TRIPPED ON FAULT
175	02-Jan-24	GULBARGA	66	HV1	MORAGERE_66	08:55	09:05	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
176	02-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,GIRIYAPURA_66,MAGALA_66	21:49	22:02	00:13	TRIPPED ON FAULT
177	02-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66,HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
178	02-Jan-24	GULBARGA	110	BELLARY NORTH-MOKA	MOKA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110	03:37	03:50	00:13	TRIPPED ON FAULT
179	02-Jan-24	GULBARGA	110	GANGAVATI-MUNIRABAD	VENKATAGIRI_110	11:40	11:50	00:10	TRIPPED ON FAULT
180	02-Jan-24	GULBARGA	110	KONKAL-RAMASAMUDRA	KONKAL_110	11:40	11:50	00:10	LINE CLEAR AVAILED
181	02-Jan-24	GULBARGA	110	MALLAT-HINDUJA_IPP	MALLAT_220	18:05	22:00	03:55	LINE CLEAR AVAILED
182	02-Jan-24	GULBARGA	110	SHAHAPUR-RAICHUR2	NALWAR_110	10:50	18:26	07:36	LINE CLEAR AVAILED
183	02-Jan-24	GULBARGA	220	ALIPUR-RAGALPADU	ALIPUR_220	09:30	19:39	10:09	LINE CLEAR AVAILED
184	02-Jan-24	GULBARGA	220	MALLAT-REPL_IPP	MALLAT_220	18:05	22:00	03:55	LINE CLEAR AVAILED
185	02-Jan-24	HASSAN	66	CRPATNA2-KIKKERI	CRPATNA_220	12:05	17:44	05:39	LINE CLEAR AVAILED
186	02-Jan-24	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPPLU_66	16:26	17:28	01:02	LINE CLEAR AVAILED
187	02-Jan-24	HASSAN	110	GAJNUR-OUTGOING LINE	GAJNUR_110	09:05	09:40	00:35	MAIN SUPPLY FAILURE
188	02-Jan-24	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	09:05	09:40	00:35	MAIN SUPPLY FAILURE
189	02-Jan-24	HASSAN	110	HV1	MADHUVANA_110	10:00	14:18	04:18	MAIN SUPPLY FAILURE
190	02-Jan-24	HASSAN	110	HV2	KULASHEKARA_110	12:02	20:15	08:13	LINE CLEAR AVAILED
191	02-Jan-24	HASSAN	110	HV2	MADHUVANA_110	10:00	14:18	04:18	MAIN SUPPLY FAILURE
192	02-Jan-24	HASSAN	110	HV3	MADHUVANA_110	10:00	14:18	04:18	MAIN SUPPLY FAILURE
193	02-Jan-24	HASSAN	110	LV1	KEMAR_220	10:26	12:03	01:37	LINE CLEAR AVAILED
194	02-Jan-24	HASSAN	110	MADHUV-BRK_HRD	MADHUVANA_110	10:00	14:18	04:18	MAIN SUPPLY FAILURE
195	02-Jan-24	HASSAN	110	MADHUV-BRK_MDV	MADHUVANA_110	10:00	14:18	04:18	MAIN SUPPLY FAILURE
196	02-Jan-24	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	11:07(27.12.2023)	16:54(2.1.2024)	159:07HRS	LINE CLEAR AVAILED
197	02-Jan-24	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	11:09(27.12.2023)	16:55(2.1.2024)	159:09HRS	LINE CLEAR AVAILED
198	02-Jan-24	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	10:00	14:18	04:18	LINE CLEAR AVAILED
199	02-Jan-24	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_220	19:30	19:50	00:20	MAIN SUPPLY FAILURE
200	02-Jan-24	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_220	22:08	22:14	00:06	MAIN SUPPLY FAILURE
201	02-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	19:34	20:46	01:12	TRIPPED ON FAULT
202	02-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	22:05	22:11	00:06	LINE CLEAR AVAILED
203	02-Jan-24	HASSAN	220	HV1	KEMAR_220	10:26	12:03	01:37	LINE CLEAR AVAILED
204	02-Jan-24	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	10:47	15:33	04:46	LINE CLEAR AVAILED
205	02-Jan-24	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	10:50	15:33	04:43	LINE CLEAR AVAILED
206	02-Jan-24	MYSORE	66	DODDINDUWADI-KOTTANUR	NO STATIONS EFFECTED	22:10	22:20	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
207	02-Jan-24	MYSORE	66	HV2	RKNAGARA_66	11:04	13:03	01:58	LINE CLEAR AVAILED
208	02-Jan-24	MYSORE	66	HV2	SATHEGALA_66	11:46	12:27	00:40	LINE CLEAR AVAILED
209	02-Jan-24	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66 JAKKANAHALLY_66MADES WARAPURA_66	06:54	07:06	00:11	TRIPPED ON FAULT
210	02-Jan-24	MYSORE	66	KR PETE-KIKKERI	NO STATIONS EFFECTED	12:02	12:58	00:55	LINE CLEAR AVAILED
211	02-Jan-24	MYSORE	66	KUSHALNAGARA 220-MYSORE-2	NO STATIONS EFFECTED	06:52	07:03	00:10	TRIPPED ON FAULT
212	02-Jan-24	MYSORE	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	10:46	13:25	02:39	LINE CLEAR AVAILED
213	02-Jan-24	MYSORE	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66MARADIHUNDI_66	03:42	03:55	00:13	TRIPPED ON FAULT
214	02-Jan-24	MYSORE	220	HV2	VAJMANGALA_220	15:23	15:56	00:33	LINE CLEAR AVAILED
215	02-Jan-24	TUMKUR	66	ANCHEPALYA 220KV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	08:23	08:33	00:10	LOAD CURTAILMENT
216	02-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66	08:28	09:15	00:47	LOAD CURTAILMENT
217	02-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:24	15:47	01:23	TRIPPED ON FAULT
218	02-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:25	15:00	00:35	MAIN SUPPLY FAILURE
219	02-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:40	15:50	00:10	MAIN SUPPLY FAILURE
220	02-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	11:30	11:50	00:20	MAIN SUPPLY FAILURE
221	02-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	11:33	11:49	00:16	LINE CLEAR AVAILED
222	02-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	13:16	13:25	00:09	LOAD CURTAILMENT
223	02-Jan-24	TUMKUR	66	BENKIKERE 220KV-CHANNAGIRI 66	CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	08:38	08:41	00:03	LOAD CURTAILMENT
224	02-Jan-24	TUMKUR	66	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	08:38	08:41	00:03	LOAD CURTAILMENT
225	02-Jan-24	TUMKUR	66	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	10:28	10:33	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
226	02-Jan-24	TUMKUR	66	BENKIKERE 220KV- GOPPENAHALLI66	GOPPENAHALLI66	08:38	08:46	00:08	LOAD CURTAILMENT
227	02-Jan-24	TUMKUR	66	CHITRADURGA 66KV- PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	8:52(21.11.2023)			LINE CLEAR AVAILED
228	02-Jan-24	TUMKUR	66	DASUDI66-HIRIYUR220	DASUDI_66	08:15	08:50	00:35	MAIN SUPPLY FAILURE
229	02-Jan-24	TUMKUR	66	DAVANGERE SRS- KUKKAWADA-1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:46	16:06	00:20	TRIPPED ON FAULT
230	02-Jan-24	TUMKUR	66	HARIYABBE_66,P D KOTE_66	HARIYABBE_66	06:35	06:45	00:10	TRIPPED ON FAULT
231	02-Jan-24	TUMKUR	66	HARIYABBE_66,P D KOTE_66	P.D.KOTE	06:35	06:45	00:10	MAIN SUPPLY FAILURE
232	02-Jan-24	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	06:35	06:45	00:10	TRIPPED ON FAULT
233	02-Jan-24	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:17	12:32	00:15	TRIPPED ON FAULT
234	02-Jan-24	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:43	12:49	00:06	TRIPPED ON FAULT
235	02-Jan-24	TUMKUR	66	HEGGERE- MALLASANDRA_66	HEGGERE_66	12:15	13:00	00:45	LINE CLEAR AVAILED
236	02-Jan-24	TUMKUR	66	HIRIYUR220KV- BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	08:13	08:27	00:14	TRIPPED ON FAULT
237	02-Jan-24	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	08:55	09:10	00:15	TRIPPED ON FAULT
238	02-Jan-24	TUMKUR	66	JAVAGONDANAHALLI- HIRIYUR	JAVAGONDANAHALLI_66	08:15	08:35	00:20	MAIN SUPPLY FAILURE
239	02-Jan-24	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66,TURUVAN UR_66	14:20	15:50	01:30	TRIPPED ON FAULT
240	02-Jan-24	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	13:45	14:40	00:55	LINE CLEAR AVAILED
241	02-Jan-24	TUMKUR	66	TR-1	MATHOD_66	12:45	12:55	00:10	MAIN SUPPLY FAILURE
242	02-Jan-24	TUMKUR	66	TR-1	LINGDHALLI_66	12:00	12:05	00:05	LINE CLEAR AVAILED
243	02-Jan-24	TUMKUR	66	TR-2	SASALUHALLA_66	02:00	06:00	04:00	LINE CLEAR AVAILED
244	02-Jan-24	TUMKUR	66	TR-2	SASALUHALLA_66	12:00	13:55	01:55	LINE CLEAR AVAILED
245	02-Jan-24	TUMKUR	66	TR-2	MATHOD_66	15:15	17:00	01:45	MAIN SUPPLY FAILURE
246	02-Jan-24	TUMKUR	110	TR-1	KATRIKEHAL_110	12:41	13:17	00:35	LINE CLEAR AVAILED
247	02-Jan-24	TUMKUR	110	TR-2	KATRIKEHAL_110	13:35	14:00	00:25	LINE CLEAR AVAILED
248	02-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
249	02-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	14:20	17:41	03:21	LINE CLEAR AVAILED
250	02-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVAILED
251	03-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	NAVALAGI_110	10:55	18:55	08:00	LINE CLEAR AVAILED
252	03-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	NAVALAGI_110	10:55	18:59	08:04	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
253	03-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	19:53 (02.01.2024)			TRIPPED ON FAULT
254	03-Jan-24	BAGALKOT	110	BANAHATTI-JAMAKHANDI	BANAHATTI_110	10:55	18:55	08:00	LINE CLEAR AVAILED
255	03-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
256	03-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
257	03-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
258	03-Jan-24	BAGALKOT	110	HAVERI220- HANGAL	HAVERI_220	15:11	16:40	1:29	LINE CLEAR AVAILED
259	03-Jan-24	BAGALKOT	110	HAVERI220- TILUVALLI	HAVERI_220	15:11	16:36	1:25	LINE CLEAR AVAILED
260	03-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
261	03-Jan-24	BAGALKOT	110	ITNAL-RAIBAG2(KABBUR2)	ITNAL_110	8:03 (03.01.2024)			LINE CLEAR AVAILED
262	03-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
263	03-Jan-24	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED
264	03-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	18:06 (11.10.2023)	13:33 (04.01.2024)	2035:27:00	LINE CLEAR AVAILED
265	03-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	KAMBAGI_110	18:28	18:42	00:14	LINE CLEAR AVAILED
266	03-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	KAMBAGI_110	18:46	19:02	00:16	LINE CLEAR AVAILED
267	03-Jan-24	BAGALKOT	110	KARWAR220-ARGA(KUMATA)	KARWAR_220	09:48	09:57	0:09	TRIPPED ON FAULT
268	03-Jan-24	BAGALKOT	110	KUMTA-SIRI1	KUMTA_110	09:15	09:57	00:42	LINE CLEAR AVAILED
269	03-Jan-24	BAGALKOT	110	KUMTA-SIRI1	KUMTA_110	10:05	13:05	03:00	TRIPPED ON FAULT
270	03-Jan-24	BAGALKOT	110	KUMTA-SIRI2	KUMTA_110	09:15	09:57	00:42	LINE CLEAR AVAILED
271	03-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
272	03-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
273	03-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
274	03-Jan-24	BAGALKOT	110	MUGALKHOD220-LN3(RAIBAG1)	MUGALKHOD_220	8:03 (03.01.2024)			LINE CLEAR AVAILED
275	03-Jan-24	BAGALKOT	110	MUGALKHOD220-LN4(RAIBAG2)	MUGALKHOD_220	8:03 (03.01.2024)			LINE CLEAR AVAILED
276	03-Jan-24	BAGALKOT	110	NAVALAGI)-F1(JAMAKHANDI)	NAVALAGI_110	10:55 (03.01.2024)			LINE CLEAR AVAILED
277	03-Jan-24	BAGALKOT	110	NAVALAGI)-F2(BANAHATTI)	NAVALAGI_110	10:55	18:50	07:55	LINE CLEAR AVAILED
278	03-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
279	03-Jan-24	BAGALKOT	110	RANEBENNUR220-BYADAGI(GUTTAL)	STATION NOT AFFECTED RANEBENNUR_220	15:36 (15.12.2023)	19:09 (03.01.2024)	459:33:00	LINE CLEAR AVAILED
280	03-Jan-24	BAGALKOT	110	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	14:52	15:20	0:28	LINE CLEAR AVAILED
281	03-Jan-24	BAGALKOT	110	RANEBENNUR220-HIREKERUR	RANEBENNUR_220	17:05	17:49	0:44	LINE CLEAR AVAILED
282	03-Jan-24	BAGALKOT	110	RANEBENNUR220-HONNATTI	RANEBENNUR_220	14:52	15:20	0:28	LINE CLEAR AVAILED
283	03-Jan-24	BAGALKOT	110	RANEBENNUR220-HONNATTI	RANEBENNUR_220	17:05	17:56	0:51	LINE CLEAR AVAILED
284	03-Jan-24	BAGALKOT	110	RANEBENNUR220-RATTIHALLI(TUMMINKATTI)	RANEBENNUR_220	14:52	15:22	0:30	LINE CLEAR AVAILED
285	03-Jan-24	BAGALKOT	110	RANEBENNUR220-RATTIHALLI(TUMMINKATTI)	RANEBENNUR_220	17:05	17:58	0:53	LINE CLEAR AVAILED
286	03-Jan-24	BAGALKOT	110	RNNABELAGALI_MUDHO(U TTUR)	RANNABELAGALI_110	06:53	07:10	00:17	TRIPPED ON FAULT
287	03-Jan-24	BAGALKOT	110	SHIGGOAN-RAMANAKOPPA(MUNDAGO D)	SHIGGOAN_110	17:11	21:35	04:24	LINE CLEAR AVAILED
288	03-Jan-24	BAGALKOT	110	SHIGGOAN-RAMANAKOPPA(MUNDAGO D)	SHIGGOAN_110	16:45	17:10	00:25	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
289	03-Jan-24	BAGALKOT	110	SHIGGOAN-RAMANAKOPPA(MUNDAGOD)	SHIGGOAN_110	15:05	16:20	01:15	LINE CLEAR AVAILED
290	03-Jan-24	BAGALKOT	110	SIRSI-JOG1	SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
291	03-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED SIRSI_220	09:16	09:24	00:08	TRIPPED ON FAULT
292	03-Jan-24	BAGALKOT	220	220/110KV, HV2	AMBEWADI_220	11:08 (01.01.2024)			LINE CLEAR AVAILED
293	03-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED SIRSI_220	09:16	09:25	00:09	TRIPPED ON FAULT
294	03-Jan-24	BAGALKOT	220	BIDNAL- NARENDRA	BIDNAL_220	01:29	13:21	11:52	LINE CLEAR AVAILED
295	03-Jan-24	BAGALKOT	220	BIDNAL- SHIGGOAN2	BIDNAL_220	14:55	16:41	1:46	TRIPPED ON FAULT
296	03-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
297	03-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	15:54	19:16	3:22	LINE CLEAR AVAILED
298	03-Jan-24	BAGALKOT	220	HAVERI- SHIGGOAN1&2	HAVERI_220	15:59	16:34	0:35	LINE CLEAR AVAILED
299	03-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
300	03-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
301	03-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	10:38	19:35	08:57	LINE CLEAR AVAILED
302	03-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
303	03-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
304	03-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
305	03-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
306	03-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
307	03-Jan-24	BANGALORE	66	DB PURA 220 - D CROSS 2	AIR(EHT)	12:08	16:48	04:40	LINE CLEAR AVAILED
308	03-Jan-24	BANGALORE	66	DIBBURAHALLI - SADALI	DIBBURAHALLI	10:20	10:50	00:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
309	03-Jan-24	BANGALORE	66	DODDABELAVANGALA - DB PURA 220	DODDABELAVANGALA	07:30	07:31	00:01	LINE CLEAR AVAILED
310	03-Jan-24	BANGALORE	66	HV1	PLATINUM CITY	19:43	20:47	01:04	LINE CLEAR AVAILED
311	03-Jan-24	BANGALORE	66	HV1	NAGANATHPURA 220	19:44	20:44	01:00	LINE CLEAR AVAILED
312	03-Jan-24	BANGALORE	66	HV1	DIBBURAHALLI	09:43	10:20	00:37	TRIPPED ON FAULT
313	03-Jan-24	BANGALORE	66	HV1	DIBBURAHALLI	10:20	10:55	00:35	LINE CLEAR AVAILED
314	03-Jan-24	BANGALORE	66	HV1	G KODIHALLI	10:18	10:21	00:03	LINE CLEAR AVAILED
315	03-Jan-24	BANGALORE	66	HV1	GANJIGUNTE	07:30	07:40	00:10	TRIPPED ON FAULT
316	03-Jan-24	BANGALORE	66	HV2	HAL 220	11:58	12:06	00:08	TRIPPED ON FAULT
317	03-Jan-24	BANGALORE	66	HV2	NAGANATHPURA 220	19:44	20:44	01:00	LINE CLEAR AVAILED
318	03-Jan-24	BANGALORE	66	HV2	SUGUTUR	17:00	18:15	01:15	TRIPPED ON FAULT
319	03-Jan-24	BANGALORE	66	HV2	YEDUMADU	13:43	14:40	00:57	LINE CLEAR AVAILED
320	03-Jan-24	BANGALORE	66	HV2	BANGARPETE	21:05	23:50	02:45	TRIPPED ON FAULT
321	03-Jan-24	BANGALORE	66	HV3	NAGANATHPURA 220	19:44	20:44	01:00	LINE CLEAR AVAILED
322	03-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPET 2	BANGARPETE	13:43	14:02	00:19	LINE CLEAR AVAILED
323	03-Jan-24	BANGALORE	66	KOLAR 220 - NANGALI	KEMBODI	13:43	14:08	00:25	LINE CLEAR AVAILED
324	03-Jan-24	BANGALORE	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR, SM MANGALA	13:43	14:08	00:25	LINE CLEAR AVAILED
325	03-Jan-24	BANGALORE	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	13:45	14:08	00:23	LINE CLEAR AVAILED
326	03-Jan-24	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY (EHT)	13:43	14:08	00:25	LINE CLEAR AVAILED
327	03-Jan-24	BANGALORE	66	MAGADI 220 - MAGADI 66	MAGADI 66, HOSPALYA CIRLCE	06:31	06:52	00:21	TRIPPED ON FAULT
328	03-Jan-24	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT), ELECTRONIC CITY, HULIMANGALA	18:28	18:56	00:28	LINE CLEAR AVAILED
329	03-Jan-24	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, HUSKUR(CHOKKASANDRA) , TATA BP SOLAR(EHT)	19:44	20:44	01:00	LINE CLEAR AVAILED
330	03-Jan-24	BANGALORE	66	THAYALUR - T GOLLAHALLI 220	THAYALUR, NG HULKUR, MALLANAYAKANAHALLI	14:50	16:40	01:50	LINE CLEAR AVAILED
331	03-Jan-24	BANGALORE	66	VICTORIA - A STATION 220	VICTORIA	23:04	23:06	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
332	03-Jan-24	BANGALORE	66	YELAHANKA 220 - KANASAWADI	KANASAWADI	16:19	16:29	00:10	TRIPPED ON FAULT
333	03-Jan-24	BANGALORE	220	HV1	NAGANATHPURA 220	19:44	20:44	01:00	LINE CLEAR AVAILED
334	03-Jan-24	BANGALORE	220	HV2	NAGANATHPURA 220	19:44	20:44	01:00	LINE CLEAR AVAILED
335	03-Jan-24	BANGALORE	220	KOLAR 220 - PGCIL 1	KOLAR 220	13:42	14:07	00:25	TRIPPED ON FAULT
336	03-Jan-24	BANGALORE	400	ICT 3	DEVANAHALLI HARDWARE PARK 400	11:31	18:31	07:00	TRIPPED ON FAULT
337	03-Jan-24	GULBARGA	66	HV1	HARVI_66	18:15	18:30	00:15	LINE CLEAR AVAILED
338	03-Jan-24	GULBARGA	66	ITTAGGI-KUDLIGI1	KUDLIGI_66,KOGALI_66,HANASI_66	12:01	14:35	02:34	LINE CLEAR AVAILED
339	03-Jan-24	GULBARGA	66	ITTAGGI-KUDLIGI2	CJHALLI_66,HOSAHALLI_66,CHORNOOR_66,BANVEKAL_66	12:02	14:34	02:32	LINE CLEAR AVAILED
340	03-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66,HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
341	03-Jan-24	GULBARGA	110	BELLARY NORTH-PDHALLI	MOKA_110,PD_HALLI_110,BISIHALLI_110,HALKUNDI_110	16:10	18:35	02:25	LINE CLEAR AVAILED
342	03-Jan-24	GULBARGA	110	GANGAVATI-MUNIRABAD	VENKATAGIRI_110	02:18	02:25	00:07	TRIPPED ON FAULT
343	03-Jan-24	GULBARGA	110	HANAWAL-YERADONA	HANAWAL_110,YERADONA_110	02:18	02:25	00:07	MAIN SUPPLY FAILURE
344	03-Jan-24	GULBARGA	110	HV1	KALBURGI_WEST_110	18:07	18:15	00:08	TRIPPED ON FAULT
345	03-Jan-24	GULBARGA	110	LINGASUGUR-L GAMESHA	LINGASUGUR_220	0:00:00	00:10	00:10	TRIPPED ON FAULT
346	03-Jan-24	GULBARGA	110	SHAHAPUR-DEVAPUR	DEVAPUR_110,SHORAPUR_110	04:32	04:43	00:11	TRIPPED ON FAULT
347	03-Jan-24	GULBARGA	110	SHAHAPUR-DEVAPUR	DEVAPUR_110,SHORAPUR_110	05:56	06:10	00:14	TRIPPED ON FAULT
348	03-Jan-24	GULBARGA	110	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	18:04	18:14	00:10	TRIPPED ON FAULT
349	03-Jan-24	GULBARGA	220	HV1	KAPNOOR_220	11:45	14:33	02:48	LINE CLEAR AVAILED
350	03-Jan-24	GULBARGA	220	ITTAGGI-EMBASSY	ITTAGGI_220	18:55(3.1.2024)			LINE CLEAR AVAILED
351	03-Jan-24	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	15:02	20:23	05:21	LINE CLEAR AVAILED
352	03-Jan-24	HASSAN	66	GORUR-HASSAN	GORUR_66	07:15	07:35	00:20	MAIN SUPPLY FAILURE
353	03-Jan-24	HASSAN	66	HSSN22-ARKLGUD2	HASSAN_220	07:15	07:34	00:19	TRIPPED ON FAULT
354	03-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	17:05	18:15	01:10	LINE CLEAR AVAILED
355	03-Jan-24	HASSAN	110	GANDAS-HV2	GANDASI_110	17:10	17:44	00:34	TRIPPED ON FAULT
356	03-Jan-24	MYSORE	66	DODDINDUVADI-KOTHNUR	NO STATIONS EFFECTED	02:20	02:30	00:10	TRIPPED ON FAULT
357	03-Jan-24	MYSORE	66	HOOTGALLY-BANNIKUPPE	BANNIKUPPE_66	06:30	06:41	00:11	TRIPPED ON FAULT
358	03-Jan-24	MYSORE	66	KOTHNUR-HANUR	NO STATIONS EFFECTED	22:00	22:05	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
359	03-Jan-24	MYSORE	66	PONNAMPETE-SRIMANGALA	SRIMANGALA_66	06:30	06:41	00:11	TRIPPED ON FAULT
360	03-Jan-24	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	16:40	18:13	01:33	LINE CLEAR AVAILED
361	03-Jan-24	MYSORE	220	KR PETE220-CRPATNA	NO STATIONS EFFECTED	11:52	13:34	01:42	LINE CLEAR AVAILED
362	03-Jan-24	MYSORE	220	KR PETE220-YACHANAHALLI	NO STATIONS EFFECTED	17:13	18:20	01:07	LINE CLEAR AVAILED
363	03-Jan-24	MYSORE	220	VAJMANGALA-HV1	BANNUR_66 MEGHALAPURA_66 AYRALLI_66 MARADIHUNDI_66	06:25	06:41	00:16	TRIPPED ON FAULT
364	03-Jan-24	TUMKUR	66	SIRA 220-BUKKAPATNA 66	BUKKAPATNA_66	12:17	12:25	00:08	TRIPPED ON FAULT
365	03-Jan-24	TUMKUR	66	BENKIKERE 220KV - BENKIKERE66	BENKIKERE_66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
366	03-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	17:10	19:10	02:00	MAIN SUPPLY FAILURE
367	03-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
368	03-Jan-24	TUMKUR	66	BENKIKERE 220KV-CHANNAGIRI 66	CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
369	03-Jan-24	TUMKUR	66	BENKIKERE 220KV-DEVARAHALLI 66	DEVARAHALLI_66,CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
370	03-Jan-24	TUMKUR	66	BENKIKERE 220KV-GOPPENAHALLI66	GOPPENAHALLI66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
371	03-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR 66	NALLUR_66	17:15	19:15	02:00	MAIN SUPPLY FAILURE
372	03-Jan-24	TUMKUR	66	BENKIKERE 220--RAMAGIRI66	RAMAGIRI_66	17:10	19:15	02:05	MAIN SUPPLY FAILURE
373	03-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	8:52(21.11.2023)			LINE CLEAR AVAILED
374	03-Jan-24	TUMKUR	66	DAVANGERE SRS-CHITRADURGA 1(MAYAKONDA 66)	MAYAKONDA_66.SASALUHALLA_66,CHIKKAJAJUR_66	19:55	20:05	00:10	MAIN SUPPLY FAILURE
375	03-Jan-24	TUMKUR	66	GARAGA66-MATHOD66	GARAGA_66,PANCHANAHALLI_66	13:20	14:35	01:15	MAIN SUPPLY FAILURE
376	03-Jan-24	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	13:14	13:29	00:15	TRIPPED ON FAULT
377	03-Jan-24	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:10	18:20	01:10	MAIN SUPPLY FAILURE
378	03-Jan-24	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	19:20	19:30	00:10	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
379	03-Jan-24	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:13	19:04	01:51	MAIN SUPPLY FAILURE
380	03-Jan-24	TUMKUR	66	HONNALLI 220kV- SASVEHALLI	SAAVEHALLI_66	17:13	19:04	01:51	MAIN SUPPLY FAILURE
381	03-Jan-24	TUMKUR	66	HONNALLI220- KUNDUR66	KUNDUR_66	13:56	14:09	00:13	TRIPPED ON FAULT
382	03-Jan-24	TUMKUR	66	HONNALLI220- KUNDUR66	KUNDUR_66	17:13	19:04	01:51	MAIN SUPPLY FAILURE
383	03-Jan-24	TUMKUR	66	HOSADURGA220-BAGUR 66	BAGUR_66	17:10	19:15	02:05	MAIN SUPPLY FAILURE
384	03-Jan-24	TUMKUR	66	HOSADURGA220- HALURAMESHWARA66	HALURAMESHWARA_66	17:10	19:15	02:05	MAIN SUPPLY FAILURE
385	03-Jan-24	TUMKUR	66	JAGALUR-BIDARAKERE_66	JAGALUR_66,TURUVANUR_66	06:10	06:15	00:05	MAIN SUPPLY FAILURE
386	03-Jan-24	TUMKUR	66	KADAJJI_66- SRS DAVANGERE	KADAJJI_66	17:15	19:10	01:55	MAIN SUPPLY FAILURE
387	03-Jan-24	TUMKUR	66	KUKKAWADA- BASAVAPATNA_66	KUKKAWADA_66,	17:15	19:10	01:55	MAIN SUPPLY FAILURE
388	03-Jan-24	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66,TURUVANUR_66.	17:15	19:10	01:55	MAIN SUPPLY FAILURE
389	03-Jan-24	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	17:15	19:10	01:55	MAIN SUPPLY FAILURE
390	03-Jan-24	TUMKUR	66	MADANAYAKANAHALLI- CHITRADURGA220	MADANAYAKANAHALLI_66, TURUVANUR_66	06:10	06:16	00:06	TRIPPED ON FAULT
391	03-Jan-24	TUMKUR	66	MELLEKATTE66- DAVANAGERE SRS 220KV	MELLEKATTE_66	17:12	19:05	01:53	MAIN SUPPLY FAILURE
392	03-Jan-24	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50(03.01.2024)			MAIN SUPPLY FAILURE
393	03-Jan-24	TUMKUR	66	PAVAGADA220- PAVAGADA66	PAVAGADA_66,VENKATAPU RA_66,THERIYUR_66	12:40	14:00	01:20	LINE CLEAR AVAILED
394	03-Jan-24	TUMKUR	66	SASALUHALLA- PANDARAHALLI_66 O/G LINE	SASUVEHALLI_66	17:10	19:10	02:00	MAIN SUPPLY FAILURE
395	03-Jan-24	TUMKUR	66	SHYAGALE_66- KEREBILCHI_66	SHYAGALE_66	17:15	19:10	01:55	MAIN SUPPLY FAILURE
396	03-Jan-24	TUMKUR	66	TR-1	LINGDHALLI_66	14:00	14:40	00:40	LINE CLEAR AVAILED
397	03-Jan-24	TUMKUR	66	TR-1	DAVANGERE_SRS_220	17:13	19:04	01:51	MAIN SUPPLY FAILURE
398	03-Jan-24	TUMKUR	66	TR-2	BADAVANAHALLI_66	18:00	18:10	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
399	03-Jan-24	TUMKUR	66	TR-2	DAVANGERE_SRS_220	17:13	19:04	01:51	MAIN SUPPLY FAILURE
400	03-Jan-24	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	06:10	06:16	00:06	TRIPPED ON FAULT
401	03-Jan-24	TUMKUR	66	YARAGUNTA66-DAVANAGERESRS66	YARAGUNTA_66	17:15	19:10	01:55	MAIN SUPPLY FAILURE
402	03-Jan-24	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	09:45	09:51	00:06	LINE CLEAR AVAILED
403	03-Jan-24	TUMKUR	110	KB CROSS 220kV-TIMMANAHALLI110	TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	09:50	10:13	00:23	LINE CLEAR AVAILED
404	03-Jan-24	TUMKUR	110	KB CROSS 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	09:45	09:51	00:06	LINE CLEAR AVAILED
405	03-Jan-24	TUMKUR	110	TR-1	KADEHALLI_110	14:30	14:35	00:05	TRIPPED ON FAULT
406	03-Jan-24	TUMKUR	110	TR-2	KADEHALLI_110	09:40	09:50	00:10	MAIN SUPPLY FAILURE
407	03-Jan-24	TUMKUR	220	BENKIKERE 220KV-HONNALLI 220KV -2	BENKIKERE_220	17:13	19:03	01:50	MAIN SUPPLY FAILURE
408	03-Jan-24	TUMKUR	220	DAVANGERE SRS- GUTTUR 1	DAVANGERE_SRS_220	17:12:30	18:57:08	01:44	LINE CLEAR AVAILED
409	03-Jan-24	TUMKUR	220	DAVANGERE SRS- GUTTUR 2	DAVANGERE_SRS_220	17:12:30	18:57:08	01:44	LINE CLEAR AVAILED
410	03-Jan-24	TUMKUR	220	DAVANGERE SRS- GUTTUR 2	DAVANGERE_SRS_220	18:58:18	21:10:26	02:12	TRIPPED ON FAULT
411	03-Jan-24	TUMKUR	220	DAVANGERE SRS- GUTTUR 3	DAVANGERE_SRS_220	17:12:30	18:57:36	01:45	LINE CLEAR AVAILED
412	03-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
413	03-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	15:03	15:52	00:49	TRIPPED ON FAULT
414	03-Jan-24	TUMKUR	220	GUTUR_400-RANEENNUR	GUTUR_400	14:51	15:18	00:27	TRIPPED ON FAULT
415	03-Jan-24	TUMKUR	220	HONNALLI 220kV-BENKIKERE 220 1&2	HONNALLI_220	17:13	19:02	01:49	MAIN SUPPLY FAILURE
416	03-Jan-24	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS 1	HONNALLI_220	17:13	19:09	01:56	MAIN SUPPLY FAILURE
417	03-Jan-24	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS 2	HONNALLI_220	17:13	19:09	01:56	MAIN SUPPLY FAILURE
418	03-Jan-24	TUMKUR	220	HOSADURGA220-BENKIKERE 220KV 2	HOSADURGA_220	17:10	19:05	01:55	MAIN SUPPLY FAILURE
419	03-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18(03.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
420	03-Jan-24	TUMKUR	220	TR-1	BENKIKERE_220	17:13	19:03	01:50	MAIN SUPPLY FAILURE
421	03-Jan-24	TUMKUR	220	TR-1	HOSADURGA_220	17:10	18:15	01:05	MAIN SUPPLY FAILURE
422	03-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVAILED
423	03-Jan-24	TUMKUR	220	TR-2	BENKIKERE_220	17:13	19:03	01:50	MAIN SUPPLY FAILURE
424	03-Jan-24	TUMKUR	220	TR-2	HOSADURGA_220	17:10	18:15	01:05	MAIN SUPPLY FAILURE
425	03-Jan-24	TUMKUR	220	TR-3	KBCROSS_220	09:45	09:46	00:01	TRIPPED ON FAULT
426	03-Jan-24	TUMKUR	220	TR-3	KBCROSS_220	09:51	09:56	00:05	TRIPPED ON FAULT
427	04-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	MALGHAN(B)_110	14:11	14:20	00:09	TRIPPED ON FAULT
428	04-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	MALGHAN(B)_110	11:35	11:55	00:20	TRIPPED ON FAULT
429	04-Jan-24	BAGALKOT	110	110/33KV,HV2(10MVA)	JAMAKHANDI_110	14:59	15:01	00:02	TRIPPED ON FAULT
430	04-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	TODALBAGI_110	14:11	15:20	01:09	LINE CLEAR AVAILED
431	04-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	19:53 (02.01.2024)			TRIPPED ON FAULT
432	04-Jan-24	BAGALKOT	110	ANKOLA-ARGA	ANKOLA_110	12:06	12:13	00:07	TRIPPED ON FAULT
433	04-Jan-24	BAGALKOT	110	ANKOLA-KUMTA2	ANKOLA_110	23:22 (05.01.2024)			TRIPPED ON FAULT
434	04-Jan-24	BAGALKOT	110	ANKOLA-KUMTA2	ANKOLA_110	03:30	08:55	05:25	TRIPPED ON FAULT
435	04-Jan-24	BAGALKOT	110	ANKOLA-KUMTA2	ANKOLA_110	13:30	17:08	03:38	TRIPPED ON FAULT
436	04-Jan-24	BAGALKOT	110	ATHANI220- GHATNATTI	ATHANI_220	13:01	14:44	1:43	LINE CLEAR AVAILED
437	04-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
438	04-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
439	04-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
440	04-Jan-24	BAGALKOT	110	HIDIKAL-MAHALINGAPUR	HIDAKAL_110	12:50	13:05	00:15	LINE CLEAR AVAILED
441	04-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
442	04-Jan-24	BAGALKOT	110	ITNAL-RAIBAG2(KABBUR2)	ITNAL_110	8:03 (03.01.2024)			LINE CLEAR AVAILED
443	04-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
444	04-Jan-24	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
445	04-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
446	04-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
447	04-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
448	04-Jan-24	BAGALKOT	110	MUGALKHOD220- LN3(RAIBAG1)	STATION NOT AFFECTED MUGALKHOD_220	8:03 (03.01.2024)			LINE CLEAR AVOIDED
449	04-Jan-24	BAGALKOT	110	MUGALKHOD220- LN4(RAIBAG2)	STATION NOT AFFECTED MUGALKHOD_220	8:03 (03.01.2024)			LINE CLEAR AVOIDED
450	04-Jan-24	BAGALKOT	110	NAVALAGI- F1(JAMAKHANDI)	NAVALAGI_110	10:55 (03.01.2024)			LINE CLEAR AVOIDED
451	04-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
452	04-Jan-24	BAGALKOT	110	SIRSI-JOG1	SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVOIDED
453	04-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AMBEWADI_220	11:08 (01.01.2024)			LINE CLEAR AVOIDED
454	04-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
455	04-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVOIDED
456	04-Jan-24	BAGALKOT	220	MKHUBLI- NARENDRA1	MK HUBLI_220	10:07	17:28	07:21	LINE CLEAR AVOIDED
457	04-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVOIDED
458	04-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	NARENDRA_220	10:18	18:59	08:41	LINE CLEAR AVOIDED
459	04-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED
460	04-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
461	04-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVOIDED
462	04-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
463	04-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
464	04-Jan-24	BANGALORE	66	CESSNA - EXORA 220	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	11:56	12:04	00:08	LINE CLEAR AVOIDED
465	04-Jan-24	BANGALORE	66	CESSNA - SHOBHA APARTMENT	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	14:28	14:35	00:07	LINE CLEAR AVOIDED
466	04-Jan-24	BANGALORE	66	GUNDAMGERE - SASALU	SASALU	23:05	23:24	00:19	TRIPPED ON FAULT
467	04-Jan-24	BANGALORE	66	HV1	SUGUTUR, K&C VALLEY	12:05	12:37	00:32	LINE CLEAR AVOIDED
468	04-Jan-24	BANGALORE	66	HV1	SUGUTUR, K&C VALLEY	14:00	14:25	00:25	LINE CLEAR AVOIDED
469	04-Jan-24	BANGALORE	66	HV1	ANDERSONPET	12:05	12:07	00:02	LINE CLEAR AVOIDED
470	04-Jan-24	BANGALORE	66	HV1	MARALWADI	13:15	13:25	00:10	LINE CLEAR AVOIDED
471	04-Jan-24	BANGALORE	66	HV1	HOSPALYA CIRCLE	17:00	17:55	00:55	LINE CLEAR AVOIDED
472	04-Jan-24	BANGALORE	66	HV1	CHANNAPATNA	16:03	16:04	00:01	LINE CLEAR AVOIDED
473	04-Jan-24	BANGALORE	66	HV1	TK HALLI	16:20	16:25	00:05	TRIPPED ON FAULT
474	04-Jan-24	BANGALORE	66	HV1	KUMBARANAHALLI	13:05	14:00	00:55	LINE CLEAR AVOIDED
475	04-Jan-24	BANGALORE	66	HV2	ANJANAPURA	12:12	12:20	00:08	LINE CLEAR AVOIDED
476	04-Jan-24	BANGALORE	66	HV2	SOMANATHPURA	10:35	10:40	00:05	LINE CLEAR AVOIDED
477	04-Jan-24	BANGALORE	66	HV2	NANGLI	14:40	14:45	00:05	LINE CLEAR AVOIDED
478	04-Jan-24	BANGALORE	66	HV2	SUGUTUR, K&C VALLEY	14:25	14:30	00:05	LINE CLEAR AVOIDED
479	04-Jan-24	BANGALORE	66	HV2	TEKAL	11:00	14:00	03:00	LINE CLEAR AVOIDED
480	04-Jan-24	BANGALORE	66	HV2	TK HALLI	16:25	16:50	00:25	TRIPPED ON FAULT
481	04-Jan-24	BANGALORE	66	KHB - DG1	NO STATION AFFECTED	14:40	17:06	02:26	TRIPPED ON FAULT
482	04-Jan-24	BANGALORE	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	05:53	06:23	00:30	TRIPPED ON FAULT
483	04-Jan-24	BANGALORE	66	LAKKUR - MALUR 220	LAKKUR, DEVANAGUNDHI	07:05	07:15	00:10	TRIPPED ON FAULT
484	04-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	06:37	06:50	00:13	TRIPPED ON FAULT
485	04-Jan-24	BANGALORE	66	MARALWADI - KANAKAPURA 220	MARALWADI	12:57	13:07	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
486	04-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	18:34	18:40	00:06	TRIPPED ON FAULT
487	04-Jan-24	BANGALORE	66	VICTORIA - NATIONAL COLLEGE	VICTORIA	15:04	15:06	00:02	LINE CLEAR AVAILED
488	04-Jan-24	BANGALORE	66	VR DODDI - SOMANAHALLI 220	VR DODDI	12:05	12:50	00:45	LINE CLEAR AVAILED
489	04-Jan-24	GULBARGA	66	GUDEKOTE-HANGAL	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	20:10(4.1.2024)			TRIPPED ON FAULT
490	04-Jan-24	GULBARGA	66	HANASI-KUDLIGI	HANASI_66,CHILKANHALTTI_66	08:05	09:05	01:00	LINE CLEAR AVAILED
491	04-Jan-24	GULBARGA	66	HANASI-KUDLIGI	HANASI_66,CHILKANHALTTI_66	11:05	11:15	00:10	LINE CLEAR AVAILED
492	04-Jan-24	GULBARGA	66	HV1	NEELAGUNDA_220	01:27	01:37	00:10	TRIPPED ON FAULT
493	04-Jan-24	GULBARGA	66	HV2	HANASI_66	16:20	17:00	00:40	LINE CLEAR AVAILED
494	04-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,GIRIYAPURA_66,MAGALA_66	12:04	12:13	00:09	TRIPPED ON FAULT
495	04-Jan-24	GULBARGA	66	KUDLIGI-BANVEKAL	BANVEKAL_66	08:44	08:55	00:11	LINE CLEAR AVAILED
496	04-Jan-24	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	08:37	09:00	00:23	LINE CLEAR AVAILED
497	04-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
498	04-Jan-24	GULBARGA	66	KUDLIGI-KUDLIGI	KUDLIGI_66	08:44	08:55	00:11	LINE CLEAR AVAILED
499	04-Jan-24	GULBARGA	66	NEELAGUNDA-TELAGI	TELAGI_66,KURBHAHALLI_66,SHAMNUR SUGAR_IPP, GREEN INFR_IPP	07:58	08:11	00:13	TRIPPED ON FAULT
500	04-Jan-24	GULBARGA	110	ALKOD-MALLAT	ALKOD_110,GALAG_110	20:55	21:22	00:27	TRIPPED ON FAULT
501	04-Jan-24	GULBARGA	110	BELLARY NORTH-PDHALLI	MOKA_110,PD_HALLI_110,BI SIHALLI_110,HALKUNDI_110	09:30	14:06	04:36	LINE CLEAR AVAILED
502	04-Jan-24	GULBARGA	110	HV1	ALIPUR_220	16:14	16:51	00:37	LINE CLEAR AVAILED
503	04-Jan-24	GULBARGA	110	HV1	KURDICROSS_110	19:30	19:35	00:05	TRIPPED ON FAULT
504	04-Jan-24	GULBARGA	110	HV2	KEREHALLI_110	16:20	17:00	00:40	LINE CLEAR AVAILED
505	04-Jan-24	GULBARGA	110	HV3	KURUGOD_110	06:00	06:05	00:05	TRIPPED ON FAULT
506	04-Jan-24	GULBARGA	110	HV3	KURUGOD_110	07:20	07:25	00:05	TRIPPED ON FAULT
507	04-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	20:55	21:22	00:27	TRIPPED ON FAULT
508	04-Jan-24	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110, MADLAPUR_110, MANVI_110	18:10	18:15	00:05	TRIPPED ON FAULT
509	04-Jan-24	GULBARGA	110	MANVI-MADALAPUR	MANVI_110	18:10	18:15	00:05	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
510	04-Jan-24	GULBARGA	110	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	16:04	16:14	00:10	TRIPPED ON FAULT
511	04-Jan-24	GULBARGA	220	HV1 AND HV2	MALLAT_220	20:55	21:02	00:07	TRIPPED ON FAULT
512	04-Jan-24	GULBARGA	220	ITTAGGI-EMBASSY	ITTAGGI_220	18:55(3.1.2024)	1:12(4.1.2024)	06:17	LINE CLEAR AVAILED
513	04-Jan-24	HASSAN	66	CRPATNA2-CRPTNA2	CRPATNA_220	15:37	16:11	00:34	LINE CLEAR AVAILED
514	04-Jan-24	HASSAN	66	CRPATNA2-SBL1	CRPATNA_220	08:21	13:13	04:52	TRIPPED ON FAULT
515	04-Jan-24	HASSAN	66	CRPATNA2-SBL2	CRPATNA_220	12:17	13:09	00:52	LINE CLEAR AVAILED
516	04-Jan-24	HASSAN	66	HV1	MATTANAVILE_66	08:22	08:32	00:10	MAIN SUPPLY FAILURE
517	04-Jan-24	HASSAN	66	HV1	SINGAPURA_66	13:35	14:20	00:45	LINE CLEAR AVAILED
518	04-Jan-24	HASSAN	66	HV2	HIRESAVE_66	09:10	11:30	02:20	TRIPPED ON FAULT
519	04-Jan-24	HASSAN	66	HV2	MATTANAVILE_66	08:38	08:48	00:10	MAIN SUPPLY FAILURE
520	04-Jan-24	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	08:22	08:32	00:10	MAIN SUPPLY FAILURE
521	04-Jan-24	HASSAN	66	MATTNAV-CRPATNA	MATTANAVILE_66	08:38	08:48	00:10	LINE CLEAR AVAILED
522	04-Jan-24	HASSAN	66	MATTNAV-DIDGTHL	MATTANAVILE_66	13:10	13:20	00:10	LINE CLEAR AVAILED
523	04-Jan-24	HASSAN	110	MRSSHM-MPM	MRSMSG_220	21:19	22:51	01:32	TRIPPED ON FAULT
524	04-Jan-24	MYSORE	66	DEVNUR(MYS)-VAJAMANGALA	NO STATIONS EFFECTED	12:48	19:21	06:32	LINE CLEAR AVAILED
525	04-Jan-24	MYSORE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	18:58	19:30	00:32	TRIPPED ON FAULT
526	04-Jan-24	MYSORE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	19:31			TRIPPED ON FAULT
527	04-Jan-24	MYSORE	66	FTS-RAJEEV NAGARA	DEVANOORMYS_66 RAJEEVNAGARA_66	18:58	19:36	00:38	TRIPPED ON FAULT
528	04-Jan-24	MYSORE	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	19:37			TRIPPED ON FAULT
529	04-Jan-24	MYSORE	66	HOOTAGALLI-BARC 1	NO STATIONS EFFECTED	18:30	20:25	01:55	TRIPPED ON FAULT
530	04-Jan-24	MYSORE	66	HV1	BANNUR_66	08:47	23:25	14:38	LINE CLEAR AVAILED
531	04-Jan-24	MYSORE	66	HV1	DKMAIDANA_66	18:04	18:15	00:10	TRIPPED ON FAULT
532	04-Jan-24	MYSORE	66	HV1	HANGLA_66	11:05	11:30	00:25	LINE CLEAR AVAILED
533	04-Jan-24	MYSORE	66	HV1	RAVANDUR_66	22:05	22:15	00:10	TRIPPED ON FAULT
534	04-Jan-24	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	06:30	06:33	00:03	TRIPPED ON FAULT
535	04-Jan-24	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	16:49	16:56	00:06	TRIPPED ON FAULT
536	04-Jan-24	TUMKUR	66	ANCHEPALYA 220KV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	14:53	15:03	00:10	TRIPPED ON FAULT
537	04-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66	05:57	06:18	00:21	TRIPPED ON FAULT
538	04-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	14:20	14:36	00:16	MAIN SUPPLY FAILURE
539	04-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	17:45	17:50	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
540	04-Jan-24	TUMKUR	66	ANTHRASANAHALI 220KV-TUMKUR	TUMKUR_66	14:15	16:20	02:05	TRIPPED ON FAULT
541	04-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	8:52(21.11.2023)			LINE CLEAR AVAILED
542	04-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 1	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:25	11:39	00:14	LINE CLEAR AVAILED
543	04-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:25	11:39	00:14	LINE CLEAR AVAILED
544	04-Jan-24	TUMKUR	66	DAVANGERE SRS-OBAJJIHALLI_66	OBAJJIHALLI_66	07:55	08:00	00:05	TRIPPED ON FAULT
545	04-Jan-24	TUMKUR	66	DAVANGERE SRS-OBAJJIHALLI_66	OBAJJIHALLI_66	08:00	14:25	06:25	LINE CLEAR AVAILED
546	04-Jan-24	TUMKUR	66	GARAGA66-MATHOD66	GARAGA_66,PANCHANAHALI_66	10:50	11:00	00:10	MAIN SUPPLY FAILURE
547	04-Jan-24	TUMKUR	66	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	20:10	22:30	02:20	TRIPPED ON FAULT
548	04-Jan-24	TUMKUR	66	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	22:30(04.01.2024)	1:48(05.01.2024)	3 HR 18 MIN	LINE CLEAR AVAILED
549	04-Jan-24	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	01:55	04:19	02:24	TRIPPED ON FAULT
550	04-Jan-24	TUMKUR	66	HIRIYUR 220KV- DASUDI_66	DASUDI_66	09:05	09:20	00:15	MAIN SUPPLY FAILURE
551	04-Jan-24	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	06:35	06:53	00:18	TRIPPED ON FAULT
552	04-Jan-24	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:10	16:22	00:12	LINE CLEAR AVAILED
553	04-Jan-24	TUMKUR	66	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66, PDKOTE_66	16:53	16:58	00:05	LINE CLEAR AVAILED
554	04-Jan-24	TUMKUR	66	HONNALLI 220kV-LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:33	16:43	00:10	TRIPPED ON FAULT
555	04-Jan-24	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66,BASAVAPATNA_66,SHAGALE_66	11:25	11:38	00:13	MAIN SUPPLY FAILURE
556	04-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50(03.01.2024)			MAIN SUPPLY FAILURE
557	04-Jan-24	TUMKUR	66	RANGANATHAPURA-HIRIYUR	RANGANATHAPURA_66	06:35	07:00	00:25	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
558	04-Jan-24	TUMKUR	66	SASALUHALLA-CHIKKAJAJUR	SASALUHALLA_66	12:40	12:55	00:15	MAIN SUPPLY FAILURE
559	04-Jan-24	TUMKUR	66	SHYAGALE_66-KEREBILCHI_66 W/W	SHYAGALE_66	11:25	11:38	00:13	MAIN SUPPLY FAILURE
560	04-Jan-24	TUMKUR	66	TIPTUR110-HALKURKE_110	HALKURKE_110	06:00	06:30	00:30	MAIN SUPPLY FAILURE
561	04-Jan-24	TUMKUR	66	TR-1	TUMKUR_66	14:20	14:47	00:27	MAIN SUPPLY FAILURE
562	04-Jan-24	TUMKUR	66	TR-1	BELLAVI_66	04:24	04:53	00:29	TRIPPED ON FAULT
563	04-Jan-24	TUMKUR	66	TR-1	BELLAVI_66	12:00	12:35	00:35	LINE CLEAR AVOIDED
564	04-Jan-24	TUMKUR	66	TR-1	BILCHODU_66	12:25	12:35	00:10	TRIPPED ON FAULT
565	04-Jan-24	TUMKUR	66	TR-1	CHITRADURGA_66	15:24	16:13	00:49	LINE CLEAR AVOIDED
566	04-Jan-24	TUMKUR	66	TR-2	TUMKUR_66	14:20	14:36	00:16	MAIN SUPPLY FAILURE
567	04-Jan-24	TUMKUR	66	TR-2	BELLAVI_66	11:35	12:35	01:00	LINE CLEAR AVOIDED
568	04-Jan-24	TUMKUR	66	TR-2	CHITRADURGA_66	12:23	14:13	01:50	LINE CLEAR AVOIDED
569	04-Jan-24	TUMKUR	66	TR-2	MADADAKERE_66	23:05	23:10	00:05	TRIPPED ON FAULT
570	04-Jan-24	TUMKUR	110	HULIYAR- K B CROSS	HULIYAR_110,	06:00	06:30	00:30	MAIN SUPPLY FAILURE
571	04-Jan-24	TUMKUR	110	KB CROSS 220kV-TURUVEKERE_110	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	08:06	08:19	00:13	TRIPPED ON FAULT
572	04-Jan-24	TUMKUR	110	TR-1	TURUVEKERE_110	08:24:03	08:48:01	00:23	TRIPPED ON FAULT
573	04-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVOIDED
574	04-Jan-24	TUMKUR	220	KB CROSS 220kV-SHIMOGA1	KBCROSS_220	05:56	06:25	00:29	TRIPPED ON FAULT
575	04-Jan-24	TUMKUR	220	NITTUR 220kV-HASSAN(ARASIKERE)	NITTUR_220	10:18	14:19	04:01	LINE CLEAR AVOIDED
576	04-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18(03.01.2024)			LINE CLEAR AVOIDED
577	04-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVOIDED
578	05-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	10:06	14:15	04:09	LINE CLEAR AVOIDED
579	05-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	UCHAGOAN_110	15:10	19:04	03:54	LINE CLEAR AVOIDED
580	05-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	HOSAHONNATTI_110	10:06	14:15	04:09	LINE CLEAR AVOIDED
581	05-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	UCHAGOAN_110	11:35	13:34	01:59	LINE CLEAR AVOIDED
582	05-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANGAL_110	17:38	17:46	00:08	TRIPPED ON FAULT
583	05-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	KIRUVATTI_110	11:12	11:38	00:26	LINE CLEAR AVOIDED
584	05-Jan-24	BAGALKOT	110	110/33KV,HV3(10MVA)	HOSAHONNATTI_110	10:06	14:15	04:09	LINE CLEAR AVOIDED
585	05-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	LAXMESHVAR_110	11:11	11:30	00:19	TRIPPED ON FAULT
586	05-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	HANGAL_110	17:38	17:46	00:08	TRIPPED ON FAULT
587	05-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	19:53 (02.01.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
588	05-Jan-24	BAGALKOT	110	ANKOLA-KUMTA2	ANKOLA_110	23:22 (04.01.2024)	18:11 (05.01.2024)	18:49:00	TRIPPED ON FAULT
589	05-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
590	05-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
591	05-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
592	05-Jan-24	BAGALKOT	110	HOSAHONNATTI-F1(RANEENNUR)	HOSAHONNATTI_110	10:08	14:15	04:07	LINE CLEAR AVAILED
593	05-Jan-24	BAGALKOT	110	HOSAHONNATTI-F2(AREMALLAPUR)	HOSAHONNATTI_110	10:08	14:15	04:07	LINE CLEAR AVAILED
594	05-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
595	05-Jan-24	BAGALKOT	110	ITNAL-RAIBAG2(KABBUR2)	ITNAL_110	8:03 (03.01.2024)	15:32 (05.01.2024)	55:29:00	LINE CLEAR AVAILED
596	05-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
597	05-Jan-24	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED
598	05-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
599	05-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
600	05-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
601	05-Jan-24	BAGALKOT	110	MUGALKHOD220-LN3(RAIBAG1)	STATION NOT AFFECTED MUGALKHOD_220	8:03 (03.01.2024)	15:32 (05.01.2024)	55:29:00	LINE CLEAR AVAILED
602	05-Jan-24	BAGALKOT	110	MUGALKHOD220-LN4(RAIBAG2)	STATION NOT AFFECTED MUGALKHOD_220	8:03 (03.01.2024)	15:30 (05.01.2024)	55:27:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
603	05-Jan-24	BAGALKOT	110	MUGALKHOD220-LN12(PG HUNSHYAL)	STATION NOT AFFECTED MUGALKHOD_220	01:27	01:40	00:13	TRIPPED ON FAULT
604	05-Jan-24	BAGALKOT	110	NAVALAGI-F1(JAMAKHANDI)	NAVALAGI_110	10:55 (03.01.2024)	12:19 (05.01.2024)	49:24:00	LINE CLEAR AVOIDED
605	05-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
606	05-Jan-24	BAGALKOT	110	RANEBENNUR220-HONNATTI	STATION NOT AFFECTED RANEBENNUR_220	10:28	14:13	03:45	LINE CLEAR AVOIDED
607	05-Jan-24	BAGALKOT	110	SIRSI-JOG1	SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVOIDED
608	05-Jan-24	BAGALKOT	110	SULTANPUR-F1(KABBUR)	SULTANPUR_110	12:36 (18.11.2023)	14:36 (05.1.2024)	1154:00:00	LINE CLEAR AVOIDED
609	05-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AMBEWADI_220	11:08 (01.01.2024)	14:42 (05.01.2024)	99:34:00	LINE CLEAR AVOIDED
610	05-Jan-24	BAGALKOT	220	AMBEWADI- PONDA2	STATION NOT AFFECTED AMBEWADI_220	13:29	17:32	04:03	LINE CLEAR AVOIDED
611	05-Jan-24	BAGALKOT	220	BAGEWADI- RBRK	STATION NOT AFFECTED BAGEWADI_220	16:28	16:39	00:11	TRIPPED ON FAULT
612	05-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
613	05-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVOIDED
614	05-Jan-24	BAGALKOT	220	MK HUBLI-NARENDRA2	STATION NOT AFFECTED MK HUBLI_220	10:50	17:44	06:54	LINE CLEAR AVOIDED
615	05-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVOIDED
616	05-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	10:37	19:30	08:53	LINE CLEAR AVOIDED
617	05-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
618	05-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
619	05-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
620	05-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
621	05-Jan-24	BANGALORE	66	ATTIBELE - ANEKAL	ATTIBELE	10:45	12:05	01:20	TRIPPED ON FAULT
622	05-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
623	05-Jan-24	BANGALORE	66	BRIGADE METROPOLIS - BRIGADE TECH GARDEN	BRIGADE METROPOLIS	14:22	14:26	00:04	LINE CLEAR AVAILED
624	05-Jan-24	BANGALORE	66	DB PURA 220 - KUNDANA - DEVANAHALLI 1	KUNDANA	17:10	17:24	00:14	TRIPPED ON FAULT
625	05-Jan-24	BANGALORE	66	DB PURA 220 - KUNDANA - DEVANAHALLI 2	DEVANAHALLI 66, BRIGADE ORCHARDS	17:10	17:24	00:14	TRIPPED ON FAULT
626	05-Jan-24	BANGALORE	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	14:20	14:25	00:05	LINE CLEAR AVAILED
627	05-Jan-24	BANGALORE	66	GURUVINAPURA - CNNL(EHT)	CNNL(EHT)	08:50	14:35	05:45	LINE CLEAR AVAILED
628	05-Jan-24	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	HOSKOTE 66, GRINDWELL (EHT)	08:27	08:40	00:13	TRIPPED ON FAULT
629	05-Jan-24	BANGALORE	66	HV1	D CROSS	11:35	11:40	00:05	TRIPPED ON FAULT
630	05-Jan-24	BANGALORE	66	HV1	NG HULKUR	12:20	12:50	00:30	LINE CLEAR AVAILED
631	05-Jan-24	BANGALORE	66	HV1	KODIGEHALI	21:41	21:58	00:17	TRIPPED ON FAULT
632	05-Jan-24	BANGALORE	66	HV1	ATTIBELE	12:10	12:15	00:05	LINE CLEAR AVAILED
633	05-Jan-24	BANGALORE	66	HV1	CHANDAPURA	13:00	13:04	00:04	LINE CLEAR AVAILED
634	05-Jan-24	BANGALORE	66	HV1	YARANDANAHALLI 220	10:46	11:11	00:25	MAIN SUPPLY FAILURE
635	05-Jan-24	BANGALORE	66	HV2	BRIGADE TECH GARDEN	14:35	15:04	00:29	LINE CLEAR AVAILED
636	05-Jan-24	BANGALORE	66	HV2	BRIGADE TECH GARDEN	15:37	15:41	00:04	LINE CLEAR AVAILED
637	05-Jan-24	BANGALORE	66	HV2	SADALI	10:00	10:05	00:05	LINE CLEAR AVAILED
638	05-Jan-24	BANGALORE	66	HV2	YARANDANAHALLI 220	10:46	11:11	00:25	MAIN SUPPLY FAILURE
639	05-Jan-24	BANGALORE	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	18:39	18:45	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
640	05-Jan-24	BANGALORE	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	08:31	08:34	00:03	LINE CLEAR AVAILED
641	05-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 2	MAHALAKSHMI LAYOUT	22:02	22:07	00:05	LINE CLEAR AVAILED
642	05-Jan-24	BANGALORE	66	RAMANAGARA - BEVOOR	BEVOOR, DASHAVARA, SANKALGERE	06:52	07:01	00:09	TRIPPED ON FAULT
643	05-Jan-24	BANGALORE	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	11:48	12:02	00:14	TRIPPED ON FAULT
644	05-Jan-24	BANGALORE	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	09:30	10:20	00:50	TRIPPED ON FAULT
645	05-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - KGF 1	KGF	20:48	20:49	00:01	TRIPPED ON FAULT
646	05-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA L2	TALAGAVADI, MADDUR, KIADB SOMANAHALLI	11:37	11:42	00:05	TRIPPED ON FAULT
647	05-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR, ANEKAL(HV1)	10:46	11:53	01:07	MAIN SUPPLY FAILURE
648	05-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 1	SURYANAGAR, ANEKAL(HV1)	12:06	12:08	00:02	LINE CLEAR AVAILED
649	05-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - ANEKAL 2	ANEKAL, SAMANDURU	10:46	11:37	00:51	TRIPPED ON FAULT
650	05-Jan-24	BANGALORE	220	HV3	YARANDANAHALLI 220	10:46	11:11	00:25	TRIPPED ON FAULT
651	05-Jan-24	GULBARGA	66	GUDEKOTE-HANGAL	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	20:10(4.1.2024)	2:00(5.1.2024)	05:50	TRIPPED ON FAULT
652	05-Jan-24	GULBARGA	66	HV1	CHORNOOR_66	17:00	17:05	00:05	TRIPPED ON FAULT
653	05-Jan-24	GULBARGA	66	HV2	CHORNOOR_66	10:30	10:45	00:15	TRIPPED ON FAULT
654	05-Jan-24	GULBARGA	66	ITTAGGI-RENEW2	ITTAGGI_220	18:06	20:04	01:58	LINE CLEAR AVAILED
655	05-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
656	05-Jan-24	GULBARGA	110	KADECHUR-SAIDAPUR	KADECHUR_110	11:05	14:55	03:50	LINE CLEAR AVAILED
657	05-Jan-24	GULBARGA	110	KEMBHAVI-ASKI	ASKI_110,TALIKOT_110	18:30	18:40	00:10	TRIPPED ON FAULT
658	05-Jan-24	GULBARGA	110	KHANAPUR-RAILWAYSTATION	KHANAPUR_110	05:25	05:30	00:05	TRIPPED ON FAULT
659	05-Jan-24	GULBARGA	110	SHAHAPUR-DEVAPUR	DEVAPUR_110,SHORAPUR_110	01:03	01:10	00:07	TRIPPED ON FAULT
660	05-Jan-24	GULBARGA	110	SHAHAPUR-RAICHUR2	NALWAR_110	23:59(5.1.2024)			TRIPPED ON FAULT
661	05-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	05:15	05:28	00:13	TRIPPED ON FAULT
662	05-Jan-24	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	17:05	17:56	00:51	LINE CLEAR AVAILED
663	05-Jan-24	GULBARGA	220	LINGASUGUR-SINDHANOOR	LINGASUGUR_220	15:15	19:53	04:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
664	05-Jan-24	GULBARGA	220	SHAHAPUR-FEROZABAD2	FEROZABAD_400	13:10	13:31	00:21	LINE CLEAR AVOIDED
665	05-Jan-24	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	06:44	06:56	00:12	TRIPPED ON FAULT
666	05-Jan-24	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB_66	13:54	14:02	00:08	TRIPPED ON FAULT
667	05-Jan-24	HASSAN	66	SOMNHL-HARDNHLLY	SOMANAHALLI_66	06:15	06:30	00:15	TRIPPED ON FAULT
668	05-Jan-24	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	17:50	18:05	00:15	TRIPPED ON FAULT
669	05-Jan-24	HASSAN	110	HGUNJE-LINE6	HGGUNJE_220	16:21	16:42	00:21	TRIPPED ON FAULT
670	05-Jan-24	HASSAN	110	HV1	BANTWAL_110	11:03	14:30	03:27	LINE CLEAR AVOIDED
671	05-Jan-24	HASSAN	110	HV1	HULICAL_110	16:21	16:42	00:21	MAIN SUPPLY FAILURE
672	05-Jan-24	HASSAN	110	HV1	SHIKARIPURA_110	17:32	19:08	01:36	MAIN SUPPLY FAILURE
673	05-Jan-24	HASSAN	110	HV2	ESSUR_110	17:32	19:14	01:42	MAIN SUPPLY FAILURE
674	05-Jan-24	HASSAN	110	HV2	SHIKARIPURA_110	17:32	19:08	01:36	MAIN SUPPLY FAILURE
675	05-Jan-24	HASSAN	110	HV3	SHIRALKOPPA_110	23:25(5.1.2024)			TRIPPED ON FAULT
676	05-Jan-24	HASSAN	110	KITTADA-BLGAVE	KITTADAHALLI_110	17:32	19:05	01:33	MAIN SUPPLY FAILURE
677	05-Jan-24	HASSAN	110	MANIPAL-NITTUR	MANIPAL_110	09:15	11:30	02:15	LINE CLEAR AVOIDED
678	05-Jan-24	HASSAN	110	PUTTUR-PUTTUR2	PUTTUR_220	09:15	13:09	03:54	LINE CLEAR AVOIDED
679	05-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	17:32	19:02	01:30	LINE CLEAR AVOIDED
680	05-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	17:32	19:05	01:33	LINE CLEAR AVOIDED
681	05-Jan-24	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	15:38	17:11	01:33	TRIPPED ON FAULT
682	05-Jan-24	MYSORE	66	DEVNUR(N'GUD)-KADAKOLA	DEVNUR(N'GUD)_66	10:05	17:05	07:00	LINE CLEAR AVOIDED
683	05-Jan-24	MYSORE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	19:31	13:05	17:33:45	TRIPPED ON FAULT
684	05-Jan-24	MYSORE	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	19:37	10:24	14:46:39	TRIPPED ON FAULT
685	05-Jan-24	MYSORE	66	HV1	BANNUR_66	11:07	13:32	02:24	LINE CLEAR AVOIDED
686	05-Jan-24	MYSORE	66	HV1	LOKKANAHALLI_66	16:40	17:20	00:40	LINE CLEAR AVOIDED
687	05-Jan-24	MYSORE	66	HV2	COWDALLI_66	14:51	14:56	00:05	TRIPPED ON FAULT
688	05-Jan-24	MYSORE	66	HV2	HONNALLI_66	14:10	14:25	00:15	TRIPPED ON FAULT
689	05-Jan-24	MYSORE	66	HV2	SINDHUVALI_66	10:53	10:56	00:03	TRIPPED ON FAULT
690	05-Jan-24	MYSORE	66	KK DODDI-MANDYA	MADDUR_66 KIADB SOMANAHALLI_66	11:30	11:45	00:15	TRIPPED ON FAULT
691	05-Jan-24	MYSORE	66	KRNAGAR-BILIKERE	BILIKERE_66 DMG_HALLI_66 GVGUDI_66	14:21	14:36	00:15	TRIPPED ON FAULT
692	05-Jan-24	MYSORE	66	SHIVALLI-TUBINKERE	NAGAMANGALA_66	08:15	08:24	00:08	TRIPPED ON FAULT
693	05-Jan-24	MYSORE	66	SUTTUR-DEVNUR(N'GUD)	SUTTUR_66	10:06	18:18	08:12	LINE CLEAR AVOIDED
694	05-Jan-24	MYSORE	66	TALAKADU-ADANI	NO STATIONS EFFECTED	18:29	23:14	04:45	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
695	05-Jan-24	MYSORE	66	TNPURA-BPCL	NO STATIONS EFFECTED	23:17	23:22	00:05	TRIPPED ON FAULT
696	05-Jan-24	MYSORE	66	VAJMANGALA-DEVNUR(MYS)	NO STATIONS EFFECTED	09:37	10:13	00:36	LINE CLEAR AVAILED
697	05-Jan-24	MYSORE	220	HV1	BEGUR_220	12:35	13:06	00:31	LINE CLEAR AVAILED
698	05-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	15:48	15:58	00:10	TRIPPED ON FAULT
699	05-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:02	11:34	01:32	TRIPPED ON FAULT
700	05-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	15:46	16:13	00:27	TRIPPED ON FAULT
701	05-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	11:55	11:59	00:04	TRIPPED ON FAULT
702	05-Jan-24	TUMKUR	66	CHITRADURGA 220kV-HIREGUNTANUR	HIREGUNTANUR_66, SIRIGERE_66	15:46	16:12	00:26	MAIN SUPPLY FAILURE
703	05-Jan-24	TUMKUR	66	CHITRADURGA 220kV-HIREGUNTANUR	HIREGUNTANUR_66, SIRIGERE_66	16:18	16:39	00:21	MAIN SUPPLY FAILURE
704	05-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 1	CHITRADURGA_66	13:48	14:14	00:26	TRIPPED ON FAULT
705	05-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	8:52(21.11.2023)	12:52(05.01.2024)	42DAYS,3HRS	LINE CLEAR AVAILED
706	05-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	PANDARAHALLI_66	16:18	17:12	00:54	TRIPPED ON FAULT
707	05-Jan-24	TUMKUR	66	DAVANGERE 220KV-KADAJJI_66	KADAJJI_66	14:43	17:43	03:00	TRIPPED ON FAULT
708	05-Jan-24	TUMKUR	66	DAVANGERE 220KV-KADAJJI_66	KADAJJI_66	22:49	23:01	00:12	TRIPPED ON FAULT
709	05-Jan-24	TUMKUR	66	DAVANGERE 220KV-KADAJJI_66	KADAJJI_66	23:13	23:26	00:13	TRIPPED ON FAULT
710	05-Jan-24	TUMKUR	66	DAVANGERE SRS - HARIHARA	HARIHARA_66	10:40	10:43	00:03	LINE CLEAR AVAILED
711	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MAYAKONDA 66	MAYAKONDA_66	07:10	07:20	00:10	TRIPPED ON FAULT
712	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	10:43	15:05	04:22	TRIPPED ON FAULT
713	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	15:26	17:43	02:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
714	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	20:05	20:15	00:10	TRIPPED ON FAULT
715	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	22:49	23:03	00:14	TRIPPED ON FAULT
716	05-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE66	MELLEKATTE_66, SOKKE_66	23:13	23:26	00:13	TRIPPED ON FAULT
717	05-Jan-24	TUMKUR	66	HANAGAL- B G KERE(GUDIKOTE)	BGKERE_66,GUDEKOTE_66	22:30(04.01.2024)	1:48(05.01.2024)	3 HR 18 MIN	LINE CLEAR AVAILED
718	05-Jan-24	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:50	18:55	00:05	LINE CLEAR AVAILED
719	05-Jan-24	TUMKUR	66	MADANAYAKANAHALLI-TURUVANUR	MADANAYAKANAHALLI_66,	11:55	11:58	00:03	MAIN SUPPLY FAILURE
720	05-Jan-24	TUMKUR	66	MADHUGIRI 220kV-NITRAHALLI	NITRAHALLI_66	12:01	12:03	00:02	LINE CLEAR AVAILED
721	05-Jan-24	TUMKUR	66	PANDARAHALLI _66-H.D.PURA_66	H D PURA_66,CHITRALI_66	06:43	06:58	00:15	MAIN SUPPLY FAILURE
722	05-Jan-24	TUMKUR	66	PANDARAHALLI _66-H.D.PURA_66	H D PURA_66,CHITRALI_66	11:35	12:50	01:15	MAIN SUPPLY FAILURE
723	05-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50(03.01.2024)			MAIN SUPPLY FAILURE
724	05-Jan-24	TUMKUR	66	SHYAGALE_66-KEREBILCHI_66 W/W	SHYAGALE_66	12:00	12:05	00:05	TRIPPED ON FAULT
725	05-Jan-24	TUMKUR	66	TAVAREKERE _66SIRA_220	TAVAREKERE_66	10:28	13:43	03:15	LINE CLEAR AVAILED
726	05-Jan-24	TUMKUR	66	TR-1	ANCHEPALYA_66	04:20	04:30	00:10	TRIPPED ON FAULT
727	05-Jan-24	TUMKUR	66	TR-2	MADADAKERE_66	02:35	02:45	00:10	TRIPPED ON FAULT
728	05-Jan-24	TUMKUR	66	TR-2	MADADAKERE_66	09:30	09:35	00:05	TRIPPED ON FAULT
729	05-Jan-24	TUMKUR	66	TR-2	CHITRADURGA_66	11:10	11:42	00:32	LINE CLEAR AVAILED
730	05-Jan-24	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	11:55	11:58	00:03	MAIN SUPPLY FAILURE
731	05-Jan-24	TUMKUR	110	KB CROSS 220kV-AMMASANDRA_110	AMMASANDRA_110,SAMPIGE_110	11:09	11:27	00:18	LINE CLEAR AVAILED
732	05-Jan-24	TUMKUR	110	KB CROSS 220kV-AMMASANDRA_110	AMMASANDRA_110,SAMPIGE_110	14:01	14:20	00:19	LINE CLEAR AVAILED
733	05-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
734	05-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18(03.01.2024)			LINE CLEAR AVAILED
735	05-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVAILED
736	06-Jan-24	BAGALKOT	110	110/11KV, HV2 (20MVA)	STATION NOT AFFECTED PH COMPOUND_110	10:00	13:43	03:43	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
737	06-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	MK HUBLI_110	18:29	18:50	00:21	TRIPPED ON FAULT
738	06-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	HALIYAL_110	23:35	23:55	00:20	TRIPPED ON FAULT
739	06-Jan-24	BAGALKOT	110	ALBAL-ALAGUR	STATION NOT AFFECTED ALBAL_110	19:53 (02.01.2024)	15:15 (06.01.2024)	91:22:00	TRIPPED ON FAULT
740	06-Jan-24	BAGALKOT	110	AMBEWADI-NK -2 (KAVALWADA)	AMBEWADI_220	22:59	23:09	00:10	TRIPPED ON FAULT
741	06-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
742	06-Jan-24	BAGALKOT	110	CHIKODI220 -RAIBAG 1	CHIKODI_220	11:40	17:10	05:30	LINE CLEAR AVAILED
743	06-Jan-24	BAGALKOT	110	CHIKODI220 -RAIBAG 2	CHIKODI_220	11:40	17:10	05:30	LINE CLEAR AVAILED
744	06-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
745	06-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
746	06-Jan-24	BAGALKOT	110	HIREBAGEWADI-SUVARNA SOUDA	HIREBAGEWADI_110	12:50 (06.01.2024)			TRIPPED ON FAULT
747	06-Jan-24	BAGALKOT	110	HUBLI220- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
748	06-Jan-24	BAGALKOT	110	ITNAL_KABBUR2	ITNAL_110	15:45	18:53	03:08	LINE CLEAR AVAILED
749	06-Jan-24	BAGALKOT	110	ITNAL-RAIBAG2(KABBUR1)	ITNAL_110	15:45	18:53	03:08	LINE CLEAR AVAILED
750	06-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
751	06-Jan-24	BAGALKOT	110	KADANAKOPPA- KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED
752	06-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
753	06-Jan-24	BAGALKOT	110	MAHALINGAPUR- DAVALESHWAR	MAHALINGAPUR_220	11:05	15:35	04:30	LINE CLEAR AVAILED
754	06-Jan-24	BAGALKOT	110	MAHALINGAPUR-ITNAL	MAHALINGAPUR_220	11:05	15:35	04:30	LINE CLEAR AVAILED
755	06-Jan-24	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	MAHALINGAPUR_220	15:20	15:35	00:15	LINE CLEAR AVAILED
756	06-Jan-24	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	MK HUBLI_220	14:25	21:08	06:43	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
757	06-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
758	06-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
759	06-Jan-24	BAGALKOT	110	MUDDEBIHAL-KNMSOLAR(HIREMURAL)	HIREMURAL_110 KNM SOLAR_110	21:35	21:37	00:02	TRIPPED ON FAULT
760	06-Jan-24	BAGALKOT	110	MUGALKHOD220-LN1 (RAIBAG1)	STATION NOT AFFECTED MUGALKHOD_220	11:17	11:23	00:06	LINE CLEAR AVAILED
761	06-Jan-24	BAGALKOT	110	MUGALKHOD220-LN2 (RAIBAG2)	STATION NOT AFFECTED MUGALKHOD_220	11:18	11:23	00:05	LINE CLEAR AVAILED
762	06-Jan-24	BAGALKOT	110	MUGALKHOD220-LN3 & LN4 (ITNAL-1&2)	STATION NOT AFFECTED MUGALKHOD_220	15:45	18:53	03:08	LINE CLEAR AVAILED
763	06-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
764	06-Jan-24	BAGALKOT	110	SIRSI-JOG1	SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
765	06-Jan-24	BAGALKOT	110	SUARNAS-HIRE BAGEWADI I	STATION NOT AFFECTED SUARNASOUDHA_110	13:29 (06.01.2023)			LINE CLEAR AVAILED
766	06-Jan-24	BAGALKOT	220	220/110KV,HV3	MAHALINGAPUR_220	15:15	15:30	00:15	TRIPPED ON FAULT
767	06-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	02:29	12:36	10:07	TRIPPED ON FAULT
768	06-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
769	06-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
770	06-Jan-24	BAGALKOT	220	HAVERI-GUTTUR2	HAVERI_220	00:48	11:45	10:57	TRIPPED ON FAULT
771	06-Jan-24	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	11:24	13:37	02:13	LINE CLEAR AVAILED
772	06-Jan-24	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	16:25	20:00	03:35	TRIPPED ON FAULT
773	06-Jan-24	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	20:08 (06.1.2024)		03:52	TRIPPED ON FAULT
774	06-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
775	06-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED
776	06-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	02:30	12:36	10:06	TRIPPED ON FAULT
777	06-Jan-24	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	16:26	20:00	03:34	TRIPPED ON FAULT
778	06-Jan-24	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	20:08 (06.01.2024)			TRIPPED ON FAULT
779	06-Jan-24	BAGALKOT	220	NARENDRA-KANABARGI2	NARENDRA_220	10:59	19:03	08:04	LINE CLEAR AVOIDED
780	06-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVOIDED
781	06-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVOIDED
782	06-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
783	06-Jan-24	BAGALKOT	220	VAJRAMATTI220-ENERCON	VAJRAMATTI_220	19:11	19:19	00:08	LINE CLEAR AVOIDED
784	06-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
785	06-Jan-24	BANGALORE	66	BAGEPALLI - GULUR	NO STATION AFFECTED	06:30	06:50	00:20	TRIPPED ON FAULT
786	06-Jan-24	BANGALORE	66	BAGHMANE TECH PARK - HOODY 2	BAGHMANE TECH PARK	11:46	12:09	00:23	LINE CLEAR AVOIDED
787	06-Jan-24	BANGALORE	66	BAGHMANE WORLD TECH PARK - HOODY 1 & 2	BAGHMANE WORLD TECH PARK	10:44	10:51	00:07	LINE CLEAR AVOIDED
788	06-Jan-24	BANGALORE	66	BRIGADE METROPOLIS - BRIGADE TECH GARDEN	BRIGADE METROPOLIS	05:18	05:24	00:06	LINE CLEAR AVOIDED
789	06-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA	13:56	14:06	00:10	LINE CLEAR AVOIDED
790	06-Jan-24	BANGALORE	66	CHIKKENAHALLI - CHANNAPATNA	SHIVANAHALLI, VANDARGUPPE	10:01	12:30	02:29	LINE CLEAR AVOIDED
791	06-Jan-24	BANGALORE	66	HAL 220 - ADUGODI 1	LEELA VENTURE	11:47	12:04	00:17	LINE CLEAR AVOIDED
792	06-Jan-24	BANGALORE	66	HAL 220 - HOODY 1	ISRO (EHT), NAL	11:46	12:06	00:20	LINE CLEAR AVOIDED
793	06-Jan-24	BANGALORE	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	11:46	12:08	00:22	LINE CLEAR AVOIDED
794	06-Jan-24	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:05	11:35	00:30	LINE CLEAR AVOIDED
795	06-Jan-24	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	09:40	10:14	00:34	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
796	06-Jan-24	BANGALORE	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	11:03	11:30	00:27	LINE CLEAR AVAILED
797	06-Jan-24	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	HOSKOTE 66, GRINDWELL (EHT)	08:54	09:25	00:31	TRIPPED ON FAULT
798	06-Jan-24	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	10:04	11:01	00:57	LINE CLEAR AVAILED
799	06-Jan-24	BANGALORE	66	HV1	BANASAWADI	13:55	14:00	00:05	LINE CLEAR AVAILED
800	06-Jan-24	BANGALORE	66	HV1	BANASAWADI	17:47	17:52	00:05	LINE CLEAR AVAILED
801	06-Jan-24	BANGALORE	66	HV1	BYADRAHALLI	12:40	12:42	00:02	LINE CLEAR AVAILED
802	06-Jan-24	BANGALORE	66	HV1	RMV	11:20	11:25	00:05	LINE CLEAR AVAILED
803	06-Jan-24	BANGALORE	66	HV1	HAL 220	11:46	12:03	00:17	LINE CLEAR AVAILED
804	06-Jan-24	BANGALORE	66	HV1	HOODY 220	11:08	11:27	00:19	LINE CLEAR AVAILED
805	06-Jan-24	BANGALORE	66	HV1	HOODY 220	09:24	09:34	00:10	LINE CLEAR AVAILED
806	06-Jan-24	BANGALORE	66	HV1	MAASTHI	17:00	18:00	01:00	LINE CLEAR AVAILED
807	06-Jan-24	BANGALORE	66	HV1	HUKINDA	09:20	09:25	00:05	TRIPPED ON FAULT
808	06-Jan-24	BANGALORE	66	HV1	DABUSPETE 220	21:04	21:16	00:12	TRIPPED ON FAULT
809	06-Jan-24	BANGALORE	66	HV1	YARANDANAHALLI 220	16:06	16:16	00:10	TRIPPED ON FAULT
810	06-Jan-24	BANGALORE	66	HV2	RMV	15:22	15:25	00:03	LINE CLEAR AVAILED
811	06-Jan-24	BANGALORE	66	HV2	HAL 220	11:46	12:03	00:17	LINE CLEAR AVAILED
812	06-Jan-24	BANGALORE	66	HV2	KADUBISANAHALLI	12:55	13:00	00:05	LINE CLEAR AVAILED
813	06-Jan-24	BANGALORE	66	HV2	RR NAGAR	16:41	17:28	00:47	TRIPPED ON FAULT
814	06-Jan-24	BANGALORE	66	HV2	NANDIGANAHALLI	09:45	09:47	00:02	LINE CLEAR AVAILED
815	06-Jan-24	BANGALORE	66	HV2	NANGLI	20:45	21:14	00:29	TRIPPED ON FAULT
816	06-Jan-24	BANGALORE	66	HV2	CHANDRAPPA CIRCLE	05:27	05:33	00:06	TRIPPED ON FAULT
817	06-Jan-24	BANGALORE	66	HV2	BEVOOR	13:02	13:05	00:03	LINE CLEAR AVAILED
818	06-Jan-24	BANGALORE	66	HV3	BANASAWADI	13:55	14:00	00:05	LINE CLEAR AVAILED
819	06-Jan-24	BANGALORE	66	HV3	BANASAWADI	17:47	17:52	00:05	LINE CLEAR AVAILED
820	06-Jan-24	BANGALORE	66	K&C VALLEY - KORAMANGALA 220	K&C VALLEY	10:34	10:39	00:05	LINE CLEAR AVAILED
821	06-Jan-24	BANGALORE	66	K&C VALLEY - KORAMANGALA 220	K&C VALLEY	20:07	20:12	00:05	LINE CLEAR AVAILED
822	06-Jan-24	BANGALORE	66	KENGERI SATELLITE TOWN - KUMBALAGODU 2	KENGERI SATELLITE TOWN	06:11	06:16	00:05	LINE CLEAR AVAILED
823	06-Jan-24	BANGALORE	66	NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA	14:34	14:35	00:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
824	06-Jan-24	BANGALORE	66	NRS DB PURA 220 - APPAREL PARK - D CROSS 3	DODDABELAVANGALA	14:43	14:45	00:02	LINE CLEAR AVAILED
825	06-Jan-24	BANGALORE	66	NRS DB PURA 220 - D CROSS 2	AIR(EHT)	14:34	14:35	00:01	LINE CLEAR AVAILED
826	06-Jan-24	BANGALORE	66	NRS DB PURA 220 - D CROSS 2	AIR(EHT)	14:43	14:45	00:02	LINE CLEAR AVAILED
827	06-Jan-24	BANGALORE	66	RAMANAGARA - BEVOOR	BEVOOR, SANKALGERE, DASHAVARA	10:05	12:51	02:46	LINE CLEAR AVAILED
828	06-Jan-24	BANGALORE	66	RMV - TATA INSTITUTE(EHT)	TATA INSTITUTE(EHT)	14:03	14:55	00:52	LINE CLEAR AVAILED
829	06-Jan-24	BANGALORE	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	09:40	09:44	00:04	LINE CLEAR AVAILED
830	06-Jan-24	BANGALORE	66	SHIVANAHALLI - KOTHIPURA 220	SHIVANAHALLI, VANDARGUPPE	13:56	14:06	00:10	LINE CLEAR AVAILED
831	06-Jan-24	BANGALORE	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	10:20	10:30	00:10	LINE CLEAR AVAILED
832	06-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	RR NAGAR, GLOBAL VILLAGE(EHT)	15:48	16:46	00:58	LINE CLEAR AVAILED
833	06-Jan-24	BANGALORE	66	VRISHABHAVATHI 220 - RR NAGAR	RR NAGAR	13:43	14:05	00:22	TRIPPED ON FAULT
834	06-Jan-24	BANGALORE	220	NRS DB PURA 220 - KIADB DB PURA 220	KIADB DB PURA 220	13:46	15:01	01:15	TRIPPED ON FAULT
835	06-Jan-24	BANGALORE	220	SRS PEENYA 220 - NRS 220	NO STATION AFFECTED	13:43	14:16	00:33	TRIPPED ON FAULT
836	06-Jan-24	BANGALORE	220	SRS PEENYA 220 - SAHAKARINAGAR 220	NO STATION AFFECTED	13:43	14:16	00:33	TRIPPED ON FAULT
837	06-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
838	06-Jan-24	GULBARGA	110	HV3	SOMASAMUNDRA_110	02:33	02:41	00:08	TRIPPED ON FAULT
839	06-Jan-24	GULBARGA	110	HV3	SIRIGUPPA_110	10:00	18:00	08:00	LINE CLEAR AVAILED
840	06-Jan-24	GULBARGA	110	KAPNOOR-MAHAGOAN	MAHAGOAN-MARGUTTI	12:19	12:47	00:28	TRIPPED ON FAULT
841	06-Jan-24	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110, MANVI_110, ADVI AMARESHWAR_110	03:19	03:24	00:05	TRIPPED ON FAULT
842	06-Jan-24	GULBARGA	110	MUNIRABAD-DONIMALAI	DONIMALAI_110,STAR METALLIC_IPP	06:54	07:09	00:15	TRIPPED ON FAULT
843	06-Jan-24	GULBARGA	110	MUNIRABAD-SANKLAPUR	SANKALAPUR_110,RBSNN_FACTORY,KAMALAPUR_110 ,TORANGALLU_110,KUDTINI_110	06:17	06:26	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
844	06-Jan-24	GULBARGA	110	SHAHAPUR-RAICHUR2	NALWAR_110	23:59(5.1.2024)	0:10(06.1.2024)	00:11	TRIPPED ON FAULT
845	06-Jan-24	GULBARGA	110	SHORAPUR-YADGIR	SHORAPUR_110,DEVAPUR_110	16:13	16:16	00:03	LINE CLEAR AVAILED
846	06-Jan-24	GULBARGA	110	SHORAPUR-YADGIR	SHORAPUR_110,DEVAPUR_110	19:25	19:31	00:06	LINE CLEAR AVAILED
847	06-Jan-24	GULBARGA	110	SINDHANOOR-SR NAGAR	KARATAGI_110	05:38	05:48	00:10	TRIPPED ON FAULT
848	06-Jan-24	GULBARGA	110	SINDHANOOR-WALABALLARY	WALABALLARY_110, JAWALGERA_110	01:18	01:38	00:20	TRIPPED ON FAULT
849	06-Jan-24	GULBARGA	220	ITTAGGI-EMBASSY	ITTAGGI_220	20:30(6.1.2024)			LINE CLEAR AVAILED
850	06-Jan-24	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	16:23	19:45	03:22	LINE CLEAR AVAILED
851	06-Jan-24	GULBARGA	220	MALLAT-RTPS	MALLAT_220	12:50	15:49	02:59	LINE CLEAR AVAILED
852	06-Jan-24	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	22:18	22:25	00:07	TRIPPED ON FAULT
853	06-Jan-24	HASSAN	66	HIREMAN-CHIKAMANGALUR	HIREMAGALUR_66	11:12	11:40	00:28	LINE CLEAR AVAILED
854	06-Jan-24	HASSAN	66	HV1	HASSAN_66	18:43(6.1.2024)			TRIPPED ON FAULT
855	06-Jan-24	HASSAN	66	HV1	CHIKMAGALUR_66	11:19	11:43	00:24	LINE CLEAR AVAILED
856	06-Jan-24	HASSAN	66	HV1	RAMNATHPURA_66	06:00	18:45	12:45	LINE CLEAR AVAILED
857	06-Jan-24	HASSAN	66	HV2	CHIKMAGALUR_66	11:19	11:43	00:24	LINE CLEAR AVAILED
858	06-Jan-24	HASSAN	66	HV2	HALEBEEDU_66	12:36	12:46	00:10	LINE CLEAR AVAILED
859	06-Jan-24	HASSAN	110	HV1	SHIRALKOPPA_110	23:25(5.1.2024)	00:05(6.1.2024)	0:40HRS	LINE CLEAR AVAILED
860	06-Jan-24	HASSAN	110	HV1	SHIRALKOPPA_110	06:20	07:20	01:00	TRIPPED ON FAULT
861	06-Jan-24	HASSAN	110	HV1	ALKOLA_110	10:00	12:40	02:40	LINE CLEAR AVAILED
862	06-Jan-24	HASSAN	110	HV2	ALKOLA_110	10:00	12:40	02:40	LINE CLEAR AVAILED
863	06-Jan-24	HASSAN	110	HV3	ALKOLA_110	10:00	12:40	02:40	LINE CLEAR AVAILED
864	06-Jan-24	HASSAN	110	SHRLKP-KITTADAHLY	SHIRALKOPPA_220	14:49	15:55	01:06	TRIPPED ON FAULT
865	06-Jan-24	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	11:05	17:45	06:40	LOAD CURTAILMENT
866	06-Jan-24	HASSAN	220	HV1	MSEZ_220	10:20	13:19	02:59	LINE CLEAR AVAILED
867	06-Jan-24	HASSAN	220	LV1	MSEZ_220	10:20	13:19	02:59	LINE CLEAR AVAILED
868	06-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:00(6.01.2024)			LINE CLEAR AVAILED
869	06-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:41(6.01.2024)			LINE CLEAR AVAILED
870	06-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:00(6.01.2024)			LINE CLEAR AVAILED
871	06-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:41(6.01.2024)			LINE CLEAR AVAILED
872	06-Jan-24	MYSORE	66	DODDINDUVADI-KOTTANUR	NO STATIONS EFFECTED	06:10	06:20	00:10	TRIPPED ON FAULT
873	06-Jan-24	MYSORE	66	HAMPAPURA(K) - KODAKOLA	NO STATIONS EFFECTED	10:10	11:30	01:20	LINE CLEAR AVAILED
874	06-Jan-24	MYSORE	66	HV1	CHIKKAMANDYA_66	10:40	13:35	02:55	LINE CLEAR AVAILED
875	06-Jan-24	MYSORE	66	HV1	HOSURGATE_66	15:40	19:30	03:50	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
876	06-Jan-24	MYSORE	66	HV1	SUNTIKOPPA_66	14:17	14:30	00:13	LINE CLEAR AVAILED
877	06-Jan-24	MYSORE	66	HV1	SUNTIKOPPA_66	14:43	14:53	00:10	LINE CLEAR AVAILED
878	06-Jan-24	MYSORE	66	HV1	BEGUR_66	15:50	17:35	01:45	LINE CLEAR AVAILED
879	06-Jan-24	MYSORE	66	HV1	AYRAHALLI_66	17:30	17:40	00:10	TRIPPED ON FAULT
880	06-Jan-24	MYSORE	66	HV2	HULLAHALLI_66	16:03	16:08	00:05	TRIPPED ON FAULT
881	06-Jan-24	MYSORE	66	HV2	SUNTIKOPPA_66	14:17	14:30	00:13	LINE CLEAR AVAILED
882	06-Jan-24	MYSORE	66	HV2	SUNTIKOPPA_66	14:43	14:53	00:10	LINE CLEAR AVAILED
883	06-Jan-24	MYSORE	66	JAKKANAHALLI-NAGMANGLA	GMALLIGERE_66	13:09	17:19	04:10	TRIPPED ON FAULT
884	06-Jan-24	MYSORE	66	KR PETE-AKKIHEBBAL 1	NO STATIONS EFFECTED	17:41	17:55	00:14	TRIPPED ON FAULT
885	06-Jan-24	MYSORE	66	KUSHALNAGAR-SOMWARPETE	SOMWARPETE_33	18:35	18:49	00:13	TRIPPED ON FAULT
886	06-Jan-24	MYSORE	66	SANTHESARGUR-HAMPAPURA	ANATRSANTE_66 HDKOTE_66 YARAHALLI HANDPOST_66	22:13	22:21	00:08	TRIPPED ON FAULT
887	06-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	08:15	08:25	00:10	TRIPPED ON FAULT
888	06-Jan-24	TUMKUR	66	HV1(TR1)	BALENAHALLI_66	09:36	11:57	02:20	LINE CLEAR AVAILED
889	06-Jan-24	TUMKUR	66	HV1(TR1)	HONNALLI_66	07:20	07:38	00:18	TRIPPED ON FAULT
890	06-Jan-24	TUMKUR	66	HV2(TR2)	CHANNAGIRI_66	10:25			LINE CLEAR AVAILED
891	06-Jan-24	TUMKUR	66	HV2(TR2)	BALENAHALLI_66	13:08	15:49	02:40	LINE CLEAR AVAILED
892	06-Jan-24	TUMKUR	66	HV2(TR2)	CHITRAHALLI_66	08:30	08:32	00:02	TRIPPED ON FAULT
893	06-Jan-24	TUMKUR	66	MADHUGIRI 220KV-PULLAMAGATTA	PULLAMGATTA_66	05:11	05:18	00:07	TRIPPED ON FAULT
894	06-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50(03.01.2024)			MAIN SUPPLY FAILURE
895	06-Jan-24	TUMKUR	66	RAMAGIRI_66-HOLALKERE_66	HOLALKERE_66, CHIKKAJAJURU_66	13:10	13:30	00:20	TRIPPED ON FAULT
896	06-Jan-24	TUMKUR	66	RAMAGIRI-BAGUR LINE	RAMAGIRI_66, ENERCON_IPP_66	13:10	13:20	00:10	TRIPPED ON FAULT
897	06-Jan-24	TUMKUR	66	SHYAGALE- KEREKILCHI	SHYAGALE_66, KEREBILCHI_66, TYAVANAGI_66, SANTEBENNUR_66, BASAVAPATNA_66	13:15	13:20	00:05	TRIPPED ON FAULT
898	06-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
899	06-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 2	HAVERI_220	00:47	02:40	01:52	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
900	06-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18(03.01.2024)			LINE CLEAR AVAILED
901	06-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)			LINE CLEAR AVAILED
902	07-Jan-24	BAGALKOT	110	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED SIRSI_110	16:49	16:58	00:09	TRIPPED ON FAULT
903	07-Jan-24	BAGALKOT	110	110/11KV, HV2 (20MVA)	STATION NOT AFFECTED PH COMPOUND_110	10:50 (07.01.2024)			LINE CLEAR AVAILED
904	07-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	BIJAPUR_220	12:41	13:46	01:05	TRIPPED ON FAULT
905	07-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	MALGHAN(B)_110	09:55	10:05	00:10	TRIPPED ON FAULT
906	07-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	HALIYAL_110	09:19	12:35	03:16	LINE CLEAR AVAILED
907	07-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	KIRUVATTI_110	16:52	17:20	00:28	TRIPPED ON FAULT
908	07-Jan-24	BAGALKOT	110	AMBEWADI-NK -2 (KAVALWADA)	AMBEWADI_220	05:50	05:54	00:04	TRIPPED ON FAULT
909	07-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
910	07-Jan-24	BAGALKOT	110	BYADAGI-RAILWAY LINE	BYADAGI_110	05:17	05:47	00:30	TRIPPED ON FAULT
911	07-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
912	07-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
913	07-Jan-24	BAGALKOT	110	HIREBAGEWADI-SUVARNA SOUDA	HIREBAGEWADI_110	12:50 (06.01.2024)	15:25 (07.01.2024)	26:35:00	TRIPPED ON FAULT
914	07-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
915	07-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
916	07-Jan-24	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED
917	07-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
918	07-Jan-24	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	MK HUBLI_220	08:43	19:29	10:46	LINE CLEAR AVAILED
919	07-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
920	07-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
921	07-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
922	07-Jan-24	BAGALKOT	110	SIRSI-JOG1	SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
923	07-Jan-24	BAGALKOT	110	SUARNAS-HIRE BAGEWADI I	STATION NOT AFFECTED SUARNASOUDHA_110	13:29 (06.01.2023)	15:28 (07.01.2024)	25:59:00	LINE CLEAR AVAILED
924	07-Jan-24	BAGALKOT	110	TARIHA-SRS HUBLI-1	TARIHAL_110	10:48	12:01	01:13	LINE CLEAR AVAILED
925	07-Jan-24	BAGALKOT	110	THORVI-BHUTNAL	THORVI_110	10:07	15:48	05:41	LINE CLEAR AVAILED
926	07-Jan-24	BAGALKOT	110	UKLI-F2 Cbreaker(BAGEWADI)	STATION NOT AFFECTED UKKALI_110	13:49	14:05	00:16	LINE CLEAR AVAILED
927	07-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
928	07-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
929	07-Jan-24	BAGALKOT	220	HUBLI-NARENDRA 1	HUBLI_220	20:08 (06.1.2024)			TRIPPED ON FAULT
930	07-Jan-24	BAGALKOT	220	HUBLI-NARENDRA 2	HUBLI_220	16:11	18:55	02:44	LINE CLEAR AVAILED
931	07-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
932	07-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
933	07-Jan-24	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	20:08 (06.01.2024)			TRIPPED ON FAULT
934	07-Jan-24	BAGALKOT	220	NARENDRA-KANABARGI2	NARENDRA_220	10:34	19:05	08:31	LINE CLEAR AVAILED
935	07-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
936	07-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
937	07-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
938	07-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
939	07-Jan-24	BANGALORE	66	BAGHMANE WORLD TECH PARK - HAL 2	BAGHMANE WORLD TECH PARK	17:05	17:12	00:07	LINE CLEAR AVOIDED
940	07-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	10:52	11:05	00:13	TRIPPED ON FAULT
941	07-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	12:23	12:29	00:06	TRIPPED ON FAULT
942	07-Jan-24	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	08:49	10:22	01:33	LINE CLEAR AVOIDED
943	07-Jan-24	BANGALORE	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	14:45	15:00	00:15	LINE CLEAR AVOIDED
944	07-Jan-24	BANGALORE	66	HV1	ATTUR YELAHANKA	12:01	12:04	00:03	LINE CLEAR AVOIDED
945	07-Jan-24	BANGALORE	66	HV1	ATTUR YELAHANKA	14:20	14:50	00:30	LINE CLEAR AVOIDED
946	07-Jan-24	BANGALORE	66	HV1	ATTUR YELAHANKA	16:43	16:48	00:05	LINE CLEAR AVOIDED
947	07-Jan-24	BANGALORE	66	HV1	NANDINI LAYOUT	12:18	12:26	00:08	TRIPPED ON FAULT
948	07-Jan-24	BANGALORE	66	HV1	HOODY 220	15:20	15:37	00:17	LINE CLEAR AVOIDED
949	07-Jan-24	BANGALORE	66	HV1	ANJANAPURA	06:10	06:16	00:06	LINE CLEAR AVOIDED
950	07-Jan-24	BANGALORE	66	HV1	KHODAYS 220	09:27	09:31	00:04	TRIPPED ON FAULT
951	07-Jan-24	BANGALORE	66	HV1	KHODAYS 220	16:15	16:18	00:03	TRIPPED ON FAULT
952	07-Jan-24	BANGALORE	66	HV1	JADIGENAHALLI	17:00	17:30	00:30	LINE CLEAR AVOIDED
953	07-Jan-24	BANGALORE	66	HV1	SULIBELE	11:37	11:52	00:15	TRIPPED ON FAULT
954	07-Jan-24	BANGALORE	66	HV1	PALLICHERLU	11:17	11:30	00:13	TRIPPED ON FAULT
955	07-Jan-24	BANGALORE	66	HV1	SUGUTUR	01:25	01:35	00:10	TRIPPED ON FAULT
956	07-Jan-24	BANGALORE	66	HV1	BEVOOR	10:49	11:08	00:19	TRIPPED ON FAULT
957	07-Jan-24	BANGALORE	66	HV1	ATTIBELE	13:05	13:10	00:05	LINE CLEAR AVOIDED
958	07-Jan-24	BANGALORE	66	HV1	JIGANI 66	14:55	15:05	00:10	LINE CLEAR AVOIDED
959	07-Jan-24	BANGALORE	66	HV1	JIGANI 66	16:57	17:05	00:08	LINE CLEAR AVOIDED
960	07-Jan-24	BANGALORE	66	HV2	ATTUR YELAHANKA	12:01	12:04	00:03	LINE CLEAR AVOIDED
961	07-Jan-24	BANGALORE	66	HV2	ATTUR YELAHANKA	14:20	14:50	00:30	LINE CLEAR AVOIDED
962	07-Jan-24	BANGALORE	66	HV2	ATTUR YELAHANKA	16:43	16:48	00:05	LINE CLEAR AVOIDED
963	07-Jan-24	BANGALORE	66	HV2	BAGHMANE TECH PARK	09:13	09:14	00:01	LINE CLEAR AVOIDED
964	07-Jan-24	BANGALORE	66	HV2	ANJANAPURA	06:10	06:16	00:06	LINE CLEAR AVOIDED
965	07-Jan-24	BANGALORE	66	HV2	KHODAYS 220	09:27	09:31	00:04	TRIPPED ON FAULT
966	07-Jan-24	BANGALORE	66	HV2	KHODAYS 220	16:15	16:18	00:03	TRIPPED ON FAULT
967	07-Jan-24	BANGALORE	66	HV2	JIGANI 66	14:25	16:15	01:50	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
968	07-Jan-24	BANGALORE	66	HV3	JIGANI 66	14:55	15:05	00:10	LINE CLEAR AVAILED
969	07-Jan-24	BANGALORE	66	HV3	JIGANI 66	16:57	17:05	00:08	LINE CLEAR AVAILED
970	07-Jan-24	BANGALORE	66	HV3	YARANDANAHALLI 220	07:14	07:41	00:27	MAIN SUPPLY FAILURE
971	07-Jan-24	BANGALORE	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGGANADODDI	14:55	16:55	02:00	LINE CLEAR AVAILED
972	07-Jan-24	BANGALORE	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	17:12	17:17	00:05	LINE CLEAR AVAILED
973	07-Jan-24	BANGALORE	66	JIGANI LINK ROAD - JIGANI 220	JIGANI LINK ROAD	14:20	14:23	00:03	LINE CLEAR AVAILED
974	07-Jan-24	BANGALORE	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	16:15	16:18	00:03	TRIPPED ON FAULT
975	07-Jan-24	BANGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	10:55	11:04	00:09	LINE CLEAR AVAILED
976	07-Jan-24	BANGALORE	66	KORAMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	13:45	17:22	03:37	TRIPPED ON FAULT
977	07-Jan-24	BANGALORE	66	LEELA VENTURE - ADUGODI 1	LEELA VENTURE	06:37	06:39	00:02	LINE CLEAR AVAILED
978	07-Jan-24	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	09:16	09:26	00:10	TRIPPED ON FAULT
979	07-Jan-24	BANGALORE	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	21:40	21:44	00:04	LINE CLEAR AVAILED
980	07-Jan-24	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 2	SARAKKI	05:32	05:38	00:06	LINE CLEAR AVAILED
981	07-Jan-24	BANGALORE	66	SHOBHA APARTMENT - CESSNA	SHOBHA APARTMENT	07:45	07:55	00:10	LINE CLEAR AVAILED
982	07-Jan-24	BANGALORE	66	SOMANAHALLI 220 - HAROHALLI 2	BHORUKA(EHT), SAINT GOBIN(EHT)	08:10	09:38	01:28	LINE CLEAR AVAILED
983	07-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	09:39	09:45	00:06	LINE CLEAR AVAILED
984	07-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - CHANDAPURA	CHANDAPURA	07:14	07:41	00:27	MAIN SUPPLY FAILURE
985	07-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT)	07:14	07:41	00:27	MAIN SUPPLY FAILURE
986	07-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - KEONICS 1	BOMMASANDRA I/A	07:14	07:41	00:27	MAIN SUPPLY FAILURE
987	07-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	07:14	07:43	00:29	MAIN SUPPLY FAILURE
988	07-Jan-24	BANGALORE	220	HV1	YARANDANAHALLI 220	07:14	07:40	00:26	TRIPPED ON FAULT
989	07-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
990	07-Jan-24	GULBARGA	66	NEELAGUNDA-HALAVAGALU	HALAVAGALU_66,LIC-EHT(KNNL),HARVI_66	12:30	12:40	00:10	TRIPPED ON FAULT
991	07-Jan-24	GULBARGA	110	HV3	BELLARY NORTH_110	16:20	16:30	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
992	07-Jan-24	GULBARGA	110	LADHA-HUMNABAD	LADHA_110	02:50	03:05	00:15	TRIPPED ON FAULT
993	07-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	01:03	01:09	00:06	TRIPPED ON FAULT
994	07-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	02:52	02:56	00:04	TRIPPED ON FAULT
995	07-Jan-24	GULBARGA	110	SHAHAPUR-NAGNOOR	NAGANOOR_110,KEMBHAVI_110,HUNSAGI_110,ASKI_110,UGAR SUGAR_IPP	18:30	18:41	00:11	TRIPPED ON FAULT
996	07-Jan-24	GULBARGA	110	SINDHANOOR-NIRLOOTI	SINDHANOOR_220	01:40	01:50	00:10	TRIPPED ON FAULT
997	07-Jan-24	GULBARGA	220	ITTAGGI-EMBASSY	ITTAGGI_220	20:30(6.1.2024)	4:02(7.1.2024)	07:37	LINE CLEAR AVAILED
998	07-Jan-24	HASSAN	66	HASS22-ARKALGUD	HASSAN_220	11:55	12:07	00:12	TRIPPED ON FAULT
999	07-Jan-24	HASSAN	66	HV1	HASSAN_66	18:43(6.1.2024)	15:05(7.1.2024)	20:22HRS	TRIPPED ON FAULT
1000	07-Jan-24	HASSAN	66	HV1	NAGARTHI_66	09:28	09:50	00:22	LINE CLEAR AVAILED
1001	07-Jan-24	HASSAN	66	KUDLIGE-LINGDHALLY	KUDLIGERE_66	08:05	08:20	00:15	TRIPPED ON FAULT
1002	07-Jan-24	HASSAN	110	HV2	ESSUR_110	11:20	17:25	06:05	LINE CLEAR AVAILED
1003	07-Jan-24	HASSAN	110	LV2	KAVOOR_220	10:01	15:11	05:10	LINE CLEAR AVAILED
1004	07-Jan-24	HASSAN	220	HV2	KAVOOR_220	10:01	15:11	05:10	LINE CLEAR AVAILED
1005	07-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	13:00(6.01.2024)	20:26(7.01.2024)	31:26HRS	LINE CLEAR AVAILED
1006	07-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:41(6.01.2024)	20:26(7.01.2024)	44:07HRS	LINE CLEAR AVAILED
1007	07-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	20:48(7.1.2024)			TRIPPED ON FAULT
1008	07-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	13:00(6.01.2024)	20:26(7.01.2024)	31:26HRS	LINE CLEAR AVAILED
1009	07-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:41(6.01.2024)	20:26(7.01.2024)	44:07HRS	LINE CLEAR AVAILED
1010	07-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	20:48(7.1.2024)			TRIPPED ON FAULT
1011	07-Jan-24	MYSORE	66	CRNAGAR-HONNALLI	HONNALI_66 ARAKALAWADI_66 ATTIGULIPURA_66	06:35	06:44	00:08	TRIPPED ON FAULT
1012	07-Jan-24	MYSORE	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	16:06	18:20	02:13	LINE CLEAR AVAILED
1013	07-Jan-24	MYSORE	66	HV1	BANNUR_66	13:41	17:13	03:32	LINE CLEAR AVAILED
1014	07-Jan-24	MYSORE	66	HV1	HEBBAL_66	10:00	15:20	05:19	LINE CLEAR AVAILED
1015	07-Jan-24	MYSORE	66	HV1	KALAMANDIR_66	02:32	02:54	00:22	TRIPPED ON FAULT
1016	07-Jan-24	MYSORE	66	HV1	METAGALLI_66	10:16	13:38	03:22	LINE CLEAR AVAILED
1017	07-Jan-24	MYSORE	66	HV2	COWDALLI_66	09:13	09:38	00:25	TRIPPED ON FAULT
1018	07-Jan-24	MYSORE	66	HV2	HEBBAL_66	10:01	15:20	05:18	LINE CLEAR AVAILED
1019	07-Jan-24	MYSORE	66	KADAKOLA-BASTIPURA2	NO STATIONS EFFECTED	07:19	12:55	05:35	LINE CLEAR AVAILED
1020	07-Jan-24	MYSORE	66	KADAKOLA-KANNIYANBETTA	NO STATIONS EFFECTED	12:40	15:07	02:26	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1021	07-Jan-24	MYSORE	66	KUSHALNAGAR-SOMWARPETE	SOMWARPETE_33	15:45	15:53	00:07	TRIPPED ON FAULT
1022	07-Jan-24	MYSORE	66	TNPURA-BPCL	NO STATIONS EFFECTED	10:23	10:27	00:04	TRIPPED ON FAULT
1023	07-Jan-24	MYSORE	66	YARAHALLI HAND POST-HD KOTE	ANATRSANTE_66 HDKOTE_66 YARAHALLI HANDPOST_66	14:41	14:49	00:08	TRIPPED ON FAULT
1024	07-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	20:37	20:41	00:04	MAIN SUPPLY FAILURE
1025	07-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR	NALLUR_66	08:39	08:45	00:06	TRIPPED ON FAULT
1026	07-Jan-24	TUMKUR	66	CHITRADURGA 220KV-PANDARAHALLI 1	CHITRAHALLI_66, HD PURA_66	14:35	16:45	02:10	TRIPPED ON FAULT
1027	07-Jan-24	TUMKUR	66	CHITRADURGA 220KV-CHITRADURGA 4	CHITRADURGA_220	03:23	03:37	00:14	TRIPPED ON FAULT
1028	07-Jan-24	TUMKUR	66	CHITRADURGA 220KV-CHITRADURGA 4	CHITRADURGA_220	14:31	17:31	03:00	TRIPPED ON FAULT
1029	07-Jan-24	TUMKUR	66	DEVARAHALLI-SANTHEBENNUR	SANTHEBENNUR_66 KEREBILCHI_66	09:48	09:56	00:08	TRIPPED ON FAULT
1030	07-Jan-24	TUMKUR	66	HANAGAL-GUDEKOTE(THALLAK)	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	21:36	22:12	00:36	TRIPPED ON FAULT
1031	07-Jan-24	TUMKUR	66	HANGAL66-ASEP SOLAR	ASEP SOLAR_66	21:36	22:42	01:06	TRIPPED ON FAULT
1032	07-Jan-24	TUMKUR	66	HIRIYUR220KV-BEVINAHALLI	DASOODI_66, JG HALLI_66	00:45	01:00	00:15	TRIPPED ON FAULT
1033	07-Jan-24	TUMKUR	66	HIRIYUR220KV-BEVINAHALLI	DASOODI_66, JG HALLI_66	03:50	04:02	00:12	TRIPPED ON FAULT
1034	07-Jan-24	TUMKUR	66	HONNALLI - KUNDUR	KUNDUR_66, MALEBENNUR_66, DB HALLI_66	09:22	09:33	00:11	TRIPPED ON FAULT
1035	07-Jan-24	TUMKUR	66	HV1(TR1)	CHITRAHALLI_66	09:50	09:57	00:07	TRIPPED ON FAULT
1036	07-Jan-24	TUMKUR	66	HV1(TR1)	MATHOD_66	16:05	16:16	00:10	TRIPPED ON FAULT
1037	07-Jan-24	TUMKUR	66	HV2(TR2)	CHANNAGIRI_66	10:25(06.01.24)	5:40(7.1.24)	19:55	LINE CLEAR AVAILED
1038	07-Jan-24	TUMKUR	66	HV2(TR2)	MADADKERE_66	00:39	00:45	00:06	TRIPPED ON FAULT
1039	07-Jan-24	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	10:55	12:30	01:35	TRIPPED ON FAULT
1040	07-Jan-24	TUMKUR	66	JAVAGONDANAHALLI-TAVAREKERE	TAVAREKERE_66	00:40	12:30	11:50	TRIPPED ON FAULT
1041	07-Jan-24	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	01:25	01:34	00:08	TRIPPED ON FAULT
1042	07-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50(03.01.2024)			MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1043	07-Jan-24	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	00:22	00:35	00:13	TRIPPED ON FAULT
1044	07-Jan-24	TUMKUR	66	SIRA220 - BUKKAPATNA	BUKKAPATNA_66	00:35	00:43	00:08	TRIPPED ON FAULT
1045	07-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1046	07-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18(03.01.2024)			LINE CLEAR AVAILED
1047	07-Jan-24	TUMKUR	220	TR-2	SIRA_220	10:20(31.12.2023)	17:50(7.1.24)	7days 8:10 hrs	LINE CLEAR AVAILED
1048	08-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	MK HUBLI_220	11:45	13:47	2:02	LINE CLEAR AVAILED
1049	08-Jan-24	BAGALKOT	110	110/11KV, HV2 (20MVA)	STATION NOT AFFECTED PH COMPOUND_110	10:50 (07.01.2024)	12:35 (08.01.2024)	25:45:00	LINE CLEAR AVAILED
1050	08-Jan-24	BAGALKOT	110	110/11KV, HV2(20MVA)	UCHAGOAN_110	15:20	17:04	01:44	LINE CLEAR AVAILED
1051	08-Jan-24	BAGALKOT	110	110/33KV, HV2(20MVA)	ZALKI_110	14:34	14:37	00:03	TRIPPED ON FAULT
1052	08-Jan-24	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	11:45 (08.01.2024)			TRIPPED ON FAULT
1053	08-Jan-24	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	11:45	13:40	1:55	TRIPPED ON FAULT
1054	08-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)			LINE CLEAR AVAILED
1055	08-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)			TRIPPED ON FAULT
1056	08-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
1057	08-Jan-24	BAGALKOT	110	HUBLI220- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)			LINE CLEAR AVAILED
1058	08-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1059	08-Jan-24	BAGALKOT	110	KADANAKOPPA- KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)			LINE CLEAR AVAILED
1060	08-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1061	08-Jan-24	BAGALKOT	110	MALGHAN- BASAVA SUGARS	STATION NOT AFFECTED MALGHAN(B)_110	18:20	18:40	00:20	TRIPPED ON FAULT
1062	08-Jan-24	BAGALKOT	110	MK HUBLI220- BAILHONGAL	MK HUBLI_220 BAILHONGAL_110	11:45	13:47	2:02	LINE CLEAR AVAILED
1063	08-Jan-24	BAGALKOT	110	MK HUBLI220- KHANAPUR	MK HUBLI_220 KHANAPUR_110	11:45	13:50	2:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1064	08-Jan-24	BAGALKOT	110	MK HUBLI220-BIDI	MK HUBLI_220 BEDI_110	11:45	13:49	2:04	LINE CLEAR AVAILED
1065	08-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1066	08-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1067	08-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1068	08-Jan-24	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
1069	08-Jan-24	BAGALKOT	110	SUARNASOUDA- HIREBAGEWADI1	STATION NOT AFFECTED SUARNASOUDA_110	11:45	12:15	00:30	LINE CLEAR AVAILED
1070	08-Jan-24	BAGALKOT	220	220/110KV, HV1	MK HUBLI_220	11:45	17:29	05:44	TRIPPED ON FAULT
1071	08-Jan-24	BAGALKOT	220	220/110KV, HV2	MK HUBLI_220	11:45	13:38	01:53	TRIPPED ON FAULT
1072	08-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1073	08-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
1074	08-Jan-24	BAGALKOT	220	HUBLI-NARENDRA 1	STATION NOT AFFECTED HUBLI_220	20:08 (06.1.2024)	15:53 (08.01.2024)	43:45:00	TRIPPED ON FAULT
1075	08-Jan-24	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:10	15:53	05:43	LINE CLEAR AVAILED
1076	08-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
1077	08-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	10:27	18:30	8:03	LINE CLEAR AVAILED
1078	08-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
1079	08-Jan-24	BAGALKOT	220	NARENDRA-HUBLI1	NARENDRA_220	20:08 (06.01.2024)	15:53 (08.01.2024)	43:45:00	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1080	08-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVOIDED
1081	08-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVOIDED
1082	08-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
1083	08-Jan-24	BANGALORE	66	AGALAKOTE - KEMPANAHALLI	AGALAKOTE	07:10	07:20	00:10	TRIPPED ON FAULT
1084	08-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1085	08-Jan-24	BANGALORE	66	HAL 220 - BAGMANE TECH PARK (Tapped to ADE/GTRE)	BAGMANE TECH PARK, GTRE (EHT)	16:10	16:38	00:28	TRIPPED ON FAULT
1086	08-Jan-24	BANGALORE	66	HV1	NANDINI LAYOUT	17:56	18:08	00:12	LINE CLEAR AVOIDED
1087	08-Jan-24	BANGALORE	66	HV1	BRIGADE TECH GARDEN	14:46	15:03	00:17	TRIPPED ON FAULT
1088	08-Jan-24	BANGALORE	66	HV1	BIAL BEGUR 220	07:09	07:25	00:16	TRIPPED ON FAULT
1089	08-Jan-24	BANGALORE	66	HV1	DIBBURAHALLI	12:20	12:30	00:10	TRIPPED ON FAULT
1090	08-Jan-24	BANGALORE	66	HV1	GANJIGUNTE	10:32	11:01	00:29	TRIPPED ON FAULT
1091	08-Jan-24	BANGALORE	66	HV1	GOWRIBIDANUR 220	19:55	20:05	00:10	TRIPPED ON FAULT
1092	08-Jan-24	BANGALORE	66	HV1	GOWRIBIDANUR 220	20:56	21:16	00:20	TRIPPED ON FAULT
1093	08-Jan-24	BANGALORE	66	HV1	GULUR	13:02	13:07	00:05	TRIPPED ON FAULT
1094	08-Jan-24	BANGALORE	66	HV1	TK HALLI 220	04:29	04:43	00:14	MAIN SUPPLY FAILURE
1095	08-Jan-24	BANGALORE	66	HV2	BRIGADE TECH GARDEN	14:31	14:40	00:09	TRIPPED ON FAULT
1096	08-Jan-24	BANGALORE	66	HV2	JANGAMKOTE	13:00	13:39	00:39	LINE CLEAR AVOIDED
1097	08-Jan-24	BANGALORE	66	HV2	VIJAYAPURA	20:08	20:12	00:04	MAIN SUPPLY FAILURE
1098	08-Jan-24	BANGALORE	66	HV2	VIJAYAPURA	22:35	22:40	00:05	TRIPPED ON FAULT
1099	08-Jan-24	BANGALORE	66	HV2	MALLASANDRA	07:45	08:15	00:30	TRIPPED ON FAULT
1100	08-Jan-24	BANGALORE	66	HV2	NANGLI	13:30	14:05	00:35	TRIPPED ON FAULT
1101	08-Jan-24	BANGALORE	66	HV2	NANGLI	14:22	14:30	00:08	TRIPPED ON FAULT
1102	08-Jan-24	BANGALORE	66	HV2	THAYALUR	13:55	15:30	01:35	LINE CLEAR AVOIDED
1103	08-Jan-24	BANGALORE	66	HV2	DODDAKARI	15:15	16:00	00:45	LINE CLEAR AVOIDED
1104	08-Jan-24	BANGALORE	66	HV2	YEDUMADU	23:16	23:18	00:02	TRIPPED ON FAULT
1105	08-Jan-24	BANGALORE	66	HV2	TK HALLI 220	04:29	04:46	00:17	MAIN SUPPLY FAILURE
1106	08-Jan-24	BANGALORE	66	HV3	HSR LAYOUT 220	13:38	14:08	00:30	TRIPPED ON FAULT
1107	08-Jan-24	BANGALORE	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	13:24	17:10	03:46	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1108	08-Jan-24	BANGALORE	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	09:35	09:45	00:10	TRIPPED ON FAULT
1109	08-Jan-24	BANGALORE	66	KONDASAPURA - NTT	NTT(EHT)	14:20	14:42	00:22	LINE CLEAR AVAILED
1110	08-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	20:08	20:19	00:11	TRIPPED ON FAULT
1111	08-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	21:01	21:12	00:11	TRIPPED ON FAULT
1112	08-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, THORALAKKI, BUDIKOTE	23:52	23:59	00:07	TRIPPED ON FAULT
1113	08-Jan-24	BANGALORE	66	NRS DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI, NANDI	17:08	17:14	00:06	MAIN SUPPLY FAILURE
1114	08-Jan-24	BANGALORE	66	NRS DB PURA 220 - TUBUGERE	TUBUGERE	17:08	17:14	00:06	MAIN SUPPLY FAILURE
1115	08-Jan-24	BANGALORE	66	SHOBHA DREAMS 66 - KACHAMARANAHALLI	KACHAMARANAHALLI, PRESTIGE LAKESIDE HABITAT, DIVYASHREE TECH PARK, MINOR IRRIGATION	12:55	13:25	00:30	TRIPPED ON FAULT
1116	08-Jan-24	BANGALORE	66	SOMANAHALLI 220 - ISKON	ISKON	12:54	13:04	00:10	LINE CLEAR AVAILED
1117	08-Jan-24	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	04:29	04:48	00:19	MAIN SUPPLY FAILURE
1118	08-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 1(EHT)	BWSSB 1(EHT)	04:29	04:43	00:14	MAIN SUPPLY FAILURE
1119	08-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 2(EHT)	BWSSB 2(EHT)	04:29	04:43	00:14	MAIN SUPPLY FAILURE
1120	08-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 3(EHT)	BWSSB 3(EHT)	04:29	04:43	00:14	MAIN SUPPLY FAILURE
1121	08-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 4(EHT)	BWSSB 4(EHT)	04:29	04:43	00:14	MAIN SUPPLY FAILURE
1122	08-Jan-24	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, B V HALLI	04:29	04:48	00:19	MAIN SUPPLY FAILURE
1123	08-Jan-24	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR, K HONALGERE, YATHAMBADI	04:29	04:48	00:19	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1124	08-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 1	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, KIADB SOMANAHALLI	04:29	04:48	00:19	MAIN SUPPLY FAILURE
1125	08-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 2	TALAGAVADI, KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, KIADB SOMANAHALLI	04:29	04:48	00:19	MAIN SUPPLY FAILURE
1126	08-Jan-24	BANGALORE	220	CHANNAPATNA 220 - MAGADI 220	NO STATION AFFECTED	13:25	23:59	10:34	TRIPPED ON FAULT
1127	08-Jan-24	BANGALORE	220	HV1	TK HALLI 220	04:29	04:41	00:12	TRIPPED ON FAULT
1128	08-Jan-24	BANGALORE	220	HV2	DB PURA 220	17:08	17:14	00:06	LINE CLEAR AVOIDED
1129	08-Jan-24	BANGALORE	220	HV2	TK HALLI 220	04:29	04:46	00:17	TRIPPED ON FAULT
1130	08-Jan-24	BANGALORE	220	HV3	TK HALLI 220	04:29	04:47	00:18	TRIPPED ON FAULT
1131	08-Jan-24	GULBARGA	66	HV5	MUNIRABAD_220	11:25	12:00	00:35	LINE CLEAR AVOIDED
1132	08-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVOIDED
1133	08-Jan-24	GULBARGA	110	KADACHUR-KHANAPUR	KADAECHUR_110	10:45	15:45	05:00	LINE CLEAR AVOIDED
1134	08-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	02:47	02:57	00:10	TRIPPED ON FAULT
1135	08-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	03:31	03:37	00:06	TRIPPED ON FAULT
1136	08-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	10:45	10:58	00:13	LINE CLEAR AVOIDED
1137	08-Jan-24	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110	10:59	11:05	00:06	LINE CLEAR AVOIDED
1138	08-Jan-24	GULBARGA	110	SIRWAR-RAICHUR	SIRWAR_110	11:30	17:18	05:48	LINE CLEAR AVOIDED
1139	08-Jan-24	GULBARGA	220	HV1	SINDHANOOR_220	12:27	17:22	04:55	LINE CLEAR AVOIDED
1140	08-Jan-24	GULBARGA	220	HV2	SINDHANOOR_220	17:25	20:03	02:38	LINE CLEAR AVOIDED
1141	08-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	12:45	17:05	04:20	LINE CLEAR AVOIDED
1142	08-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	16:29	17:15	00:46	LINE CLEAR AVOIDED
1143	08-Jan-24	HASSAN	66	HV2	MALLAPURA_66	15:40	17:07	01:27	LINE CLEAR AVOIDED
1144	08-Jan-24	HASSAN	110	ARSK2-BANAVARA	ARASIKERE_220	04:11	04:19	00:08	TRIPPED ON FAULT
1145	08-Jan-24	HASSAN	110	HV2	ESSUR_110	9:40(8.01.2024)			LINE CLEAR AVOIDED
1146	08-Jan-24	HASSAN	110	HV2	KONAJE_110	05:10	06:25	01:15	LINE CLEAR AVOIDED
1147	08-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	20:48(7.1.2024)	10:34(8.1.2024)	13:46HRS	LINE CLEAR AVOIDED
1148	08-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	20:48(7.1.2024)	10:34(8.1.2024)	13:46HRS	LINE CLEAR AVOIDED
1149	08-Jan-24	MYSORE	66	CRNAGAR-HONALLY	HONNALI_66 ARAKALAWADI_66 ATTIGULIPURA_66	05:33	05:39	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1150	08-Jan-24	MYSORE	66	HV1	CHICKMANDYA_66	10:40	11:00	00:20	LINE CLEAR AVAILED
1151	08-Jan-24	MYSORE	66	HV1	KMDODDI_66	04:28	04:46	00:18	LINE CLEAR AVAILED
1152	08-Jan-24	MYSORE	66	HV1	KOPPA_66	12:55	13:25	00:30	LINE CLEAR AVAILED
1153	08-Jan-24	MYSORE	66	HV2	KOPPA_66	13:25	13:40	00:15	LINE CLEAR AVAILED
1154	08-Jan-24	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	08:24	08:32	00:08	TRIPPED ON FAULT
1155	08-Jan-24	MYSORE	66	KRPET-AKKIHEBBAL1	NO STATIONS EFFECTED	12:38	13:56	01:18	LINE CLEAR AVAILED
1156	08-Jan-24	MYSORE	66	KUSHALNAGARA-RAMANTHAPURA1	RAMANATHPURA_66 KANAGALU_66 ALURSIDDAPRA_66 CBHALLI_66 RUDRAPATNA_66	11:59	12:11	00:11	LINE CLEAR AVAILED
1157	08-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	07:11	07:19	00:08	TRIPPED ON FAULT
1158	08-Jan-24	TUMKUR	66	BENKIKERE 220kV-NALLUR	NALLUR_66	16:13	16:20	00:06	LINE CLEAR AVAILED
1159	08-Jan-24	TUMKUR	66	CHITRAHALLI-H D PURA	H D PURA_66	09:13	17:53	08:39	LINE CLEAR AVAILED
1160	08-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	13:01	13:56	00:55	LINE CLEAR AVAILED
1161	08-Jan-24	TUMKUR	66	HV2(TR2)	SASLUHALLA_66	22:11	23:25	01:13	LINE CLEAR AVAILED
1162	08-Jan-24	TUMKUR	66	HV3(TR3)	HARIYABBE_66	09:09	09:15	00:05	TRIPPED ON FAULT
1163	08-Jan-24	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	13:30	18:49	05:19	TRIPPED ON FAULT
1164	08-Jan-24	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI	05:20	05:30	00:10	TRIPPED ON FAULT
1165	08-Jan-24	TUMKUR	66	PAVAGADA 220kV-SHYLAPURA	SHYLAPURA_66	09:00	09:10	00:10	TRIPPED ON FAULT
1166	08-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1167	08-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1168	08-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1169	08-Jan-24	TUMKUR	400	GUTTUR 400kV- BTPS	GUTTUR_400	19:32:25			TRIPPED ON FAULT
1170	09-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	KUD DHARWAD_110	12:46	14:48	2:02	LINE CLEAR AVAILED
1171	09-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	LAXMESHWAR_110	17:03	17:20	0:17	TRIPPED ON FAULT
1172	09-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	BEDI_110	15:22	16:52	1:30	LINE CLEAR AVAILED
1173	09-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	KUD DHARWAD_110	14:08	17:55	3:47	LINE CLEAR AVAILED
1174	09-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	KAGAWAD_110	17:33	17:51	0:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1175	09-Jan-24	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED MK HUBLI_220	11:45 (08.01.2024)	20:21 (09.01.2024)	32:36:00	TRIPPED ON FAULT
1176	09-Jan-24	BAGALKOT	110	BASAVANAKATTI-F1(HAVERI220)	BASAVANAKATTI_110	17:20	17:45	0:25	TRIPPED ON FAULT
1177	09-Jan-24	BAGALKOT	110	BASAVANAKATTI-F2(GUTTAL)	BASAVANAKATTI_110	17:40	17:50	0:10	LINE CLEAR AVOIDED
1178	09-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	15:30 (19.12.2023)	16:51 (09.01.2024)	601:21:00	LINE CLEAR AVOIDED
1179	09-Jan-24	BAGALKOT	110	DAMBAL-SUZLON2	STATION NOT AFFECTED DAMBAL_110	16:54 (8.12.2023)	17:23 (09.01.2024)	768:29:00	TRIPPED ON FAULT
1180	09-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVOIDED
1181	09-Jan-24	BAGALKOT	110	HATTARAGI-HUKKERI(GHATAPRABHA)	HATTARAGI_110	12:13	12:26	0:13	LINE CLEAR AVOIDED
1182	09-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	11:46 (01.01.2024)	11:07 (09.01.2024)	191:21:00	LINE CLEAR AVOIDED
1183	09-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
1184	09-Jan-24	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	11:42 (15.12.2023)	10:54 (09.01.2024)	599:12:00	LINE CLEAR AVOIDED
1185	09-Jan-24	BAGALKOT	110	KUDACHI220-TERDAL(MORAB)	KUDACHI_220	03:19	03:29	0:10	TRIPPED ON FAULT
1186	09-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
1187	09-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
1188	09-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1189	09-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1190	09-Jan-24	BAGALKOT	110	RANEBENNUR220-RATTIHALLI(TUMMINKATTE)	STATION NOT AFFECTED RANEBENNUR_220	06:06	06:17	0:11	TRIPPED ON FAULT
1191	09-Jan-24	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
1192	09-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MK HUBLI_220	12:15	20:13	7:58	LINE CLEAR AVAILED
1193	09-Jan-24	BAGALKOT	220	AMBEWADI- NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	12:39	17:10	4:31	LINE CLEAR AVAILED
1194	09-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1195	09-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
1196	09-Jan-24	BAGALKOT	220	HUBLI- NAGJHARI1	STATION NOT AFFECTED HUBLI_220	08:48	09:29	0:41	LINE CLEAR AVAILED
1197	09-Jan-24	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	09:37	15:19	5:42	LINE CLEAR AVAILED
1198	09-Jan-24	BAGALKOT	220	HUBLI- NAGJHARI2	STATION NOT AFFECTED HUBLI_220	13:25	15:19	1:54	LINE CLEAR AVAILED
1199	09-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
1200	09-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
1201	09-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
1202	09-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
1203	09-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1204	09-Jan-24	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	12:30	14:40	02:10	LINE CLEAR AVAILED
1205	09-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1206	09-Jan-24	BANGALORE	66	BRIGADE METROPOLIS - BRIGADE TECK GARDEN	BRIGADE METROPOLIS	10:12	10:17	00:05	LINE CLEAR AVAILED
1207	09-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA, CNNL(EHT), SHIVANAHALLI, VANDARGUPPE	10:30	10:42	00:12	TRIPPED ON FAULT
1208	09-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA, CNNL(EHT), SHIVANAHALLI, VANDARGUPPE	13:04	13:06	00:02	LINE CLEAR AVAILED
1209	09-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	10:34	10:44	00:10	TRIPPED ON FAULT
1210	09-Jan-24	BANGALORE	66	HBR LAYOUT 66 - DG3	NO STATION AFFECTED	10:32	11:55	01:23	TRIPPED ON FAULT
1211	09-Jan-24	BANGALORE	66	HENNUR CROSS - HBR LAYOUT 220	HENNUR CROSS, PURVANKARA PALM BEACH	11:45	11:49	00:04	LINE CLEAR AVAILED
1212	09-Jan-24	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SRIGIRIPURA	12:20	14:40	02:20	LINE CLEAR AVAILED
1213	09-Jan-24	BANGALORE	66	HV1	NANDINI LAYOUT	16:02	16:05	00:03	LINE CLEAR AVAILED
1214	09-Jan-24	BANGALORE	66	HV1	BUDIGERE	13:53	13:55	00:02	LINE CLEAR AVAILED
1215	09-Jan-24	BANGALORE	66	HV1	PATHAPALYA	14:20	14:25	00:05	LINE CLEAR AVAILED
1216	09-Jan-24	BANGALORE	66	HV2	VIJAYANAGARA	08:36	08:44	00:08	LINE CLEAR AVAILED
1217	09-Jan-24	BANGALORE	66	HV2	VIJAYAPURA	05:10	05:15	00:05	TRIPPED ON FAULT
1218	09-Jan-24	BANGALORE	66	HV2	NANGLI	12:30	12:40	00:10	TRIPPED ON FAULT
1219	09-Jan-24	BANGALORE	66	HV2	SUGUTUR	14:02	14:22	00:20	TRIPPED ON FAULT
1220	09-Jan-24	BANGALORE	66	HV2	TADIGOLU CROSS	13:25	14:15	00:50	LINE CLEAR AVAILED
1221	09-Jan-24	BANGALORE	66	HV2	CHANDAPURA	13:00	14:02	01:02	LINE CLEAR AVAILED
1222	09-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	00:00	00:33	00:33	TRIPPED ON FAULT
1223	09-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	02:40	06:34	03:54	LINE CLEAR AVAILED
1224	09-Jan-24	BANGALORE	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	18:10	18:22	00:12	TRIPPED ON FAULT
1225	09-Jan-24	BANGALORE	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS, PURVANKARA PALM BEACH	16:11	16:16	00:05	TRIPPED ON FAULT
1226	09-Jan-24	BANGALORE	66	VIJAYAPURA - JANGAMKOTE	JANGAMKOTE	16:35	16:40	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1227	09-Jan-24	GULBARGA	66	CHILAKANHATTI-HANASI	CHILKANHATTI_66	13:10	13:15	00:05	MAIN SUPPLY FAILURE
1228	09-Jan-24	GULBARGA	66	CHILAKANHATTI-HANASI	CHILKANHATTI_66	13:30	13:50	00:20	MAIN SUPPLY FAILURE
1229	09-Jan-24	GULBARGA	66	HALVAGALU-HARVI	HARVI_66	11:35	12:40	01:05	LINE CLEAR AVAILED
1230	09-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,TBPCL_IP P,GIRIYAPURA_66	18:25	18:34	00:09	TRIPPED ON FAULT
1231	09-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
1232	09-Jan-24	GULBARGA	110	HV1	KALABURGI NORTH_110	14:01	14:08	00:07	TRIPPED ON FAULT
1233	09-Jan-24	GULBARGA	110	HV1	YADGIR_110	14:05	14:10	00:05	TRIPPED ON FAULT
1234	09-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	13:10	13:43	00:33	LINE CLEAR AVAILED
1235	09-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	12:48	12:55	00:07	TRIPPED ON FAULT
1236	09-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	14:07	14:12	00:05	TRIPPED ON FAULT
1237	09-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	15:51	16:15	00:24	TRIPPED ON FAULT
1238	09-Jan-24	GULBARGA	110	KHANPUR-KADECHUR	KHANAPUR_110	07:30	17:50	10:20	LINE CLEAR AVAILED
1239	09-Jan-24	GULBARGA	110	KONKAL-RAMASAMUDRA	KONKAL_10	01:55	02:05	00:10	TRIPPED ON FAULT
1240	09-Jan-24	GULBARGA	110	KONKAL-RAMASAMUDRA	KONKAL_10	03:40	03:50	00:10	TRIPPED ON FAULT
1241	09-Jan-24	GULBARGA	220	HV1	MALLAT_220	14:58	18:29	03:31	LINE CLEAR AVAILED
1242	09-Jan-24	GULBARGA	220	HV1	RAICHUR_220	11:26	15:00	03:34	LINE CLEAR AVAILED
1243	09-Jan-24	HASSAN	66	HV1	RAMNATHPURA_66	11:55	12:05	00:10	MAIN SUPPLY FAILURE
1244	09-Jan-24	HASSAN	66	HV2	RAMNATHPURA_66	6:32(8.01.2024)	19:40(9.01.2024)	38:08HRS	LINE CLEAR AVAILED
1245	09-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	11:10	17:25	06:15	LINE CLEAR AVAILED
1246	09-Jan-24	HASSAN	66	HV2	CHIKMANGLUR_66	20:15	23:10	02:55	TRIPPED ON FAULT
1247	09-Jan-24	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:58	13:22	00:24	LINE CLEAR AVAILED
1248	09-Jan-24	HASSAN	66	SAKALE-HASSAN	SAKALESHPUR_66	13:00	13:22	00:22	LINE CLEAR AVAILED
1249	09-Jan-24	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	11:13	12:55	01:42	LINE CLEAR AVAILED
1250	09-Jan-24	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	11:13	12:55	01:42	LINE CLEAR AVAILED
1251	09-Jan-24	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	11:03	13:40	02:37	LINE CLEAR AVAILED
1252	09-Jan-24	HASSAN	110	GANDAS-ARSK2	GANDASI_110	11:10	13:50	02:40	LINE CLEAR AVAILED
1253	09-Jan-24	HASSAN	110	HV1	GANDASI_110	10:00	16:05	06:05	LINE CLEAR AVAILED
1254	09-Jan-24	HASSAN	110	HV1	KONDENALU_110	10:20	16:30	06:10	LINE CLEAR AVAILED
1255	09-Jan-24	HASSAN	110	HV2	ESSUR_110	9:40(8.01.2024)			LINE CLEAR AVAILED
1256	09-Jan-24	HASSAN	110	HV2	GANDASI_110	10:00	16:00	06:00	LINE CLEAR AVAILED
1257	09-Jan-24	HASSAN	110	HV2	KONDENALU_110	10:10	16:30	06:20	LINE CLEAR AVAILED
1258	09-Jan-24	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	00:24	00:45	00:21	TRIPPED ON FAULT
1259	09-Jan-24	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:31	20:35	01:04	MAIN SUPPLY FAILURE
1260	09-Jan-24	HASSAN	110	KONAJE-SALATHUR	KONAJE_110	19:31	20:35	01:04	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1261	09-Jan-24	HASSAN	110	KONDENA-KADUR-ARSIKERE	KONDENALU_110	11:15	12:05	00:50	LINE CLEAR AVAILED
1262	09-Jan-24	HASSAN	110	LV1	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1263	09-Jan-24	HASSAN	110	LV2	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1264	09-Jan-24	HASSAN	110	LV3	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1265	09-Jan-24	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:08	14:12	04:04	LINE CLEAR AVAILED
1266	09-Jan-24	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	00:30	08:40	08:10	TRIPPED ON FAULT
1267	09-Jan-24	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1268	09-Jan-24	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1269	09-Jan-24	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1270	09-Jan-24	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1271	09-Jan-24	HASSAN	220	HGUNJE-VARAH	HEGGUNJE_220	18:12	20:20	02:08	TRIPPED ON FAULT
1272	09-Jan-24	HASSAN	220	HV1	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1273	09-Jan-24	HASSAN	220	HV2	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1274	09-Jan-24	HASSAN	220	KEMAR-Kavoor1	KEMAR_220	11:28	12:29	01:01	LINE CLEAR AVAILED
1275	09-Jan-24	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	19:31	20:03	00:32	TRIPPED ON FAULT
1276	09-Jan-24	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	19:31(9.01.2024)		19:40	TRIPPED ON FAULT
1277	09-Jan-24	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	18:12	20:20	02:08	TRIPPED ON FAULT
1278	09-Jan-24	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:29	12:29	01:00	LINE CLEAR AVAILED
1279	09-Jan-24	HASSAN	220	PUTTUR-KEMAR1	PUTTUR_220	19:31	20:03	00:32	MAIN SUPPLY FAILURE
1280	09-Jan-24	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	19:31(9.01.2024)		17:28	TRIPPED ON FAULT
1281	09-Jan-24	HASSAN	220	VARAH-KEMAR3	gen_varahi	18:12	20:20	02:08	TRIPPED ON FAULT
1282	09-Jan-24	HASSAN	220	VARAH-SHIMOGA2	gen_varahi	18:12	20:20	02:08	TRIPPED ON FAULT
1283	09-Jan-24	MYSORE	66	HV1	GAMANAHALLY_66	13:50	16:49	02:59	LINE CLEAR AVAILED
1284	09-Jan-24	MYSORE	66	HV2	GAMANAHALLY_66	12:25	13:30	01:05	LINE CLEAR AVAILED
1285	09-Jan-24	MYSORE	66	HV2	SATHEGALA_66	03:55	04:02	00:07	TRIPPED ON FAULT
1286	09-Jan-24	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	JAKKANAHALLY_66MAHAD ESHWARAPURA_66GMALLI GERE_66	11:08	11:16	00:08	LINE CLEAR AVAILED
1287	09-Jan-24	MYSORE	66	NAGAMANGALA 220-HARADANAHALLI	HARADANAHALLI_66	06:55	07:07	00:12	TRIPPED ON FAULT
1288	09-Jan-24	MYSORE	66	VAJMANGALA-DEVNUR MYSURU	NO STATIONS EFFECTED	06:39	06:50	00:11	TRIPPED ON FAULT
1289	09-Jan-24	MYSORE	220	TUBINKERE-KOTHIPURA	NO STATIONS EFFECTED	11:00	15:01	04:01	LINE CLEAR AVAILED
1290	09-Jan-24	TUMKUR	66	ANCHEPALYA 220-ANCHEPALYA 2(KUDUR)	KUDUR_66, HULLENAHALLI_66	12:32	14:37	02:05	LINE CLEAR AVAILED
1291	09-Jan-24	TUMKUR	66	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66,ADICHUCHAN AGIRI_66, B G NAGARA_66	12:31	14:40	02:09	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1292	09-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	12:31	14:40	02:09	LINE CLEAR AVAILED
1293	09-Jan-24	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR	HEBBUR_66	12:31	14:40	02:09	LINE CLEAR AVAILED
1294	09-Jan-24	TUMKUR	66	BEVINAHALLI-JAVAGONDANAHALLI	BEVINAHALLI_66	14:00	14:20	00:20	LINE CLEAR AVAILED
1295	09-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	12:09	12:19	00:09	TRIPPED ON FAULT
1296	09-Jan-24	TUMKUR	66	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	10:56	11:09	00:13	TRIPPED ON FAULT
1297	09-Jan-24	TUMKUR	66	HOSADURGA 220KV-HALURAMESHWARA_66KV	HALURAMESHWARA_66KV, MADADKERE_66	06:55	07:10	00:15	TRIPPED ON FAULT
1298	09-Jan-24	TUMKUR	66	HV1(TR1)	DASUDI_66	12:00	14:10	02:10	LINE CLEAR AVAILED
1299	09-Jan-24	TUMKUR	66	HV1(TR1)	LINAGADAHALLI_66	14:04	14:12	00:08	TRIPPED ON FAULT
1300	09-Jan-24	TUMKUR	66	HV2(TR2)	HOSADURGA_66	15:49	15:57	00:07	TRIPPED ON FAULT
1301	09-Jan-24	TUMKUR	66	HV2(TR2)	KUKKAWADA_66	01:46	01:52	00:06	TRIPPED ON FAULT
1302	09-Jan-24	TUMKUR	66	MADANAYAKANAHALLI-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, JAGALUR, BIDARKERE_66	02:11	02:17	00:06	TRIPPED ON FAULT
1303	09-Jan-24	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	05:58	06:28	00:30	TRIPPED ON FAULT
1304	09-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1305	09-Jan-24	TUMKUR	66	THERIYUR 66-PAVAGADA	THERIYUR_66	18:25	18:40	00:15	TRIPPED ON FAULT
1306	09-Jan-24	TUMKUR	110	HONNAVALI 110-KADUR220(ARASEKERE)	HONNAVALI_110	11:00	13:35	02:35	LINE CLEAR AVAILED
1307	09-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1308	09-Jan-24	TUMKUR	220	HV1(TR1)	JAGALUR_220	11:00	16:19	05:19	LINE CLEAR AVAILED
1309	09-Jan-24	TUMKUR	220	JAGALUR 400kV-THALLAKK 220kV	THALLAKK_220	11:20	17:44	06:24	LINE CLEAR AVAILED
1310	09-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1311	09-Jan-24	TUMKUR	400	GUTTUR 400kV- BTPS	GUTTUR_400	19:32(8.1.24)			TRIPPED ON FAULT
1312	10-Jan-24	BAGALKOT	110	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED KANABARGI_110	10:30	13:08	02:38	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1313	10-Jan-24	BAGALKOT	110	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED KUD DHARWAD_110	13:15	18:35	05:20	LINE CLEAR AVAILED
1314	10-Jan-24	BAGALKOT	110	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED ALBAL_110	11:16 (10.01.2024)			LINE CLEAR AVAILED
1315	10-Jan-24	BAGALKOT	110	110/11KV, HV1 (20MVA)	STATION NOT AFFECTED BEDI_110	10:55	13:56	03:01	LINE CLEAR AVAILED
1316	10-Jan-24	BAGALKOT	110	110/11KV,HV1 (20MVA)	STATION NOT AFFECTED SIRSI_110	10:04	14:20	04:16	LINE CLEAR AVAILED
1317	10-Jan-24	BAGALKOT	110	110/11KV,HV2 (10MVA)	STATION NOT AFFECTED SIRSI_110	10:04	14:20	04:16	LINE CLEAR AVAILED
1318	10-Jan-24	BAGALKOT	110	110/11KV,HV3(20MVA)	STATION NOT AFFECTED MUDHOL_110	13:01	14:43	01:42	LINE CLEAR AVAILED
1319	10-Jan-24	BAGALKOT	110	110/33KV, HV3 (10MVA)	RUSTUMPUR LIS_33, BELGAVI WS1,2&3_33 & GODCHINMALKI LIS_33 STATION NOT AFFECTED HIDKALDAM_110	12:00	17:30	05:30	LINE CLEAR AVAILED
1320	10-Jan-24	BAGALKOT	110	110/33KV, HV3 (20MVA)	STATION NOT AFFECTED KANABARGI_110	12:10	13:30	01:20	LINE CLEAR AVAILED
1321	10-Jan-24	BAGALKOT	110	110/33KV,HV1(20MVA)	STATION NOT AFFECTED MUDHOL_110	10:20	10:37	00:17	TRIPPED ON FAULT
1322	10-Jan-24	BAGALKOT	110	110/33KV,HV2 (10MVA)	STATION NOT AFFECTED MURDESHWAR_110	15:50	15:50	00:00	LINE CLEAR AVAILED
1323	10-Jan-24	BAGALKOT	110	AMBEWADI220-NK2 (HALIYAL)	HALIYAL_110 STATION NOT AFFECTED AMBEWADI_220	02:36	02:40	00:04	TRIPPED ON FAULT
1324	10-Jan-24	BAGALKOT	110	AMBEWADI- NK2(KAVALWADA)	KAVALWADA_110, KALAGATAGI_110	02:36	02:40	00:04	TRIPPED ON FAULT
1325	10-Jan-24	BAGALKOT	110	GADAG-LAXMESHWAR	STATION NOT AFFECTED GADAG_220	03:17	10:55	07:38	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1326	10-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
1327	10-Jan-24	BAGALKOT	110	HUBLI220-KADANKOPPA	STATION NOT AFFECTED HUBLI_220	06:43	18:25	11:42	LINE CLEAR AVAILED
1328	10-Jan-24	BAGALKOT	110	HUBLI220-SIRSI(KALAGHATAGI)	STATION NOT AFFECTED HUBLI_220	06:11	18:24	12:13	LINE CLEAR AVAILED
1329	10-Jan-24	BAGALKOT	110	INDI220-ZALKI2	STATION NOT AFFECTED INDI_220	03:50	04:15	00:25	TRIPPED ON FAULT
1330	10-Jan-24	BAGALKOT	110	ISLAMPUR-F2 (HIDKALDAM2)	STATION NOT AFFECTED ISLAMPUR_110	15:09	16:26	01:17	LINE CLEAR AVAILED
1331	10-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1332	10-Jan-24	BAGALKOT	110	KUMTA-RAILWAY LINE	KUMTA_110	09:15	14:23	05:08	LINE CLEAR AVAILED
1333	10-Jan-24	BAGALKOT	110	KUMTA-SIRSI1	KUMTA_110	09:15	16:26	07:11	LINE CLEAR AVAILED
1334	10-Jan-24	BAGALKOT	110	KUMTA-SIRSI2	KUMTA_110	09:15	16:26	07:11	LINE CLEAR AVAILED
1335	10-Jan-24	BAGALKOT	110	LAKMESWR-GADAG1	STATION NOT AFFECTED LAXMESHVAR_110	03:15	14:36	11:21	TRIPPED ON FAULT
1336	10-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1337	10-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1338	10-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1339	10-Jan-24	BAGALKOT	110	MUGALKHOD220-SULATANPUR	STATION NOT AFFECTED MUGALKHOD_220	15:03	16:51	01:48	LINE CLEAR AVAILED
1340	10-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1341	10-Jan-24	BAGALKOT	110	SIRSI- SIRSI-1	SIRSI_220	10:06	16:17	06:11	LINE CLEAR AVAILED
1342	10-Jan-24	BAGALKOT	110	SIRSI- SIRSI-2	SIRSI_220	10:06	16:18	06:12	LINE CLEAR AVAILED
1343	10-Jan-24	BAGALKOT	110	SIRSI- UMMACHAGI	SIRSI_220	10:06	16:24	06:18	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1344	10-Jan-24	BAGALKOT	110	SIRSI-HUBLI 1	STATION NOT AFFECTED SIRSI_110	10:10	16:21	06:11	LINE CLEAR AVOIDED
1345	10-Jan-24	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)	14:20 (10.01.2024)	172:43:00	LINE CLEAR AVOIDED
1346	10-Jan-24	BAGALKOT	110	SIRSI-JOG1	STATION NOT AFFECTED SIRSI_110	16:21 (10.01.2024)			LINE CLEAR AVOIDED
1347	10-Jan-24	BAGALKOT	110	SIRSI-KAVALWADA	STATION NOT AFFECTED SIRSI_110	10:10	16:21	06:11	LINE CLEAR AVOIDED
1348	10-Jan-24	BAGALKOT	110	SIRSI-KUMATA 1& 2	STATION NOT AFFECTED SIRSI_110	10:10	16:21	06:11	LINE CLEAR AVOIDED
1349	10-Jan-24	BAGALKOT	110	STPR-F1Cbreaker (MHPUR)	STATION NOT AFFECTED SULATNPUR_110	10:36	18:08	07:32	LINE CLEAR AVOIDED
1350	10-Jan-24	BAGALKOT	110	STPR-F2 Cbreaker (MUGHULKHOD)	STATION NOT AFFECTED SULATNPUR_110	10:30	18:13	07:43	LINE CLEAR AVOIDED
1351	10-Jan-24	BAGALKOT	110	TODALB-JAMKHANDI (SUGARS)	TODALBAGI_110	07:15	07:21	00:06	TRIPPED ON FAULT
1352	10-Jan-24	BAGALKOT	110	UMMACHAG-SIRSI	STATION NOT AFFECTED (UMMACHAGI_110)	10:00	16:42	06:42	LINE CLEAR AVOIDED
1353	10-Jan-24	BAGALKOT	220	110/11KV,HV1(10MVA)	SIRSI_220	10:15	16:17	06:02	LINE CLEAR AVOIDED
1354	10-Jan-24	BAGALKOT	220	110/11KV,HV2(10MVA)	SIRSI_220	10:15	16:18	06:03	LINE CLEAR AVOIDED
1355	10-Jan-24	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED MUGALKHOD_220	10:19	17:30	07:11	LINE CLEAR AVOIDED
1356	10-Jan-24	BAGALKOT	220	220/110KV,HV1	SIRSI_220	10:15	16:16	06:01	LINE CLEAR AVOIDED
1357	10-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	SIRSI_220	10:15	16:16	06:01	LINE CLEAR AVOIDED
1358	10-Jan-24	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED MUGALKHOD_220	10:18	17:30	07:12	LINE CLEAR AVOIDED
1359	10-Jan-24	BAGALKOT	220	220/110KV,LV1	SIRSI_220	10:15	16:22	06:07	LINE CLEAR AVOIDED
1360	10-Jan-24	BAGALKOT	220	AMBEWADI - NARENDRA 1	STATION NOT AFFECTED AMBEWADI_220	10:52	16:05	05:13	LINE CLEAR AVOIDED
1361	10-Jan-24	BAGALKOT	220	AMBEWADI - NARENDRA 2	STATION NOT AFFECTED AMBEWADI_220	14:00	16:05	02:05	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1362	10-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA1	STATION NOT AFFECTED AMBEWADI_220	10:52	16:05	05:13	LINE CLEAR AVAILED
1363	10-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	14:00	16:05	02:05	LINE CLEAR AVAILED
1364	10-Jan-24	BAGALKOT	220	BELGAVI-KANABARAGI 2	STATION NOT AFFECTED BELAGAVI_220	10:02	18:56	08:54	LINE CLEAR AVAILED
1365	10-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1366	10-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
1367	10-Jan-24	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	10:18	16:12	05:54	LINE CLEAR AVAILED
1368	10-Jan-24	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:23	16:15	05:52	LINE CLEAR AVAILED
1369	10-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
1370	10-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
1371	10-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	10:52	16:05	05:13	LINE CLEAR AVAILED
1372	10-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	14:05	16:04	01:59	LINE CLEAR AVAILED
1373	10-Jan-24	BAGALKOT	220	SIRSI- HUBLI-1	SIRSI_220	10:19	16:12	05:53	LINE CLEAR AVAILED
1374	10-Jan-24	BAGALKOT	220	SIRSI- HUBLI-2	SIRSI_220	10:20	16:15	05:55	LINE CLEAR AVAILED
1375	10-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)	16:19 (10.01.2024)	247:24:00	LINE CLEAR AVAILED
1376	10-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	16:22 (10.01.2024)			LINE CLEAR AVAILED
1377	10-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)	16:22 (10.01.2024)	247:26:00	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1378	10-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	16:23 (10.01.2024)			LINE CLEAR AVOIDED
1379	10-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
1380	10-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1381	10-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR	07:20	07:30	00:10	TRIPPED ON FAULT
1382	10-Jan-24	BANGALORE	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGIRIPURA	15:20	16:10	00:50	LINE CLEAR AVOIDED
1383	10-Jan-24	BANGALORE	66	HV1	IISc	09:27	09:34	00:07	LINE CLEAR AVOIDED
1384	10-Jan-24	BANGALORE	66	HV1	NANDINI LAYOUT	15:40	15:44	00:04	LINE CLEAR AVOIDED
1385	10-Jan-24	BANGALORE	66	HV1	GUNDAMGERE	06:52	07:02	00:10	TRIPPED ON FAULT
1386	10-Jan-24	BANGALORE	66	HV1	BAGEPALLI	10:10	10:15	00:05	LINE CLEAR AVOIDED
1387	10-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	10:40	10:45	00:05	LINE CLEAR AVOIDED
1388	10-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	13:20	13:25	00:05	LINE CLEAR AVOIDED
1389	10-Jan-24	BANGALORE	66	HV1	MULBAGAL	11:43	12:22	00:39	TRIPPED ON FAULT
1390	10-Jan-24	BANGALORE	66	HV1	KGF	11:45	12:40	00:55	LINE CLEAR AVOIDED
1391	10-Jan-24	BANGALORE	66	HV2	VIJAYANAGARA	22:08	22:20	00:12	LINE CLEAR AVOIDED
1392	10-Jan-24	BANGALORE	66	HV2	BG ROAD	13:58	14:07	00:09	TRIPPED ON FAULT
1393	10-Jan-24	BANGALORE	66	HV2	MULBAGAL	11:43	12:22	00:39	TRIPPED ON FAULT
1394	10-Jan-24	BANGALORE	66	HV3	NAGANATHPURA 220	07:14	07:20	00:06	TRIPPED ON FAULT
1395	10-Jan-24	BANGALORE	66	ITI 220 - BANASAWADI	BANASAWADI(HV2)	02:10	02:20	00:10	TRIPPED ON FAULT
1396	10-Jan-24	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	17:02	17:06	00:04	LINE CLEAR AVOIDED
1397	10-Jan-24	BANGALORE	66	KUDURU - SRIGIRIPURA	SRIGIRIPURA	04:32	04:40	00:08	TRIPPED ON FAULT
1398	10-Jan-24	BANGALORE	66	MAGADI 220 - T G HALLI	V G DODDI, T G HALLI, TAVARAKERE	08:57	09:38	00:41	LINE CLEAR AVOIDED
1399	10-Jan-24	BANGALORE	66	SADALI - DIBBURAHALLI	DIBBURAHALLI	15:30	15:54	00:24	TRIPPED ON FAULT
1400	10-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	06:47	07:05	00:18	TRIPPED ON FAULT
1401	10-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	06:32	06:42	00:10	TRIPPED ON FAULT
1402	10-Jan-24	BANGALORE	220	HOODY 220 - ITPL 220	ITPL 220	16:12	16:55	00:43	TRIPPED ON FAULT
1403	10-Jan-24	BANGALORE	400	NELAMANGALA 400 - TALAGUPPA 400	NO STATION AFFECTED	13:02	19:27	06:25	TRIPPED ON FAULT
1404	10-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,TBPCL_IP P,GIRIYAPURA_66	12:02	13:17	00:11	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1405	10-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,TBPCL_IP,P,GIRIYAPURA_66	03:46	03:55	00:11	TRIPPED ON FAULT
1406	10-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66,HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
1407	10-Jan-24	GULBARGA	66	NEELANGUNDA-PUNABGHATA	PUNABGATTA_66,UCHCHANGIDURGA_66,PALLAGATTA_66,BILCHOD_66	12:40	12:46	00:11	TRIPPED ON FAULT
1408	10-Jan-24	GULBARGA	110	HV3	KANAKAGIRI_110	13:50	14:10	00:20	TRIPPED ON FAULT
1409	10-Jan-24	GULBARGA	110	HV3	SOMASAMUNDRA_110	06:30	06:45	00:11	TRIPPED ON FAULT
1410	10-Jan-24	GULBARGA	110	KHANAPUR-KADECHUR	KADECHUR_110,SAIDAPUR_110	05:28	05:38	00:11	TRIPPED ON FAULT
1411	10-Jan-24	GULBARGA	110	M KOLLUR-DEODURGA	DEODURGA_110	05:10	05:20	00:11	TRIPPED ON FAULT
1412	10-Jan-24	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,WALKAMDINI_110	19:33	19:51	00:18	TRIPPED ON FAULT
1413	10-Jan-24	GULBARGA	110	MUNIRABAD-BHORUKA	MUNIRABAD_220	12:31	13:00	00:11	TRIPPED ON FAULT
1414	10-Jan-24	GULBARGA	110	SHAHAPUR-RAICHUR2	NALWAR_110	05:12	05:19	00:11	TRIPPED ON FAULT
1415	10-Jan-24	GULBARGA	110	SULEKAL-MALLAPUR	KAMPLI_110,MALLAPUR_110	12:43	12:57	00:14	TRIPPED ON FAULT
1416	10-Jan-24	GULBARGA	220	HALWARTHY-LINGAPUR	HALWARTHY_220	09:27	14:23	04:56	LINE CLEAR AVAILED
1417	10-Jan-24	GULBARGA	220	HV2	CHICKSUGUR_110,SHAKTINAGAR_110,GABUR_110,GUGAL_110	10:37	14:32	03:55	LINE CLEAR AVAILED
1418	10-Jan-24	GULBARGA	220	MALLAT-LINGASUGUR	LINGASUGUR_220	03:50	04:00	00:10	TRIPPED ON FAULT
1419	10-Jan-24	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	10:40	13:20	02:40	MAIN SUPPLY FAILURE
1420	10-Jan-24	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	10:40	13:20	02:40	MAIN SUPPLY FAILURE
1421	10-Jan-24	HASSAN	66	BELUR66-CHIKMNGLR	BELUR_66	10:35	17:05	06:30	LINE CLEAR AVAILED
1422	10-Jan-24	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:25	17:10	06:45	LINE CLEAR AVAILED
1423	10-Jan-24	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	17:52	18:10	00:18	TRIPPED ON FAULT
1424	10-Jan-24	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	10:42	13:18	02:36	LINE CLEAR AVAILED
1425	10-Jan-24	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	10:20	13:38	03:18	LINE CLEAR AVAILED
1426	10-Jan-24	HASSAN	66	HASSN220-SKPURA1	HASSAN_220	10:35	13:20	02:45	LINE CLEAR AVAILED
1427	10-Jan-24	HASSAN	66	HASSN220-SKPURA2	HASSAN_220	10:36	10:49	00:13	LINE CLEAR AVAILED
1428	10-Jan-24	HASSAN	66	HASSN220-SKPURA2	HASSAN_220	13:25	13:28	00:03	LINE CLEAR AVAILED
1429	10-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	10:40	13:20	02:40	MAIN SUPPLY FAILURE
1430	10-Jan-24	HASSAN	66	HV1	BELUR_66	10:15	17:38	07:23	LINE CLEAR AVAILED
1431	10-Jan-24	HASSAN	66	HV1	HALEBEEDU_66	12:44	13:15	00:31	LINE CLEAR AVAILED
1432	10-Jan-24	HASSAN	66	HV1	MALLAPURA_66	12:34	16:55	04:21	LINE CLEAR AVAILED
1433	10-Jan-24	HASSAN	66	HV1	RAMNATHPURA_66	16:43	19:31	02:48	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1434	10-Jan-24	HASSAN	66	HV1	SAKALESH PURA_66	13:25	13:30	00:05	MAIN SUPPLY FAILURE
1435	10-Jan-24	HASSAN	66	HV1 CB	UGANE_66	04:54	05:05	00:11	MAIN SUPPLY FAILURE
1436	10-Jan-24	HASSAN	66	HV1 CB	UGANE_66	10:35	17:08	06:33	LINE CLEAR AVOIDED
1437	10-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	10:40	13:20	02:40	MAIN SUPPLY FAILURE
1438	10-Jan-24	HASSAN	66	HV2	BELUR_66	10:15	17:38	07:23	LINE CLEAR AVOIDED
1439	10-Jan-24	HASSAN	66	HV2	MALLAPURA_66	12:34	16:55	04:21	LINE CLEAR AVOIDED
1440	10-Jan-24	HASSAN	66	HV2	RAMNATH PURA_66	08:30	16:47	08:17	LINE CLEAR AVOIDED
1441	10-Jan-24	HASSAN	66	HV2	RAMNATH PURA_66	18:46	18:50	00:04	MAIN SUPPLY FAILURE
1442	10-Jan-24	HASSAN	66	HV2	SAKALESH PURA_66	13:25	13:30	00:05	MAIN SUPPLY FAILURE
1443	10-Jan-24	HASSAN	66	KANDLI-HASSAN	KANDLI_66	10:35	13:29	02:54	MAIN SUPPLY FAILURE
1444	10-Jan-24	HASSAN	66	SAKALE-HANBALU	SAKALESH PURA_66	13:25	13:30	00:05	MAIN SUPPLY FAILURE
1445	10-Jan-24	HASSAN	66	SAKALE-HASSN1	SAKALESH PURA_66	13:25	13:30	00:05	MAIN SUPPLY FAILURE
1446	10-Jan-24	HASSAN	66	SAKALE-HASSN2	SAKALESH PURA_66	13:25	13:30	00:05	MAIN SUPPLY FAILURE
1447	10-Jan-24	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	10:50	11:05	00:15	LINE CLEAR AVOIDED
1448	10-Jan-24	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	13:30	13:42	00:12	LINE CLEAR AVOIDED
1449	10-Jan-24	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:45	14:00	00:15	TRIPPED ON FAULT
1450	10-Jan-24	HASSAN	66	UGANE-L2	UGANE_66	04:54	05:05	00:11	MAIN SUPPLY FAILURE
1451	10-Jan-24	HASSAN	66	UGANE-L2	UGANE_66	10:35	17:08	06:33	LINE CLEAR AVOIDED
1452	10-Jan-24	HASSAN	110	HV1	SHIRALKOPPA_220	9:45(10.1.2024)			TRIPPED ON FAULT
1453	10-Jan-24	HASSAN	110	HV1	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1454	10-Jan-24	HASSAN	110	HV1	KONAJE_110	10:09	11:20	01:11	LINE CLEAR AVOIDED
1455	10-Jan-24	HASSAN	110	HV1	MADHUVANA_110	18:00	20:10	02:10	TRIPPED ON FAULT
1456	10-Jan-24	HASSAN	110	HV1	SALATHUR_110	10:12	12:22	02:10	LINE CLEAR AVOIDED
1457	10-Jan-24	HASSAN	110	HV2	BRAHMAVARA_110	10:28	12:56	02:28	LINE CLEAR AVOIDED
1458	10-Jan-24	HASSAN	110	HV2	BRAHMAVARA_110	12:58	15:24	02:26	LINE CLEAR AVOIDED
1459	10-Jan-24	HASSAN	110	HV2	KONAJE_110	11:25	13:33	02:08	LINE CLEAR AVOIDED
1460	10-Jan-24	HASSAN	110	HV2	SALATHUR_110	12:01	14:16	02:15	LINE CLEAR AVOIDED
1461	10-Jan-24	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	11:47	12:07	00:20	MAIN SUPPLY FAILURE
1462	10-Jan-24	HASSAN	110	LV1	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1463	10-Jan-24	HASSAN	110	LV1	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1464	10-Jan-24	HASSAN	110	LV2	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1465	10-Jan-24	HASSAN	110	MRSSHM-MPM	MRS MG_220	06:19	06:52	00:33	TRIPPED ON FAULT
1466	10-Jan-24	HASSAN	110	PUTTUR-MADAV	PUTTUR_220	11:45	12:00	00:15	LINE CLEAR AVOIDED
1467	10-Jan-24	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	11:48	11:59	00:11	LINE CLEAR AVOIDED
1468	10-Jan-24	HASSAN	110	SHRLKP-ANVATTI	SHIRALKOPPA_220	09:45	10:20	00:35	TRIPPED ON FAULT
1469	10-Jan-24	HASSAN	110	SHRLKP-ANVATTI	SHIRALKOPPA_220	12:15	12:20	00:05	TRIPPED ON FAULT
1470	10-Jan-24	HASSAN	110	SHRLKP-ANVATTI	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1471	10-Jan-24	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1472	10-Jan-24	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:15	12:20	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1473	10-Jan-24	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1474	10-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	09:45	10:30	00:45	TRIPPED ON FAULT
1475	10-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:05	12:20	00:15	TRIPPED ON FAULT
1476	10-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	12:25	13:30	01:05	TRIPPED ON FAULT
1477	10-Jan-24	HASSAN	110	SHRLKP-MAVLI	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1478	10-Jan-24	HASSAN	110	SHRLKP-MAVLI	SHIRALKOPPA_220	12:05	12:15	00:10	TRIPPED ON FAULT
1479	10-Jan-24	HASSAN	110	SHRLKP-MAVLI	SHIRALKOPPA_220	12:25	19:10	06:45	TRIPPED ON FAULT
1480	10-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1481	10-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:05	12:15	00:10	TRIPPED ON FAULT
1482	10-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1483	10-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1484	10-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:05	12:15	00:10	TRIPPED ON FAULT
1485	10-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1486	10-Jan-24	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	11:47	12:01	00:14	MAIN SUPPLY FAILURE
1487	10-Jan-24	HASSAN	220	HGUNJE-VRHI	HEGGUNJE_220	12:13	16:58	04:45	TRIPPED ON FAULT
1488	10-Jan-24	HASSAN	220	HV1	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1489	10-Jan-24	HASSAN	220	HV1	SHIRALKOPPA_220	09:45	10:25	00:40	TRIPPED ON FAULT
1490	10-Jan-24	HASSAN	220	HV1	PUTTUR_220	11:50	11:57	00:07	LINE CLEAR AVAILED
1491	10-Jan-24	HASSAN	220	HV2	SHIRALKOPPA_220	12:25	13:05	00:40	TRIPPED ON FAULT
1492	10-Jan-24	HASSAN	220	HV7	PUTTUR_220	11:50	11:57	00:07	LINE CLEAR AVAILED
1493	10-Jan-24	HASSAN	220	KEMAR'-PUTUR2	KEMAR_220	19:31(9.01.2024)	11:38(10.01.2024)	16:07HRS	LINE CLEAR AVAILED
1494	10-Jan-24	HASSAN	220	KEMAR'-PUTUR2	KEMAR_220	19:31(9.01.2024)	11:30(10.01.2024)	15:59HRS	LINE CLEAR AVAILED
1495	10-Jan-24	HASSAN	220	VARAHI-KEMAR3	gen_varahi	12:13	16:58	04:45	TRIPPED ON FAULT
1496	10-Jan-24	HASSAN	400	TALAGU-NELMNGLA	TALAGUPPA_400	13:02	19:27	06:25	TRIPPED ON FAULT
1497	10-Jan-24	MYSORE	66	BASARALU-NAGAMANGALA	BASARALU_66	09:15	17:30	08:15	LINE CLEAR AVAILED
1498	10-Jan-24	MYSORE	66	HV2	PERIYAPATNA_66	11:23	13:59	02:35	LINE CLEAR AVAILED
1499	10-Jan-24	MYSORE	66	HV5	SFCSHIVA_66	21:28			LINE CLEAR AVAILED
1500	10-Jan-24	MYSORE	66	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	02:39	02:48	00:08	TRIPPED ON FAULT
1501	10-Jan-24	MYSORE	66	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	06:55	07:05	00:10	TRIPPED ON FAULT
1502	10-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66PGPALY A_66	01:54	01:59	00:04	TRIPPED ON FAULT
1503	10-Jan-24	MYSORE	66	PERIYAPATNA-HANGODU	NO STATIONS EFFECTED	05:25	05:35	00:10	TRIPPED ON FAULT
1504	10-Jan-24	MYSORE	66	PERIYAPATNA-KAMPLAPURA	NO STATIONS EFFECTED	05:25	05:35	00:10	TRIPPED ON FAULT
1505	10-Jan-24	MYSORE	66	SANTHESARGUR-CHANDRAWADI	NO STATIONS EFFECTED	14:25	14:35	00:10	TRIPPED ON FAULT
1506	10-Jan-24	MYSORE	66	YELANDUR-MAMBALLI	MAMBALLI_66	10:40	10:48	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1507	10-Jan-24	TUMKUR	66	ANTHRASANAHALI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	15:07	18:14	03:07	LINE CLEAR AVAILED
1508	10-Jan-24	TUMKUR	66	BILCHODU66-NEELAGUBDA_220	PALLAGATTE_66, BILCHODE_66	13:45	13:50	00:05	TRIPPED ON FAULT
1509	10-Jan-24	TUMKUR	66	BILCHODU66-NEELAGUBDA_220	PALLAGATTE_66, BILCHODE_66	15:00	15:20	00:20	TRIPPED ON FAULT
1510	10-Jan-24	TUMKUR	66	BILCHODU66-NEELAGUBDA_220	PALLAGATTE_66, BILCHODE_66	16:20	16:50	00:30	TRIPPED ON FAULT
1511	10-Jan-24	TUMKUR	66	BILCHODU-UCHANGIDURGA	BILCHODU_66	10:15	10:30	00:15	MAIN SUPPLY FAILURE
1512	10-Jan-24	TUMKUR	66	BILCHODU-UCHANGIDURGA	BILCHODU_66	12:00	12:50	00:50	LINE CLEAR AVAILED
1513	10-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	09:17	18:14	08:57	LINE CLEAR AVAILED
1514	10-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	04:00	04:08	00:08	TRIPPED ON FAULT
1515	10-Jan-24	TUMKUR	66	CHITRAHALLI-PANDRAHALLI	CHITRAHALLI_66, H D PURA	03:55	04:10	00:15	MAIN SUPPLY FAILURE
1516	10-Jan-24	TUMKUR	66	CHITRAHALLI-PANDRAHALLI	CHITRAHALLI_66, H D PURA	09:03	18:16	09:13	MAIN SUPPLY FAILURE
1517	10-Jan-24	TUMKUR	66	HANAGAL- RAMPURA	RAMAPURA_66 NAGASAMUDRA_66	11:55	12:06	00:11	TRIPPED ON FAULT
1518	10-Jan-24	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	HONNUDIKE_66	09:16	10:46	01:30	TRIPPED ON FAULT
1519	10-Jan-24	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66, DASUDI_66	06:05	06:15	00:10	TRIPPED ON FAULT
1520	10-Jan-24	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66, DASUDI_66	00:42	00:55	00:13	TRIPPED ON FAULT
1521	10-Jan-24	TUMKUR	66	HV2(TR2)	MADADKERE_66	11:37	11:41	00:04	TRIPPED ON FAULT
1522	10-Jan-24	TUMKUR	66	MATHOD 66-KANCHIPURA	KANCHIPURA_66	06:30	06:40	00:10	TRIPPED ON FAULT
1523	10-Jan-24	TUMKUR	66	MATHOD 66-KANCHIPURA	KANCHIPURA_66	18:25	18:40	00:15	TRIPPED ON FAULT
1524	10-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1525	10-Jan-24	TUMKUR	66	SIRA220-MADHUGIRI 1	GULIGENAHALLI_66, MADHUGIRI_66	12:15	13:30	01:14	LINE CLEAR AVAILED
1526	10-Jan-24	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	15:10	15:20	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1527	10-Jan-24	TUMKUR	66	URDIGERE- ANTHRASANAHALLI	URDIGERE_66	18:00	18:15	00:15	LINE CLEAR AVAILED
1528	10-Jan-24	TUMKUR	220	DAVANGERE SRS- GUTTUR_2	DAVANGERE_SRS_220	15:41	17:42	02:01	LINE CLEAR AVAILED
1529	10-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1530	10-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1531	10-Jan-24	TUMKUR	400	GUTTUR 400KV- BTPS	GUTTUR_400	19:32 (08.01.24)	16:37 (10.1.24)	1DAY 21:05	TRIPPED ON FAULT
1532	11-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	TAKKALAKI_110	07:37	07:41	00:04	TRIPPED ON FAULT
1533	11-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	TALIKOT_110	07:44	08:03	00:19	TRIPPED ON FAULT
1534	11-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	KUD DHARWAD_110	12:06	18:37	06:31	LINE CLEAR AVAILED
1535	11-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	TAKKALAKI_110	07:37	07:41	00:04	TRIPPED ON FAULT
1536	11-Jan-24	BAGALKOT	110	110/11KV,HV-2(10MVA)	TALIKOT_110	07:44	08:03	00:19	TRIPPED ON FAULT
1537	11-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA-HV4)	KULIGOD_110	15:03	17:05	02:02	TRIPPED ON FAULT
1538	11-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA-HV4)	KULIGOD_110	17:50	20:33	02:43	LINE CLEAR AVAILED
1539	11-Jan-24	BAGALKOT	110	BYADAGI-RAIWAY LINE	BYADAGI_110	11:36	14:30	02:54	LINE CLEAR AVAILED
1540	11-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
1541	11-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1542	11-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1543	11-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1544	11-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1545	11-Jan-24	BAGALKOT	110	MUKARTHIHAL-SPV	MUKARTHIHAL_110	19:06 (11.01.2024)			LINE CLEAR AVAILED
1546	11-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1547	11-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1548	11-Jan-24	BAGALKOT	110	TAKKALAKI-KNS SOLAR	TAKKALAKI_110	07:37	07:41	00:04	TRIPPED ON FAULT
1549	11-Jan-24	BAGALKOT	110	TAKKALAKI-THORVI(KIADB BIJAPUR)	TAKKALAKI_110	07:37	07:40	00:03	TRIPPED ON FAULT
1550	11-Jan-24	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	07:37	07:40	00:03	TRIPPED ON FAULT
1551	11-Jan-24	BAGALKOT	110	TAKKALAKI-WARADA	TAKKALAKI_110	07:37	07:41	00:04	TRIPPED ON FAULT
1552	11-Jan-24	BAGALKOT	220	220/110KV, HV2(HV4), LV2(LV4)	GADAG_220	19:04	19:15	00:11	TRIPPED ON FAULT
1553	11-Jan-24	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	10:34	12:03	01:29	LINE CLEAR AVAILED
1554	11-Jan-24	BAGALKOT	220	BELAGAVI- KANABARGI1	STATION NOT AFFECTED BELAGAVI_220	10:03	19:22	09:19	LINE CLEAR AVAILED
1555	11-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1556	11-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
1557	11-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
1558	11-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI1	STATION NOT AFFECTED NARENDRA_220	11:06	15:55	04:49	LINE CLEAR AVAILED
1559	11-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
1560	11-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)			LINE CLEAR AVAILED
1561	11-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)			LINE CLEAR AVAILED
1562	11-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
1563	11-Jan-24	BANGALORE	66	66KV CHINTAMANI 66 - RAILWAY TRACTION 66/25KV	RAILWAY TRACTION SUBSTATION CHINTAMANI	17:32	18:25	00:53	TRIPPED ON FAULT
1564	11-Jan-24	BANGALORE	66	66KV MITTEMARI 220 - PATHPALYA - GULUR	PATHAPALYA, THIMMAMPALLI, GULUR	11:03	11:09	00:06	TRIPPED ON FAULT
1565	11-Jan-24	BANGALORE	66	AVANI-K&C VALLEY	K&C VALLEY PUMP HOUSE	00:00	23:59:00	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1566	11-Jan-24	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	00:50	02:21	01:31	MAIN SUPPLY FAILURE
1567	11-Jan-24	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	00:50	02:21	01:31	MAIN SUPPLY FAILURE
1568	11-Jan-24	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	12:48	13:08	00:20	TRIPPED ON FAULT
1569	11-Jan-24	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI	00:50	02:21	01:31	MAIN SUPPLY FAILURE
1570	11-Jan-24	BANGALORE	66	HV1	CHATRA	18:01	18:06	00:05	TRIPPED ON FAULT
1571	11-Jan-24	BANGALORE	66	HV1	CHATRA	09:02	09:10	00:08	TRIPPED ON FAULT
1572	11-Jan-24	BANGALORE	66	HV1	MAGADI 220	13:57	16:30	02:33	LINE CLEAR AVAILED
1573	11-Jan-24	BANGALORE	66	HV2	VIJAYNAGAR	22:17	22:28	00:11	LINE CLEAR AVAILED
1574	11-Jan-24	BANGALORE	66	HV2	SULIBELE	17:40	18:05	00:25	LINE CLEAR AVAILED
1575	11-Jan-24	BANGALORE	66	HV2	NARASAPURA	12:40	12:50	00:10	LINE CLEAR AVAILED
1576	11-Jan-24	BANGALORE	66	HV2	GUDEMARANAHALLI	23:30	23:35	00:05	TRIPPED ON FAULT
1577	11-Jan-24	BANGALORE	66	MAGADI 220 - MAGADI 66	MAGADI 66, HOSPALYA CIRCLE	12:45	15:16	02:31	LINE CLEAR AVAILED
1578	11-Jan-24	BANGALORE	66	MALLASANDRA - DRDO(EHT)	MALLASANDRA, DALASANUR, YELDUR, SRINIVASPURA, G KODIHALLI	13:15	13:20	00:05	TRIPPED ON FAULT
1579	11-Jan-24	BANGALORE	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	17:25	17:30	00:05	LINE CLEAR AVAILED
1580	11-Jan-24	BANGALORE	66	SOMENAHALLI - PERESANDRA	PERESANDRA	11:10	11:30	00:20	TRIPPED ON FAULT
1581	11-Jan-24	BANGALORE	66	SRINIVASPURA 66 - KOLAR 220	G KODIHALLI, SRINIVASPURA	14:30	14:33	00:03	LINE CLEAR AVAILED
1582	11-Jan-24	BANGALORE	66	VIJAYNAGAR - NRS 220	VIJAYNAGAR	22:16	22:27	00:11	LINE CLEAR AVAILED
1583	11-Jan-24	BANGALORE	220	220KV CHINTAMANI-SRINIVASAPURA LINE-2	NO STATION AFFECTED	00:50	02:23	01:33	TRIPPED ON FAULT
1584	11-Jan-24	BANGALORE	220	220KV PGCIL KOLAR-CHINTAMANI LINE-1	CHINTAMANI 220	00:50	02:19	01:29	TRIPPED ON FAULT
1585	11-Jan-24	BANGALORE	220	HV1	CHINTAMANI 220	00:50	02:21	01:31	TRIPPED ON FAULT
1586	11-Jan-24	GULBARGA	66	HIREHADAGALLI-GIRIYAPURA	GIRIYAPUR_66,MAGALA_66	18:30	18:45	00:15	TRIPPED ON FAULT
1587	11-Jan-24	GULBARGA	66	HV2	HUVINHADAGALLI_66	06:55	07:00	00:05	TRIPPED ON FAULT
1588	11-Jan-24	GULBARGA	66	HV2	HUVINHADAGALLI_66	08:05	08:10	00:05	TRIPPED ON FAULT
1589	11-Jan-24	GULBARGA	66	HV2	HUVINHADAGALLI_66	08:15	08:20	00:05	TRIPPED ON FAULT
1590	11-Jan-24	GULBARGA	66	HV3	HALVAGALU_66	10:00	10:20	00:20	TRIPPED ON FAULT
1591	11-Jan-24	GULBARGA	66	KUDLIGI-BANVEKAL	BANVEKAL_66	04:20	04:40	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1592	11-Jan-24	GULBARGA	66	KUDLIGI-GUDEKOTE	GUDEKOTE_66,CJHALLI_66, HOSAHALLI_66	17:00(19.12.2023)			LINE CLEAR AVAILED
1593	11-Jan-24	GULBARGA	110	ALIPUR-BELLARY NORTH	BELLARY NORTH_110,SOMASAMUNDRA_110,ACC FACTORY_IPP	08:53	23:42	14:49	LINE CLEAR AVAILED
1594	11-Jan-24	GULBARGA	110	CHINCHOLI-SEDAM	CHINCHOLI_110	18:23	18:34	00:11	TRIPPED ON FAULT
1595	11-Jan-24	GULBARGA	110	KONKAL-RAMASAMMUDRA	KONKAL_110	02:31	02:40	00:09	TRIPPED ON FAULT
1596	11-Jan-24	GULBARGA	110	KONKAL-RAMASAMMUDRA	KONKAL_110	04:38	04:45	00:07	TRIPPED ON FAULT
1597	11-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	04:06	04:13	00:07	TRIPPED ON FAULT
1598	11-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	06:06	06:11	00:05	TRIPPED ON FAULT
1599	11-Jan-24	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110,NALWAR_110	18:18	20:07	01:49	LINE CLEAR AVAILED
1600	11-Jan-24	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110,NALWAR_110	23:49	23:56	00:07	TRIPPED ON FAULT
1601	11-Jan-24	GULBARGA	220	HV1	LINGASUGUR_220	07:46	12:12	04:26	LINE CLEAR AVAILED
1602	11-Jan-24	GULBARGA	220	HV1	SHAHAPUR_220	16:00	20:01	04:01	LINE CLEAR AVAILED
1603	11-Jan-24	GULBARGA	220	HV2	LINGASUGUR_220	12:18	15:24	03:06	LINE CLEAR AVAILED
1604	11-Jan-24	HASSAN	66	HASSN220-SKPURA	HASSAN_220	18:42	19:05	00:23	TRIPPED ON FAULT
1605	11-Jan-24	HASSAN	66	HV1	MALLAPURA_66	12:12	12:56	00:44	LINE CLEAR AVAILED
1606	11-Jan-24	HASSAN	66	HV1	RAMNATHPURA_66	10:00	12:40	02:40	LINE CLEAR AVAILED
1607	11-Jan-24	HASSAN	66	HV2	MALLAPURA_66	12:12	12:56	00:44	LINE CLEAR AVAILED
1608	11-Jan-24	HASSAN	66	KANDLI-HASSAN	KANDLI_66	18:43	19:05	00:22	MAIN SUPPLY FAILURE
1609	11-Jan-24	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	18:42	19:15	00:33	MAIN SUPPLY FAILURE
1610	11-Jan-24	HASSAN	66	MALLAPUR-SHIMOGA	MALLAPURA_66	12:12	12:55	00:43	LINE CLEAR AVAILED
1611	11-Jan-24	HASSAN	66	SAKALE-HASSAN	SAKALESHPURA_66	18:42	19:10	00:28	TRIPPED ON FAULT
1612	11-Jan-24	HASSAN	110	HV1	SHIRALKOPPA_220	9:45(10.1.2024)	19:10(11.1.2024)	81:25HRS	LINE CLEAR AVAILED
1613	11-Jan-24	HASSAN	110	HV1	MANIPAL_110	10:12	13:04	02:52	LINE CLEAR AVAILED
1614	11-Jan-24	HASSAN	110	HV2	ESSUR_110	9:40(8.01.2024)	12:55(11.1.2024)	75:15HRS	LINE CLEAR AVAILED
1615	11-Jan-24	HASSAN	110	HV2	MANIPAL_110	13:06	15:22	02:16	LINE CLEAR AVAILED
1616	11-Jan-24	HASSAN	110	HV3	GURUVAYANKERE_110	10:53	16:47	05:54	LINE CLEAR AVAILED
1617	11-Jan-24	HASSAN	110	KADUR-AJAMPURA	KADUR_220	12:57	13:13	00:16	TRIPPED ON FAULT
1618	11-Jan-24	HASSAN	110	LPH-LST3	gen_lph	11:09	13:42	02:33	LINE CLEAR AVAILED
1619	11-Jan-24	HASSAN	110	LPH-LST4	gen_lph	14:03	14:54	00:51	LINE CLEAR AVAILED
1620	11-Jan-24	HASSAN	110	LV3	KEMAR	11:20	13:33	02:13	LINE CLEAR AVAILED
1621	11-Jan-24	HASSAN	110	SAGARA-LST4	SAGARA_110	11:10	13:40	02:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1622	11-Jan-24	HASSAN	220	CRPATNA2-GOPALPURA	SHANTIGRAMA_400	08:23	11:40	03:17	LINE CLEAR AVAILED
1623	11-Jan-24	HASSAN	220	CRPATNA2-HSN400	CRPATNA_220	08:03	11:31	03:28	LINE CLEAR AVAILED
1624	11-Jan-24	HASSAN	220	CRPATNA2-HSN400	GOPALAPURA_220	08:23	11:40	03:17	LINE CLEAR AVAILED
1625	11-Jan-24	HASSAN	220	HV3	KEMAR	11:20	13:32	02:12	LINE CLEAR AVAILED
1626	11-Jan-24	MYSORE	66	HV1	CHIKKA_MANDYA_66	10:42	10:45	00:03	TRIPPED ON FAULT
1627	11-Jan-24	MYSORE	66	HV2	CHIKKA_MANDYA_66	10:42	10:45	00:03	TRIPPED ON FAULT
1628	11-Jan-24	MYSORE	66	HV5	SFCSHIVA_66	21:28 (10.01.2024)	00:16	2:47 HRs	LINE CLEAR AVAILED
1629	11-Jan-24	MYSORE	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	16:25	16:30	00:05	TRIPPED ON FAULT
1630	11-Jan-24	MYSORE	66	MADIKERI-VIRAJPETE	NO STATIONS EFFECTED	02:35	02:50	00:15	TRIPPED ON FAULT
1631	11-Jan-24	MYSORE	66	MAHADESHWARAPURA-JAKKANAHALLI	G MALLIGERE_66 JAKKANAHALLY_66	15:20	15:25	00:05	LINE CLEAR AVAILED
1632	11-Jan-24	MYSORE	66	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	12:39	17:37	04:58	TRIPPED ON FAULT
1633	11-Jan-24	MYSORE	66	PERIYAPATNA-KAMPLAPURA	NO STATIONS EFFECTED	02:32	03:03	00:31	TRIPPED ON FAULT
1634	11-Jan-24	MYSORE	220	KADAKOLA-HOOTAGALLY	NO STATIONS EFFECTED	18:15	18:34	00:19	TRIPPED ON FAULT
1635	11-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHARA_66	14:32	14:40	00:08	TRIPPED ON FAULT
1636	11-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, SHYAGALE66	21:48	22:06	00:18	TRIPPED ON FAULT
1637	11-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	11:14	11:24	00:10	TRIPPED ON FAULT
1638	11-Jan-24	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:59	11:45	00:46	LINE CLEAR AVAILED
1639	11-Jan-24	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	11:25	11:42	00:17	LINE CLEAR AVAILED
1640	11-Jan-24	TUMKUR	66	HIRIYUR 220KV- THALLAK	THALLAK_66, RANGENAHALLI_66	11:06	11:34	00:28	LINE CLEAR AVAILED
1641	11-Jan-24	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:48	11:45	00:57	LINE CLEAR AVAILED
1642	11-Jan-24	TUMKUR	66	HV1(TR1)	MELLEKATTE_66,	17:04	17:55	00:51	LINE CLEAR AVAILED
1643	11-Jan-24	TUMKUR	66	HV1(TR1)	TUMKUR_66	13:08	13:26	00:18	LINE CLEAR AVAILED
1644	11-Jan-24	TUMKUR	66	HV2(TR2)	MADADKERE_66	09:10	09:15	00:05	TRIPPED ON FAULT
1645	11-Jan-24	TUMKUR	66	HV2(TR2)	MADADKERE_66	10:30	10:40	00:10	TRIPPED ON FAULT
1646	11-Jan-24	TUMKUR	66	HV2(TR2)	TUMKUR_66	12:48	13:05	00:17	LINE CLEAR AVAILED
1647	11-Jan-24	TUMKUR	66	KUKKAWADA-DAVANGERE SRS	KUKKAWADA_66, SHAGALE_66	21:48	21:58	00:10	TRIPPED ON FAULT
1648	11-Jan-24	TUMKUR	66	MADHUGIRI 220KV-PULLAMAGATTA	PULLAMGATTA_66	02:51	03:10	00:19	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1649	11-Jan-24	TUMKUR	66	MADHUGIRI 220KV- SIRA 1	GULIGENAHALLI_66,	02:04	02:32	00:27	TRIPPED ON FAULT
1650	11-Jan-24	TUMKUR	66	MADHUGIRI 220KV- SIRA 1	GULIGENAHALLI_66,	22:22	22:40	00:18	TRIPPED ON FAULT
1651	11-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1652	11-Jan-24	TUMKUR	66	SIRA220-BUKKAPATNA	BUKKAPATNA_66	18:32	18:40	00:08	TRIPPED ON FAULT
1653	11-Jan-24	TUMKUR	66	TUMKUR-URDIGERE KOLALA	TUMKUR_66	12:12	12:40	00:28	LINE CLEAR AVAILED
1654	11-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1655	11-Jan-24	TUMKUR	220	HV2(TR2)	HIRIYUR_220	11:07	11:31	00:24	LINE CLEAR AVAILED
1656	11-Jan-24	TUMKUR	220	HV2(TR2)	JAGALUR_400	10:23	17:08	06:45	LINE CLEAR AVAILED
1657	11-Jan-24	TUMKUR	220	HV3(TR3)	DAVANAGERE_220	13:28	14:17	00:49	TRIPPED ON FAULT
1658	11-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1659	11-Jan-24	TUMKUR	400	HV1(TR1)	JAGALUR_400	10:24	17:03	06:38	LINE CLEAR AVAILED
1660	12-Jan-24	BAGALKOT	110	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED KUD DHARWAD_110	15:47	18:40	02:53	LINE CLEAR AVAILED
1661	12-Jan-24	BAGALKOT	110	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KUD DHARWAD_110	11:43	15:45	04:02	LINE CLEAR AVAILED
1662	12-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	MUNDAGOD_110	10:00	14:39	04:39	LINE CLEAR AVAILED
1663	12-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	MUNDAGOD_110	15:40	17:40	02:00	LINE CLEAR AVAILED
1664	12-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	BIJAPUR_220	11:10	11:19	00:09	LINE CLEAR AVAILED
1665	12-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	ALBAL_110	12:02	17:32	05:30	LINE CLEAR AVAILED
1666	12-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	MAMADAPUR(G)_110	12:32	12:47	00:15	TRIPPED ON FAULT
1667	12-Jan-24	BAGALKOT	110	220/110KV,HV1,LV1	KUDUCHI_220,MORAB_110, YELPARHATTI_110,KUDUCHI_110,HARUGERI_110,SHIRAGUPPI_110	18:30	19:00	00:30	TRIPPED ON FAULT
1668	12-Jan-24	BAGALKOT	110	220/110KV,HV2,LV2	STATION NOT AFFECTED MUGALKHOD_220	10:06	14:03	03:57	LINE CLEAR AVAILED
1669	12-Jan-24	BAGALKOT	110	GARAG-F1(NARENDRA)	STATION NOT AFFECTED GARAG_110	11:30	17:08	05:38	LINE CLEAR AVAILED
1670	12-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1671	12-Jan-24	BAGALKOT	110	HUBLI-RAMANAKOPPA	STATION NOT AFFECTED HUBLI_220	00:16	09:11	08:55	TRIPPED ON FAULT
1672	12-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1673	12-Jan-24	BAGALKOT	110	KUDUCHI-AINAPUR	KUDUCHI_220	18:40	19:35	00:55	TRIPPED ON FAULT
1674	12-Jan-24	BAGALKOT	110	KUDUCHI-SHIRAGUPPI	KUDUCHI_220	11:05	13:40	02:35	LINE CLEAR AVAILED
1675	12-Jan-24	BAGALKOT	110	KUDUCHI-UGAR KHUD	KUDUCHI_220	18:40	19:37	00:57	TRIPPED ON FAULT
1676	12-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1677	12-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1678	12-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1679	12-Jan-24	BAGALKOT	110	MUKARTHIHAL-SPV	MUKARTHIHAL_110	19:06 (11.01.2024)	6:09 (12:01.2024)	11:03:00	LINE CLEAR AVAILED
1680	12-Jan-24	BAGALKOT	110	MUKARTHIHAL-SPV	MUKARTHIHAL_110	19:27 (12.01.2024)			LINE CLEAR AVAILED
1681	12-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
1682	12-Jan-24	BAGALKOT	110	RAMANKO-SRS	RAMANKOPPA_110	01:06	10:05	08:59	LINE CLEAR AVAILED
1683	12-Jan-24	BAGALKOT	110	SANKS110-CHIKKODI	STATION NOT AFFECTED SANKESHWAR_110	18:07	18:18	00:11	LINE CLEAR AVAILED
1684	12-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
1685	12-Jan-24	BAGALKOT	110	VAJARMATTI-MANTUR-II	STATION NOT AFFECTED VAJARMATTI_220	12:46	15:31	02:45	LINE CLEAR AVAILED
1686	12-Jan-24	BAGALKOT	110	YLWD-F2 Cbreaker (SAVALAGI)	STATION NOT AFFECTED YELLAMANWADI_110	15:51	15:58	00:07	LINE CLEAR AVAILED
1687	12-Jan-24	BAGALKOT	220	220/110KV, HV2,LV2	STATION NOT AFFECTED CHIKKODI_220	10:36	12:16	01:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1688	12-Jan-24	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED HUBLI_220	00:16	00:32	00:16	TRIPPED ON FAULT
1689	12-Jan-24	BAGALKOT	220	220/110KV,HV2	KUDUCHI_220	19:03	19:06	00:03	TRIPPED ON FAULT
1690	12-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	KUDUCHI_220	18:30	19:10	00:40	TRIPPED ON FAULT
1691	12-Jan-24	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED HUBLI_220	00:16	00:33	00:17	TRIPPED ON FAULT
1692	12-Jan-24	BAGALKOT	220	220/110KV,LV2	KUDUCHI_220	19:03	19:08	00:05	TRIPPED ON FAULT
1693	12-Jan-24	BAGALKOT	220	AMBEWADI-PONDA1	STATION NOT AFFECTED AMBEWADI_220	15:24	16:52	01:28	TRIPPED ON FAULT
1694	12-Jan-24	BAGALKOT	220	AMBEWADI-PONDA2	STATION NOT AFFECTED AMBEWADI_220	09:46	12:04	02:18	TRIPPED ON FAULT
1695	12-Jan-24	BAGALKOT	220	BELGAUM-KANABARGI1	STATION NOT AFFECTED BELGAUM_220	09:36	19:58	10:22	LINE CLEAR AVAILED
1696	12-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
1697	12-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
1698	12-Jan-24	BAGALKOT	220	KUDUCHI-ATHANI	KUDUCHI_220	18:40	19:38	00:58	TRIPPED ON FAULT
1699	12-Jan-24	BAGALKOT	220	KUDUCHI-CHIKKODI1	KUDUCHI_220	18:40	18:50	00:10	TRIPPED ON FAULT
1700	12-Jan-24	BAGALKOT	220	KUDUCHI-CHIKKODI2	KUDUCHI_220	19:03	19:05	00:02	TRIPPED ON FAULT
1701	12-Jan-24	BAGALKOT	220	KUDUCHI-MAHALINGAPUR	KUDUCHI_220	19:03	19:45	00:42	TRIPPED ON FAULT
1702	12-Jan-24	BAGALKOT	220	MAHALINGAPUR-KUDACHI	STATION NOT AFFECTED MAHALINGAPUR_220	18:28	19:45	01:17	TRIPPED ON FAULT
1703	12-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
1704	12-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
1705	12-Jan-24	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	15:15	15:42	00:27	LINE CLEAR AVAILED
1706	12-Jan-24	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	15:16	15:42	00:26	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1707	12-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	14:55	15:15	00:20	LINE CLEAR AVOIDED
1708	12-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	15:29	15:34	00:05	LINE CLEAR AVOIDED
1709	12-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	15:42 (12.01.2024)			LINE CLEAR AVOIDED
1710	12-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	15:34 (12.01.2024)			LINE CLEAR AVOIDED
1711	12-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	8:55 (31.12.2023)	14:52 (12.01.2024)	293:57:00	LINE CLEAR AVOIDED
1712	12-Jan-24	BAGALKOT	220	SIRSI-SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	8:56 (31.12.2023)	15:16 (12.01.2024)	294:20:00	LINE CLEAR AVOIDED
1713	12-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
1714	12-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1715	12-Jan-24	BANGALORE	66	CHINTAMANI 66 - RAILWAY TRACTION	RAILWAY SUBSTATION CHINTAMANI	12:56	13:23	00:27	TRIPPED ON FAULT
1716	12-Jan-24	BANGALORE	66	GOKULA - MATHIKERE	MATHIKERE	14:15	14:30	00:15	LINE CLEAR AVOIDED
1717	12-Jan-24	BANGALORE	66	HSR LAYOUT 220 - NAGANATHPURA 1	NO STATION AFFECTED	11:24	23:59	12:35	TRIPPED ON FAULT
1718	12-Jan-24	BANGALORE	66	HV1	SULIBELE	23:19	23:25	00:06	TRIPPED ON FAULT
1719	12-Jan-24	BANGALORE	66	HV1	M GOLLAHALLI	00:58	01:16	00:18	TRIPPED ON FAULT
1720	12-Jan-24	BANGALORE	66	HV1	M GOLLAHALLI	09:25	09:35	00:10	TRIPPED ON FAULT
1721	12-Jan-24	BANGALORE	66	HV1	PERESANDRA	16:00	16:05	00:05	LINE CLEAR AVOIDED
1722	12-Jan-24	BANGALORE	66	HV1	CHATRA	13:45	13:50	00:05	TRIPPED ON FAULT
1723	12-Jan-24	BANGALORE	66	HV1	CHATRA	21:10	21:15	00:05	TRIPPED ON FAULT
1724	12-Jan-24	BANGALORE	66	HV2	CHELUR	16:50	16:55	00:05	LINE CLEAR AVOIDED
1725	12-Jan-24	BANGALORE	66	HV2	SUGUTUR	15:10	15:45	00:35	LINE CLEAR AVOIDED
1726	12-Jan-24	BANGALORE	66	HV2	KYASAMBALLI	11:40	12:30	00:50	LINE CLEAR AVOIDED
1727	12-Jan-24	BANGALORE	66	HV2	CHANDAPURA	14:40	14:42	00:02	LINE CLEAR AVOIDED
1728	12-Jan-24	BANGALORE	66	HV3	HSR LAYOUT 220	05:20	07:30	02:10	LINE CLEAR AVOIDED
1729	12-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1730	12-Jan-24	BANGALORE	66	KODIHALLI - BIJJAHALLI	BIJJAHALLI, HUNSENAHALLI	11:52	12:22	00:30	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1731	12-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPETE 1	NO STATION AFFECTED	07:25	07:36	00:11	TRIPPED ON FAULT
1732	12-Jan-24	BANGALORE	66	MAASTHI - ADANI SOLAR(EHT)	NO STATION AFFECTED	06:20	06:30	00:10	TRIPPED ON FAULT
1733	12-Jan-24	BANGALORE	66	PRESTIGE SHANTINIKETHAN - HOODY 220	PRESTIGE SHANTINIKETHAN	11:42	11:57	00:15	LINE CLEAR AVOIDED
1734	12-Jan-24	BANGALORE	66	RMV - GOKULA	RMV, TATA INSTITUTE(EHT)	13:30	13:34	00:04	LINE CLEAR AVOIDED
1735	12-Jan-24	BANGALORE	66	RMV - HEBBALA	RMV, TATA INSTITUTE(EHT)	14:45	14:49	00:04	LINE CLEAR AVOIDED
1736	12-Jan-24	BANGALORE	66	SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	11:30	13:16	01:46	TRIPPED ON FAULT
1737	12-Jan-24	GULBARGA	66	HAMPASAGAR-HIREHADAGALI-2	SOVENHALLI_66	18:30	18:42	00:12	TRIPPED ON FAULT
1738	12-Jan-24	GULBARGA	66	HANGAL-GUDEKOTE	CJ_HALLI_66,HOSAHALLI_66	10:20	10:30	00:10	TRIPPED ON FAULT
1739	12-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	16:30	17:00	00:30	LINE CLEAR AVOIDED
1740	12-Jan-24	GULBARGA	220	SHAHAPUR-FIROZABAD-2	SHAHPUR_220	15:32	15:34	00:02	TRIPPED ON FAULT
1741	12-Jan-24	GULBARGA	220	SHAHAPUR-FIROZABAD-2	SHAHPUR_220	15:34	18:34	03:00	LINE CLEAR AVOIDED
1742	12-Jan-24	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	11:40	11:45	00:05	LINE CLEAR AVOIDED
1743	12-Jan-24	HASSAN	66	HNP	HNPURA_66	10:30	12:44	02:14	LINE CLEAR AVOIDED
1744	12-Jan-24	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	12:35	12:40	00:05	LINE CLEAR AVOIDED
1745	12-Jan-24	HASSAN	66	HV1	HOLEHONNUR_66	09:20	10:21	01:01	MAIN SUPPLY FAILURE
1746	12-Jan-24	HASSAN	66	HV2	HOLEHONNUR_66	09:20	10:21	01:01	MAIN SUPPLY FAILURE
1747	12-Jan-24	HASSAN	66	KANDLI-SAKLIESHPUR	KANDLI_66	12:10	13:10	01:00	LINE CLEAR AVOIDED
1748	12-Jan-24	HASSAN	66	MYSOR1	HNPURA_220	18:11	18:30	00:19	TRIPPED ON FAULT
1749	12-Jan-24	HASSAN	66	SAKALE-HASSAN1	SAKALESHPURA_66	12:10	13:12	01:02	LINE CLEAR AVOIDED
1750	12-Jan-24	HASSAN	66	SAKALE-HASSAN2	SAKALESHPURA_66	11:40	11:45	00:05	LINE CLEAR AVOIDED
1751	12-Jan-24	HASSAN	66	TAVAREC-HONNALLI	TAVARECHETTANAHALLY_66	09:25	10:13	00:48	TRIPPED ON FAULT
1752	12-Jan-24	HASSAN	110	BANTWA-AMR	BANTWALA_110	14:45	15:53	01:08	LINE CLEAR AVOIDED
1753	12-Jan-24	HASSAN	110	HV1	BANTWALA_110	09:45	12:30	02:45	LINE CLEAR AVOIDED
1754	12-Jan-24	HASSAN	110	HV1	BANTWALA_110	12:35	15:27	02:52	LINE CLEAR AVOIDED
1755	12-Jan-24	HASSAN	110	HV1	JADE_110	17:07	17:37	00:30	LINE CLEAR AVOIDED
1756	12-Jan-24	HASSAN	110	HV2	JADE_110	17:07	17:37	00:30	LINE CLEAR AVOIDED
1757	12-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVOIDED
1758	12-Jan-24	HASSAN	220	HGUNJE-HONNALLI	HEGGUNJE_220	10:19	14:16	03:57	LINE CLEAR AVOIDED
1759	12-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVOIDED
1760	12-Jan-24	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:19	14:16	03:57	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1761	12-Jan-24	MYSORE	66	CRNAGA-KOLLEGALA	MUGUR_66 JANNUR_66 THAYUR_66 TNARSIPURA_66 GARGESHWARI_66	14:35	14:39	00:04	TRIPPED ON FAULT
1762	12-Jan-24	MYSORE	66	HOOTGALLY-RBI	NO STATIONS EFFECTED	13:19	14:53	01:33	TRIPPED ON FAULT
1763	12-Jan-24	MYSORE	66	HV1	BGPURA_66	13:03	13:30	00:26	LINE CLEAR AVAILED
1764	12-Jan-24	MYSORE	66	HV1	HONNALLY_66	17:05	17:36	00:31	LINE CLEAR AVAILED
1765	12-Jan-24	MYSORE	66	HV2	HONNALLY_66	16:10	17:00	00:50	LINE CLEAR AVAILED
1766	12-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	10:40	10:52	00:12	TRIPPED ON FAULT
1767	12-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07			TRIPPED ON FAULT
1768	12-Jan-24	MYSORE	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	08:03	08:40	00:37	TRIPPED ON FAULT
1769	12-Jan-24	MYSORE	66	SHANIVARSANTE-YESSLUR	YESSLUR_66 HETTUR_66	19:50	20:09	00:18	TRIPPED ON FAULT
1770	12-Jan-24	MYSORE	66	THANDYA-NANJUNGUD	NANJANGUD_66	09:35	11:05	01:30	LINE CLEAR AVAILED
1771	12-Jan-24	TUMKUR	66	CHITRADURGA 220KV-H.D.PURA_66	HDPURA_66, CHITRAHALLI_66	09:55	18:48	08:53	MAIN SUPPLY FAILURE
1772	12-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1773	12-Jan-24	TUMKUR	66	SHYAGALE-KEREBILCHI_66	SHYAGALE_66	15:35	15:40	00:05	TRIPPED ON FAULT
1774	12-Jan-24	TUMKUR	66	TAVAREKERE_66-JAVAGONDANAHALLI_66	TAVAREKERE_66	04:47	05:05	00:18	TRIPPED ON FAULT
1775	12-Jan-24	TUMKUR	66	THOVINAKERE66- TMTP	THOVINAKERE_66	11:20	12:00	00:40	LINE CLEAR AVAILED
1776	12-Jan-24	TUMKUR	66	TR-1	HOLALKERE_66	12:00	13:50	01:50	LINE CLEAR AVAILED
1777	12-Jan-24	TUMKUR	66	TR-1&TR-2	THOVINAKERE_66	11:20	12:00	00:40	LINE CLEAR AVAILED
1778	12-Jan-24	TUMKUR	66	TR-2	HOLALKERE_66	14:50	16:15	01:25	LINE CLEAR AVAILED
1779	12-Jan-24	TUMKUR	66	TR-2	THOVINAKERE_66	10:00	12:10	02:10	LINE CLEAR AVAILED
1780	12-Jan-24	TUMKUR	66	TR-3	HOLALKERE_66	13:15	15:10	01:55	LINE CLEAR AVAILED
1781	12-Jan-24	TUMKUR	110	KB CROSS 220KV-HANDANKERE110	HANDANKERE_110MHULIYAR_110	12:24	13:10	00:46	LINE CLEAR AVAILED
1782	12-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1783	12-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1784	12-Jan-24	TUMKUR	220	TR-3	DAVANGERE_SRS_220	14:35	14:56	00:21	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1785	12-Jan-24	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	13:40	20:08	06:28	TRIPPED ON FAULT
1786	13-Jan-24	BAGALKOT	110	110/11KV, HV1 (10MVA)	STATION NOT AFFECTED KUD DHARWAD_110	11:52	16:47	04:55	LINE CLEAR AVAILED
1787	13-Jan-24	BAGALKOT	110	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED KUD DHARWAD_110	16:49	17:45	00:56	LINE CLEAR AVAILED
1788	13-Jan-24	BAGALKOT	110	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED MALGHAN(B)_110	10:55	11:00	00:05	TRIPPED ON FAULT
1789	13-Jan-24	BAGALKOT	110	110/11KV,HV1 (10MVA)	NAVALGUND_110	15:02	17:05	02:03	TRIPPED ON FAULT
1790	13-Jan-24	BAGALKOT	110	220/110KV, LV2 (100MVA)	STATION NOT AFFECTED MAHALINGAPUR_220	07:00	07:09	00:09	LINE CLEAR AVAILED
1791	13-Jan-24	BAGALKOT	110	BYADAGI-RAILWAY LINE	STATION NOT AFFECTED BYADAGI_110	11:31	14:42	03:11	LINE CLEAR AVAILED
1792	13-Jan-24	BAGALKOT	110	GHATAPRABHA-GOKAK	STATION NOT AFFECTED GHATAPRABHA_220	00:15	00:23	00:08	TRIPPED ON FAULT
1793	13-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
1794	13-Jan-24	BAGALKOT	110	INDI220-ATHARGA	STATION NOT AFFECTED INDI_220	13:15	13:30	00:15	TRIPPED ON FAULT
1795	13-Jan-24	BAGALKOT	110	ITNAL-RAUBK2 (MUGALKHOD220-1)	STATION NOT AFFECTED ITNAL_110	12:50	13:00	00:10	TRIPPED ON FAULT
1796	13-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1797	13-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1798	13-Jan-24	BAGALKOT	110	MAHALINGAPUR220-BANAHATTI	BANAHATTI_110 STATION NOT AFFECTED MAHALINGAPUR_220	07:00	07:39	00:39	LINE CLEAR AVAILED
1799	13-Jan-24	BAGALKOT	110	MAHALINGAPUR220-GSML-1	GSML_110 STATION NOT AFFECTED MAHALINGAPUR_220	06:55	07:44	00:49	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1800	13-Jan-24	BAGALKOT	110	MAHALINGAPUR220-GSML-2	GSML_110 STATION NOT AFFECTED MAHALINGAPUR_220	07:00	07:48	00:48	LINE CLEAR AVOIDED
1801	13-Jan-24	BAGALKOT	110	MAHALINGAPUR220-RANNABELAGALI	RANNABELAGALI_110 STATION NOT AFFECTED MAHALINGAPUR_220	07:00	07:48	00:48	LINE CLEAR AVOIDED
1802	13-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
1803	13-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1804	13-Jan-24	BAGALKOT	110	MUKARTHIHAL-SPV	MUKARTHIHAL_110	19:27 (12.01.2024)	5:28 (13.01.2024)	10:01:00	LINE CLEAR AVOIDED
1805	13-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
1806	13-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVOIDED
1807	13-Jan-24	BAGALKOT	110	UTTUR-F2 YWD CB (YADWAD)	STATION NOT AFFECTED UTTUR_110	06:28	06:36	00:08	TRIPPED ON FAULT
1808	13-Jan-24	BAGALKOT	220	220/110KV, HV2 (100MVA)	STATION NOT AFFECTED MAHALINGAPUR_220	06:55	07:09	00:14	TRIPPED ON FAULT
1809	13-Jan-24	BAGALKOT	220	BELGAUM-KANABARGI1	STATION NOT AFFECTED BELGAUM_220	09:24	17:28	08:04	LINE CLEAR AVOIDED
1810	13-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
1811	13-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVOIDED
1812	13-Jan-24	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	13:17	18:27	05:10	TRIPPED ON FAULT
1813	13-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1814	13-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED
1815	13-Jan-24	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	13:18	18:27	05:09	TRIPPED ON FAULT
1816	13-Jan-24	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	14:28 (13.01.2024)			LINE CLEAR AVOIDED
1817	13-Jan-24	BAGALKOT	220	SIRSI220-HUBLI2	STATION NOT AFFECTED SIRSI_220	14:28 (13.01.2024)			LINE CLEAR AVOIDED
1818	13-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	15:42 (12.01.2024)	14:28 (13.01.2024)	22:46:00	LINE CLEAR AVOIDED
1819	13-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	15:34 (12.01.2024)	14:28 (13.01.2024)		LINE CLEAR AVOIDED
1820	13-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
1821	13-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1822	13-Jan-24	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	11:13	11:15	00:02	TRIPPED ON FAULT
1823	13-Jan-24	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	K RAGHUTTAHALLI, BOMMEPALLI CROSS, YENNIGADALE	05:05	05:15	00:10	TRIPPED ON FAULT
1824	13-Jan-24	BANGALORE	66	DABUSPETE 220 - SK STEEL(EHT)	SK STEEL(EHT), KOLALA, URDIGERE	08:34	08:50	00:16	TRIPPED ON FAULT
1825	13-Jan-24	BANGALORE	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE(EHT)	11:56	13:00	01:04	LINE CLEAR AVOIDED
1826	13-Jan-24	BANGALORE	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	10:41	10:58	00:17	TRIPPED ON FAULT
1827	13-Jan-24	BANGALORE	66	HV1	SOMANATHPURA	13:20	13:25	00:05	LINE CLEAR AVOIDED
1828	13-Jan-24	BANGALORE	66	HV1	THONDEBHAVI	12:00	12:15	00:15	TRIPPED ON FAULT
1829	13-Jan-24	BANGALORE	66	HV1	KGF	06:55	08:35	01:40	LINE CLEAR AVOIDED
1830	13-Jan-24	BANGALORE	66	HV2	BANASAWADI	13:17	13:22	00:05	LINE CLEAR AVOIDED
1831	13-Jan-24	BANGALORE	66	HV2	KUMBARANAHALLI	16:30	16:40	00:10	TRIPPED ON FAULT
1832	13-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1833	13-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPETE 2	BANGARPETE	16:50	16:55	00:05	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1834	13-Jan-24	BANGALORE	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR, SM MANGALA	16:53	16:56	00:03	LOAD CURTAILMENT
1835	13-Jan-24	BANGALORE	66	KOLAR 220 - VOKKALERI	VOKKALERI, KC VALLEY PUMP HOUSE	16:53	16:56	00:03	LOAD CURTAILMENT
1836	13-Jan-24	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	22:24	23:59	01:35	TRIPPED ON FAULT
1837	13-Jan-24	GULBARGA	66	HV1	CHORNOOR_66	09:45	09:55	00:10	TRIPPED ON FAULT
1838	13-Jan-24	GULBARGA	66	HV1	HARAVI_66	10:50	12:10	01:20	LINE CLEAR AVOIDED
1839	13-Jan-24	GULBARGA	66	HV3	HALAVAGALU_66	18:20	18:50	00:30	LINE CLEAR AVOIDED
1840	13-Jan-24	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66	01:13	01:25	00:12	TRIPPED ON FAULT
1841	13-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66, TBPCL	06:22	06:29	00:07	TRIPPED ON FAULT
1842	13-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66, TBPCL	01:01	06:29	05:28	TRIPPED ON FAULT
1843	13-Jan-24	GULBARGA	110	HV1	KALBURGI_NORTH_110	11:01	13:11	02:10	LINE CLEAR AVOIDED
1844	13-Jan-24	GULBARGA	110	SULEKAL-AMPYRE_SOLAR	SULEKAL_220	01:59	02:38	00:39	TRIPPED ON FAULT
1845	13-Jan-24	GULBARGA	220	HALWARTHY-DONI1	HALWARTHY_220	06:03	06:26	00:23	TRIPPED ON FAULT
1846	13-Jan-24	GULBARGA	220	HV1	KAPNOOR_220	10:40	14:11	03:31	LINE CLEAR AVOIDED
1847	13-Jan-24	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	06:20	10:50	04:30	TRIPPED ON FAULT
1848	13-Jan-24	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	09:07	13:20	04:13	TRIPPED ON FAULT
1849	13-Jan-24	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	09:07	10:03	00:56	MAIN SUPPLY FAILURE
1850	13-Jan-24	HASSAN	110	HULICA-KVR	HULICAL_110	09:10	10:00	00:50	MAIN SUPPLY FAILURE
1851	13-Jan-24	HASSAN	110	HULICA-SMG	HULICAL_110	13:00	13:35	00:35	LINE CLEAR AVOIDED
1852	13-Jan-24	HASSAN	110	HV3	PUTTUR_220	13:02	13:04	00:02	LINE CLEAR AVOIDED
1853	13-Jan-24	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:45	13:57	00:12	LINE CLEAR AVOIDED
1854	13-Jan-24	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	18:06	18:18	00:12	LINE CLEAR AVOIDED
1855	13-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVOIDED
1856	13-Jan-24	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	13:45	13:51	00:06	LINE CLEAR AVOIDED
1857	13-Jan-24	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	18:21	18:29	00:08	LINE CLEAR AVOIDED
1858	13-Jan-24	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	13:45	13:50	00:05	LINE CLEAR AVOIDED
1859	13-Jan-24	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	18:21	18:29	00:08	LINE CLEAR AVOIDED
1860	13-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVOIDED
1861	13-Jan-24	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	13:45	13:48	00:03	LINE CLEAR AVOIDED
1862	13-Jan-24	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	18:21	18:29	00:08	LINE CLEAR AVOIDED
1863	13-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:02	18:28	08:26	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1864	13-Jan-24	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	18:24(13.01.2024)			TRIPPED ON FAULT
1865	13-Jan-24	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	13:45	13:48	00:03	LINE CLEAR AVAILED
1866	13-Jan-24	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	18:21	18:29	00:08	LINE CLEAR AVAILED
1867	13-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavaty	10:02	18:28	08:26	LINE CLEAR AVAILED
1868	13-Jan-24	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	18:24(13.01.2024)			TRIPPED ON FAULT
1869	13-Jan-24	MYSORE	66	AKKIHEBBAL-KAVERI HYDRO	NO STATIONS EFFECTED	10:04	10:32	00:27	TRIPPED ON FAULT
1870	13-Jan-24	MYSORE	66	GUNDALPET-HANGLA	HANGALA_66 BHARAGI_66	05:49	05:54	00:05	TRIPPED ON FAULT
1871	13-Jan-24	MYSORE	66	HEBBANI-SFC9	NO STATIONS EFFECTED	08:19	08:32	00:13	TRIPPED ON FAULT
1872	13-Jan-24	MYSORE	66	K R PETE -AKKIHEBBAL1	NO STATIONS EFFECTED	10:04	10:20	00:15	TRIPPED ON FAULT
1873	13-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)			TRIPPED ON FAULT
1874	13-Jan-24	MYSORE	66	KUSHALNAGAR-SOMWARPETE	SOMWARPETE_33	12:18	12:27	00:09	LINE CLEAR AVAILED
1875	13-Jan-24	MYSORE	66	MADHUVANAHALLI-DODDINDUVADI	DODDINDUVADI_66 KOTHANUR_66	18:40	19:00	00:20	TRIPPED ON FAULT
1876	13-Jan-24	MYSORE	66	MADHUVANAHALLI-KUNTUR	NO STATIONS EFFECTED	18:40	19:00	00:20	TRIPPED ON FAULT
1877	13-Jan-24	MYSORE	66	SANTHESARGUR-HAMPAPURA	ANATRSANTE_66 HDKOTE_66 YARAHALLI HANDPOST_66	22:18	22:28	00:10	TRIPPED ON FAULT
1878	13-Jan-24	MYSORE	66	SFC-10MW SOLAR	NO STATIONS EFFECTED	08:20	08:30	00:10	TRIPPED ON FAULT
1879	13-Jan-24	MYSORE	66	SFC-5MW SOLAR	NO STATIONS EFFECTED	08:20	08:30	00:10	TRIPPED ON FAULT
1880	13-Jan-24	MYSORE	66	SFC-HEBBANI 9	NO STATIONS EFFECTED	08:20	08:35	00:15	TRIPPED ON FAULT
1881	13-Jan-24	TUMKUR	66	SIRA 220-SIRA 3	SIRA_66	11:06	12:20	01:14	LINE CLEAR AVAILED
1882	13-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	17:10	17:35	00:25	TRIPPED ON FAULT
1883	13-Jan-24	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	09:12	09:29	00:17	TRIPPED ON FAULT
1884	13-Jan-24	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	09:31	09:36	00:05	TRIPPED ON FAULT
1885	13-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66,	19:32	19:38	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1886	13-Jan-24	TUMKUR	66	DAVANGERE SRS-ANGODU 66	ANGODU_66	16:43	16:53	00:10	TRIPPED ON FAULT
1887	13-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:20	12:29	00:09	TRIPPED ON FAULT
1888	13-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	08:36	08:46	00:10	LINE CLEAR AVAILED
1889	13-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:48(13.01.2024)			TRIPPED ON FAULT
1890	13-Jan-24	TUMKUR	66	HOSADURGA220-HOSADURGA 66	HOSADURGA_66	04:10	04:20	00:10	TRIPPED ON FAULT
1891	13-Jan-24	TUMKUR	66	PAVAGADA 220kV-SHYLAPURA	SHYLAPURA_66	09:10	09:20	00:10	TRIPPED ON FAULT
1892	13-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
1893	13-Jan-24	TUMKUR	66	SHYAGALE-KEREBILCHI_66	SHYAGALE_66 KEREBILCHI_66	15:25	15:30	00:05	TRIPPED ON FAULT
1894	13-Jan-24	TUMKUR	66	TMTP_66-BRAHMASANDRA_66	TMTP_66, ANKSANDRA,SUNVIK PLANT.	00:51	01:09	00:18	TRIPPED ON FAULT
1895	13-Jan-24	TUMKUR	66	TR-1	MADHUGIRI_220	19:08	19:17	00:09	TRIPPED ON FAULT
1896	13-Jan-24	TUMKUR	66	TR-1	B.H.GIRI_66	03:05	03:10	00:05	TRIPPED ON FAULT
1897	13-Jan-24	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	7:05 (13.01.2024)	14:30 (14.01.2024)	1 DAY 7 HR 25 MINUTES	LINE CLEAR AVAILED
1898	13-Jan-24	TUMKUR	110	KB CROSS 220kV-MAYASANDRA	MAYASANDRA_110,KADEH ALLI_110	09:26	09:29	00:03	LINE CLEAR AVAILED
1899	13-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
1900	13-Jan-24	TUMKUR	220	GUTUR_400-RANEENNUR	GUTUR_400	16:14	16:40	00:26	TRIPPED ON FAULT
1901	13-Jan-24	TUMKUR	220	HONNALLI 220k-BENKIKERE-1&2	HONNALLI_220	16:18	16:40	00:22	MAIN SUPPLY FAILURE
1902	13-Jan-24	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS1 &2	HONNALLI_220	16:15	16:40	00:25	MAIN SUPPLY FAILURE
1903	13-Jan-24	TUMKUR	220	HOSADURGA220-BENKIKERE 220KV 1	HOSADURGA_220	16:15	16:50	00:35	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1904	13-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
1905	13-Jan-24	TUMKUR	220	TR-3	DAVANGERE_SRS_220	12:10	13:30	01:20	LINE CLEAR AVAILED
1906	13-Jan-24	TUMKUR	400	ICT-1	GUTTUR_400	16:04	16:36	00:32	TRIPPED ON FAULT
1907	14-Jan-24	BAGALKOT	110	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED MALGHAN(B)_110	13:49	13:55	00:06	TRIPPED ON FAULT
1908	14-Jan-24	BAGALKOT	110	110/11KV, HV2 (10MVA)	STATION NOT AFFECTED MALGHAN(B)_110	09:30	09:35	00:05	TRIPPED ON FAULT
1909	14-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	MUNAVALLI_110	10:38	10:55	00:17	TRIPPED ON FAULT
1910	14-Jan-24	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED GHATAPRABHA_220	19:43	20:29	00:46	TRIPPED ON FAULT
1911	14-Jan-24	BAGALKOT	110	AHERI220- LN5(DEVARHIPPARAGI)	STATION NOT AFFECTED AHERI_220	13:55	22:25	08:30	LINE CLEAR AVAILED
1912	14-Jan-24	BAGALKOT	110	ATHANI-GHATANATTI	ATHANI_220	05:23	05:43	00:20	TRIPPED ON FAULT
1913	14-Jan-24	BAGALKOT	110	BELGAUM220- BELGAUM(NEHRU NAGAR)	STATION NOT AFFECTED BELGAUM_220	09:30	17:39	08:09	LINE CLEAR AVAILED
1914	14-Jan-24	BAGALKOT	110	BELGAUM-MACHE	STATION NOT AFFECTED BELGAUM_110	09:30	17:41	08:11	LINE CLEAR AVAILED
1915	14-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
1916	14-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
1917	14-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
1918	14-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
1919	14-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
1920	14-Jan-24	BAGALKOT	110	MUGALKHOD220- MAHALINGAPUR	STATION NOT AFFECTED MUGALKHOD_220	06:44	08:01	01:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1921	14-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
1922	14-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVOIDED
1923	14-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED GHATAPRABHA_220	19:43	20:26	00:43	TRIPPED ON FAULT
1924	14-Jan-24	BAGALKOT	220	BAGEWADI- RBRK	STATION NOT AFFECTED BAGEWADI_220	12:02	12:34	00:32	TRIPPED ON FAULT
1925	14-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
1926	14-Jan-24	BAGALKOT	220	CHIKKODI- MUGALKHOD1	STATION NOT AFFECTED CHIKKODI_220	18:05	18:30	00:25	TRIPPED ON FAULT
1927	14-Jan-24	BAGALKOT	220	CHIKKODI- MUGALKHOD2	STATION NOT AFFECTED CHIKKODI_220	18:05	18:30	00:25	TRIPPED ON FAULT
1928	14-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVOIDED
1929	14-Jan-24	BAGALKOT	220	MUGALKHOD- GHATAPRABHA1	MUGALKHOD_220	21:32 (14.01.2024)			LINE CLEAR AVOIDED
1930	14-Jan-24	BAGALKOT	220	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	18:05 (14.01.2024)			TRIPPED ON FAULT
1931	14-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVOIDED
1932	14-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI1	STATION NOT AFFECTED NARENDRA_220	10:40	17:22	06:42	LINE CLEAR AVOIDED
1933	14-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED
1934	14-Jan-24	BAGALKOT	220	SIRSI- SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	19:36	21:17	01:41	LINE CLEAR AVOIDED
1935	14-Jan-24	BAGALKOT	220	SIRSI- SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	19:36	21:17	01:41	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1936	14-Jan-24	BAGALKOT	220	SIRSI220-HUBLI1	STATION NOT AFFECTED SIRSI_220	14:28 (13.01.2024)	19:36 (14.01.2024)	29:08:00	LINE CLEAR AVOIDED
1937	14-Jan-24	BAGALKOT	220	SIRSI220-HUBLI2	SIRSI_220	14:28 (13.01.2024)	19:36 (14.01.2024)	29:08:00	LINE CLEAR AVOIDED
1938	14-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
1939	14-Jan-24	BANGALORE	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	10:00	10:10	00:10	LINE CLEAR AVOIDED
1940	14-Jan-24	BANGALORE	66	APPAREL PARK - NRS DB PURA 220	APPAREL PARK	20:05	20:10	00:05	LINE CLEAR AVOIDED
1941	14-Jan-24	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	15:52	15:57	00:05	LINE CLEAR AVOIDED
1942	14-Jan-24	BANGALORE	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	09:45	09:57	00:12	LINE CLEAR AVOIDED
1943	14-Jan-24	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE(HV2)	17:00	17:10	00:10	MAIN SUPPLY FAILURE
1944	14-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1945	14-Jan-24	BANGALORE	66	GOKULA - BEL(EHT)	BEL(EHT)	11:34	12:07	00:33	LINE CLEAR AVOIDED
1946	14-Jan-24	BANGALORE	66	HV1	DIVYASHREE TECH PARK	10:35	10:36	00:01	LINE CLEAR AVOIDED
1947	14-Jan-24	BANGALORE	66	HV1	KHODAYS 220	09:17	09:21	00:04	LINE CLEAR AVOIDED
1948	14-Jan-24	BANGALORE	66	HV1	SULIBELE	10:31	10:36	00:05	TRIPPED ON FAULT
1949	14-Jan-24	BANGALORE	66	HV1	KAMASAMUDRA	11:40	13:40	02:00	LINE CLEAR AVOIDED
1950	14-Jan-24	BANGALORE	66	HV1	RANGANADODDI	10:30	10:50	00:20	LINE CLEAR AVOIDED
1951	14-Jan-24	BANGALORE	66	HV1	BV HALLI	11:41	11:54	00:13	TRIPPED ON FAULT
1952	14-Jan-24	BANGALORE	66	HV1	JIGANI 220	11:31	12:05	00:34	LINE CLEAR AVOIDED
1953	14-Jan-24	BANGALORE	66	HV1	JIGANI 220	17:20	18:00	00:40	LINE CLEAR AVOIDED
1954	14-Jan-24	BANGALORE	66	HV2	KHODAYS 220	09:17	09:21	00:04	LINE CLEAR AVOIDED
1955	14-Jan-24	BANGALORE	66	HV2	RANGANADODDI	16:05	16:25	00:20	LINE CLEAR AVOIDED
1956	14-Jan-24	BANGALORE	66	HV2	ATTIBELE	17:50	17:55	00:05	LINE CLEAR AVOIDED
1957	14-Jan-24	BANGALORE	66	HV2	JIGANI 220	11:31	12:05	00:34	LINE CLEAR AVOIDED
1958	14-Jan-24	BANGALORE	66	HV2	JIGANI 220	17:20	18:00	00:40	LINE CLEAR AVOIDED
1959	14-Jan-24	BANGALORE	66	HV2	SARJAPURA 220	17:00	17:22	00:22	MAIN SUPPLY FAILURE
1960	14-Jan-24	BANGALORE	66	HV3	EPIP 220	14:52	15:00	00:08	TRIPPED ON FAULT
1961	14-Jan-24	BANGALORE	66	HV3	BIDADI 220	11:18	11:22	00:04	LINE CLEAR AVOIDED
1962	14-Jan-24	BANGALORE	66	ISRO LAYOUT - SARAKKI	ISRO LAYOUT	16:22	16:28	00:06	LINE CLEAR AVOIDED
1963	14-Jan-24	BANGALORE	66	ISRO LAYOUT - SUBRAMANYAPURA 220	ISRO LAYOUT	15:02	15:25	00:23	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1964	14-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1965	14-Jan-24	BANGALORE	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	11:31	12:05	00:34	LINE CLEAR AVOIDED
1966	14-Jan-24	BANGALORE	66	JIGANI 220 - KUMBARANAHALLI	KUMBARANAHALLI, BAGANDODDI	17:20	18:00	00:40	LINE CLEAR AVOIDED
1967	14-Jan-24	BANGALORE	66	JIGANI 66 - JIGANI 220	JIGANI 66, JIGANI LINK ROAD	11:25	11:30	00:05	LINE CLEAR AVOIDED
1968	14-Jan-24	BANGALORE	66	JIGANI 66 - YARANDANAHALLI 220	JIGANI 66	18:03	18:08	00:05	LINE CLEAR AVOIDED
1969	14-Jan-24	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, ANNABEL(DLF), SAUDELA	15:02	15:24	00:22	MAIN SUPPLY FAILURE
1970	14-Jan-24	BANGALORE	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	10:00	19:51	09:51	LINE CLEAR AVOIDED
1971	14-Jan-24	BANGALORE	66	KIADB HARDWARE PARK 220 - VIDYANAGARA	NO STATION AFFECTED	17:49	18:50	01:01	TRIPPED ON FAULT
1972	14-Jan-24	BANGALORE	66	NIMHANS 220 - JAYADEVA	SARAKKI 1 & 2	08:14	08:30	00:16	TRIPPED ON FAULT
1973	14-Jan-24	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
1974	14-Jan-24	BANGALORE	66	PRESTIGE FALCON CITY - KHODAYS 220	PRESTIGE FALCON CITY	15:03	15:25	00:22	MAIN SUPPLY FAILURE
1975	14-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	15:03	15:38	00:35	MAIN SUPPLY FAILURE
1976	14-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	15:03	15:25	00:22	MAIN SUPPLY FAILURE
1977	14-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - SUBRAMANYAPURA 66	SUBRAMANYAPURA 66	15:03	15:12	00:09	MAIN SUPPLY FAILURE
1978	14-Jan-24	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	16:01	16:04	00:03	LINE CLEAR AVOIDED
1979	14-Jan-24	BANGALORE	220	DB PURA 220 - KIADB DB PURA 220	KIADB DB PURA 220	10:01	19:43	09:42	LINE CLEAR AVOIDED
1980	14-Jan-24	BANGALORE	220	HV1	JIGANI 220	11:31	12:05	00:34	LINE CLEAR AVOIDED
1981	14-Jan-24	BANGALORE	220	HV1	JIGANI 220	17:20	18:00	00:40	LINE CLEAR AVOIDED
1982	14-Jan-24	BANGALORE	220	HV2	SARJAPURA 220	17:00	17:21	00:21	TRIPPED ON FAULT
1983	14-Jan-24	BANGALORE	220	KHODAYS 220 - SUBRAMANYAPURA 220	KHODAYS 220	15:01	15:24	00:23	LINE CLEAR AVOIDED
1984	14-Jan-24	BANGALORE	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 220, KHODAYS 220	15:06	15:24	00:18	TRIPPED ON FAULT
1985	14-Jan-24	GULBARGA	66	HV2	HARAPPANAHALLI_66	10:30	10:35	00:05	TRIPPED ON FAULT
1986	14-Jan-24	GULBARGA	66	HV3	HALAVAGALU_66	11:15	11:25	00:10	LINE CLEAR AVOIDED
1987	14-Jan-24	GULBARGA	66	HV3	HALAVAGALU_66	12:15	12:20	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
1988	14-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOKKE_66, TBPCL	01:13	01:25	00:12	TRIPPED ON FAULT
1989	14-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	10:55	11:05	00:10	TRIPPED ON FAULT
1990	14-Jan-24	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	06:43	07:25	00:42	TRIPPED ON FAULT
1991	14-Jan-24	GULBARGA	110	HATTIGUDUR-RAICHUR-2	HATTIGUDUR_110	13:34	13:54	00:20	TRIPPED ON FAULT
1992	14-Jan-24	GULBARGA	110	KUSHTAGI-HANUMSAGAR	HANUMSAGAR_110, HIREGONNAAGAR_66,HANUMNAL_66	05:48	06:07	00:19	TRIPPED ON FAULT
1993	14-Jan-24	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	19:28	19:41	00:13	TRIPPED ON FAULT
1994	14-Jan-24	HASSAN	66	HV1	CHIKMANGLUR_66	06:12	09:18	03:06	TRIPPED ON FAULT
1995	14-Jan-24	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	12:20	13:19	00:59	TRIPPED ON FAULT
1996	14-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
1997	14-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
1998	14-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	15:11	15:46	00:35	TRIPPED ON FAULT
1999	14-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	19:20(14.1.2024)			TRIPPED ON FAULT
2000	14-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	15:09	17:23	02:14	LINE CLEAR AVAILED
2001	14-Jan-24	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	18:24(13.01.2024)	16:28(14.01.2024)	22:04HRS	LINE CLEAR AVAILED
2002	14-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA1	gen_sharavaty	15:11	15:46	00:35	TRIPPED ON FAULT
2003	14-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavathy	19:20(14.1.2024)			TRIPPED ON FAULT
2004	14-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA4	gen_sharavaty	15:09	17:23	02:14	LINE CLEAR AVAILED
2005	14-Jan-24	HASSAN	220	VARAHI-SHIMOGA1	gen_varahi	18:24(13.01.2024)	16:29(14.01.2024)	22:05HRS	LINE CLEAR AVAILED
2006	14-Jan-24	MYSORE	66	CR NAGARA-HONNALLI	ARKALVADI_66 ATTIGULIPURA_66 HONNALLY_MYS_66	04:40	04:51	00:11	TRIPPED ON FAULT
2007	14-Jan-24	MYSORE	66	D R PETE-KUNTHUR	SANTHEMARAHALLI_66	06:30	06:35	00:05	TRIPPED ON FAULT
2008	14-Jan-24	MYSORE	66	GAVADGERE-HUNSUR	ELAVALA_66 HUNSUR_66	07:20	07:34	00:14	TRIPPED ON FAULT
2009	14-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:49			LINE CLEAR AVAILED
2010	14-Jan-24	MYSORE	66	HUNSUR 220-HUNSUR 1	BANNIKUPPE_66 ELAVALA_66 HUNSUR_66	07:20	07:30	00:10	TRIPPED ON FAULT
2011	14-Jan-24	MYSORE	66	HUNSUR 220-HUNSUR 2	BANNIKUPPE_66 ELAVALA_66 HUNSUR_66	07:20	07:30	00:10	TRIPPED ON FAULT
2012	14-Jan-24	MYSORE	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	11:02	14:43	03:40	LINE CLEAR AVAILED
2013	14-Jan-24	MYSORE	66	HV1	MALAVALLI_66	14:09	14:23	00:14	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2014	14-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)			TRIPPED ON FAULT
2015	14-Jan-24	MYSORE	66	KUNTHUR-BANNARI	NO STATIONS EFFECTED	06:30	06:35	00:05	TRIPPED ON FAULT
2016	14-Jan-24	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	04:27	04:32	00:05	TRIPPED ON FAULT
2017	14-Jan-24	MYSORE	66	MUGUR-THAYURU	GARGESHWARI_66 THAYURU_66 TNARASIPURA_66	23:21	23:26	00:05	TRIPPED ON FAULT
2018	14-Jan-24	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	NO STATIONS EFFECTED	00:07	00:17	00:10	TRIPPED ON FAULT
2019	14-Jan-24	MYSORE	66	VAJAMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	13:40	13:57	00:17	TRIPPED ON FAULT
2020	14-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	7:05 (13.01.2024)	14:30 (14.01.2024)	1 DAY 7 HR 25 MINUTES	LINE CLEAR AVAILED
2021	14-Jan-24	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66,	02:48	03:14	00:26	TRIPPED ON FAULT
2022	14-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:48(13.01.2024)	12:05(14.01.2024)	12:17	TRIPPED ON FAULT
2023	14-Jan-24	TUMKUR	66	MADHUGIRI 220kv-MEDIGESHI	MEDIGESHI_66	01:55	02:11	00:16	TRIPPED ON FAULT
2024	14-Jan-24	TUMKUR	66	MADHUGIRI 220kv-MEDIGESHI	MEDIGESHI_66	03:57	07:31	03:34	TRIPPED ON FAULT
2025	14-Jan-24	TUMKUR	66	OBAJJIHALLI_66-TELAGI_66	OBAJJIHALLI_66	10:50	11:07	00:17	TRIPPED ON FAULT
2026	14-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2027	14-Jan-24	TUMKUR	66	THALLAK 220kv- P R PURA	PR PURA_66	13:39	14:39	01:00	TRIPPED ON FAULT
2028	14-Jan-24	TUMKUR	66	THALLAK 220kv- P R PURA	PR PURA_66	03:54	04:01	00:07	TRIPPED ON FAULT
2029	14-Jan-24	TUMKUR	66	TR-2	HARAPANAHALLI_66	10:30	10:35	00:05	TRIPPED ON FAULT
2030	14-Jan-24	TUMKUR	66	TR-2	PAVAGADA_66	10:50	11:45	00:55	LINE CLEAR AVAILED
2031	14-Jan-24	TUMKUR	110	KB CROSS 220kv-TURUVEKERE_110	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	05:45	05:54	00:09	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2032	14-Jan-24	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	07:33	08:00	00:27	TRIPPED ON FAULT
2033	14-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
2034	14-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2035	14-Jan-24	TUMKUR	400	ICT-2	GUTTUR_400	10:46	15:01	04:15	TRIPPED ON FAULT
2036	15-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	GUTTAL_110	16:35	17:09	00:34	LINE CLEAR AVAILED
2037	15-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANAGAL_110	10:38	10:50	00:12	TRIPPED ON FAULT
2038	15-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	HANAGAL_110	10:38	10:50	00:12	TRIPPED ON FAULT
2039	15-Jan-24	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:20	13:34	03:14	LINE CLEAR AVAILED
2040	15-Jan-24	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_220	08:41	08:57	00:16	TRIPPED ON FAULT
2041	15-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
2042	15-Jan-24	BAGALKOT	110	HAVERI-SAVANUR	STATION NOT AFFECTED HAVERI_220	11:30 (05.01.2024)	0:36 (15.01.2024)	229:06:00	LINE CLEAR AVAILED
2043	15-Jan-24	BAGALKOT	110	HUNAGUND-JINDAL	HUNAGUND_110	05:55	06:02	00:07	TRIPPED ON FAULT
2044	15-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
2045	15-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2046	15-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2047	15-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
2048	15-Jan-24	BAGALKOT	110	MUGALKHOD220- NAGNUR	STATION NOT AFFECTED MUGALKHOD_220	03:27	03:39	00:12	TRIPPED ON FAULT
2049	15-Jan-24	BAGALKOT	110	MUGALKHOD220- NAGNUR	STATION NOT AFFECTED MUGALKHOD_220	15:14	15:26	00:12	TRIPPED ON FAULT
2050	15-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2051	15-Jan-24	BAGALKOT	110	SANKS110-CHIKKODI	STATION NOT AFFECTED SANKESHWAR_110	08:22	08:38	00:16	TRIPPED ON FAULT
2052	15-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
2053	15-Jan-24	BAGALKOT	110	UDIKERI-NKR Cbreaker (NOKAR SLR)	STATION NOT AFFECTED UDIKERI_110	14:36	23:04	08:28	LINE CLEAR AVAILED
2054	15-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED NARENDRA_220	10:51	14:17	03:26	LINE CLEAR AVAILED
2055	15-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2056	15-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)			LINE CLEAR AVAILED
2057	15-Jan-24	BAGALKOT	220	MUGALKHOD- GHATAPRABHA1	MUGALKHOD_220	21:32 (14.01.2024)	00:40 (15.01.2024)	3:08:00	LINE CLEAR AVAILED
2058	15-Jan-24	BAGALKOT	220	MUGALKHOD- GHATAPRABHA2	MUGALKHOD_220	18:05 (14.01.2024)	00:40 (15.01.2024)	6:35:00	TRIPPED ON FAULT
2059	15-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
2060	15-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
2061	15-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2062	15-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2063	15-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2064	15-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2065	15-Jan-24	BANGALORE	66	C STATION - HEBBALA 220	C STATION	06:03	06:07	00:04	LINE CLEAR AVAILED
2066	15-Jan-24	BANGALORE	66	HONNIGANAHALLI - HALAGURU	HALAGURU	06:50	06:55	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2067	15-Jan-24	BANGALORE	66	HV1	DIVYASHREE TECH PARK	11:00	11:02	00:02	LINE CLEAR AVAILED
2068	15-Jan-24	BANGALORE	66	HV1	SOUTH CITY	06:46	06:54	00:08	TRIPPED ON FAULT
2069	15-Jan-24	BANGALORE	66	HV1	NANDAGUDI	14:20	14:33	00:13	TRIPPED ON FAULT
2070	15-Jan-24	BANGALORE	66	HV1	M GOLLAHALLI	14:30	14:50	00:20	TRIPPED ON FAULT
2071	15-Jan-24	BANGALORE	66	HV1	YARANDANAHALLI 220	14:30	14:45	00:15	TRIPPED ON FAULT
2072	15-Jan-24	BANGALORE	66	HV1	YARANDANAHALLI 220	16:18	16:22	00:04	TRIPPED ON FAULT
2073	15-Jan-24	BANGALORE	66	HV2	TUBAGERE	15:35	16:07	00:32	LINE CLEAR AVAILED
2074	15-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2075	15-Jan-24	BANGALORE	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	09:12	09:21	00:09	TRIPPED ON FAULT
2076	15-Jan-24	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2077	15-Jan-24	BANGALORE	66	YELAHANKA 220 - KANASAWADI	KANASAWADI	07:44	07:59	00:15	TRIPPED ON FAULT
2078	15-Jan-24	BANGALORE	400	NELAMANGALA 400 - TALAGUPPA 400	NO STATION AFFECTED	14:34	20:02	05:28	TRIPPED ON FAULT
2079	15-Jan-24	GULBARGA	66	HALAVAGALU-HARVI	HARVI_66, HALAVAGALU_110	06:28	06:41	00:13	MAIN SUPPLY FAILURE
2080	15-Jan-24	GULBARGA	66	HV2	HARAPPANAHALLI_66	11:20	11:25	00:05	TRIPPED ON FAULT
2081	15-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66	12:23	13:01	00:38	LINE CLEAR AVAILED
2082	15-Jan-24	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCCHANGIDURGA_66	06:35	06:46	00:11	LINE CLEAR AVAILED
2083	15-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	11:15	11:30	00:15	TRIPPED ON FAULT
2084	15-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	12:10	12:15	00:05	TRIPPED ON FAULT
2085	15-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	12:15	14:05	01:50	TRIPPED ON FAULT
2086	15-Jan-24	GULBARGA	110	HV1	VENKATAGIRI_110	08:05	08:35	00:30	LINE CLEAR AVAILED
2087	15-Jan-24	GULBARGA	110	HV1	HANAWAL_110	16:20	17:05	00:45	LINE CLEAR AVAILED
2088	15-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	03:18	03:28	00:10	TRIPPED ON FAULT
2089	15-Jan-24	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	11:30	11:43	00:13	TRIPPED ON FAULT
2090	15-Jan-24	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	18:04	18:20	00:16	TRIPPED ON FAULT
2091	15-Jan-24	HASSAN	66	HASSN22-HN PURA	HASSAN_220	07:59	17:32	09:33	TRIPPED ON FAULT
2092	15-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2093	15-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2094	15-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	19:20(14.1.2024)	12:08(15.1.2024)	'16:48HRS	TRIPPED ON FAULT
2095	15-Jan-24	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	16:36(15.01.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2096	15-Jan-24	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	16:36(15.01.2024)			TRIPPED ON FAULT
2097	15-Jan-24	HASSAN	400	TALAGU-NELMANGALA	TALAGUPPA_400	14:34	20:02	05:28	TRIPPED ON FAULT
2098	15-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:49 (14/012024)			LINE CLEAR AVAILED
2099	15-Jan-24	MYSORE	66	HV1	ARAKERE_66	13:40	13:52	00:12	TRIPPED ON FAULT
2100	15-Jan-24	MYSORE	66	HV1	HALAGUR_66	06:49	06:54	00:05	LINE CLEAR AVAILED
2101	15-Jan-24	MYSORE	66	HV2	HALAGUR_66	06:49	06:54	00:05	LINE CLEAR AVAILED
2102	15-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)			TRIPPED ON FAULT
2103	15-Jan-24	MYSORE	66	TALAKADU-CHANDALLI	NO STATIONS EFFECTED	18:28	19:34	01:06	TRIPPED ON FAULT
2104	15-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	06:16	06:58	00:42	MAIN SUPPLY FAILURE
2105	15-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 2	CHITRADURGA_220	1816(15.01.2024)			TRIPPED ON FAULT
2106	15-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 3	CHITRADURGA_220	18:16	18:47	00:31	LINE CLEAR AVAILED
2107	15-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA4	CHITRADURGA_220	18:16	18:47	00:31	LINE CLEAR AVAILED
2108	15-Jan-24	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 3	CHITRADURGA_66	18:20	18:47	00:27	MAIN SUPPLY FAILURE
2109	15-Jan-24	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 4	CHITRADURGA_66	18:20	18:47	00:27	MAIN SUPPLY FAILURE
2110	15-Jan-24	TUMKUR	66	CHITRADURGA 66kV-PANDARAHALLI 2	CHITRADURGA_66	18:20	18:56	00:36	MAIN SUPPLY FAILURE
2111	15-Jan-24	TUMKUR	66	CHITRAHALLI-PANDRAHALLI	CHITRAHALLI_66, H D PURA	10:15	19:00	08:45	MAIN SUPPLY FAILURE
2112	15-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	09:00	09:18	00:18	LINE CLEAR AVAILED
2113	15-Jan-24	TUMKUR	66	HONNALLI 220kV-NYAMATHI_66	NYAMATHI_66	14:42	14:52	00:10	TRIPPED ON FAULT
2114	15-Jan-24	TUMKUR	66	MALLADIHALLI_66-BENKIKERE_220	MALLADIHALLI_66	07:35	07:55	00:20	MAIN SUPPLY FAILURE
2115	15-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2116	15-Jan-24	TUMKUR	66	TR-2	HARAPANAHALLI_66	11:20	11:25	00:05	TRIPPED ON FAULT
2117	15-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM			LINE CLEAR AVAILED
2118	15-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2119	16-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	HOSAHONNATTI_110	08:05	20:21	12:16	LINE CLEAR AVAILED
2120	16-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	MALGHAN(B)_110	16:16	18:16	02:00	LINE CLEAR AVAILED
2121	16-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	RAIBAG_110	12:05	16:50	04:45	LINE CLEAR AVAILED
2122	16-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	RAMADURGA_110	10:15	18:00	07:45	LINE CLEAR AVAILED
2123	16-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	BEDI_110	17:24	18:00	00:36	LINE CLEAR AVAILED
2124	16-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	DADDI_110	13:05	14:17	01:12	LINE CLEAR AVAILED
2125	16-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	HOSAHONNATTI_110	08:05	20:21	12:16	LINE CLEAR AVAILED
2126	16-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	BISNAL_110	16:38	16:41	00:03	LINE CLEAR AVAILED
2127	16-Jan-24	BAGALKOT	110	110/33KV,HV3(10MVA)	GOKAK_110	15:54	16:02	00:08	TRIPPED ON FAULT
2128	16-Jan-24	BAGALKOT	110	110/33KV,HV3(10MVA)	HOSAHONNATTI_110	08:05	20:21	12:16	LINE CLEAR AVAILED
2129	16-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	MUNAVALLI_110	16:53	17:20	00:27	TRIPPED ON FAULT
2130	16-Jan-24	BAGALKOT	110	110/33KV,HV4(20MVA)	ZALKI_110	17:45	17:48	00:03	TRIPPED ON FAULT
2131	16-Jan-24	BAGALKOT	110	220/110KV, LV2(LV3)	KUDACHI_220	04:00	04:38	00:38	TRIPPED ON FAULT
2132	16-Jan-24	BAGALKOT	110	AMBEWADI220- SUPA2	AMBEWADI_220	10:22	12:55	02:33	LINE CLEAR AVAILED
2133	16-Jan-24	BAGALKOT	110	ATHANI220- BALIGERI	ATHANI_220	04:03	04:31	00:28	LINE CLEAR AVAILED
2134	16-Jan-24	BAGALKOT	110	ATHANI220- BALIGERI	ATHANI_220	04:49	10:55	06:06	LINE CLEAR AVAILED
2135	16-Jan-24	BAGALKOT	110	DAMBAL-SUZLON1	DAMBAL_110	13:51	15:37	01:46	TRIPPED ON FAULT
2136	16-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
2137	16-Jan-24	BAGALKOT	110	HOSAHONNATTI-GUTTAL	HOSAHONNATTI_110	8:05 (16.01.2024)			TRIPPED ON FAULT
2138	16-Jan-24	BAGALKOT	110	HOSAHONNATTI-RANEBENNUR	HOSAHONNATTI_110	08:05	20:20	12:15	LINE CLEAR AVAILED
2139	16-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
2140	16-Jan-24	BAGALKOT	110	KUDACHI220- ATHANI	KUDACHI_220	04:00	08:25	04:25	TRIPPED ON FAULT
2141	16-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2142	16-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2143	16-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
2144	16-Jan-24	BAGALKOT	110	NARENDRA220-TADASINAKOPPA	NARENDRA_220	11:55	16:48	04:53	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2145	16-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2146	16-Jan-24	BAGALKOT	110	RANEBENNUR220-BYADAGI(GUTTAL)	RANEBENNUR_220	19:06	19:47	00:41	LINE CLEAR AVAILED
2147	16-Jan-24	BAGALKOT	110	RANEBENNUR220- GUTTAL	RANEBENNUR_220	10:30	13:30	03:00	LINE CLEAR AVAILED
2148	16-Jan-24	BAGALKOT	110	RANEBENNUR220-HONNATTI	RANEBENNUR_220	08:30	20:17	11:47	LINE CLEAR AVAILED
2149	16-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVAILED
2150	16-Jan-24	BAGALKOT	220	220/110KV, HV1(HV3)	CHIKKODI_220	10:30	13:20	02:50	LINE CLEAR AVAILED
2151	16-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2152	16-Jan-24	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	14:29 (28.12.2023)	19:03 (16.01.2024)	460:34:00	LINE CLEAR AVAILED
2153	16-Jan-24	BAGALKOT	220	KUDACHI- ATHANI	KUDACHI_220	03:30	04:42	01:12	TRIPPED ON FAULT
2154	16-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVAILED
2155	16-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVAILED
2156	16-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2157	16-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2158	16-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2159	16-Jan-24	BANGALORE	66	ANJANAPURA - BG ROAD	ANJANAPURA	10:00	14:15	04:15	LINE CLEAR AVAILED
2160	16-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	LINE CLEAR AVAILED
2161	16-Jan-24	BANGALORE	66	HBR LAYOUT 220 - HBR LAYOUT 66	HBR LAYOUT 66, LR BANDE	13:43	14:02	00:19	TRIPPED ON FAULT
2162	16-Jan-24	BANGALORE	66	HEBBALA 220 - BANASAWADI	BANASAWADI(HV1 & HV3)	13:43	13:57	00:14	TRIPPED ON FAULT
2163	16-Jan-24	BANGALORE	66	HEBBALA 220 - BANASAWADI	BANASAWADI(HV1 & HV3)	16:26	16:38	00:12	TRIPPED ON FAULT
2164	16-Jan-24	BANGALORE	66	HV1	ATTUR YELAHANKA	10:31	10:37	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2165	16-Jan-24	BANGALORE	66	HV1	BANASAWADI	14:25	14:27	00:02	LINE CLEAR AVAILED
2166	16-Jan-24	BANGALORE	66	HV1	BANASAWADI	17:42	17:45	00:03	LINE CLEAR AVAILED
2167	16-Jan-24	BANGALORE	66	HV1	DIVYASHREE TECH PARK	09:30	09:35	00:05	LINE CLEAR AVAILED
2168	16-Jan-24	BANGALORE	66	HV1	AUSTIN TOWN	16:50	16:58	00:08	LINE CLEAR AVAILED
2169	16-Jan-24	BANGALORE	66	HV1	KHODAYS 220	10:02	10:08	00:06	LINE CLEAR AVAILED
2170	16-Jan-24	BANGALORE	66	HV1	IRAGAMPALLI	09:20	10:05	00:45	TRIPPED ON FAULT
2171	16-Jan-24	BANGALORE	66	HV1	JANGAMKOTE	09:38	09:46	00:08	TRIPPED ON FAULT
2172	16-Jan-24	BANGALORE	66	HV1	YENNIGADALE	11:35	12:47	01:12	LINE CLEAR AVAILED
2173	16-Jan-24	BANGALORE	66	HV1	YENNIGADALE	15:28	15:30	00:02	LINE CLEAR AVAILED
2174	16-Jan-24	BANGALORE	66	HV1	KGF	14:50	19:05	04:15	LINE CLEAR AVAILED
2175	16-Jan-24	BANGALORE	66	HV1	BEVOOR	16:00	16:38	00:38	LINE CLEAR AVAILED
2176	16-Jan-24	BANGALORE	66	HV2	KHODAYS 220	10:02	10:08	00:06	LINE CLEAR AVAILED
2177	16-Jan-24	BANGALORE	66	HV2	YENNIGADALE	11:35	12:47	01:12	LINE CLEAR AVAILED
2178	16-Jan-24	BANGALORE	66	HV2	YENNIGADALE	17:13	18:33	01:20	LINE CLEAR AVAILED
2179	16-Jan-24	BANGALORE	66	HV2	CHIKKABALLAPURA URBAN	16:15	16:20	00:05	LINE CLEAR AVAILED
2180	16-Jan-24	BANGALORE	66	HV2	HULLENHALLI	16:12	16:24	00:12	TRIPPED ON FAULT
2181	16-Jan-24	BANGALORE	66	HV2	HULLENHALLI	16:50	17:00	00:10	TRIPPED ON FAULT
2182	16-Jan-24	BANGALORE	66	HV2	BEVOOR	16:00	16:38	00:38	LINE CLEAR AVAILED
2183	16-Jan-24	BANGALORE	66	HV3	BANASAWADI	14:25	14:27	00:02	LINE CLEAR AVAILED
2184	16-Jan-24	BANGALORE	66	HV3	BANASAWADI	17:42	17:45	00:03	LINE CLEAR AVAILED
2185	16-Jan-24	BANGALORE	66	HV3	BIDADI 220	08:14	08:23	00:09	TRIPPED ON FAULT
2186	16-Jan-24	BANGALORE	66	IISc - HEBBALA 220	IISc	06:08	06:13	00:05	LINE CLEAR AVAILED
2187	16-Jan-24	BANGALORE	66	ISKON - SOMANAHALLI 220	ISKON	11:30	11:37	00:07	LINE CLEAR AVAILED
2188	16-Jan-24	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	13:40	13:43	00:03	LINE CLEAR AVAILED
2189	16-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2190	16-Jan-24	BANGALORE	66	KORAMANGALA 220 - GOLF LINK HAL 1	NO STATION AFFECTED	22:09	23:03	00:54	TRIPPED ON FAULT
2191	16-Jan-24	BANGALORE	66	MAASTHI - SOLAR(EHT)	NO STATION AFFECTED	11:35	11:45	00:10	TRIPPED ON FAULT
2192	16-Jan-24	BANGALORE	66	NRS 220 - TELECOM LAYOUT 2	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2193	16-Jan-24	BANGALORE	66	PADMANABHANAGAR-NATIONAL COLLEGE	PADMANABHANAGARA	15:06	15:09	00:03	LINE CLEAR AVAILED
2194	16-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	11:38	11:50	00:12	TRIPPED ON FAULT
2195	16-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	11:50	14:02	02:12	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2196	16-Jan-24	BANGALORE	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	16:15	18:30	02:15	TRIPPED ON FAULT
2197	16-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	12:50	14:02	01:12	LINE CLEAR AVAILED
2198	16-Jan-24	GULBARGA	66	CJ HALLI-GUDEKOTE LINE	CJ HALLI_66,HOSAHALLI_66	09:55	11:35	01:40	LINE CLEAR AVAILED
2199	16-Jan-24	GULBARGA	66	CJ HALLI-GUDEKOTE LINE	CJ HALLI_66,HOSAHALLI_66	11:40	12:30	00:50	LINE CLEAR AVAILED
2200	16-Jan-24	GULBARGA	66	HV2	GIRIYAPUR_66	05:25	05:30	00:05	TRIPPED ON FAULT
2201	16-Jan-24	GULBARGA	66	HV2	GIRIYAPURA_66	05:25	05:30	00:05	TRIPPED ON FAULT
2202	16-Jan-24	GULBARGA	66	TELGI-YARGUNTA	OBJ HALLI_66	12:25	16:00	03:35	LINE CLEAR AVAILED
2203	16-Jan-24	GULBARGA	110	BEVOOR-MANGALURU	MANGALURU_110	11:13	12:26	01:13	LINE CLEAR AVAILED
2204	16-Jan-24	GULBARGA	110	CHICKSUGUR-RAICHUR	CHICKSUGUR_110	06:57	08:54	01:57	MAIN SUPPLY FAILURE
2205	16-Jan-24	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	07:00	08:55	01:55	MAIN SUPPLY FAILURE
2206	16-Jan-24	GULBARGA	110	GUGAL-RAICHUR	GUGAL_110	07:00	08:55	01:55	MAIN SUPPLY FAILURE
2207	16-Jan-24	GULBARGA	110	HV1	HANAWALA_110	12:45	13:40	00:55	LINE CLEAR AVAILED
2208	16-Jan-24	GULBARGA	110	KUSTAGI-KALABANDI	KALABANDI KBJNL_110	22:43	22:55	00:12	TRIPPED ON FAULT
2209	16-Jan-24	GULBARGA	110	SHAKTINAGAR-RAICHUR	SHAKTINAGAR_110	06:55	08:54	01:59	MAIN SUPPLY FAILURE
2210	16-Jan-24	GULBARGA	110	SINDHANOOR-SR NAGAR	KARATAGI_110,	14:22	16:10	01:48	TRIPPED ON FAULT
2211	16-Jan-24	GULBARGA	220	HV1	RAICHUR_220	07:00	08:43	01:43	LINE CLEAR AVAILED
2212	16-Jan-24	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	20:58	21:15	00:17	TRIPPED ON FAULT
2213	16-Jan-24	HASSAN	66	HNPR2-HNPR1	HNPUA_220	07:45	07:55	00:10	TRIPPED ON FAULT
2214	16-Jan-24	HASSAN	66	HV2	SAKALESHPUA_66	10:40	13:55	03:15	LINE CLEAR AVAILED
2215	16-Jan-24	HASSAN	66	HV2	SBELAGOLA_66	13:10	13:20	00:10	LINE CLEAR AVAILED
2216	16-Jan-24	HASSAN	66	MATTNAV-CRPATNA	MATTNAVILE_66	18:10(16.01.2024)			LINE CLEAR AVAILED
2217	16-Jan-24	HASSAN	110	ARASIK-L1	ARASIKERE_220	14:11	17:00	02:49	TRIPPED ON FAULT
2218	16-Jan-24	HASSAN	110	BANTWA-SALATTUR	BANTWALA_110	09:43	13:33	03:50	LINE CLEAR AVAILED
2219	16-Jan-24	HASSAN	110	HV2	BANAVARA_110	05:35	06:00	00:25	MAIN SUPPLY FAILURE
2220	16-Jan-24	HASSAN	110	HV2	BANAVARA_110	09:15	09:30	00:15	MAIN SUPPLY FAILURE
2221	16-Jan-24	HASSAN	110	HV2	BANAVARA_110	15:10	16:10	01:00	MAIN SUPPLY FAILURE
2222	16-Jan-24	HASSAN	110	HV2	BANAVARA_110	16:35	17:00	00:25	MAIN SUPPLY FAILURE
2223	16-Jan-24	HASSAN	110	HV3	BANTWALA_110	12:07	14:11	02:04	LINE CLEAR AVAILED
2224	16-Jan-24	HASSAN	110	HV4	BANTWALA_110	10:38	13:32	02:54	LINE CLEAR AVAILED
2225	16-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2226	16-Jan-24	HASSAN	220	HV2	SHIRALKOPPA_220	13:09	14:29	01:20	MAIN SUPPLY FAILURE
2227	16-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2228	16-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	19:20(14.1.2024)			TRIPPED ON FAULT
2229	16-Jan-24	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	16:36(15.01.2024)	12:50(16.01.2024)	20:26HRS	LINE CLEAR AVAILED
2230	16-Jan-24	HASSAN	220	SHRAVTY-SHIRALKOPPA	gen_sharavaty	13:09	15:20	02:11	TRIPPED ON FAULT
2231	16-Jan-24	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	13:09	15:20	02:11	TRIPPED ON FAULT
2232	16-Jan-24	HASSAN	220	VARAHI-SHIMOGA2	gen_varahi	16:36(15.01.2024)	12:50(16.01.2024)	20:26HRS	LINE CLEAR AVAILED
2233	16-Jan-24	HASSAN	220	VARAHI-SHMG3	gen_varahi	13:44	18:44	05:00	LINE CLEAR AVAILED
2234	16-Jan-24	MYSORE	66	BEGUR 220-BEGUR 1	NO STATIONS EFFECTED	20:48:00	20:52:00	00:04:00	TRIPPED ON FAULT
2235	16-Jan-24	MYSORE	66	BEGUR 220-GUNDLUPETE 1	NO STATIONS EFFECTED	07:15:00	07:20:00	00:05:00	TRIPPED ON FAULT
2236	16-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:49 (14/012024)			LINE CLEAR AVAILED
2237	16-Jan-24	MYSORE	66	HUNSUR 220-KAMPLAPURA	NO STATIONS EFFECTED	18:32:00	18:49:00	00:17:00	TRIPPED ON FAULT
2238	16-Jan-24	MYSORE	66	HV1	HARADANAHALLI_66	07:45:00	07:55:00	00:10:00	MAIN SUPPLY FAILURE
2239	16-Jan-24	MYSORE	66	HV1	KIADB SOMNAHALLI_66	15:07:00	15:27:00	00:20:00	TRIPPED ON FAULT
2240	16-Jan-24	MYSORE	66	HV1	PONNAMPETE_66	15:14:12	16:31:50	01:17:38	LINE CLEAR AVAILED
2241	16-Jan-24	MYSORE	66	HV2	GUNDLUPETE_66	13:00:00	13:10:00	00:10:00	TRIPPED ON FAULT
2242	16-Jan-24	MYSORE	66	HV2	HARADANAHALLI_66	07:45:00	07:55:00	00:10:00	MAIN SUPPLY FAILURE
2243	16-Jan-24	MYSORE	66	HV2	PONNAMPETE_66	16:31:50	17:05:58	00:34:08	LINE CLEAR AVAILED
2244	16-Jan-24	MYSORE	66	HV3	PONNAMPETE_66	10:48:07			LINE CLEAR AVAILED
2245	16-Jan-24	MYSORE	66	HV5	SFC SIVA_66	06:19:00	13:25:42	07:06:42	LINE CLEAR AVAILED
2246	16-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)			TRIPPED ON FAULT
2247	16-Jan-24	MYSORE	66	KR NAGARA-MYSORE-1	MIRLE_66	16:16:44	17:37:21	01:20:37	LINE CLEAR AVAILED
2248	16-Jan-24	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	16:12:24	17:36:48	01:24:24	LINE CLEAR AVAILED
2249	16-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	05:45:00	05:55:00	00:10:00	TRIPPED ON FAULT
2250	16-Jan-24	TUMKUR	66	BILCHODU- BADALADAKU	BILCHODU_66,PALLAGATT E_66,SOKKE_66	22:10	22:35	00:25	MAIN SUPPLY FAILURE
2251	16-Jan-24	TUMKUR	66	BILCHODU- BADALADAKU	BILCHODU_66,PALLAGATT E_66,SOKKE_66	22:50	23:00	00:10	MAIN SUPPLY FAILURE
2252	16-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 2	CHITRADURGA_220	1816(15.01.2024)	13:22(16.01.2024)	19 HR 6MIN	TRIPPED ON FAULT
2253	16-Jan-24	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 1	CHITRADURGA_66	11:29	13:22	01:53	LINE CLEAR AVAILED
2254	16-Jan-24	TUMKUR	66	CHITRADURGA 66kV-CHITRADURGA 3	CHITRADURGA_66	16:38	17:44	01:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2255	16-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	07:01	07:20	00:19	TRIPPED ON FAULT
2256	16-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA 2	KUKKAWADA_66, SHYAGALE66,KEREBILCHI_66	07:05	07:20	00:15	MAIN SUPPLY FAILURE
2257	16-Jan-24	TUMKUR	66	DAVANGERE SRS-MAYAKONDA 66	MAYAKONDA_66,SASALUHALLA_66,PANDARAHALLI_2	11:03	11:23	00:20	TRIPPED ON FAULT
2258	16-Jan-24	TUMKUR	66	HIRIYUR 220KV- THALLAK 66	THALLAKK_66	06:40	06:50	00:10	TRIPPED ON FAULT
2259	16-Jan-24	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	12:40	13:50	01:10	LINE CLEAR AVOIDED
2260	16-Jan-24	TUMKUR	66	KATTIGE- HONNALI_66	KATTIGE_66	18:05	19:00	00:55	LINE CLEAR AVOIDED
2261	16-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2262	16-Jan-24	TUMKUR	66	SASALUHALLA-MAYAKONDA	SASALUHALLA_66	11:05	11:25	00:20	MAIN SUPPLY FAILURE
2263	16-Jan-24	TUMKUR	66	TR-1	CHANNAGIRI_66	15:45	16:25	00:40	LINE CLEAR AVOIDED
2264	16-Jan-24	TUMKUR	66	TR-1	I.D.HALLI_66	12:40	13:50	01:10	LINE CLEAR AVOIDED
2265	16-Jan-24	TUMKUR	66	TR-1	MELLAKATE_66	12:55	13:00	00:05	TRIPPED ON FAULT
2266	16-Jan-24	TUMKUR	66	TR-1&TR-2	KATTIGE_66	18:05	19:00	00:55	LINE CLEAR AVOIDED
2267	16-Jan-24	TUMKUR	66	TR-2	I.D.HALLI_66	11:35	13:20	01:45	LINE CLEAR AVOIDED
2268	16-Jan-24	TUMKUR	110	KB CROSS 220kv-MAYASANDRA	MAYASANDRA_110,KADEHALLI_110	06:39	06:47	00:08	TRIPPED ON FAULT
2269	16-Jan-24	TUMKUR	110	TR-1	KALLUR_110	18:25	19:15	00:50	LINE CLEAR AVOIDED
2270	16-Jan-24	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	OPEN ON (28.12.23) 2:29:35 PM	19:03(16.01.2024)	18 days 16 HR 34 MIN	LINE CLEAR AVOIDED
2271	16-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVOIDED
2272	17-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	NAVALAGI_110	11:17	12:12	00:55	LINE CLEAR AVOIDED
2273	17-Jan-24	BAGALKOT	110	110/11KV,HV-1(10MVA)	UKKALI_110	11:45	12:35	00:50	LINE CLEAR AVOIDED
2274	17-Jan-24	BAGALKOT	110	110/11KV,HV-1(20MVA)	UDYAMBAG_110	11:17	12:13	00:56	LINE CLEAR AVOIDED
2275	17-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	HATTARAGI_110	08:01	09:45	01:44	TRIPPED ON FAULT
2276	17-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	MUNAVALLI_110	16:32	17:17	00:45	TRIPPED ON FAULT
2277	17-Jan-24	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED HUBLI_220	09:57	19:21	09:24	LINE CLEAR AVOIDED
2278	17-Jan-24	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED AHERI_220	07:08	10:56	03:48	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2279	17-Jan-24	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED AHERI_220	07:08	10:56	03:48	LINE CLEAR AVOIDED
2280	17-Jan-24	BAGALKOT	110	ANKOLA- KUMATA2	STATION NOT AFFECTED ANKOLA_110	6:33 (17.01.2024)			LINE CLEAR AVOIDED
2281	17-Jan-24	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110	10:54	10:56	00:02	LINE CLEAR AVOIDED
2282	17-Jan-24	BAGALKOT	110	GADAG220- BETAGERI(ROH)	STATION NOT AFFECTED GADAG_220	18:27	22:04	03:37	TRIPPED ON FAULT
2283	17-Jan-24	BAGALKOT	110	GADAG220-LAXMESHWAR2	STATION NOT AFFECTED GADAG_220	22:03	22:22	00:19	TRIPPED ON FAULT
2284	17-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVOIDED
2285	17-Jan-24	BAGALKOT	110	HEELADAHALLI(BELUR)- AREMALLAPUR	HEELADAHALLI_110	01:15	01:45	00:30	TRIPPED ON FAULT
2286	17-Jan-24	BAGALKOT	110	HIREMASALI-ATHARAGA	HIREMASALI_110	10:15	10:16	00:01	TRIPPED ON FAULT
2287	17-Jan-24	BAGALKOT	110	HOSAHONNATTI-BELUR	HOSAHONNATTI_110	01:00	01:10	00:10	LINE CLEAR AVOIDED
2288	17-Jan-24	BAGALKOT	110	HOSAHONNATTI-GUTTAL	HOSAHONNATTI_110	8:05 (16.01.2024)			TRIPPED ON FAULT
2289	17-Jan-24	BAGALKOT	110	HUBLI220- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	18:40	18:41	00:01	LINE CLEAR AVOIDED
2290	17-Jan-24	BAGALKOT	110	HUBLI220- RAMANKOPPA	STATION NOT AFFECTED HUBLI_220	18:59	19:00	00:01	LINE CLEAR AVOIDED
2291	17-Jan-24	BAGALKOT	110	HUDLI-ANKALAGI	HUDALI_110	18:30	18:45	00:15	TRIPPED ON FAULT
2292	17-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
2293	17-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
2294	17-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
2295	17-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2296	17-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
2297	17-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2023)			LINE CLEAR AVOIDED
2298	17-Jan-24	BAGALKOT	110	UKKALI- F2(B BAGEWADI)	UKKALI_110	11:15	12:31	01:16	LINE CLEAR AVOIDED
2299	17-Jan-24	BAGALKOT	110	YELLAMMANAVADI-SAVALAGI	YELLAMMANAVADI_110	11:39	11:50	00:11	LINE CLEAR AVOIDED
2300	17-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED HUBLI_220	09:57	19:21	09:24	LINE CLEAR AVOIDED
2301	17-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AHERI_220	07:10	10:56	03:46	LINE CLEAR AVOIDED
2302	17-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED NARENDRA_220	13:32	14:11	00:39	LINE CLEAR AVOIDED
2303	17-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED AHERI_220	07:10	10:54	03:44	LINE CLEAR AVOIDED
2304	17-Jan-24	BAGALKOT	220	AHERI- F1(BIJAPUR1)	STATION NOT AFFECTED AHERI_220	07:02	10:54	03:52	LINE CLEAR AVOIDED
2305	17-Jan-24	BAGALKOT	220	AHERI- F2(BIJAPUR2)	STATION NOT AFFECTED AHERI_220	07:04	10:54	03:50	LINE CLEAR AVOIDED
2306	17-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
2307	17-Jan-24	BAGALKOT	220	BIJAPUR-AHERI1	STATION NOT AFFECTED BIJAPUR_220	07:04	10:53	03:49	LINE CLEAR AVOIDED
2308	17-Jan-24	BAGALKOT	220	BIJAPUR-AHERI2	STATION NOT AFFECTED BIJAPUR_220	07:04	10:53	03:49	LINE CLEAR AVOIDED
2309	17-Jan-24	BAGALKOT	220	GHATAPRABHA-MUGALKHOD1	STATION NOT AFFECTED GHATAPRABHA_220	15:27	17:53	02:26	LINE CLEAR AVOIDED
2310	17-Jan-24	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATAPRABHA_220	00:04	00:33	00:29	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2311	17-Jan-24	BAGALKOT	220	MUGALKHOD-GHATAPRABHA1	STATION NOT AFFECTED MUGALKHOD_220	15:30	17:55	02:25	LINE CLEAR AVOIDED
2312	17-Jan-24	BAGALKOT	220	NARENDRA- BIDNAL	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)			LINE CLEAR AVOIDED
2313	17-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)			LINE CLEAR AVOIDED
2314	17-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2315	17-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2316	17-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
2317	17-Jan-24	BANGALORE	66	APPAREL PARK - KIADB DB PURA 220	APPAREL PARK	15:00	15:05	00:05	MAIN SUPPLY FAILURE
2318	17-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2319	17-Jan-24	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:05	16:16	00:11	TRIPPED ON FAULT
2320	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	09:15	17:05	07:50	LINE CLEAR AVOIDED
2321	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 1	GANJIGUNTE, PALLICHERLU	09:15	15:45	06:30	LINE CLEAR AVOIDED
2322	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - GANJIGUNTE 2	GANJIGUNTE, PALLICHERLU	09:15	15:45	06:30	LINE CLEAR AVOIDED
2323	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	09:15	17:05	07:50	LINE CLEAR AVOIDED
2324	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	09:15	17:24	08:09	LINE CLEAR AVOIDED
2325	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	09:15	17:25	08:10	LINE CLEAR AVOIDED
2326	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - SRINIVASPURA	G KODIHALLI, SRINIVASPURA	09:15	17:05	07:50	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2327	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - TADIGOLU CROSS	TADIGOLU CROSS, LAKSHMIPURA, ADDAGAL, GOWNIPALLI, SOMAYAJANAHALLI, RAYALPADU	09:15	18:15	09:00	LINE CLEAR AVAILED
2328	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	09:15	17:34	08:19	LINE CLEAR AVAILED
2329	17-Jan-24	BANGALORE	66	CHINTAMANI 220 - YENNIGADALE	K RAGUTTAHALLI, BOMMEPALLI CROSS, YENIGADALE	09:15	17:05	07:50	LINE CLEAR AVAILED
2330	17-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI, NANDI	16:05	16:15	00:10	TRIPPED ON FAULT
2331	17-Jan-24	BANGALORE	66	GANJIGUNTE - DIBBURAHALLI	PALICHERLU, GANJIGUNTE	18:12	18:20	00:08	LINE CLEAR AVAILED
2332	17-Jan-24	BANGALORE	66	HOSKOTE 220 - DG4(VIDYANAGARA)	HOSKOTE 66, GRINDWELL(EHT)	16:19	16:33	00:14	TRIPPED ON FAULT
2333	17-Jan-24	BANGALORE	66	HV1	MATHIKERE	03:25	03:38	00:13	TRIPPED ON FAULT
2334	17-Jan-24	BANGALORE	66	HV1	MATHIKERE	04:30	05:10	00:40	LINE CLEAR AVAILED
2335	17-Jan-24	BANGALORE	66	HV1	ADUGODI	12:14	13:45	01:31	LINE CLEAR AVAILED
2336	17-Jan-24	BANGALORE	66	HV1	Y HUNSENAHALLI	18:05	18:10	00:05	LINE CLEAR AVAILED
2337	17-Jan-24	BANGALORE	66	HV1	VATADAHOSAHALLI	16:05	16:10	00:05	LINE CLEAR AVAILED
2338	17-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	12:50	12:55	00:05	LINE CLEAR AVAILED
2339	17-Jan-24	BANGALORE	66	HV1	ANDERSONPET	13:00	13:02	00:02	LINE CLEAR AVAILED
2340	17-Jan-24	BANGALORE	66	HV1	MALUR 66	11:35	11:50	00:15	LINE CLEAR AVAILED
2341	17-Jan-24	BANGALORE	66	HV2	NRS 220	07:30	07:35	00:05	LINE CLEAR AVAILED
2342	17-Jan-24	BANGALORE	66	HV2	MATHIKERE	05:00	05:35	00:35	LINE CLEAR AVAILED
2343	17-Jan-24	BANGALORE	66	HV2	IRAGAMPALLI	05:10	05:35	00:25	TRIPPED ON FAULT
2344	17-Jan-24	BANGALORE	66	HV2	YENIGADALE	08:02	09:14	01:12	LINE CLEAR AVAILED
2345	17-Jan-24	BANGALORE	66	HV2	ADDAGAL	02:25	02:40	00:15	TRIPPED ON FAULT
2346	17-Jan-24	BANGALORE	66	HV3	ADUGODI	10:15	13:35	03:20	LINE CLEAR AVAILED
2347	17-Jan-24	BANGALORE	66	HV3	NAGANATHPURA 220	07:54	08:05	00:11	TRIPPED ON FAULT
2348	17-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2349	17-Jan-24	BANGALORE	66	LAKKUR - MALUR 220	LAKKUR, DEVANAGUNDI	17:20	17:35	00:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2350	17-Jan-24	BANGALORE	66	MITTEMARI 220 - SADALI	SADALI, DIBBURAHALLI	09:30	15:25	05:55	LINE CLEAR AVAILED
2351	17-Jan-24	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY, ELITA PROMENENDE	10:35	10:40	00:05	LINE CLEAR AVAILED
2352	17-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	00:34	00:44	00:10	TRIPPED ON FAULT
2353	17-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	01:45	02:10	00:25	TRIPPED ON FAULT
2354	17-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - H GOLLAHALLI	H GOLLAHALLI, MUDIYANUR	06:15	06:25	00:10	TRIPPED ON FAULT
2355	17-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLA PURA I/A 1	CHIKKABALLAPURA I/A	16:05	16:16	00:11	TRIPPED ON FAULT
2356	17-Jan-24	BANGALORE	66	VIJAYAPURA - JANGAMKOTE	JANGAMKOTE	09:25	17:15	07:50	LINE CLEAR AVAILED
2357	17-Jan-24	BANGALORE	220	CHINTAMANI 220 - PGCIL KOLAR 1	CHINTAMANI 220	09:31	17:05	07:34	LINE CLEAR AVAILED
2358	17-Jan-24	BANGALORE	220	CHINTAMANI 220 - PGCIL KOLAR 2	CHINTAMANI 220	09:31	17:05	07:34	LINE CLEAR AVAILED
2359	17-Jan-24	BANGALORE	220	GOWRIBIDANUR 220 - KIADB DB PURA 220	NO STATION AFFECTED	15:02	16:42	01:40	TRIPPED ON FAULT
2360	17-Jan-24	BANGALORE	220	KIADB DB PURA 220 - NRS DB PURA 220	KIADB DB PURA 220	15:01	15:06	00:05	LINE CLEAR AVAILED
2361	17-Jan-24	GULBARGA	66	HV2	HUVINA HADAGALLI_66	11:50	12:18	00:28	TRIPPED ON FAULT
2362	17-Jan-24	GULBARGA	66	KUDALGI-CHOORNUR	CHORNOOR_66	11:10	11:35	00:25	LINE CLEAR AVAILED
2363	17-Jan-24	GULBARGA	66	KUDALGI-KOTTUR	UJJINI_66	12:00	12:20	00:20	TRIPPED ON FAULT
2364	17-Jan-24	GULBARGA	66	KUDALGI-KOTTUR	UJJINI_66	17:40	19:20	01:40	LINE CLEAR AVAILED
2365	17-Jan-24	GULBARGA	110	ALIPUR-BELLARY SOUTH	BELLARY SOUTH_110,HALKUNDI_110	18:15	18:37	00:22	LINE CLEAR AVAILED
2366	17-Jan-24	GULBARGA	110	ALKOD-MALLAT	ALKOD_110,GALAG_110	18:22	18:27	00:05	TRIPPED ON FAULT
2367	17-Jan-24	GULBARGA	110	HV1	GIS SHANTINAGAR	09:10	09:58	00:48	LINE CLEAR AVAILED
2368	17-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	11:00	14:45	03:45	LINE CLEAR AVAILED
2369	17-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	15:23	15:35	00:12	TRIPPED ON FAULT
2370	17-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	18:25	19:15	00:50	TRIPPED ON FAULT
2371	17-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	19:15	20:43	01:28	LINE CLEAR AVAILED
2372	17-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	18:22	18:27	00:05	TRIPPED ON FAULT
2373	17-Jan-24	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	15:12	15:17	00:05	TRIPPED ON FAULT
2374	17-Jan-24	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	18:25	18:30	00:05	TRIPPED ON FAULT
2375	17-Jan-24	GULBARGA	110	SIRWAR-RAICHUR	SIRWAR_110	04:10	04:25	00:15	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2376	17-Jan-24	GULBARGA	220	KONKAL-RAMASAMUDRA	KONKAL_110	11:43	16:21	04:38	LINE CLEAR AVAILED
2377	17-Jan-24	HASSAN	66	BALEHN-ALDUR	BALEHONNUR_66	11:46	14:20	02:34	LINE CLEAR AVAILED
2378	17-Jan-24	HASSAN	66	HASSN22-BELUR	HASSAN_220	08:00	08:30	00:30	TRIPPED ON FAULT
2379	17-Jan-24	HASSAN	66	HASSN22-HASSAN	HASSAN_220	08:00	08:26	00:26	TRIPPED ON FAULT
2380	17-Jan-24	HASSAN	66	HASSN22-HN PURA	HASSAN_220	08:00	11:06	03:06	TRIPPED ON FAULT
2381	17-Jan-24	HASSAN	66	HASSN22--SUZLON	HASSAN_220	08:00	08:52	00:52	TRIPPED ON FAULT
2382	17-Jan-24	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	08:00	08:51	00:51	TRIPPED ON FAULT
2383	17-Jan-24	HASSAN	66	HV1	SAKALESH PURA_66	13:25	13:50	00:25	LINE CLEAR AVAILED
2384	17-Jan-24	HASSAN	66	HV1	SIGEBAGE_66	09:28	14:25	04:57	LINE CLEAR AVAILED
2385	17-Jan-24	HASSAN	66	KANDLI-SAKLESH PUR	KANDLI_66	13:27	13:36	00:09	LINE CLEAR AVAILED
2386	17-Jan-24	HASSAN	66	MATTA NAV-CR PATNA	MATTA NAVILE_66	18:10(16.01.2024)	11:03(17.01.2024)	'16:53HRS	LINE CLEAR AVAILED
2387	17-Jan-24	HASSAN	66	MRSSHM-DVG2	MRS MG_220	09:27	14:21	04:54	LINE CLEAR AVAILED
2388	17-Jan-24	HASSAN	66	SAKALE-HASSAN	SAKALESH PURA_66	13:29	13:36	00:07	LINE CLEAR AVAILED
2389	17-Jan-24	HASSAN	66	SIGEBAG-KDL GRE	SIGEBAGE_66	09:28	15:45	06:17	LINE CLEAR AVAILED
2390	17-Jan-24	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	09:28	14:23	04:55	LINE CLEAR AVAILED
2391	17-Jan-24	HASSAN	66	UDDURKO-NITTUR	UDDURKOPPLU_66	8:00 (17.01.2024)			LINE CLEAR AVAILED
2392	17-Jan-24	HASSAN	66	UDDURKO-UDDUR	UDDURKOPPLU_66	08:00	08:52	00:52	TRIPPED ON FAULT
2393	17-Jan-24	HASSAN	110	HV1	KARAYA_110	11:47	12:20	00:33	LINE CLEAR AVAILED
2394	17-Jan-24	HASSAN	110	HV2	KONAJE_110	10:15	14:17	04:02	LINE CLEAR AVAILED
2395	17-Jan-24	HASSAN	110	LV3	MRS MG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2396	17-Jan-24	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	21:04 (17.01.2024)			TRIPPED ON FAULT
2397	17-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	18:02	20:31	02:29	TRIPPED ON FAULT
2398	17-Jan-24	HASSAN	220	HEGGUBJE-VARAH	HEGGUNJE_220	11:51	13:55	02:04	LINE CLEAR AVAILED
2399	17-Jan-24	HASSAN	220	HV1	MSEZ_220	09:55	16:00	06:05	LINE CLEAR AVAILED
2400	17-Jan-24	HASSAN	220	HV3	MRS MG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2401	17-Jan-24	HASSAN	220	SHRAVITY-SHIMOGA3	gen_sharavathy	19:20(14.01.2024)	19:16(17.01.2024)	71:56HRS	LINE CLEAR AVAILED
2402	17-Jan-24	HASSAN	220	VARAH-KEMAR3	gen_varahi	11:54	13:56	02:02	LINE CLEAR AVAILED
2403	17-Jan-24	MYSORE	66	BANNUR-SFC	NO STATIONS EFFECTED	05:27	10:34	05:07	LINE CLEAR AVAILED
2404	17-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:49 (14/012024)			LINE CLEAR AVAILED
2405	17-Jan-24	MYSORE	66	HV1	MADHUVANAHALLI_66	10:57	12:40	01:43	LINE CLEAR AVAILED
2406	17-Jan-24	MYSORE	66	HV1	MALLAVALLI_66	18:30	19:08	00:38	LINE CLEAR AVAILED
2407	17-Jan-24	MYSORE	66	HV1	PONNAMPETE_66	14:45	14:50	00:05	TRIPPED ON FAULT
2408	17-Jan-24	MYSORE	66	HV2	MADHUVANAHALLI_66	12:37	14:20	01:43	LINE CLEAR AVAILED
2409	17-Jan-24	MYSORE	66	HV3	PONNAMPETE_66	10:48:07	16:22:00 (17/01/2024)	29:33:53	LINE CLEAR AVAILED
2410	17-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2411	17-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	07:21	07:34	00:12	TRIPPED ON FAULT
2412	17-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	16:43	16:47	00:04	LINE CLEAR AVAILED
2413	17-Jan-24	MYSORE	66	NAGAMANGALA 220-BG NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	01:30	01:43	00:13	TRIPPED ON FAULT
2414	17-Jan-24	MYSORE	66	PERIAPATANA-HANGUD	NO STATIONS EFFECTED	14:43	14:50	00:06	TRIPPED ON FAULT
2415	17-Jan-24	MYSORE	66	SFCSIVA-CHEL	NO STATIONS EFFECTED	10:47	18:52	08:05	LINE CLEAR AVAILED
2416	17-Jan-24	MYSORE	220	HV1	MADHUVANAHALLI_220	12:59	16:33	03:33	LINE CLEAR AVAILED
2417	17-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66	08:17	09:09	00:52	LOAD CURTAILMENT
2418	17-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	08:17	09:09	00:52	LOAD CURTAILMENT
2419	17-Jan-24	TUMKUR	66	BENKIKERE 220kv-DEVARAHALLI	DEVARAHALLI_66KEREKIBILA CHI66-SANTEBENNUR_66	12:10	12:15	00:05	TRIPPED ON FAULT
2420	17-Jan-24	TUMKUR	66	BENKIKERE 220kv-MALLADIHALLI	MALLADIHALLI_66	13:10	14:10	01:00	MAIN SUPPLY FAILURE
2421	17-Jan-24	TUMKUR	66	BILCHODU- BADALADAKU	BILCHODU_66,PALLAGATTE_66,SOKKE_66	12:05	12:20	00:15	MAIN SUPPLY FAILURE
2422	17-Jan-24	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66,SOKKE_66	17:45	19:00	01:15	MAIN SUPPLY FAILURE
2423	17-Jan-24	TUMKUR	66	BILCHODU-PALLAGATTE	PALLAGATTE_66,SOKKE_66	19:35	19:45	00:10	LINE CLEAR AVAILED
2424	17-Jan-24	TUMKUR	66	CHITRADURGA 220kv-HIREGUNTANUR	HIREGUNTANUR_66,	07:10	08:33	01:23	TRIPPED ON FAULT
2425	17-Jan-24	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	23:04	23:19	00:15	TRIPPED ON FAULT
2426	17-Jan-24	TUMKUR	66	HONNALLI 220kv-LINGADAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	06:28	06:48	00:20	TRIPPED ON FAULT
2427	17-Jan-24	TUMKUR	66	HONNALLI 220kv-SAVALANGA 66	SAVALANGA_66	09:22	10:28	01:06	LOAD CURTAILMENT
2428	17-Jan-24	TUMKUR	66	HONNALLI 220kv-MALEBENNUR 66	MALLEBENNUR_66	10:33	11:00	00:27	LOAD CURTAILMENT
2429	17-Jan-24	TUMKUR	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	11:00	11:48	00:48	LOAD CURTAILMENT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2430	17-Jan-24	TUMKUR	66	MADHUGIRI 220kV- PULLAMAGATTA	PULLAMGATTA_66	16:39	16:52	00:13	TRIPPED ON FAULT
2431	17-Jan-24	TUMKUR	66	MAVINAKATTE66- LINGADAHALLI(MRS SHIMOGA)	MAVINAKATTE_66	09:30	10:10	00:40	MAIN SUPPLY FAILURE
2432	17-Jan-24	TUMKUR	66	MAVINAKATTE66- LINGADAHALLI(MRS SHIMOGA)	MAVINAKATTE_66	17:15	17:25	00:10	MAIN SUPPLY FAILURE
2433	17-Jan-24	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2434	17-Jan-24	TUMKUR	66	THALLAK 220kV- P R PURA	PR PURA_66	17:41	17:51	00:10	LINE CLEAR AVAILED
2435	17-Jan-24	TUMKUR	66	TR-1	KUNIGAL_66	22:50	22:57	00:07	TRIPPED ON FAULT
2436	17-Jan-24	TUMKUR	66	TR-1	LINGADAHALLY_66	10:05	11:10	01:05	TRIPPED ON FAULT
2437	17-Jan-24	TUMKUR	66	TR-1	MAVINAKATTE_66	06:00	06:05	00:05	TRIPPED ON FAULT
2438	17-Jan-24	TUMKUR	66	TR-2	BUKKAPATNA_66	07:55	08:20	00:25	LINE CLEAR AVAILED
2439	17-Jan-24	TUMKUR	66	TR-2	CHANNAGIRI_66	03:40	03:50	00:10	TRIPPED ON FAULT
2440	17-Jan-24	TUMKUR	66	TR-2	GOPPENAHALLI66	17:00(17.01.2024)	14:50(18.01.2024)	21:50	LINE CLEAR AVAILED
2441	17-Jan-24	TUMKUR	66	TR-3	THALLAKK_220	17:41	18:21	00:40	LINE CLEAR AVAILED
2442	17-Jan-24	TUMKUR	110	TR-1	KB CROSS_220	15:06	15:09	00:03	LINE CLEAR AVAILED
2443	17-Jan-24	TUMKUR	220	ANCHEPALYA 220kV- NELSANGALA 1(NAGAMANGALA 1)	ANCHEPALYA_220	16:29	17:59	01:30	LINE CLEAR AVAILED
2444	17-Jan-24	TUMKUR	220	HONNALLI 220kV- BENKIKERE 220 1	HONNALLI_220	09:26	09:41	00:15	LOAD CURTAILMENT
2445	17-Jan-24	TUMKUR	220	HONNALLI 220kV- BENKIKERE 220 2	HONNALLI_220	10:33	11:00	00:27	LOAD CURTAILMENT
2446	17-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2447	18-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	HALIYAL_110	03:37	03:47	00:10	TRIPPED ON FAULT
2448	18-Jan-24	BAGALKOT	110	110/11KV, HV2(10MVA)	RANEBENNUR_220	11:30	15:44	04:14	TRIPPED ON FAULT
2449	18-Jan-24	BAGALKOT	110	110/11KV, HV4(10MVA)	HUBLI_220	11:00	13:28	02:28	LINE CLEAR AVAILED
2450	18-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	BISANAL_110	11:02	14:19	03:17	LINE CLEAR AVAILED
2451	18-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	BISANAL_110	11:02	14:19	03:17	LINE CLEAR AVAILED
2452	18-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANAGAL_110	10:50	11:04	00:14	TRIPPED ON FAULT
2453	18-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	MUNAVALLI_110	13:15	18:33	05:18	TRIPPED ON FAULT
2454	18-Jan-24	BAGALKOT	110	ALBAL-RAY SOLAR	STATION NOT AFFECTED ALBAL_110	21:10 (18.01.2024)			TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2455	18-Jan-24	BAGALKOT	110	ANKOLA- KUMATA2	STATION NOT AFFECTED ANKOLA_110	6:33 (17.01.2024)			LINE CLEAR AVAILED
2456	18-Jan-24	BAGALKOT	110	ANNIGERI-GADAG	STATION NOT AFFECTED ANNIGERI_110	14:41 (18.01.2024)			TRIPPED ON FAULT
2457	18-Jan-24	BAGALKOT	110	ATHANI220- AIGALI	ATHANI_220	09:04	18:11	09:07	LINE CLEAR AVAILED
2458	18-Jan-24	BAGALKOT	110	ATHARGA-RAILWAY LINE	ATHARGA_110	15:59	16:02	00:03	LINE CLEAR AVAILED
2459	18-Jan-24	BAGALKOT	110	CHIKKODI220- DKSS COGEN	STATION NOT AFFECTED CHIKKODI_220	12:05	12:08	00:03	LINE CLEAR AVAILED
2460	18-Jan-24	BAGALKOT	110	DADDI-F2(HONAGA)	DADDI_110	05:01	05:23	00:22	TRIPPED ON FAULT
2461	18-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
2462	18-Jan-24	BAGALKOT	110	HALIYAL- ALNAVAR	HALIYAL_110	03:37	03:57	00:20	TRIPPED ON FAULT
2463	18-Jan-24	BAGALKOT	110	HALIYAL- GMR(ALNAVAR)	STATION NOT AFFECTED HALIYAL_110	03:49	03:57	00:08	TRIPPED ON FAULT
2464	18-Jan-24	BAGALKOT	110	HOSAHONNATTI-GUTTAL	HOSAHONNATTI_110	8:05 (16.01.2024)	11:55 (18.01.2024)	51:50:00	TRIPPED ON FAULT
2465	18-Jan-24	BAGALKOT	110	ITNAL -RAIBAG	ITNAL_110	12:44 (18.01.2024)			LINE CLEAR AVAILED
2466	18-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
2467	18-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2468	18-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2469	18-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
2470	18-Jan-24	BAGALKOT	110	MUNDAGOD-SRS HUBLI(SHIGGOAN)	MUNDAGOD_110	11:02	12:49	01:47	LINE CLEAR AVAILED
2471	18-Jan-24	BAGALKOT	110	MUNDAGOD-SRS HUBLI(SHIGGOAN)	MUNDAGOD_110	17:18	17:26	00:08	LINE CLEAR AVAILED
2472	18-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2473	18-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVOIDED
2474	18-Jan-24	BAGALKOT	110	YELLAMMANAWADI-F1(AIGALI)	YELLAMMANAWADI_110	18:01 (18.01.2024)			LINE CLEAR AVOIDED
2475	18-Jan-24	BAGALKOT	220	BIDNAL- NARENDRA	STATION NOT AFFECTED BIDNAL_220	12:29	20:39	08:10	LINE CLEAR AVOIDED
2476	18-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
2477	18-Jan-24	BAGALKOT	220	CHIKKODI-KOLAHPUR1(TALANDAGE)	STATION NOT AFFECTED CHIKKODI_220	13:11	19:19	06:08	LINE CLEAR AVOIDED
2478	18-Jan-24	BAGALKOT	220	NARENDRA-HAVERI1(BIDNAL)	STATION NOT AFFECTED NARENDRA_220	20:30	20:38	00:08	LINE CLEAR AVOIDED
2479	18-Jan-24	BAGALKOT	220	NARENDRA-HAVERI1(BIDNAL)	STATION NOT AFFECTED NARENDRA_220	6:59 (03.01.2024)	19:28 (18.01.2024)	372:29:00	LINE CLEAR AVOIDED
2480	18-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	11:54	20:09	08:15	LINE CLEAR AVOIDED
2481	18-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	11:54	20:09	08:15	LINE CLEAR AVOIDED
2482	18-Jan-24	BAGALKOT	220	NARENDRA-SHIGGOAN1(SHIGGOAN)	STATION NOT AFFECTED NARENDRA_220	19:03 (18.01.2024)			TRIPPED ON FAULT
2483	18-Jan-24	BAGALKOT	220	NARENDRA-SHIGGOAN1(SHIGGOAN)	STATION NOT AFFECTED NARENDRA_220	7:00 (03.01.2024)	19:03 (18.01.2024)	372:03:00	LINE CLEAR AVOIDED
2484	18-Jan-24	BAGALKOT	220	SHIGGOAN- NARENDRA	STATION NOT AFFECTED SHIGGOAN_220	12:28	18:00	05:32	LINE CLEAR AVOIDED
2485	18-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2486	18-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2487	18-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2488	18-Jan-24	BANGALORE	66	ANJANAPURA - BG ROAD	ANJANAPURA	09:30	09:35	00:05	LINE CLEAR AVAILED
2489	18-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2490	18-Jan-24	BANGALORE	66	BAGEPALLI - MITTEMARI 220	BAGEPALLI	16:05	16:10	00:05	LINE CLEAR AVAILED
2491	18-Jan-24	BANGALORE	66	CHIKKABALLAPURA I/A - NALLIMARADANAHALLI	NALLIMARADANAHALLI	16:30	16:53	00:23	TRIPPED ON FAULT
2492	18-Jan-24	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	12:14	12:22	00:08	MAIN SUPPLY FAILURE
2493	18-Jan-24	BANGALORE	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:14	12:22	00:08	MAIN SUPPLY FAILURE
2494	18-Jan-24	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	12:14	12:22	00:08	MAIN SUPPLY FAILURE
2495	18-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	10:12	10:22	00:10	TRIPPED ON FAULT
2496	18-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:30	16:56	00:26	TRIPPED ON FAULT
2497	18-Jan-24	BANGALORE	66	DB PURA 220 - D CROSS 1	D CROSS	11:01	14:33	03:32	LINE CLEAR AVAILED
2498	18-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KUDMALKUNTE	KUDMALKUNTE, TERIYUR, VENKATAPURA	14:10	14:49	00:39	TRIPPED ON FAULT
2499	18-Jan-24	BANGALORE	66	GURUVINAPURA - SOMANAHALLI 220	GURUVINAPURA, BV HALLI	15:10	15:12	00:02	LINE CLEAR AVAILED
2500	18-Jan-24	BANGALORE	66	GURUVINAPURA - TK HALLI 220	GURUVINAPURA, BV HALLI	10:57	11:16	00:19	LINE CLEAR AVAILED
2501	18-Jan-24	BANGALORE	66	HV1	BANASAWADI	22:50	22:57	00:07	LINE CLEAR AVAILED
2502	18-Jan-24	BANGALORE	66	HV1	MEI LAYOUT	10:20	10:23	00:03	LINE CLEAR AVAILED
2503	18-Jan-24	BANGALORE	66	HV1	DIVYASHREE TECH PARK	15:15	15:17	00:02	LINE CLEAR AVAILED
2504	18-Jan-24	BANGALORE	66	HV1	JAYADEVA	19:32	19:48	00:16	TRIPPED ON FAULT
2505	18-Jan-24	BANGALORE	66	HV1	ST JOHNS WOOD	13:12	13:17	00:05	LINE CLEAR AVAILED
2506	18-Jan-24	BANGALORE	66	HV2	MEI LAYOUT	12:10	12:12	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2507	18-Jan-24	BANGALORE	66	HV2	JAYADEVA	12:43	12:50	00:07	LINE CLEAR AVAILED
2508	18-Jan-24	BANGALORE	66	HV2	ST JOHNS WOOD	11:01	11:10	00:09	LINE CLEAR AVAILED
2509	18-Jan-24	BANGALORE	66	HV2	SM MANGALA	13:30	13:45	00:15	LINE CLEAR AVAILED
2510	18-Jan-24	BANGALORE	66	HV2	SUGATUR	10:50	11:10	00:20	TRIPPED ON FAULT
2511	18-Jan-24	BANGALORE	66	HV2	MAASTHI	16:55	17:05	00:10	LINE CLEAR AVAILED
2512	18-Jan-24	BANGALORE	66	HV2	YEDUMADU	23:56	23:59	00:03	TRIPPED ON FAULT
2513	18-Jan-24	BANGALORE	66	HV3	BANASAWADI	22:50	22:57	00:07	LINE CLEAR AVAILED
2514	18-Jan-24	BANGALORE	66	ITI 220 - BANASAWADI	BANASAWADI(HV2)	14:20	14:28	00:08	MAIN SUPPLY FAILURE
2515	18-Jan-24	BANGALORE	66	ITI 220 - DRDO (EHT)	DRDO (EHT)	14:20	14:28	00:08	MAIN SUPPLY FAILURE
2516	18-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2517	18-Jan-24	BANGALORE	66	ITI 220 - NGEF	NGEF, NGEF(EHT)	14:20	14:28	00:08	MAIN SUPPLY FAILURE
2518	18-Jan-24	BANGALORE	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	11:12	16:25	05:13	LINE CLEAR AVAILED
2519	18-Jan-24	BANGALORE	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE HOUSING ORGANISATION	15:02	15:25	00:23	TRIPPED ON FAULT
2520	18-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPETE 1	NO STATION AFFECTED	16:20	23:59	07:39	TRIPPED ON FAULT
2521	18-Jan-24	BANGALORE	66	KOLAR 220 - BANGARPETE 2	BANGARPETE	16:20	17:45	01:25	TRIPPED ON FAULT
2522	18-Jan-24	BANGALORE	66	KONDASAPURA - NTT(EHT)	NTT(EHT)	15:47	15:52	00:05	MAIN SUPPLY FAILURE
2523	18-Jan-24	BANGALORE	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNIPALLI, RAYALPADU	09:51	10:55	01:04	LINE CLEAR AVAILED
2524	18-Jan-24	BANGALORE	66	MAASTHI - MALUR 220	MAASTHI	14:10	15:21	01:11	LINE CLEAR AVAILED
2525	18-Jan-24	BANGALORE	66	MAASTHI - SOLAR(IPP)	NO STATION AFFECTED	12:30	12:38	00:08	LINE CLEAR AVAILED
2526	18-Jan-24	BANGALORE	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	11:45	11:52	00:07	LINE CLEAR AVAILED
2527	18-Jan-24	BANGALORE	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	14:39	14:45	00:06	LINE CLEAR AVAILED
2528	18-Jan-24	BANGALORE	66	RANGANADODDI - SOMANAHALLI 220	RANGANADODDI	06:10	06:15	00:05	MAIN SUPPLY FAILURE
2529	18-Jan-24	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	10:03	15:03	05:00	LINE CLEAR AVAILED
2530	18-Jan-24	BANGALORE	66	ST JOHNS WOOD - ADUGODI	ST JOHNS WOOD	13:12	13:19	00:07	LINE CLEAR AVAILED
2531	18-Jan-24	BANGALORE	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	10:49	10:54	00:05	LINE CLEAR AVAILED
2532	18-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLAPURA I/A 1	CHIKKABALLAPURA I/A	10:13	10:24	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2533	18-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLAPURA I/A 1	CHIKKABALLAPURA I/A	16:30	16:38	00:08	TRIPPED ON FAULT
2534	18-Jan-24	BANGALORE	66	VIDYANAGARA - HENNUR CROSS	NO STATION AFFECTED	06:36	08:31	01:55	TRIPPED ON FAULT
2535	18-Jan-24	BANGALORE	66	YELAHANKA 220 - RAJANUKUNTE	RAJANUKUNTE	17:34	17:49	00:15	TRIPPED ON FAULT
2536	18-Jan-24	BANGALORE	220	HOODY 220 - ITI 220	ITI 220	14:16	14:28	00:12	TRIPPED ON FAULT
2537	18-Jan-24	BANGALORE	220	HV1	CHINTAMNI 220	12:14	12:22	00:08	LINE CLEAR AVAILED
2538	18-Jan-24	BANGALORE	400	NELAMANGALA 400 - GOOTY 400	NO STATION AFFECTED	12:41	14:02	01:21	TRIPPED ON FAULT
2539	18-Jan-24	GULBARGA	66	HV1	ITTAGGI_220	15:14	15:50	00:36	LINE CLEAR AVAILED
2540	18-Jan-24	GULBARGA	66	HV1	TELAGI_66	07:40	07:45	00:05	LINE CLEAR AVAILED
2541	18-Jan-24	GULBARGA	66	HV3	KUDALGI_220	15:14	15:50	00:36	LINE CLEAR AVAILED
2542	18-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI2	SOVENHALLI_66,TBPCL_66	20:10	20:36	00:26	TRIPPED ON FAULT
2543	18-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI2	SOVENHALLI_66	20:10	20:36	00:26	TRIPPED ON FAULT
2544	18-Jan-24	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGLI_66, HOLAGUNDI_66	22:06	22:33	00:27	TRIPPED ON FAULT
2545	18-Jan-24	GULBARGA	66	KUDALGI-KOGALI	KOGALI_66	18:25	18:45	00:20	TRIPPED ON FAULT
2546	18-Jan-24	GULBARGA	110	HV1	KURUGOD_110	13:37	13:42	00:05	TRIPPED ON FAULT
2547	18-Jan-24	GULBARGA	110	HV1	BELLARY NORTH_110	16:25	16:35	00:10	TRIPPED ON FAULT
2548	18-Jan-24	GULBARGA	110	HV1	SOMASAMUNDRA_110	16:25	17:25	01:00	LINE CLEAR AVAILED
2549	18-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	18:55	19:20	00:25	TRIPPED ON FAULT
2550	18-Jan-24	GULBARGA	110	KURUGOD-SUZLON	KURUGOD_110	12:40	14:04	01:24	LINE CLEAR AVAILED
2551	18-Jan-24	GULBARGA	110	M.KOLLUR-DEODURGA LINE-2	M.KOLLUR_110	02:10	02:25	00:15	TRIPPED ON FAULT
2552	18-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	02:50	02:56	00:06	TRIPPED ON FAULT
2553	18-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	19:47	19:57	00:10	TRIPPED ON FAULT
2554	18-Jan-24	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	02:10	02:17	00:07	TRIPPED ON FAULT
2555	18-Jan-24	GULBARGA	110	YADGIR-SHAHPUR	YADGIR_110	02:10	02:17	00:07	TRIPPED ON FAULT
2556	18-Jan-24	GULBARGA	110	YADGIR-SHAHPUR	YADGIR_110	02:50	02:56	00:06	TRIPPED ON FAULT
2557	18-Jan-24	GULBARGA	110	YADGIR-SHAHPUR	YADGIR_110	19:47	19:57	00:10	TRIPPED ON FAULT
2558	18-Jan-24	GULBARGA	220	HV1	KAPNOOR_220	13:19	17:00	03:41	LINE CLEAR AVAILED
2559	18-Jan-24	GULBARGA	220	HV2	KAPNOOR_220	09:58	13:12	03:14	LINE CLEAR AVAILED
2560	18-Jan-24	HASSAN	66	HV1	CHANNARAYAPATNA_66	22:40(18.1.2024)			TRIPPED ON FAULT
2561	18-Jan-24	HASSAN	66	HV1	HARIHARPURA_66	14:05	15:50	01:45	LINE CLEAR AVAILED
2562	18-Jan-24	HASSAN	66	HV2	HALLYMYSORE_66	09:45	13:10	03:25	LINE CLEAR AVAILED
2563	18-Jan-24	HASSAN	66	HV2	HARIHARPURA_66	11:35	14:05	02:30	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2564	18-Jan-24	HASSAN	110	ARSK2-GANDSI	ARSIKERE_220	12:42	12:56	00:14	TRIPPED ON FAULT
2565	18-Jan-24	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	09:55	17:10	07:15	LINE CLEAR AVAILED
2566	18-Jan-24	HASSAN	110	BLGMBA-L1	BELAGUMBA_110	12:42	13:04	00:22	MAIN SUPPLY FAILURE
2567	18-Jan-24	HASSAN	110	HGUNJE-HALADY	HEGGUNJE_220	09:28	17:00	07:32	LINE CLEAR AVAILED
2568	18-Jan-24	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	09:30	15:17	05:47	LINE CLEAR AVAILED
2569	18-Jan-24	HASSAN	110	HV1	JADE_110	16:39	18:46	02:07	LINE CLEAR AVAILED
2570	18-Jan-24	HASSAN	110	HV2	HULICAL_110	09:10	14:50	05:40	LINE CLEAR AVAILED
2571	18-Jan-24	HASSAN	110	HV2	JADE_110	16:39	18:42	02:03	LINE CLEAR AVAILED
2572	18-Jan-24	HASSAN	110	HV2	KULASHEKARA_110	10:15	14:03	03:48	LINE CLEAR AVAILED
2573	18-Jan-24	HASSAN	110	HV3	HIRIYADKA_110	12:00	13:28	01:28	LINE CLEAR AVAILED
2574	18-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2575	18-Jan-24	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	21:04 (17.01.2024)	00:36(18.1.2024)	3:32HRS	LINE CLEAR AVAILED
2576	18-Jan-24	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	11:25	11:33	00:08	TRIPPED ON FAULT
2577	18-Jan-24	HASSAN	220	HV1	gen_varahi	12:42	12:54	00:12	TRIPPED ON FAULT
2578	18-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2579	18-Jan-24	HASSAN	220	VARAHI-SHMG3	gen_varahi	18:29	19:22	00:53	LINE CLEAR AVAILED
2580	18-Jan-24	MYSORE	66	BANNIMANTAP -FTS 2	NO STATIONS EFFECTED	09:28	09:45	00:16	TRIPPED ON FAULT
2581	18-Jan-24	MYSORE	66	FTS-RAJEEVNAGARA	DEVANOORMYS_66RAJEEV NAGARA_66	09:28	09:42	00:13	TRIPPED ON FAULT
2582	18-Jan-24	MYSORE	66	HOOTAGALLI-BANNIMANTAP 1	NO STATIONS EFFECTED	06:38	07:00	00:22	TRIPPED ON FAULT
2583	18-Jan-24	MYSORE	66	HOOTAGALLI-BANNIMANTAP 2	DEVANOORMYS_66RAJEEV NAGARA_66FTS_66BANNIMANTAP_66	06:38	06:58	00:20	TRIPPED ON FAULT
2584	18-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	14:49 (14/012024)	12:19 (18/01/2024)	93:29 HRs	LINE CLEAR AVAILED
2585	18-Jan-24	MYSORE	66	HUNSUR-220HUNSUR 1	NO STATIONS EFFECTED	12:35	14:43	02:08	LINE CLEAR AVAILED
2586	18-Jan-24	MYSORE	66	HUNSUR-220HUNSUR 2	NO STATIONS EFFECTED	14:45	16:21	01:35	LINE CLEAR AVAILED
2587	18-Jan-24	MYSORE	66	HUNSUR-ELWALA	NO STATIONS EFFECTED	16:23	18:13	01:49	LINE CLEAR AVAILED
2588	18-Jan-24	MYSORE	66	HV1	HUNSUR_66	17:40	18:04	00:23	LINE CLEAR AVAILED
2589	18-Jan-24	MYSORE	66	HV1	NANJANGUD_66	12:07	16:08	04:00	LINE CLEAR AVAILED
2590	18-Jan-24	MYSORE	66	HV2	HUNSUR_66	17:04	17:30	00:26	LINE CLEAR AVAILED
2591	18-Jan-24	MYSORE	66	JAKKANAHALLI-NAGMANGALA	GMAILIGERE_66	08:20	08:31	00:10	TRIPPED ON FAULT
2592	18-Jan-24	MYSORE	66	KADAKOLA-HOOTGALLY	NO STATIONS EFFECTED	15:07 (12/01/2024)	8:14 (18/01/2024)	137:06 HRS	TRIPPED ON FAULT
2593	18-Jan-24	MYSORE	66	KR PETE 220-KR PETE 1	KRPETE_66	10:37	17:12	06:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2594	18-Jan-24	MYSORE	66	KR PETE 220-KR PETE 2	NO STATIONS EFFECTED	10:37	17:12	06:34	LINE CLEAR AVAILED
2595	18-Jan-24	MYSORE	66	KR PETE-AKKIHEBBAL1	AKKIHEBBAL_66	10:25	18:10	07:45	LINE CLEAR AVAILED
2596	18-Jan-24	MYSORE	66	KR PETE-AKKIHEBBAL2	NO STATIONS EFFECTED	17:30	18:10	00:39	LINE CLEAR AVAILED
2597	18-Jan-24	MYSORE	66	KR PETE-KIKERI	KIKKERI_66	10:20	18:11	07:51	LINE CLEAR AVAILED
2598	18-Jan-24	MYSORE	66	KUSHALNAGARA 220-RAMANTHAPURA1	KANAGALU_66 ALURSIDDAPRA_66 CBHALLI_66 RUDRAPATNA_66	06:55	07:03	00:07	TRIPPED ON FAULT
2599	18-Jan-24	MYSORE	66	NAGAMANGALA-TUBINKERE 2	NAGAMANGALA_66	17:13	17:44	00:31	LINE CLEAR AVAILED
2600	18-Jan-24	TUMKUR	66	BENKIKERE 220KV-CHANNAGIRI 66	CHANNAGIRI_66,MALLADIHALLI_66,NALLUR_66	15:00	15:56	00:56	LINE CLEAR AVAILED
2601	18-Jan-24	TUMKUR	66	BENKIKERE 220kv-DEVARAHALLI	DEVARAHALLI_66KEREHILACHI66-SANTEBENNUR_66	10:42	16:09	05:27	TRIPPED ON FAULT
2602	18-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR 66	NALLUR_66	00:43	00:55	00:12	TRIPPED ON FAULT
2603	18-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR 66	NALLUR_66	02:16	02:50	00:34	TRIPPED ON FAULT
2604	18-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR 66	NALLUR_66	15:30	15:56	00:26	LINE CLEAR AVAILED
2605	18-Jan-24	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	08:09	08:21	00:12	TRIPPED ON FAULT
2606	18-Jan-24	TUMKUR	66	CHITRADURGA 66kv-CHITRADURGA 1	CHITRADURGA_66	15:59	17:12	01:13	LINE CLEAR AVAILED
2607	18-Jan-24	TUMKUR	66	DAVANGERE SRS - HARIHARAHOSPET_66	HARIHARAHOSPET_66	09:42	10:59	01:17	LINE CLEAR AVAILED
2608	18-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:00	12:55	02:55	LINE CLEAR AVAILED
2609	18-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:55	13:07	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2610	18-Jan-24	TUMKUR	66	DAVANGERE SRS-MAYAKONDA 66	MAYAKONDA_66	11:24	11:48	00:24	LINE CLEAR AVAILED
2611	18-Jan-24	TUMKUR	66	DAVANGERE SRS-MAYAKONDA 66	MAYAKONDA_66	16:54	17:05	00:11	LINE CLEAR AVAILED
2612	18-Jan-24	TUMKUR	66	DAVANGERE220kV-DAVANGERE 66	DAVANAGERE_66	10:00	17:25	07:25	LINE CLEAR AVAILED
2613	18-Jan-24	TUMKUR	66	GUTTUR220-HALASABALU	HALASABALU_66	16:08	16:21	00:13	TRIPPED ON FAULT
2614	18-Jan-24	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHAPURA_66	14:50	16:20	01:30	LINE CLEAR AVAILED
2615	18-Jan-24	TUMKUR	66	HOLALKERE_66-2- RAMGIRI_66	CHIKKAJAJUR_66,	17:48	18:00	00:12	TRIPPED ON FAULT
2616	18-Jan-24	TUMKUR	66	I D HALLI- KODIGENAHALLI	IDHALLY_66	12:20	12:30	00:10	LINE CLEAR AVAILED
2617	18-Jan-24	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	12:50	13:00	00:10	LINE CLEAR AVAILED
2618	18-Jan-24	TUMKUR	66	LOKIKERE66-(SHYAGALE66)KEREBILAC HI66	KEREBILACHI_66,SANTEBE NNUR_66	11:45	11:50	00:05	LINE CLEAR AVAILED
2619	18-Jan-24	TUMKUR	66	LOKIKERE66-(SHYAGALE66)KEREBILAC HI66	KEREBILACHI_66,SANTEBE NNUR_66	16:15	16:20	00:05	LINE CLEAR AVAILED
2620	18-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2621	18-Jan-24	TUMKUR	66	THALLAK 220-PR PURA	PR PURA_66,DYAVARANAHALLI_66,MYLANAHALLI_66	15:15	15:23	00:08	LINE CLEAR AVAILED
2622	18-Jan-24	TUMKUR	66	TR-1&TR-2	IDHALLY_66	12:50	13:00	00:10	LINE CLEAR AVAILED
2623	18-Jan-24	TUMKUR	66	TR-2	GOPPENAHALLI66	17:00(17.01.2024)	14:50(18.01.2024)		LINE CLEAR AVAILED
2624	18-Jan-24	TUMKUR	66	TR-2	GOPPENAHALLI66	17:00(17.01.2024)	14:50(18.01.2024)	21:50	LINE CLEAR AVAILED
2625	18-Jan-24	TUMKUR	66	TR-2	THALLAK_220	15:00	17:45	02:45	LINE CLEAR AVAILED
2626	18-Jan-24	TUMKUR	66	TR-2	GOPPENAHALLI66	15:05	15:30	00:25	LINE CLEAR AVAILED
2627	18-Jan-24	TUMKUR	66	TR-2	HINDASGATTA_66	15:47	15:54	00:07	TRIPPED ON FAULT
2628	18-Jan-24	TUMKUR	66	TR-3	THALLAK_220	10:14	17:37	07:23	LINE CLEAR AVAILED
2629	18-Jan-24	TUMKUR	110	TR-1	K B CROSS_220	15:06	15:09	00:03	LINE CLEAR AVAILED
2630	18-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2631	18-Jan-24	TUMKUR	220	TR-2	THALLAK_220	15:01	17:39	02:38	LINE CLEAR AVAILED
2632	18-Jan-24	TUMKUR	220	TR-3	THALLAK_220	10:15	17:36	07:21	LINE CLEAR AVAILED
2633	19-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	UKKALI_110	03:08	03:15	00:07	TRIPPED ON FAULT
2634	19-Jan-24	BAGALKOT	110	110/11KV, HV1(20MVA)	NAVALAGI_110	08:15	08:20	00:05	TRIPPED ON FAULT
2635	19-Jan-24	BAGALKOT	110	110/11KV. HV-1(20MVA)	GOKAK_110	10:39	10:50	00:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2636	19-Jan-24	BAGALKOT	110	110/33KV.HV-2(10MVA)	MURDESHWAR_110	11:02	12:28	01:26	LINE CLEAR AVAILED
2637	19-Jan-24	BAGALKOT	110	110/33KV.HV-3(10MVA)	MURDESHWAR_110	11:03	12:27	01:24	LINE CLEAR AVAILED
2638	19-Jan-24	BAGALKOT	110	ALBAL-RAY SOLAR	STATION NOT AFFECTED ALBAL_110	21:10 (18.01.2024)	14:30 (19.01.2024)	17:20:00	TRIPPED ON FAULT
2639	19-Jan-24	BAGALKOT	110	ANKOLA- KUMATA2	STATION NOT AFFECTED ANKOLA_110	6:33 (17.01.2024)	11:54 (19.01.2024)	53:21:00	LINE CLEAR AVAILED
2640	19-Jan-24	BAGALKOT	110	ANNIGERI-GADAG	STATION NOT AFFECTED ANNIGERI_110	14:41 (18.01.2024)	12:43 (19.01.2024)	22:02:00	TRIPPED ON FAULT
2641	19-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
2642	19-Jan-24	BAGALKOT	110	ITNAL -RAIBAG	ITNAL_110	12:44 (18.01.2024)	13:30 (19.01.2024)	24:46:00	LINE CLEAR AVAILED
2643	19-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
2644	19-Jan-24	BAGALKOT	110	KUDACHI220- SHIRAGUPPI	STATION NOT AFFECTED KUDACHI_220	10:30	15:35	05:05	LINE CLEAR AVAILED
2645	19-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
2646	19-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
2647	19-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
2648	19-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
2649	19-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
2650	19-Jan-24	BAGALKOT	110	YELLAMMANAWADI- F1(AIGALI)	YELLAMANAWADI_110	18:01 (18.01.2024)			LINE CLEAR AVAILED
2651	19-Jan-24	BAGALKOT	220	BIDNAL- NARENDRA	STATION NOT AFFECTED BIDNAL_220	10:46	14:41	03:55	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2652	19-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
2653	19-Jan-24	BAGALKOT	220	CHIKKODI- AEQUS1(MUGALKHOD1)	STATION NOT AFFECTED CHIKKODI_220	10:01	12:45	02:43	LINE CLEAR AVOIDED
2654	19-Jan-24	BAGALKOT	220	MUGALKHOD- CHIKKODI1	STATION NOT AFFECTED MUGALKHOD_220	10:01	12:44	02:43	LINE CLEAR AVOIDED
2655	19-Jan-24	BAGALKOT	220	NARENDRA- HAVERI1(BIDNAL)	STATION NOT AFFECTED NARENDRA_220	10:46	14:40	03:55	LINE CLEAR AVOIDED
2656	19-Jan-24	BAGALKOT	220	NARENDRA- SHIGGOAN1(SHIGGOAN)	STATION NOT AFFECTED NARENDRA_220	19:03 (18.01.2024)	14:24 (19.01.2024)	19:03:00	TRIPPED ON FAULT
2657	19-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2658	19-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
2659	19-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
2660	19-Jan-24	BANGALORE	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	06:35	06:45	00:10	LINE CLEAR AVOIDED
2661	19-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2662	19-Jan-24	BANGALORE	66	BANGARPET - T GOLLAHALLI 220	BANGARPET	17:55	18:00	00:05	LINE CLEAR AVOIDED
2663	19-Jan-24	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	16:42	17:00	00:18	TRIPPED ON FAULT
2664	19-Jan-24	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	18:04	18:56	00:52	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2665	19-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI, NANDI	13:35	14:30	00:55	LINE CLEAR AVAILED
2666	19-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI, NANDI	17:00	18:58	01:58	LINE CLEAR AVAILED
2667	19-Jan-24	BANGALORE	66	EMBASSY TECH PARK - VIKAS TECH PARK 220	EMBASSY TECH PARK	07:31	07:56	00:25	MAIN SUPPLY FAILURE
2668	19-Jan-24	BANGALORE	66	EMBASSY TECH PARK - VIKAS TECH PARK 220	EMBASSY TECH PARK	08:23	08:26	00:03	MAIN SUPPLY FAILURE
2669	19-Jan-24	BANGALORE	66	EMBASSY TECH PARK - VIKAS TECH PARK 220	EMBASSY TECH PARK	12:12	12:15	00:03	MAIN SUPPLY FAILURE
2670	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	16:00	16:16	00:16	MAIN SUPPLY FAILURE
2671	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	17:29	17:32	00:03	LINE CLEAR AVAILED
2672	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	16:00	16:16	00:16	MAIN SUPPLY FAILURE
2673	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	17:29	17:32	00:03	LINE CLEAR AVAILED
2674	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	16:00	16:16	00:16	MAIN SUPPLY FAILURE
2675	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	17:29	17:32	00:03	LINE CLEAR AVAILED
2676	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KUDMALKUNTE	KUDMALKUNTE	16:00	16:16	00:16	MAIN SUPPLY FAILURE
2677	19-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KUDMALKUNTE	KUDMALKUNTE	17:29	17:32	00:03	LINE CLEAR AVAILED
2678	19-Jan-24	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	11:31	11:37	00:06	LINE CLEAR AVAILED
2679	19-Jan-24	BANGALORE	66	HV1	BANASAWADI	01:07	01:12	00:05	LINE CLEAR AVAILED
2680	19-Jan-24	BANGALORE	66	HV1	SARAKKI	10:11	17:41	07:30	LINE CLEAR AVAILED
2681	19-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	14:40	14:42	00:02	LINE CLEAR AVAILED
2682	19-Jan-24	BANGALORE	66	HV1	KYASAMBALLI	16:30	18:20	01:50	LINE CLEAR AVAILED
2683	19-Jan-24	BANGALORE	66	HV2	SARAKKI	10:11	17:00	06:49	LINE CLEAR AVAILED
2684	19-Jan-24	BANGALORE	66	HV2	HULLENAHALLI	17:18	17:26	00:08	TRIPPED ON FAULT
2685	19-Jan-24	BANGALORE	66	HV2	KUMBARANAHALLI	07:22	07:27	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2686	19-Jan-24	BANGALORE	66	HV3	BANASAWADI	01:07	01:12	00:05	LINE CLEAR AVAILED
2687	19-Jan-24	BANGALORE	66	HV3	SARAKKI	11:44	17:26	05:42	LINE CLEAR AVAILED
2688	19-Jan-24	BANGALORE	66	ITI 220 - HOODY 66	NO STATION AFFECTED	00:00	00:31	00:31	TRIPPED ON FAULT
2689	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	17:42	18:10	00:28	MAIN SUPPLY FAILURE
2690	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - KUNUR	KUNUR, HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALALLI	17:42	18:10	00:28	MAIN SUPPLY FAILURE
2691	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARANAHALLI, CHIKKENAHALLI	17:42	18:12	00:30	MAIN SUPPLY FAILURE
2692	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	MARALWADI, GODURU	17:42	18:13	00:31	MAIN SUPPLY FAILURE
2693	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - TK HALLI 2	SHIVANAHALLI DAIRY, DODDALAHALLI	17:42	18:18	00:36	MAIN SUPPLY FAILURE
2694	19-Jan-24	BANGALORE	66	KANAKAPURA 220 - TK HALLI 3	HONNIGANAHALLI, ACHALU, HALAGURU	17:42	18:13	00:31	MAIN SUPPLY FAILURE
2695	19-Jan-24	BANGALORE	66	NARASAPURA - WISTRON(EHT)	WISTRON(EHT)	14:10	17:50	03:40	LINE CLEAR AVAILED
2696	19-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	07:33	08:02	00:29	MAIN SUPPLY FAILURE
2697	19-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	12:12	12:16	00:04	LINE CLEAR AVAILED
2698	19-Jan-24	BANGALORE	66	SARAKKI - JAYADEVA 1& 2	SARAKKI	11:45	16:49	05:04	LINE CLEAR AVAILED
2699	19-Jan-24	BANGALORE	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	11:07	11:15	00:08	LINE CLEAR AVAILED
2700	19-Jan-24	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	07:03	07:15	00:12	TRIPPED ON FAULT
2701	19-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLAPURA I/A	CHIKKABALLAPURA I/A	13:37	14:15	00:38	LINE CLEAR AVAILED
2702	19-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLAPURA I/A	CHIKKABALLAPURA I/A	16:40	17:00	00:20	TRIPPED ON FAULT
2703	19-Jan-24	BANGALORE	66	TUBAGERE - CHIKKABALLAPURA I/A	CHIKKABALLAPURA I/A	18:04	18:55	00:51	LINE CLEAR AVAILED
2704	19-Jan-24	BANGALORE	66	VIDYANAGAR - HENNUR CROSS	NO STATION AFFECTED	06:25	09:02	02:37	TRIPPED ON FAULT
2705	19-Jan-24	BANGALORE	220	HV2	EXORA 220(NO LOAD AFFECTED)	07:31	08:48	01:17	TRIPPED ON FAULT
2706	19-Jan-24	BANGALORE	220	HV2	VIKAS TECH PARK 220	07:33	08:02	00:29	TRIPPED ON FAULT
2707	19-Jan-24	BANGALORE	220	HV3	GOWRIBIDANUR 220	15:55	17:30	01:35	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2708	19-Jan-24	BANGALORE	220	JIGANI 220 - YARANDANAHALLI 2	NO STATION AFFECTED	15:25	15:42	00:17	LINE CLEAR AVOIDED
2709	19-Jan-24	BANGALORE	220	KIADB HAROHALLI I/A 220 - KANAKAPURA 220	KANAKAPURA 220	17:42	18:10	00:28	LINE CLEAR AVOIDED
2710	19-Jan-24	BANGALORE	400	NELAMANGALA 400 - TALAGUPPA 400	NO STATION AFFECTED	13:10	15:06	01:56	TRIPPED ON FAULT
2711	19-Jan-24	GULBARGA	66	HV1	NEELAGUNDA_220	02:55	03:00	00:05	TRIPPED ON FAULT
2712	19-Jan-24	GULBARGA	66	ITTAGGI-HIREHADAGALLI1	GIRIYAPURA_66,MAGALA_66	18:44	18:54	00:10	TRIPPED ON FAULT
2713	19-Jan-24	GULBARGA	66	UCCHANGIDURGA-KOTTUR	UJJANI_66	12:25	13:35	01:10	LINE CLEAR AVOIDED
2714	19-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	10:30	10:55	00:25	TRIPPED ON FAULT
2715	19-Jan-24	GULBARGA	110	HV2	KALBURGI WEST_110	16:34	16:44	00:10	TRIPPED ON FAULT
2716	19-Jan-24	GULBARGA	110	KALBURGI WEST TO KAPNOOR	KALBURGI WEST_110	15:45	18:30	02:45	LINE CLEAR AVOIDED
2717	19-Jan-24	GULBARGA	110	LINGASUGUR-GURGUNTA	GURGUNTA_110	01:18	01:47	00:29	TRIPPED ON FAULT
2718	19-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	00:40	00:50	00:10	TRIPPED ON FAULT
2719	19-Jan-24	GULBARGA	110	SHAHAPUR-NAGNOOR	NAGANOOR_110,KEMBHAVI_110,HUNSAGI_110,ASKI_110	16:11	18:26	02:15	TRIPPED ON FAULT
2720	19-Jan-24	HASSAN	66	HV1	CHANNARAYAPATNA_66	22:40(18.1.2024)	10:54 (20.1.2024)		LINE CLEAR AVOIDED
2721	19-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	17:02	17:48	00:46	LINE CLEAR AVOIDED
2722	19-Jan-24	HASSAN	66	UDDURKO-SUZLON1	UDDURKOPLU_66	10:15	12:47	02:32	LINE CLEAR AVOIDED
2723	19-Jan-24	HASSAN	66	UDDURKO-SUZLON2	UDDURKOPLU_66	10:15	12:49	02:34	LINE CLEAR AVOIDED
2724	19-Jan-24	HASSAN	110	GURUVA-EMAR1	GURUVAYANKERE_110	09:39	09:42	00:03	LINE CLEAR AVOIDED
2725	19-Jan-24	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	11:23	11:36	00:13	LINE CLEAR AVOIDED
2726	19-Jan-24	HASSAN	110	HV	PUTTUR_220	09:53	12:50	02:57	LINE CLEAR AVOIDED
2727	19-Jan-24	HASSAN	110	HV1	KADUR_220	14:23	14:49	00:26	MAIN SUPPLY FAILURE
2728	19-Jan-24	HASSAN	110	HV2	KADUR_220	14:23	14:49	00:26	MAIN SUPPLY FAILURE
2729	19-Jan-24	HASSAN	110	HV2	HOSANGADI_110	10:30	12:55	02:25	LINE CLEAR AVOIDED
2730	19-Jan-24	HASSAN	110	HV2	KULASHEKARA_110	10:27	13:54	03:27	LINE CLEAR AVOIDED
2731	19-Jan-24	HASSAN	110	HV3	KADUR_220	14:23	14:49	00:26	MAIN SUPPLY FAILURE
2732	19-Jan-24	HASSAN	110	KADUR-AJAMPURA	KADUR_220	14:23	15:17	00:54	MAIN SUPPLY FAILURE
2733	19-Jan-24	HASSAN	110	KADUR-NAGENAHALLY	KADUR_220	14:23	15:26	01:03	MAIN SUPPLY FAILURE
2734	19-Jan-24	HASSAN	110	KADUR-NERELEKERE	KADUR_220	14:23	15:12	00:49	MAIN SUPPLY FAILURE
2735	19-Jan-24	HASSAN	110	KADUR-RAILWAY	KADUR_220	14:23	14:51	00:28	MAIN SUPPLY FAILURE
2736	19-Jan-24	HASSAN	110	KADUR-TNGL	KADUR_220	14:23	15:21	00:58	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2737	19-Jan-24	HASSAN	110	KADUR-YGTI	KADUR_220	14:23	15:20	00:57	MAIN SUPPLY FAILURE
2738	19-Jan-24	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	09:39	09:42	00:03	LINE CLEAR AVAILED
2739	19-Jan-24	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:23	11:36	00:13	LINE CLEAR AVAILED
2740	19-Jan-24	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:56	13:25	02:29	LINE CLEAR AVAILED
2741	19-Jan-24	HASSAN	110	LV1	KEMAR_220	12:24	13:55	01:31	LINE CLEAR AVAILED
2742	19-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2743	19-Jan-24	HASSAN	110	SHRLKPSORAB	SHIRALKOPPA_220	15:46	16:07	00:21	TRIPPED ON FAULT
2744	19-Jan-24	HASSAN	220	HASSN22-Shomoga	HASSaN_220	01:06	01:37	00:31	TRIPPED ON FAULT
2745	19-Jan-24	HASSAN	220	HV1	KEMAR_220	12:24	13:55	01:31	LINE CLEAR AVAILED
2746	19-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)			LINE CLEAR AVAILED
2747	19-Jan-24	HASSAN	220	KADUR-SHIMOGA	KADUR_220	14:23	16:08	01:45	TRIPPED ON FAULT
2748	19-Jan-24	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	14:23	16:09	01:46	TRIPPED ON FAULT
2749	19-Jan-24	MYSORE	66	HV1	BGPURA_66	14:36	15:47	01:10	LINE CLEAR AVAILED
2750	19-Jan-24	MYSORE	66	HV1	BOOKANAKERE_66	09:59	18:09	08:09	LINE CLEAR AVAILED
2751	19-Jan-24	MYSORE	66	HV1	CHINAKURALI_66	10:00	15:20	05:20	LINE CLEAR AVAILED
2752	19-Jan-24	MYSORE	66	HV1	HALAGUR_66	17:41	18:14	00:33	MAIN SUPPLY FAILURE
2753	19-Jan-24	MYSORE	66	HV1	MAMBALLI_66	09:05	09:45	00:40	TRIPPED ON FAULT
2754	19-Jan-24	MYSORE	66	HV1	MEGALAPURA_66	12:25	12:45	00:20	LINE CLEAR AVAILED
2755	19-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	18:08	18:30	00:21	LINE CLEAR AVAILED
2756	19-Jan-24	MYSORE	66	HV2	BGPURA_66	10:48	13:02	02:14	LINE CLEAR AVAILED
2757	19-Jan-24	MYSORE	66	HV2	BOOKANAKERE_66	09:59	18:09	08:09	LINE CLEAR AVAILED
2758	19-Jan-24	MYSORE	66	HV2	CHINAKURALI_66	10:00	15:20	05:20	LINE CLEAR AVAILED
2759	19-Jan-24	MYSORE	66	HV2	HALAGUR_66	17:41	18:14	00:33	MAIN SUPPLY FAILURE
2760	19-Jan-24	MYSORE	66	HV2	MEGALAPURA_66	12:46	13:48	01:02	LINE CLEAR AVAILED
2761	19-Jan-24	MYSORE	66	HV2	THUMBLA_66	14:20	15:45	01:25	LINE CLEAR AVAILED
2762	19-Jan-24	MYSORE	66	HV3	KIKKERI_66	14:30	14:36	00:06	LINE CLEAR AVAILED
2763	19-Jan-24	MYSORE	66	HV3	KIKKERI_66	15:49	15:54	00:04	LINE CLEAR AVAILED
2764	19-Jan-24	MYSORE	66	HV3	KRPET_66	18:45	19:35	00:50	LINE CLEAR AVAILED
2765	19-Jan-24	MYSORE	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66	12:01	15:52	03:51	LINE CLEAR AVAILED
2766	19-Jan-24	MYSORE	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KRPET_66	10:54	11:45	00:51	LINE CLEAR AVAILED
2767	19-Jan-24	MYSORE	66	KR PETE 220-KR PETE 2	AKKIHEBBAL_66 KRPET_66	10:54	11:45	00:51	LINE CLEAR AVAILED
2768	19-Jan-24	MYSORE	66	KR PETE-KIKKERI	NO STATIONS EFFECTED	10:31	12:40	02:08	LINE CLEAR AVAILED
2769	19-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	04:09	04:13	00:04	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2770	19-Jan-24	MYSORE	66	MADIKERI-SUNTTIKOPA	NO STATIONS EFFECTED	09:45	12:29	02:44	LINE CLEAR AVAILED
2771	19-Jan-24	MYSORE	66	NAGAMANGALA 220-BG NAGARA	ADICHUNCHANAGIRI_66 BGNAGARA_66 KADABALLY_66 VADERALLI_66	07:01	07:07	00:06	TRIPPED ON FAULT
2772	19-Jan-24	MYSORE	66	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	10:25	17:09	06:44	LINE CLEAR AVAILED
2773	19-Jan-24	MYSORE	66	NAGAMANGALA 220-HARADANAHALLI(JAK)	HARADANAHALLI(JAK)_66	09:18	09:23	00:05	TRIPPED ON FAULT
2774	19-Jan-24	MYSORE	66	NAGAMANGALA - TUBINAKERE 2	NAGAMANGALA_66	18:09	18:30	00:20	LINE CLEAR AVAILED
2775	19-Jan-24	MYSORE	66	TUBINKERE-JAKKANAHALLI	NO STATIONS EFFECTED	11:50	13:20	01:30	LINE CLEAR AVAILED
2776	19-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66	06:24	06:56	00:32	TRIPPED ON FAULT
2777	19-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:33	17:16	06:43	LINE CLEAR AVAILED
2778	19-Jan-24	TUMKUR	66	BENKIKERE 220KV MALLADIHALLI66	MALLADIHALLI66	14:40	14:49	00:09	LINE CLEAR AVAILED
2779	19-Jan-24	TUMKUR	66	BENKIKERE 220KV-NALLUR 66	NALLUR_66	14:23	14:36	00:13	TRIPPED ON FAULT
2780	19-Jan-24	TUMKUR	66	BILCHODU- BADALADAKU	BILCHODU_66,PALLAGATT E_66,SOKKE_66	12:25	13:35	01:10	LINE CLEAR AVAILED
2781	19-Jan-24	TUMKUR	66	BILCHODU- UCHANGIDURGA	BILCHODU_66	14:00	14:05	00:05	LINE CLEAR AVAILED
2782	19-Jan-24	TUMKUR	66	CHITRADURGA 220kv-MALAPANAHALLI_66	MALAPANAHALLI_66	14:00	14:10	00:10	LINE CLEAR AVAILED
2783	19-Jan-24	TUMKUR	66	DASUDI-SRS HIRIYUR_220	DASUDI_66	07:00	07:25	00:25	MAIN SUPPLY FAILURE
2784	19-Jan-24	TUMKUR	66	DAVANGERE SRS-HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:10	11:17	00:07	LINE CLEAR AVAILED
2785	19-Jan-24	TUMKUR	66	GARAGA66-MATHOD_66	GARAGA_66,PANCHANAHA LLI_66	07:00	07:40	00:40	MAIN SUPPLY FAILURE
2786	19-Jan-24	TUMKUR	66	GARAGA66-MATHOD_66	GARAGA_66,PANCHANAHA LLI_66	09:10	09:15	00:05	MAIN SUPPLY FAILURE
2787	19-Jan-24	TUMKUR	66	GARAGA66-MATHOD_66	GARAGA_66,PANCHANAHA LLI_66	18:10	18:40	00:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2788	19-Jan-24	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66,P.D.KOTE_66	06:55	07:35	00:40	TRIPPED ON FAULT
2789	19-Jan-24	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66,P.R.PURA., KAMARAHALLY_66	06:55	07:35	00:40	TRIPPED ON FAULT
2790	19-Jan-24	TUMKUR	66	HIRIYUR 220KV-BARAMAGIRI	BARAMAGIRI_66,MATHOD	06:55	18:15	11:20	MAIN SUPPLY FAILURE
2791	19-Jan-24	TUMKUR	66	HIRIYUR 220KV- MATHOD 1	MATHOD_66	06:59			LINE CLEAR AVAILED
2792	19-Jan-24	TUMKUR	66	HIRIYUR 220KV- MATHOD 2	MATHOD_66	06:59	18:24	11:25	LINE CLEAR AVAILED
2793	19-Jan-24	TUMKUR	66	HIRIYUR 220KV-RANGANATHPURA	RANGANATHPURA_66	06:55	07:35	00:40	LINE CLEAR AVAILED
2794	19-Jan-24	TUMKUR	66	HIRIYUR 220KV- THALLAK 66	THALLAKK_66	06:55	07:35	00:40	LINE CLEAR AVAILED
2795	19-Jan-24	TUMKUR	66	HIRIYUR 220KV-SIRA(HIRIYUR)	HIRIYUR_66	06:55	07:35	00:40	LINE CLEAR AVAILED
2796	19-Jan-24	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	06:55	07:35	00:40	LINE CLEAR AVAILED
2797	19-Jan-24	TUMKUR	66	HIRIYUR220kV-P R PURA	PRPURA_66,HARIYABBE_66 ,PDKOTE_66	06:55	07:35	00:40	LINE CLEAR AVAILED
2798	19-Jan-24	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	05:35	05:41	00:06	TRIPPED ON FAULT
2799	19-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2800	19-Jan-24	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	12:25	13:35	01:10	LINE CLEAR AVAILED
2801	19-Jan-24	TUMKUR	66	SOKKE-UJJINI_66	SOKKE_66	12:25	13:35	01:10	LINE CLEAR AVAILED
2802	19-Jan-24	TUMKUR	66	THALLAK 220kV- P R PURA	PR PURA_66	17:53	17:58	00:05	LINE CLEAR AVAILED
2803	19-Jan-24	TUMKUR	66	TR-1	KATTIGE_66	13:25	13:30	00:05	TRIPPED ON FAULT
2804	19-Jan-24	TUMKUR	66	TR-1	KORA_66,	15:10	15:35	00:25	LINE CLEAR AVAILED
2805	19-Jan-24	TUMKUR	66	TR-1&TR-2	MALAPANAHALLI_66	11:15	11:45	00:30	LINE CLEAR AVAILED
2806	19-Jan-24	TUMKUR	66	TR-1(LV SIDE)	HIRIYUR_220	06:59	07:20	00:21	TRIPPED ON FAULT
2807	19-Jan-24	TUMKUR	66	TR-2	KORA_66,	11:05	12:35	01:30	LINE CLEAR AVAILED
2808	19-Jan-24	TUMKUR	66	TR-3	KORA_66,	14:35	15:05	00:30	LINE CLEAR AVAILED
2809	19-Jan-24	TUMKUR	66	TR-3(LV SIDE)	HIRIYUR_220	06:59	07:20	00:21	TRIPPED ON FAULT
2810	19-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2811	19-Jan-24	TUMKUR	220	TR-1(HV SIDE)	HIRIYUR_220	06:59	07:20	00:21	TRIPPED ON FAULT
2812	19-Jan-24	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	06:59	07:20	00:21	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2813	20-Jan-24	BAGALKOT	110	110/11KV, HV3 (10MVA)	STATION NOT AFFECTED BIJAPUR CITY_110	08:46	08:56	00:10	TRIPPED ON FAULT
2814	20-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	MALGHAN(S)_110	9:10 (19.01.2024)	11:25 (20.01.2024)	26:15:00	LINE CLEAR AVAILED
2815	20-Jan-24	BAGALKOT	110	110/33KV, HV1(20MVA)	STATION NOT AFFECTED HUBLI_220	10:16	10:18	00:02	LINE CLEAR AVAILED
2816	20-Jan-24	BAGALKOT	110	110/33KV, HV2(20MVA)	STATION NOT AFFECTED HUBLI_220	10:15	10:16	00:01	LINE CLEAR AVAILED
2817	20-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	MUNDARAGI_110	12:30	15:12	02:42	LINE CLEAR AVAILED
2818	20-Jan-24	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED HUBLI_220	09:48	09:51	00:03	LINE CLEAR AVAILED
2819	20-Jan-24	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED NARENDRA_220	16:40	16:55	00:15	LINE CLEAR AVAILED
2820	20-Jan-24	BAGALKOT	110	220/110KV, LV3	STATION NOT AFFECTED HUBLI_220	10:37	13:13	02:36	LINE CLEAR AVAILED
2821	20-Jan-24	BAGALKOT	110	BENAKATTI(BGM)- F2(YARAGATTI)	BENAKATTI(BGM)_110	08:38	08:43	00:05	LINE CLEAR AVAILED
2822	20-Jan-24	BAGALKOT	110	GOPANAKOPPA- MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
2823	20-Jan-24	BAGALKOT	110	HUBLI220- ANAND NAGAR	STATION NOT AFFECTED HUBLI_220	10:00	10:01	00:01	LINE CLEAR AVAILED
2824	20-Jan-24	BAGALKOT	110	HUBLI220- PH COMPOUND	STATION NOT AFFECTED HUBLI_220	09:54	09:55	00:01	LINE CLEAR AVAILED
2825	20-Jan-24	BAGALKOT	110	HUBLI220- SIRSI(KALGHATAGI)	STATION NOT AFFECTED HUBLI_220	10:07	10:08	00:01	LINE CLEAR AVAILED
2826	20-Jan-24	BAGALKOT	110	HUBLI220- TARIHAL1	STATION NOT AFFECTED HUBLI_220	10:02	10:04	00:02	LINE CLEAR AVAILED
2827	20-Jan-24	BAGALKOT	110	HUBLI220- TARIHAL2	STATION NOT AFFECTED HUBLI_220	10:04	10:05	00:01	LINE CLEAR AVAILED
2828	20-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2829	20-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
2830	20-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
2831	20-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
2832	20-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
2833	20-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVOIDED
2834	20-Jan-24	BAGALKOT	110	SOUDATTI220- BENAKATTI	SOUDATTI_220, BENAKATTI_110, KATKOL_110, ITANAL_110, MUGALIHAI_110, YARGATTI_110	07:58	08:36	00:38	TRIPPED ON FAULT
2835	20-Jan-24	BAGALKOT	110	UDYAMBAG-MACHE	UDYAMBAG_110	13:40 (08.01.2024)	16:16 (20.01.2024)	290:36:00	LINE CLEAR AVOIDED
2836	20-Jan-24	BAGALKOT	110	YELLAMMANAWADI- F1(AIGALI)	YELLAMANAWADI_110	18:01 (18.01.2024)	17:31 (20.01.2024)	47:30:00	LINE CLEAR AVOIDED
2837	20-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED NARENDRA_220	10:45	16:45	06:00	LINE CLEAR AVOIDED
2838	20-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED NARENDRA_220	16:40	16:51	00:11	LINE CLEAR AVOIDED
2839	20-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED HUBLI_220	09:48	09:51	00:03	LINE CLEAR AVOIDED
2840	20-Jan-24	BAGALKOT	220	220/110KV, HV3	STATION NOT AFFECTED HUBLI_220	10:32	13:13	02:41	LINE CLEAR AVOIDED
2841	20-Jan-24	BAGALKOT	220	AMBEWADI- PONDA1	STATION NOT AFFECTED AMBEWADI_220	8:45 (20.01.2024)			LINE CLEAR AVOIDED
2842	20-Jan-24	BAGALKOT	220	AMBEWADI- PONDA2	STATION NOT AFFECTED AMBEWADI_220	8:43 (20.01.2024)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2843	20-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
2844	20-Jan-24	BAGALKOT	220	CHIKKODI- AEQUS1(MUGALKHOD2)	STATION NOT AFFECTED CHIKKODI_220	09:44	12:06	02:22	LINE CLEAR AVAILED
2845	20-Jan-24	BAGALKOT	220	KUDACHI- MAHALINGAPUR2 (MAHALINGAPUR)	STATION NOT AFFECTED KUDACHI_220	12:51	17:12	04:21	LINE CLEAR AVAILED
2846	20-Jan-24	BAGALKOT	220	MUGALKHOD- CHIKKODI2	STATION NOT AFFECTED MUGALKHOD_220	09:44	12:06	02:22	LINE CLEAR AVAILED
2847	20-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2848	20-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
2849	20-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
2850	20-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
2851	20-Jan-24	BANGALORE	66	BURUDAGUNTE - GANJIGUNTE	BURUDAGUNTE, IRAGAMPALLI, M GOLLAHALLI	18:11	18:16	00:05	LINE CLEAR AVAILED
2852	20-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE	13:49	14:07	00:18	TRIPPED ON FAULT
2853	20-Jan-24	BANGALORE	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	11:13	11:53	00:40	TRIPPED ON FAULT
2854	20-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	12:04	12:07	00:03	LINE CLEAR AVAILED
2855	20-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	16:43	16:46	00:03	LINE CLEAR AVAILED
2856	20-Jan-24	BANGALORE	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA	11:24	11:30	00:06	LINE CLEAR AVAILED
2857	20-Jan-24	BANGALORE	66	HV1	BANASAWADI	02:23	02:41	00:18	LINE CLEAR AVAILED
2858	20-Jan-24	BANGALORE	66	HV1	BANASAWADI	06:57	07:00	00:03	LINE CLEAR AVAILED
2859	20-Jan-24	BANGALORE	66	HV1	PRESTIGE SHANTINIKETHAN	09:00	13:05	04:05	LINE CLEAR AVAILED
2860	20-Jan-24	BANGALORE	66	HV1	JAYADEVA	10:14	15:21	05:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2861	20-Jan-24	BANGALORE	66	HV1	NAGANATHPURA 220	10:03	10:08	00:05	LINE CLEAR AVAILED
2862	20-Jan-24	BANGALORE	66	HV1	GOWRIBIDANUR 220	09:05	09:10	00:05	TRIPPED ON FAULT
2863	20-Jan-24	BANGALORE	66	HV1	VIDURASHWATHA	14:30	14:40	00:10	TRIPPED ON FAULT
2864	20-Jan-24	BANGALORE	66	HV1	CHATRA	18:44	18:49	00:05	TRIPPED ON FAULT
2865	20-Jan-24	BANGALORE	66	HV2	JAYADEVA	11:12	15:40	04:28	LINE CLEAR AVAILED
2866	20-Jan-24	BANGALORE	66	HV2	NAGANATHPURA 220	13:26	13:27	00:01	LINE CLEAR AVAILED
2867	20-Jan-24	BANGALORE	66	HV2	HULLENAHALLI	16:28	16:33	00:05	TRIPPED ON FAULT
2868	20-Jan-24	BANGALORE	66	HV2	HULLENAHALLI	18:10	20:30	02:20	TRIPPED ON FAULT
2869	20-Jan-24	BANGALORE	66	HV3	BANASAWADI	02:23	02:41	00:18	LINE CLEAR AVAILED
2870	20-Jan-24	BANGALORE	66	HV3	BANASAWADI	06:57	07:00	00:03	LINE CLEAR AVAILED
2871	20-Jan-24	BANGALORE	66	HV3	NAGANATHPURA 220	14:44	14:52	00:08	LINE CLEAR AVAILED
2872	20-Jan-24	BANGALORE	66	JAYANAGAR - NATIONAL COLLEGE	JAYANAGAR	16:37	16:40	00:03	LINE CLEAR AVAILED
2873	20-Jan-24	BANGALORE	66	JAYANAGAR - NIMHANS 220	JAYADEVA	11:52	15:02	03:10	LINE CLEAR AVAILED
2874	20-Jan-24	BANGALORE	66	KIADB HAROHALLI I/A 220 - VR DODDI	VR DODDI	11:10	16:45	05:35	LINE CLEAR AVAILED
2875	20-Jan-24	BANGALORE	66	KOLAR 220 - PGCIL AUX	PGCIL AUX, SUGUTUR, SM MANGALA	23:33	23:41	00:08	TRIPPED ON FAULT
2876	20-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	15:22	15:28	00:06	LINE CLEAR AVAILED
2877	20-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	16:16	16:28	00:12	LINE CLEAR AVAILED
2878	20-Jan-24	BANGALORE	66	SARAKKI - JAYADEVA 1 & 2	SARAKKI	11:35	11:40	00:05	LINE CLEAR AVAILED
2879	20-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - BRIGADE CORNERSTONE UTOPIA	BRIGADE CORNERSTONE UTOPIA	14:31	15:02	00:31	MAIN SUPPLY FAILURE
2880	20-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - SHOBHA DREAMS 66	DIVYASHREE TECH PARK, MINOR IRRIGATION, KACHAMARANAHALLI, PRESTIGE LAKESIDE HABITAT, SHOBHA DREAMS 66	14:31	15:02	00:31	MAIN SUPPLY FAILURE
2881	20-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - SORAHUNASE	SORAHUNASE	14:31	15:02	00:31	MAIN SUPPLY FAILURE
2882	20-Jan-24	BANGALORE	66	SHOBHA INDRAPRASTHA - A STATION 220	SHOBHA INDRAPRASHTA	15:35	15:38	00:03	LINE CLEAR AVAILED
2883	20-Jan-24	BANGALORE	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, ANJANAPURA	07:22	07:35	00:13	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2884	20-Jan-24	BANGALORE	66	T BEGUR - AVERAHALLI	T BEGUR	12:02	13:00	00:58	LINE CLEAR AVAILED
2885	20-Jan-24	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	BV HALLI, GURUVINAPURA	11:06	14:16	03:10	LINE CLEAR AVAILED
2886	20-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL	PRIMAL	10:30	10:35	00:05	LINE CLEAR AVAILED
2887	20-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL	PRIMAL	13:50	13:52	00:02	LINE CLEAR AVAILED
2888	20-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	15:22	15:28	00:06	LINE CLEAR AVAILED
2889	20-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:16	16:28	00:12	LINE CLEAR AVAILED
2890	20-Jan-24	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	15:22	15:24	00:02	LINE CLEAR AVAILED
2891	20-Jan-24	BANGALORE	66	YELAHANKA 220 - SOLADEVANAHALLI	SOLADEVANAHALLI	11:56	12:16	00:20	TRIPPED ON FAULT
2892	20-Jan-24	BANGALORE	220	HOODY 400 - SHOBHA DREAMS 220	SHOBHA DREAMS 220	14:31	15:02	00:31	TRIPPED ON FAULT
2893	20-Jan-24	BANGALORE	220	SHOBHA DREAMS 220 - HOODY 400	SHOBHA DREAMS 220	14:31	15:02	00:31	TRIPPED ON FAULT
2894	20-Jan-24	BANGALORE	220	SHOBHA DREAMS 220 - SOMANAHALLI 220	SHOBHA DREAMS 220	14:31	15:02	00:31	TRIPPED ON FAULT
2895	20-Jan-24	BANGALORE	220	SOMANAHALLI 220 - SHOBHA DREAMS 220	SHOBHA DREAMS 220	14:31	15:02	00:31	TRIPPED ON FAULT
2896	#####	GULBARGA	66	BENAVEKAL-AVADA SOLAR_IPP	BENAVEKAL_66	13:05	14:25	01:20	LINE CLEAR AVAILED
2897	#####	GULBARGA	66	BENAVEKAL-BADALADKU	BENAVEKAL_66,AVADA SOLAR_IPP	12:15	12:50	00:35	LINE CLEAR AVAILED
2898	#####	GULBARGA	66	HIREHADAGALLI-GIRIYAPUR	GIRIYAPURA_66,MAGALA_66	04:24	04:30	00:06	TRIPPED ON FAULT
2899	#####	GULBARGA	66	HV2	GUDEKOTE_66	16:25	16:30	00:05	MAIN SUPPLY FAILURE
2900	#####	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66	04:24	04:35	00:11	TRIPPED ON FAULT
2901	#####	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66	11:00	12:19	01:19	LINE CLEAR AVAILED
2902	#####	GULBARGA	66	ITTAGI-HIREHADAGALI LINE 2	SOVENHALLI_66	19:47	20:09	00:22	TRIPPED ON FAULT
2903	#####	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:32	19:45	00:13	TRIPPED ON FAULT
2904	#####	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	19:47	19:59	00:12	TRIPPED ON FAULT
2905	#####	GULBARGA	66	KUDLIGI-CHORNOOR	CHORNOOR_66	16:50	17:50	01:00	MAIN SUPPLY FAILURE
2906	#####	GULBARGA	66	KUDLIGI-HANSI	HANSI_66	16:50	17:45	00:55	MAIN SUPPLY FAILURE
2907	#####	GULBARGA	66	KUDLIGI-KUDLIGI	KUDLIGI_66,KOGLI_66	16:50	17:20	00:30	MAIN SUPPLY FAILURE
2908	#####	GULBARGA	110	HV1	YARDONA_110	09:55	10:05	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2909	#####	GULBARGA	110	KAPNOOR-GULBARGA WEST LIN1	GULBARGA WEST_110,GULBARGA SOUTH_110	13:31	17:45	04:14	LINE CLEAR AVAILED
2910	#####	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	09:15	18:05	08:50	LINE CLEAR AVAILED
2911	#####	GULBARGA	110	SIRIGUPPA-DHADESUGUR	TEKKALKOTE_110,SIRIGERI CROSS_110	08:45	09:35	00:50	LINE CLEAR AVAILED
2912	#####	GULBARGA	220	HV2	KAPNOOR_220	09:27	16:04	06:37	LINE CLEAR AVAILED
2913	#####	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	15:23	18:56	03:33	LINE CLEAR AVAILED
2914	#####	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	15:15	16:25	01:10	LINE CLEAR AVAILED
2915	20-Jan-24	HASSAN	110	HV1	KADUR_220	10:50	11:10	00:20	LINE CLEAR AVAILED
2916	20-Jan-24	HASSAN	110	HV1	KARAYA_110	10:15	12:38	02:23	LINE CLEAR AVAILED
2917	20-Jan-24	HASSAN	110	LV3	MRSMSG_220	12:01 (12.01.2024)	18:41 (20.01.2024)	222:40HRS	LINE CLEAR AVAILED
2918	20-Jan-24	HASSAN	110	MRSSHM-TRKER	MRSMSG_220	16:20	17:23	01:03	TRIPPED ON FAULT
2919	20-Jan-24	HASSAN	110	SHIRAL-SANDA	SHIRALKOPPA_110	14:33	14:42	00:09	LINE CLEAR AVAILED
2920	20-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:13	14:41	03:28	LINE CLEAR AVAILED
2921	20-Jan-24	HASSAN	110	SLTR	PUTTUR_110	11:31	12:14	00:43	LINE CLEAR AVAILED
2922	20-Jan-24	HASSAN	220	HV3	MRSMSG_220	12:01 (12.01.2024)	18:41 (20.01.2024)	222:40HRS	LINE CLEAR AVAILED
2923	20-Jan-24	MYSORE	66	BESAGARAHALLI-DUDDENHALLY	NO STATIONS EFFECTED	12:00	14:40	02:40	LINE CLEAR AVAILED
2924	20-Jan-24	MYSORE	66	DOORA-CHANDRAWADI	CHANDRAVADI_66 HURA_66 HULLAHALLI_66.	03:06	03:12	00:06	TRIPPED ON FAULT
2925	20-Jan-24	MYSORE	66	DR PETE-MADHUVANAHALLI	SANTHEMARAHALLI_66	10:05	15:02	04:56	LINE CLEAR AVAILED
2926	20-Jan-24	MYSORE	66	G UKKADA-PANDAVAPURA	PANDAVAPURA_66	10:56	14:50	03:53	LINE CLEAR AVAILED
2927	20-Jan-24	MYSORE	66	GAVADAGERE-CHUNCHUNKATTE	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	13:15	13:40	00:25	TRIPPED ON FAULT
2928	20-Jan-24	MYSORE	66	GAVADAGERE-KR NAGARA	BILIKERE_66 GVGUDI_66 KRNAGARA_66	13:15	13:40	00:25	TRIPPED ON FAULT
2929	20-Jan-24	MYSORE	66	HUNSUR -HUNSUR 1	NO STATIONS EFFECTED	13:06	14:06	00:59	LINE CLEAR AVAILED
2930	20-Jan-24	MYSORE	66	HV1	ADDIHALLI_66	12:53	13:16	00:23	TRIPPED ON FAULT
2931	20-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	07:33	07:40	00:06	TRIPPED ON FAULT
2932	20-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	20:02	20:04	00:02	TRIPPED ON FAULT
2933	20-Jan-24	MYSORE	66	HV2	MALAVALLI_66	11:31	13:50	02:18	LINE CLEAR AVAILED
2934	20-Jan-24	MYSORE	66	HV2	TERAKANAMBE_66	07:02	08:00	00:57	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2935	20-Jan-24	MYSORE	66	HV3	KUSHALANAGARA_66	13:13	13:37	00:23	LINE CLEAR AVAILED
2936	20-Jan-24	MYSORE	66	HV4	KUSHALANAGARA_66	13:16	13:40	00:24	LINE CLEAR AVAILED
2937	20-Jan-24	MYSORE	66	KAMPLAPURA-PERİYAPATNA	NO STATIONS EFFECTED	13:17	13:28	00:11	TRIPPED ON FAULT
2938	20-Jan-24	MYSORE	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	13:02	13:04	00:02	LINE CLEAR AVAILED
2939	20-Jan-24	MYSORE	66	KUSHALNAGARA-BYLUKUPPE	BYLUKUPPE_66	13:27	13:32	00:04	LINE CLEAR AVAILED
2940	20-Jan-24	MYSORE	66	KUSHALNAGARA-PERİYAPATNA 2	BYLUKUPPE_66	13:17	13:39	00:22	TRIPPED ON FAULT
2941	20-Jan-24	MYSORE	66	MADHUVANAHALLI-KUNTHUR	KUNTHUR_66	11:37	12:49	01:12	LINE CLEAR AVAILED
2942	20-Jan-24	MYSORE	66	NAGAMANGALA 220-GUDDENAHALLI	BOGADHI MANDYA_66 GUDDENAHALLI_66	05:36	05:43	00:07	TRIPPED ON FAULT
2943	20-Jan-24	MYSORE	66	PERIAPATNA-KUSHALNAGARA 1	PERIYAPATNA_66 PONNAMPET_66 SRIMANGALA_66 VIRAJPET_66	13:19	13:29	00:09	TRIPPED ON FAULT
2944	20-Jan-24	MYSORE	220	HV1	KUSHALNAGARA_220	13:16	13:30	00:14	LINE CLEAR AVAILED
2945	20-Jan-24	MYSORE	220	HV2	KUSHALNAGARA_220	13:17	13:29	00:12	LINE CLEAR AVAILED
2946	20-Jan-24	TUMKUR	66	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	10:20	17:45	07:25	MAIN SUPPLY FAILURE
2947	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	13:23	13:25	00:02	LINE CLEAR AVAILED
2948	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-HIRIYUR_66	SANEKERE_66, CHALKERE_66, IMANGALA_66	13:23	14:27	01:04	LINE CLEAR AVAILED
2949	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-KARAD IPP	KARAD IPP	13:23	13:25	00:02	LINE CLEAR AVAILED
2950	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	15:10	15:13	00:03	TRIPPED ON FAULT
2951	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	13:23	14:02	00:39	LINE CLEAR AVAILED
2952	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	13:23	13:25	00:02	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2953	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	06:11	06:18	00:07	TRIPPED ON FAULT
2954	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	13:23	13:25	00:02	LINE CLEAR AVAILED
2955	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 4	CHITRADURGA_220	13:23	13:25	00:02	LINE CLEAR AVAILED
2956	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	13:23	13:25	00:02	LINE CLEAR AVAILED
2957	20-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA3	CHITRADURGA_220	13:23	13:25	00:02	LINE CLEAR AVAILED
2958	20-Jan-24	TUMKUR	66	HANAGAL- RAMPURA	RAMAPURA_66 NAGASAMUDRA_66	10:00	19:46	09:45	LINE CLEAR AVAILED
2959	20-Jan-24	TUMKUR	66	HV1(TR1)	CHITRADURGA_220	13:23	13:34	00:11	TRIPPED ON FAULT
2960	20-Jan-24	TUMKUR	66	HV1(TR1)	CHITRAHALLI_66	08:05	08:10	00:05	TRIPPED ON FAULT
2961	20-Jan-24	TUMKUR	66	HV1(TR1)	KATTIGE_66	06:00	06:30	00:30	LINE CLEAR AVAILED
2962	20-Jan-24	TUMKUR	66	HV1(TR1)	TUMKUR_66	12:54	13:12	00:18	LINE CLEAR AVAILED
2963	20-Jan-24	TUMKUR	66	HV1(TR1)	TUMKUR_66	13:18	13:27	00:09	LINE CLEAR AVAILED
2964	20-Jan-24	TUMKUR	66	KATTIGE- BEDRUKATTE	KATTIGE_66	11:00	11:40	00:40	MAIN SUPPLY FAILURE
2965	20-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
2966	20-Jan-24	TUMKUR	66	SIRA220-SIRA 1	SIRA_66	16:05	16:35	00:30	LINE CLEAR AVAILED
2967	20-Jan-24	TUMKUR	66	SIRA220-TAVAREKERE	TAVAREKERE_66	14:15	16:10	01:55	LINE CLEAR AVAILED
2968	20-Jan-24	TUMKUR	66	SIRA220-TAVAREKERE	TAVAREKERE_66	16:34	16:38	00:04	LINE CLEAR AVAILED
2969	20-Jan-24	TUMKUR	110	HV1(TR1)	SOMALAPURA_110	11:17	17:27	06:09	LINE CLEAR AVAILED
2970	20-Jan-24	TUMKUR	110	HV2(TR2)	BEVINAHALLI_66	07:50	08:50	01:00	LINE CLEAR AVAILED
2971	20-Jan-24	TUMKUR	110	K G TEMPLE-UNGRDLI	KGTEMPLE_110	14:36	18:21	03:45	LINE CLEAR AVAILED
2972	20-Jan-24	TUMKUR	110	NITTUR 220kV-AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	13:20	14:28	01:08	LINE CLEAR AVAILED
2973	20-Jan-24	TUMKUR	110	NITTUR 220kV-DODDAGUNI	DODDAGUNI_110	13:20	17:21	04:01	LINE CLEAR AVAILED
2974	20-Jan-24	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110, BIDARE_110	13:20	14:28	01:08	LINE CLEAR AVAILED
2975	20-Jan-24	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	13:20	14:28	01:08	LINE CLEAR AVAILED
2976	20-Jan-24	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	13:20	17:21	04:01	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2977	20-Jan-24	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	13:20	17:21	04:01	LINE CLEAR AVAILED
2978	20-Jan-24	TUMKUR	110	NITTUR 220kV- SOMALAPURA	SOMALAPURA_66	13:20	17:21	04:01	LINE CLEAR AVAILED
2979	20-Jan-24	TUMKUR	220	BENKIKERE 220kV- HONNALLI LINE 1	BENKIKERE_220	13:25	14:45	01:20	MAIN SUPPLY FAILURE
2980	20-Jan-24	TUMKUR	220	GUTTUR 400kV- BTPS	GUTTUR_400	09:55	18:35	08:40	LINE CLEAR AVAILED
2981	20-Jan-24	TUMKUR	220	HV1(TR1)	CHITRADURGA_220	13:23	16:10	02:47	LINE CLEAR AVAILED
2982	20-Jan-24	TUMKUR	220	HV1(TR1)	CHITRADURGA_220	13:23	13:25	00:02	TRIPPED ON FAULT
2983	20-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
2984	21-Jan-24	BAGALKOT	110	110/11KV, HV1 (20MVA)	MACHE_110	10:19	17:10	06:51	LINE CLEAR AVAILED
2985	21-Jan-24	BAGALKOT	110	110/11KV, HV3 (10MVA)	JAMAKHANDI_110	15:15	17:40	02:25	LINE CLEAR AVAILED
2986	21-Jan-24	BAGALKOT	110	110/11KV, HV3 (20MVA)	MACHE_110	10:19	17:10	06:51	LINE CLEAR AVAILED
2987	21-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	SIRSI_110	00:26	00:41	00:15	TRIPPED ON FAULT
2988	21-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	KUDCHI_110	10:16	11:05	00:49	LINE CLEAR AVAILED
2989	21-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	UDYAMBAG_110	10:17	11:19	01:02	LINE CLEAR AVAILED
2990	21-Jan-24	BAGALKOT	110	110/33KV, HV2 (20MVA)	STATION NOT AFFECTED HANAGAL_110	15:09	15:20	00:11	TRIPPED ON FAULT
2991	21-Jan-24	BAGALKOT	110	110/33KV, HV4(20MVA)	MACHE_110	10:19	17:10	06:51	LINE CLEAR AVAILED
2992	21-Jan-24	BAGALKOT	110	110/33KV,HV4(20MVA-HV2)	ZALAKI_110	00:20	00:25	00:05	TRIPPED ON FAULT
2993	21-Jan-24	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED NARENDRA_220	11:13	16:21	05:08	LINE CLEAR AVAILED
2994	21-Jan-24	BAGALKOT	110	ATHANI220- AIGALI	STATION NOT AFFECTED ATHANI_220	07:25	07:44	00:19	TRIPPED ON FAULT
2995	21-Jan-24	BAGALKOT	110	ATHANI220- BALIGERI	STATION NOT AFFECTED ATHANI_220	07:25	07:46	00:21	TRIPPED ON FAULT
2996	21-Jan-24	BAGALKOT	110	ATHANI220- KARIMASUTI	STATION NOT AFFECTED ATHANI_220	07:25	07:43	00:18	TRIPPED ON FAULT
2997	21-Jan-24	BAGALKOT	110	ATHANI220- KARIMASUTI	STATION NOT AFFECTED ATHANI_220	07:43	08:06	00:23	TRIPPED ON FAULT
2998	21-Jan-24	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTED ATHANI_220	07:25	07:43	00:18	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
2999	21-Jan-24	BAGALKOT	110	ATHANI220-ATHANI	STATION NOT AFFECTED ATHANI_220	02:20	02:33	00:13	TRIPPED ON FAULT
3000	21-Jan-24	BAGALKOT	110	ATHANI220-ATHANI	STATION NOT AFFECTED ATHANI_220	07:25	07:45	00:20	TRIPPED ON FAULT
3001	21-Jan-24	BAGALKOT	110	BELUR-NARENDRA220-2	STATION NOT AFFECTED BELUR_110	11:44	13:32	01:48	LINE CLEAR AVAILED
3002	21-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
3003	21-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
3004	21-Jan-24	BAGALKOT	110	KARWAR220- KARWAR	STATION NOT AFFECTED KARWAR_220	07:57	08:12	00:15	TRIPPED ON FAULT
3005	21-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3006	21-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3007	21-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3008	21-Jan-24	BAGALKOT	110	NARENDRA220- BELUR2	STATION NOT AFFECTED NARENDRA_220	11:45	13:32	01:47	LINE CLEAR AVAILED
3009	21-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3010	21-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
3011	21-Jan-24	BAGALKOT	110	SUVARNA SOUDA-MACHE	SUVARNA SOUDA_110	11:30	17:01	05:31	LINE CLEAR AVAILED
3012	21-Jan-24	BAGALKOT	110	TAKKALAKI-TIKOTA	TAKKALAKI_110	01:03	01:11	00:08	TRIPPED ON FAULT
3013	21-Jan-24	BAGALKOT	110	VADAGOAN-MACHE	VADAGOAN_110	10:53	17:02	06:09	LINE CLEAR AVAILED
3014	21-Jan-24	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED NARENDRA_220	11:14	16:21	05:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3015	21-Jan-24	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	8:45 (20.01.2024)			LINE CLEAR AVAILED
3016	21-Jan-24	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	8:43 (20.01.2024)			LINE CLEAR AVAILED
3017	21-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3018	21-Jan-24	BAGALKOT	220	DHONI- LINGAPUR1(HALVARTHI2)	STATION NOT AFFECTED DHONI_400	09:38	17:25	07:47	LINE CLEAR AVAILED
3019	21-Jan-24	BAGALKOT	220	DHONI- LINGAPUR2(HALVARTHI1)	STATION NOT AFFECTED DHONI_400	09:38	17:15	07:37	LINE CLEAR AVAILED
3020	21-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI2	STATION NOT AFFECTED NARENDRA_220	10:48	20:59	10:11	LINE CLEAR AVAILED
3021	21-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
3022	21-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
3023	21-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3024	21-Jan-24	BANGALORE	66	ALIPURA - THONDEBHAVI	ALIPURA	10:30	17:10	06:40	LINE CLEAR AVAILED
3025	21-Jan-24	BANGALORE	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	15:46	15:53	00:07	LINE CLEAR AVAILED
3026	21-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3027	21-Jan-24	BANGALORE	66	BAGEPALLI - MITTEMARI 220	BAGEPALLI	10:15	17:25	07:10	LINE CLEAR AVAILED
3028	21-Jan-24	BANGALORE	66	CHIKKABALLAPURA I/A - DB PURA 220	NO STATION AFFECTED	07:56	08:08	00:12	TRIPPED ON FAULT
3029	21-Jan-24	BANGALORE	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	NO STATION AFFECTED	07:56	08:08	00:12	TRIPPED ON FAULT
3030	21-Jan-24	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	10:00	14:05	04:05	LINE CLEAR AVAILED
3031	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - ACC (EHT)	ACC (EHT)	11:00	17:10	06:10	LINE CLEAR AVAILED
3032	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	11:00	17:19	06:19	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3033	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - BAGEPALLI 2	VIDHURASHWATHA, GUNDLU KOTTUR, GULUR	11:00	17:10	06:10	LINE CLEAR AVAILED
3034	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE, SASALU	11:00	17:10	06:10	LINE CLEAR AVAILED
3035	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI	11:00	17:19	06:19	LINE CLEAR AVAILED
3036	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI, ALIPURA	11:00	17:10	06:10	LINE CLEAR AVAILED
3037	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 2	THONDEBHAVI, ALIPURA	11:00	17:19	06:19	LINE CLEAR AVAILED
3038	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - HOSUR RAMAPURA	HOSUR RAMAPURA	11:00	17:10	06:10	LINE CLEAR AVAILED
3039	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KODIGENAHALLI	ID HALLI, KODIGENAHALLI	11:00	17:19	06:19	LINE CLEAR AVAILED
3040	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - KUDMALKUNTE	KUDMALKUNTE, THRIYURU, VENKATAPURA	11:00	17:10	06:10	LINE CLEAR AVAILED
3041	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	05:20	06:15	00:55	LOAD CURTAILMENT
3042	21-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	11:00	17:10	06:10	LINE CLEAR AVAILED
3043	21-Jan-24	BANGALORE	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE, SASALU	10:57	11:00	00:03	LINE CLEAR AVAILED
3044	21-Jan-24	BANGALORE	66	HSR LAYOUT 220 - KORAMANGALA 1	NO STATION AFFECTED	00:00	00:24	00:24	TRIPPED ON FAULT
3045	21-Jan-24	BANGALORE	66	HV1	ABBIGERE	12:20	12:25	00:05	LINE CLEAR AVAILED
3046	21-Jan-24	BANGALORE	66	HV1	EPIP 220	10:05	10:10	00:05	LINE CLEAR AVAILED
3047	21-Jan-24	BANGALORE	66	HV1	GOWRIBIDANUR 220	11:00	17:16	06:16	LINE CLEAR AVAILED
3048	21-Jan-24	BANGALORE	66	HV1	MITTEMARI 220	20:10	20:15	00:05	MAIN SUPPLY FAILURE
3049	21-Jan-24	BANGALORE	66	HV1	HUKUNDA	14:00	14:10	00:10	TRIPPED ON FAULT
3050	21-Jan-24	BANGALORE	66	HV2	ABBIGERE	13:50	13:55	00:05	LINE CLEAR AVAILED
3051	21-Jan-24	BANGALORE	66	HV2	GOWRIBIDANUR 220	11:00	17:16	06:16	LINE CLEAR AVAILED
3052	21-Jan-24	BANGALORE	66	HV2	HULLENAHALLI	11:50	12:20	00:30	LINE CLEAR AVAILED
3053	21-Jan-24	BANGALORE	66	HV2	HULLENAHALLI	18:00	18:05	00:05	TRIPPED ON FAULT
3054	21-Jan-24	BANGALORE	66	HV2	BOMMASANDRA I/A	10:20	15:43	05:23	LINE CLEAR AVAILED
3055	21-Jan-24	BANGALORE	66	JANGAMKOTE - CHINTAMANI 220	JANGAMKOTE	15:28	15:40	00:12	LINE CLEAR AVAILED
3056	21-Jan-24	BANGALORE	66	JANGAMKOTE - VIJAYAPURA	JANGAMKOTE	11:20	11:23	00:03	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3057	21-Jan-24	BANGALORE	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	08:36	17:17	08:41	LINE CLEAR AVAILED
3058	21-Jan-24	BANGALORE	66	KORAMANGALA 220 - HSR 1	NO STATION AFFECTED	17:12	23:59	06:47	TRIPPED ON FAULT
3059	21-Jan-24	BANGALORE	66	KYALANUR - TALAGAWARA	KYALANUR	17:23	17:27	00:04	LINE CLEAR AVAILED
3060	21-Jan-24	BANGALORE	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI, RAYALPADU	09:00	09:07	00:07	TRIPPED ON FAULT
3061	21-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSAHALLI	11:05	17:40	06:35	LINE CLEAR AVAILED
3062	21-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSAHALLI	20:10	20:15	00:05	MAIN SUPPLY FAILURE
3063	21-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	10:15	17:25	07:10	LINE CLEAR AVAILED
3064	21-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	20:10	20:15	00:05	MAIN SUPPLY FAILURE
3065	21-Jan-24	BANGALORE	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	10:20	17:27	07:07	LINE CLEAR AVAILED
3066	21-Jan-24	BANGALORE	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, GULUR	11:00	17:30	06:30	LINE CLEAR AVAILED
3067	21-Jan-24	BANGALORE	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	10:15	17:55	07:40	LINE CLEAR AVAILED
3068	21-Jan-24	BANGALORE	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR	20:10	20:15	00:05	MAIN SUPPLY FAILURE
3069	21-Jan-24	BANGALORE	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	10:15	17:00	06:45	LINE CLEAR AVAILED
3070	21-Jan-24	BANGALORE	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	20:10	20:15	00:05	MAIN SUPPLY FAILURE
3071	21-Jan-24	BANGALORE	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA	07:45	08:15	00:30	TRIPPED ON FAULT
3072	21-Jan-24	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	06:06	06:09	00:03	LINE CLEAR AVAILED
3073	21-Jan-24	BANGALORE	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	11:29	11:32	00:03	LINE CLEAR AVAILED
3074	21-Jan-24	BANGALORE	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI	08:35	08:40	00:05	LINE CLEAR AVAILED
3075	21-Jan-24	BANGALORE	66	PERESANDRA - SOMENAHALLI	PERESANDRA	23:20	23:25	00:05	LINE CLEAR AVAILED
3076	21-Jan-24	BANGALORE	66	SADALI - DIBBURAHALLI	SADALI	17:58	18:10	00:12	LINE CLEAR AVAILED
3077	21-Jan-24	BANGALORE	66	SADALI - MITTEMARI 220	SADALI, DIBBURAHALLI	10:58	11:12	00:14	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3078	21-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - BRIGADE CORNERSTONE UTOPIA	BRIGADE CORNERSTONE UTOPIA	14:12	14:50	00:38	MAIN SUPPLY FAILURE
3079	21-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - SHOBHA DREAMS 66	DIVYASHREE TECH PARK, MINOR IRRIGATION, KACHAMARANAHALLI, PRESTIGE LAKESIDE HABITAT, SHOBHA DREAMS 66	14:12	14:50	00:38	MAIN SUPPLY FAILURE
3080	21-Jan-24	BANGALORE	66	SHOBHA DREAMS 220 - SORAHUNASE	SORAHUNASE	14:12	14:50	00:38	MAIN SUPPLY FAILURE
3081	21-Jan-24	BANGALORE	66	SOMANAHALLI 220 - KANAKAPURA 2	RANGANADODDI	10:39	16:30	05:51	LINE CLEAR AVAILED
3082	21-Jan-24	BANGALORE	66	SOMENAHALLI - GOWRIBIDANUR 220	SOMENAHALLI	22:50	23:15	00:25	LINE CLEAR AVAILED
3083	21-Jan-24	BANGALORE	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	17:00	19:05	02:05	LINE CLEAR AVAILED
3084	21-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - DEVARABISANAHALLI	DEVARABISANAHALLI	16:00	17:20	01:20	LINE CLEAR AVAILED
3085	21-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL	PRIMAL	15:48	15:54	00:06	LINE CLEAR AVAILED
3086	21-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - PRIMAL	PRIMAL	19:00	19:06	00:06	LINE CLEAR AVAILED
3087	21-Jan-24	BANGALORE	66	YARANDANAHALLI 220 - KEONICS 1	BOMMASANDRA I/A	12:23	15:43	03:20	LINE CLEAR AVAILED
3088	21-Jan-24	BANGALORE	220	GOWRIBIDANUR 220 - MITTEMARI 1	MITTEMARI 220	20:10	20:15	00:05	TRIPPED ON FAULT
3089	21-Jan-24	BANGALORE	220	HOODY 400 - SHOBHA DREAMS 220	SHOBHA DREAMS 220	14:12	15:02	00:50	TRIPPED ON FAULT
3090	21-Jan-24	BANGALORE	220	HV1	GOWRIBIDANUR 220	11:00	17:10	06:10	LINE CLEAR AVAILED
3091	21-Jan-24	BANGALORE	220	HV1	MITTEMARI 220	11:05	17:17	06:12	LINE CLEAR AVAILED
3092	21-Jan-24	BANGALORE	220	HV2	GOWRIBIDANUR 220	11:00	17:10	06:10	LINE CLEAR AVAILED
3093	21-Jan-24	BANGALORE	220	HV2	MITTEMARI 220	11:05	17:17	06:12	LINE CLEAR AVAILED
3094	21-Jan-24	BANGALORE	220	HV3	GOWRIBIDANUR 220	11:00	17:10	06:10	LINE CLEAR AVAILED
3095	21-Jan-24	BANGALORE	220	MITTEMARI 220 - GOWRIBIDANUR 220	MITTEMARI 220	11:05	17:15	06:10	LINE CLEAR AVAILED
3096	21-Jan-24	BANGALORE	220	SHOBHA DREAMS 220 - HOODY 400	SHOBHA DREAMS 220	14:12	15:02	00:50	TRIPPED ON FAULT
3097	21-Jan-24	BANGALORE	220	SHOBHA DREAMS 220 - SOMANAHALLI 220	SHOBHA DREAMS 220	14:12	14:47	00:35	TRIPPED ON FAULT
3098	21-Jan-24	BANGALORE	220	SOMANAHALLI 220 - SHOBHA DREAMS 220	SHOBHA DREAMS 220	14:12	14:47	00:35	TRIPPED ON FAULT
3099	21-Jan-24	GULBARGA	66	HV2	GUDDEKOTE_66	12:00	12:10	00:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3100	21-Jan-24	GULBARGA	66	HV2	CHORNOOR_66	04:00	04:20	00:20	TRIPPED ON FAULT
3101	21-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66, MAGLA_66, GIRIYAPUR_66	06:30	06:48	00:18	TRIPPED ON FAULT
3102	21-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI2	SOVENHALLI_66, HIREHADAGALI_66, MAGLA_66, GIRIYAPUR_66	06:30	06:48	00:18	TRIPPED ON FAULT
3103	21-Jan-24	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCCHANGIDURGA_66	06:07	06:30	00:23	TRIPPED ON FAULT
3104	21-Jan-24	GULBARGA	110	GABUR-RAICHUR	GABUR_110, GUGAL_110	03:20	03:30	00:10	TRIPPED ON FAULT
3105	21-Jan-24	GULBARGA	110	HV1	KAMALAPUR_110	9:00(21.1.2024)			LINE CLEAR AVAILED
3106	21-Jan-24	GULBARGA	110	HV3	KURUGOD_110	09:50	10:10	00:20	TRIPPED ON FAULT
3107	21-Jan-24	GULBARGA	110	KAPNOOR-ALAND	ALAND_110, KADAGANCHI_110	12:11	12:46	00:35	LINE CLEAR AVAILED
3108	21-Jan-24	GULBARGA	110	KAPNOOR-KALBURGI WEST2	KALBURGI WEST_110	15:38	16:18	00:40	LINE CLEAR AVAILED
3109	21-Jan-24	GULBARGA	110	KAPNOOR-KAPNOOR	KAPNOOR_110	09:05	16:01	06:56	LINE CLEAR AVAILED
3110	21-Jan-24	GULBARGA	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	12:53	14:02	01:09	LINE CLEAR AVAILED
3111	21-Jan-24	GULBARGA	110	KHANAPUR-MUDNALA TRACTION	KHANAPUR_110	21:30	21:38	00:08	TRIPPED ON FAULT
3112	21-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	06:45	06:50	00:05	TRIPPED ON FAULT
3113	21-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	07:01	07:13	00:12	TRIPPED ON FAULT
3114	21-Jan-24	GULBARGA	110	SEDAM-CHINCHOLI-1	CHINCHOLI-1_110	06:50	13:50	07:00	LINE CLEAR AVAILED
3115	21-Jan-24	GULBARGA	110	SEDAM-CHINCHOLI-2	CHINCHOLI-2_110	11:43	13:52	02:09	LINE CLEAR AVAILED
3116	21-Jan-24	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110,DEVAPUR_110	23:13	23:19	00:06	TRIPPED ON FAULT
3117	21-Jan-24	GULBARGA	110	SINDHANOOR-MARALIHALLA	MUKUNDA_110	20:02	20:12	00:10	TRIPPED ON FAULT
3118	21-Jan-24	GULBARGA	110	SINDHANOOR-SR NAGAR	KARATAGI_110	12:16	12:26	00:10	TRIPPED ON FAULT
3119	21-Jan-24	GULBARGA	110	SIRIGUPPA-TEKKALKOTE	TEKKALKOTE_110,SIRIGERI CROSS_110,DHADESUGUR_110	21:19	21:34	00:15	TRIPPED ON FAULT
3120	21-Jan-24	GULBARGA	110	VASAVADATTA-SEDAM	VASAVADATTA_110	11:38	13:54	02:16	LINE CLEAR AVAILED
3121	21-Jan-24	GULBARGA	110	VENKATAGIRI-MUNIRABAD	VENKATAGIRI_110	17:08	17:23	00:15	MAIN SUPPLY FAILURE
3122	21-Jan-24	GULBARGA	220	HALWARTHY-DONI 1&2	HALWARTHY_220	09:37	17:25	07:48	LINE CLEAR AVAILED
3123	21-Jan-24	HASSAN	66	HASSN22-BELUR	HASSAN_220	10:05	12:07	02:02	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3124	21-Jan-24	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATHPURA_220	14:30	14:35	00:05	MAIN SUPPLY FAILURE
3125	21-Jan-24	HASSAN	110	HV2	ARASIKERE_110	17:50	18:25	00:35	TRIPPED ON FAULT
3126	21-Jan-24	HASSAN	110	HV2	ARASIKERE_110	18:45	20:56	02:11	TRIPPED ON FAULT
3127	21-Jan-24	HASSAN	110	HV2	HOSNGADI_110	14:16	16:13	01:57	TRIPPED ON FAULT
3128	21-Jan-24	MYSORE	66	HV1	KADAKOLA_220	12:37	15:41	03:03	LINE CLEAR AVAILED
3129	21-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	23:07	23:11	00:03	TRIPPED ON FAULT
3130	21-Jan-24	MYSORE	66	HV2	KADAKOLA_220	15:43	17:08	01:25	LINE CLEAR AVAILED
3131	21-Jan-24	MYSORE	66	JAIPURA-HAMPAPURA	NO STATIONS EFFECTED	08:04	13:42	05:38	LINE CLEAR AVAILED
3132	21-Jan-24	MYSORE	66	JYOTHINAGAR-FTS	NO STATIONS EFFECTED	04:18	04:29	00:11	TRIPPED ON FAULT
3133	21-Jan-24	MYSORE	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	16:51	16:53	00:02	LINE CLEAR AVAILED
3134	21-Jan-24	MYSORE	66	KUSHALNAGARA-MYSORE 1	NO STATIONS EFFECTED	12:31	12:53	00:22	TRIPPED ON FAULT
3135	21-Jan-24	MYSORE	66	KUSHALNAGARA-PERIPATNA-1	NO STATIONS EFFECTED	12:43	12:52	00:08	TRIPPED ON FAULT
3136	21-Jan-24	MYSORE	66	KUSHALNAGARA-RAMANTHAPURA1	ALUR SIDDAPURA_66 KANAGAL_66	13:25	16:57	03:31	TRIPPED ON FAULT
3137	21-Jan-24	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	07:46	18:57	11:10	LINE CLEAR AVAILED
3138	21-Jan-24	MYSORE	220	HV1	KADAKOLA_220	08:10	18:43	10:33	LINE CLEAR AVAILED
3139	21-Jan-24	MYSORE	220	HV2	KUSHALNAGARA_220	13:26	13:29	00:03	LINE CLEAR AVAILED
3140	21-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220kV-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:00	17:11	07:10	LINE CLEAR AVAILED
3141	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-BENKIKERE	BENKIKERE_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE
3142	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-BENKIKERE	BENKIKERE_66	13:25	14:45	01:20	MAIN SUPPLY FAILURE
3143	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE
3144	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	13:25	14:45	01:20	MAIN SUPPLY FAILURE
3145	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE
3146	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	13:25	14:45	01:20	MAIN SUPPLY FAILURE
3147	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3148	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-MALLADIHALLI	MALLADIHALLI_66	13:25	14:45	01:20	MAIN SUPPLY FAILURE
3149	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-NALLUR	NALLUR_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE
3150	21-Jan-24	TUMKUR	66	BENKIKERE 220kV-NALLUR	NALLUR_66	13:25	14:45	01:20	MAIN SUPPLY FAILURE
3151	21-Jan-24	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	09:05	11:35	02:30	MAIN SUPPLY FAILURE
3152	21-Jan-24	TUMKUR	66	BENKIKERE-CHANNAGIRI	BENKIKERE_66	11:35	14:45	03:10	MAIN SUPPLY FAILURE
3153	21-Jan-24	TUMKUR	66	HONNALLI - KUNDUR	KUNDUR_66	09:05	11:38	02:33	MAIN SUPPLY FAILURE
3154	21-Jan-24	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:05	11:38	00:33	TRIPPED ON FAULT
3155	21-Jan-24	TUMKUR	66	HONNALLI 220KV-NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	11:05	11:38	00:33	TRIPPED ON FAULT
3156	21-Jan-24	TUMKUR	66	HONNALLI 220kV-(LINGADAHALLI) NALLUR_66	NALLURU_66,	09:05	11:38	02:33	MAIN SUPPLY FAILURE
3157	21-Jan-24	TUMKUR	66	HONNALLI220-HONNALLI66	HONNALLI_66, KATTIGE_66	11:05	11:38	00:33	TRIPPED ON FAULT
3158	21-Jan-24	TUMKUR	66	HV1(TR1)	MELLEKATTE_66	14:53	14:59	00:06	TRIPPED ON FAULT
3159	21-Jan-24	TUMKUR	66	HV2(TR2)	CHITRAHALLI_66	07:55	08:00	00:05	TRIPPED ON FAULT
3160	21-Jan-24	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	06:00	06:10	00:10	MAIN SUPPLY FAILURE
3161	21-Jan-24	TUMKUR	66	MADHUGIRI 220kV-KORATAGERE 1	KORATAGERE_66	10:25	17:46	07:21	LINE CLEAR AVAILED
3162	21-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3163	21-Jan-24	TUMKUR	66	SHYAGALE- KEREKILCHI	SHYAGALE_66, KEREBILCHI_66, TYAVANAGI_66, SANTEBENNUR_66, BASAVAPATNA_66	07:10	07:20	00:10	TRIPPED ON FAULT
3164	21-Jan-24	TUMKUR	220	BENKIKERE 220kV-HONNALLI LINE 1	BENKIKERE_220	13:25	14:40	01:15	MAIN SUPPLY FAILURE
3165	21-Jan-24	TUMKUR	220	GUTTUR 400KV-DAVANAGERE 1	DAVANAGERE_SRS_220	09:04	10:14	01:10	TRIPPED ON FAULT
3166	21-Jan-24	TUMKUR	220	GUTTUR 400KV-DAVANAGERE 1	DAVANAGERE_SRS_220	13:25	14:34	01:09	TRIPPED ON FAULT
3167	21-Jan-24	TUMKUR	220	GUTTUR 400KV-DAVANAGERE 3	DAVANAGERE_SRS_220	04:46	10:11	05:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3168	21-Jan-24	TUMKUR	220	GUTTUR 400KV-DAVANAGERE 3	DAVANAGERE_SRS_220	13:25	14:24	00:59	TRIPPED ON FAULT
3169	21-Jan-24	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	11:05	11:38	00:33	TRIPPED ON FAULT
3170	21-Jan-24	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	11:05	11:38	00:33	TRIPPED ON FAULT
3171	21-Jan-24	TUMKUR	220	TR-1	DAVANAGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
3172	22-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	ANNIGERI_110	13:01	13:11	00:10	TRIPPED ON FAULT
3173	22-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	UKKALI_110	07:47	08:57	01:10	TRIPPED ON FAULT
3174	22-Jan-24	BAGALKOT	110	110/33KV, HV2(20MVA)	HANGAL_110	16:02	16:14	00:12	TRIPPED ON FAULT
3175	22-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	KULIGOD_110	04:19	04:29	00:10	TRIPPED ON FAULT
3176	22-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
3177	22-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	00:44	00:49	00:05	LINE CLEAR AVAILED
3178	22-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)			LINE CLEAR AVAILED
3179	22-Jan-24	BAGALKOT	110	HOSAHONNATTI-F2(BELUR2)	HOSAHONNATTI_110	09:52	10:29	00:37	LINE CLEAR AVAILED
3180	22-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
3181	22-Jan-24	BAGALKOT	110	KUDACHI220-TERDAL(MORAB)	KUDACHI_220	06:18	06:38	00:15	TRIPPED ON FAULT
3182	22-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3183	22-Jan-24	BAGALKOT	110	MAHALINGAPUR220-RABKAVI	STATION NOT AFFECTED MAHALINGAPUR_220	11:15	11:29	00:14	TRIPPED ON FAULT
3184	22-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3185	22-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3186	22-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3187	22-Jan-24	BAGALKOT	110	SANKESHWAR-CHIKKODI220	SANKESHWAR_110	10:29	11:07	00:38	TRIPPED ON FAULT
3188	22-Jan-24	BAGALKOT	110	SHIGGAON220-LN4(SAVANUR)	SHIGGAON_220	00:17	01:01	00:44	TRIPPED ON FAULT
3189	22-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
3190	22-Jan-24	BAGALKOT	220	220/110KV,HV1,LV1	AMBEWADI_220	20:08	20:27	00:19	LINE CLEAR AVAILED
3191	22-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	AMBEWADI_220	20:29	20:44	00:15	LINE CLEAR AVAILED
3192	22-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	HUBLI_220	10:12	13:27	03:15	LINE CLEAR AVAILED
3193	22-Jan-24	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	8:45 (20.01.2024)	21:42 (22.01.2024)	60:57:00	LINE CLEAR AVAILED
3194	22-Jan-24	BAGALKOT	220	AMBEWADI- PONDA2	AMBEWADI_220	8:43 (20.01.2024)	21:45 (22.01.2024)	61:02:00	LINE CLEAR AVAILED
3195	22-Jan-24	BAGALKOT	220	AMBEWADI-NAGJARI1	AMBEWADI_220	20:03	20:26	00:23	LINE CLEAR AVAILED
3196	22-Jan-24	BAGALKOT	220	AMBEWADI-NAGJARI2	AMBEWADI_220	20:28	20:42	00:14	LINE CLEAR AVAILED
3197	22-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	20:05	20:25	00:20	LINE CLEAR AVAILED
3198	22-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	20:28	20:43	00:15	LINE CLEAR AVAILED
3199	22-Jan-24	BAGALKOT	220	BAGALKOT - GADAG2	BAGAKOT_220	13:35 (22.01.2024)			TRIPPED ON FAULT
3200	22-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3201	22-Jan-24	BAGALKOT	220	GADG-BAGALKOT2	GADAG_220	13:35	17:46	04:11	TRIPPED ON FAULT
3202	22-Jan-24	BAGALKOT	220	GADG-BAGALKOT2	GADAG_220	17:48 (22.01.2024)			TRIPPED ON FAULT
3203	22-Jan-24	BAGALKOT	220	NARENDRA-KANABARGI 2	NARENDRA_220	10:21	19:01	08:40	LINE CLEAR AVAILED
3204	22-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
3205	22-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVAILED
3206	22-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3207	22-Jan-24	BANGALORE	66	ABBIGERE - WELCAST	ABBIGERE	00:39	00:43	00:04	LINE CLEAR AVAILED
3208	22-Jan-24	BANGALORE	66	ATTUR YELAHANKA - DG3	ABBIGERE, WELCAST	00:01	00:14	00:13	TRIPPED ON FAULT
3209	22-Jan-24	BANGALORE	66	AUSTIN TOWN - KORAMANGALA 1	AUSTIN TOWN	05:54	06:00	00:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3210	22-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3211	22-Jan-24	BANGALORE	66	BIAL BEGUR 220 - BIAL 2	BIAL	12:19	12:34	00:15	MAIN SUPPLY FAILURE
3212	22-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE, SHIVANAHALLI	12:27	12:41	00:14	TRIPPED ON FAULT
3213	22-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, DASHAVARA, SANKALGERE, VANDARGUPPE, SHIVANAHALLI	12:44	13:03	00:19	TRIPPED ON FAULT
3214	22-Jan-24	BANGALORE	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	09:46	09:53	00:07	TRIPPED ON FAULT
3215	22-Jan-24	BANGALORE	66	GUNDAMGERE - DB PURA 220	GUNDAMGERE, SASALU	10:55	11:30	00:35	LINE CLEAR AVOIDED
3216	22-Jan-24	BANGALORE	66	HBR LAYOUT 66 - DG3	NO STATION AFFECTED	06:27	09:16	02:49	TRIPPED ON FAULT
3217	22-Jan-24	BANGALORE	66	HV1	MALLANAYAKANAHALLI	12:30	12:35	00:05	LINE CLEAR AVOIDED
3218	22-Jan-24	BANGALORE	66	HV1	SANKALGERE	17:20	18:10	00:50	LINE CLEAR AVOIDED
3219	22-Jan-24	BANGALORE	66	HV1	YARANDANAHALLI 220	12:05	12:13	00:08	TRIPPED ON FAULT
3220	22-Jan-24	BANGALORE	66	HV2	BIEC	10:37	10:47	00:10	LINE CLEAR AVOIDED
3221	22-Jan-24	BANGALORE	66	HV2	CHANDAPURA	14:25	15:25	01:00	LINE CLEAR AVOIDED
3222	22-Jan-24	BANGALORE	66	HV3	SARAKKI	17:34	17:45	00:11	TRIPPED ON FAULT
3223	22-Jan-24	BANGALORE	66	HV3	NELAMANGALA 66	10:44	10:52	00:08	TRIPPED ON FAULT
3224	22-Jan-24	BANGALORE	66	JAYADEVA - SARAKKI 1	NO STATION AFFECTED	08:54	12:24	03:30	TRIPPED ON FAULT
3225	22-Jan-24	BANGALORE	66	MAASTHI - SOLAR(IPP)	NO STATION AFFECTED	09:30	09:35	00:05	TRIPPED ON FAULT
3226	22-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	04:46	05:01	00:15	TRIPPED ON FAULT
3227	22-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	05:01	05:13	00:12	TRIPPED ON FAULT
3228	22-Jan-24	BANGALORE	66	MARALAWADI - KANAKAPURA 220	GODUR, MARALAWADI	09:52	10:05	00:13	TRIPPED ON FAULT
3229	22-Jan-24	BANGALORE	66	PERESANDRA - MANDIKAL	SOMENAHALLI, PERESANDRA	18:00	18:05	00:05	LINE CLEAR AVOIDED
3230	22-Jan-24	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	05:06	05:10	00:04	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3231	22-Jan-24	BANGALORE	66	SOMANAHALLI 220 - JIGANI 1	RBI, SOUTH CITY, ELITA PROMENENDE	09:45	09:56	00:11	TRIPPED ON FAULT
3232	22-Jan-24	BANGALORE	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI, PERESANDRA	16:10	16:15	00:05	LINE CLEAR AVAILED
3233	22-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 1	KM DODDI, TALAGAVADI	14:43	14:58	00:15	TRIPPED ON FAULT
3234	22-Jan-24	BANGALORE	66	WELCAST - SRS PEENYA 220	WELCAST	07:16	07:19	00:03	LINE CLEAR AVAILED
3235	22-Jan-24	BANGALORE	66	YELAHANKA 220 - KANASAWADI	KANASAWADI	20:06	20:16	00:10	TRIPPED ON FAULT
3236	22-Jan-24	BANGALORE	220	HV3	BIAL BEGUR 220	12:19	12:33	00:14	TRIPPED ON FAULT
3237	22-Jan-24	GULBARGA	66	HPHALLI-SUZLON1	HARAPANAHALLI_66	13:45	14:25	00:40	LINE CLEAR AVAILED
3238	22-Jan-24	GULBARGA	66	NEELGUNDA-PUNABGATTA	PUNABGATTA_66, UCCHANGIDURGA_66	09:20	09:29	00:09	TRIPPED ON FAULT
3239	22-Jan-24	GULBARGA	110	HV1	KAMALAPUR_110	9:00(21.1.2024)	18:30(22.01.2024)	33:30:00	LINE CLEAR AVAILED
3240	22-Jan-24	GULBARGA	110	HV1	ALIPUR_220	09:22	09:51	00:29	TRIPPED ON FAULT
3241	22-Jan-24	GULBARGA	110	HV2	CHICKSUGUR_110	23:18(22.01.2024)	00:57(23.01.2024)	01:39HRS	TRIPPED ON FAULT
3242	22-Jan-24	GULBARGA	110	HV2	MADLAPUR_110	14:05	14:15	00:10	TRIPPED ON FAULT
3243	22-Jan-24	GULBARGA	110	HV2	KURUGOD_110	16:55	17:20	00:25	TRIPPED ON FAULT
3244	22-Jan-24	GULBARGA	110	KHANAPUR-SONATHI	KHANAPUR_110	11:55	17:30	05:35	LINE CLEAR AVAILED
3245	22-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	19:30	19:40	00:10	TRIPPED ON FAULT
3246	22-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	05:59	06:09	00:10	TRIPPED ON FAULT
3247	22-Jan-24	GULBARGA	220	HV1	KUSHTAGI_220	09:24	13:39	04:15	LINE CLEAR AVAILED
3248	22-Jan-24	GULBARGA	220	HV2	KUSHTAGI_220	13:46	16:11	02:25	LINE CLEAR AVAILED
3249	22-Jan-24	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	15:08	15:18	00:10	TRIPPED ON FAULT
3250	22-Jan-24	HASSAN	66	HV2	HALEBEEDU_66	18:00	19:31	01:31	TRIPPED ON FAULT
3251	22-Jan-24	HASSAN	110	LPH-MGHE 2	gen_lph	15:28	16:07	00:39	LINE CLEAR AVAILED
3252	22-Jan-24	HASSAN	110	MGHE-JLT4	gen_mghe	15:30	16:05	00:35	LINE CLEAR AVAILED
3253	22-Jan-24	MYSORE	66	220NAGAMANGALA - KESALGERE	NO STATIONS EFFECTED	06:59	07:04	00:05	TRIPPED ON FAULT
3254	22-Jan-24	MYSORE	66	HOOTAGALLI-HAMPAPURA(KAGGERE)	HAMPAPURA(KAGGERE)_66	06:57	07:17	00:20	TRIPPED ON FAULT
3255	22-Jan-24	MYSORE	66	HV1	HARADANAHALLI(JAK)_66	13:07	14:16	01:08	LINE CLEAR AVAILED
3256	22-Jan-24	MYSORE	66	HV1	KMDODDI_66	16:06	17:55	01:49	LINE CLEAR AVAILED
3257	22-Jan-24	MYSORE	66	HV1	HALGURU_66	09:15	09:20	00:05	LINE CLEAR AVAILED
3258	22-Jan-24	MYSORE	66	HV1	HALGURU_66	16:39	16:44	00:05	LINE CLEAR AVAILED
3259	22-Jan-24	MYSORE	66	HV2	KOPPA_66	11:10	12:55	01:45	LINE CLEAR AVAILED
3260	22-Jan-24	MYSORE	66	HV2	HALGURU_66	09:00	17:05	08:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3261	22-Jan-24	MYSORE	66	KM DODDI-KK DODDI	KMDODDI_66KOLKARANAD ODDI_66	16:41	17:11	00:30	LINE CLEAR AVAILED
3262	22-Jan-24	MYSORE	66	KM DODDI-KK DODDI	KMDODDI_66KOLKARANAD ODDI_66	17:18	17:55	00:37	LINE CLEAR AVAILED
3263	22-Jan-24	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66KOLKARANAD ODDI_66 MADDUR_66 SOMANAHALLI_66	14:42	15:03	00:21	TRIPPED ON FAULT
3264	22-Jan-24	MYSORE	66	MADHUVANAHALLI- LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	01:23	01:28	00:05	TRIPPED ON FAULT
3265	22-Jan-24	MYSORE	66	MADHUVANAHALLI- LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	16:12	16:37	00:24	TRIPPED ON FAULT
3266	22-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV- BELLAVI	BELLAVI_66	07:08	07:41	00:33	LOAD CURTAILMENT
3267	22-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	07:08	07:41	00:33	LOAD CURTAILMENT
3268	22-Jan-24	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	66KV PANDARAHALLI, HOLALKERE_66	07:21	08:02	00:41	TRIPPED ON FAULT
3269	22-Jan-24	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR NEW MUSS	13:12	13:23	00:11	TRIPPED ON FAULT
3270	22-Jan-24	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	09:38	09:41	00:03	LINE CLEAR AVAILED
3271	22-Jan-24	TUMKUR	66	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	09:47	09:57	00:10	LINE CLEAR AVAILED
3272	22-Jan-24	TUMKUR	66	DAVANGERE SRS- MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	09:29	09:45	00:16	LINE CLEAR AVAILED
3273	22-Jan-24	TUMKUR	66	HARIYABBE- CHIKKABANAGERE (P D KOTE)	HARIYABBE_66	02:04	02:10	00:06	TRIPPED ON FAULT
3274	22-Jan-24	TUMKUR	66	HIREHALLI - BADDIHALLI(MELEKOTE)	MELEKOTE_66, BADDIHALLI_66	15:51	16:53	01:02	LINE CLEAR AVAILED
3275	22-Jan-24	TUMKUR	66	HOLALKERE- PANDRAHALLI1	HOLALKERE_66	07:20	08:00	00:40	MAIN SUPPLY FAILURE
3276	22-Jan-24	TUMKUR	66	HOLALKERE- PANDRAHALLI1	HOLALKERE_66	08:05	08:15	00:10	MAIN SUPPLY FAILURE
3277	22-Jan-24	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	08:34	08:44	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3278	22-Jan-24	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	07:13	07:27	00:14	LOAD CURTAILMENT
3279	22-Jan-24	TUMKUR	66	HONNUDIKE_66-HIREHALLI	HONNUDIKE_66	15:50	16:55	01:05	LINE CLEAR AVOIDED
3280	22-Jan-24	TUMKUR	66	HV1(TR1)	CHITRAHALLI_66	13:00	13:10	00:10	TRIPPED ON FAULT
3281	22-Jan-24	TUMKUR	66	HV1(TR1)	TAVAREKERE_66	18:02	18:05	00:02	TRIPPED ON FAULT
3282	22-Jan-24	TUMKUR	66	HV1(TR1)	YEDIYUR_66	06:55	08:55	02:00	LINE CLEAR AVOIDED
3283	22-Jan-24	TUMKUR	66	JNKOTE_66- MALLAPPANAHALLI	66KV IMANGALA, MALLAPPANAHALLI_66	13:13	13:31	00:18	TRIPPED ON FAULT
3284	22-Jan-24	TUMKUR	66	OBAJJIHALLI-YARAGUNTA LINE	OBAJJIHALLI_66	10:52	12:30	01:38	LINE CLEAR AVOIDED
3285	22-Jan-24	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3286	22-Jan-24	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	02:04	04:11	02:06	TRIPPED ON FAULT
3287	22-Jan-24	TUMKUR	66	PDKOTE-HARIYABBE	PDKOTE_66	02:05	02:15	00:10	MAIN SUPPLY FAILURE
3288	22-Jan-24	TUMKUR	110	HV1(TR1)	NITTUR_220	16:36	16:40	00:04	TRIPPED ON FAULT
3289	22-Jan-24	TUMKUR	220	SIRA220-HIRIYUR1 220	SIRA_220	14:49	18:18	03:28	LINE CLEAR AVOIDED
3290	22-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVOIDED
3291	22-Jan-24	TUMKUR	400	GUTTUR 400KV- BTPS	GUTTUR_400	10:48	18:46	07:57	LINE CLEAR AVOIDED
3292	23-Jan-24	BAGALKOT	110	110/11KV, HV2(10MVA)	RANEBENNUR_220	16:16	17:47	01:31	LINE CLEAR AVOIDED
3293	23-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	ALBAL_110	11:20	18:06	06:46	LINE CLEAR AVOIDED
3294	23-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	BANAHATTI_110	12:02	12:50	00:48	LINE CLEAR AVOIDED
3295	23-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	ALBAL_110	12:30	12:40	00:10	TRIPPED ON FAULT
3296	23-Jan-24	BAGALKOT	110	110/11KV,HV3(10MVA)	BIJAPUR CITY_110	17:07	17:21	00:14	LINE CLEAR AVOIDED
3297	23-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	HUBLI_220	10:51	17:32	06:41	LINE CLEAR AVOIDED
3298	23-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVOIDED
3299	23-Jan-24	BAGALKOT	110	220/110KV, LV1	STATION NOT AFFECTED HUBLI_220	11:06	17:51	06:45	LINE CLEAR AVOIDED
3300	23-Jan-24	BAGALKOT	110	ATHANI220-GHATANATTI	STATION NOT AFFECTED ATHANI_220	04:33	04:53	00:20	TRIPPED ON FAULT
3301	23-Jan-24	BAGALKOT	110	CHIKKODI220-DKSS COGEN	STATION NOT AFFECTED CHIKKODI_220	06:24	06:35	00:11	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3302	23-Jan-24	BAGALKOT	110	DADDI-F2(HONAGA)	HONAGA_110 STATION NOT AFFECTED DADDI_110	12:06	12:48	00:42	LINE CLEAR AVOIDED
3303	23-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVOIDED
3304	23-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)			LINE CLEAR AVOIDED
3305	23-Jan-24	BAGALKOT	110	JAMAKHANDI-PRABHULINGESHWAR	STATION NOT AFFECTED JAMAKHANDI_110	7:50 (14:01.2024)	7:32 (23.01.2024)	215:42:00	LINE CLEAR AVOIDED
3306	23-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
3307	23-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	12:12 (23.01.2024)			LINE CLEAR AVOIDED
3308	23-Jan-24	BAGALKOT	110	KUD DHARWAD-NARENDRA	STATION NOT AFFECTED KUD DHARWAD_110	12:02	17:05	05:03	LINE CLEAR AVOIDED
3309	23-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
3310	23-Jan-24	BAGALKOT	110	MAMADAPUR-B-BAGEWADI1	MAMADAPUR(B)_110,MALGHAN_110,MATTIHAL_110,RONIHAL_110,KAMBAGI_110,BELLUBBI_110,DEVARGENNUR_110,SHIRBUR_110	10:26	12:06	01:40	LINE CLEAR AVOIDED
3311	23-Jan-24	BAGALKOT	110	MAMADAPUR-B-BAGEWADI2	MAMADAPUR(B)_110,MALGHAN_110,MATTIHAL_110,RONIHAL_110,KAMBAGI_110,BELLUBBI_110,DEVARGENNUR_110,SHIRBUR_110	10:27	12:06	01:39	LINE CLEAR AVOIDED
3312	23-Jan-24	BAGALKOT	110	MAMADAPUR-TODALBAGI	MAMADAPUR_110	10:27	12:09	01:42	LINE CLEAR AVOIDED
3313	23-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3314	23-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3315	23-Jan-24	BAGALKOT	110	NAGANUR-TIGADI	NAGANUR_110	11:15	15:04	03:49	LINE CLEAR AVAILED
3316	23-Jan-24	BAGALKOT	110	NARENDRA220- KUD1 (DHARWAD)	STATION NOT AFFECTED NARENDRA_220	12:06	17:05	04:59	LINE CLEAR AVAILED
3317	23-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3318	23-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
3319	23-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MAHALINGAPUR_220	9:20 (23.01.2024)			LINE CLEAR AVAILED
3320	23-Jan-24	BAGALKOT	220	BAGALKOT - GADAG1	STATION NOT AFFECTED BAGALKOT_220	11:28	13:52	02:24	LINE CLEAR AVAILED
3321	23-Jan-24	BAGALKOT	220	BAGALKOT - GADAG2	STATION NOT AFFECTED BAGAKOT_220	13:35 (22.01.2024)	13:49 (23.01.2024)	24:14:00	TRIPPED ON FAULT
3322	23-Jan-24	BAGALKOT	220	BAGEWADI220-MAMADAPUR1	STATION NOT AFFECTED BAGEWADI_220	10:20	11:41	01:21	LINE CLEAR AVAILED
3323	23-Jan-24	BAGALKOT	220	BAGEWADI220-MAMADAPUR2	STATION NOT AFFECTED BAGEWADI_220	10:20	13:01	02:41	LINE CLEAR AVAILED
3324	23-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3325	23-Jan-24	BAGALKOT	220	CHIKKODI-AEQUS1(KANAGALA1)	STATION NOT AFFECTED CHIKKODI_220	10:31	12:07	01:36	LINE CLEAR AVAILED
3326	23-Jan-24	BAGALKOT	220	CHIKKODI-AEQUS2(KANAGALA2)	STATION NOT AFFECTED CHIKKODI_220	12:09	13:20	01:11	LINE CLEAR AVAILED
3327	23-Jan-24	BAGALKOT	220	GADAG- BAGALKOT1	STATION NOT AFFECTED GADAG_220	11:48	13:52	02:04	LINE CLEAR AVAILED
3328	23-Jan-24	BAGALKOT	220	GADG-BAGALKOT2	GADAG_220	17:48 (22.01.2024)	13:49 (23.01.2024)	20:01	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3329	23-Jan-24	BAGALKOT	220	KANAGALA- F3(CHIKKODI2)	STATION NOT AFFECTED KANAGALA_220	12:08	13:20	01:12	LINE CLEAR AVOIDED
3330	23-Jan-24	BAGALKOT	220	KANAGALA- F4(CHIKKODI1)	STATION NOT AFFECTED KANAGALA_220	10:32	12:06	01:34	LINE CLEAR AVOIDED
3331	23-Jan-24	BAGALKOT	220	NARENDRA- KANABARGI1	STATION NOT AFFECTED NARENDRA_220	11:25	19:05	07:40	LINE CLEAR AVOIDED
3332	23-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
3333	23-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)			LINE CLEAR AVOIDED
3334	23-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
3335	23-Jan-24	Bangalore	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3336	23-Jan-24	Bangalore	66	BUDIKOTE - TEKAL	BUDIKOTE	17:35	17:50	00:15	LINE CLEAR AVOIDED
3337	23-Jan-24	Bangalore	66	DALASANUR - MALLASANDRA	DALASANUR	13:00	13:10	00:10	LINE CLEAR AVOIDED
3338	23-Jan-24	Bangalore	66	DALASANUR - YELDUR	YELDUR	10:45	12:16	01:31	LINE CLEAR AVOIDED
3339	23-Jan-24	Bangalore	66	DALASANUR - YELDUR	YELDUR	12:16	13:08	00:52	LOAD CURTAILMENT
3340	23-Jan-24	Bangalore	66	DB PURA 220 - D CROSS 2	AIR(EHT)	12:23	14:23	02:00	LINE CLEAR AVOIDED
3341	23-Jan-24	Bangalore	66	DB PURA 220 - D CROSS 3	DODDABELAVANGALA	11:03	14:23	03:20	LINE CLEAR AVOIDED
3342	23-Jan-24	Bangalore	66	DB PURA 220 - VIJAYAPURA	JANGAMAKOTE	10:31	19:48	09:17	LINE CLEAR AVOIDED
3343	23-Jan-24	Bangalore	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI	07:10	08:10	01:00	LOAD CURTAILMENT
3344	23-Jan-24	Bangalore	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL	07:10	07:12	00:02	LOAD CURTAILMENT
3345	23-Jan-24	Bangalore	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE, SASALU	11:05	14:55	03:50	LINE CLEAR AVOIDED
3346	23-Jan-24	Bangalore	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	14:31	15:06	00:35	LINE CLEAR AVOIDED
3347	23-Jan-24	Bangalore	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SRIGIRIPURA	07:13	07:33	00:20	MAIN SUPPLY FAILURE
3348	23-Jan-24	Bangalore	66	HV1	GOKULA	07:26	07:36	00:10	TRIPPED ON FAULT
3349	23-Jan-24	Bangalore	66	HV1	NANDINI LAYOUT	13:44	13:46	00:02	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3350	23-Jan-24	Bangalore	66	HV1	VIKAS TECH PARK 220	12:25	13:18	00:53	LINE CLEAR AVOIDED
3351	23-Jan-24	Bangalore	66	HV1	BG ROAD	08:49	08:55	00:06	TRIPPED ON FAULT
3352	23-Jan-24	Bangalore	66	HV1	SOUTH CITY	10:12	14:20	04:08	LINE CLEAR AVOIDED
3353	23-Jan-24	Bangalore	66	HV1	BOMMEPALLI CROSS	16:40	17:55	01:15	LINE CLEAR AVOIDED
3354	23-Jan-24	Bangalore	66	HV1	TEKAL	12:35	13:30	00:55	LINE CLEAR AVOIDED
3355	23-Jan-24	Bangalore	66	HV1	DASHAVARA	09:26	09:31	00:05	TRIPPED ON FAULT
3356	23-Jan-24	Bangalore	66	HV1	SANKALGERE	16:35	17:45	01:10	LINE CLEAR AVOIDED
3357	23-Jan-24	Bangalore	66	HV2	VIJAYANAGARA	20:04	20:25	00:21	TRIPPED ON FAULT
3358	23-Jan-24	Bangalore	66	HV2	SOUTH CITY	10:12	14:20	04:08	LINE CLEAR AVOIDED
3359	23-Jan-24	Bangalore	66	HV2	MALLASANDRA	16:03	16:50	00:47	LINE CLEAR AVOIDED
3360	23-Jan-24	Bangalore	66	HV2	SUGUTUR	18:40	18:55	00:15	TRIPPED ON FAULT
3361	23-Jan-24	Bangalore	66	ISRO LAYOUT - SARAKKI 1	NO STATION AFFECTED	15:00	18:30	03:30	TRIPPED ON FAULT
3362	23-Jan-24	Bangalore	66	KOLAR 220 - BANGARPET 2	BANGARPET	07:10	07:40	00:30	LOAD CURTAILMENT
3363	23-Jan-24	Bangalore	66	KUDMALKUNTE - TERIYURU 2	TERIYURU	07:13	07:40	00:27	LOAD CURTAILMENT
3364	23-Jan-24	Bangalore	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNIPALLI, RAYALPADU	08:00	18:57	10:57	LINE CLEAR AVOIDED
3365	23-Jan-24	Bangalore	66	LAKSHMIPURA - TADIGOLU CROSS	LAKSHMIPURA, SOMAYAJANAHALLI	15:15	18:55	03:40	LINE CLEAR AVOIDED
3366	23-Jan-24	Bangalore	66	MARALAWADI - KANAKAPURA 220	MARALAWADI, GODUR	09:53	09:55	00:02	TRIPPED ON FAULT
3367	23-Jan-24	Bangalore	66	PERESANDRA - MITTEMARI 220	PERESANDRA	19:10	19:15	00:05	LINE CLEAR AVOIDED
3368	23-Jan-24	Bangalore	66	PERESANDRA - MITTEMARI 220	PERESANDRA	19:55	20:00	00:05	LINE CLEAR AVOIDED
3369	23-Jan-24	Bangalore	66	PERESANDRA - SOMENAHALLI	PERESANDRA	09:35	09:40	00:05	LINE CLEAR AVOIDED
3370	23-Jan-24	Bangalore	66	SOMANAHALLI 220 - HAROHALLI 1	RANGANADODDI, SANJEEVAIAHNA DODDI	16:21	16:22	00:01	LINE CLEAR AVOIDED
3371	23-Jan-24	Bangalore	66	SOMANAHALLI 220 - HAROHALLI 2	INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT), VR DODDI	11:18	11:29	00:11	TRIPPED ON FAULT
3372	23-Jan-24	Bangalore	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR, YEDUMADU	17:36	17:37	00:01	LINE CLEAR AVOIDED
3373	23-Jan-24	Bangalore	66	SRINIVASPURA 66 - CHINTAMANI 220	SRINIVASPURA 66	13:00	13:08	00:08	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3374	23-Jan-24	Bangalore	66	SUBRAMANYAPURA 220 - REMCO 2	REMCO(HV1), GLOBAL TECH PARK	08:36	08:46	00:10	TRIPPED ON FAULT
3375	23-Jan-24	Bangalore	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	07:50	08:20	00:30	TRIPPED ON FAULT
3376	23-Jan-24	Bangalore	66	TADIGOLU CROSS - CHINTAMANI 220	TADIGOLU CROSS	19:20	19:30	00:10	LINE CLEAR AVAILED
3377	23-Jan-24	Bangalore	66	VEMGAL - KYALANUR	KYALANUR	07:10	07:43	00:33	LOAD CURTAILMENT
3378	23-Jan-24	Bangalore	66	VIJAYAPURA - DB PURA 220	VIJAYAPURA	10:30	14:45	04:15	LINE CLEAR AVAILED
3379	23-Jan-24	Bangalore	66	VIKAS TECH PARK 220 - PRIMAL	PRIMAL	10:55	14:20	03:25	LINE CLEAR AVAILED
3380	23-Jan-24	GULBARGA	110	AFZALPUR-CHOWDAPUR	AFZALPUR_110	23:41	23:46	00:05	MAIN SUPPLY FAILURE
3381	23-Jan-24	GULBARGA	110	BELLARY NORTH-PDHALLI	MOKA_110,PD_HALLI_110,BI SIHALLI_110	08:10	19:30	11:20	LINE CLEAR AVAILED
3382	23-Jan-24	GULBARGA	110	HANAWAL-MARALIHALLA	YARADONA_110, BENNUR_110	14:15	21:05	06:50	LINE CLEAR AVAILED
3383	23-Jan-24	GULBARGA	110	HV1	ADAVIAMARESHWAR_110	11:13	11:15	00:02	LINE CLEAR AVAILED
3384	23-Jan-24	GULBARGA	110	HV1	ADAVIAMARESHWAR_110	17:05	17:06	00:01	LINE CLEAR AVAILED
3385	23-Jan-24	GULBARGA	110	HV3	SOMASAMUNDRA_110	06:56	07:14	00:18	TRIPPED ON FAULT
3386	23-Jan-24	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDGAL_110, BAYYAPUR_110	21:35	21:44	00:09	TRIPPED ON FAULT
3387	23-Jan-24	GULBARGA	110	LV1	ITTAGI_220	18:47	19:47	01:00	TRIPPED ON FAULT
3388	23-Jan-24	GULBARGA	110	LV2	ITTAGI_220	18:48	19:05	00:17	TRIPPED ON FAULT
3389	23-Jan-24	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110,DEVAPUR_110	23:10	23:16	00:06	TRIPPED ON FAULT
3390	23-Jan-24	GULBARGA	110	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	21:54	22:04	00:10	TRIPPED ON FAULT
3391	23-Jan-24	GULBARGA	110	SINDHANOOR-SR NAGAR	KARATAGI_110	18:30	20:50	02:20	LINE CLEAR AVAILED
3392	23-Jan-24	GULBARGA	220	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	8:44(23.01.2024)			LINE CLEAR AVAILED
3393	23-Jan-24	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	8:52(23.012024)			LINE CLEAR AVAILED
3394	23-Jan-24	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	11:28	11:34	00:06	LINE CLEAR AVAILED
3395	23-Jan-24	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	16:11	19:10	02:59	LINE CLEAR AVAILED
3396	23-Jan-24	HASSAN	66	HASSN22-BELUR	HASSAN_220	16:11	18:17	02:06	LINE CLEAR AVAILED
3397	23-Jan-24	HASSAN	66	HASSN22-HN PURA	HASSAN_220	16:11	18:17	02:06	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3398	23-Jan-24	HASSAN	66	HASSN22-MALLALI	HASSAN_220	18:33	19:08	00:35	LINE CLEAR AVOIDED
3399	23-Jan-24	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	18:33	18:37	00:04	LINE CLEAR AVOIDED
3400	23-Jan-24	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	19:05	19:08	00:03	LINE CLEAR AVOIDED
3401	23-Jan-24	HASSAN	66	HASSN22-SKPURA	HASSAN_220	18:37	19:15	00:38	LINE CLEAR AVOIDED
3402	23-Jan-24	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	18:37	18:44	00:07	LINE CLEAR AVOIDED
3403	23-Jan-24	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	19:10	19:14	00:04	LINE CLEAR AVOIDED
3404	23-Jan-24	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	16:13	18:11	01:58	LINE CLEAR AVOIDED
3405	23-Jan-24	HASSAN	66	HNPR2-HNPR1	HNPURA_220	10:20	17:47	07:27	LINE CLEAR AVOIDED
3406	23-Jan-24	HASSAN	66	HNPURA-HASSAN	HNPURA_66	10:50	17:50	07:00	MAIN SUPPLY FAILURE
3407	23-Jan-24	HASSAN	66	HNPURA-RAMNATHPURA	HNPURA_66	10:22	17:49	07:27	MAIN SUPPLY FAILURE
3408	23-Jan-24	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	10:22	17:49	07:27	MAIN SUPPLY FAILURE
3409	23-Jan-24	HASSAN	66	HV1	HNPURA_66	10:22	17:49	07:27	MAIN SUPPLY FAILURE
3410	23-Jan-24	HASSAN	66	HV2	HNPURA_66	10:22	17:49	07:27	MAIN SUPPLY FAILURE
3411	23-Jan-24	HASSAN	66	HV2	RAMNATHPURA_66	11:59	14:17	02:18	LINE CLEAR AVOIDED
3412	23-Jan-24	HASSAN	66	LV1	HASSAN_220	18:41	19:05	00:24	LINE CLEAR AVOIDED
3413	23-Jan-24	HASSAN	66	LV2	HASSAN_220	16:19	18:05	01:46	LINE CLEAR AVOIDED
3414	23-Jan-24	HASSAN	110	HV1	NAVUNDA_110	11:45	15:34	03:49	LINE CLEAR AVOIDED
3415	23-Jan-24	HASSAN	110	HV2	NAVUNDA_110	10:35	15:35	05:00	LINE CLEAR AVOIDED
3416	23-Jan-24	HASSAN	110	HV3	BANTWAL_110	15:36	16:25	00:49	LINE CLEAR AVOIDED
3417	23-Jan-24	HASSAN	110	LV1	KEMAR_220	10:37	13:10	02:33	LINE CLEAR AVOIDED
3418	23-Jan-24	HASSAN	110	NAVUNDA-MADHUVANA	NAVUNDA_110	11:58	15:31	03:33	LINE CLEAR AVOIDED
3419	23-Jan-24	HASSAN	110	SAGARA-SORABA	SAGARA_110	11:00	12:35	01:35	LINE CLEAR AVOIDED
3420	23-Jan-24	HASSAN	220	HV1	HASSAN_220	18:41	19:02	00:21	LINE CLEAR AVOIDED
3421	23-Jan-24	HASSAN	220	HV1	KEMAR_220	10:37	13:10	02:33	LINE CLEAR AVOIDED
3422	23-Jan-24	HASSAN	220	HV2	HASSAN_220	16:19	18:03	01:44	LINE CLEAR AVOIDED
3423	23-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	12:46	17:33	04:47	LINE CLEAR AVOIDED
3424	23-Jan-24	HASSAN	220	SHARAVTY-SHMGA1	gen_sharavaty	12:46	17:33	04:47	LINE CLEAR AVOIDED
3425	23-Jan-24	MYSORE	66	CHANDRAWADI-KADAKOLA	HULLAHALLI_66	10:36	17:26	06:50	LINE CLEAR AVOIDED
3426	23-Jan-24	MYSORE	66	CR NAGARA-KOLLEGALA	GARGESHWARI_66 JANNUR_66 MUGUR_66 S TNARASIPURA_66 THAYURU_66	12:01	12:06	00:04	TRIPPED ON FAULT
3427	23-Jan-24	MYSORE	66	CR NAGARA-KOLLEGALA	GARGESHWARI_66 JANNUR_66 MUGUR_66 S TNARASIPURA_66 THAYURU_66	22:43	22:51	00:08	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3428	23-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	20:07			LINE CLEAR AVAILED
3429	23-Jan-24	MYSORE	66	HULLAHALLI-DOORA	HULLAHALLI_66	10:00	17:27	07:27	LINE CLEAR AVAILED
3430	23-Jan-24	MYSORE	66	HV1	BGPURA_66	12:58	15:00	02:01	LINE CLEAR AVAILED
3431	23-Jan-24	MYSORE	66	HV1	HANGLA_66	15:27	16:39	01:11	LINE CLEAR AVAILED
3432	23-Jan-24	MYSORE	66	HV1	HULLAHALLI_66	10:00	17:28	07:28	LINE CLEAR AVAILED
3433	23-Jan-24	MYSORE	66	HV1	KIRUGAVALU_66	17:36	17:37	00:01	LINE CLEAR AVAILED
3434	23-Jan-24	MYSORE	66	HV1	KIRUGAVALU_66	17:39	17:40	00:01	LINE CLEAR AVAILED
3435	23-Jan-24	MYSORE	66	HV1	KRISHNAPURA_66	10:00	15:30	05:30	LINE CLEAR AVAILED
3436	23-Jan-24	MYSORE	66	HV1	SANTHEBACHALLI_66	10:00	17:00	07:00	LINE CLEAR AVAILED
3437	23-Jan-24	MYSORE	66	HV2	GUNDULPET_66	16:25	17:50	01:25	LINE CLEAR AVAILED
3438	23-Jan-24	MYSORE	66	HV2	HANGLA_66	15:35	15:40	00:05	TRIPPED ON FAULT
3439	23-Jan-24	MYSORE	66	HV2	HONNALLY_MYS_66	20:05	20:15	00:10	TRIPPED ON FAULT
3440	23-Jan-24	MYSORE	66	HV2	HULLAHALLI_66	10:00	17:28	07:28	LINE CLEAR AVAILED
3441	23-Jan-24	MYSORE	66	HV2	KIRUGAVALU_66	17:36	17:37	00:01	LINE CLEAR AVAILED
3442	23-Jan-24	MYSORE	66	HV2	KRISHNAPURA_66	10:00	15:30	05:30	LINE CLEAR AVAILED
3443	23-Jan-24	MYSORE	66	HV2	KOPPA_66	10:20	16:30	06:10	LINE CLEAR AVAILED
3444	23-Jan-24	MYSORE	66	HV2	SANTHEBACHALLI_66	10:00	17:00	07:00	LINE CLEAR AVAILED
3445	23-Jan-24	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66	22:26	22:38	00:12	TRIPPED ON FAULT
3446	23-Jan-24	MYSORE	66	KR PETE 220-CR PATNA	KRISHNAPURA_66	12:11	14:01	01:50	LINE CLEAR AVAILED
3447	23-Jan-24	MYSORE	66	KR PETE 220-SANTHEBACHALLI 1	NO STATIONS EFFECTED	12:09	13:36	01:26	LINE CLEAR AVAILED
3448	23-Jan-24	MYSORE	66	KR PETE 220-SANTHEBACHALLI 2	NO STATIONS EFFECTED	13:40	16:46	03:05	LINE CLEAR AVAILED
3449	23-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	07:59	10:02	02:02	LINE CLEAR AVAILED
3450	23-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	18:30	18:36	00:06	TRIPPED ON FAULT
3451	23-Jan-24	MYSORE	66	SFC SIVA-PGL	NO STATIONS EFFECTED	10:40	12:57	02:17	LINE CLEAR AVAILED
3452	23-Jan-24	MYSORE	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	10:40	13:31	02:51	LINE CLEAR AVAILED
3453	23-Jan-24	MYSORE	220	HV2	TUBINAKERE_220	10:26	19:54	09:27	LINE CLEAR AVAILED
3454	23-Jan-24	TUMKUR	66	ANCHEPALYA 220-HEBBUR	HEBBUR_66	07:13	07:37	00:24	MAIN SUPPLY FAILURE
3455	23-Jan-24	TUMKUR	66	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66,ADICHUCHAN AGIRI_66, B G NAGARA_66	07:13	07:35	00:22	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3456	23-Jan-24	TUMKUR	66	ANCHEPALYA 220kV- BG NAGAR	JIDDIGERE_66, YEDIYUR_66,ADICHUCHAN AGIRI_66, B G NAGARA_66	16:39	16:49	00:10	TRIPPED ON FAULT
3457	23-Jan-24	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	07:13	07:38	00:25	MAIN SUPPLY FAILURE
3458	23-Jan-24	TUMKUR	66	BANUVALLI- HONNALLI	NANDIGUDI_66,MALEBENNUR_66	10:10	16:00	05:50	LINE CLEAR AVAILED
3459	23-Jan-24	TUMKUR	66	BENKIKERE 220kV- DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREKILCHI_66	21:08	21:16	00:08	TRIPPED ON FAULT
3460	23-Jan-24	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	HDPURA_66, CHITRAHALLI_66	07:01	07:22	00:21	LINE CLEAR AVAILED
3461	23-Jan-24	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	07:01	07:12	00:11	LINE CLEAR AVAILED
3462	23-Jan-24	TUMKUR	66	Davangere SRS _ Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	12:31	12:54	00:23	TRIPPED ON FAULT
3463	23-Jan-24	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHARA_66	09:06	09:20	00:14	LINE CLEAR AVAILED
3464	23-Jan-24	TUMKUR	66	DEVARAHALLI- KEREKILCHI	DEVARAHALLI_66	21:08	21:16	00:08	MAIN SUPPLY FAILURE
3465	23-Jan-24	TUMKUR	66	HOLALKERE- PANDRAHALLI2	HOLALKERE_66	07:00	07:22	00:22	MAIN SUPPLY FAILURE
3466	23-Jan-24	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	10:20	13:31	03:11	LINE CLEAR AVAILED
3467	23-Jan-24	TUMKUR	66	HONNALLI 220kV- NALLUR_66	BASAVAPATNA_66,	09:10	09:24	00:14	LOAD CURTAILMENT
3468	23-Jan-24	TUMKUR	66	HV1(TR1)	HANGAL_66	17:15	17:38	00:22	LINE CLEAR AVAILED
3469	23-Jan-24	TUMKUR	66	HV1(TR1)	YEDIYUR_66	06:57	08:25	01:27	LINE CLEAR AVAILED
3470	23-Jan-24	TUMKUR	66	HV2(TR2)	HIREHALLI_66	11:32	13:45	02:12	LINE CLEAR AVAILED
3471	23-Jan-24	TUMKUR	66	HV2(TR2)	HONNUDIKE_66	12:30	12:45	00:15	LINE CLEAR AVAILED
3472	23-Jan-24	TUMKUR	66	HV2(TR2)	KUKKAWADA_66	12:05	14:33	02:28	TRIPPED ON FAULT
3473	23-Jan-24	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	21:39	21:52	00:12	TRIPPED ON FAULT
3474	23-Jan-24	TUMKUR	66	NANDIHALLI - BANUVALLI_66	NANDIHALLI_66	10:10	16:20	06:10	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3475	23-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3476	23-Jan-24	TUMKUR	66	TURUVANUR66-CHITRADURGA	TURUVANUR_66	06:59	07:36	00:37	MAIN SUPPLY FAILURE
3477	23-Jan-24	TUMKUR	220	CHITRADURGA 220-GUTTUR 220	GUTTUR 220	10:07	13:30	03:23	LINE CLEAR AVAILED
3478	23-Jan-24	TUMKUR	220	HV2(TR2)	ANCHEPALYA_220	07:13	07:33	00:20	TRIPPED ON FAULT
3479	23-Jan-24	TUMKUR	220	MADHUGIRI 220kV-PAVAGADA_220 2	PAVAGADA_220	10:54	16:07	05:13	LINE CLEAR AVAILED
3480	23-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
3481	23-Jan-24	TUMKUR	400	GUTTUR 400kV- BTPS	GUTTUR_400	08:54	18:43	09:49	LINE CLEAR AVAILED
3482	24-Jan-24	BAGALKOT	110	110/11KV, HV1(20MVA)	HIREKERUR_110	10:14	18:54	08:40	LINE CLEAR AVAILED
3483	24-Jan-24	BAGALKOT	110	110/11KV, HV2(10MVA)	SUARNASOUDA_110	11:05	11:31	00:26	LINE CLEAR AVAILED
3484	24-Jan-24	BAGALKOT	110	110/11KV, HV2(20MVA)	BANAHATTI_110	09:57	11:57	02:00	LINE CLEAR AVAILED
3485	24-Jan-24	BAGALKOT	110	110/11KV, HV2(20MVA)	NIDAGUNDI_110	17:34	17:59	00:25	LINE CLEAR AVAILED
3486	24-Jan-24	BAGALKOT	110	110/11KV, HV2(20MVA)	SIRSI_110	11:50	11:55	00:05	LINE CLEAR AVAILED
3487	24-Jan-24	BAGALKOT	110	110/11KV, HV2A(10MVA)	JAMKHANDI_110	11:01	11:33	00:32	LINE CLEAR AVAILED
3488	24-Jan-24	BAGALKOT	110	110/11KV, HV4(20MVA)	KULIGOD_110	12:01	12:15	00:14	TRIPPED ON FAULT
3489	24-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	HALIYAL_110	04:50	09:10	04:20	TRIPPED ON FAULT
3490	24-Jan-24	BAGALKOT	110	110/33KV, HV2(20MVA)	HANGAL_110	09:46	09:57	00:11	TRIPPED ON FAULT
3491	24-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	KULIGOD_110	16:15	17:01	00:46	LINE CLEAR AVAILED
3492	24-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVAILED
3493	24-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	HONNAVAR_110	09:34	14:13	04:39	LINE CLEAR AVAILED
3494	24-Jan-24	BAGALKOT	110	GHATAPRABHA-KABBUR(NAGAR MUNAVALLI)	STATION NOT AFFECTED GHATAPRABHA_220	09:58	15:23	05:25	LINE CLEAR AVAILED
3495	24-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
3496	24-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)			LINE CLEAR AVAILED
3497	24-Jan-24	BAGALKOT	110	HUNGUND- B. BAGEWADI (KUDAL SANGAM)	HUNGUND_110	06:31	06:44	00:13	TRIPPED ON FAULT
3498	24-Jan-24	BAGALKOT	110	HUNGUND- ILKAL2	HUNGUND_110	06:31	06:43	00:12	TRIPPED ON FAULT
3499	24-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3500	24-Jan-24	BAGALKOT	110	KAMBAGI-F2(TODALBAGI)	STATION NOT AFFECTED KAMBAGI_110	12:12 (23.01.2024)	18:09 (24.01.2024)	29:57:00	LINE CLEAR AVOIDED
3501	24-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
3502	24-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVOIDED
3503	24-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3504	24-Jan-24	BAGALKOT	110	MUNDAGOD-SRS HUBLI	STATION NOT AFFECTED MUNDAGOD_110	6:37 (24.01.2024)			LINE CLEAR AVOIDED
3505	24-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVOIDED
3506	24-Jan-24	BAGALKOT	110	SHIGGAON220-MUNDGOD	STATION NOT AFFECTED SHIGGAON_220	06:19	18:59	12:40	TRIPPED ON FAULT
3507	24-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVOIDED
3508	24-Jan-24	BAGALKOT	220	NARENDRA - HUBLI1	STATION NOT AFFECTED NARENDRA_220	13:38	13:58	00:20	TRIPPED ON FAULT
3509	24-Jan-24	BAGALKOT	220	NARENDRA - HUBLI2	STATION NOT AFFECTED NARENDRA_220	13:38	18:45	05:07	TRIPPED ON FAULT
3510	24-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED MAHALINGAPUR_220	9:20 (23.01.2024)	19:44 (24.01.2024)	34:24:00	LINE CLEAR AVOIDED
3511	24-Jan-24	BAGALKOT	220	220/110KV,HV1,LV1	KUDUCHI_220	11:24	22:42	11:18	LINE CLEAR AVOIDED
3512	24-Jan-24	BAGALKOT	220	ATHANI-GHATANATTI	STATION NOT AFFECTED ATHANI_220	04:33	04:53	00:20	TRIPPED ON FAULT
3513	24-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
3514	24-Jan-24	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	16:36	20:14	03:38	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3515	24-Jan-24	BAGALKOT	220	HUBLI- NAGJHARI-3	STATION NOT AFFECTED HUBLI_220	16:38	17:59	01:21	TRIPPED ON FAULT
3516	24-Jan-24	BAGALKOT	220	HUBLI-NARENDRA-1	STATION NOT AFFECTED HUBLI_220	13:39	18:44	05:05	TRIPPED ON FAULT
3517	24-Jan-24	BAGALKOT	220	NARENDRA- KANBARGI1	STATION NOT AFFECTED NARENDRA_220	10:32	19:33	09:01	LINE CLEAR AVAILED
3518	24-Jan-24	BAGALKOT	220	RANEBENNUR- HIREKERUR	STATION NOT AFFECTED RANEBENNUR_220	12:50	19:00	06:10	LINE CLEAR AVAILED
3519	24-Jan-24	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)	8:48 (24.01.2024)	216:21:00	LINE CLEAR AVAILED
3520	24-Jan-24	BAGALKOT	220	SIRSI- HUBLI-1	STATION NOT AFFECTED SIRSI_220	16:05 (24.01.2024)			LINE CLEAR AVAILED
3521	24-Jan-24	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	8:27 (15.01.2024)	8:49 (24.01.2024)	216:22:00	LINE CLEAR AVAILED
3522	24-Jan-24	BAGALKOT	220	SIRSI- HUBLI-2	STATION NOT AFFECTED SIRSI_220	16:05 (24.01.2024)			LINE CLEAR AVAILED
3523	24-Jan-24	BAGALKOT	220	SIRSI220- SHARAVATI-1	STATION NOT AFFECTED SIRSI_220	08:48	16:05	07:17	LINE CLEAR AVAILED
3524	24-Jan-24	BAGALKOT	220	SIRSI220- SHARAVATI-2	STATION NOT AFFECTED SIRSI_220	08:49	16:05	07:16	LINE CLEAR AVAILED
3525	24-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3526	24-Jan-24	BAGALKOT	220	VAJRAMATTI220-KATARAKI	STATION NOT AFFECTED VAJRARMATTI_220	23:28	23:46	00:18	LINE CLEAR AVAILED
3527	24-Jan-24	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	09:37	10:18	00:41	MAIN SUPPLY FAILURE
3528	24-Jan-24	BANGALORE	66	ATTIBELE - SARJAPURA 220	ATTIBELE	18:40	20:01	01:21	MAIN SUPPLY FAILURE
3529	24-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3530	24-Jan-24	BANGALORE	66	CESSNA - SHOBHA APARTMENT	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL(EHT)	10:25	10:28	00:03	LINE CLEAR AVAILED
3531	24-Jan-24	BANGALORE	66	CESSNA - SHOBHA APARTMENT	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL(EHT)	22:38	22:41	00:03	LINE CLEAR AVAILED
3532	24-Jan-24	BANGALORE	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI, BRIGADE ORCHARDS	10:17	15:55	05:38	LINE CLEAR AVAILED
3533	24-Jan-24	BANGALORE	66	DB PURA 220 - KUNDANA	KUNDANA	10:17	16:21	06:04	LINE CLEAR AVAILED
3534	24-Jan-24	BANGALORE	66	DIBBURAHALLI - GANJIGUNTE	DIBBURAHALLI	16:19	16:26	00:07	LINE CLEAR AVAILED
3535	24-Jan-24	BANGALORE	66	DIBBURAHALLI - SADALI	DIBBURAHALLI	14:00	14:10	00:10	LINE CLEAR AVAILED
3536	24-Jan-24	BANGALORE	66	DIBBURAHALLI - SADALI	DIBBURAHALLI	17:59	18:09	00:10	LINE CLEAR AVAILED
3537	24-Jan-24	BANGALORE	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	22:35	22:40	00:05	LINE CLEAR AVAILED
3538	24-Jan-24	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	09:37	10:20	00:43	MAIN SUPPLY FAILURE
3539	24-Jan-24	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	18:40	20:10	01:30	MAIN SUPPLY FAILURE
3540	24-Jan-24	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	20:10	20:20	00:10	LINE CLEAR AVAILED
3541	24-Jan-24	BANGALORE	66	ELITA PROMENENDE - KHODAYS 220	ELITA PROMENENDE	07:55	07:57	00:02	LINE CLEAR AVAILED
3542	24-Jan-24	BANGALORE	66	EXORA 220 - CESSNA	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL(EHT)	09:37	10:04	00:27	MAIN SUPPLY FAILURE
3543	24-Jan-24	BANGALORE	66	EXORA 220 - CESSNA	CESSNA, EXORA 66, KALYANI TECH PARK, ORACEL(EHT)	18:40	19:30	00:50	MAIN SUPPLY FAILURE
3544	24-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE, SASALU	07:45	08:15	00:30	LOAD CURTAILMENT
3545	24-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE, SASALU	13:15	15:12	01:57	TRIPPED ON FAULT
3546	24-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 1	MANCHENAHALLI, GUNDAMGERE, SASALU	15:12	17:28	02:16	LINE CLEAR AVAILED
3547	24-Jan-24	BANGALORE	66	GUNDAMGERE - GOWRIBIDANUR 220	GUNDAMGERE, SASALU	07:58	08:03	00:05	LINE CLEAR AVAILED
3548	24-Jan-24	BANGALORE	66	HAL 220 - ADUGODI 2	GOLF LINK, AMARJYOTHI(HV2)	22:18	22:35	00:17	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3549	24-Jan-24	BANGALORE	66	HBR LAYOUT 66 - HBR LAYOUT 220	HBR LAYOUT 66, LR BANDE	14:49	15:00	00:11	LINE CLEAR AVAILED
3550	24-Jan-24	BANGALORE	66	HSR LAYOUT 220 - ST JOHN WOOD	ST JOHN WOOD	19:06	19:11	00:05	LINE CLEAR AVAILED
3551	24-Jan-24	BANGALORE	66	HV1	MITTEMARI 220	12:45	13:55	01:10	LINE CLEAR AVAILED
3552	24-Jan-24	BANGALORE	66	HV1	SRINIVASAPURA 220	15:38	18:00	02:22	TRIPPED ON FAULT
3553	24-Jan-24	BANGALORE	66	HV1	TAYALUR	01:10	04:45	03:35	LINE CLEAR AVAILED
3554	24-Jan-24	BANGALORE	66	HV1	HUKUNDA	12:40	12:45	00:05	LINE CLEAR AVAILED
3555	24-Jan-24	BANGALORE	66	HV1	CHANDRAPPA CIRCLE	06:40	06:45	00:05	TRIPPED ON FAULT
3556	24-Jan-24	BANGALORE	66	HV1	SARJAPURA 220	09:37	10:17	00:40	MAIN SUPPLY FAILURE
3557	24-Jan-24	BANGALORE	66	HV1	SARJAPURA 220	18:40	19:54	01:14	MAIN SUPPLY FAILURE
3558	24-Jan-24	BANGALORE	66	HV2	VIJAYANAGARA	00:00	00:55	00:55	TRIPPED ON FAULT
3559	24-Jan-24	BANGALORE	66	HV2	NAGANATHPURA 220	11:02	11:07	00:05	LINE CLEAR AVAILED
3560	24-Jan-24	BANGALORE	66	HV2	KONDASAPURA	15:15	15:20	00:05	LINE CLEAR AVAILED
3561	24-Jan-24	BANGALORE	66	HV2	TAYALUR	01:10	04:45	03:35	LINE CLEAR AVAILED
3562	24-Jan-24	BANGALORE	66	HV2	HUKUNDA	14:05	14:10	00:05	LINE CLEAR AVAILED
3563	24-Jan-24	BANGALORE	66	HV2	SARJAPURA 220	09:37	10:18	00:41	MAIN SUPPLY FAILURE
3564	24-Jan-24	BANGALORE	66	HV2	SARJAPURA 220	18:40	19:54	01:14	MAIN SUPPLY FAILURE
3565	24-Jan-24	BANGALORE	66	HV3	YARANDANAHALLI 220	17:30	20:35	03:05	TRIPPED ON FAULT
3566	24-Jan-24	BANGALORE	66	HV3	YARANDANAHALLI 220	20:35	21:57	01:22	TRIPPED ON FAULT
3567	24-Jan-24	BANGALORE	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	10:30	15:10	04:40	LINE CLEAR AVAILED
3568	24-Jan-24	BANGALORE	66	JANGAMKOTE - CHINTAMANI 220	JANGAMKOTE	16:19	16:25	00:06	LINE CLEAR AVAILED
3569	24-Jan-24	BANGALORE	66	JANGAMKOTE - VIJAYAPURA	JANGAMKOTE	10:09	10:14	00:05	LINE CLEAR AVAILED
3570	24-Jan-24	BANGALORE	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, GODURU	10:05	18:12	08:07	LINE CLEAR AVAILED
3571	24-Jan-24	BANGALORE	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	10:28	10:30	00:02	LINE CLEAR AVAILED
3572	24-Jan-24	BANGALORE	66	KHODAYS 220 - PRESTIGE FALCON CTIY	PRESTIGE FALCON CITY	10:28	10:30	00:02	LINE CLEAR AVAILED
3573	24-Jan-24	BANGALORE	66	KUDMALKUNTE - TERIYURU	TERIYURU	07:45	08:37	00:52	LOAD CURTAILMENT
3574	24-Jan-24	BANGALORE	66	LAKKUR - MALUR 220	LAKKUR, DEVANAGUNDHI	04:45	05:05	00:20	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3575	24-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	02:06	02:14	00:08	TRIPPED ON FAULT
3576	24-Jan-24	BANGALORE	66	RAJANUKUNTE - YELAHANKA 220	RAJANUKUNTE	11:45	11:55	00:10	LINE CLEAR AVAILED
3577	24-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	10:12	10:18	00:06	MAIN SUPPLY FAILURE
3578	24-Jan-24	BANGALORE	66	RMZ - VIKAS TECH PARK 220	RMZ	20:02	20:07	00:05	MAIN SUPPLY FAILURE
3579	24-Jan-24	BANGALORE	66	SOUTH CITY - RBI	SOUTH CITY	13:05	13:48	00:43	LINE CLEAR AVAILED
3580	24-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - NANGLI	NANGLI, BAIRKURU	03:02	04:32	01:30	LINE CLEAR AVAILED
3581	24-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	00:02	00:12	00:10	TRIPPED ON FAULT
3582	24-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	03:02	04:32	01:30	LINE CLEAR AVAILED
3583	24-Jan-24	BANGALORE	66	TAYALUR - NG HULKUR	NG HULKUR	00:32	04:42	04:10	TRIPPED ON FAULT
3584	24-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	09:37	09:51	00:14	MAIN SUPPLY FAILURE
3585	24-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	18:40	18:50	00:10	MAIN SUPPLY FAILURE
3586	24-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	09:37	09:51	00:14	MAIN SUPPLY FAILURE
3587	24-Jan-24	BANGALORE	66	VIKAS TECH PARK 220 - RMZ	RMZ	20:02	20:07	00:05	MAIN SUPPLY FAILURE
3588	24-Jan-24	BANGALORE	220	EXORA 220 - MALUR 220	EXORA 220	09:37	10:04	00:27	MAIN SUPPLY FAILURE
3589	24-Jan-24	BANGALORE	220	EXORA 220 - MALUR 220	EXORA 220	18:40	19:30	00:50	MAIN SUPPLY FAILURE
3590	24-Jan-24	BANGALORE	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	09:37	09:51	00:14	TRIPPED ON FAULT
3591	24-Jan-24	BANGALORE	220	HOODY 220 - MALUR 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	18:40	18:50	00:10	TRIPPED ON FAULT
3592	24-Jan-24	BANGALORE	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	09:37	10:10	00:33	MAIN SUPPLY FAILURE
3593	24-Jan-24	BANGALORE	220	MALUR 220 - HOODY 220	SARJAPURA 220, VIKAS TECH PARK 220, EXORA 220	18:40	20:39	01:59	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3594	24-Jan-24	BANGALORE	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	09:37	10:15	00:38	MAIN SUPPLY FAILURE
3595	24-Jan-24	GULBARGA	66	HV1	BANAVEKAL_66	12:55	13:00	00:05	TRIPPED ON FAULT
3596	24-Jan-24	GULBARGA	66	KUDALGI-GUDDEKOTE	GUDDEKOTE_66, CJ HALLI_66, HOSAHALLI_66	05:45	24:00:00	18:15	TRIPPED ON FAULT
3597	24-Jan-24	GULBARGA	66	KUDALGI-HANASI	HANASI_66, CHILAKANAHATTI_66	03:30	03:45	00:15	TRIPPED ON FAULT
3598	24-Jan-24	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66,SUZL ON WIND_IPP	10:23	18:38	08:15	LINE CLEAR AVAILED
3599	24-Jan-24	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUNDRA_110,ACC EHT_IPP	08:10	20:11	12:01	LINE CLEAR AVAILED
3600	24-Jan-24	GULBARGA	110	GURMITKAL-SEDAM	GURMITKAL_110	11:49	15:30	03:41	LINE CLEAR AVAILED
3601	24-Jan-24	GULBARGA	110	HV1	ALIPUR_220	16:35	17:40	01:05	LINE CLEAR AVAILED
3602	24-Jan-24	GULBARGA	110	KUSHTAGI-ILKAL2	ILKAL_110	06:24	06:41	00:17	TRIPPED ON FAULT
3603	24-Jan-24	GULBARGA	110	MADIYAL-KAPNOOR	MADIYAL_110	00:38	00:43	00:05	MAIN SUPPLY FAILURE
3604	24-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	10:15	13:47	03:32	LINE CLEAR AVAILED
3605	24-Jan-24	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110,KAMALAPUR_110,KUDITINI_110	08:10	17:32	09:22	LINE CLEAR AVAILED
3606	24-Jan-24	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110,DEVAPUR_110	06:19	06:24	00:05	TRIPPED ON FAULT
3607	24-Jan-24	GULBARGA	110	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	09:20	12:45	03:25	LINE CLEAR AVAILED
3608	24-Jan-24	GULBARGA	110	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	12:50(24.01.2024)			LINE CLEAR AVAILED
3609	24-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR 2	SINDHANOOR_110	09:15(24.01.2024)			LINE CLEAR AVAILED
3610	24-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	09:15	12:45	03:30	LINE CLEAR AVAILED
3611	24-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	12:50(24.01.2024)			LINE CLEAR AVAILED
3612	24-Jan-24	GULBARGA	110	SINDHANOOR-WALABALLARY	WALABALLARY_110	09:30(24.01.2024)			LINE CLEAR AVAILED
3613	24-Jan-24	GULBARGA	220	HV1	MUNIRABAD_220	09:01	12:56	03:55	LINE CLEAR AVAILED
3614	24-Jan-24	GULBARGA	220	HV1	ITTAGI_220	06:46	07:00	00:14	TRIPPED ON FAULT
3615	24-Jan-24	GULBARGA	220	HV1	ITTAGI_220	08:52	08:55	00:03	TRIPPED ON FAULT
3616	24-Jan-24	GULBARGA	220	HV1 & HV2	ITTAGI_220	17:57	18:41	00:44	TRIPPED ON FAULT
3617	24-Jan-24	GULBARGA	220	HV2	MUNIRABAD_220	13:09	17:12	04:03	LINE CLEAR AVAILED
3618	24-Jan-24	GULBARGA	220	LINGAPUR-MUNIRABAD	MUNIRABAD_220	09:02	12:56	03:54	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3619	24-Jan-24	GULBARGA	220	LINGAPUR-MUNIRABAD	MUNIRABAD_220	13:08	17:10	04:02	LINE CLEAR AVAILED
3620	24-Jan-24	GULBARGA	220	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	8:44(23.01.2024)			LINE CLEAR AVAILED
3621	24-Jan-24	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	8:52(23.012024)			LINE CLEAR AVAILED
3622	24-Jan-24	HASSAN	66	ARAKALGUD	HASSAN_220	11:47	11:51	00:04	LINE CLEAR AVAILED
3623	24-Jan-24	HASSAN	66	AREHALI-SAKLESPUR	AREHALLI_66	14:10	15:08	00:58	MAIN SUPPLY FAILURE
3624	24-Jan-24	HASSAN	66	HANUBAL-SAKLESPUR	HANUBALU_66	14:09	15:00	00:51	MAIN SUPPLY FAILURE
3625	24-Jan-24	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	08:18	21:43	13:25	LINE CLEAR AVAILED
3626	24-Jan-24	HASSAN	66	HNPR2-MYSOR2	HNPURA_220	15:33	15:44	00:11	TRIPPED ON FAULT
3627	24-Jan-24	HASSAN	66	HNPR2-RNPR1	HNPURA_220	08:30	18:40	10:10	LINE CLEAR AVAILED
3628	24-Jan-24	HASSAN	66	HV1	AREHALLI_66	13:05	15:15	02:10	LINE CLEAR AVAILED
3629	24-Jan-24	HASSAN	66	HV1	HANUBALU_66	14:09	15:00	00:51	MAIN SUPPLY FAILURE
3630	24-Jan-24	HASSAN	66	HV1	NAGARTHI_66	15:35	15:45	00:10	MAIN SUPPLY FAILURE
3631	24-Jan-24	HASSAN	66	HV1	SALAGAME_66	14:10	15:55	01:45	LINE CLEAR AVAILED
3632	24-Jan-24	HASSAN	66	HV1	SALAGAME_66	15:05	15:48	00:43	LINE CLEAR AVAILED
3633	24-Jan-24	HASSAN	66	HV2	AREHALLI_66	15:00	15:15	00:15	LINE CLEAR AVAILED
3634	24-Jan-24	HASSAN	66	HV2	AREHALLI_66	11:20	13:05	01:45	LINE CLEAR AVAILED
3635	24-Jan-24	HASSAN	66	Lv2	HNPURA_220	08:32	21:21	12:49	LINE CLEAR AVAILED
3636	24-Jan-24	HASSAN	66	NGRTHI-KADVINKOTE	NAGARTHI_66	15:35	15:45	00:10	MAIN SUPPLY FAILURE
3637	24-Jan-24	HASSAN	66	NGRTHI-MANGERE	NAGARTHI_66	15:35	15:45	00:10	LINE CLEAR AVAILED
3638	24-Jan-24	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	14:09	15:00	00:51	LINE CLEAR AVAILED
3639	24-Jan-24	HASSAN	66	SALAGAM-HIREMANGLUR	SALAGAME_66	15:49	15:55	00:06	LINE CLEAR AVAILED
3640	24-Jan-24	HASSAN	66	SALAGAM-UDURKOPPLU	SALAGAME_66	15:05	15:48	00:43	LINE CLEAR AVAILED
3641	24-Jan-24	HASSAN	110	ARSK2-BNVARA	ARSIKERE_220	10:28	12:12	01:44	LINE CLEAR AVAILED
3642	24-Jan-24	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	11:49	14:12	02:23	LINE CLEAR AVAILED
3643	24-Jan-24	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	07:47	08:23	00:36	TRIPPED ON FAULT
3644	24-Jan-24	HASSAN	110	BLGMBA-ARSIKERE	BELAGUMBA_110	11:39	14:40	03:01	LINE CLEAR AVAILED
3645	24-Jan-24	HASSAN	110	HV1	BANAVARA_110	10:20	12:05	01:45	LINE CLEAR AVAILED
3646	24-Jan-24	HASSAN	110	HV1	BANAVARA_110	12:15	16:15	04:00	LINE CLEAR AVAILED
3647	24-Jan-24	HASSAN	110	HV1	BELAGUMBA_110	10:00	17:25	07:25	LINE CLEAR AVAILED
3648	24-Jan-24	HASSAN	110	HV1	KONAJE_110	10:36	12:54	02:18	LINE CLEAR AVAILED
3649	24-Jan-24	HASSAN	110	HV2	ANAVATTI_110	18:25	18:46	00:21	TRIPPED ON FAULT
3650	24-Jan-24	HASSAN	110	HV2	BANAVARA_110	13:15	16:45	03:30	LINE CLEAR AVAILED
3651	24-Jan-24	HASSAN	110	HV2	BANAVARA_110	10:20	12:05	01:45	LINE CLEAR AVAILED
3652	24-Jan-24	HASSAN	110	HV2	BELAGUMBA_110	10:00	17:25	07:25	LINE CLEAR AVAILED
3653	24-Jan-24	HASSAN	110	HV2	KONAJE_110	13:00	13:47	00:47	LINE CLEAR AVAILED
3654	24-Jan-24	HASSAN	110	KAVOOR-AMR	KAVOOR_220	09:14	13:20	04:06	LINE CLEAR AVAILED
3655	24-Jan-24	HASSAN	110	LV1	ARSIKERE_220	07:47	08:14	00:27	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3656	24-Jan-24	HASSAN	110	LV1	ARSIKERE_220	12:16	13:35	01:19	LINE CLEAR AVOIDED
3657	24-Jan-24	HASSAN	220	HV1	ARSIKERE_220	12:16	13:35	01:19	LINE CLEAR AVOIDED
3658	24-Jan-24	HASSAN	220	HV1	ARSIKERE_220	07:47	08:11	00:24	TRIPPED ON FAULT
3659	24-Jan-24	HASSAN	220	HV2	HNPURA_220	08:32	21:21	12:49	LINE CLEAR AVOIDED
3660	24-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:35	14:50	04:15	LINE CLEAR AVOIDED
3661	24-Jan-24	HASSAN	220	SHRAVTY-SHIMOGA3	gen_sharavaty	10:33	14:50	04:17	LINE CLEAR AVOIDED
3662	24-Jan-24	MYSORE	66	BEGUR 220-HARVEY	NO STATIONS EFFECTED	02:25	02:35	00:10	TRIPPED ON FAULT
3663	24-Jan-24	MYSORE	66	ELAVALA-HUNSUR	NO STATIONS EFFECTED	10:48	13:08	02:19	LINE CLEAR AVOIDED
3664	24-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	20:07 (23/01/2024)			LINE CLEAR AVOIDED
3665	24-Jan-24	MYSORE	66	HUNSUR-ELAVALA	NO STATIONS EFFECTED	11:10	12:57	01:47	LINE CLEAR AVOIDED
3666	24-Jan-24	MYSORE	66	HUNSUR-HUNSUR-1	NO STATIONS EFFECTED	16:10	18:12	02:01	LINE CLEAR AVOIDED
3667	24-Jan-24	MYSORE	66	HV1	ADDIHALLI_66	10:05	16:09	06:04	LINE CLEAR AVOIDED
3668	24-Jan-24	MYSORE	66	HV1	BEGUR_66	11:56	12:06	00:10	TRIPPED ON FAULT
3669	24-Jan-24	MYSORE	66	HV1	DODDINADUVADI_66	07:37	07:47	00:09	LINE CLEAR AVOIDED
3670	24-Jan-24	MYSORE	66	HV1	GUNDULPET_66	02:03	02:14	00:10	TRIPPED ON FAULT
3671	24-Jan-24	MYSORE	66	HV1	HARVEY_66	11:57	13:25	01:27	LINE CLEAR AVOIDED
3672	24-Jan-24	MYSORE	66	HV1	KIRUGAVALU_66	13:19	13:21	00:02	LINE CLEAR AVOIDED
3673	24-Jan-24	MYSORE	66	HV2	ADDIHALLI_66	10:05	16:09	06:04	LINE CLEAR AVOIDED
3674	24-Jan-24	MYSORE	66	HV2	MANDYA_66	12:01	13:54	01:52	LINE CLEAR AVOIDED
3675	24-Jan-24	MYSORE	66	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66	01:14	01:22	00:07	TRIPPED ON FAULT
3676	24-Jan-24	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	18:13	18:32	00:19	TRIPPED ON FAULT
3677	24-Jan-24	MYSORE	66	KADAKOLA-THANDYA	THANDYA_66	18:13	18:21	00:08	TRIPPED ON FAULT
3678	24-Jan-24	MYSORE	66	KR PETE 220-MAHADESHWARAPURA	G MALLIGERE_66 JAKKANAHALLY_66 MADESWARAPURA_66	10:43	12:43	01:59	LINE CLEAR AVOIDED
3679	24-Jan-24	MYSORE	66	TALAGAVADI-KK DODDI-MADDUR	KIADB SOMANAHALLI_66 MADDUR_66	15:48	16:06	00:18	TRIPPED ON FAULT
3680	24-Jan-24	MYSORE	66	THANDYA-NANJANGUDU	NANJANGUDU_66	18:14	18:40	00:26	TRIPPED ON FAULT
3681	24-Jan-24	MYSORE	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	13:23	13:30	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3682	24-Jan-24	TUMKUR	66	ANTHRASANAHALI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	07:35	07:46	00:10	LOAD CURTAILMENT
3683	24-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	10:30	15:10	04:40	LINE CLEAR AVAILED
3684	24-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 4	CHITRADURGA_220	10:30	14:14	03:44	LINE CLEAR AVAILED
3685	24-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	12:55	15:10	02:15	LINE CLEAR AVAILED
3686	24-Jan-24	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA3	CHITRADURGA_220	10:30	14:14	03:44	LINE CLEAR AVAILED
3687	24-Jan-24	TUMKUR	66	CHITRAHALI-CHITRADURGA	CHITRAHALI_66	10:00	16:30	06:30	LINE CLEAR AVAILED
3688	24-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	16:37	16:47	00:10	TRIPPED ON FAULT
3689	24-Jan-24	TUMKUR	66	HV1(TR1)	CHITRAHALI_66	10:05	19:00	08:55	LINE CLEAR AVAILED
3690	24-Jan-24	TUMKUR	66	HV1(TR1)	HANGAL_66	13:27	13:32	00:04	TRIPPED ON FAULT
3691	24-Jan-24	TUMKUR	66	HV1(TR1)	HONNENAHALLI_66	11:30	14:00	02:30	LINE CLEAR AVAILED
3692	24-Jan-24	TUMKUR	66	HV1(TR1) (12.5MVA)	THIMMASANDRA_66	11:30	18:00	06:30	LINE CLEAR AVAILED
3693	24-Jan-24	TUMKUR	66	HV1(TR1) (8MVA)	THIMMASANDRA_66	10:00	16:15	06:15	LINE CLEAR AVAILED
3694	24-Jan-24	TUMKUR	66	HV1(TR1) (8MVA)	THIMMASANDRA_66	16:45	18:00	01:15	LINE CLEAR AVAILED
3695	24-Jan-24	TUMKUR	66	HV2(TR2)	CHITRAHALI_66	10:05	16:41	06:36	LINE CLEAR AVAILED
3696	24-Jan-24	TUMKUR	66	HV2(TR2)	GARAGA_66	11:58	12:13	00:15	LINE CLEAR AVAILED
3697	24-Jan-24	TUMKUR	66	HV2(TR2)	MALEBENNURU_66	10:53	17:38	06:44	LINE CLEAR AVAILED
3698	24-Jan-24	TUMKUR	66	MADHUGIRI 220kV-PULLAMAGATTA	PULLAMGATTA_66	05:25	05:36	00:11	TRIPPED ON FAULT
3699	24-Jan-24	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJHALLI_66	10:23	18:39	08:16	LINE CLEAR AVAILED
3700	24-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3701	24-Jan-24	TUMKUR	66	TURUVANUR66-JAGALUR	TURUVANUR_66	07:26	07:41	00:15	LINE CLEAR AVAILED
3702	24-Jan-24	TUMKUR	110	HV3(TR3)	AMMASANDRA_110	15:12	15:18	00:06	TRIPPED ON FAULT
3703	24-Jan-24	TUMKUR	220	HIRIYUR220-MADHUGIRI(GOWRIBIDANUR)	MADHUGIRI_220	10:12	16:38	06:25	LINE CLEAR AVAILED
3704	24-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3705	24-Jan-24	TUMKUR	400	JAGALUR 400kV-BPS2(BALLARI400kV)	JAGALUR 400kV	11:52	15:52	03:59	LINE CLEAR AVAILED
3706	25-Jan-24	BAGALKOT	110	110/11KV, HV1 (10MVA)	NAVANAGAR_110	13:00	14:20	01:20	LINE CLEAR AVAILED
3707	25-Jan-24	BAGALKOT	110	110/11KV,HV1 (20MVA)	VAJRAMATTI_110	10:15	14:19	04:04	LINE CLEAR AVAILED
3708	25-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	MUGALKHOD_220	10:02	12:11	02:09	LINE CLEAR AVAILED
3709	25-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	NAVALAGI_110	11:25	12:55	01:30	LINE CLEAR AVAILED
3710	25-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	NIPPANI_110	22:14	23:26	01:12	TRIPPED ON FAULT
3711	25-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVAILED
3712	25-Jan-24	BAGALKOT	110	DAMBAL-MUNDARGI	DAMBAL_110	12:02	12:20	00:18	TRIPPED ON FAULT
3713	25-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
3714	25-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)			LINE CLEAR AVAILED
3715	25-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
3716	25-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3717	25-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3718	25-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3719	25-Jan-24	BAGALKOT	110	MUNDAGOD-SRS HUBLI	STATION NOT AFFECTED MUNDAGOD_110	6:37 (24.01.2024)	10:34 (25.01.2024)	27:57:00	LINE CLEAR AVAILED
3720	25-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
3721	25-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
3722	25-Jan-24	BAGALKOT	110	UAS-F2 Cbreaker (MR NAGAR)	UAS DHARWAD_110	12:15	13:00	00:45	LINE CLEAR AVAILED
3723	25-Jan-24	BAGALKOT	110	VAJRAMATTI220-KATARAKI	VAJARMATTI_220	00:21	00:30	00:09	LINE CLEAR AVAILED
3724	25-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	8:35 (25.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3725	25-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
3726	25-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
3727	25-Jan-24	BAGALKOT	220	NARENDRA-KANABARGI1	NARENDRA_220	10:49	19:23	08:34	LINE CLEAR AVAILED
3728	25-Jan-24	BAGALKOT	220	SIRSI- HUBLI-1	STATION NOT AFFECTED SIRSI_220	16:05 (24.01.2024)	10:30 (25.01.2024)	18:25:00	LINE CLEAR AVAILED
3729	25-Jan-24	BAGALKOT	220	SIRSI- HUBLI-2	STATION NOT AFFECTED SIRSI_220	16:05 (24.01.2024)	10:30 (25.01.2024)	18:25:00	LINE CLEAR AVAILED
3730	25-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	10:30 (25.01.2024)			LINE CLEAR AVAILED
3731	25-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	10:30 (25.01.2024)			LINE CLEAR AVAILED
3732	25-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
3733	25-Jan-24	BANGALORE	66	ACHALU - HONNIGANAHALLI	HONNIGANAHALLI	14:05	16:25	02:20	LINE CLEAR AVAILED
3734	25-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3735	25-Jan-24	BANGALORE	66	BIEC - SRS PEENYA 220	BIEC	10:54	11:14	00:20	LINE CLEAR AVAILED
3736	25-Jan-24	BANGALORE	66	CESSNA - HSR LAYOUT 220	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	16:25	16:28	00:03	LINE CLEAR AVAILED
3737	25-Jan-24	BANGALORE	66	CESSNA - EXORA 220	CESSNA, EXORA 66, KALYANI TECH PARK, ORACLE(EHT)	13:08	13:12	00:04	LINE CLEAR AVAILED
3738	25-Jan-24	BANGALORE	66	CHINTAMANI 66 - RAILWAY TRACTION	RAILWAY TRACTION	14:29	14:45	00:16	TRIPPED ON FAULT
3739	25-Jan-24	BANGALORE	66	DABUSPET 220 - AVERAHALLI	AVERAHALLI, T BEGUR	07:14	07:36	00:22	TRIPPED ON FAULT
3740	25-Jan-24	BANGALORE	66	DOMMASANDRA - KACHAMARANAHALLI	DOMMASANDRA	16:28	16:34	00:06	LINE CLEAR AVAILED
3741	25-Jan-24	BANGALORE	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	13:05	13:15	00:10	LINE CLEAR AVAILED
3742	25-Jan-24	BANGALORE	66	HV1	K&C VALLEY	10:32	13:50	03:18	LINE CLEAR AVAILED
3743	25-Jan-24	BANGALORE	66	HV1	VIKAS TECH PARK 220	12:35	12:42	00:07	LINE CLEAR AVAILED
3744	25-Jan-24	BANGALORE	66	HV1	VIKAS TECH PARK 220	16:27	16:32	00:05	LINE CLEAR AVAILED
3745	25-Jan-24	BANGALORE	66	HV1	BAGEPALLI	12:15	12:20	00:05	LINE CLEAR AVAILED
3746	25-Jan-24	BANGALORE	66	HV1	SUGUTUR	12:55	13:20	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3747	25-Jan-24	BANGALORE	66	HV1	MAASTHI	11:10	11:15	00:05	LINE CLEAR AVAILED
3748	25-Jan-24	BANGALORE	66	HV1	GUDEMARAMAHALLI	12:25	12:40	00:15	LINE CLEAR AVAILED
3749	25-Jan-24	BANGALORE	66	HV1	GUDEMARAMAHALLI	12:40	14:00	01:20	LINE CLEAR AVAILED
3750	25-Jan-24	BANGALORE	66	HV2	VIKAS TECH PARK 220	12:35	12:42	00:07	LINE CLEAR AVAILED
3751	25-Jan-24	BANGALORE	66	HV2	VIKAS TECH PARK 220	16:27	16:32	00:05	LINE CLEAR AVAILED
3752	25-Jan-24	BANGALORE	66	HV2	AUSTIN TOWN	03:12	03:21	00:09	TRIPPED ON FAULT
3753	25-Jan-24	BANGALORE	66	HV2	DASHAVARA	14:20	14:45	00:25	LINE CLEAR AVAILED
3754	25-Jan-24	BANGALORE	66	ISKON - SOMANAHALLI 220	ISKON	15:04	15:10	00:06	LINE CLEAR AVAILED
3755	25-Jan-24	BANGALORE	66	ISKON - SUBRAMANYAPURA 220	ISKON	18:12	18:18	00:06	LINE CLEAR AVAILED
3756	25-Jan-24	BANGALORE	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	13:48	13:51	00:03	MAIN SUPPLY FAILURE
3757	25-Jan-24	BANGALORE	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	16:09	16:27	00:18	MAIN SUPPLY FAILURE
3758	25-Jan-24	BANGALORE	66	JAYADEVA - NIMHANS 220	JAYADEVA	12:16	14:54	02:38	LINE CLEAR AVAILED
3759	25-Jan-24	BANGALORE	66	JAYADEVA - SARAKKI 1 & 2	SARAKKI	12:06	12:13	00:07	LINE CLEAR AVAILED
3760	25-Jan-24	BANGALORE	66	KOLAR 220 - THAYLUR	TAMAKA	13:32	13:37	00:05	LINE CLEAR AVAILED
3761	25-Jan-24	BANGALORE	66	KONDASAPURA - HOSKOTE 220	KONDASAPURA	14:41	14:46	00:05	LINE CLEAR AVAILED
3762	25-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	22:05	22:10	00:05	LINE CLEAR AVAILED
3763	25-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	11:43	11:48	00:05	LINE CLEAR AVAILED
3764	25-Jan-24	BANGALORE	66	MALUR 220 - MAASTHI	MAASTHI	12:34	12:47	00:13	TRIPPED ON FAULT
3765	25-Jan-24	BANGALORE	66	PERESNADRA - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI	19:15	19:20	00:05	LINE CLEAR AVAILED
3766	25-Jan-24	BANGALORE	66	PERESNADRA - SOMENAHALLI	PERESANDRA	15:40	15:45	00:05	LINE CLEAR AVAILED
3767	25-Jan-24	BANGALORE	66	PERESNADRA - SOMENAHALLI	PERESANDRA, SOMENAHALLI	16:10	16:15	00:05	LINE CLEAR AVAILED
3768	25-Jan-24	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	16:38	16:43	00:05	LINE CLEAR AVAILED
3769	25-Jan-24	BANGALORE	66	SHOBHA FOREST - BRIGADE MEADOWS	SHOBHA FOREST	17:45	17:52	00:07	LINE CLEAR AVAILED
3770	25-Jan-24	BANGALORE	66	SOMANATHPURA - CHELUR	CHELUR, CHAKAVELU	10:55	11:05	00:10	TRIPPED ON FAULT
3771	25-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - KGF 1	KGF	22:48	23:59	01:11	LINE CLEAR AVAILED
3772	25-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - KGF 2	KAMASAMUDRA, BEML	22:48	23:59	01:11	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3773	25-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI	12:23	12:33	00:10	TRIPPED ON FAULT
3774	25-Jan-24	BANGALORE	220	HV2	T GOLLAHALLI 220	19:48	23:59	04:11	TRIPPED ON FAULT
3775	25-Jan-24	GULBARGA	66	HV1	KUDALGI_220	03:40	03:47	00:07	TRIPPED ON FAULT
3776	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX1	ITTAGI_220	13:12	13:24	00:12	TRIPPED ON FAULT
3777	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX2	ITTAGI_220	13:12	13:24	00:12	TRIPPED ON FAULT
3778	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX2	ITTAGI_220	13:25	13:36	00:11	TRIPPED ON FAULT
3779	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX2	ITTAGI_220	13:49	13:54	00:05	TRIPPED ON FAULT
3780	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX2	ITTAGI_220	13:54	16:02	02:08	TRIPPED ON FAULT
3781	25-Jan-24	GULBARGA	66	ITTAGI-CLEAN MAX2	ITTAGI_220	16:45	17:05	00:20	TRIPPED ON FAULT
3782	25-Jan-24	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINHADAGALI_66, HOLAGUNDI_66	09:35	09:45	00:10	TRIPPED ON FAULT
3783	25-Jan-24	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINHADAGALI_66, HOLAGUNDI_66	10:05	14:28	04:23	LINE CLEAR AVAILED
3784	25-Jan-24	GULBARGA	66	KUDALAGI-KOTTUR	UJJINI_66, NIMBALAGERE_66	03:40	03:47	00:07	TRIPPED ON FAULT
3785	25-Jan-24	GULBARGA	66	KUDALGI-BANAVEKAL	BANAVEKAL_66, CJ HALLI_66, HOSAHALLI_66	03:40	03:47	00:07	LINE CLEAR AVAILED
3786	25-Jan-24	GULBARGA	110	FARTHABAD-SHAHABAD	SHAHABAD_220	08:55	09:05	00:10	TRIPPED ON FAULT
3787	25-Jan-24	GULBARGA	110	HV1	KALBURGI UNIVERSITY_110	11:30	13:03	01:33	LINE CLEAR AVAILED
3788	25-Jan-24	GULBARGA	110	MUDGAL-BAYYAPUR	BAYYAPUR_110	20:20	20:40	00:20	TRIPPED ON FAULT
3789	25-Jan-24	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110,DEVAPUR_110	06:18	06:28	00:10	TRIPPED ON FAULT
3790	25-Jan-24	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110,DEVAPUR_110	10:46	12:15	01:29	LINE CLEAR AVAILED
3791	25-Jan-24	GULBARGA	220	HALWARTHY-X-INDIA	HALWARTHY_220	11:55	24:00:00	12:05	LINE CLEAR AVAILED
3792	25-Jan-24	GULBARGA	220	MALLAT-RTPS	RTPS_220	11:40	18:40:00	07:00	LINE CLEAR AVAILED
3793	25-Jan-24	GULBARGA	220	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	8:44(23.01.2024)			LINE CLEAR AVAILED
3794	25-Jan-24	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	8:52(23.01.2024)			LINE CLEAR AVAILED
3795	25-Jan-24	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	02:55	03:12	00:17	TRIPPED ON FAULT
3796	25-Jan-24	HASSAN	66	BHADRA-SHMGA 2	gen_bhadra	15:47	16:02	00:15	TRIPPED ON FAULT
3797	25-Jan-24	HASSAN	66	HNPR2-CRPTN	HNPURA_220	16:50	18:34	01:44	MAIN SUPPLY FAILURE
3798	25-Jan-24	HASSAN	66	HNPR2-HASS1	HNPURA_220	16:50	18:31	01:41	MAIN SUPPLY FAILURE
3799	25-Jan-24	HASSAN	66	HNPR2-HNPR1	HNPURA_220	16:50	18:33	01:43	MAIN SUPPLY FAILURE
3800	25-Jan-24	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	09:35	09:45	00:10	MAIN SUPPLY FAILURE
3801	25-Jan-24	HASSAN	66	HNPR2-MYSOR1	HNPURA_220	09:45	16:50	07:05	MAIN SUPPLY FAILURE
3802	25-Jan-24	HASSAN	66	HNPR2-MYSOR2	HNPURA_220	16:50	18:33	01:43	MAIN SUPPLY FAILURE
3803	25-Jan-24	HASSAN	66	HNPR2-RNPR1	HNPURA_220	16:50	18:33	01:43	MAIN SUPPLY FAILURE
3804	25-Jan-24	HASSAN	66	HNPR2-RNPR1	HNPURA_220	16:50	18:35	01:45	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3805	25-Jan-24	HASSAN	66	HNPR2-RNPR2	HNPURA_220	16:50	18:36	01:46	MAIN SUPPLY FAILURE
3806	25-Jan-24	HASSAN	66	HV1	MALLIPATNA_66	10:14(25.1.2024)			LINE CLEAR AVOIDED
3807	25-Jan-24	HASSAN	66	HV1	HANUBALU_66	12:10	12:25	00:15	MAIN SUPPLY FAILURE
3808	25-Jan-24	HASSAN	66	HV1	HANUBALU_66	16:50	17:00	00:10	TRIPPED ON FAULT
3809	25-Jan-24	HASSAN	66	HV1	CHKNGR	12:42	12:45	00:03	TRIPPED ON FAULT
3810	25-Jan-24	HASSAN	66	Lv1	HNPURA_220	16:50	18:29	01:39	MAIN SUPPLY FAILURE
3811	25-Jan-24	HASSAN	66	Lv2	HNPURA_220	16:50	18:29	01:39	MAIN SUPPLY FAILURE
3812	25-Jan-24	HASSAN	110	ALKLA	SAGARA	08:32	16:12	07:40	LINE CLEAR AVOIDED
3813	25-Jan-24	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	08:33	15:46	07:13	LINE CLEAR AVOIDED
3814	25-Jan-24	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	11:00	11:23	00:23	LINE CLEAR AVOIDED
3815	25-Jan-24	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	11:00	11:23	00:23	LINE CLEAR AVOIDED
3816	25-Jan-24	HASSAN	110	GURUVA-SLVPWR	GURUVAYANKERE_110	11:00	11:23	00:23	LINE CLEAR AVOIDED
3817	25-Jan-24	HASSAN	110	HV1	KEMAR_220	11:03	11:20	00:17	LINE CLEAR AVOIDED
3818	25-Jan-24	HASSAN	110	HV1	ALKOLA_110	08:33	15:47	07:14	LINE CLEAR AVOIDED
3819	25-Jan-24	HASSAN	110	HV1	BANTWA	12:14	13:24	01:10	LINE CLEAR AVOIDED
3820	25-Jan-24	HASSAN	110	HV2	KEMAR_220	11:03	11:20	00:17	LINE CLEAR AVOIDED
3821	25-Jan-24	HASSAN	110	HV2	MRS_220	09:23	15:58	06:35	LINE CLEAR AVOIDED
3822	25-Jan-24	HASSAN	110	HV2	ALKOLA_110	08:33	16:16	07:43	LINE CLEAR AVOIDED
3823	25-Jan-24	HASSAN	110	HV2	KULASHAPURA_110	10:06	16:48	06:42	LINE CLEAR AVOIDED
3824	25-Jan-24	HASSAN	110	HV3	MRS_220	09:23	15:59	06:36	LINE CLEAR AVOIDED
3825	25-Jan-24	HASSAN	110	HV3	ALKOLA_110	08:33	15:49	07:16	LINE CLEAR AVOIDED
3826	25-Jan-24	HASSAN	110	HV3	KULASHAPURA_110	10:06	16:41	06:35	LINE CLEAR AVOIDED
3827	25-Jan-24	HASSAN	110	HV4	MRS_220	09:23	16:16	06:53	LINE CLEAR AVOIDED
3828	25-Jan-24	HASSAN	110	KADUR-AJAMPURA	KADUR_110	06:52	08:58	02:06	LINE CLEAR AVOIDED
3829	25-Jan-24	HASSAN	110	KADUR-NERELEKERE	KADUR_110	06:52	08:04	01:12	LINE CLEAR AVOIDED
3830	25-Jan-24	HASSAN	110	KADUR-RAILWY TRAC	KADUR_110	06:52	07:14	00:22	LINE CLEAR AVOIDED
3831	25-Jan-24	HASSAN	110	KADUR-SHIMOGA	ANANDAPURA_110	08:25	10:00	01:35	LINE CLEAR AVOIDED
3832	25-Jan-24	HASSAN	110	KADUR-TNGL	KADUR_110	06:52	08:36	01:44	LINE CLEAR AVOIDED
3833	25-Jan-24	HASSAN	110	KADUR-YAGTI	KADUR_110	06:52	08:14	01:22	LINE CLEAR AVOIDED
3834	25-Jan-24	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	11:01	11:22	00:21	LINE CLEAR AVOIDED
3835	25-Jan-24	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	11:01	11:23	00:22	LINE CLEAR AVOIDED
3836	25-Jan-24	HASSAN	110	KEMAR-Manipal1	KEMAR_220	11:02	11:21	00:19	LINE CLEAR AVOIDED
3837	25-Jan-24	HASSAN	110	KEMAR-Manipal2	KEMAR_220	11:04	11:22	00:18	LINE CLEAR AVOIDED
3838	25-Jan-24	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	11:01	11:21	00:20	LINE CLEAR AVOIDED
3839	25-Jan-24	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	11:01	11:22	00:21	LINE CLEAR AVOIDED
3840	25-Jan-24	HASSAN	110	LV1	KEMAR_220	11:03	11:20	00:17	LINE CLEAR AVOIDED
3841	25-Jan-24	HASSAN	110	LV1	MRS_220	08:32	14:19	05:47	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3842	25-Jan-24	HASSAN	110	LV2	KEMAR_220	11:03	11:20	00:17	LINE CLEAR AVAILED
3843	25-Jan-24	HASSAN	110	LV3	KEMAR_220	11:04	11:34	00:30	LINE CLEAR AVAILED
3844	25-Jan-24	HASSAN	110	MRS	ALKOLA_110	08:33	15:13	06:40	LINE CLEAR AVAILED
3845	25-Jan-24	HASSAN	110	MRSSHM-SS1	MRS_220	08:30	15:52	07:22	LINE CLEAR AVAILED
3846	25-Jan-24	HASSAN	110	MRSSHM-SS2	MRS_220	08:26	15:34	07:08	LINE CLEAR AVAILED
3847	25-Jan-24	HASSAN	110	PUTUR 1	PUTTUR	11:02	15:32	04:30	LINE CLEAR AVAILED
3848	25-Jan-24	HASSAN	110	SLTR	PUTTUR	11:04	11:15	00:11	LINE CLEAR AVAILED
3849	25-Jan-24	HASSAN	220	GOPALAP-BASTIPURA	GOPALAPURA_110	16:50	18:50	02:00	TRIPPED ON FAULT
3850	25-Jan-24	HASSAN	220	GOPALAP-HNPUR21	GOPALAPURA_110	16:50	18:27	01:37	TRIPPED ON FAULT
3851	25-Jan-24	HASSAN	220	GOPALAP-HNPUR22	GOPALAPURA_110	16:50	18:27	01:37	TRIPPED ON FAULT
3852	25-Jan-24	HASSAN	220	HV1	HASSAN_220	12:14	12:17	00:03	TRIPPED ON FAULT
3853	25-Jan-24	HASSAN	220	HV1	KEMAR_220	11:03	11:19	00:16	LINE CLEAR AVAILED
3854	25-Jan-24	HASSAN	220	HV1	MRS_220	08:32	14:19	05:47	LINE CLEAR AVAILED
3855	25-Jan-24	HASSAN	220	HV1	HNPURA_220	16:50	18:34	01:44	MAIN SUPPLY FAILURE
3856	25-Jan-24	HASSAN	220	HV2	HASSAN_220	11:09	12:42	01:33	LINE CLEAR AVAILED
3857	25-Jan-24	HASSAN	220	HV2	KEMAR_220	11:03	11:20	00:17	LINE CLEAR AVAILED
3858	25-Jan-24	HASSAN	220	HV2	HNPURA_220	16:50	18:34	01:44	MAIN SUPPLY FAILURE
3859	25-Jan-24	HASSAN	220	HV3	KEMAR_220	11:03	11:19	00:16	LINE CLEAR AVAILED
3860	25-Jan-24	HASSAN	220	HV3	KADUR_110	06:52	08:58	02:06	TRIPPED ON FAULT
3861	25-Jan-24	HASSAN	220	KADUR-SHIMOGA	KADUR_110	06:52	11:02	04:10	TRIPPED ON FAULT
3862	25-Jan-24	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	11:04	11:15	00:11	LINE CLEAR AVAILED
3863	25-Jan-24	HASSAN	220	LV1	HASSAN_220	12:14	12:17	00:03	TRIPPED ON FAULT
3864	25-Jan-24	HASSAN	220	LV2	HASSAN_220	11:09	12:42	01:33	LINE CLEAR AVAILED
3865	25-Jan-24	HASSAN	220	MRSSHM-KADUR	MRS_220	06:52	11:02	04:10	TRIPPED ON FAULT
3866	25-Jan-24	MYSORE	66	HALAGUR-HONNAGANAHALLI	HALGURU_66	13:03	13:45	00:42	LINE CLEAR AVAILED
3867	25-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	20:07 (23/01/2024)			LINE CLEAR AVAILED
3868	25-Jan-24	MYSORE	66	HEBBAL-HOOTAGALLI	HEBBAL_66METAGALLY_66	08:55	09:08	00:12	TRIPPED ON FAULT
3869	25-Jan-24	MYSORE	66	HV1	HANGLA_66	12:30	14:45	02:15	LINE CLEAR AVAILED
3870	25-Jan-24	MYSORE	66	HV1	NANJANGUDU_66	05:52	06:32	00:40	TRIPPED ON FAULT
3871	25-Jan-24	MYSORE	66	HV1	NANJANGUDU_66	06:40	06:46	00:06	TRIPPED ON FAULT
3872	25-Jan-24	MYSORE	66	HV1	NANJANGUDU_66	11:01	14:17	03:16	TRIPPED ON FAULT
3873	25-Jan-24	MYSORE	66	HV1	CHANDALLI_66	06:35	08:15	01:40	LINE CLEAR AVAILED
3874	25-Jan-24	MYSORE	66	HV2	CHANDALLI_66	08:30	12:00	03:30	LINE CLEAR AVAILED
3875	25-Jan-24	MYSORE	66	KK DODDI-MADDUR	MADDUR_66SOMANAHALLI_66	12:20	12:32	00:12	TRIPPED ON FAULT
3876	25-Jan-24	MYSORE	66	NANJANGUDU-NESLE	NO STATIONS EFFECTED	15:30	16:27	00:57	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3877	25-Jan-24	MYSORE	66	SFC SIVA-ATRIA	NO STATIONS EFFECTED	13:40	17:10	03:30	LINE CLEAR AVAILED
3878	25-Jan-24	MYSORE	66	VAJMANGALA-KADAKOLA1	AYRALLI_66MARADIHUNDI_66	05:45	06:02	00:17	TRIPPED ON FAULT
3879	25-Jan-24	MYSORE	220	TUBINKERE-CHANNAPATNA	NO STATIONS EFFECTED	11:06	16:09	05:03	LINE CLEAR AVAILED
3880	25-Jan-24	MYSORE	220	TUBINKERE-GOPALAPURA	NO STATIONS EFFECTED	16:50	18:55	02:05	TRIPPED ON FAULT
3881	25-Jan-24	TUMKUR	66	ANCHEPALYA 220-HEBBUR	HEBBUR_66	12:36	12:45	00:09	LINE CLEAR AVAILED
3882	25-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	10:12	10:50	00:38	TRIPPED ON FAULT
3883	25-Jan-24	TUMKUR	66	BENKIKERE 220kv-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	17:07	17:57	00:50	TRIPPED ON FAULT
3884	25-Jan-24	TUMKUR	66	BENKIKERE 220kv-NALLUR	NALLUR_66	15:41	15:51	00:10	TRIPPED ON FAULT
3885	25-Jan-24	TUMKUR	66	CHITRADURGA 220kv-HGML(HIRIYUR)	IMANGALA_66, ENERCON1_IPP_66, HIRIYUR_66	01:02	01:13	00:11	TRIPPED ON FAULT
3886	25-Jan-24	TUMKUR	66	CHITRADURGA 220kv-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	07:23	07:42	00:19	LOAD CURTAILMENT
3887	25-Jan-24	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	07:23	07:32	00:09	LOAD CURTAILMENT
3888	25-Jan-24	TUMKUR	66	DASUDI-SRS HIRIYUR_220	DASUDI_66	12:30	13:00	00:30	LINE CLEAR AVAILED
3889	25-Jan-24	TUMKUR	66	DAVANGERE SRS-MELLEKATTE_66	MELLEKATTE_66, KADAJJI_66	07:58	08:05	00:07	TRIPPED ON FAULT
3890	25-Jan-24	TUMKUR	66	HIRIYUR 220KV- MATHOD	MATHOD_66, HINDASGHATTA_66, BHARAMAGIRI_66, GARAGA_66, PANCHANAHALLI_66, KANCHEPURA_66	07:15	09:01	01:46	LINE CLEAR AVAILED
3891	25-Jan-24	TUMKUR	66	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:43	12:54	00:11	LINE CLEAR AVAILED
3892	25-Jan-24	TUMKUR	66	HIRIYUR220kv-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:05	12:15	00:10	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3893	25-Jan-24	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	12:17	12:22	00:05	TRIPPED ON FAULT
3894	25-Jan-24	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	07:25	07:40	00:15	MAIN SUPPLY FAILURE
3895	25-Jan-24	TUMKUR	66	HONNALLI 220kV-KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	15:31	16:17	00:46	LINE CLEAR AVAILED
3896	25-Jan-24	TUMKUR	66	HONNALLI 220kV-NALLUR_66	NALLUR_66	05:00	05:15	00:15	TRIPPED ON FAULT
3897	25-Jan-24	TUMKUR	66	HONNALLI 220kV-NALLUR_66	NALLUR_66	15:31	17:14	01:43	LINE CLEAR AVAILED
3898	25-Jan-24	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	10:03	10:11	00:08	TRIPPED ON FAULT
3899	25-Jan-24	TUMKUR	66	HONNALLI 220KV-SASUVEHALLI	SASUVEHALLI_66,	15:31	17:11	01:40	LINE CLEAR AVAILED
3900	25-Jan-24	TUMKUR	66	JAGALUR_66-BIDARAKERE_66	JAGALUR_66	07:20	07:30	00:10	MAIN SUPPLY FAILURE
3901	25-Jan-24	TUMKUR	66	KB CROSS 220kV-TURUVEKERE_110	TURUVEKERE_110, TANDAGA_110, NONAVINAKERE_110, GUNGURMALE_110	10:39	12:50	02:11	LINE CLEAR AVAILED
3902	25-Jan-24	TUMKUR	66	PAVAGADA 220kV-SHYLAPURA	SHYLAPURA_66	09:25	09:35	00:10	TRIPPED ON FAULT
3903	25-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
3904	25-Jan-24	TUMKUR	66	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	14:23	14:43	00:20	MAIN SUPPLY FAILURE
3905	25-Jan-24	TUMKUR	66	THALLAK 220-P R PURA	PR PURA_66,MYLANAHALLI_66, V V PORA_66, DYAVARANAHALLI_66	18:39	18:50	00:11	TRIPPED ON FAULT
3906	25-Jan-24	TUMKUR	66	TR-1	DASUDI_66	12:10	13:00	00:50	LINE CLEAR AVAILED
3907	25-Jan-24	TUMKUR	66	TR1(100MVA)	HONNALLI_66	15:31	16:17	00:46	LINE CLEAR AVAILED
3908	25-Jan-24	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	16:25	18:30	02:05	LINE CLEAR AVAILED
3909	25-Jan-24	TUMKUR	66	TR-2	ANCHEPALYA_66	11:15	11:45	00:30	LINE CLEAR AVAILED
3910	25-Jan-24	TUMKUR	66	TR-2	ANCHEPALYA_66	12:00	12:05	00:05	TRIPPED ON FAULT
3911	25-Jan-24	TUMKUR	66	TR-2	DASUDI_66	11:50	12:15	00:25	LINE CLEAR AVAILED
3912	25-Jan-24	TUMKUR	66	TR-2	HONALLI_66	18:30	19:30	01:00	LINE CLEAR AVAILED
3913	25-Jan-24	TUMKUR	66	TR-2	RAMAPURA_66	16:37	16:47	00:10	TRIPPED ON FAULT
3914	25-Jan-24	TUMKUR	66	TR2(100MVA)	HONNALLI_66	15:31	16:17	00:46	LINE CLEAR AVAILED
3915	25-Jan-24	TUMKUR	66	TR2(100MVA)	NITTUR_220	03:05	03:27	00:22	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3916	25-Jan-24	TUMKUR	66	TR-3	HOLALKERE_66	18:05	18:30	00:25	LINE CLEAR AVAILED
3917	25-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
3918	25-Jan-24	TUMKUR	220	TR1(100MVA)	HIRIYUR_220	14:55	16:16	01:21	LINE CLEAR AVAILED
3919	26-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	STATION NOT AFFECTED AEQUS_220	10:21	13:04	02:43	LINE CLEAR AVAILED
3920	26-Jan-24	BAGALKOT	110	110/11KV,HV1(20MVA)	STATION NOT AFFECTED AEQUS_220	13:14	14:35	01:21	LINE CLEAR AVAILED
3921	26-Jan-24	BAGALKOT	110	110/33KV, HV2(20MVA)	HANGAL_110	15:50	16:00	00:10	TRIPPED ON FAULT
3922	26-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVAILED
3923	26-Jan-24	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	11:01	19:00	07:59	LINE CLEAR AVAILED
3924	26-Jan-24	BAGALKOT	110	ATHANI220-KARIMASUTILIS	STATION NOT AFFECTED ATHANI_220	06:55	07:19	00:24	TRIPPED ON FAULT
3925	26-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
3926	26-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)			LINE CLEAR AVAILED
3927	26-Jan-24	BAGALKOT	110	INDI-ATHARGA	STATION NOT AFFECTED INDI_220	00:35	00:55	00:20	TRIPPED ON FAULT
3928	26-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
3929	26-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
3930	26-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
3931	26-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
3932	26-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3933	26-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVOIDED
3934	26-Jan-24	BAGALKOT	110	YLWD-F1CBreaker (AIGALI)	STATION NOT AFFECTED YELLAMANAWADI_110	18:45 (26.01.2024)			LINE CLEAR AVOIDED
3935	26-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	MAHALINGAPUR_220	8:35 (25.01.2024)	16:50 (26.01.2024)	22:57:00	LINE CLEAR AVOIDED
3936	26-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	17:29 (26.01.2024)			LINE CLEAR AVOIDED
3937	26-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	STATION NOT AFFECTED NARENDRA_220	10:48	12:10	01:22	LINE CLEAR AVOIDED
3938	26-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVOIDED
3939	26-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVOIDED
3940	26-Jan-24	BAGALKOT	220	SIRSI220-HUBLI1	SIRSI_220	11:17	13:48	02:31	LINE CLEAR AVOIDED
3941	26-Jan-24	BAGALKOT	220	SIRSI220-HUBLI2	SIRSI_220	11:18	13:48	02:30	LINE CLEAR AVOIDED
3942	26-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	10:30 (25.01.2024)	11:17 (26.01.2024)	24:47:00	LINE CLEAR AVOIDED
3943	26-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVOIDED
3944	26-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	10:30 (25.01.2024)	11:17 (26.01.2024)	24:47:00	LINE CLEAR AVOIDED
3945	26-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVOIDED
3946	26-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVOIDED
3947	26-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
3948	26-Jan-24	BANGALORE	66	BAGEPALLI - MITTEMARI 220	BAGEPALLI	11:00	11:05	00:05	LINE CLEAR AVOIDED
3949	26-Jan-24	BANGALORE	66	HBR LAYOUT 220 - HENNUR CROSS	HENNUR CROSS, PURVANKARA PALM BEACH	18:57	19:43	00:46	TRIPPED ON FAULT
3950	26-Jan-24	BANGALORE	66	HV1	NANDAGUDI	02:55	03:25	00:30	TRIPPED ON FAULT
3951	26-Jan-24	BANGALORE	66	HV1	MAASTHI	09:05	09:10	00:05	TRIPPED ON FAULT
3952	26-Jan-24	BANGALORE	66	HV1	VR DODDI	11:38	11:58	00:20	LINE CLEAR AVOIDED
3953	26-Jan-24	BANGALORE	66	HV2	VIJAYANAGARA	22:04	22:14	00:10	LINE CLEAR AVOIDED
3954	26-Jan-24	BANGALORE	66	HV2	GUDEMARANAHALLI	06:52	06:58	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3955	26-Jan-24	BANGALORE	66	HV3	YARANDANAHALLI 220	11:53	13:03	01:10	LINE CLEAR AVAILED
3956	26-Jan-24	BANGALORE	66	MAGADI 220 - GUDEMARANAHALLI	GUDEMARANAHALLI	06:26	06:50	00:24	TRIPPED ON FAULT
3957	26-Jan-24	BANGALORE	66	MAGADI 220 - T G HALLI	V G DODDI	14:13	15:37	01:24	LINE CLEAR AVAILED
3958	26-Jan-24	BANGALORE	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	09:15	09:24	00:09	LINE CLEAR AVAILED
3959	26-Jan-24	BANGALORE	66	MALUR 220 - KGF 1	TEKAL, BUDIKOTE, TORLAKKI	09:25	09:32	00:07	LINE CLEAR AVAILED
3960	26-Jan-24	BANGALORE	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	09:25	09:32	00:07	LINE CLEAR AVAILED
3961	26-Jan-24	BANGALORE	66	MALUR 220 - LAKKUR	DEVANGONDHI, LAKKUR	14:23	14:33	00:10	LINE CLEAR AVAILED
3962	26-Jan-24	BANGALORE	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	22:06	22:14	00:08	LINE CLEAR AVAILED
3963	26-Jan-24	BANGALORE	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	06:28	06:32	00:04	LINE CLEAR AVAILED
3964	26-Jan-24	BANGALORE	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	15:35	16:00	00:25	TRIPPED ON FAULT
3965	26-Jan-24	BANGALORE	66	TG HALLI - TAVAREKERE	TG HALLI, TAVAREKERE	16:15	16:22	00:07	LINE CLEAR AVAILED
3966	26-Jan-24	BANGALORE	220	HV2	T GOLLAHALLI 220	00:00	23:59	23:59	TRIPPED ON FAULT
3967	26-Jan-24	GULBARGA	66	HV1	BANAVEKAL_66	12:10	12:20	00:10	TRIPPED ON FAULT
3968	26-Jan-24	GULBARGA	66	HV1	UPANAYAKANAHALLI_66	11:15	12:30	01:15	LINE CLEAR AVAILED
3969	26-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGHALI1	HIREHADAGALI_66, TB HALLI_66	04:27	04:34	00:07	TRIPPED ON FAULT
3970	26-Jan-24	GULBARGA	66	ITTAGI-HUVINHADAGALI	HUVINHADAGALI_66	04:43	07:42	02:59	LINE CLEAR AVAILED
3971	26-Jan-24	GULBARGA	110	KHANAPUR-KADECHUR	KADECHUR_110, SAIDAPUR_110	04:58	05:10	0:12:00	TRIPPED ON FAULT
3972	26-Jan-24	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDGAL_110, BAYYAPUR_110	19:27	19:42	00:15	TRIPPED ON FAULT
3973	26-Jan-24	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	21:58	22:05	00:07	TRIPPED ON FAULT
3974	26-Jan-24	GULBARGA	220	MALLAT-RTPS	RTPS_220	10:16	15:59	05:43	LINE CLEAR AVAILED
3975	26-Jan-24	GULBARGA	220	SHAHAPUR-FEROZABAD1	SHAHAPUR_220	8:44(23.01.2024)	19:47(26.01.2024)	83:03:00	LINE CLEAR AVAILED
3976	26-Jan-24	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	8:52(23.01.2024)	19:50(26.01.2024)	82:58:00	LINE CLEAR AVAILED
3977	26-Jan-24	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	18:58	19:10	00:12	LINE CLEAR AVAILED
3978	26-Jan-24	HASSAN	66	HV1	MALLIPATNA_66	10:14(25.1.2024)	8:52(26.1.2024)		LINE CLEAR AVAILED
3979	26-Jan-24	HASSAN	110	BANTWA-KAVOOR	BANTWALA_110	14:02	15:25	01:23	LINE CLEAR AVAILED
3980	26-Jan-24	HASSAN	110	HV2	MANIPAL_110	16:44	16:56	00:12	LINE CLEAR AVAILED
3981	26-Jan-24	HASSAN	110	HV2	SHIKARIPURA_110	12:45	13:00	00:15	TRIPPED ON FAULT
3982	26-Jan-24	HASSAN	110	HV2	ESSUR_110	17:07	17:50	00:43	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
3983	26-Jan-24	HASSAN	110	MRSSHM-MYSORE	MRS_220	10:10	15:39	05:29	LINE CLEAR AVAILED
3984	26-Jan-24	HASSAN	220	MRSSHM-SHIMOGA1	gen_varahi	10:30	15:15	04:45	LINE CLEAR AVAILED
3985	26-Jan-24	HASSAN	220	MRSSHM-VARAH1	MRS_220	10:28	15:15	04:47	LINE CLEAR AVAILED
3986	26-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	20:07 (23/01/2024)			LINE CLEAR AVAILED
3987	26-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
3988	26-Jan-24	MYSORE	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	11:25 (26/01/2024)			LINE CLEAR AVAILED
3989	26-Jan-24	MYSORE	66	HV2	COWDALLI_66	07:13	07:19	00:06	TRIPPED ON FAULT
3990	26-Jan-24	MYSORE	66	HV2	HONNALLY_MYS_66	09:05	18:32	09:27	TRIPPED ON FAULT
3991	26-Jan-24	MYSORE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	07:46	08:43	00:57	TRIPPED ON FAULT
3992	26-Jan-24	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	09:28	13:14	03:46	LINE CLEAR AVAILED
3993	26-Jan-24	TUMKUR	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREKILCHI_66	15:06	15:12	00:06	TRIPPED ON FAULT
3994	26-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	23:26(26.01.2024)	1:13 (27.1.24)	01:47	LINE CLEAR AVAILED
3995	26-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	23:33(26.01.2024)	1:15 (27.1.24)	01:49	LINE CLEAR AVAILED
3996	26-Jan-24	TUMKUR	66	Davangere SRS _Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	11:34	12:30	00:56	MAIN SUPPLY FAILURE
3997	26-Jan-24	TUMKUR	66	DAVANGERE SRS-KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	07:48	08:45	00:57	TRIPPED ON FAULT
3998	26-Jan-24	TUMKUR	66	HOSADURGA_220KV-HALURAMESHWARA_66KV	HALURAMESHWARA_66K, MADADKERE_66	14:00	14:05	00:05	LINE CLEAR AVAILED
3999	26-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4000	26-Jan-24	TUMKUR	66	SIRA220-PATNAYAKANAHALLI 1	PATNAYAKANAHALLI 1	14:55	15:04	00:09	LINE CLEAR AVAILED
4001	26-Jan-24	TUMKUR	66	SIRA220-TAVAREKERE	TAVAREKERE_66	14:55	15:31	00:36	LINE CLEAR AVAILED
4002	26-Jan-24	TUMKUR	66	TR-1	MAVINAKATTE_66	09:10	09:15	00:05	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4003	26-Jan-24	TUMKUR	66	TR-2	MAVINAKATTE_66	08:35	08:40	00:05	TRIPPED ON FAULT
4004	26-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
4005	27-Jan-24	BAGALKOT	110	HAVERI220-BYADAGI	HAVERI_220	11:39	11:54	00:15	LINE CLEAR AVAILED
4006	27-Jan-24	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	16:52 (27.01.2024)			LINE CLEAR AVAILED
4007	27-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	HEBBALLI_110	20:06	20:14	00:08	LINE CLEAR AVAILED
4008	27-Jan-24	BAGALKOT	110	110/11KV, HV2(10MVA)	MALGHAN(S)_110	22:00	22:02	00:02	TRIPPED ON FAULT
4009	27-Jan-24	BAGALKOT	110	110/11KV, HV2(20MVA)	MALGHAN(S)_110	22:06	22:09	00:03	TRIPPED ON FAULT
4010	27-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GHATAPRABHA_110	04:36	04:46	00:10	TRIPPED ON FAULT
4011	27-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVAILED
4012	27-Jan-24	BAGALKOT	110	110/33KV,HV2 (20MVA)	RATTIHALLI_110	12:05	12:09	00:04	TRIPPED ON FAULT
4013	27-Jan-24	BAGALKOT	110	ALBAL- RFE(RAYS SOLAR)	ALBAL_110	16:04	17:04	01:00	TRIPPED ON FAULT
4014	27-Jan-24	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	23:30	23:43	00:13	TRIPPED ON FAULT
4015	27-Jan-24	BAGALKOT	110	CHIKKODI220-BHOJ	CHIKKODI_220	13:20	13:45	00:25	LINE CLEAR AVAILED
4016	27-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)			LINE CLEAR AVAILED
4017	27-Jan-24	BAGALKOT	110	HAVERI220- BYADAGI	HAVERI_220	11:39	11:54	00:15	LINE CLEAR AVAILED
4018	27-Jan-24	BAGALKOT	110	HAVERI220- SAVANUR	STATION NOT AFFECTED HAVERI_220	1:10 (22.01.2024)	11:44 (27.01.2024)	130:34:00	LINE CLEAR AVAILED
4019	27-Jan-24	BAGALKOT	110	HAVERI220- TILUVALLI	HAVERI_220	11:39	11:53	00:14	LINE CLEAR AVAILED
4020	27-Jan-24	BAGALKOT	110	HAVERI220 BASAVANAKATTI	HAVERI_220	11:38	11:50	00:12	LINE CLEAR AVAILED
4021	27-Jan-24	BAGALKOT	110	HAVERI220-TILUVALI(HANAGAL)	HAVERI_220	11:39	11:54	00:15	LINE CLEAR AVAILED
4022	27-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
4023	27-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4024	27-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4025	27-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
4026	27-Jan-24	BAGALKOT	110	MUGALKHOD220-LN12(PG HUNSHYAL)	MUGALKHOD_220	05:09	05:25	00:16	TRIPPED ON FAULT
4027	27-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4028	27-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
4029	27-Jan-24	BAGALKOT	110	VAJARMATTI-MUDHOL	VAJARMATTI_220	06:03	07:07	01:04	TRIPPED ON FAULT
4030	27-Jan-24	BAGALKOT	110	YLWD-F1CBreaker (AIGALI)	STATION NOT AFFECTED YELLAMANAWADI_110	18:45 (26.01.2024)			LINE CLEAR AVAILED
4031	27-Jan-24	BAGALKOT	220	220/110KV, HV1&LV1	HAVERI_220	11:23	11:48	00:25	TRIPPED ON FAULT
4032	27-Jan-24	BAGALKOT	220	220/110KV, HV2&LV2	HAVERI_220	11:23	11:48	00:25	TRIPPED ON FAULT
4033	27-Jan-24	BAGALKOT	220	220/110KV,HV1,LV1	HAVERI_220,TILUVALI_110, KNNL_110,GM SUGAR_110	11:24	11:48	00:24	TRIPPED ON FAULT
4034	27-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	HAVERI_220	11:23	11:48	00:25	TRIPPED ON FAULT
4035	27-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	AMBEWADI_220	10:48	13:16	02:28	LINE CLEAR AVAILED
4036	27-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	17:29 (26.01.2024)			LINE CLEAR AVAILED
4037	27-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:56	16:02	05:06	LINE CLEAR AVAILED
4038	27-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	10:56	16:03	05:07	LINE CLEAR AVAILED
4039	27-Jan-24	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	10:42	12:55	02:13	LINE CLEAR AVAILED
4040	27-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4041	27-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
4042	27-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:55	16:03	05:08	LINE CLEAR AVAILED
4043	27-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	10:55	16:03	05:08	LINE CLEAR AVAILED
4044	27-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4045	27-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4046	27-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4047	27-Jan-24	BAGALKOT	400	DHONI400-GUDDADAHALLI	DHONI_400	14:06	14:42	00:36	TRIPPED ON FAULT
4048	27-Jan-24	BAGALKOT	400	DHONI400-GUDDADAHALLI	DHONI_400	17:57 (27.01.2024)			LINE CLEAR AVAILED
4049	27-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4050	27-Jan-24	BANGALORE	66	BYADARAHALLI - KODIGEHALI	KODIGEHALI	13:13	13:38	00:25	LINE CLEAR AVAILED
4051	27-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA, CNL(EHT), SHIVANAHALLI, VANDARGUPPE	23:00	23:13	00:13	TRIPPED ON FAULT
4052	27-Jan-24	BANGALORE	66	GURUVINAPURA - TK HALLI 220	GURUVINAPURA, BV HALLI	08:03	08:11	00:08	LINE CLEAR AVAILED
4053	27-Jan-24	BANGALORE	66	HBR LAYOUT 66 - DG3	KONDASPURA	09:20	11:20	02:00	LINE CLEAR AVAILED
4054	27-Jan-24	BANGALORE	66	HV1	MAHALAKSHMI LAYOUT	06:25	06:30	00:05	LINE CLEAR AVAILED
4055	27-Jan-24	BANGALORE	66	HV1	BYADARAHALLI	09:47	10:00	00:13	LINE CLEAR AVAILED
4056	27-Jan-24	BANGALORE	66	HV1	BTM 4TH PHASE	10:25	13:15	02:50	LINE CLEAR AVAILED
4057	27-Jan-24	BANGALORE	66	HV2	MAHALAKSHMI LAYOUT	06:25	06:30	00:05	LINE CLEAR AVAILED
4058	27-Jan-24	BANGALORE	66	HV2	KACHMARANAHALLI	10:35	10:40	00:05	LINE CLEAR AVAILED
4059	27-Jan-24	BANGALORE	66	HV2	PRESTIGE SHANTHINIKETHAN	09:00	09:05	00:05	LINE CLEAR AVAILED
4060	27-Jan-24	BANGALORE	66	HV2	BTM 4TH PHASE	10:25	14:28	04:03	LINE CLEAR AVAILED
4061	27-Jan-24	BANGALORE	66	HV2	YARANDANAHALLI 220	15:47	15:58	00:11	TRIPPED ON FAULT
4062	27-Jan-24	BANGALORE	66	JAYADEVA - ADUGODI 1	NO STATION AFFECTED	09:19	13:31	04:12	TRIPPED ON FAULT
4063	27-Jan-24	BANGALORE	66	KGF - MALUR 220	KGF, KAMASAMUDRA, BEML(EHT)	20:50	20:55	00:05	LINE CLEAR AVAILED
4064	27-Jan-24	BANGALORE	66	KHODAYS GLASS FACTORY 220 - BTM 4TH PHASE	BTM 4TH PHASE, SAUDELA, ANNABEL(DLF)	11:58	12:02	00:04	LINE CLEAR AVAILED
4065	27-Jan-24	BANGALORE	66	KHODAYS GLASS FACTORY 220 - PRESTIGE FALCON CITY	PRESTIGE FALCON CITY	11:58	12:00	00:02	LINE CLEAR AVAILED
4066	27-Jan-24	BANGALORE	66	KIADB HARDWARE PARK 220 - VIDYANAGAR	NO STATION AFFECTED	16:59	18:17	01:18	TRIPPED ON FAULT
4067	27-Jan-24	BANGALORE	66	KORMANGALA 220 - AUSTIN TOWN 1	NO STATION AFFECTED	22:23	23:39	01:16	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4068	27-Jan-24	BANGALORE	66	MALUR 220 - LAKKUR	LAKKUR, DEVANGUNDI	21:07	21:11	00:04	LINE CLEAR AVAILED
4069	27-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:35	18:50	00:15	TRIPPED ON FAULT
4070	27-Jan-24	BANGALORE	66	TK HALLI - MANDYA 1	TALAGAVADI, K M DOODI, KK DODDI, MADDUR, KIADB SOMANAHALLI	23:32	23:48	00:16	TRIPPED ON FAULT
4071	27-Jan-24	BANGALORE	66	TK HALLI - MANDYA 2	TALAGAVADI, K M DOODI, KK DODDI, MADDUR, KIADB SOMANAHALLI	23:32	23:48	00:16	TRIPPED ON FAULT
4072	27-Jan-24	BANGALORE	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS, PURVANKARA PALM BEACH	16:45	17:17	00:32	TRIPPED ON FAULT
4073	27-Jan-24	GULBARGA	66	HV2	TAMBRAHALLI_66	18:05	18:10	00:05	TRIPPED ON FAULT
4074	27-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGHALI1	HIREHADAGALI_66, TB HALLI_66	14:55	15:01	00:06	TRIPPED ON FAULT
4075	27-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGHALI2	HIREHADAGALI_66	14:55	15:05	00:10	TRIPPED ON FAULT
4076	27-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGHALI2	HIREHADAGALI_66	20:26	20:36	00:10	TRIPPED ON FAULT
4077	27-Jan-24	GULBARGA	110	HV2	HANUMSAGAR_110	10:51	11:00	00:09	TRIPPED ON FAULT
4078	27-Jan-24	GULBARGA	110	HV2	HANUMSAGAR_110	17:50	18:20	00:30	TRIPPED ON FAULT
4079	27-Jan-24	GULBARGA	110	HV2	HANUMSAGAR_110	18:40	18:45	00:05	TRIPPED ON FAULT
4080	27-Jan-24	GULBARGA	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	07:56	08:10	00:14	TRIPPED ON FAULT
4081	27-Jan-24	GULBARGA	110	KAPNOOR-MAHAGOAN	MAHAGOAN_110, MARGUTTI_110	08:10	15:02	06:52	LINE CLEAR AVAILED
4082	27-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	11:52	11:57	00:05	TRIPPED ON FAULT
4083	27-Jan-24	GULBARGA	110	MALLAT-ALKOD	ALKOD_110, GALAG_110	23:58HRS	00:11HRS	00:13HRS	TRIPPED ON FAULT
4084	27-Jan-24	GULBARGA	220	MALLAT-RTPS	RTPS_220	10:16	18:12	07:56	LINE CLEAR AVAILED
4085	27-Jan-24	HASSAN	66	BHADRA-LINGADAHALLI	gen_bhadra	07:22	07:30	00:08	TRIPPED ON FAULT
4086	27-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	23:25(27.1.2024)			LINE CLEAR AVAILED
4087	27-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	13:15	15:40	02:25	LINE CLEAR AVAILED
4088	27-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	16:00	16:15	00:15	LINE CLEAR AVAILED
4089	27-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	21:35	21:45	00:10	LINE CLEAR AVAILED
4090	27-Jan-24	HASSAN	110	ARSK2-GANDSI	ARSIKERE_220	06:27	06:52	00:25	TRIPPED ON FAULT
4091	27-Jan-24	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	06:27	06:52	00:25	LINE CLEAR AVAILED
4092	27-Jan-24	HASSAN	110	LV1	ARSK2	06:27	06:52	00:25	TRIPPED ON FAULT
4093	27-Jan-24	HASSAN	220	GERSOPA-SHIMOGA1	gen_gerusoppa	17:45(27.1.2024)			LINE CLEAR AVAILED
4094	27-Jan-24	HASSAN	220	HV1	ARSK2	06:27	06:52	00:25	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4095	27-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY2	MRS_220	13:48(27.1.2024)			LINE CLEAR AVAILED
4096	27-Jan-24	HASSAN	220	MRSSHM-STRP1	MRS_220	17:45(27.1.2024)			LINE CLEAR AVAILED
4097	27-Jan-24	MYSORE	66	BANNIMANTAPA-FTS 1	FTS_66	10:03	18:06	08:03	LINE CLEAR AVAILED
4098	27-Jan-24	MYSORE	66	BANNIMANTAPA-FTS 2	FTS_66	10:03	18:06	08:03	LINE CLEAR AVAILED
4099	27-Jan-24	MYSORE	66	BANNIMANTAPA-HOOTAGALLY 1	BANNIMANTAP_66	10:04	18:02	07:58	LINE CLEAR AVAILED
4100	27-Jan-24	MYSORE	66	BANNIMANTAPA-HOOTAGALLY 2	BANNIMANTAP_66	10:04	18:02	07:58	LINE CLEAR AVAILED
4101	27-Jan-24	MYSORE	66	CHIKKAMANDYA-MANDYA	NO STATIONS EFFECTED	09:40	09:57	00:16	TRIPPED ON FAULT
4102	27-Jan-24	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	08:10	21:40	13:30	LINE CLEAR AVAILED
4103	27-Jan-24	MYSORE	66	FTS-RAJEEV NAGARA	NO STATIONS EFFECTED	09:08	18:13	09:05	LINE CLEAR AVAILED
4104	27-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	20:07 (23/01/2024)	8:10 (27/01/2024)	84:03 HRs	LINE CLEAR AVAILED
4105	27-Jan-24	MYSORE	66	HAMPAPURA-MANDYA	NO STATIONS EFFECTED	08:13			LINE CLEAR AVAILED
4106	27-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4107	27-Jan-24	MYSORE	66	HOOTAGALLI-BANNIMANTAPPA 1	BANNIMANTAP_66	11:15	18:01	06:45	LINE CLEAR AVAILED
4108	27-Jan-24	MYSORE	66	HOOTAGALLI-BANNIMANTAPPA 2	BANNIMANTAP_66	11:15	18:02	06:46	LINE CLEAR AVAILED
4109	27-Jan-24	MYSORE	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	06:12			LINE CLEAR AVAILED
4110	27-Jan-24	MYSORE	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	11:25 (26/01/2024)			LINE CLEAR AVAILED
4111	27-Jan-24	MYSORE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	08:12	18:05	09:52	LINE CLEAR AVAILED
4112	27-Jan-24	MYSORE	66	HOOTAGALLI-DATTAGALLI	NO STATIONS EFFECTED	07:41	18:08	10:26	LINE CLEAR AVAILED
4113	27-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	06:35			LINE CLEAR AVAILED
4114	27-Jan-24	MYSORE	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	08:28			LINE CLEAR AVAILED
4115	27-Jan-24	MYSORE	66	HOOTAGALLI-KHB	NO STATIONS EFFECTED	8:28 (27/01/2024)	19:05 (28/01/2024)	24:00 HRs	LINE CLEAR AVAILED
4116	27-Jan-24	MYSORE	66	HOOTAGALLI-VIJAYANAGARA	VIJAYANAGRAMYS_66	14:13	18:34	04:21	LINE CLEAR AVAILED
4117	27-Jan-24	MYSORE	66	HV1	BANNIMANTAP_66	10:04	18:07	08:02	LINE CLEAR AVAILED
4118	27-Jan-24	MYSORE	66	HV2	BANNIMANTAP_66	10:04	18:07	08:02	LINE CLEAR AVAILED
4119	27-Jan-24	MYSORE	66	HV2	KOLLEGALA_66	16:44	16:52	00:07	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4120	27-Jan-24	MYSORE	66	KIRUGAVLU-MALIYURU	MALIYURU_66	17:29	17:47	00:17	TRIPPED ON FAULT
4121	27-Jan-24	MYSORE	66	KM DODDI-MANDYA	NO STATIONS EFFECTED	08:35	18:29	09:53	LINE CLEAR AVAILED
4122	27-Jan-24	MYSORE	66	KUSHALANAGARA 220-MUTHINAMULLUSOGE LIS	NO STATIONS EFFECTED	09:58	12:43	02:45	TRIPPED ON FAULT
4123	27-Jan-24	MYSORE	66	MALAVALLI-SHIMSHA	HADLI_66 MALAVALLI_66	08:04	08:18	00:14	TRIPPED ON FAULT
4124	27-Jan-24	MYSORE	66	MYSORE SOUTH-KADAKOLA	BOGADHI_66 KALAMANDIRA_66 MYSORESOUTH_66	17:24	17:28	00:04	TRIPPED ON FAULT
4125	27-Jan-24	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	22:38			LINE CLEAR AVAILED
4126	27-Jan-24	MYSORE	66	RK NAGARA-DATTAGALLI	RKNAGARA_66	09:56	16:14	06:17	LINE CLEAR AVAILED
4127	27-Jan-24	MYSORE	66	VAJAMANGALA-HEBBANI	NO STATIONS EFFECTED	12:44	12:50	00:06	TRIPPED ON FAULT
4128	27-Jan-24	MYSORE	66	VAJAMANGALA-JYOTHINAGARA	JYOTHINAGARA_66	09:26	16:45	07:19	LINE CLEAR AVAILED
4129	27-Jan-24	MYSORE	66	VIJAYANAGARA-FTS	VIJAYANAGRAMYS_66	09:21	17:30	08:08	LINE CLEAR AVAILED
4130	27-Jan-24	MYSORE	66	VIJAYANAGARA-HOOTAGALLY	VIJAYANAGRAMYS_66	08:49	17:30	08:41	LINE CLEAR AVAILED
4131	27-Jan-24	MYSORE	220	HOOTAGALLI-BASTHIPURA 1	NO STATIONS EFFECTED	09:18	17:37	08:19	LINE CLEAR AVAILED
4132	27-Jan-24	MYSORE	220	HOOTAGALLI-BASTHIPURA 2	NO STATIONS EFFECTED	09:20	17:38	08:18	LINE CLEAR AVAILED
4133	27-Jan-24	MYSORE	220	HOOTAGALLI-VAJAMANGALA	NO STATIONS EFFECTED	08:56	17:56	08:59	LINE CLEAR AVAILED
4134	27-Jan-24	MYSORE	220	HV3	HOOTAGALLY_220	11:26	15:52	04:26	LINE CLEAR AVAILED
4135	27-Jan-24	MYSORE	220	VAJAMANGALA-HOOTAGALLY	NO STATIONS EFFECTED	10:48	17:58	07:10	LINE CLEAR AVAILED
4136	27-Jan-24	TUMKUR	66	BENKIKERE 220kV-DEVARAHALLI	DEVARAHALLI_66, SANTEBENNUR_66, KEREBILCHI_66	10:46	10:51	00:05	TRIPPED ON FAULT
4137	27-Jan-24	TUMKUR	66	BENKIKERE 220kV-GOPPENAHALLI	TAVAREKERE_66, GOPPENAHALLI_66	08:30	08:36	00:06	LINE CLEAR AVAILED
4138	27-Jan-24	TUMKUR	66	BENKIKERE 220kV-NALLUR	NALLUR_66	08:31	08:37	00:06	LINE CLEAR AVAILED
4139	27-Jan-24	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	23:26 (26.01.2024)	1:13 (27.1.24)	01:43	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4140	27-Jan-24	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66	23:33 (26.01.2024)	1:15 (27.1.24)	01:45	LINE CLEAR AVAILED
4141	27-Jan-24	TUMKUR	66	HIRIYUR 220kV- BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66, DASUDI_66, CHANGAVARA_66	00:15	00:30	00:15	TRIPPED ON FAULT
4142	27-Jan-24	TUMKUR	66	LV1(TR1)	BENKIKERE_220	08:31	10:45	02:14	LINE CLEAR AVAILED
4143	27-Jan-24	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66- PANCHANAHALLI_66	06:45	06:55	00:10	TRIPPED ON FAULT
4144	27-Jan-24	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR) VENKATA PURA	VENKATAPURA_66 (GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4145	27-Jan-24	TUMKUR	66	SIRA 220- PATNAYAKANAHALLI 2	PATNAYAKANAHALLI 2	15:59	16:04	00:05	LINE CLEAR AVAILED
4146	27-Jan-24	TUMKUR	66	SIRA 220-TAVAREKERE	TAVAREKERE_66	15:59	16:06	00:07	LINE CLEAR AVAILED
4147	27-Jan-24	TUMKUR	66	THALLAK 220-P R PURA	PR PURA_66, MYLANAHALLI_66, V V PORA_66, DYAVARANAHALLI_66	22:18	22:33	00:15	TRIPPED ON FAULT
4148	27-Jan-24	TUMKUR	66	THALLAK_220 KV-P.R.PURA	P.R.PURA_66	10:18	10:33	00:15	MAIN SUPPLY FAILURE
4149	27-Jan-24	TUMKUR	220	HV1(TR1)	BENKIKERE_220	08:31	10:45	02:14	LINE CLEAR AVAILED
4150	27-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
4151	28-Jan-24	BAGALKOT	110	HAVERI 220-SAVANUR	HAVERI_220	16:52 (27.01.2024)			LINE CLEAR AVAILED
4152	28-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)			LINE CLEAR AVAILED
4153	28-Jan-24	BAGALKOT	110	BANAHATTI- JAMAKHANDI (NAVALGI)	STATION NOT AFFECTED BANAHATTI_110	11:06	15:36	04:30	LINE CLEAR AVAILED
4154	28-Jan-24	BAGALKOT	110	DADDI- F2(HONAGA)	DADDI_110	18:18	18:33	00:15	TRIPPED ON FAULT
4155	28-Jan-24	BAGALKOT	110	GADAGROAD- BIDNAL (GOPPANAKOPPA)	GADAG ROAD_110	21:16 (28.01.2024)			LINE CLEAR AVAILED
4156	28-Jan-24	BAGALKOT	110	GHATAPRABHA 220- P G HUNSHYAL	GHATAPRABHA_220	11:04	11:36	00:32	LINE CLEAR AVAILED
4157	28-Jan-24	BAGALKOT	110	GHATAPRABHA 220- GHATAPRABHA1	GHATAPRABHA_220	10:13	11:31	01:18	LINE CLEAR AVAILED
4158	28-Jan-24	BAGALKOT	110	GHATAPRABHA 220-GOKAK	GHATAPRABHA_220	11:02	11:26	00:24	LINE CLEAR AVAILED
4159	28-Jan-24	BAGALKOT	110	GHATAPRABHA 220- KABBUR	GHATAPRABHA_220	11:04	11:41	00:37	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4160	28-Jan-24	BAGALKOT	110	GHATAPRABHA220-MUDALAGI(MANTUR)	GHATAPRABHA_220	11:04	11:39	00:35	LINE CLEAR AVAILED
4161	28-Jan-24	BAGALKOT	110	GHATAPRABHA220-SHIRGOAN	GHATAPRABHA_220	11:04	11:42	00:38	LINE CLEAR AVAILED
4162	28-Jan-24	BAGALKOT	110	GOPANAKOPPA-MRUTHYUNJAYANAGAR 2(1)	STATION NOT AFFECTED GOPANAKOPPA_110	16:20 (26.10.2023)	21:02 (28.01.2024)	2260:42:00	LINE CLEAR AVAILED
4163	28-Jan-24	BAGALKOT	110	GOPANAKOPPA- GADAG ROAD	GOPANAKOPPA_110	21:45 (28.01.2024)			LINE CLEAR AVAILED
4164	28-Jan-24	BAGALKOT	110	INDI-HIREBEVANUR	INDI_220	07:18	07:28	00:10	TRIPPED ON FAULT
4165	28-Jan-24	BAGALKOT	110	JAMBAGI-VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
4166	28-Jan-24	BAGALKOT	110	JAMKHANDI-MAHALINGAPUR (NAVALGI)	STATION NOT AFFECTED JAMKHANDI_110	11:05	16:04	04:59	LINE CLEAR AVAILED
4167	28-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4168	28-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4169	28-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
4170	28-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4171	28-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
4172	28-Jan-24	BAGALKOT	110	YLWD-F1CBreaker (AIGALI)	STATION NOT AFFECTED YELLAMANAWADI_110	18:45 (26.01.2024)			LINE CLEAR AVAILED
4173	28-Jan-24	BAGALKOT	220	220/110KV,HV1,LV1	GHATAPRABHA_220	10:13	11:23	01:10	TRIPPED ON FAULT
4174	28-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	GHATAPRABHA_220	10:22	11:24	01:02	TRIPPED ON FAULT
4175	28-Jan-24	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220	17:29 (26.01.2024)	15:34 (28.01.2024)	46:05:00	LINE CLEAR AVAILED
4176	28-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	08:46	19:46	11:00	LINE CLEAR AVAILED
4177	28-Jan-24	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	08:45	19:16	10:31	LINE CLEAR AVAILED
4178	28-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4179	28-Jan-24	BAGALKOT	220	GHATAPRABHA-MUGALKHOD1	GHATAPRABHA_220	10:10	11:16	01:06	TRIPPED ON FAULT
4180	28-Jan-24	BAGALKOT	220	GHATAPRABHA-MUGALKHOD2	GHATAPRABHA_220	10:13	11:20	01:07	TRIPPED ON FAULT
4181	28-Jan-24	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	10:10	13:00	02:50	TRIPPED ON FAULT
4182	28-Jan-24	BAGALKOT	220	GHATAPRABHA-NARENDRA2	GHATAPRABHA_220	10:13	13:03	02:50	TRIPPED ON FAULT
4183	28-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
4184	28-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	10:55	16:03	05:08	LINE CLEAR AVAILED
4185	28-Jan-24	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	10:55	16:03	05:08	LINE CLEAR AVAILED
4186	28-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4187	28-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4188	28-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4189	28-Jan-24	BAGALKOT	400	DHONI400-GUDDADAHALLI	DHONI_400	17:57 (27.01.2024)	0:44 (28.01.2024)	6:47:00	LINE CLEAR AVAILED
4190	28-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4191	28-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA, CNL(EHT), SHIVANAHALLI, VANDARGUPPE	07:10	07:20	00:10	TRIPPED ON FAULT
4192	28-Jan-24	BANGALORE	66	GOWRIBIDANUR 220 - DB PURA 2	ALIPURA, THONDEBHAVI	06:21	06:29	00:08	TRIPPED ON FAULT
4193	28-Jan-24	BANGALORE	66	HANUMANTHANAGARA - SOMANAHALLI 220	HANUMANTHANAGARA	10:15	16:00	05:45	LINE CLEAR AVAILED
4194	28-Jan-24	BANGALORE	66	HSR LAYOUT 220 - ADUGODI 2	ADUGODI, JAKKASANDRA	18:22	18:32	00:10	TRIPPED ON FAULT
4195	28-Jan-24	BANGALORE	66	HV1	KIADB DB PURA 220	10:02	16:28	06:26	LINE CLEAR AVAILED
4196	28-Jan-24	BANGALORE	66	HV2	WELCAST	10:04	10:08	00:04	LINE CLEAR AVAILED
4197	28-Jan-24	BANGALORE	66	HV2	KIADB DB PURA 220	10:02	16:28	06:26	LINE CLEAR AVAILED
4198	28-Jan-24	BANGALORE	66	HV3	KIADB DB PURA 220	10:02	16:28	06:26	LINE CLEAR AVAILED
4199	28-Jan-24	BANGALORE	66	KGF - T GOLLAHALLI 220	NO STATION AFFECTED	18:25	18:36	00:11	TRIPPED ON FAULT
4200	28-Jan-24	BANGALORE	66	KIADB DB PURA 220 - APPAREL PARK	APPAREL PARK	10:02	16:48	06:46	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4201	28-Jan-24	BANGALORE	66	KIADB DB PURA 220 - HSS (EHT)	HSS (EHT)	10:02	16:29	06:27	LINE CLEAR AVAILED
4202	28-Jan-24	BANGALORE	66	KIADB DB PURA 220 - INDO MM (EHT)	INDO MM (EHT)	10:02	16:29	06:27	LINE CLEAR AVAILED
4203	28-Jan-24	BANGALORE	66	KOLAR - VEMGAL	VEMGAL, KYALANUR, TALGUNDA	08:11	17:48	09:37	LINE CLEAR AVAILED
4204	28-Jan-24	BANGALORE	66	MAASTHI - SOLAR (IPP)	NO STATION AFFECTED	10:05	10:15	00:10	TRIPPED ON FAULT
4205	28-Jan-24	BANGALORE	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	11:27	11:32	00:05	LINE CLEAR AVAILED
4206	28-Jan-24	BANGALORE	66	MARALAWADI - KANAKAPURA 220	MARALWADI, GODUR	10:05	10:07	00:02	TRIPPED ON FAULT
4207	28-Jan-24	BANGALORE	66	MITTEMARI 220 - BAGEPALLI 1	VATADAHOSAHALLI	03:52	03:59	00:07	TRIPPED ON FAULT
4208	28-Jan-24	BANGALORE	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	11:34	11:38	00:04	LINE CLEAR AVAILED
4209	28-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - H GOLAHALLI	H GOLLAHALLI, MUDIYANUR	05:05	05:15	00:10	TRIPPED ON FAULT
4210	28-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - KGF 2	NO STATION AFFECTED	18:25	18:35	00:10	TRIPPED ON FAULT
4211	28-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - NANGLI	NANGALI, BYRAKUR	10:49	15:15	04:26	LINE CLEAR AVAILED
4212	28-Jan-24	BANGALORE	220	HV1	KIADB DB PURA 220	10:01	16:27	06:26	LINE CLEAR AVAILED
4213	28-Jan-24	BANGALORE	220	HV2	KIADB DB PURA 220	10:01	16:27	06:26	LINE CLEAR AVAILED
4214	28-Jan-24	BANGALORE	220	KIADB DB PURA 220 - GOWRIBIDANUR 220	KIADB DB PURA 220	10:00	16:27	06:27	LINE CLEAR AVAILED
4215	28-Jan-24	GULBARGA	110	GANGAVATI-VENKATAGIRI	VENKATAGIRI_110	12:18	12:26	00:08	MAIN SUPPLY FAILURE
4216	28-Jan-24	GULBARGA	110	HV3	SOMASAMUNDRA_110	05:47	05:53	00:06	TRIPPED ON FAULT
4217	28-Jan-24	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	06:46	07:08	00:22	TRIPPED ON FAULT
4218	28-Jan-24	GULBARGA	110	LINGASUGUR-MUDAGAL	MUDGAL_110, BAYYAPUR_110	23:50	23:56	00:06	TRIPPED ON FAULT
4219	28-Jan-24	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	06:21	06:26	00:05	TRIPPED ON FAULT
4220	28-Jan-24	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	18:42	18:52	00:10	TRIPPED ON FAULT
4221	28-Jan-24	GULBARGA	110	SULEKAL-MALLAPUR	MALLAPUR_110	02:23	02:34	00:11	MAIN SUPPLY FAILURE
4222	28-Jan-24	GULBARGA	220	LINGAPUR-GDHALLI1	GUDDAHALLI_220,DHRUVD ESH_IPP	09:58	15:06	05:08	LINE CLEAR AVAILED
4223	28-Jan-24	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	10:10	10:40	00:30	LINE CLEAR AVAILED
4224	28-Jan-24	HASSAN	66	DODDAHA-HOOTGALLI	DODDAHALLY_66	19:13	19:18	00:05	LINE CLEAR AVAILED
4225	28-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	10:00	10:10	00:10	LINE CLEAR AVAILED
4226	28-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	10:10	10:40	00:30	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4227	28-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	23:25(27.1.2024)	10:40(28.1.2028)		LINE CLEAR AVAILED
4228	28-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	10:10	10:40	00:30	MAIN SUPPLY FAILURE
4229	28-Jan-24	HASSAN	110	HV2	KARKALA_110	11:29	11:35	00:06	TRIPPED ON FAULT
4230	28-Jan-24	HASSAN	110	HV3	BAIKAMPADY_110	13:03	14:00	00:57	LINE CLEAR AVAILED
4231	28-Jan-24	HASSAN	110	HV3	GURUVAYANKERE_110	11:18	12:31	01:13	LINE CLEAR AVAILED
4232	28-Jan-24	HASSAN	110	HV4	BAIKAMPADY_110	10:25	13:00	02:35	LINE CLEAR AVAILED
4233	28-Jan-24	HASSAN	220	GERSOPA-SHIMOGA1	gen_gerusoppa	17:45(27.1.2024)			LINE CLEAR AVAILED
4234	28-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY2	MRS_220	13:48(27.1.2024)	22:33(28.1.2024)		LINE CLEAR AVAILED
4235	28-Jan-24	HASSAN	220	MRSSHM-STRP1	MRS_220	17:45(27.1.2024)			LINE CLEAR AVAILED
4236	28-Jan-24	MYSORE	66	BG NAGARA-VADERALLI	ADICHUNCHANAGIRI_66 VADERALLI_66	03:10	03:15	00:05	TRIPPED ON FAULT
4237	28-Jan-24	MYSORE	66	BG NAGARA-VADERALLI	ADICHUNCHANAGIRI_66 VADERALLI_66	06:28	06:32	00:04	TRIPPED ON FAULT
4238	28-Jan-24	MYSORE	66	D R PETE-KUNTHUR	SANTHEMARAHALLI_66	05:01	05:08	00:07	TRIPPED ON FAULT
4239	28-Jan-24	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	06:33	18:13	11:39	LINE CLEAR AVAILED
4240	28-Jan-24	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	20:53			LINE CLEAR AVAILED
4241	28-Jan-24	MYSORE	66	FTS-BANNIMANTAPA 1	NO STATIONS EFFECTED	06:36	18:05	11:29	LINE CLEAR AVAILED
4242	28-Jan-24	MYSORE	66	FTS-BANNIMANTAPA 2	NO STATIONS EFFECTED	06:36	18:05	11:29	LINE CLEAR AVAILED
4243	28-Jan-24	MYSORE	66	FTS-RAJEEV NAGARA	DEVANOORMYS_66 RAJEEVNAGARA_66	09:53	20:51	10:58	LINE CLEAR AVAILED
4244	28-Jan-24	MYSORE	66	HAMPAPURA-MANDYA	NO STATIONS EFFECTED	8:13 (27/01/2024)			LINE CLEAR AVAILED
4245	28-Jan-24	MYSORE	66	HEBBAL-HOOTAGALLY	HEBBAL_66	13:08	17:54	04:46	LINE CLEAR AVAILED
4246	28-Jan-24	MYSORE	66	HEBBAL-METTAGALLY	METAGALLY_66	08:55	17:57	09:01	LINE CLEAR AVAILED
4247	28-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4248	28-Jan-24	MYSORE	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	6:12 (27/01/2024)			LINE CLEAR AVAILED
4249	28-Jan-24	MYSORE	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	11:25 (26/01/2024)			LINE CLEAR AVAILED
4250	28-Jan-24	MYSORE	66	HOOTAGALLI-BEML	NO STATIONS EFFECTED	09:45	18:00	08:15	LINE CLEAR AVAILED
4251	28-Jan-24	MYSORE	66	HOOTAGALLI-BOGADHI	NO STATIONS EFFECTED	06:38	18:05	11:27	LINE CLEAR AVAILED
4252	28-Jan-24	MYSORE	66	HOOTAGALLI-DATAGALLI	NO STATIONS EFFECTED	06:30	18:04	11:34	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4253	28-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
4254	28-Jan-24	MYSORE	66	HOOTAGALLI-HEBBAL	HEBBAL_66 METAGALLY_66	13:14	17:54	04:39	LINE CLEAR AVAILED
4255	28-Jan-24	MYSORE	66	HUNSUR 220-HUNSUR 1	BANNIKUPPE_66 ELAVALA_66 HUNSUR_66	01:30	01:41	00:11	TRIPPED ON FAULT
4256	28-Jan-24	MYSORE	66	HUNSUR 220-HUNSUR 2	BANNIKUPPE_66 ELAVALA_66 HUNSUR_66	01:30	01:41	00:11	TRIPPED ON FAULT
4257	28-Jan-24	MYSORE	66	HUNSUR-ELAWALA	ELAVALA_66 HUNSUR_66	01:30	01:42	00:12	TRIPPED ON FAULT
4258	28-Jan-24	MYSORE	66	HV1	HEBBAL_66	13:08	17:55	04:47	LINE CLEAR AVAILED
4259	28-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	09:11	09:15	00:04	TRIPPED ON FAULT
4260	28-Jan-24	MYSORE	66	HV1	NAGAMANGALA_66	17:29	18:05	00:35	LINE CLEAR AVAILED
4261	28-Jan-24	MYSORE	66	HV1	THANDYA_66	09:04	17:35	08:31	LINE CLEAR AVAILED
4262	28-Jan-24	MYSORE	66	HV2	HANGLA_66	15:30	15:35	00:05	TRIPPED ON FAULT
4263	28-Jan-24	MYSORE	66	HV2	HEBBAL_66	13:08	17:55	04:47	LINE CLEAR AVAILED
4264	28-Jan-24	MYSORE	66	HV2	THANDYA_66	09:04	17:35	08:31	LINE CLEAR AVAILED
4265	28-Jan-24	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	06:51	18:01	11:10	LINE CLEAR AVAILED
4266	28-Jan-24	MYSORE	66	KADAKOLA-NANJANGUDU 1	NANJANGUDU_66	09:16	17:12	07:56	LINE CLEAR AVAILED
4267	28-Jan-24	MYSORE	66	KADAKOLA-THANDYA	THANDYA_66	09:14	17:14	07:59	LINE CLEAR AVAILED
4268	28-Jan-24	MYSORE	66	KM DODDI-MANDYA	NO STATIONS EFFECTED	06:39	18:07	11:27	LINE CLEAR AVAILED
4269	28-Jan-24	MYSORE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	18:05			LINE CLEAR AVAILED
4270	28-Jan-24	MYSORE	66	MYSORE SOUTH-KADAKOLA	NO STATIONS EFFECTED	22:38 (27/01/2024)	6:38 (28/01/2024)	7:59 HRs	LINE CLEAR AVAILED
4271	28-Jan-24	MYSORE	66	NAGAMANGALA-TUBINAKERE 1	NAGAMANGALA_66	17:29	18:04	00:35	LINE CLEAR AVAILED
4272	28-Jan-24	MYSORE	66	VAJAMANGALA-DEVNUR(MYS)	NO STATIONS EFFECTED	14:19	17:13	02:54	LINE CLEAR AVAILED
4273	28-Jan-24	MYSORE	220	HOOTAGALLI-BASTHIPURA 1	NO STATIONS EFFECTED	07:17	17:45	10:28	LINE CLEAR AVAILED
4274	28-Jan-24	MYSORE	220	HOOTAGALLI-BASTHIPURA 2	NO STATIONS EFFECTED	07:17	17:46	10:28	LINE CLEAR AVAILED
4275	28-Jan-24	MYSORE	220	HOOTAGALLI-VAJAMANGALA	NO STATIONS EFFECTED	07:00	17:56	10:55	LINE CLEAR AVAILED
4276	28-Jan-24	MYSORE	220	HV2	HOOTAGALLY_220	10:29	15:22	04:52	LINE CLEAR AVAILED
4277	28-Jan-24	TUMKUR	66	ANCHEPALYA 220- B G NAGARA66	JIDDEGERE_66,YEDIYUR_66,THIPPUR_66	03:10	03:15	00:05	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4278	28-Jan-24	TUMKUR	66	ANCHEPALYA 220- B G NAGARA66	JIDDEGERE_66,YEDIYUR_66,THIPPUR_66	06:25	06:40	00:15	MAIN SUPPLY FAILURE
4279	28-Jan-24	TUMKUR	66	ANCHEPALYA 220- B G NAGARA66	JIDDEGERE_66,YEDIYUR_66,THIPPUR_66	15:40	16:40	01:00	LINE CLEAR AVAILED
4280	28-Jan-24	TUMKUR	66	ANTHRASANAHALI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:31	10:33	00:02	LINE CLEAR AVAILED
4281	28-Jan-24	TUMKUR	66	Davangere SRS _ Mayakonda	Mayakonda_66, CHIKKAJAJUR_66, SASALUHALLA_66	09:58	10:10	00:12	LINE CLEAR AVAILED
4282	28-Jan-24	TUMKUR	66	HV1(TR1)	KIADB_220	10:20	13:11	02:51	LINE CLEAR AVAILED
4283	28-Jan-24	TUMKUR	66	HV2(TR2)	KIADB_220	10:20	13:01	02:41	LINE CLEAR AVAILED
4284	28-Jan-24	TUMKUR	66	KDBVNP- TMTP	TMTP_66	10:11	13:06	02:55	LINE CLEAR AVAILED
4285	28-Jan-24	TUMKUR	66	LV1(TR1)	KIADB_66	10:12	13:02	02:50	LINE CLEAR AVAILED
4286	28-Jan-24	TUMKUR	66	LV2(TR2)	KIADB_66	10:06	15:44	05:38	LINE CLEAR AVAILED
4287	28-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4288	28-Jan-24	TUMKUR	66	TMTP_66-BRAHMASANDRA_66	TMTP_66	10:10	14:05	03:55	LINE CLEAR AVAILED
4289	28-Jan-24	TUMKUR	66	TMTP66-KIADB VNP220LINE-3	TMTP_66	10:10	13:05	02:55	LINE CLEAR AVAILED
4290	28-Jan-24	TUMKUR	66	TMTP66-KORA LINE-1	TMTP_66,	06:19	06:40	00:21	TRIPPED ON FAULT
4291	28-Jan-24	TUMKUR	66	TMTP66-KORA LINE-1	TMTP_66,	06:52	07:05	00:13	TRIPPED ON FAULT
4292	28-Jan-24	TUMKUR	66	TMTP66-THOVINAKERE	TMTP_66	10:10	17:05	06:55	LINE CLEAR AVAILED
4293	28-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
4294	29-Jan-24	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	16:52 (27.01.2024)			LINE CLEAR AVAILED
4295	29-Jan-24	BAGALKOT	110	110/11KV, HV1(10MVA)	AREMALLAPUR_110	11:39	19:57	08:18	LINE CLEAR AVAILED
4296	29-Jan-24	BAGALKOT	110	110/11KV, HV3(10MVA)	BIJAPUR CITY_110	7:47 (29.01.2024)			LINE CLEAR AVAILED
4297	29-Jan-24	BAGALKOT	110	110/11KV,HV2 (20MVA)	STATION NOT AFFECTED YELLAMANAWADI_110	11:50	15:51	04:01	TRIPPED ON FAULT
4298	29-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)	17:34 (29.01.2024)	136:09:00	LINE CLEAR AVAILED
4299	29-Jan-24	BAGALKOT	110	ANKALAGI- BELGAUM	ANKALAGI_110	11:48	13:57	02:09	LINE CLEAR AVAILED
4300	29-Jan-24	BAGALKOT	110	ATHANI-AIGALI	ATHANI_220	10:05	14:35	04:30	LINE CLEAR AVAILED
4301	29-Jan-24	BAGALKOT	110	CHIKKODI220-SANKESHWAR(HUKKERI)	CHIKKODI_220	10:49	12:29	01:40	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4302	29-Jan-24	BAGALKOT	110	GADAGROAD- BIDNAL (GOPPANAKOPPA)	GADAG ROAD_110	21:16 (28.01.2024)			LINE CLEAR AVAILED
4303	29-Jan-24	BAGALKOT	110	GOPPANAKOPPA- GADAG ROAD	GOPPANAKOPPA_110	21:45 (28.01.2024)			LINE CLEAR AVAILED
4304	29-Jan-24	BAGALKOT	110	HUDLI- ANKALGI	HUDLI_110	11:49	13:30	01:41	LINE CLEAR AVAILED
4305	29-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
4306	29-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4307	29-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4308	29-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)			LOAD CURTAILMENT
4309	29-Jan-24	BAGALKOT	110	MUDDEBIHAL-KNM SOLAR(HIREMURAL)	MUDDEBIHAL_110	07:05	11:32	04:27	LINE CLEAR AVAILED
4310	29-Jan-24	BAGALKOT	110	MUGALKHOD-NAGANUR	MUGALKHOD_220	16:10	16:40	00:30	TRIPPED ON FAULT
4311	29-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4312	29-Jan-24	BAGALKOT	110	SHIGGOAN- LN2(MUNDAGOD)	SHIGGOAN_220	13:34	13:57	00:23	LINE CLEAR AVAILED
4313	29-Jan-24	BAGALKOT	110	SHIGON-RMKP Cbreaker (MUNDGOD)	STATION NOT AFFECTED SHIGGOAN_110	13:30	14:05	00:35	LINE CLEAR AVAILED
4314	29-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
4315	29-Jan-24	BAGALKOT	110	YLWD-F1CBreaker (AIGALI)	STATION NOT AFFECTED YELLAMANAWADI_110	18:45 (26.01.2024)	10:23 (29.01.2024)	63:38:00	LINE CLEAR AVAILED
4316	29-Jan-24	BAGALKOT	220	220/110KV,HV1,LV1	INDI_220	8:58	16:35	07:37	LINE CLEAR AVAILED
4317	29-Jan-24	BAGALKOT	220	220/110KV,HV2,LV2	INDI_220	17:30	18:10	00:40	LINE CLEAR AVAILED
4318	29-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4319	29-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
4320	29-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4321	29-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4322	29-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4323	29-Jan-24	BANGALORE	66	AREHALLI - BANASHANKARI	AREHALLI	17:58	18:04	00:06	LINE CLEAR AVAILED
4324	29-Jan-24	BANGALORE	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	15:01	15:06	00:05	LINE CLEAR AVAILED
4325	29-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4326	29-Jan-24	BANGALORE	66	BYADRAHALLI - KODIGEHALI	KODIGEHALI	09:20	09:30	00:10	LINE CLEAR AVAILED
4327	29-Jan-24	BANGALORE	66	CHANNAPATNA 220 - KOTHIPURA 2	BEVOOR, SANKALGERE, DASHAVARA, CNL(EHT), SHIVANAHALLI, VANDARGUPPE	14:47	14:59	00:12	TRIPPED ON FAULT
4328	29-Jan-24	BANGALORE	66	CHINTAMANI 66 - RAILWAY TRACTION	RAILWAY TRACTION	14:26	14:42	00:16	TRIPPED ON FAULT
4329	29-Jan-24	BANGALORE	66	ELECTRONIC CITY - HULIMANGALA	HULIMANGALA	10:39	10:50	00:11	MAIN SUPPLY FAILURE
4330	29-Jan-24	BANGALORE	66	ELECTRONIC CITY - YARANDANAHALLI 220	ELECTRONIC CITY, HULIMANGALA	15:34	15:38	00:04	LINE CLEAR AVAILED
4331	29-Jan-24	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	09:39	09:43	00:04	LINE CLEAR AVAILED
4332	29-Jan-24	BANGALORE	66	HV1	PILLAGUPPA	09:25	09:40	00:15	TRIPPED ON FAULT
4333	29-Jan-24	BANGALORE	66	HV1	GUNDAMGERE	23:38	23:52	00:14	TRIPPED ON FAULT
4334	29-Jan-24	BANGALORE	66	HV1	MAASTHI	12:00	12:15	00:15	LINE CLEAR AVAILED
4335	29-Jan-24	BANGALORE	66	HV2	KENGERI SATELLITE TOWN	15:15	15:20	00:05	LINE CLEAR AVAILED
4336	29-Jan-24	BANGALORE	66	HV2	VR DODDI	12:25	13:45	01:20	LINE CLEAR AVAILED
4337	29-Jan-24	BANGALORE	66	ITI 220 - DRDO	DRDO	12:50	13:16	00:26	LINE CLEAR AVAILED
4338	29-Jan-24	BANGALORE	66	ITI 220 - DRDO	DRDO	14:17	14:23	00:06	LINE CLEAR AVAILED
4339	29-Jan-24	BANGALORE	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	11:19	11:23	00:04	LINE CLEAR AVAILED
4340	29-Jan-24	BANGALORE	66	JANGAMKOTE - MELUR	JANGAMKOTE, VIJAYAPURA	15:56	16:00	00:04	LINE CLEAR AVAILED
4341	29-Jan-24	BANGALORE	66	JAYANAGARA - NATIONAL COLLEGE	JAYANAGARA	17:21	17:23	00:02	LINE CLEAR AVAILED
4342	29-Jan-24	BANGALORE	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	10:29	10:43	00:14	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4343	29-Jan-24	BANGALORE	66	LAKKUR - MALUR 220	LAKKUR, DEVANAGUNDHI	05:35	05:55	00:20	TRIPPED ON FAULT
4344	29-Jan-24	BANGALORE	66	MAASTHI - ADANI SOLAR(IPP)	NO STATION AFFECTED	18:05	18:10	00:05	TRIPPED ON FAULT
4345	29-Jan-24	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1, INFOSYS(EHT), HULIMANGALA, ELECTRONIC CITY	09:15	09:48	00:33	MAIN SUPPLY FAILURE
4346	29-Jan-24	BANGALORE	66	NAGANATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, HUSKUR(CHOKKASANDRA), TATA BP SOLAR(EHT), BIOCON(EHT), TECH MAHINDRA(EHT)	09:15	09:48	00:33	MAIN SUPPLY FAILURE
4347	29-Jan-24	BANGALORE	66	NALLIMARADANAHALLI - CHIKKABALLAPURA I/A	NALLIMARADANAHALLI	16:30	18:15	01:45	LINE CLEAR AVAILED
4348	29-Jan-24	BANGALORE	66	NALLIMARADANAHALLI - CHIKKABALLAPURA I/A	NALLIMARADANAHALLI	18:55	19:20	00:25	LINE CLEAR AVAILED
4349	29-Jan-24	BANGALORE	66	PERESANDRA - GOWRIBIDANUR 220	PERESANDRA	15:05	15:10	00:05	LINE CLEAR AVAILED
4350	29-Jan-24	BANGALORE	66	PERESANDRA - SOMENAHALLI	PERESANDRA	12:50	12:55	00:05	LINE CLEAR AVAILED
4351	29-Jan-24	BANGALORE	66	SARAKKI - JAYADEVA	SARAKKI	10:28	10:31	00:03	LINE CLEAR AVAILED
4352	29-Jan-24	BANGALORE	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	17:28	17:32	00:04	LINE CLEAR AVAILED
4353	29-Jan-24	BANGALORE	66	SHOBHA INDRAPRASTHA - A STATION 220	SHOBHA INDRAPRASHTA	10:38	10:43	00:05	LINE CLEAR AVAILED
4354	29-Jan-24	BANGALORE	66	SOMENAHALLI - MITTEMARI 220	SOMENAHALLI	12:55	13:05	00:10	LINE CLEAR AVAILED
4355	29-Jan-24	BANGALORE	66	SOMENAHALLI - PERESANDRA	SOMENAHALLI	14:55	15:00	00:05	LINE CLEAR AVAILED
4356	29-Jan-24	BANGALORE	66	T GOLLAHALLI 220 - TAYALUR	TAYALUR, NG HULKUR, MALLANAYAKANAHALLI	12:42	12:58	00:16	TRIPPED ON FAULT
4357	29-Jan-24	BANGALORE	66	VIJAYAPURA - DB PURA 220	JANGAMKOTE, VIJAYAPURA	11:00	11:12	00:12	LINE CLEAR AVAILED
4358	29-Jan-24	BANGALORE	220	MYLASANDRA 400 - NAGANATHPURA 220	NAGANATHPURA 220	09:15	09:48	00:33	TRIPPED ON FAULT
4359	29-Jan-24	BANGALORE	220	NAGANATHPURA 220 - MYLASANDRA 220	NAGANATHPURA 220	09:15	09:48	00:33	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4360	29-Jan-24	GULBARGA	66	CJ HALLI-GUDDEKOTE	C J HALLI_66, HOSAHALLI_66	06:45	07:15	00:30	TRIPPED ON FAULT
4361	29-Jan-24	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,SUZL ON WIND_IPP	00:15	00:20	00:05	TRIPPED ON FAULT
4362	29-Jan-24	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,SUZL ON WIND_IPP	07:45	08:25	00:40	TRIPPED ON FAULT
4363	29-Jan-24	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,SUZL ON WIND_IPP	12:20	12:25	00:05	TRIPPED ON FAULT
4364	29-Jan-24	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,SUZL ON WIND_IPP	12:25	17:30	05:05	TRIPPED ON FAULT
4365	29-Jan-24	GULBARGA	66	HV3	TELAGI_66	07:50	07:55	00:05	TRIPPED ON FAULT
4366	29-Jan-24	GULBARGA	66	HV3	TELAGI_66	13:20	13:25	00:05	TRIPPED ON FAULT
4367	29-Jan-24	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66 ,BACHIKONDANAHALLI_66	15:20	15:57	00:37	LINE CLEAR AVAILED
4368	29-Jan-24	GULBARGA	66	ITTAGI-HAGARIBOMMANAHALLI	HAGARIBOMMANAHALLI_66 ,BACHIKONDANAHALLI_66	19:08	19:13	00:05	TRIPPED ON FAULT
4369	29-Jan-24	GULBARGA	66	ITTAGI-HIREHADAGALI2	SOVENHALLI_66, HIREHADAGALI_66, MAGLA_66, GIRIYAPUR_66	02:15	02:25	00:10	TRIPPED ON FAULT
4370	29-Jan-24	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66,SUZL ON WIND_IPP	14:40	14:44	00:04	LINE CLEAR AVAILED
4371	29-Jan-24	GULBARGA	66	TELAGI-KURBARARHALLI	KURBARARHALLI_66	07:50	10:40	02:50	LINE CLEAR AVAILED
4372	29-Jan-24	GULBARGA	110	AURAD-DONGARGOAN	AURAD_110	10:05	14:30	04:25	LINE CLEAR AVAILED
4373	29-Jan-24	GULBARGA	110	HALWARTHY-KOPPAL 1& 2	KOPPAL_110	14:07	14:59	00:52	TRIPPED ON FAULT
4374	29-Jan-24	GULBARGA	110	HV2	HANAMSAGAR_110	17:05	18:05	01:00	LINE CLEAR AVAILED
4375	29-Jan-24	GULBARGA	110	HV2	BELLARY NORTH_110	10:58	14:46	03:48	LINE CLEAR AVAILED
4376	29-Jan-24	GULBARGA	110	LADHA-BHALKI	LADHA_110	05:25	05:35	00:10	TRIPPED ON FAULT
4377	29-Jan-24	GULBARGA	110	MALLAT-MADALAPUR	ADAVIAMARESHWAR_110, JAWALGERA_110	19:36	19:42	00:06	TRIPPED ON FAULT
4378	29-Jan-24	GULBARGA	110	MUNIRABAD-MALLAPURA	KEREHALLI_110,MALLAPURA_110	21:10	21:20	00:10	TRIPPED ON FAULT
4379	29-Jan-24	GULBARGA	110	RAJESHWAR-SASTHAPUR	RAJESHWAR_110	13:25	13:35	00:10	TRIPPED ON FAULT
4380	29-Jan-24	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	04:09	04:19	00:10	TRIPPED ON FAULT
4381	29-Jan-24	GULBARGA	220	HV1	HALBARGA_220	14:30	17:10	02:40	LINE CLEAR AVAILED
4382	29-Jan-24	GULBARGA	220	KOLLUR-DEODURGA	KOLLUR_110	04:06	04:16	00:10	TRIPPED ON FAULT
4383	29-Jan-24	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE
4384	29-Jan-24	HASSAN	66	ARAKAL-MALLIPATNA	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4385	29-Jan-24	HASSAN	66	ARAKAL-SANIRSANTE	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE
4386	29-Jan-24	HASSAN	66	BALLUPE-SKLPR	BALLUPETE_66	11:20	14:20	03:00	LINE CLEAR AVAILED
4387	29-Jan-24	HASSAN	66	CRPTN	HNPPURA_220	01:37	02:08	00:31	LINE CLEAR AVAILED
4388	29-Jan-24	HASSAN	66	DODMGE	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE
4389	29-Jan-24	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	14:49	15:28	00:39	LINE CLEAR AVAILED
4390	29-Jan-24	HASSAN	66	HASSN22-BELUR	HASSAN_220	14:49	15:28	00:39	LINE CLEAR AVAILED
4391	29-Jan-24	HASSAN	66	HASSN22-CHIKAMAGLUR2	HASSAN_220	14:49	17:19	02:30	LINE CLEAR AVAILED
4392	29-Jan-24	HASSAN	66	HASSN22-HN PURA	HASSAN_220	14:49	15:38	00:49	LINE CLEAR AVAILED
4393	29-Jan-24	HASSAN	66	HASSN22-HSN66	HASSAN_220	14:49	15:28	00:39	LINE CLEAR AVAILED
4394	29-Jan-24	HASSAN	66	HASSN22-R R NAGAR	HASSAN_220	06:34	07:50	01:16	TRIPPED ON FAULT
4395	29-Jan-24	HASSAN	66	HASSN22-SKPURA2	HASSAN_220	11:17	14:21	03:04	LINE CLEAR AVAILED
4396	29-Jan-24	HASSAN	66	HASSN22-UDDURKOPLU	HASSAN_220	14:49	16:04	01:15	LINE CLEAR AVAILED
4397	29-Jan-24	HASSAN	66	HNPR2--CRPTN	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4398	29-Jan-24	HASSAN	66	HNPR2-HASS1	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4399	29-Jan-24	HASSAN	66	HNPR2-HASS1	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4400	29-Jan-24	HASSAN	66	HNPR2-HASS2	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4401	29-Jan-24	HASSAN	66	HNPR2-HASS2	HNPPURA_220	07:28	07:38	00:10	TRIPPED ON FAULT
4402	29-Jan-24	HASSAN	66	HNPR2-HASS3	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4403	29-Jan-24	HASSAN	66	HNPR2-HNPR1	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4404	29-Jan-24	HASSAN	66	HNPR2-HNPR1	HNPR2	03:15	05:00	01:45	LINE CLEAR AVAILED
4405	29-Jan-24	HASSAN	66	HNPR2-MYSOR1	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4406	29-Jan-24	HASSAN	66	HNPR2-MYSOR2	HNPPURA_220	01:37	02:08	00:31	TRIPPED ON FAULT
4407	29-Jan-24	HASSAN	66	HNPR2-RNPR1	HNPR2	01:37	05:13	03:36	TRIPPED ON FAULT
4408	29-Jan-24	HASSAN	66	HNPR2-RNPR2	HNPR2	01:37	05:00	03:23	TRIPPED ON FAULT
4409	29-Jan-24	HASSAN	66	HNPPURA-RAMNATHPURA	HNPPURA_66	03:29	05:00	01:31	LINE CLEAR AVAILED
4410	29-Jan-24	HASSAN	66	HV1	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE
4411	29-Jan-24	HASSAN	66	HV1	DUDDA_66	14:50	16:05	01:15	MAIN SUPPLY FAILURE
4412	29-Jan-24	HASSAN	66	HV2	ARAKALGUD_66	14:50	15:25	00:35	MAIN SUPPLY FAILURE
4413	29-Jan-24	HASSAN	66	HV2	DUDDA_66	14:50	16:05	01:15	MAIN SUPPLY FAILURE
4414	29-Jan-24	HASSAN	66	HV2	HALEBEEDU_66	12:00	12:41	00:41	LINE CLEAR AVAILED
4415	29-Jan-24	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	06:57	07:03	00:06	MAIN SUPPLY FAILURE
4416	29-Jan-24	HASSAN	66	LV1	HNPPURA_220	01:37	02:04	00:27	TRIPPED ON FAULT
4417	29-Jan-24	HASSAN	66	LV2	HASSAN_220	14:49	15:28	00:39	TRIPPED ON FAULT
4418	29-Jan-24	HASSAN	66	LV2	HNPPURA_220	01:37	02:04	00:27	TRIPPED ON FAULT
4419	29-Jan-24	HASSAN	66	UDDURKO-CHIKMNGLR	UDDURKOPLU_66	14:50	16:05	01:15	MAIN SUPPLY FAILURE
4420	29-Jan-24	HASSAN	66	UDDURKO--CHIKNDGOLA	UDDURKOPLU_66	14:50	16:05	01:15	TRIPPED ON FAULT
4421	29-Jan-24	HASSAN	66	UDDURKO-HASSAN1	UDDURKOPLU_66	14:50	16:05	01:15	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4422	29-Jan-24	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	14:50	17:15	02:25	MAIN SUPPLY FAILURE
4423	29-Jan-24	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPLU_66	14:50 (29.01.2024)			MAIN SUPPLY FAILURE
4424	29-Jan-24	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPLU_66	14:50	19:40	04:50	MAIN SUPPLY FAILURE
4425	29-Jan-24	HASSAN	110	HV1	BAIKAMPADY_110	10:25	16:00	05:35	LINE CLEAR AVAILED
4426	29-Jan-24	HASSAN	110	HV1	GURUPURA_110	10:42	13:18	02:36	LINE CLEAR AVAILED
4427	29-Jan-24	HASSAN	110	HV6	KAVOOR_220	12:45	15:36	02:51	LINE CLEAR AVAILED
4428	29-Jan-24	HASSAN	220	GERSOPA-SHIMOGA1	gen_gerusoppa	17:45(27.1.2024)	9:58(29.1.024)		LINE CLEAR AVAILED
4429	29-Jan-24	HASSAN	220	HV1	HNPURA_220	01:37	02:02	00:25	TRIPPED ON FAULT
4430	29-Jan-24	HASSAN	220	HV2	HNPURA_220	01:37	02:03	00:26	TRIPPED ON FAULT
4431	29-Jan-24	HASSAN	220	HV2	HASSAN_220	14:49	15:28	00:39	TRIPPED ON FAULT
4432	29-Jan-24	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	17:45(27.1.2024)	9:58(29.1.024)		LINE CLEAR AVAILED
4433	29-Jan-24	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	11:27	15:12	03:45	LINE CLEAR AVAILED
4434	29-Jan-24	HASSAN	220	VARAH1-SHIMOGA1	gen_varahi	11:27	15:12	03:45	LINE CLEAR AVAILED
4435	29-Jan-24	MYSORE	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	08:05	09:46	01:40	LINE CLEAR AVAILED
4436	29-Jan-24	MYSORE	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	20:53 (28/01/2024)	8:10 (29/01/2024)	11:17 HRs	LINE CLEAR AVAILED
4437	29-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	07:41	07:46	00:05	LINE CLEAR AVAILED
4438	29-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	07:55			LINE CLEAR AVAILED
4439	29-Jan-24	MYSORE	66	HAMPAPURA-MANDYA	NO STATIONS EFFECTED	8:13 (27/01/2024)	7:41 (29/01/2024)	47:27 HRs	LINE CLEAR AVAILED
4440	29-Jan-24	MYSORE	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	08:08			LINE CLEAR AVAILED
4441	29-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4442	29-Jan-24	MYSORE	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	11:32	11:53	00:20	TRIPPED ON FAULT
4443	29-Jan-24	MYSORE	66	HOOTAGALLI-BARC 2	NO STATIONS EFFECTED	6:12 (27/01/2024)	9:29 (29/01/2024)	51:17 HRS	LINE CLEAR AVAILED
4444	29-Jan-24	MYSORE	66	HOOTAGALLI-BARC1	NO STATIONS EFFECTED	11:25 (26/01/2024)	13:01 (29/01/2024)	70:51 HRs	LINE CLEAR AVAILED
4445	29-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
4446	29-Jan-24	MYSORE	66	HV1	SUNTIKOPPA_66	13:22	15:40	02:18	LINE CLEAR AVAILED
4447	29-Jan-24	MYSORE	66	HV2	DODDINADUVADI_66	13:00	13:10	00:10	TRIPPED ON FAULT
4448	29-Jan-24	MYSORE	66	HV2	KMDODDI_66	13:32	13:50	00:17	LINE CLEAR AVAILED
4449	29-Jan-24	MYSORE	66	HV2	PANDAVAPURA_66	15:11	16:15	01:04	LINE CLEAR AVAILED
4450	29-Jan-24	MYSORE	66	HV2	SUNTIKOPPA_66	08:48	13:47	04:59	LINE CLEAR AVAILED
4451	29-Jan-24	MYSORE	66	HV2	SUNTIKOPPA_66	15:19	17:42	02:23	LINE CLEAR AVAILED
4452	29-Jan-24	MYSORE	66	HV5	SFC SIVA-	13:22			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4453	29-Jan-24	MYSORE	66	KUSHALANAGARA 220-PERİYAPATNA-1	NO STATIONS EFFECTED	11:16	12:44	01:28	LINE CLEAR AVAILED
4454	29-Jan-24	MYSORE	66	MYSORE SOUTH-GIS KALAMANDIR	NO STATIONS EFFECTED	18:05 (28/01/2024)	22:20 (29/01/2024)	28:15 HRs	LINE CLEAR AVAILED
4455	29-Jan-24	MYSORE	66	NAGAMANGALA 220-NAGAMANGALA 2	NAGAMANGALA_66	05:48	05:58	00:10	TRIPPED ON FAULT
4456	29-Jan-24	MYSORE	66	RAVANDURU-ADANI	NO STATIONS EFFECTED	21:40	21:56	00:16	TRIPPED ON FAULT
4457	29-Jan-24	MYSORE	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	05:36	05:47	00:10	TRIPPED ON FAULT
4458	29-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	01:20	01:30	00:09	TRIPPED ON FAULT
4459	29-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	03:48	04:00	00:11	TRIPPED ON FAULT
4460	29-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NAGAMANGALA_66	04:22	11:56	07:34	TRIPPED ON FAULT
4461	29-Jan-24	MYSORE	66	VADERALLI-YADIYUR	NO STATIONS EFFECTED	07:20	07:30	00:10	TRIPPED ON FAULT
4462	29-Jan-24	MYSORE	220	KADAKOLA-HOOTAGALLY	NO STATIONS EFFECTED	11:04	13:35	02:31	LINE CLEAR AVAILED
4463	29-Jan-24	MYSORE	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	10:57	19:32	08:34	LINE CLEAR AVAILED
4464	29-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-KUNIGAL	KUNIGAL_66	09:35	13:48	04:13	LINE CLEAR AVAILED
4465	29-Jan-24	TUMKUR	66	BHARAMAGIRI-MATHOD	BHARAMAGIRI_66	14:55	16:30	01:35	LINE CLEAR AVAILED
4466	29-Jan-24	TUMKUR	66	DASUDI-SRS HIRIYUR_220	DASUDI_66	15:50	16:20	00:30	MAIN SUPPLY FAILURE
4467	29-Jan-24	TUMKUR	66	DAVANGERE SRS-ANGODU 66	ANGODU_66	17:36	17:43	00:07	TRIPPED ON FAULT
4468	29-Jan-24	TUMKUR	66	GOWRASAMUDRA-THALLAK 220kV220	GOWRASAMUDRA,KONANS AGARA	10:50	14:00	03:10	LINE CLEAR AVAILED
4469	29-Jan-24	TUMKUR	66	HARAPPANAHALLI-ITTAGI	HARAPPANAHALLI_66	12:30	17:20	04:50	LINE CLEAR AVAILED
4470	29-Jan-24	TUMKUR	66	HIRIYUR 220KV-BEVINAHALLI	BEVINAHALLI_66	15:52	16:20	00:28	TRIPPED ON FAULT
4471	29-Jan-24	TUMKUR	66	HIRIYUR220-MATHOD 1	MATHOD_66,HINDASGHATT A_66,KANCHIPURA_66,GAR AGA_66,PANCHANAHALLI_66,HOSADURGA_66	15:22	16:34	01:12	LINE CLEAR AVAILED
4472	29-Jan-24	TUMKUR	66	HOSADURRG-MATHOD	HOSADURGA_66	11:30	15:45	04:15	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4473	29-Jan-24	TUMKUR	66	MADHUGIRI 220kV-PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	06:33	06:45	00:12	TRIPPED ON FAULT
4474	29-Jan-24	TUMKUR	66	MATHOD- PANCHANAHALLI	GARAGA_66- PANCHANAHALLI_66	10:20	16:35	06:15	LINE CLEAR AVAILED
4475	29-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4476	29-Jan-24	TUMKUR	66	THALLAK 220kV-GOWRASAMUDRA	GOWRASAMUDRA,KONANSAGARA	10:38	13:59	03:21	LINE CLEAR AVAILED
4477	29-Jan-24	TUMKUR	66	THALLAK 220-MYLANAHALLI	PR PURA_66,MYLANAHALLI_66, V V PORA_66	10:30	17:35	07:05	LINE CLEAR AVAILED
4478	29-Jan-24	TUMKUR	66	TR-1	ANCHEPALYA_66	10:40	14:25	03:45	LINE CLEAR AVAILED
4479	29-Jan-24	TUMKUR	66	TR-1	CHAWDANAKUPPE_66	10:00	12:05	02:05	LINE CLEAR AVAILED
4480	29-Jan-24	TUMKUR	66	TR-1&TR-2	HARAPPANAHALLI_66	12:30	17:20	04:50	LINE CLEAR AVAILED
4481	29-Jan-24	TUMKUR	66	TR-1&TR-2	GOWRASAMUDRA_66	09:40	14:40	05:00	LINE CLEAR AVAILED
4482	29-Jan-24	TUMKUR	66	TR-2	ANCHEPALYA_66	10:40	14:25	03:45	LINE CLEAR AVAILED
4483	29-Jan-24	TUMKUR	66	TR-2	CHAWDANAKUPPE_66	12:05	12:25	00:20	LINE CLEAR AVAILED
4484	29-Jan-24	TUMKUR	66	TR-2	HONNALLI_66	12:10	15:10	03:00	LINE CLEAR AVAILED
4485	29-Jan-24	TUMKUR	66	TR-3	ANCHEPALYA_66	11:20	14:15	02:55	LINE CLEAR AVAILED
4486	29-Jan-24	TUMKUR	66	TR-3	HOLALKERE_66	18:15	18:55	00:40	LINE CLEAR AVAILED
4487	29-Jan-24	TUMKUR	110	TR-3(HV SIDE)	K B CROSS_220	09:33	09:38	00:05	TRIPPED ON FAULT
4488	29-Jan-24	TUMKUR	110	TR-3(LV SIDE)	K B CROSS_220	09:33	09:38	00:05	TRIPPED ON FAULT
4489	29-Jan-24	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	10:33	18:30	07:57	LINE CLEAR AVAILED
4490	29-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
4491	29-Jan-24	TUMKUR	220	TR-3	HIRIYUR_220	16:00	16:15	00:15	LINE CLEAR AVAILED
4492	30-Jan-24	BAGALKOT	110	110/11KV, HV3(10MVA)	BIJAPUR CITY_110	7:47 (29.01.2024)	15:18 (30.01.2024)	07:31	LINE CLEAR AVAILED
4493	30-Jan-24	BAGALKOT	110	110/11KV, HV3(10MVA)	SADALAGA_110	14:31	16:22	01:51	LINE CLEAR AVAILED
4494	30-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	DEVANGOAN_110	13:42	18:34	04:52	LINE CLEAR AVAILED
4495	30-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	LAKMESHWAR_110	14:28	14:55	00:27	TRIPPED ON FAULT
4496	30-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	DEVANGOAN_110	18:00	18:40	00:40	LINE CLEAR AVAILED
4497	30-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	KALADAGI_110	22:55	23:15	00:20	TRIPPED ON FAULT
4498	30-Jan-24	BAGALKOT	110	110/33KV, HV3(20MVA)	GUTTAL_110	18:25 (23.01.2024)	17:34 (29.01.2024)	136:09:00	LINE CLEAR AVAILED
4499	30-Jan-24	BAGALKOT	110	110/33KV,HV3(20MVA)	GUTTAL_110	16:58	19:02	02:04	LINE CLEAR AVAILED
4500	30-Jan-24	BAGALKOT	110	AHERI220- LN6(MALGHAN)	AHERI_220	04:30	04:42	00:12	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4501	30-Jan-24	BAGALKOT	110	AHERI220- LN7(MORATAGI)	AHERI_220	04:30	04:43	00:13	TRIPPED ON FAULT
4502	30-Jan-24	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVOIDED
4503	30-Jan-24	BAGALKOT	110	BAGALKOT220-F3- NAVANAGAR-1	STATION NOT AFFECTED BAGALKOT_220	16:50	18:25	01:35	LINE CLEAR AVOIDED
4504	30-Jan-24	BAGALKOT	110	BAGALKOT220-F3- NAVANAGAR-2	STATION NOT AFFECTED BAGALKOT_220	16:51	18:25	01:34	LINE CLEAR AVOIDED
4505	30-Jan-24	BAGALKOT	110	BIDNAL220- NAVALGUND	STATION NOT AFFECTED BIDNAL_220	12:49	18:05	05:16	LINE CLEAR AVOIDED
4506	30-Jan-24	BAGALKOT	110	GADAGROAD- BIDNAL (GOPPANAKOPPA)	GADAG ROAD_110	21:16 (28.01.2024)			LINE CLEAR AVOIDED
4507	30-Jan-24	BAGALKOT	110	GOPPANAKOPPA- GADAG ROAD	STATION NOT AFFECTED GOPPANAKOPPA_110	21:45 (28.01.2024)			LINE CLEAR AVOIDED
4508	30-Jan-24	BAGALKOT	110	HAVERI220- HANGAL(TILUVALLI)	STATION NOT AFFECTED HAVERI_220	11:09	11:15	00:06	LINE CLEAR AVOIDED
4509	30-Jan-24	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	16:52 (27.01.2024)			LINE CLEAR AVOIDED
4510	30-Jan-24	BAGALKOT	110	HUBLI220- KADANKOPPA	STATION NOT AFFECTED HUBLI_220	10:11	14:45	04:34	LINE CLEAR AVOIDED
4511	30-Jan-24	BAGALKOT	110	HUBLI220- KALGHATAGI	STATION NOT AFFECTED HUBLI_220	10:05	14:40	04:35	LINE CLEAR AVOIDED
4512	30-Jan-24	BAGALKOT	110	JAMAKHANDI- MAHALINGAPUR(NAVALAGI)	JAMAKHANDI_110	13:21	13:50	00:29	LINE CLEAR AVOIDED
4513	30-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVOIDED
4514	30-Jan-24	BAGALKOT	110	KADANAKOPPA-HUBLI	KADANAKOPPA_110	10:06	14:45	04:39	LINE CLEAR AVOIDED
4515	30-Jan-24	BAGALKOT	110	LACHYAN- DHULKED	LACHYAN_110	14:30	14:45	00:15	TRIPPED ON FAULT
4516	30-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVOIDED
4517	30-Jan-24	BAGALKOT	110	MK HUBLI220- KITTUR(MK HUBLI2	STATION NOT AFFECTED MK HUBLI_220	12:06	14:17	02:11	LINE CLEAR AVOIDED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4518	30-Jan-24	BAGALKOT	110	MK HUBLI-MACHE(MK HUBLI220(2))	MK HUBLI_110	12:03	14:57	02:54	LINE CLEAR AVAILED
4519	30-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4520	30-Jan-24	BAGALKOT	110	MRUTHYUNJAY NAGAR-GOPANKOPPA2	STATION NOT AFFECTED MRUTHYNJAY NAGAR_110	18:03 (3.10.2023)	6:55 (30.01.2024)	2844:52:00	LOAD CURTAILMENT
4521	30-Jan-24	BAGALKOT	110	MRUTHYUNJAYNAGAR-GOPPANAKOPPA1	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	06:48	09:52	03:04	TRIPPED ON FAULT
4522	30-Jan-24	BAGALKOT	110	MUGALKHOD220- HALLUR	STATION NOT AFFECTED MUGALKHOD_220	15:30	17:35	02:05	LINE CLEAR AVAILED
4523	30-Jan-24	BAGALKOT	110	NAVALAGI- F2(JAMKHANDI)	NAVALAGI_110	13:20	13:26	00:06	LINE CLEAR AVAILED
4524	30-Jan-24	BAGALKOT	110	NAVALGUND- BIDNAL220	NAVALGUND_110	12:56 (30.01.2024)			LINE CLEAR AVAILED
4525	30-Jan-24	BAGALKOT	110	PG HUNSHYAL-MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4526	30-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED
4527	30-Jan-24	BAGALKOT	110	VAJRAMATTI220-SIRAGUPPI	STATION NOT AFFECTED VAJRAMATTI_220	12:44	12:58	00:14	TRIPPED ON FAULT
4528	30-Jan-24	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED AMBEWADI_220	10:55	15:43	04:48	LINE CLEAR AVAILED
4529	30-Jan-24	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED MUGALKHOD_220	15:30	17:34	02:04	LINE CLEAR AVAILED
4530	30-Jan-24	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED INDI_220	08:35	13:45	05:10	LINE CLEAR AVAILED
4531	30-Jan-24	BAGALKOT	220	BIDNAL- HUBLI1	STATION NOT AFFECTED BIDNAL_220	10:46	18:09	07:23	LINE CLEAR AVAILED
4532	30-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4533	30-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
4534	30-Jan-24	BAGALKOT	220	HUBLI- BIDNAL1	STATION NOT AFFECTED HUBLI_220	10:45	18:09	07:24	LINE CLEAR AVAILED
4535	30-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4536	30-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4537	30-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4538	30-Jan-24	BANGALORE	66	AGALAKOTE - ANCHEPALYA 220	AGALAKOTE	11:34	12:04	00:30	LOAD CURTAILMENT
4539	30-Jan-24	BANGALORE	66	AGALAKOTE - KOTHIURA 220	AGALAKOTE	13:20	13:25	00:05	TRIPPED ON FAULT
4540	30-Jan-24	BANGALORE	66	BAGHMANE WORLD TECH PARK - HOODY 1 & 2	BAGHMANE WORLD TECH PARK	17:30	17:35	00:05	LINE CLEAR AVAILED
4541	30-Jan-24	BANGALORE	66	BRIGADE METROPOLIS - BRIGADE TECH GARDEN	BRIGADE METROPOLIS	11:50	11:55	00:05	LINE CLEAR AVAILED
4542	30-Jan-24	BANGALORE	66	BRIGADE METROPOLIS - EPIP 220	BRIGADE METROPOLIS	13:32	13:37	00:05	LINE CLEAR AVAILED
4543	30-Jan-24	BANGALORE	66	BYADRAHALLI - KODIGEHALLI	KODIGEHALLI	13:29	13:42	00:13	LINE CLEAR AVAILED
4544	30-Jan-24	BANGALORE	66	DABUSPETE 220 - NELAMANGALA 66	NELAMANGALA 66	17:49	18:29	00:40	TRIPPED ON FAULT
4545	30-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYPURA	VIJAYPURA, JANGAMKOTE	10:35	11:06	00:31	LINE CLEAR AVAILED
4546	30-Jan-24	BANGALORE	66	HBR LAYOUT 66 - BANASAWADI	BANASAWADI	15:50	15:54	00:04	LINE CLEAR AVAILED
4547	30-Jan-24	BANGALORE	66	HEJJALA - KUMBALGODU 220	HEJJALA	14:35	14:45	00:10	TRIPPED ON FAULT
4548	30-Jan-24	BANGALORE	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	17:43	17:46	00:03	LINE CLEAR AVAILED
4549	30-Jan-24	BANGALORE	66	HOODY 220 - PRESTIGE SHANTINIKETHAN	PRESTIGE SHANTINIKETHAN	17:35	17:39	00:04	LINE CLEAR AVAILED
4550	30-Jan-24	BANGALORE	66	HV1	BANASAWADI	15:15	15:22	00:07	LINE CLEAR AVAILED
4551	30-Jan-24	BANGALORE	66	HV1	BANASAWADI	15:49	15:56	00:07	LINE CLEAR AVAILED
4552	30-Jan-24	BANGALORE	66	HV1	KENGERI SATELLITE TOWN	16:11	16:18	00:07	LINE CLEAR AVAILED
4553	30-Jan-24	BANGALORE	66	HV1	NRS 220	10:43	14:49	04:06	LINE CLEAR AVAILED
4554	30-Jan-24	BANGALORE	66	HV1	KIADB HAROHALI I/A 220	10:55	16:15	05:20	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4555	30-Jan-24	BANGALORE	66	HV1	VR DODDI	08:55	08:57	00:02	TRIPPED ON FAULT
4556	30-Jan-24	BANGALORE	66	HV1	VR DODDI	10:40	10:50	00:10	TRIPPED ON FAULT
4557	30-Jan-24	BANGALORE	66	HV2	NRS 220	10:43	14:49	04:06	LINE CLEAR AVAILED
4558	30-Jan-24	BANGALORE	66	HV2	HOODY 220	19:39	19:50	00:11	TRIPPED ON FAULT
4559	30-Jan-24	BANGALORE	66	HV2	DEVARABISANAHALLI	10:50	11:05	00:15	TRIPPED ON FAULT
4560	30-Jan-24	BANGALORE	66	HV2	VIDYANAGAR	05:09	06:03	00:54	TRIPPED ON FAULT
4561	30-Jan-24	BANGALORE	66	HV2	DEVANAHALLI 66	18:45	18:50	00:05	TRIPPED ON FAULT
4562	30-Jan-24	BANGALORE	66	HV3	BANASAWADI	15:15	15:22	00:07	LINE CLEAR AVAILED
4563	30-Jan-24	BANGALORE	66	HV3	BANASAWADI	15:49	15:56	00:07	LINE CLEAR AVAILED
4564	30-Jan-24	BANGALORE	66	HV3	NRS 220	10:43	14:51	04:08	LINE CLEAR AVAILED
4565	30-Jan-24	BANGALORE	66	HV4	NRS 220	10:43	14:51	04:08	LINE CLEAR AVAILED
4566	30-Jan-24	BANGALORE	66	IISc - HEBBALA 220	IISc	16:19	16:24	00:05	LINE CLEAR AVAILED
4567	30-Jan-24	BANGALORE	66	IISc - NRS 220	IISc	10:12	10:14	00:02	LINE CLEAR AVAILED
4568	30-Jan-24	BANGALORE	66	JANGAMKOTE - CHINTAMANI 220	VIJAYPURA, JANGAMKOTE	16:52	16:56	00:04	LINE CLEAR AVAILED
4569	30-Jan-24	BANGALORE	66	KIADB HAROHALLI I/A 220 - SANJEEVANDODDI	SANJEEVANDODDI, RANGANDODDI	10:05	10:15	00:10	TRIPPED ON FAULT
4570	30-Jan-24	BANGALORE	66	NALLIMARDANAHALLI - CB PURA 1	NALLIMARDANAHALLI	17:30	18:55	01:25	LINE CLEAR AVAILED
4571	30-Jan-24	BANGALORE	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	10:39	15:26	04:47	LINE CLEAR AVAILED
4572	30-Jan-24	BANGALORE	66	NRS 220 - TELECOM LAYOUT 1	TELECOM LAYOUT	10:29	16:15	05:46	LINE CLEAR AVAILED
4573	30-Jan-24	BANGALORE	66	SIDLAGHATTA - CHINTAMANI 220	SIDLAGHATTA, MELUR	17:45	18:20	00:35	TRIPPED ON FAULT
4574	30-Jan-24	BANGALORE	66	SRINIVASPURA 220 - DALSANUR	DALASANUR, YELDUR	10:28	11:01	00:33	TRIPPED ON FAULT
4575	30-Jan-24	BANGALORE	66	SRINIVASPURA 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLY, SOMAYAJALAHALLI, SOLAR IPP	05:10	05:55	00:45	TRIPPED ON FAULT
4576	30-Jan-24	BANGALORE	66	SRINIVASPURA 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, RAYALPADU, GOWNIPALLY, SOMAYAJALAHALLI, SOLAR IPP	06:05	07:55	01:50	TRIPPED ON FAULT
4577	30-Jan-24	BANGALORE	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	13:05	13:10	00:05	LINE CLEAR AVAILED
4578	30-Jan-24	BANGALORE	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	10:19	10:24	00:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4579	30-Jan-24	BANGALORE	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHNAGAR	18:19	18:23	00:04	LINE CLEAR AVAILED
4580	30-Jan-24	BANGALORE	220	HV1	NRS 220	10:43	14:44	04:01	LINE CLEAR AVAILED
4581	30-Jan-24	BANGALORE	220	HV1	KIADB HAROHALLI I/A 220	10:55	16:15	05:20	LINE CLEAR AVAILED
4582	30-Jan-24	BANGALORE	220	HV2	NRS 220	10:43	14:44	04:01	LINE CLEAR AVAILED
4583	30-Jan-24	BANGALORE	220	NELAMANGALA 400 - ANCHEPALYA 220	NO STATION AFFECTED	11:28	13:09	01:41	TRIPPED ON FAULT
4584	30-Jan-24	GULBARGA	66	HARAPANAHALLI-NEELAGUNDA	HARAPANAHALLI_66,SUZL ON WIND_IPP	18:45	18:50	00:05	LINE CLEAR AVAILED
4585	30-Jan-24	GULBARGA	66	HV1	BANAVEKAL_66	18:05	18:30	00:25	LINE CLEAR AVAILED
4586	30-Jan-24	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66, HOLAGUNDI_66	09:08	14:57	05:49	LINE CLEAR AVAILED
4587	30-Jan-24	GULBARGA	110	HV1	NALWAR_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4588	30-Jan-24	GULBARGA	110	HV1	KHANAPUR_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4589	30-Jan-24	GULBARGA	110	HV2	KHANAPUR_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4590	30-Jan-24	GULBARGA	110	KHANAPUR-KADECHUR	KADECHUR_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4591	30-Jan-24	GULBARGA	110	KHANAPUR-RAILWAY	RAILWAY_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4592	30-Jan-24	GULBARGA	110	KHANAPUR-SONATHI	SONATHI_110	12:15	18:07	05:52	LINE CLEAR AVAILED
4593	30-Jan-24	GULBARGA	110	KHANAPUR-WADAGERA	WADAGERA_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4594	30-Jan-24	GULBARGA	110	KONKAL-RAMASAMUDRA	KONKAL_110	00:02	00:22	00:20	TRIPPED ON FAULT
4595	30-Jan-24	GULBARGA	110	MUDAGAL-BAYYAPUR	BAYYAPUR_110	11:35	12:35	01:00	LINE CLEAR AVAILED
4596	30-Jan-24	GULBARGA	110	NALWAR-SOLAR	NALWAR_110	16:30	17:30	01:00	LINE CLEAR AVAILED
4597	30-Jan-24	GULBARGA	110	SINDHANOOR-DHADESUGUR	DHADESUGUR_110, SIRGUPPA_110, TEKKALKOTE_110	12:50(24.01.2024)	17:35(30.01.2024)	148:45HRS	LINE CLEAR AVAILED
4598	30-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR 2	SINDHANOOR_110	09:15(24.01.2024)	17:55(30.01.2024)	152:40HRS	LINE CLEAR AVAILED
4599	30-Jan-24	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	12:50(24.01.2024)	17:55(30.01.2024)	149:05HRS	LINE CLEAR AVAILED
4600	30-Jan-24	GULBARGA	110	SINDHANOOR-WALABALLARY	WALABALLARY_110	09:30(24.01.2024)	17:45(30.01.2024)	152:15HRS	LINE CLEAR AVAILED
4601	30-Jan-24	GULBARGA	110	SIRIGUPPA-DHADESUGUR	SIRIGUPPA_110,TEKKALKOTE_110,SIRIGERICROSS_110	18:53	20:07	01:14	LINE CLEAR AVAILED
4602	30-Jan-24	GULBARGA	110	YADGIR-KBJNL	KBJNL_110	12:03	12:07	00:04	LINE CLEAR AVAILED
4603	30-Jan-24	HASSAN	66	BALLUPE-SKLPR	BALLUPETE_66	10:55	14:20	03:25	LINE CLEAR AVAILED
4604	30-Jan-24	HASSAN	66	HASSN220-SKPURA1	HASSAN_220	10:51	14:24	03:33	LINE CLEAR AVAILED
4605	30-Jan-24	HASSAN	66	HV1	AREHALLI_66	13:40	14:15	00:35	LINE CLEAR AVAILED
4606	30-Jan-24	HASSAN	66	HV1	AREHALLI_66	23:40	23:45	00:05	MAIN SUPPLY FAILURE
4607	30-Jan-24	HASSAN	66	HV2	AREHALLI_66	11:30	12:35	01:05	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4608	30-Jan-24	HASSAN	66	HV2	AREHALLI_66	23:40	23:45	00:05	MAIN SUPPLY FAILURE
4609	30-Jan-24	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	18:25	18:40	00:15	TRIPPED ON FAULT
4610	30-Jan-24	HASSAN	66	SAKALE-HANBAL	SAKALESH PURA_66	23:40	23:45	00:05	LINE CLEAR AVAILED
4611	30-Jan-24	HASSAN	66	UDDURKO-NITTUR1	UDDURKOPPLU_66	14:50 (29.01.2024)	17:50(30.1.2024)		LINE CLEAR AVAILED
4612	30-Jan-24	HASSAN	66	UDDURKO-NITTUR2	UDDURKOPPLU_66	15:50	17:50	02:00	LINE CLEAR AVAILED
4613	30-Jan-24	HASSAN	110	HOSNGD-VTRG1	HOSANGADI_110	12:40	13:50	01:10	LINE CLEAR AVAILED
4614	30-Jan-24	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	11:33	12:39	01:06	LINE CLEAR AVAILED
4615	30-Jan-24	HASSAN	110	HV1	BARANGI_110	08:00	08:35	00:35	LINE CLEAR AVAILED
4616	30-Jan-24	HASSAN	110	HV1	HOSANGADI_110	10:50	14:15	03:25	LINE CLEAR AVAILED
4617	30-Jan-24	HASSAN	110	HV1	MADHUVANA_110	11:04	13:10	02:06	LINE CLEAR AVAILED
4618	30-Jan-24	HASSAN	110	HV1	MADHUVANA_110	11:06	13:10	02:04	LINE CLEAR AVAILED
4619	30-Jan-24	HASSAN	110	HV2	HOSANGADI_110	14:00	16:43	02:43	LINE CLEAR AVAILED
4620	30-Jan-24	HASSAN	110	HV2	HULICAL_110	12:30	13:25	00:55	LINE CLEAR AVAILED
4621	30-Jan-24	HASSAN	110	HV4	KAVOOR_220	09:35	18:16	08:41	LINE CLEAR AVAILED
4622	30-Jan-24	HASSAN	110	KAVOOR-KEMAR	KAVOOR_220	10:59	13:36	02:37	LINE CLEAR AVAILED
4623	30-Jan-24	HASSAN	110	LV1	KEMAR_220	10:47	13:54	03:07	LINE CLEAR AVAILED
4624	30-Jan-24	HASSAN	220	GERSOPA-SHIMOGA	gen_gersoppa	13:21(30.1.2024)			TRIPPED ON FAULT
4625	30-Jan-24	HASSAN	220	HV1	KEMAR_220	10:47	13:54	03:07	LINE CLEAR AVAILED
4626	30-Jan-24	HASSAN	220	KEMAR-KAVOOR	KEMAR_220	10:59	13:36	02:37	LINE CLEAR AVAILED
4627	30-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:21(30.1.2024)			TRIPPED ON FAULT
4628	30-Jan-24	MYSORE	66	BEGUR 220-HARAVE	HARVEY_66	06:31	06:39	00:08	TRIPPED ON FAULT
4629	30-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVAILED
4630	30-Jan-24	MYSORE	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVAILED
4631	30-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVAILED
4632	30-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVAILED
4633	30-Jan-24	MYSORE	66	HV1	MALAVALLI_66	14:36	14:41	00:04	LINE CLEAR AVAILED
4634	30-Jan-24	MYSORE	66	HV2	MADDUR_66	10:50	12:03	01:13	LINE CLEAR AVAILED
4635	30-Jan-24	MYSORE	66	HV2	SANTHEMARAHALLI_66	14:23	14:31	00:08	LINE CLEAR AVAILED
4636	30-Jan-24	MYSORE	66	HV2	THUMBLA_66	09:01	09:11	00:10	TRIPPED ON FAULT
4637	30-Jan-24	MYSORE	66	HV5	SFC SIVA_66	13:22 (29/01/2024)			LINE CLEAR AVAILED
4638	30-Jan-24	MYSORE	66	JAKKANAHALLI-NAGMANGALA	GMALLIGERE_66	19:01	19:06	00:05	TRIPPED ON FAULT
4639	30-Jan-24	MYSORE	66	MADDUR-SOMANAHALLI	SOMWARPETE_33SOMANA HALLI_66	12:05	13:22	01:17	LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4640	30-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	22:29	22:35	00:06	TRIPPED ON FAULT
4641	30-Jan-24	MYSORE	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PGPALYA_66	23:19	23:38	00:18	TRIPPED ON FAULT
4642	30-Jan-24	MYSORE	66	PONNAMPETE-SRIMANGALA	SRIMANGALA_66	18:59	19:06	00:07	TRIPPED ON FAULT
4643	30-Jan-24	MYSORE	220	HV1	KUSHALNAGARA_220	12:39	15:20	02:40	LINE CLEAR AVAILED
4644	30-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-AMRUTHUR	AMRUTHUR_66, SANTEMAVATTUR_66, YADAVANI_66	11:32	11:56	00:24	LINE CLEAR AVAILED
4645	30-Jan-24	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:32	12:06	00:34	LINE CLEAR AVAILED
4646	30-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-BELLAVI	BELLAVI_66	10:27	10:35	00:08	LINE CLEAR AVAILED
4647	30-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI_66	11:27	12:25	00:58	LINE CLEAR AVAILED
4648	30-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-HOSAKERE_66	HOSAKERE_66,	11:40	15:05	03:25	LINE CLEAR AVAILED
4649	30-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	08:26	08:27	00:01	LINE CLEAR AVAILED
4650	30-Jan-24	TUMKUR	66	ANTHRASANAHALLI 220KV-TUMKUR	TUMKUR_66	08:26	08:27	00:01	LINE CLEAR AVAILED
4651	30-Jan-24	TUMKUR	66	BALENAHALLI-CHALKERE_66	BALENAHALLI_66	11:10	16:41	05:31	LINE CLEAR AVAILED
4652	30-Jan-24	TUMKUR	66	BEVINAHALLI-JAVAGONDANAHALLI	BEVINAHALLI_66	16:45	17:15	00:30	MAIN SUPPLY FAILURE
4653	30-Jan-24	TUMKUR	66	CHITRADURGA 220kV-THALLAK	THALLAKK_66	10:39	16:13	05:34	LINE CLEAR AVAILED
4654	30-Jan-24	TUMKUR	66	DASUDI-SRS HIRIYUR_220	DASUDI_66	16:45	17:15	00:30	MAIN SUPPLY FAILURE
4655	30-Jan-24	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	16:46	17:16	00:30	LINE CLEAR AVAILED
4656	30-Jan-24	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:36	12:47	00:11	TRIPPED ON FAULT
4657	30-Jan-24	TUMKUR	66	HONNALLI 220kV-BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:05	14:50	01:45	LINE CLEAR AVAILED
4658	30-Jan-24	TUMKUR	66	HONNALLI 220kV-BANUVALLI_66	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	12:35	14:50	02:15	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4659	30-Jan-24	TUMKUR	66	HONNALLI220- KUNDUR66	KUNDUR_66	14:20	16:43	02:23	LINE CLEAR AVAILED
4660	30-Jan-24	TUMKUR	66	HOSADURGA220- HALURAMESHWARA66	HALURAMESHWARA_66	18:05	19:05	01:00	TRIPPED ON FAULT
4661	30-Jan-24	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE
4662	30-Jan-24	TUMKUR	66	THALLAK 220kV- CHALLAKERE	CHALLAKERE_66, SANIKERE_66	10:29	15:45	05:16	LINE CLEAR AVAILED
4663	30-Jan-24	TUMKUR	66	THERIYUR 66-PAVAGADA	THERIYUR_66	06:00	06:15	00:15	TRIPPED ON FAULT
4664	30-Jan-24	TUMKUR	66	TR-1	CHAWDANAKUPPE_66	11:35	12:00	00:25	LINE CLEAR AVAILED
4665	30-Jan-24	TUMKUR	66	TR-1	CHITRAHALLI_66	15:45	15:50	00:05	TRIPPED ON FAULT
4666	30-Jan-24	TUMKUR	66	TR-1	CHITRAHALLI_66	18:50	21:21	02:31	TRIPPED ON FAULT
4667	30-Jan-24	TUMKUR	66	TR-1	GOPPENAHALLI-66	09:01	11:10	02:09	TRIPPED ON FAULT
4668	30-Jan-24	TUMKUR	66	TR-1	GOPPENAHALLI-66	15:10	15:15	00:05	TRIPPED ON FAULT
4669	30-Jan-24	TUMKUR	66	TR2	BALENAHALLI_66	09:02	09:16	00:14	TRIPPED ON FAULT
4670	30-Jan-24	TUMKUR	66	TR-2	TUMKUR_66	10:50	10:58	00:08	LINE CLEAR AVAILED
4671	30-Jan-24	TUMKUR	66	TR-2	TUMKUR_66	11:42	11:46	00:04	LINE CLEAR AVAILED
4672	30-Jan-24	TUMKUR	66	TR-2	P.D.KOTE_66	03:00	03:05	00:05	TRIPPED ON FAULT
4673	30-Jan-24	TUMKUR	110	KB CROSS 220kV- TIMMANAHALLI110	TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110	05:48	05:53	00:05	TRIPPED ON FAULT
4674	30-Jan-24	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1(NAGAMANGALA 1)	ANCHEPALYA_220	11:28	13:09	01:41	TRIPPED ON FAULT
4675	30-Jan-24	TUMKUR	220	ANTHRASANAHALLI 220kV- SHIMOGA	ANTHRASANAHALLI_220	07:32	07:51	00:19	LINE CLEAR AVAILED
4676	30-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVAILED
4677	30-Jan-24	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	07:49:12	08:16:30	00:27	LINE CLEAR AVAILED
4678	30-Jan-24	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	07:43:31	07:47:57	00:04	LINE CLEAR AVAILED
4679	30-Jan-24	TUMKUR	220	TR-3	ANTHRASANAHALLI_220	08:15	08:25	00:10	LINE CLEAR AVAILED
4680	31-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	BASAVANAKATTI_110	15:28	15:42	00:14	LINE CLEAR AVAILED
4681	31-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	KADAKLAT_110	10:45	14:28	03:43	LINE CLEAR AVAILED
4682	31-Jan-24	BAGALKOT	110	110/11KV,HV1(10MVA)	MORATAGI_110	12:20	15:52	03:32	LINE CLEAR AVAILED
4683	31-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	KADAKLAT_110	10:05	14:24	04:19	LINE CLEAR AVAILED
4684	31-Jan-24	BAGALKOT	110	110/11KV,HV2(10MVA)	KADAKLAT_110	09:13	09:30	00:17	TRIPPED ON FAULT
4685	31-Jan-24	BAGALKOT	110	110/11KV,HV2(20MVA)	MAMADAPUR(B)_110	10:28	10:35	00:07	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4686	31-Jan-24	BAGALKOT	110	110/11KV,HV3(20MVA)	BIJAPUR CITY_110	16:21	19:31	03:10	LINE CLEAR AVAILED
4687	31-Jan-24	BAGALKOT	110	110/11KV,HV3(20MVA)	GOKAK_110	01:02	01:11	00:09	TRIPPED ON FAULT
4688	31-Jan-24	BAGALKOT	110	110/11KV,HV4(10MVA)	GHATAPRABHA_110	12:30	16:13	03:43	LINE CLEAR AVAILED
4689	31-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA)	HANAGAL_110	12:20	12:31	00:11	TRIPPED ON FAULT
4690	31-Jan-24	BAGALKOT	110	110/33KV,HV2(20MVA-HV1)	KARWAR_110	17:46	18:01	00:15	LINE CLEAR AVAILED
4691	31-Jan-24	BAGALKOT	110	ATHANI220-AIGALI	STATION NOT AFFECTED ATHANI_220	10:05 (29.01.2024)			LINE CLEAR AVAILED
4692	31-Jan-24	BAGALKOT	110	ATHARGA- BAGEWADI(INFINITY SOLAR)	ATHARGA_110	17:45	18:07	00:22	LINE CLEAR AVAILED
4693	31-Jan-24	BAGALKOT	110	ATHARGA-RAILWAY	ATHARGA_110	17:45	18:07	00:22	LINE CLEAR AVAILED
4694	31-Jan-24	BAGALKOT	110	GADAGROAD- BIDNAL (GOPPANAKOPPA)	GADAG ROAD_110	21:16 (28.01.2024)			LINE CLEAR AVAILED
4695	31-Jan-24	BAGALKOT	110	GOPPANAKOPPA- GADAG ROAD	STATION NOT AFFECTED GOPPANAKOPPA_110	21:45 (28.01.2024)			LINE CLEAR AVAILED
4696	31-Jan-24	BAGALKOT	110	HAVERI220- HANAGAL(TILUVALI)	HAVERI_220	06:59	07:02	00:03	LINE CLEAR AVAILED
4697	31-Jan-24	BAGALKOT	110	HAVERI220- HANAGAL(TILUVALI)	HAVERI_220	10:00	17:52	07:52	LINE CLEAR AVAILED
4698	31-Jan-24	BAGALKOT	110	HAVERI220-SAVANUR	HAVERI_220	16:52 (27.01.2024)	7:21 (31.01.2024)	86:29:00	LINE CLEAR AVAILED
4699	31-Jan-24	BAGALKOT	110	HUBLI- KADANAKOPPA	HUBLI_220	10:05	12:18	02:13	LINE CLEAR AVAILED
4700	31-Jan-24	BAGALKOT	110	JAMBAGI- VAJRAMATTI(MUDHOL)	STATION NOT AFFECTED K D JAMBAGI_110	12:09 (13.07.2023)			LINE CLEAR AVAILED
4701	31-Jan-24	BAGALKOT	110	KADANAKOPPA-HUBLI	KADANAKOPPA_110	10:02	12:18	02:16	LINE CLEAR AVAILED
4702	31-Jan-24	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	11:01 (22.11.2023)			LINE CLEAR AVAILED
4703	31-Jan-24	BAGALKOT	110	MKHUBLI220-MKHUBLI1	STATION NOT AFFECTED MKHUBLI_220	12:40 (18.09.2022)			LINE CLEAR AVAILED
4704	31-Jan-24	BAGALKOT	110	NAVALGUND- BIDNAL220	NAVALGUND_110	12:56 (30.01.2024)	9:47 (31.01.2024)	20:51:00	LINE CLEAR AVAILED
4705	31-Jan-24	BAGALKOT	110	PG HUNSHYAL- MUDALAGI(MUGALKHOD)	STATION NOT AFFECTED PG HUNSHYAL_110	16:22 (21.09.2023)			LINE CLEAR AVAILED
4706	31-Jan-24	BAGALKOT	110	SIRSI-JOG1(SIDDAPUR)	STATION NOT AFFECTED SIRSI_110	9:37 (03.01.2024)			LINE CLEAR AVAILED

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4707	31-Jan-24	BAGALKOT	110	VJJARAMATT-KATARAKI	VJARAMATTI_ 220	11:19	13:20	02:01	LINE CLEAR AVAILED
4708	31-Jan-24	BAGALKOT	220	BIDNAL- SOUDATTI	STATION NOT AFFECTED BIDNAL_220	6:22 (20.12.2023)			LINE CLEAR AVAILED
4709	31-Jan-24	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	10:27 (25.01.2024)			LINE CLEAR AVAILED
4710	31-Jan-24	BAGALKOT	220	HUBLI- NAGHZARI-1	HUBLI_220	10:46	13:33	02:47	LINE CLEAR AVAILED
4711	31-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI1	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4712	31-Jan-24	BAGALKOT	220	SIRSI220-SHARAVATHI2	SIRSI_220	13:48 (26.01.2024)			LINE CLEAR AVAILED
4713	31-Jan-24	BAGALKOT	220	SOUDATTI-BIDNAL	STATION NOT AFFECTED SOUDATTI_220	6:20 (20.12.2023)			LINE CLEAR AVAILED
4714	31-Jan-24	BANGALORE	66	AVANI - K&C VALLEY	NO STATION AFFECTED	00:00	23:59	23:59	TRIPPED ON FAULT
4715	31-Jan-24	BANGALORE	66	BRIGADE TECH GARDEN - EPIP 1	BRIGADE TECH GARDEN	06:50	07:00	00:10	LINE CLEAR AVAILED
4716	31-Jan-24	BANGALORE	66	BYADRAHALLI - KODIGEHALLI	KODIGEHALLI (NEL)	13:05	13:33	00:28	LINE CLEAR AVAILED
4717	31-Jan-24	BANGALORE	66	BYADRAHALLI - KODIGEHALLI	KODIGEHALLI (NEL)	16:33	16:49	00:16	LINE CLEAR AVAILED
4718	31-Jan-24	BANGALORE	66	C STATION - A STATION 220	C STATION	06:00	06:06	00:06	LINE CLEAR AVAILED
4719	31-Jan-24	BANGALORE	66	DB PURA 220 - VIJAYPURA	VIJAYPURA, JANGAMKOTE	10:55	11:00	00:05	LINE CLEAR AVAILED
4720	31-Jan-24	BANGALORE	66	ELITA PROMENENDE - KHODAYS 220	ELITA PROMENENDE	13:49	13:51	00:02	LINE CLEAR AVAILED
4721	31-Jan-24	BANGALORE	66	ELITA PROMENENDE - RBI	ELITA PROMENENDE	12:17	12:21	00:04	LINE CLEAR AVAILED
4722	31-Jan-24	BANGALORE	66	EMBASSY TECH PARK - VIKAS TECH PARK 220	EMBASSY TECH PARK	11:40	13:15	01:35	LINE CLEAR AVAILED
4723	31-Jan-24	BANGALORE	66	HV1	HENNUR CROSS	12:32	12:36	00:04	LINE CLEAR AVAILED
4724	31-Jan-24	BANGALORE	66	HV1	WELCAST	11:04	11:09	00:05	LINE CLEAR AVAILED
4725	31-Jan-24	BANGALORE	66	HV1	HAROBELE	13:10	13:40	00:30	LINE CLEAR AVAILED
4726	31-Jan-24	BANGALORE	66	HV1	BEVOOR	13:02	13:07	00:05	LINE CLEAR AVAILED
4727	31-Jan-24	BANGALORE	66	HV1	TK HALLI 220	02:18	02:34	00:16	MAIN SUPPLY FAILURE
4728	31-Jan-24	BANGALORE	66	HV1	GOWRIBIDANUR 220	10:33	10:42	00:09	TRIPPED ON FAULT
4729	31-Jan-24	BANGALORE	66	HV1	GOWNIPALLI	12:01	12:30	00:29	TRIPPED ON FAULT
4730	31-Jan-24	BANGALORE	66	HV1	HAROBELE	13:10	13:15	00:05	LINE CLEAR AVAILED
4731	31-Jan-24	BANGALORE	66	HV2	DEVARABISANAHALLI	11:15	11:20	00:05	LINE CLEAR AVAILED
4732	31-Jan-24	BANGALORE	66	HV2	HAROBELE	13:45	14:15	00:30	LINE CLEAR AVAILED
4733	31-Jan-24	BANGALORE	66	HV2	CHANNAPATNA 220	09:31	09:35	00:04	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4734	31-Jan-24	BANGALORE	66	HV2	TK HALLI 220	02:18	02:39	00:21	MAIN SUPPLY FAILURE
4735	31-Jan-24	BANGALORE	66	HV2	IRAGAMPALLI	10:15	10:20	00:05	LINE CLEAR AVAILED
4736	31-Jan-24	BANGALORE	66	HV2	DEVANAHALLI 66	01:15	01:20	00:05	TRIPPED ON FAULT
4737	31-Jan-24	BANGALORE	66	HV2	HAROBEL	13:45	13:50	00:05	LINE CLEAR AVAILED
4738	31-Jan-24	BANGALORE	66	IRAGAMPALLI - BURUDAGUNTE	BURUDAGUNTE	10:17	10:22	00:05	LINE CLEAR AVAILED
4739	31-Jan-24	BANGALORE	66	IRAGAMPALLI - CHINTAMANI 220	IRAGAMPALLI, M GOLLAHALLI, BURUDAGUNTE	10:06	10:11	00:05	LINE CLEAR AVAILED
4740	31-Jan-24	BANGALORE	66	IRAGAMPALLI - M GOLAHALLI	M GOLAHALLI	10:17	10:22	00:05	LINE CLEAR AVAILED
4741	31-Jan-24	BANGALORE	66	JANGAMKOTE - CHINTAMANI 220	JANGAMKOTE, VIJAYPURA	17:15	17:18	00:03	LINE CLEAR AVAILED
4742	31-Jan-24	BANGALORE	66	JAYANAGAR - NATIONAL COLLEGE	JAYANAGAR	17:54	17:55	00:01	LINE CLEAR AVAILED
4743	31-Jan-24	BANGALORE	66	JAYANAGAR - NIMHANS 220	JAYANAGAR	16:46	16:50	00:04	LINE CLEAR AVAILED
4744	31-Jan-24	BANGALORE	66	KENGERI SATELLITE TOWN - KUMBALAGODU 2	KENGERI SATELLITE TOWN	11:25	11:30	00:05	LINE CLEAR AVAILED
4745	31-Jan-24	BANGALORE	66	KENGERI SATELLITE TOWN - SIR MV LAYOUT	KENGERI SATELLITE TOWN	13:35	13:40	00:05	LINE CLEAR AVAILED
4746	31-Jan-24	BANGALORE	66	KOLAR 220 - NARASAPURA 1	NO STATION AFFECTED	04:55	05:05	00:10	TRIPPED ON FAULT
4747	31-Jan-24	BANGALORE	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	14:06	14:20	00:14	LINE CLEAR AVAILED
4748	31-Jan-24	BANGALORE	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	14:42	14:46	00:04	MAIN SUPPLY FAILURE
4749	31-Jan-24	BANGALORE	66	MARALAWADI - KANAKAPURA 220	MARALAWADI, GODUR	16:58	17:13:00	00:15	TRIPPED ON FAULT
4750	31-Jan-24	BANGALORE	66	MARALAWADI - KANAKAPURA 220	MARALAWADI, GODUR	16:58	17:13	00:15	TRIPPED ON FAULT
4751	31-Jan-24	BANGALORE	66	NARASAPURA - KOLAR 1	NO STATION AFFECTED	04:55	05:05	00:10	TRIPPED ON FAULT
4752	31-Jan-24	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI 1 & 2	14:06	14:22	00:16	MAIN SUPPLY FAILURE
4753	31-Jan-24	BANGALORE	66	NIMHANS 220 - JAYADEVA	JAYADEVA, SARAKKI 1 & 2	14:42	14:51	00:09	MAIN SUPPLY FAILURE
4754	31-Jan-24	BANGALORE	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	14:06	14:22	00:16	MAIN SUPPLY FAILURE
4755	31-Jan-24	BANGALORE	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	14:42	14:51	00:09	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4756	31-Jan-24	BANGALORE	66	SIDDLAGHATTA - CHINTAMANI 220	SIDDLAGHATTA, MELUR, JANGAMKOTE, VIJAYPURA	11:48	12:40	00:52	TRIPPED ON FAULT
4757	31-Jan-24	BANGALORE	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	02:18	02:40	00:22	MAIN SUPPLY FAILURE
4758	31-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 1	BWSSB(EHT)	02:18	02:35	00:17	MAIN SUPPLY FAILURE
4759	31-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 2	BWSSB(EHT)	02:18	02:35	00:17	MAIN SUPPLY FAILURE
4760	31-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 3	BWSSB(EHT)	02:18	02:35	00:17	MAIN SUPPLY FAILURE
4761	31-Jan-24	BANGALORE	66	TK HALLI 220 - BWSSB 4	BWSSB(EHT)	02:18	02:35	00:17	MAIN SUPPLY FAILURE
4762	31-Jan-24	BANGALORE	66	TK HALLI 220 - HAROHALLI 2	GURUVINAPURA, B V HALLI	02:18	02:41	00:23	MAIN SUPPLY FAILURE
4763	31-Jan-24	BANGALORE	66	TK HALLI 220 - HEBBANI 1	NO STATION AFFECTED	02:18	02:50	00:32	TRIPPED ON FAULT
4764	31-Jan-24	BANGALORE	66	TK HALLI 220 - IGGALUR	IGGALUR,K HONALGERE, YATHAMBADI	02:18	02:41	00:23	MAIN SUPPLY FAILURE
4765	31-Jan-24	BANGALORE	66	TK HALLI 220 - LIMBAVALI	NO STATION AFFECTED	02:18	02:48	00:30	TRIPPED ON FAULT
4766	31-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB SOMANAHALLI, MADDUR, TALAGAVADI	02:18	02:40	00:22	MAIN SUPPLY FAILURE
4767	31-Jan-24	BANGALORE	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB SOMANAHALLI, MADDUR, TALAGAVADI	02:18	02:40	00:22	MAIN SUPPLY FAILURE
4768	31-Jan-24	BANGALORE	66	VIDURASHWATHA - GUNDLU KOTTUR	GUNDLU KOTTUR	00:40	00:45	00:05	TRIPPED ON FAULT
4769	31-Jan-24	BANGALORE	220	CHANNAPATNA 220 - TUBINAKERE 220	NO STATION AFFECTED	12:28	13:05	00:37	TRIPPED ON FAULT
4770	31-Jan-24	BANGALORE	220	HV1	TK HALLI 220	02:18	02:34	00:16	MAIN SUPPLY FAILURE
4771	31-Jan-24	BANGALORE	220	HV2	KORAMANGALA 220	14:06	14:20	00:14	MAIN SUPPLY FAILURE
4772	31-Jan-24	BANGALORE	220	HV2	KORAMANGALA 220	14:42	14:46	00:04	MAIN SUPPLY FAILURE
4773	31-Jan-24	BANGALORE	220	HV2	TK HALLI 220	02:18	02:38	00:20	MAIN SUPPLY FAILURE
4774	31-Jan-24	BANGALORE	220	HV3	TK HALLI 220	02:18	02:37	00:19	MAIN SUPPLY FAILURE
4775	31-Jan-24	BANGALORE	220	KOLAR 220 - MALUR 1	NO STATION AFFECTED	13:06	15:47	02:41	TRIPPED ON FAULT
4776	31-Jan-24	BANGALORE	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	14:06	14:20	00:14	LINE CLEAR AVAILED
4777	31-Jan-24	BANGALORE	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	14:42	14:46	00:04	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4778	31-Jan-24	BANGALORE	220	KORAMANGALA 220 - NIMHANS 220	NIMHANS 220	14:06	14:20	00:14	LINE CLEAR AVAILED
4779	31-Jan-24	BANGALORE	220	KORAMANGALA 220 - NIMHANS 220	NIMHANS 220	14:42	14:49	00:07	MAIN SUPPLY FAILURE
4780	31-Jan-24	BANGALORE	220	TK HALLI 220 - VAJAMANGALA 220	TK HALLI 220	02:18	02:33	00:15	TRIPPED ON FAULT
4781	31-Jan-24	BANGALORE	400	NELAMANGALA 400 - TALAGUPPA 400	NO STATION AFFECTED	14:40	15:58	01:18	TRIPPED ON FAULT
4782	31-Jan-24	GULBARGA	66	CJ HALLI-HANGAL	CJ HALLI_66, HOSAHALLI_66	16:30	18:30	02:00	LINE CLEAR AVAILED
4783	31-Jan-24	GULBARGA	66	HV1	HARVI_66	10:10	18:40	08:30	LINE CLEAR AVAILED
4784	31-Jan-24	GULBARGA	66	HV1	NEELAGUNDA_220	14:17	18:38	04:21	LINE CLEAR AVAILED
4785	31-Jan-24	GULBARGA	66	HV1,HV2	HALVAGALU_66	10:10	18:40	08:30	LINE CLEAR AVAILED
4786	31-Jan-24	GULBARGA	66	HV1,HV2	HARAPANAHALLI_66	05:30	05:55	00:25	TRIPPED ON FAULT
4787	31-Jan-24	GULBARGA	66	HV1,HV2	HARAPANAHALLI_66	17:10	18:00	00:50	LINE CLEAR AVAILED
4788	31-Jan-24	GULBARGA	110	GABUR-RAICHUR	GABUR_110, GUGAL_110	13:40	13:50	00:10	MAIN SUPPLY FAILURE
4789	31-Jan-24	GULBARGA	110	HV3	KURUGOD_110	16:35	16:40	00:05	TRIPPED ON FAULT
4790	31-Jan-24	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	10:08	10:16	00:08	TRIPPED ON FAULT
4791	31-Jan-24	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	05:27	05:32	00:05	TRIPPED ON FAULT
4792	31-Jan-24	GULBARGA	110	MARGUTTI-HUMNABAD	MARGUTTI_110	11:29	17:29	06:00	LINE CLEAR AVAILED
4793	31-Jan-24	GULBARGA	110	SHAHABAD-FHARTHABAD	FHARTHABAD_110	11:00	12:30	01:30	LINE CLEAR AVAILED
4794	31-Jan-24	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	23:48	23:57	00:09	TRIPPED ON FAULT
4795	31-Jan-24	GULBARGA	110	YAKATPUR-KAMTHANA	YAKATPUR_110	11:05	12:00	00:55	LINE CLEAR AVAILED
4796	31-Jan-24	GULBARGA	220	HV1	NEELAGUNDA_220	11:30	18:34	07:04	LINE CLEAR AVAILED
4797	31-Jan-24	GULBARGA	220	HV2	NEELAGUNDA_220	14:17	18:34	04:17	LINE CLEAR AVAILED
4798	31-Jan-24	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	11:22	14:36	03:14	LINE CLEAR AVAILED
4799	31-Jan-24	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	13:34	15:54	02:20	TRIPPED ON FAULT
4800	31-Jan-24	GULBARGA	220	LINGASUGUR-KUSHATAGI	LINGASUGUR_220	10:47	12:31	01:44	LINE CLEAR AVAILED
4801	31-Jan-24	GULBARGA	220	RAICHUR-RTPS1	RAICHUR_220	09:05	19:44	10:39	LINE CLEAR AVAILED
4802	31-Jan-24	HASSAN	66	HV1	DUDDA_66	14:40	15:27	00:47	LINE CLEAR AVAILED
4803	31-Jan-24	HASSAN	66	MRSSHM-DVG1	MRSMSG_220	14:40	15:31	00:51	TRIPPED ON FAULT
4804	31-Jan-24	HASSAN	110	ARSK2-ARSKR	ARSIKERE_220	14:40	15:34	00:54	MAIN SUPPLY FAILURE
4805	31-Jan-24	HASSAN	110	ARSK2-GANDASI	ARSIKERE_220	14:40	15:38	00:58	MAIN SUPPLY FAILURE
4806	31-Jan-24	HASSAN	110	ARSK2-GERUMARA	ARSIKERE_220	14:40	15:30	00:50	MAIN SUPPLY FAILURE
4807	31-Jan-24	HASSAN	110	BANTWA-AMR	BANTWAL_110	12:45	13:55	01:10	LINE CLEAR AVAILED
4808	31-Jan-24	HASSAN	110	GURUPUR-MOODABIDRE	GURUPURA-110	14:40	14:59	00:19	MAIN SUPPLY FAILURE
4809	31-Jan-24	HASSAN	110	HV1	KEMAR_220	14:42	15:03	00:21	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4810	31-Jan-24	HASSAN	110	HV1	MADHUVANA_110	12:46	13:40	00:54	LINE CLEAR AVAILED
4811	31-Jan-24	HASSAN	110	HV1	SINGATGERE_66	12:20	13:20	01:00	LINE CLEAR AVAILED
4812	31-Jan-24	HASSAN	110	HV2	KADUR_220	14:40	15:20	00:40	MAIN SUPPLY FAILURE
4813	31-Jan-24	HASSAN	110	HV2	MRSMSG_220	14:40	15:57	01:17	TRIPPED ON FAULT
4814	31-Jan-24	HASSAN	110	HV3	MRSMSG_220	14:40	15:56	01:16	TRIPPED ON FAULT
4815	31-Jan-24	HASSAN	110	HV4	MRSMSG_220	14:40	15:55	01:15	TRIPPED ON FAULT
4816	31-Jan-24	HASSAN	110	HV5	MRSMSG_220	14:40	15:17	00:37	TRIPPED ON FAULT
4817	31-Jan-24	HASSAN	110	KADUR-AJAMPURA	KADUR_220	14:40	15:19	00:39	TRIPPED ON FAULT
4818	31-Jan-24	HASSAN	110	KADUR-NERELEKERE	KADUR_220	14:40	15:18	00:38	TRIPPED ON FAULT
4819	31-Jan-24	HASSAN	110	KADUR-TNGL	KADUR_220	14:40	15:20	00:40	TRIPPED ON FAULT
4820	31-Jan-24	HASSAN	110	KADUR-YGTI	KADUR_220	14:40	15:20	00:40	TRIPPED ON FAULT
4821	31-Jan-24	HASSAN	110	KAVOOR-AMR	KAVOOR_220	11:55	14:07	02:12	TRIPPED ON FAULT
4822	31-Jan-24	HASSAN	110	KEMAR-KARKLA	KEMAR_220	14:42	15:06	00:24	TRIPPED ON FAULT
4823	31-Jan-24	HASSAN	110	KEMAR-MOODABIDRE	KEMAR_220	14:42	15:05	00:23	TRIPPED ON FAULT
4824	31-Jan-24	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	14:51	16:28	01:37	MAIN SUPPLY FAILURE
4825	31-Jan-24	HASSAN	110	LV1	KADUR_220	14:40	15:06	00:26	MAIN SUPPLY FAILURE
4826	31-Jan-24	HASSAN	110	LV1	MRSMSG_220	14:40	15:15	00:35	TRIPPED ON FAULT
4827	31-Jan-24	HASSAN	110	LV2	KADUR_220	14:40	15:06	00:26	MAIN SUPPLY FAILURE
4828	31-Jan-24	HASSAN	110	LV2	MRSMSG_220	14:40	15:16	00:36	TRIPPED ON FAULT
4829	31-Jan-24	HASSAN	110	LV3	MRSMSG_220	14:40	15:16	00:36	TRIPPED ON FAULT
4830	31-Jan-24	HASSAN	110	LV3	KAVOOR_220	10:42	13:55	03:13	LINE CLEAR AVAILED
4831	31-Jan-24	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	14:40	15:33	00:53	TRIPPED ON FAULT
4832	31-Jan-24	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	14:40	15:32	00:52	TRIPPED ON FAULT
4833	31-Jan-24	HASSAN	110	MRSSHM-BADRAVATY3	MRSMSG_220	14:40	15:20	00:40	TRIPPED ON FAULT
4834	31-Jan-24	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	14:40	15:26	00:46	TRIPPED ON FAULT
4835	31-Jan-24	HASSAN	110	MRSSHM-MPM	MRSMSG_220	14:40	15:35	00:55	TRIPPED ON FAULT
4836	31-Jan-24	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	14:40	15:33	00:53	TRIPPED ON FAULT
4837	31-Jan-24	HASSAN	110	MRSSHM-SS1	MRSMSG_220	14:40	15:24	00:44	TRIPPED ON FAULT
4838	31-Jan-24	HASSAN	110	MRSSHM-SS2	MRSMSG_220	14:40	15:24	00:44	TRIPPED ON FAULT
4839	31-Jan-24	HASSAN	110	MRSSHM-TRKER	MRSMSG_220	14:40	15:34	00:54	TRIPPED ON FAULT
4840	31-Jan-24	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR_220	14:51	16:02	01:11	LINE CLEAR AVAILED
4841	31-Jan-24	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	14:51	16:02	01:11	LINE CLEAR AVAILED
4842	31-Jan-24	HASSAN	110	SHRLKP-BARANG	SHIRALKOPA_220	14:40	15:23	00:43	MAIN SUPPLY FAILURE
4843	31-Jan-24	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPA_220	14:40	15:14	00:34	MAIN SUPPLY FAILURE
4844	31-Jan-24	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPA_220	14:40	15:03	00:23	MAIN SUPPLY FAILURE
4845	31-Jan-24	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPA_220	14:40	15:07	00:27	MAIN SUPPLY FAILURE
4846	31-Jan-24	HASSAN	110	SHRLKP-SORAB	SHIRALKOPA_220	14:40	15:06	00:26	MAIN SUPPLY FAILURE
4847	31-Jan-24	HASSAN	220	GERSOPA-SHIMOGA	gen_gersoppa	13:21(30.1.2024)	10:01(31.01.2024)		LINE CLEAR AVAILED
4848	31-Jan-24	HASSAN	220	HV1	KADUR_220	14:40	15:06	00:26	MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4849	31-Jan-24	HASSAN	220	HV1	MRSMSG_220	14:40	15:15	00:35	TRIPPED ON FAULT
4850	31-Jan-24	HASSAN	220	HV2	KADUR_220	14:40	15:06	00:26	MAIN SUPPLY FAILURE
4851	31-Jan-24	HASSAN	220	HV3	KADUR_220	14:40	15:07	00:27	MAIN SUPPLY FAILURE
4852	31-Jan-24	HASSAN	220	HV3	MRSMSG_220	14:40	15:16	00:36	TRIPPED ON FAULT
4853	31-Jan-24	HASSAN	220	HV3	KAVOOR_220	10:42	13:55	03:13	LINE CLEAR AVOIDED
4854	31-Jan-24	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	14:40	15:20	00:40	TRIPPED ON FAULT
4855	31-Jan-24	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	14:40	15:46	01:06	TRIPPED ON FAULT
4856	31-Jan-24	HASSAN	220	MRSSHM-DAVANGERE	MRSMSG_220	14:40	15:28	00:48	TRIPPED ON FAULT
4857	31-Jan-24	HASSAN	220	MRSSHM-HASSAN	MRSMSG_220	14:40	15:44	01:04	TRIPPED ON FAULT
4858	31-Jan-24	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	14:40	15:28	00:48	TRIPPED ON FAULT
4859	31-Jan-24	HASSAN	220	MRSSHM-HSN4001	MRSMSG_220	14:40	15:11	00:31	TRIPPED ON FAULT
4860	31-Jan-24	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	14:40	15:20	00:40	TRIPPED ON FAULT
4861	31-Jan-24	HASSAN	220	MRSSHM-KBCRS	MRSMSG_220	14:40	15:41	01:01	TRIPPED ON FAULT
4862	31-Jan-24	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMSG_220	13:21(30.1.2024)	10:01(31.01.2024)		LINE CLEAR AVOIDED
4863	31-Jan-24	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	14:40	15:14	00:34	TRIPPED ON FAULT
4864	31-Jan-24	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	14:40	15:14	00:34	TRIPPED ON FAULT
4865	31-Jan-24	HASSAN	220	SHRAVITY-SHIRALKOPPA	gen_sharavathy	14:40	16:09	01:29	TRIPPED ON FAULT
4866	31-Jan-24	HASSAN	220	SHRAVITY-SIRISI 1	gen_sharavathy	14:40	16:09	01:29	TRIPPED ON FAULT
4867	31-Jan-24	HASSAN	220	SHRAVITY-SIRISI 2	gen_sharavathy	14:40	16:09	01:29	TRIPPED ON FAULT
4868	31-Jan-24	HASSAN	400	TALAGU-HSN400	TALAGUPPA_400	14:40	15:58	01:18	TRIPPED ON FAULT
4869	31-Jan-24	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	14:40	15:58	01:18	TRIPPED ON FAULT
4870	31-Jan-24	MYSORE	66	BOOKANAKERE-CHINKURALLI	NO STATIONS EFFECTED	10:20	12:33	02:13	LINE CLEAR AVOIDED
4871	31-Jan-24	MYSORE	66	HAMPAPURA-BASARALU	NO STATIONS EFFECTED	7:55 (29/01/2024)			LINE CLEAR AVOIDED
4872	31-Jan-24	MYSORE	66	HARVEY-CR NAGARA	NO STATIONS EFFECTED	8:08 (29/01/2024)			LINE CLEAR AVOIDED
4873	31-Jan-24	MYSORE	66	HOOTAGALLI-BANNIKUPPE	NO STATIONS EFFECTED	11:53 (26/01/2024)			LINE CLEAR AVOIDED
4874	31-Jan-24	MYSORE	66	HOOTAGALLI-ELWALA	NO STATIONS EFFECTED	6:35 (27/01/2024)			LINE CLEAR AVOIDED
4875	31-Jan-24	MYSORE	66	HUNSUR 220-KAMPLAPURA	NO STATIONS EFFECTED	04:04	04:12	00:08	TRIPPED ON FAULT
4876	31-Jan-24	MYSORE	66	HV1	MALAVALLI_66	09:02	09:21	00:19	TRIPPED ON FAULT
4877	31-Jan-24	MYSORE	66	HV2	THUMBLA_66	15:00	16:30	01:30	LINE CLEAR AVOIDED
4878	31-Jan-24	MYSORE	66	HV5	SFC SIVA_66	19:30			LINE CLEAR AVOIDED
4879	31-Jan-24	MYSORE	66	HV5	SFC SIVA_66	13:22 (29/01/2024)	8:12 (31/01/2024)	42:50 HRs	LINE CLEAR AVOIDED
4880	31-Jan-24	MYSORE	66	KADAKOLA-MYSORE SOUTH	MYSORESOUTH_66	07:52	07:58	00:06	TRIPPED ON FAULT

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4881	31-Jan-24	MYSORE	66	MADIKERI-VIRAJPETE	NO STATIONS EFFECTED	03:18	03:33	00:15	TRIPPED ON FAULT
4882	31-Jan-24	MYSORE	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	15:22	15:25	00:03	LINE CLEAR AVAILED
4883	31-Jan-24	MYSORE	66	SHIVALLI-NAGAMANGALA	NO STATIONS EFFECTED	10:31	11:04	00:33	LINE CLEAR AVAILED
4884	31-Jan-24	MYSORE	220	HEBBANI-TK HALLI	NO STATIONS EFFECTED	02:17	02:53	00:36	TRIPPED ON FAULT
4885	31-Jan-24	MYSORE	220	VAJMANGALA-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 KIADB SOMANAHALLI_66 K_HONNALGERE_66 TALAGAVADI_66	02:18	02:33	00:15	TRIPPED ON FAULT
4886	31-Jan-24	TUMKUR	66	BILCHODU-PALLAGATTE	BILCHODU_66	15:00	15:10	00:10	TRIPPED ON FAULT
4887	31-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	00:30	00:38	00:08	TRIPPED ON FAULT
4888	31-Jan-24	TUMKUR	66	CHITRADURGA 220kV-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	07:27	07:39	00:12	LINE CLEAR AVAILED
4889	31-Jan-24	TUMKUR	66	GUTTUR 220-HALASABALU 66	GUTTUR_220	18:41	18:50	00:09	TRIPPED ON FAULT
4890	31-Jan-24	TUMKUR	66	HANAGAL- B G KERE(GUDIKOTE)	HANGAL_66	16:28	17:15	00:47	LINE CLEAR AVAILED
4891	31-Jan-24	TUMKUR	66	HANAGAL- RAMPURA	RAMAPURA_66	16:28	17:15	00:47	LINE CLEAR AVAILED
4892	31-Jan-24	TUMKUR	66	HANGAL66-THALLAK 1	HANGAL_66	16:28	17:15	00:47	LINE CLEAR AVAILED
4893	31-Jan-24	TUMKUR	66	HANGAL66-THALLAK 2	HANGAL_66	16:28	17:15	00:47	LINE CLEAR AVAILED
4894	31-Jan-24	TUMKUR	66	HONNALLI220- KUNDUR66	KUNDUR_66	10:13	10:23	00:10	TRIPPED ON FAULT
4895	31-Jan-24	TUMKUR	66	JAGALURU_66-BIDARAKERE_66	JAGALURU_66, SOKKE_66	00:30	00:35	00:05	MAIN SUPPLY FAILURE
4896	31-Jan-24	TUMKUR	66	KALAMARANAHALLI-HIRIYUR	KALAMARANAHALLI_66	16:40	16:45	00:05	LINE CLEAR AVAILED
4897	31-Jan-24	TUMKUR	66	PAVAGADA-(GOWRIBIDANUR)VENKATA PURA	VENKATAPURA_66(GOWRI BIDANUR_66)	12:50 (03.01.2024)			MAIN SUPPLY FAILURE

SL NO.	DATE	TRANSMISSION ZONE	VOLTAGE CLASS	LINE/TRANSFORMER	AFFECTED STATIONS	OPENED_AT (A)	CLOSED_AT (B)	DURATION	REMARKS
4898	31-Jan-24	TUMKUR	66	PAVAGADA220-PAVAGADA66	PAVAGADA_66, VENKATAPURA_66, THERIYUR_66	22:53	22:58	01:15	TRIPPED ON FAULT
4899	31-Jan-24	TUMKUR	66	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	20:05	20:30	00:25	TRIPPED ON FAULT
4900	31-Jan-24	TUMKUR	66	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	16:30	17:20	00:50	MAIN SUPPLY FAILURE
4901	31-Jan-24	TUMKUR	66	RAMPURA66-NAGASAMUDRA	RAMAPURA_66	20:05	20:30	00:25	MAIN SUPPLY FAILURE
4902	31-Jan-24	TUMKUR	66	SOKKE-JAGLUR	SOKKE_66	15:00	15:10	00:10	TRIPPED ON FAULT
4903	31-Jan-24	TUMKUR	66	SOKKE-UJJINI_66	SOKKE_66	15:00	15:10	00:10	TRIPPED ON FAULT
4904	31-Jan-24	TUMKUR	66	TR-1	THALLAK_220	15:03	17:05	01:56	LINE CLEAR AVOIDED
4905	31-Jan-24	TUMKUR	66	TR-1	KIADB V N PURA_220	10:31	12:53	02:22	LINE CLEAR AVOIDED
4906	31-Jan-24	TUMKUR	66	TR-1	LINGADAHALLY_66	03:25	03:35	00:10	TRIPPED ON FAULT
4907	31-Jan-24	TUMKUR	66	TR-1	MADADAKERE_66	02:05	02:10	00:05	TRIPPED ON FAULT
4908	31-Jan-24	TUMKUR	66	TR-1	MADADAKERE_66	11:00	11:10	00:10	TRIPPED ON FAULT
4909	31-Jan-24	TUMKUR	66	TR-1	MELLEKATTE_66	06:00	06:05	00:05	TRIPPED ON FAULT
4910	31-Jan-24	TUMKUR	66	TR-1	NAGALAMADIKE_66	11:10	12:10	01:00	LINE CLEAR AVOIDED
4911	31-Jan-24	TUMKUR	66	TR-1&TR-2	HANGAL_66	16:28	17:15	00:47	LINE CLEAR AVOIDED
4912	31-Jan-24	TUMKUR	66	TR-2	THALLAK_220	09:35	10:44	01:15	LINE CLEAR AVOIDED
4913	31-Jan-24	TUMKUR	66	TR-2	KIADB V N PURA_220	12:52	13:58	01:06	LINE CLEAR AVOIDED
4914	31-Jan-24	TUMKUR	66	TR-2	BALENAHALLI_66	15:31	15:42	00:11	TRIPPED ON FAULT
4915	31-Jan-24	TUMKUR	66	TR-2	RAMAPURA_66	07:40	07:55	00:15	TRIPPED ON FAULT
4916	31-Jan-24	TUMKUR	66	TR-3	KBCROSS_220	21:27	21:32	00:05	TRIPPED ON FAULT
4917	31-Jan-24	TUMKUR	220	ANTHRASANAHALLI 220kV-SHIMOGA	ANTHRASANAHALLI_220	14:39	15:20	00:41	TRIPPED ON FAULT
4918	31-Jan-24	TUMKUR	220	HONNALLI 220kV-SHIMOGA 220kV-1	HONNALLI_220	14:40	15:29	00:49	MAIN SUPPLY FAILURE
4919	31-Jan-24	TUMKUR	220	HONNALLI 220kV-SHIMOGA 220kV-2	HONNALLI_220	14:40	15:29	00:49	MAIN SUPPLY FAILURE
4920	31-Jan-24	TUMKUR	220	KB CROSS 220kV-SHIMOGA1	KBCROSS_220	14:40	15:42	01:02	TRIPPED ON FAULT
4921	31-Jan-24	TUMKUR	220	TR-1	DAVANGERE_SRS_220	10:18 (03.01.2024)			LINE CLEAR AVOIDED
4922	31-Jan-24	TUMKUR	220	TR-1	THALLAK_220	15:09	17:05	01:56	LINE CLEAR AVOIDED
4923	31-Jan-24	TUMKUR	220	TR-2	THALLAK_220	09:29	10:44	01:15	LINE CLEAR AVOIDED
4924	31-Jan-24	TUMKUR	220	TR-3	KBCROSS_220	21:27	21:32	00:05	TRIPPED ON FAULT