

On the economics of electrical storage for variable renewable energy sources

Alexander Zerrahn^a, Wolf-Peter Schill^b, Claudia Kemfert^c

^a*Corresponding author, German Institute for Economic Research (DIW Berlin), Mohrenstr. 58, 10117 Berlin, Germany, azerrahn@diw.de*

^b*German Institute for Economic Research (DIW Berlin), Mohrenstr. 58, 10117 Berlin, Germany, wschill@diw.de*

^c*German Institute for Economic Research (DIW Berlin), Mohrenstr. 58, 10117 Berlin, Germany and Hertie School of Governance, Friedrichstr. 180, 10117 Berlin, Germany, ckemfert@diw.de*

Abstract

The use of renewable energy sources is a major strategy to mitigate climate change. Yet Sinn (2017) argues that excessive electrical storage requirements could limit the further expansion of variable wind and solar energy. We question, and alter, strong implicit assumptions of Sinn's approach and find that storage needs are considerably lower, up to two orders of magnitude. First, we move away from corner solutions by allowing for combinations of storage and renewable curtailment. Second, we specify a parsimonious model to derive first-best outcomes. We conclude that electrical storage is unlikely to limit the transition to renewable energy.

Keywords: variable renewable energy sources, wind, solar, energy storage

JEL codes: O33, Q21, Q41, Q42

1. Introduction

In the 2015 Paris Agreement, the world agreed on ambitious targets for reducing greenhouse gas emissions to combat climate change (United Nations, 2015). The use of renewable energy sources is a major strategy for decarbonizing the global economy. As the potentials of hydro, biomass or geothermal energy are limited in many countries, wind power and solar photovoltaics (PV) play an increasing role. For example in Germany, often considered as a frontrunner in the use of variable renewable energy sources, the government plans to expand the share of renewable energy in gross electricity consumption to at least 80% by 2050, compared to 32% in 2016 and only around 3% in the early 1990s (BMWi, 2017). Closing this gap requires a massive further expansion of wind and solar power.

Opposed to *dispatchable* technologies like coal- or natural gas-fired power plants that can produce whenever economically attractive, electricity generation from wind and solar PV plants is *variable*: it depends on exogenous weather conditions, the time of day, season, and location (Edenhofer et al., 2013; Joskow, 2011). At the same time, maintaining power system stability requires to continuously ensure that supply meets demand. The potential temporal mismatch of supply and demand raises two fundamental questions: how to deal with variable renewable energy at times when there is too much supply, and how to serve demand at times when supply is scarce. Evidently, electrical storage can provide a solution, for instance in the form of batteries or pumped-hydro storage plants, allowing to shift energy over time.

In a recent analysis, Sinn (2017) argues that electrical storage requirements may become excessive and could thus impede the further expansion of variable wind and solar power in Germany. Based on historic time series of electricity demand and variable renewable energy supply, he illustrates that without storage a fully renewable electricity supply would imply not using 61% of the possible power generation from wind and solar generators. In contrast, to avoid any “waste” of renewable energy,

storage requirements to take up renewable surplus energy¹ quickly rise to vast numbers. Under such a strategy, current German storage installations would not allow a share of wind and solar PV in electricity demand greater than 30%.² And for a fully renewable electricity supply, storage requirements would be more than 400 times as high as the currently installed German pumped-hydro storage capacity, and also much higher than the entire European potential to build such plants (eSTORAGE, 2015).

These considerations deserve merit as they illustrate important properties of variable renewable energy sources. Yet the approach is based on strong implicit assumptions, two of which are particularly questionable. First, it only considers two extreme cases in which either all surplus energy is stored or none. In turn, either storage needs are excessive or an excessive share of the available renewable energy is not used. Yet any economically efficient solution is likely to be located in between, i.e., combines some amount of storage and some renewable curtailment. Second, Sinn uses an objective function—minimization of the required storage energy capacity—that is unlikely to lead to a first-best outcome. This objective neither captures the full costs of storage nor the costs of other required assets in the power market.

We address, and alter, these implicit assumptions and show that their effects are significant. Both results and conclusions change substantially. When moving away from corner solutions, storage needs are up to two orders of magnitude lower in a framework otherwise identical to Sinn (2017). Using a parsimonious model with a more suitable objective function which leads to first-best solutions, we also find moderate storage requirements. They are even lower if we consider a future broadening of the electricity sector, that is, the additional use of renewable electricity in other sectors.

Throughout the paper, we provide the economic intuition of what drives storage requirements and use. Variable renewable energy sources are not only *variable* in

¹Sometimes also referred to as excess energy; Sinn (2017) uses the term “overshooting spikes”.

²In 2016, Germany had a share of wind and solar energy of 19.6% in gross electricity demand (BMW, 2017).

supply, they are also nearly free of *variable cost*. A wind or solar PV plant generates electricity whenever the wind blows or the sun shines without requiring any fuel. *Curtailment* of renewable energy denotes the operation of a wind or PV plant below its actual temporary generation potential, that is, neither consuming the actually available renewable energy in the moment of generation nor storing it for later use. Analogously, also conventional power plants do not generate electricity at full capacity at all times.

The rationale is the following: if electricity demand is satisfied, electrical storage can be used to take up renewable surplus energy. Yet integrating increasing amounts of such surpluses requires disproportionately growing storage capacities which are not valuable at most times (Denholm and Hand, 2011; Schill, 2014). Instead, an efficient solution seeks to balance investments into storage, renewables that get curtailed at times, and other capacities to minimize the total cost of providing electricity.

The remainder of this paper proceeds as follows: In Section 2, we show that Sinn’s results are outliers compared to the established literature. We then replicate his findings using open data and an open software tool in Section 3. In Section 4, we extend the basic model to target solutions between the two extreme cases. In Section 5, we devise a parsimonious model to endogenously determine optimal storage and renewable capacities as well as renewable curtailment levels. In Section 6, we discuss further relevant factors and flexibility options that influence storage needs. Section 7 concludes that electrical storage requirements are not likely to limit the transition to renewable energy.

2. Literature review

Researchers from various fields have addressed the nexus of variable renewable energy and storage. Several review papers highlight different perspectives: the economic and regulatory challenges of integrating variable renewable energy sources (Perez-Arriaga and Batlle, 2012), features of techno-economic models required to

generate policy-relevant insights (Pfenninger et al., 2014),³ and the role of long-term storage (Blanco and Faaij, 2018). A synthesis of model-based analyses suggests that electrical storage requirements for renewable energy integration are generally moderate. They may only increase substantially in scenarios approaching a fully renewable energy system (Zerrahn and Schill, 2017).

For Germany, Sinn (2017) derives electrical storage capacity needs of 2,100 gigawatt hours (GWh) (5,800 GWh, 16,300 GWh), corresponding to 0.42% (1.15%, 3.23%) of yearly electricity demand, to achieve combined shares of wind and solar power of 50% (68%, 89%). To put these numbers into perspective, we compare Sinn’s results with other studies on future electricity systems with high shares of variable renewables.

Also for Germany, Schill and Zerrahn (2018) determine optimal storage requirements in long-run scenarios. For 68% (78%, 88%) variable renewables,⁴ they arrive at 55 GWh (159 GWh, 436 GWh) storage, corresponding to 0.01% (0.03%, 0.09%) of annual demand. Further results on storage needs for the German energy transition are available among policy studies (Fraunhofer, 2014). A particularly influential study concludes that hardly any additional storage investments are necessary in Germany and Europe in the short and medium term (Pape et al., 2014): In 2050 scenarios with European shares of variable renewables around 40% (45%, 55%), additional storage capacity between around 14 and 650 GWh is needed (corresponding to 0.00% to 0.02% of annual demand), largely located outside Germany.

For Europe, Scholz et al. (2017) derive cost-minimal storage capacities corresponding to about 0.08% (0.28%) of yearly demand to achieve 74% (85%) variable renewables in a setting with equal contributions of wind and solar power. Using the same numerical model, Cebulla et al. (2017) derive larger storage needs of around 1% of yearly load at a variable renewables share of 80% in a transmission-constrained European scenario. This number decreases to 0.5% in case of increasing transmission

³As techno-economic models, we classify numerical bottom-up electricity market simulation models that explicitly incorporate relevant technical constraints.

⁴Corresponding to overall renewables shares of 80%, 90%, and 100%.

capacity.

For the U.S., MacDonald et al. (2016) find that integrating up to 55% variable renewables in 2030 does not require any electrical storage. Instead, pan-U.S. geographical balancing, facilitated by transmission investments, mitigates the variability of wind and solar power. For the Pennsylvania-New Jersey-Maryland market, Budischak et al. (2013) conclude that a large stock of electric vehicle batteries, corresponding to 0.3% of yearly overall demand, would enable pushing the renewables share to 99.9% in 99.9% of all hours. Using stationary batteries would—at higher overall cost—require even less storage capacity. Jacobson et al. (2015) show that a fully renewable (wind and solar power contributing 90%) U.S. energy system covering all end use sectors would be possible with an electrical storage capacity smaller than 0.1% of yearly electricity demand.⁵ For Texas, three papers with different approaches also conclude on moderate storage requirements: capacities corresponding to 0.06% (0.14%) of annual demand would suffice to integrate a combined share of wind and solar PV of 70% (80%) (de Sisternes et al., 2016; Denholm and Hand, 2011). Safaei and Keith (2015) derive optimal storage deployment of 0.10% of annual demand for a 66% wind power share.

Based on our review, Figure 1 plots the shares of variable renewable energy against storage energy requirements, normalized by yearly energy demand, and contrasts them with Sinn’s findings.⁶ It also includes the results of this paper from Section 5. Two findings stand out: first, storage needs disproportionately grow with higher renewables shares. Therefore, the vertical axis is provided in a logarithmic scale. This is driven by the distribution of surplus energy, which has high peaks in only a few hours of the year and is very small or zero in most other hours. Second, storage requirements found in the literature are considerable lower than those calculated by Sinn (2017)—often by at least an order of magnitude as the outer line

⁵This number includes 13 GWh of thermal storage coupled to concentrating solar thermal power generation. In addition, the optimal solution includes substantial heat storage capacities.

⁶See Appendix A for more detailed information. Complementary to storage energy capacity in Figure 1, Figure A.1 in Appendix A also provides additional information on storage power ratings.

illustrates.




Figure 1: Storage energy requirements in the literature are much lower than found by Sinn (2017). Data labels indicate corresponding renewable curtailment in percent.

What drives these large differences? One important factor is renewable curtailment; the data labels in Figure 1 provide the numbers in percent of the annually available renewable energy. While Sinn forces the storage to take up every potential kilowatt hour of surplus energy that could be generated by wind power and solar PV generators, the literature agrees that a complete integration of variable renewable energy is not desirable (see, in particular, Budischak et al., 2013; Schill, 2014; Schill and Zerrahn, 2018; Ueckerdt et al., 2017). A combination of renewable capacity oversizing and some temporary curtailment substitutes storage expansion when imposing economic efficiency criteria, such as finding a technology portfolio for least-cost renewable energy supply. In equilibrium, the marginal effects of adding another unit of storage and adding another unit of renewable generation that gets curtailed at times are equal. A social planner would thus trade off storage against renewable curtailment and other options that can provide flexibility. Accordingly, renewable curtailment is not necessarily inefficient.

Beyond curtailment, further options on both the supply and demand sides can

provide flexibility for variable renewable energy sources and thus substitute for electrical storage (Lund et al., 2015). These comprise geographical balancing (Fürsch et al., 2013; Haller et al., 2012; MacDonald et al., 2016), demand-side management (Pape et al., 2014; Schill and Zerrahn, 2018), and the flexible use of renewables in other sectors such as heat or mobility (Budischak et al., 2013; Jacobson et al., 2015). To be concise, we largely abstract from such options in our analysis, as in Sinn’s original framework. We further discuss this avenue in Section 6.

Our literature review highlights two main insights: first, Sinn’s findings are outliers compared to the consensus of established studies. Second, his extreme findings are driven by not considering relevant economic trade-offs concerning the provision of flexibility, in particular by neglecting potential renewable curtailment.

3. Replication and intuition

We first replicate the central results of Sinn’s analysis, using a spreadsheet tool and open-source input data. Following recent discussions on good practice in the field of energy research (Pfenninger, 2017; Pfenninger et al., 2018), we provide our tools and all input parameters under a permissive open-source license in a public repository⁷

3.1. Focus of our analysis

In our replication, we focus on the central Section 6 in Sinn (2017). Here, he derives storage requirements to integrate increasing shares of variable renewable energy from wind and solar PV in final electricity demand, ranging between 16.6% and 89%. In Sections 7 and 8, he provides stylized geographical extensions of this approach; while these are illustrative, we stick to the central model and its mechanics from Section 6.⁸

⁷<https://doi.org/10.5281/zenodo.1170554>.

⁸Sinn’s Sections 7 and 8 illustrate storage-reducing effects of geographical balancing. These are related to smoother aggregate demand and renewable supply patterns when considering multiple countries at a time and access to flexible hydro capacities in Norway and the Alps. Yet Sinn makes a range of strong assumptions, for example, on an unchanged geographical distribution of renewables. Sinn’s Section 9 provides largely qualitative reflections on sector coupling aspects. We quantitatively analyze this in our Section 5.4.

In Sections 2–4, Sinn suggests transforming variable renewable supply to a perfectly constant output over all hours of a year. Such smoothing results in excessive storage needs. However, there is no economic or technical reason for this kind of smoothing. It seems to be inspired by the notion that renewable generators should mimic the characteristics of conventional power plants. In this case, additional backup capacities (referred to as “double structures”) would be obsolete. However, it is not clear why using existing backup power plants should be less desirable than installing additional electrical storage; the approach is silent about any efficiency or optimality criteria. The lack of practical relevance is illustrated by the fact that resulting storage requirements cannot be empirically observed in countries with high variable renewables shares like Denmark, Ireland or Spain.⁹

3.2. Replication using open data and an open software tool

We derive input data from the Open Power System Data platform, which collects and provides European electricity market data from official sources (OPSD, 2017). Input parameters comprise hourly time series of realized German electricity demand and availability of onshore wind power and solar PV, defined as capacity factors between zero and one. Electricity demand enters the analysis as inelastic, that is, we do not fit any demand curves. This assumption follows Sinn (2017) and is also standard in much of the literature.¹⁰ Capacity factors are calculated by relating historic hourly feed-in to installed renewable generation capacity in respective hours. As in Sinn (2017), all input data is taken from the base year 2014.

To achieve an exogenously specified share of renewable electricity, the time series of capacity factors is scaled up until renewables meet the targeted share δ of annual demand.¹¹ Renewables satisfy demand either contemporaneously, that is in the hour

⁹Especially the Irish electricity system has a high supply of wind power and at the same time only few options for intertemporal balancing. The share of wind energy in Ireland was above 20% in 2016, with wind capacities somewhat above 2,800 megawatts (SEAI, 2017). The only pumped-hydro storage plant had a capacity of somewhat below 300 megawatts and the interconnector to Great Britain a capacity of 500 megawatts. Compare also OPSD, 2017.

¹⁰Assuming an inelastic short-run electricity demand appears appropriate because hourly wholesale price signals are so far not passed through to the majority of final consumers. We briefly discuss more flexible demand in Section 6.

¹¹As inferred from Sinn (2017), we do not add storage energy losses to overall demand throughout

of generation, or in a following hour facilitated by storage. To this end, we impose the storage heuristic employed by Sinn: if renewable generation exceeds demand in an hour, electrical storage takes up the surplus. It is released as soon as demand net of renewable generation is positive again. As Sinn (2017), we assume an efficiency of $\overrightarrow{\eta} = 81\%$ when storing in and $\overleftarrow{\eta} = 92.6\%$ when storing out. The remaining, non-renewable share of annual demand $1 - \delta$ is supplied by some unspecified conventional technology.

The approach aims at finding the smallest possible storage size to integrate all renewable generation. It is equivalent to Sinn’s objective of scaling the storage such that it is empty in at least one hour. The hourly storage use pattern is shifted up and down until the minimum storage size is found. To avoid free lunch, we require the storage level in the first and last hour of the year to be equal.

Using open data and open software tool, we are able to replicate Sinn’s central findings.¹² Additionally, we provide results for further shares of variable renewable electricity ranging between 20 and 90 percent. Figure 2 shows storage requirements for varying shares of renewable electricity in final demand. Results from our calculations are given in black, Sinn’s results in gray.

Storage needs rise sharply if more renewable electricity must be integrated. While current German pumped-hydro storage installations of somewhat below 0.04 terawatt hours (TWh) would suffice to fully integrate almost 30% renewable electricity, even moderate further increases in renewables would substantially drive up storage requirements. For 50% variable renewables, they already amount to 2.1 TWh, that is, they are two orders of magnitude higher. As Sinn does not provide his data and calculations open-source, we cannot trace back the small numerical differences to our findings to a specific reason; presumably, they arise due to slight differences in the input data.

our analysis.

¹²See Table 1 in Sinn (2017).




Figure 2: Storage requirements rise sharply in the share of variable renewables if all renewable surplus energy must be integrated. Results replicate the findings from Sinn (2017) using open data and an open software tool.

3.3. (Non-)Robustness

We address the robustness of findings in a sensitivity analysis using different base years. Both the time series of demand and the availability of renewable energy may change substantially between years. To this end, we repeat the basic analysis using hourly time series of demand and the renewables capacity factor of the base years 2012, 2013, 2015, and 2016.

Figure 3 depicts the results: storage requirements turn out to be highly sensitive to the choice of the base year. Taking data from 2014 yields the highest storage needs up to a variable renewables share of 65%. In contrast, data from 2015 leads to the smallest storage sizes up to 65% renewables. For instance, comparing the 50% renewables case, storage installations are less than a fifth for 2015 data as compared to 2014 data. For a high renewable penetration beyond 65%, data from the base year 2013 leads to the smallest storage. Using 2014 data generally yields comparatively large storage capacities. We explain the drivers of storage requirements below.




Figure 3: Storage requirements are highly sensitive to the choice of the base year supplying the input data for demand and renewable availability time series.

3.4. Intuition: the residual load duration curve

To gain intuition what drives storage requirements, we use the concept of *residual load duration curves (RLDCs)*. Residual load—also referred to as net load—is defined as hourly demand minus renewable feed-in in the respective hour. It is the remaining load that conventional plants or storage installations must serve.¹³ A residual load duration curve is a graphical representation of residual load of all 8,760 hours of a year, sorted in descending order. The positive integral of the curve corresponds to the energy that must be provided by non-renewable energy, storage generation or imports. The RLDC concept is prominent in the energy economics literature (compare also Ueckerdt et al., 2017).

Figure 4 shows RLDCs for the above analysis in case of 80% renewables, using 2014 as the base year.¹⁴ The solid line shows residual load before storage use. To the right, below the horizontal axis, residual load is negative, see area *A*. In these hours, there is a surplus of renewable generation. To the left, there are hours with positive

¹³The expressions load and demand can be used interchangeably.

¹⁴We also use the base year 2014 in the remainder of this analysis, as in Sinn (2017).

residual load, areas B and C . In these hours, there is relatively high demand and low renewable energy generation. The dotted line shows the RLDC after storage use.¹⁵ The storage takes up energy in hours of excess renewable supply and releases it in hours with excess demand. Graphically, it shifts the surplus energy represented by area A to area B , which equals the size of area A reduced by the storage's efficiency losses. Area C represents the annual residual load that must be served by other generators, for instance conventional or dispatchable renewable plants. By assumption, it corresponds to 20% of total demand in this case.¹⁶




Figure 4: Residual load before and after storage use for the 80% renewables case. Storage shifts surplus renewable energy (area A) to hours with positive residual load (area B).

Importantly, nothing forces the storage to shift energy to hours with highest residual loads, that is, greatest scarcity, at the very left-hand side of the RLDC; the operational heuristic prescribes to empty the storage as soon as residual demand is positive again. With the present patterns of demand and renewable feed-in, it is

¹⁵As the residual load after storage use is also sorted in descending order, the order of hours may differ between the solid and the dotted line.

¹⁶For simplicity, we do not consider electricity trade with neighboring countries. In reality, some part of the renewable surplus, area A , is likely to be exported, while some part of the remaining residual load, area C , is likely to be imported. The specific effects depend on trade capacities and the residual load patterns in the neighboring countries.

unlikely that an hour with very high residual load follows closely to an hour with renewable surplus generation. The RLDC representation dissolves the temporal sequence of hours during the year.

4. Storage requirements under renewable curtailment

The residual load duration curve illustrates the two challenges of integrating high shares of variable renewable electricity: (i) on the left-hand side of the curve, there are hours with high demand that variable renewables cannot directly supply; (ii) on the right-hand side, there are hours with renewable surplus generation. Both sides of the RLDC have an impact on storage requirements.

4.1. Power-oriented renewable curtailment

The RLDCs suggest that curtailment of renewable surpluses may reduce storage requirements. We first devise a strategy that allows curtailment of all renewable energy surpluses beyond a defined threshold. This threshold can be interpreted as the power capacity of a storage (in megawatt, MW); this is the energy the storage can take up per hour—as opposed to the energy capacity the storage can accommodate in total (in megawatt hours, MWh). This distinction is an essential characteristic of any electric storage technology and missing in Sinn (2017). In case of pumped-hydro storage, the power capacity describes the power of the pumps or of the turbine to generate electricity; the energy capacity indicates the volume (in energy terms) of the storage basin.

We extend the basic model by a renewable curtailment threshold, equivalent to the power capacity of the storage. If hourly surplus generation is below the threshold, it is channeled into the storage; all renewable surplus energy beyond the threshold is curtailed. Otherwise, the model is identical to Section 3 and storage use remains myopic. To gain some intuition, Figure 5 shows RLDCs for 80% renewables in final demand and a curtailment threshold of 44.1 gigawatt (GW), which leads to curtailment of 5% of maximum yearly renewable generation. The threshold is indicated by the horizontal solid gray part of the RLDC after renewable curtailment

on the right-hand side. Area D represents all renewable surplus that is curtailed. The storage shifts the remaining surplus energy from area A to area B . The remaining energy demand, area C , is supplied by other means. This renewable curtailment strategy avoids storing the most excessive surplus events.




Figure 5: Residual load before and after renewable curtailment as well as storage use for the 80% renewables case. Under the power-oriented renewable curtailment strategy, curtailment occurs in hours with the greatest renewable energy surplus.

We iterate through combinations of minimum renewable requirements and maximum allowed renewable curtailment. In doing so, the spreadsheet model endogenously determines the curtailment threshold—or storage power capacity—such that no more renewable energy is curtailed than maximally allowed. Figure 6 shows the results. It is evident that increasing levels of renewable curtailment lead to lower storage requirements. The decrease is close to linear though somewhat convex. For instance, while a complete integration of 50% variable renewable electricity triggers 2.1 TWh storage energy capacity, allowing curtailment of 5% of the annual renewable generation reduces storage needs to 0.3 TWh.

Specifically, we provide solutions that lie between the two extremes “no renewable curtailment” and “no storage”, which Sinn (2017) only considers. The vertical axis of Figure 6 indicates storage requirements if no renewable curtailment is al-




Figure 6: Storage energy requirements substantially decrease when power-oriented curtailment of renewable electricity is allowed.

lowed. The numbers are identical to those that we replicate from Sinn’s approach (compare Figure 2 and the right panel of his Table 1). The horizontal axis shows renewable curtailment levels if no storage is allowed. Here, we also replicate Sinn’s findings on “efficiency losses” that are given in the left panel of his Table 1. For instance, for 50% renewables, our model returns a renewable curtailment between 6.0 and 6.5%, as indicated by the point where the solid gray line intersects the horizontal axis in Figure 6. For the same case, Sinn determines an “efficiency” of 93.8%, which corresponds to curtailment of 6.2%.¹⁷

Thus, we provide a solution space combining curtailment and storage that lies between the two extreme cases. For other base years, results are qualitatively unchanged; however, they exhibit great variation concerning the level of required storage.

To achieve the same share of renewable energy in final demand, the required

¹⁷For conciseness, we refrain from calculating the exact numbers here. Results on other renewables shares also replicate Sinn’s findings: in Sinn (2017), 40% renewables correspond to 1.7% renewable curtailment if no storage is available, see left panel of his Table 1. We determine a figure between 1.5 and 2%. For 60% (70%, 80%) renewables, Sinn finds 14.8% (27.1%, 42.6%) renewable curtailment and we determine a figure between 15 and 16% (between 25 and 30%, between 40 and 45%).

renewable capacities are necessarily higher when allowing for curtailment, that is, if some of the available energy is not used. However, this increase is moderate, as Figure 7 shows. For instance, achieving 50% renewable energy in final demand requires 214 GW renewables without curtailment. With 5% curtailment, the necessary renewable capacities are somewhat higher, at 226 GW.




Figure 7: While some renewable curtailment substantially decreases storage requirements, somewhat larger renewables capacities are necessary to achieve a specified share of renewable energy in final demand.

Yet renewable curtailment does not increase the necessary backup capacities to supply the remaining residual electricity demand after storage. They are no larger than in the case without renewable curtailment. Inspecting the left-most part of the RLDCs in Figures 4 and 5, there is also no reason to assume so.¹⁸

4.2. Energy-oriented renewable curtailment

While the power-oriented storage strategy—curtailing renewable surplus whenever it exceeds a defined threshold—seems plausible, it may not be optimal with

¹⁸Backup capacities could only be smaller under the no-curtailment-regime if there was an extended number of hours with high surpluses, directly followed by hours with the highest residual loads. This case is rather unlikely; also, we cannot observe it in our data. In Section 5.3, we show how storage can lower the need for backup capacities.

respect to finding the smallest required storage energy capacity. Given historic input data, it turns out that extended periods of renewable surpluses in contiguous hours determine the maximum energy capacity of the storage, and not single periods with the highest surplus generation. For instance, storing a moderate surplus in ten consecutive hours may require more storage than storing an extreme surplus event in one hour.




Figure 8: Residual load before and after renewable curtailment as well as storage use for the 80% renewables case. Under the energy-oriented curtailment strategy, renewable curtailment occurs in hours where it triggers the greatest storage energy capacity reductions.

Therefore, we alternatively implement an energy-oriented renewable curtailment strategy. The storage operational pattern remains myopic and is identical to the above cases; however, renewable curtailment occurs if and only if the storage is fully loaded. Thus, it targets a minimum energy capacity requirement. Again, we iterate through minimum renewable requirements and maximum renewable curtailment constraints to explore the solution space and endogenously determine minimum storage capacities.

To provide some intuition, Figure 8 shows the resulting residual load duration curves for the case of 80% renewables and a maximum curtailment of 5% of the annual renewable energy. Curtailed energy, area D , is identical to the one under

the power-oriented renewable curtailment strategy, area D in Figure 6. However, renewable curtailment is concentrated in hours in which surpluses trigger the highest storage requirements; these are not necessarily the hours with the highest surplus generation. Storage shifts the remaining surplus generation, area A , to hours with positive residual load, area B . Note that renewable curtailment and the storage operational pattern are still myopic and deterministic, that is, they do not require perfect foresight: surplus energy is charged into the storage as long as there are free capacities, and is curtailed otherwise. The stored energy serves residual load as soon as it is positive again.




Figure 9: Storage energy requirements substantially decrease if an energy-oriented renewable curtailment strategy is in place.

Figure 9 shows the resulting storage requirements for varying minimum shares of renewable energy. Overall, storage requirements decrease substantially even if only small levels of renewable curtailment are allowed. Again, the intersection points with the axes represent Sinn's solutions: on the vertical axis all renewable energy must be integrated; on the horizontal axis no storage is available. Any combination of both options yields significantly lower storage needs; the decrease is much more convex than under the power-oriented renewable curtailment strategy; already a

small curtailment budget triggers a large effect.¹⁹

For instance, while a complete integration of 50% variable renewable electricity requires 2.1 TWh storage energy capacity, allowing for 5% renewable curtailment reduces storage needs to 0.019 TWh, or 19 GWh. This is one order of magnitude lower than under the power-oriented curtailment strategy, two orders of magnitude lower than without renewable curtailment, and less than the pumped-hydro power capacity installed in Germany by 2018. Allowing 8% curtailment, 44 GWh of storage, slightly more than installed in Germany by 2018, would suffice to reach 70% variable renewable energy.

5. Cost-minimal storage requirements

The data-driven analysis in Section 4 alters an important implicit assumption of Sinn’s approach: plausible solutions lie between the two corner solutions of no renewable curtailment or no storage. However, the approach is still unlikely to result in an efficient market outcome because of the objective function used. From an economic perspective, finding least-cost solutions is relevant, that is, cost-minimal combinations of conventional and renewable generation, renewable curtailment, and electrical storage.²⁰ As we also include a stylized representation of conventional generators, we explicitly address what Sinn refers to as “double structure buffering.”

In this context, both storage energy capacity (in MWh) and storage power capacity (in MW) matter with respect to costs.²¹ To find optimal solutions, we employ a stylized and parsimonious numerical optimization model.²² We provide the source code and all input data under a permissive open-source license in a public reposi-

¹⁹Also here, renewable curtailment does not increase backup needs. Likewise, allowing renewable curtailment goes along with slightly higher renewable capacities necessary to achieve the imposed renewables share in final demand. By construction, numbers are identical to the power-oriented curtailment strategy.

²⁰For the sake of conciseness and traceability, we still neglect other potential sources of flexibility, such as load shifting or dispatchable biomass. We illustrate the effects of such flexibility options in Schill and Zerrahn (2018).

²¹For simplicity, we assume identical charging and discharging capacity.

²²The model is derived from our established and more detailed open-source model DIETER; see Zerrahn and Schill (2017) for an exposition. The model is implemented in the General Algebraic Modeling System (GAMS).

tory.²³

The economic optimization approach addresses both challenges of renewable energy integration. First, it delivers an efficient solution to the trade-off how much and when renewable surplus energy to curtail, and how much and when to store. This corresponds to the right-hand side of the residual load duration curve. Second, it determines efficient conventional, renewable, and storage capacities to serve demand at any point in time; this corresponds to the left-hand side of the residual load duration curve. The results of the cost minimization model can be interpreted as long-run equilibria under the assumption of perfect competition and complete information. The model thus mimics a first-best social planner approach.

5.1. The model

The numerical model minimizes the total costs of satisfying electricity demand in every hour h of a year. The objective function (1) sums the products of specific investment costs κ^i and capacity entry N of storage, differentiated by energy N^{se} and power N^{sp} , renewables N^r , and conventional capacity N^c . Throughout the model, upper-case Roman letters indicate variables. We parametrize storage costs according to pumped-hydro storage, which features relatively high costs for power capacity $\kappa^{i,sp}$ and relatively low costs for energy capacity $\kappa^{i,se}$. For conciseness, we consider one stylized technology for variable renewables which aggregates the generation patterns of onshore wind power and solar PV,²⁴ and two stylized conventional technologies $c \in \{base, peak\}$, parametrized to lignite and natural gas plants. Base generators incur high capacity costs and low variable costs, and vice versa for peak plants. Investment costs are annualized using typical lifetimes of power plants. For simplicity, we abstract from the lumpiness of investments. All variables are continuous and positive.

Moreover, the objective function comprises operational costs for conventional plants $\kappa^{v,c}$, consisting of fuel and other variable costs, and storage use $\kappa^{v,s}$. These

²³<https://doi.org/10.5281/zenodo.1170554>

²⁴According to the base year 2014, the synthesized renewable technology consists of 61% onshore wind power and 39% solar PV.

operational costs apply to each megawatt hour of conventional generation G_h^c and each megawatt hour of storage charge charging \vec{S}_h and discharging \overleftarrow{S}_h .

Renewable energy does not incur any variable costs. We also do not impose any costs for curtailment of renewables. As the objective function comprises the investment costs of renewable plants, it accounts for the full cost of renewable energy irrespective whether it eventually satisfies demand or is curtailed at times.²⁵ By analogy, also the use of conventional plants below capacity does not receive any penalty in the objective function.

All parameter assumptions lean on established projections for Germany for 2035.²⁶ The concrete numbers are provided in the Zenodo repository.

$$\begin{aligned} \min Z = & \kappa^{i,se} N^{se} + \kappa^{i,sp} N^{sp} + \sum_c \kappa^{i,c} N^c + \kappa^{i,r} N^r \\ & + \sum_{c,h} \kappa^{v,c} G_h^c + \sum_h \kappa^{v,s} \left(\vec{S}_h + \overleftarrow{S}_h \right) \end{aligned} \quad (1)$$

The market clearing condition (2) makes sure that price-inelastic electricity demand d_h in every hour is satisfied either by renewable generation G_h^r , conventional generation or generation from storage.

$$d_h = \sum_c G_h^c + G_h^r + \overleftarrow{S}_h \quad \forall h \quad (2)$$

Constraint (3a) ensures that hourly generation by conventional plants does not exceed installed capacity. Hourly renewable energy supply is determined as the product of the exogenous hourly capacity factor $\gamma_h \in [0, 1]$ and the installed capacity. Both the hourly time series of electricity demand and the capacity factor enter the

²⁵According to current German legislation, owners of wind and PV plants generally receive a subsidy payment for each megawatt hour of energy generated, also when being curtailed, to recover their investments. Analogously, the model's objective function accounts for investment costs of wind and PV plants irrespective whether generation is curtailed at times or not. In 2016, curtailment amounted to 2.3% of the renewable energy generation under the German subsidy scheme, however, entirely mandated by the electricity network operators to ease congestion (BNetzA and BKartA, 2017).

²⁶We do not aim to derive detailed projections for a future electricity market in Germany here. Our stylized analysis only focuses on relevant drivers influencing an cost-optimal storage capacity. Therefore, we abstract from further economic and technological details.

model as data. We take the same time series as in Sections 3 and 4, that is, German data from the base year 2014. Renewable energy either satisfies demand, is charged into the storage \vec{S}_h , or gets curtailed C_h^r (3b). For convenience, we stick to the assumption that storage can only be charged with renewable energy.

$$G_h^c \leq N^c \quad \forall h \quad (3a)$$

$$\gamma_h N^r = G_h^r + \vec{S}_h + C_h^r \quad \forall h \quad (3b)$$

The storage level \bar{S}_h in any hour equals the storage level in the previous hour $h - 1$, plus the energy charged to storage \vec{S}_h minus the energy discharged \overleftarrow{S}_h , both corrected by efficiency losses (4a), which are identical to the spreadsheet approach. Capacity constraints impose that the hourly energy charged or discharged does not exceed the installed pump or turbine capacity (4b–4c) and that the storage level never exceeds the installed energy storage capacity (4d). Further, we require an identical storage level in the first and last period of the analysis.

$$\bar{S}_h = \bar{S}_{h-1} + \overrightarrow{\eta} \vec{S}_h - \frac{\overleftarrow{S}_h}{\overleftarrow{\eta}} \quad \forall h \quad (4a)$$

$$\vec{S}_h \leq N^{sp} \quad \forall h \quad (4b)$$

$$\overleftarrow{S}_h \leq N^{sp} \quad \forall h \quad (4c)$$

$$\bar{S}_h \leq N^{se} \quad \forall h \quad (4d)$$

To explore rising shares of renewable electricity, we exogenously impose a minimum share of yearly final demand to be satisfied by renewables, $\delta \in [0, 1]$, for reasons of convenience imposed as maximum share of conventional energy (5). We explore minimum renewables shares between 25% and 90% in five percentage points increments.

$$\sum_{c,h} G_h^c \leq (1 - \delta) \sum_h d_h \quad (5)$$

The model is a linear program and solved numerically to global optimality. The

result is a cost-minimal combination of renewable, conventional, and storage capacity investments as well as their optimal hourly dispatch. Specifically, two strategies can increase the required minimum share of renewables: the use of storage to integrate surpluses, or larger renewable capacities plus curtailment. The model solves this trade-off endogenously. Note that, opposed to the myopic models in Section 4, this approach requires the assumption of perfect foresight to optimally schedule the release of energy from the storage.²⁷

5.2. Intuition

To again provide some intuition before discussing numerical results, Figure 10 plots the resulting RLDCs for the 80% renewables case. If capacity entry is costly with respect to both storage power and storage energy, the optimal solution combines both channels analyzed in Section 4. Areas D_1 and D_2 represent the curtailed renewable energy. The kink to the right is driven by power-oriented curtailment, compare Figure 5. The renewable surplus gets curtailed beyond the threshold of 46 GW, as the shaded area D_1 indicates, limited by the optimal storage power capacity. Curtailment of renewable surplus D_2 is driven by energy-oriented renewable curtailment, compare Figure 8, targeted at limiting the storage energy capacity. Area A represents the stored renewable surplus energy, which the storage shifts to hours with positive residual load.

The optimal release of the stored renewable energy surpluses economically balances three uses: First, the energy shifted to area B_1 reduces generation—and according variable costs—of the base technology, which otherwise operates whenever residual load is positive. Second, the energy shifted to area B_2 reduces variable costs of the peak technology. Base capacity is 29.4 GW, indicated by the horizontal part of the dotted line; beyond, the peak plant with higher variable costs additionally generates electricity. Third, the energy shifted to area B_3 replaces capacity entry—and respective cost—of the peak technology. If there was no storage, additional

²⁷In the real world, proficient market forecasts are essential for storage operators. The market reality thus likely lies between the myopic and the perfect foresight cases.

generation capacity would have to satisfy the demand exceeding 53.5 GW, indicated by the left-most horizontal part of the dotted line.²⁸




Figure 10: Residual load before and after renewable curtailment as well as storage use for the 80% renewables case. In the cost-optimal solution, curtailment follows both a power- and an energy-oriented strategy. The storage shifts renewable surpluses in time to replace variable costs and investments of conventional generators.

Thus, the cost-minimization model illustrates two economic values of electrical storage beyond avoiding renewable curtailment in a concise way. First, an arbitrage value materializes when stored renewable surplus energy replaces variable costs of other generators, in particular fuel costs. Second, a capacity value materializes when stored renewable surplus energy replaces conventional power plant capacities which otherwise would have to be provided for hours of residual load peaks. Still, only renewable energy can enter the storage by assumption. Opening up the storage for conventional energy would strengthen both economic values. In reality, no reason prohibits such operation.²⁹

²⁸In fact, the storage crowds out both peak and base capacities; the optimization endogenously determines the optimal relationship. In the figure, only the dampening effect on peak capacities is clearly visible.

²⁹Residential battery storage coupled to prosumage-oriented solar PV installations constitutes a notable exception (Schill et al., 2017).

5.3. Results

Figure 11 summarizes the results of the parsimonious optimization model. Optimal storage capacities, both with respect to energy and power, rise with the share of variable renewable energy. However, overall storage requirements remain moderate. For instance, a storage energy capacity of 35 GWh suffices to achieve a share of 50% renewables in final demand. This is about two orders of magnitude less than in Sinn’s analysis, but slightly more than when targeting minimum storage requirements because the model considers additional values of storage. Yet it is still less than installed in Germany by 2018. Analogous findings prevail for other renewables shares.³⁰




Figure 11: Cost-optimal storage capacities and renewable curtailment rise with the minimum share of variable renewables. Yet they remain moderate.

When increasing the targeted renewables share, the optimal storage energy capacity grows much faster than the optimal storage power capacity. For 50% renewables, 35 GWh energy are accompanied by about 6 GW storage power. Dividing energy by power yields an energy-to-power (E/P) ratio of about 6 hours. The E/P ratio is an important metric to characterize a storage technology and reflects its temporal

³⁰Figure B.1 in Appendix B provides results for alternative base years.

layout: a 6 hours storage is a typical short-to-medium-term storage to compensate diurnal fluctuations, such as of solar PV generation. If it is completely charged, it can generate electricity for 6 hours at maximum power rating.³¹ For higher renewables shares, the E/P ratio increases to reach about 19 hours for 90% renewables. This highlights the importance of considering both rather inexpensive storage energy and rather expensive storage power separately. Moreover, no need for a true long-term storage arises, that is, storing energy for weeks or months.

Optimal endogenous renewable curtailment also grows with higher minimum renewables shares. As such, the economics of renewable electricity provide no reason why curtailment should be avoided. It can be more efficient not to use available renewable energy at times despite costly investment into wind and PV plants. The optimal solution combines conventional plants, storage, and renewables, part of which being curtailed at times.

5.4. *Extension: flexible sector coupling (power-to-x)*

In future low-carbon energy systems, renewable electricity supply considered as surplus energy in the above framework is likely to be highly valuable for new uses. Merging electricity, heating, and transport sectors can not only provide flexibility for integrating variable renewables into the power market, but can also contribute to decarbonizing these other sectors (Mathiesen et al., 2015). This concept, often referred to as *sector coupling*, comprises using renewable electricity, for example, for residential heating (see Bloess et al., 2018, for an overview of the recent literature) or for electric mobility (Richardson, 2013). Moreover, renewable electricity can also be used to produce other energy carriers, such as hydrogen or synthetic gaseous or liquid fuels, by means of electrolysis (Schiebahn et al., 2015). Such sector coupling options are often referred to as *power-to-x* (or P2X). They can lower electrical storage requirements if the new loads are sufficiently flexible and the additional demand can be shifted to periods in which renewable availability is high.

³¹The German pumped-hydro storage fleet has an E/P ratio of about 7 hours.

To illustrate this avenue in our model, we add a stylized additional electricity demand of a generic *power-to-x* technology with a capacity of $n^x = 50$ GW and 2,000 full-load hours to our model, which corresponds to an additional annual energy demand of $d^x = 100$ TWh.³² For instance, this could be a fleet of electric vehicles: assuming a yearly electricity demand of 2000 kWh per vehicle, this would correspond to 50 million vehicles. Alternatively, the additional demand may come from flexible electric heaters, or from electrolyzers converting renewable surplus electricity into hydrogen. For simplicity, we do not further restrict the timing of this additional consumption; it is only limited by the installed power capacity, i.e. the *power-to-x* demand is assumed to be highly flexible. In line with the literature, we generally assume that it is less costly to store x , for instance heat or synthetic fuels, than electrical energy, rendering the timing of the *power-to-x* generation more flexible. Moreover, we require the additional demand to be satisfied entirely by additional renewables. To this end, we augment Equation (3b) to

$$\gamma_h N^r = G_h^r + \vec{S}_h + C_h^r + \vec{X}_h \quad \forall h \quad (3b')$$

where the variable \vec{X}_h is the hourly *power-to-x* demand that is optimized endogenously. Two further equations restrict the hourly demand by the installed capacity n^x (6a) and require that annual *power-to-x* demand d^x is satisfied over the year (6b). Otherwise, all model assumptions and equations are identical to Section 5.1.

$$\vec{X}_h \leq n^x \quad \forall h \quad (6a)$$

$$\sum_h \vec{X}_h = d^x \quad (6b)$$

Figure 12 summarizes the results. For most renewables shares, both optimal storage capacities and renewable curtailment rates are substantially lower in case

³²Full-load hours are an indicator for the annual use of the technology in terms of hours with demand at full capacity; for instance, 2,000 full-load hours are equal to 4,000 hours of use at half capacity.

power-to-x technologies are included. For instance, for 50% renewables, the storage energy capacity drops from 35 GWh to 4 GWh and renewable curtailment from 5% to below 1%. Electrical storage requirements are lower up to a renewables share of 85%. In the 90% renewable case, storage needs are the same as in the case without *power-to-x*, as the additional demand can be completely satisfied from renewable surplus generation that would otherwise be curtailed.




Figure 12: Cost-optimal electrical storage capacities and renewable curtailment with an additional annual *power-to-x* electricity demand of 100 GWh are substantially lower.

The rationale is the following: renewable capacities rise from 223 GW to 298 GW to supply part of the additional *power-to-x* demand. Another part of the additional demand is satisfied by renewable electricity previously curtailed or stored. Accordingly, both storage needs and renewable curtailment rates are substantially lower in most cases.³³

As we assume *power-to-x* to be perfectly flexible, the diminishing effects on storage requirements and renewable curtailment constitute an upper bound for less flex-

³³To be transparent, results strongly depend on the assumptions on capacities and full-load hours of the generic *power-to-x* technology. See Figure C.1 in Appendix C. The effect of *power-to-x* on storage needs is zero or negative in this setting up to 4,000 full load hours, which is a considerably high value. With the parameterization used here, the largest effect on electrical storage emerges between 1500 and 2000 full-load hours.

ible real-world applications. However, they illustrate that flexible sector coupling could substantially drive down electrical storage needs. If additional flexible electricity demand emerges that contributes to decarbonizing other energy sectors, then renewable surplus generation becomes a valuable resource.³⁴

6. Discussion

Departing from Sinn (2017), we implement small but relevant changes to move his the setup away from corner solutions. The impact is substantial and reduces storage needs up to two orders of magnitude. At the same time, our analysis remains stylized and tractable. In the following, we highlight further important points that researchers should consider when analyzing storage needs to integrate variable renewable electricity, both against the background of Sinn’s analysis and the large body of academic literature.

First, the definition of efficiency should be clarified when it comes to variable renewable energy sources. Sinn (2017) seems to refer to inefficiency as both curtailment of renewables and storage use as such; the first motivated by avoiding waste, the second by avoiding backup capacities (referred to as “double structure buffering”).³⁵ However, a welfare economic approach should rather target the least-cost provision of electricity for given minimum renewable energy constraints. The result is a combination of conventional and renewable plants, storage, and curtailment of a certain amount of renewable energy. Why the one or the other should be “inefficient” is unclear. In the optimum, the marginal cost of further expanding storage, renewables that are curtailed at times, and conventional capacities is equal. Which shares of renewable energy are optimal when also considering external costs, for instance, arising from climate change, local emissions or land use change, whether the

³⁴Likewise, more variable generation and, accordingly, wholesale market prices, may incentivize also the current electricity demand to become more temporally flexible in the long-run. This would have an analogous mitigative effect on storage needs.

³⁵See, for instance, Table 1 or Figure 8 in Sinn (2017). Moreover, the notion of “wasting energy” from renewables is questionable. On that note, one may also consider electricity not produced by conventional plants, that is, full-load hours smaller than 8,760, as “waste”. In both cases, marginal costs are zero.

market achieves this solution, or which regulatory measures are required is another issue left for analysis and discussion elsewhere.

Second, electrical storage has values beyond arbitrage. It can provide firm capacity and thus reduce the need for backup plants (see Section 5.2), provide balancing reserves and other ancillary services to maintain power system stability, and may also help mitigating grid constraints.

Third, other types of energy storage are relevant beyond pumped-hydro. These comprise batteries, which could become much cheaper in the future (Schmidt et al., 2017),³⁶ or power-to-gas storage. Specifically, different storage technologies have different costs for power and energy capacities. While batteries are relatively cheap in power, they are expensive in energy, and vice versa for power-to-gas. Thus, electrical storage technologies have different optimal E/P ratios: batteries are generally suited for short-term storage of a few hours, pumped hydro for around six to ten hours, and power-to-gas for longer periods. An optimal deployment of different storage types can address different types of renewable fluctuations, for example, intra-hourly, diurnal or even seasonal (Safaei and Keith, 2015; Scholz et al., 2017; Zerrahn and Schill, 2017). Such a differentiated storage fleet also tends to be smaller and cheaper.

Fourth, scaling up historical feed-in time series of a fixed proportion of wind and solar power tends to over-estimate flexibility requirements. Both market forces and the renewables support scheme in Germany tend to incentivize renewable generation when prices are higher and supply is, accordingly, scarce. Such *system-friendly* renewables comprise wind turbines that dis-proportionally produce electricity when wind speeds are low, both due to their location and technical layout (May, 2017). A similar argument holds for solar PV panels, which may be directed such that they generate more electricity in morning or afternoon hours. Even more relevant, offshore wind turbines have much smoother generation patterns and higher full-load hours

³⁶Batteries may gain additional relevance in the context of grid-integrated electric vehicles (Budischak et al., 2013).

than onshore wind parks.³⁷ The sensitivity toward the base year in Section 3 further illustrates the relevance of appropriate input data choices. Ideally, analyses should be based on bottom-up weather data covering as many years as possible (Staffell and Pfenninger, 2016).

Fifth, further electricity market integration across national borders generally yields smoother residual load. When balanced over greater geographical areas, the variability of wind, solar, and demand tends to be evened out (Cebulla et al., 2017; Fürsch et al., 2013; Haller et al., 2012; MacDonald et al., 2016). This results in smoother residual load patterns and lower storage requirements.

Finally, a temporally more flexible demand can also substitute electrical storage (Denholm and Hand, 2011; Pape et al., 2014; Schill and Zerrahn, 2018). If a more variable electricity supply triggers more volatile prices, and these prices are passed through to consumers, then the demand side should have increasing incentives to consume more flexibly and profit from arbitrage gains.

7. Conclusions

The use of renewable energy is a major strategy to mitigate greenhouse gas emissions, reduce fossil fuel imports, and create a sustainable energy system. However, integrating growing shares of variable wind and solar power in electricity markets poses increasing challenges. Electrical storage is an important—albeit not the only—option to address the mismatching time profiles of variable renewable supply and electric demand. In a recent analysis, Sinn (2017) calculates storage needs in a German setting and finds vastly growing electrical storage requirements, already for renewable supply shares only moderately greater than currently in Germany. Based on these findings, he suggests that electrical storage may limit the further expansion of variable renewable energy sources.

While Sinn’s illustrations deserve merit, the findings are not backed up by the

³⁷For instance, in Germany in 2016, offshore wind had more than 3,200 full-load hours and a coefficient of variation of 0.73; for onshore (solar PV), full-load hours were somewhat below 1,600 (900) and the coefficient of variation was 0.83 (1.53) (OPSD, 2017).

literature. A large body of techno-economic studies conclude on substantially lower storage needs, also for high shares of variable renewables. An important reason for Sinn’s deviating findings is that he only considers corner solutions—either no storage, resulting in vast renewable curtailment, or no curtailment, resulting in excessive storage requirements. Further, Sinn’s objective function is unlikely to lead to efficient outcomes.

We show that addressing these implicit assumptions matters: both results and conclusions change substantially. Our analysis, based on open-source tools and open data, concludes that storage needs are lower by up to two orders of magnitude. Our findings are in line with most of the literature. Cost-efficient solutions optimally combine renewable capacity expansion, renewable curtailment, and electrical storage. We also illustrate that electrical storage needs may decrease further if the electricity sector is broadened to also include flexible additional demand, for example related to heating or mobility. While we demonstrate that such *power-to-x* may substantially change the picture, further and more detailed research on this avenue would be desirable.

All things considered, we conclude that electrical storage requirements do not limit the further expansion of variable renewable energy sources.

Acknowledgments

We thank Friedrich Kunz for extensive discussions as well as Christian von Hirschhausen, Julia Rechlitz, Jörn Richstein, and Fabian Stöckl for many valuable comments. We further thank Mona Setje-Eilers for research assistance. Parts of this analysis were carried out in the context of the research project Kopernikus P2X, funded by the German Federal Ministry of Education and Research (grant number FKZ 03SFK2B1). Declarations of interest: none.

References

- H. Blanco and A. Faaij. A review at the role of storage in energy systems with a focus on power to gas and long-term storage. *Renewable and Sustainable Energy Reviews*, 81(1):1049–1086, 2018. doi: 10.1016/j.rser.2017.07.062.
- A. Bloess, W.-P. Schill, and A. Zerrahn. Power-to-heat for renewable energy integration: A review of technologies, modeling approaches, and flexibility potentials. *Applied Energy*, 212:1611–1626, 2018. doi: 10.1016/j.apenergy.2017.12.073.
- C. Budischak, D. Sewell, H. Thomson, L. Mach, D.E. Veron, and W. Kempton. Cost-minimized combinations of wind power, solar power and electrochemical storage, powering the grid up to 99.9% of the time. *Journal of Power Sources*, 225:60–74, 2013. doi: 10.1016/j.jpowsour.2012.09.054.
- Bundesnetzagentur (BNetzA) and Bundeskartellamt (BKartA). Monitoring-bericht 2017. URL https://www.bundesnetzagentur.de/SharedDocs/Downloads/DE/Allgemeines/Bundesnetzagentur/Publikationen/Berichte/2017/Monitoringbericht_2017.pdf?__blob=publicationFile&v=3. Accessed February 12, 2018.
- F. Cebulla, T. Naegler, and M. Pohl. Electrical energy storage in highly renewable European energy systems: Capacity requirements, spatial distribution, and storage dispatch. *Journal of Energy Storage*, 14(1):211–223, 2017. doi: 10.1016/j.est.2017.10.004.
- F.J. de Sisternes, J.D. Jenkins, and A. Botterud. The value of energy storage in decarbonizing the electricity sector. *Applied Energy*, 175:368–379, 2016. doi: 10.1016/j.apenergy.2016.05.014.
- P. Denholm and M. Hand. Grid flexibility and storage required to achieve very high penetration of variable renewable electricity. *Energy Policy*, 39(3):1817–1830, 2011. doi: 10.1016/j.enpol.2011.01.019.

O. Edenhofer, L. Hirth, B. Knopf, M. Pahle, S. Schlömer, E. Schmid, and F. Ueckerdt. On the economics of renewable energy sources. *Energy Economics*, 40: S12–S23, 2013. doi: 10.1016/j.eneco.2013.09.015.

Federal Ministry for Economic Affairs and Energy (BMWi). Renewable Energy Sources in Figures. National and International Development, 2016, 2017. URL https://www.bmwi.de/Redaktion/EN/Publikationen/renewable-energy-sources-in-figures-2016.pdf?__blob=publicationFile&v=5. Accessed February 12, 2018.

Fraunhofer UMSICHT and Fraunhofer IWES. Abschlussbericht Metastudie "Energiespeicher". Studie im Auftrag des Bundesministeriums für Wirtschaft und Energie (BMWi), 2014. URL <https://www.umsicht.fraunhofer.de/content/dam/umsicht/de/dokumente/pressemitteilungen/2015/Abschlussbericht-Metastudie-Energiespeicher.pdf>. Accessed February 12, 2018.

M. Fürsch, S. Hagspiel, C. Jägemann, S. Nagl, D. Lindenberger, and E. Tröster. The role of grid extensions in a cost-efficient transformation of the European electricity system until 2050. *Applied Energy*, 104:642–652, 2013. doi: 10.1016/j.apenergy.2012.11.050.

M. Haller, S. Ludig, and N. Bauer. Decarbonization scenarios for the EU and MENA power system: considering spatial distribution and short term dynamics of renewable generation. *Energy Policy*, 36(1):149–184, 2012. doi: 10.1016/j.enpol.2012.04.069.

M.Z. Jacobson, M.A. Delucchi, M.A. Cameron, and B.A. Frew. Low-cost solution to the grid reliability problem with 100% penetration of intermittent wind, water, and solar for all purposes. *Proceedings of the National Academy of Sciences of the United States of America*, 112(49):15060–15065, 2015. doi: 10.1073/pnas.1510028112.

- P.L. Joskow. Comparing the costs of intermittent and dispatchable electricity generation technologies. *American Economic Review: Papers & Proceedings*, 100(3): 238–241, 2011. doi: 10.1257/aer.100.3.238.
- P.D. Lund, J. Lindgren, J. Mikkola, and J. Salpakari. Review of energy system flexibility measures to enable high levels of variable renewable electricity. *Renewable and Sustainable Energy Reviews*, 45:785–807, 2015. doi: 10.1016/j.rser.2015.01.057.
- A.E. MacDonald, C.T.M. Clack, A. Alexander, A. Dunbar, J. Wilczak, and Y. Xie. Future cost competitive electricity systems and their impact on US CO₂ emissions. *Nature Climate Change*, 6:526–531, 2016. doi: 10.1038/nclimate2921.
- B.V. Mathiesen, H. Lund, D. Connolly, H. Wenzel, P.A. Østergaard, B. Möller, S. Nielsen, I. Ridjan, P. Karnoe, K. Sperling, and F.K. Hvelplund. Smart energy systems for coherent 100% renewable energy and transport solutions. *Applied Energy*, 145:139 – 154, 2015. ISSN 0306-2619. doi: <https://doi.org/10.1016/j.apenergy.2015.01.075>. URL <http://www.sciencedirect.com/science/article/pii/S0306261915001117>.
- N. May. The impact of wind power support schemes on technology choices. *Energy Economics*, 65:343–354, 2017. doi: 10.1016/j.eneco.2017.05.017.
- Open Power System Data. Data Package Renewable power plants. Version 2017-02-16, 2017. URL https://data.open-power-system-data.org/renewable_power_plants/2017-02-16/. Accessed February 12, 2018.
- C. Pape, N. Gerhard, P. Härtel, A. Scholz, R. Schwinn, T. Drees, A. Maaz, J. Sprey, C. Breuer, A. Moser, F. Sailer, S. Reuter, and T. Müller. Roadmap Speicher. Bestimmung des Speicherbedarfs in Deutschland im europäischen Kontext und Ableitung von technisch-ökonomischen sowie rechtlichen Handlungsempfehlungen für die Speicherförderung. Endbericht, Kassel, Aachen, Würzburg, 2014. URL http://www.fvee.de/fileadmin/publikationen/Politische_Papiere_FVEE/

- 14.IWES_Roadmap-Speicher/14_IWES-et al_Roadmap-Speicher_Langfassung.pdf. Accessed February 12, 2018.
- I.J. Perez-Arriaga and C. Batlle. Impacts of intermittent renewables on electricity generation system operation. *Economics of Energy & Environmental Policy*, 1(2): 3–17, 2012. doi: 10.5547/2160-5890.1.2.1.
- S. Pfenninger. Energy scientists must show their workings. *Nature*, 542(7642):393, 2017. doi: 10.1038/542393a.
- S. Pfenninger, A. Hawkes, and J. Keirstead. Energy systems modeling for twenty-first century energy challenges. *Renewable and Sustainable Energy Reviews*, 33: 74–86, 2014. doi: 10.1016/j.rser.2014.02.003.
- S. Pfenninger, L. Hirth, I. Schlecht, E. Schmid, F. Wiese, T. Brown, C. Davis, M. Gidden, H. Heinrichs, C. Heuberger, S. Hilpert, U. Krien, C. Matke, A. Nebel, R. Morrison, B. Müller, G. Plessmann, M. Reeg, J.C. Richstein, A. Shivakumar, I. Staffell, T. Tröndle, and C. Wingenbach. Opening the black box of energy modelling: Strategies and lessons learned. *Energy Strategy Reviews*, 19:63–71, 2018. doi: 10.1016/j.esr.2017.12.002. URL <http://www.sciencedirect.com/science/article/pii/S2211467X17300809>.
- B.D. Richardson. Electric vehicles and the electric grid: a review of modeling approaches, impacts, and renewable energy integration. *Renewable and Sustainable Energy Reviews*, 19:247–254, 2013. doi: 10.1016/j.rser.2012.11.042.
- H. Safaei and D.W. Keith. How much bulk energy storage is needed to decarbonize electricity? *Energy and Environmental Science*, 8(12):3409–3417, 2015. doi: 10.1039/C5EE01452B.
- S. Schiebahn, T. Grube, M. Robinius, V. Tietze, B. Kumar, and D. Stolten. Power to gas: Technological overview, systems analysis and economic assessment for a case study in Germany. *International Journal of Hydrogen Energy*, 40(12):4285–4294, 2015. doi: 10.1016/j.ijhydene.2015.01.123.

- W.-P. Schill. Residual load, renewable surplus generation and storage requirements in Germany. *Energy Policy*, 73:65–79, 2014. doi: 10.1016/j.enpol.2014.05.032.
- W.-P. Schill and A. Zerrahn. Long-run power storage requirements for high shares of renewables: results and sensitivities. *Renewable and Sustainable Energy Reviews*, 83:156–171, 2018. doi: 10.1016/j.rser.2017.05.205.
- W.-P. Schill, A. Zerrahn, and F. Kunz. Prosumage of solar electricity: pros, cons, and the system perspective. *Economics of Energy & Environmental Policy*, 6(1): 7–31, 2017. doi: 10.5547/2160-5890.6.1.wsch.
- O. Schmidt, A. Hawkes, A. Gambhir, and I. Staffell. The future cost of electrical energy storage based on experience rates. *Nature Energy*, 2:17110, 2017. doi: 10.1038/nenergy.2017.110.
- Y. Scholz, H.C. Gils, and R.C. Pietzcker. Application of a high-detail energy system model to derive power sector characteristics at high wind and solar shares. *Energy Economics*, 64:568–582, 2017. doi: 10.1016/j.eneco.2016.06.021.
- H.-W. Sinn. Buffering volatility: A study on the limits of Germany’s energy revolution. *European Economic Review*, 99:130–150, 2017. doi: 10.1016/j.euroecorev.2017.05.007.
- I. Staffell and S. Pfenninger. Using bias-corrected reanalysis to simulate current and future wind power output. *Energy*, 114:1224–1239, 2016. doi: 10.1016/j.energy.2016.08.068.
- Sustainable Energy Authority of Ireland (SEAI). Energy in Ireland 1990–2016, 2017. URL <https://www.seai.ie/resources/publications/Energy-in-Ireland-1990-2016-Full-report.pdf>. Accessed February 12, 2018.
- F. Ueckerdt, R. Pietzcker, Y. Scholz, D. Stetter, A. Giannousakis, and G. Luderer. Decarbonizing global power supply under region-specific consideration of challenges and options of integrating variable renewables in the REMIND model. *Energy Economics*, 64:665–684, 2017. doi: 10.1016/j.eneco.2016.05.012.

United Nations. Paris Agreement, 2015. URL http://unfccc.int/files/essential_background/convention/application/pdf/english_paris_agreement.pdf. Accessed November 5, 2017.

H. van de Vegte. Overview of potential locations for new pumped storage plants in EU 15, Switzerland and Norway. Deliverable D4.2 Final Report of the research project eSTORAGE within the seventh EU framework programme, 2015. URL http://www.estorage-project.eu/wp-content/uploads/2013/06/eStorage_D4.2-Overview-of-potential-locations-for-new-variable-PSP-in-Europe.pdf. Accessed February 12, 2018.

A. Zerrahn and W.-P. Schill. Long-run power storage requirements for high shares of renewables: review and a new model. *Renewable and Sustainable Energy Reviews*, 79:1518–1534, 2017. doi: 10.1016/j.rser.2016.11.098.

Appendix A. Literature review: power storage requirements

Figure A.1 illustrates the comparison between storage power (i.e. discharge) capacity requirements derived by Sinn (2017) and the literature. As Sinn (2017) does not explicitly mention any storage power capacities, we use the numbers from our replication of his calculations presented in Section 3. We also include our findings from the cost minimization approach. For comparability across studies, we normalize storage power capacities by dividing them by the system peak load. The system peak load arises in the hour with the highest demand. For Germany, it amounted to about 79 GW in 2014. As in the case of storage *energy*, the literature finds much lower storage *power* requirements than Sinn (2017).




Figure A.1: The literature finds much lower storage discharge power capacities than Sinn (2017).

Figures 1 and A.1 require information not explicitly provided in several of the underlying studies. We calculate or infer missing data. Further, we select the most relevant cases. In the following, we provide additional information:

- Budischak et al. (2013): Case with 2030 cost assumptions.
- Cebulla et al. (2017): Baseline; peak load is not provided, but inferred from the ratio between peak load and yearly demand from Scholz et al. (2017).

- de Sisternes et al. (2016): Scenarios without nuclear and with 10-hour storage; total yearly demand is not provided, but inferred from peak load using the ratio between peak load and yearly demand from Denholm and Hand (2011).
- Jacobson et al. (2015): Yearly demand taken from Table 2 (without storage losses).
- MacDonald et al. (2016): Scenario with low-cost renewables and high-cost natural gas; total yearly demand is not provided, but inferred from peak load using the ratio between peak load and yearly demand from Budischak et al. (2013).
- Pape et al. (2014): Only 2050 cases; variable renewable energy shares based on own estimations; peak load is not provided, but inferred from the ratio between peak load and yearly demand from Scholz et al. (2017).
- Safaei and Keith (2015): Derived from Table S3, case with no dispatchable zero-emission generation; total yearly demand is not provided, but inferred from peak load using the ratio between peak load and yearly demand from Denholm and Hand (2011).
- Schill (2014): Only 2032 cases.
- Schill and Zerrahn (2018): Results for baseline assumptions.
- Sinn (2017): Peak load and yearly demand as in present analysis.
- Scholz et al. (2017): Scenario with medium carbon price and equal shares of solar and wind.

Appendix B. Sensitivity: optimal storage for different base years

Figure B.1 shows the cost-minimal storage energy capacities when using different base years. Base years 2015 and 2016 deliver much lower optimal storage capacities than the other base years. Smoother patterns of residual load are an important factor driving this result.




Figure B.1: Cost-minimal storage capacities are highly sensitive toward the choice of the base year. Results also substantially differ from the calculations that do not take costs into account (compare Figure 3).

Appendix C. Power-to-x: sensitivity with respect to different configurations

Figure C.1 plots optimal storage energy capacities for different capacities and full-load hours of the generic *power-to-x* technology. Specifically, medium full-load hours between around 1,000 and 3,500 can trigger substantially lower storage needs. For lower full-load hours, *power-to-x* demand can largely be satisfied from renewable surpluses otherwise curtailed, so there is little or no effect on optimal storage capacity. For very high full-load hours, storage needs increase again. This is because of the increasing mismatch of the time profiles of additional *power-to-x* demand and renewable availability, which triggers dis-proportional renewable capacity expansion, and in turn increases renewable curtailment and the optimal amount of electrical storage.




Figure C.1: Storage requirements for different *power-to-x* settings for 70% variable renewables. The impact of additional flexible power-to-x demand on electrical storage requirements is largest between 1500 and 2000 full-load hours.