

S/S Inc./220KV S.S./JLN No./ 59

at 14/2/07

To

M/s Bhagyalaxmi Steel alloy Pvt Ltd.
New MIDC Talana.

Subj:- Information regarding power cut on
Monday

Sir

Pt. find enclosed h/w required information
of power cut on Monday from Oct 06 to Jan. 07
Submitted for your information P.
Thanking you.

Enclod 2.A.

Yours



Dy Ex. Engineer
220 KV Sub Station
JALNA.

Ref. :


Cn. S. P. Transmission Co. Ltd.

Date :-

220 kv. sub. station, Jalna.

Interruption of 33 kv. Bhagya Lakshmi Feeds, on 10 Oct. 06 to Jan. 07

Date	Tripping Time	Charging Time	Duration	
2.10.06	6.00	22.0	16.00	Strag. day. 2/5
9.10.06	6.00	22.0	16.00	— do —
16.10.06	6.00	22.0	16.0	— do —
26.10.06	19.15	19.20	0.05	Tripping
— do —	19.20	19.28	0.08	— do —
1.11.06	5.15	5.20	0.05	Tripping
1.11.06	6.00	11.03	5.03	Strag. day. 4/5.
19.06	12.05	12.13	0.12	Load change over on 25 MVA Tr. due 2P. on 25 MVA Tr.
10-	18.20	18.25	0.05	— do — 50 MVA on 25 MVA Tr.
25.12.06	25.11.25	14.30	3.05	Maintenance. Strag. day outage.
1.1.07	12.05	12.35	0.30	LP Issued to Mr. Sepati S. P. Emergency work.
24.1.07	6.30	6.40	0.10	Tripping
29.1.07	11.00	15.45	4.45	Maintenance of 25 220/33 kv. 25 MVA Tr.
31.1.07	22.05	22.10	0.05	Tripping.


Dy Ex. Engineer
220 KV Sub Station
JALNA.