

Start

Mist Collector turned ON
from main operation panel (Function
Screen).

DO: MS19 0→1

Electromagnetic contactor MS19 closes.

Mist Collector starts.

Stop

Mist Collector turned OFF
from main operation panel (Function
Screen).

DO: MS19 1→0

Electromagnetic contactor MS19 opens.

Mist Collector stops.