

## Start

## Stop

Mist collector turned On  
from main operation panel (Function  
Screen).

DO: MS19 0→1

Electromagnetic contactor MS19 closes.

Mist Collector starts.

Mist collector turned Off  
from main operation panel (Function  
Screen).

DO: MS19 1→0

Electromagnetic contactor MS19 opens.

Mist Collector stops.