

Annexure 1
DEPARTMENT OF LABOUR
OCCUPATION HEALTHY AND SAFETY ACT, 1993
CERTIFICATE OF COMPLIANCE



GENERAL ELECTRICAL INSTALLATION
CERTIFICATE OF COMPLIANCE

Certificate of compliance in accordance with regulation 7(1) of the Electrical Installation Regulations, 2009.

CERTIFICATE NO.

NM 755822

Certificate type (tick appropriate block)

Initial Certificate ☒ Supplementary Certificate ☐

Supplement No.: N/A to Initial Certificate No.: N/A as issued on: N/A

Identification of the relevant electrical installation

(Address or other unique reference, where applicable)

Physical address: Plot 465 Kromdraai

Name of building: _____ GPS Coordinates: _____

Suburb / Township: Kromdraai Pole number: _____

District / Town / City: Mabazimbi Erf / Lot No: _____

Declaration by registered person

I, Chris Mukuwa (ID No.: 8707235153080)

a registered person, declare that I have personally carried out the inspection and testing of the electrical installation described in the attached test report as per the requirements of:

(Tick appropriate box)

- a) electrical installation regulations 9(2) (a) (new electrical installation); or ☒
- b) electrical installation regulations 9(2) (b) (existing electrical installation); or ☐
- c) electrical installation regulations 9(2) (c) (new part to existing installation) ☐

and deem the installation to be reasonably safe when properly used.

I have entered the number of this Certificate on the attached test report(s).

I declare that the persons responsible for the design, specification, procurement, construction commissioning and inspection and test have completed the relevant sections of the test report.

Registered person registration number: EF13882 Date of registration: Feb-2022

Type of registration: (Tick appropriate box)

Electrical tester for single phase ☐ Installation electrician ☒ Master installation electrician ☐

Signature: Royel Date: 30-11-2023

Contact details of registered person:

Address: 39 Doodts Street Roslyn N/A

Tel. No.: _____ Fax No.: _____

Cell No.: 078 619 0334 Email: N/A

- NOTE**
- This Certificate is not valid unless all the sections have been completed correctly and the test report in the format approved by the chief inspector is attached.
 - This Certificate will be invalid if any corrections have been made.

Declaration by electrical contractor

I, Chris Mukuwa (ID No.: 8707235153080)

declare that the electrical installation has been carried out in accordance with the requirements of the Occupational Health and Safety Act, 1993, and regulations made thereunder.

Electrical contractor registration number: CN002766 Date of registration: Feb-2022

Signature: Royel

Contact details of electrical contractor: Name: Royal Africa Multifacient Service

Address: 103 Inkongane Street Meadowlands Zone 7

Tel. No.: 081 773 0317 Fax No.: _____

Cell No.: _____ Email: africanmultifacient@gnail

Recipient name: Robert Gerry Signature: [Signature] Date: 30/11/2023

010 271 0688 043 726 6359
012 342 3242 041 363 1990
031 312 6313 021 462 2690
051 447 0859 011 392 0000

TEST REPORT
for ELECTRICAL INSTALLATIONS
(To SANS 10142-1)

Certificate of
Compliance (CoC) No.:

Date of issue: 30-11-2023

Test Report for DB/ Supply: 230V

Additional pages added: ☐ Yes Number added: ☐ No

NOTE 1 In terms of South African legislation, the user or lessor is responsible for the safety of the electrical installation

NOTE 2 This report covers only the part of the installation described in section 3.

NOTE 3 This report covers the circuits for fixed appliances, but does not cover the actual appliance, for example stoves, geysers, air conditioning and refrigeration plant and lights.

NOTE 4 Medical and hazardous locations require additional test reports (see 8.7).

NOTE 5 Enter the required information or tick the appropriate block.

SECTION 1 - LOCATION (Only required if not provided on Certificate of compliance)

Physical address:

Name of building:

SECTION 2 - INSTALLATION

☒ Permanent installation

☐ Temporary installation

Type of electricity supply system:

☒ TN-S

☐ TN-C-S

☐ TN-C

☐ TT

☐ IT

Characteristics of supply:

Voltage:

☒ 230 V

☐ 400 V

☐ 525 V

☐ Other

Number of phases:

☒ One

☐ Two

☐ Three

Phase rotation:

☐ Clockwise

☐ Anticlockwise

Frequency:

☒ 50 Hz

☐ Other

☐ d.c.

Main switch type:

☐ Switch disconnector (on-load isolator)

☐ Fuse switch

☐ Circuit-breaker

☒ Earth leakage circuit-breaker

☐ Earth leakage switch disconnector

Number of poles:

Current rating: 63 A

A Short-circuit/withstand rating: 3 kA

Rated earth leakage tripping current

☒ 30 mA

☐ Other

Is surge protection installed (see 6.7.6 and annex I):

☒ Yes

☐ No

Is lightning protection installed (see 6.7.7 and annex I):

☐ Yes

☒ No

Is alternative power supply installed? (See 7.1.2)

☐ Yes

☒ No

Is any part of the installation a specialized electrical installation?

☐ Yes

☒ No

Is any part of the installation at a voltage above 1 kV?

☐ Yes

☒ No

If yes, complete additional test reports (see 8.7)

SECTION 3 - DESCRIPTION OF INSTALLATION COVERED BY THIS REPORT (Add additional pages, specification references or drawings, etc., where applicable)

x 2 8000w inverters (RCT) x 37 12V Acid Batteries 60 panels (540w)

Number of circuits or points	New	Existing	Number of circuits or points	New	Existing
Lighting circuits			Fan circuits		
Lighting points			Fixed appliance circuits		
Socket-outlet circuits			Other		
Socket-outlets			Other		
Air-conditioning circuits			Other		
Transformer circuits:			Other		
Heating circuits			Other		
Alternative power supply connections			Other		
Other circuits or points			Other		

SECTION 4 - INSPECTION AND TESTS (new and existing installations)

Mark as appropriate

	Yes	No	NA
1. Conductors are of the correct rating and current carrying capacity for the protective devices and connected load	☒	☐	☐
2. Components have been correctly selected and installed	☒	☐	☐
3. Disconnecting devices are correctly located and all switchgear switches the phase conductors	☒	☐	☐
4. Circuits, fuses, switches, terminals, earth leakage units, circuit-breakers, distribution boards are correctly and permanently marked or labelled	☒	☐	☐

Tests	Units	Reading/result
1. Continuity of bonding	-	Compliant
2. Resistance of earth continuity conductor at all points of consumption	-	Compliant
3. Continuity of ring circuits (if applicable)	-	Compliant
4. Earth loop impedance test at main or local switch	Ω	0.5
5. Neutral loop impedance test: at main or local switch	Ω	0.9
6. Prospective short-circuit current at main or local switch (PSCC)	kA	0.31 kA ☐ Calculated ☐ Measured
7. Elevated voltage between incoming neutral and external earth (ground)	V	0.7
8. Insulation resistance	MΩ	23R7
9. Voltage at distribution board with no load for each phase to neutral	V	23R0
10. Voltage at distribution board with load (as calculated for full load) for each phase to neutral	V	25
11. Value of operation of earth leakage units	mA	correct
12. Operation of earth leakage test button	-	correct
13. Polarity of points of consumption	-	correct
14. Phase rotation is consistent at points all of consumption for three-phase systems	-	correct
15. All switching devices, make-and-break circuits	-	correct

Comments:

Comments on parts of the installation not covered by this report:

SECTION 5 RESPONSIBILITY - INSPECTION AND TESTS

I, being the person responsible for the INSPECTION AND TESTING of the electrical installation, particulars of which are described in section 3 of this form, CERTIFY that the inspection and testing are done in accordance with this part of SANS 10142, that the results obtained and reflected on this report are correct, and indicate The extent of liability of the signatory is limited to the installation described in section 3 of this form.

Name of registered person: Chris Mankwena

Registration Certificate no.: IF 13662

Type of registration: ☐ Master installation electrician

☒ Installation electrician

☐ Single-phase tester

Signature: [Signature]

Date: 30-11-2023

Tel no.: N/A