

Certificate

Extended Step - Drawdown Yield & Recovery Test
(IN COMPLIANCE WITH SANS 10299-4:2003)

DATE: 15 APRIL 2019
CLIENT: SAUTECH PROPERTIES - MR HC VAN JAARSVELD
REGISTERED ADDRESS: PORTION 465 OF THE FARM KROMDRAAI KQ560
BOREHOLE DEPTH: 80 M (EIGHT ZERO) FROM MOUTH
STATIC WATER TABLE: 15 M (ONE FIVE) FROM MOUTH
TEST METHOD: STEP DRAWDOWN DOMESTIC
TEST DEPTH: 75 M (SEVEN FIVE) FROM MOUTH CONSTANT
TEST INTERVALS: 15 (ONE FIVE) MINUTES
SUSTAINABILITY TEST: 3998L (THREE NINE NINE EIGHT) PER HOUR CONSTANT OVER 8 HOUR TESTING PERIOD
VERIFIED YIELD POTENTIAL: 80% THUS APPROXIMATELY 3198L PER HOUR



WP410062L

TEST CONDUCTED BY: ADRI TALJAARD

BOREHOLE WATER
ASSOCIATION OF
SOUTHERN AFRICA



BOORGAT WATER
ASSOSIASIE VAN
SUIDELIKE AFRICA