2022 CALGreen CHECKLIST - **RESIDENTIAL - NEW**

(MANDATORY MEASURES + TIER 1)

FREE ACCESS TO CALIFORNIA CODES: https://www.dgs.ca.gov/BSC/Codes#@ViewBag.JumpTo

City of SANTA ROSA
Planning & Economic Development - Building Division
PAGE 1 of 22
EFFECTIVE: 01 JANUARY 2023

Applies to building permit applications received on or after January 1, 2023, for newly constructed hotels, motels, lodging houses, dwellings, dormitories, condominiums, shelters, congregate residences, employee housing, factory-built housing, and other types of dwellings containing sleeping accommodations with or without common toilet or cooking facilities including accessory buildings, facilities and uses thereto. Detached "U" occupancy buildings are not subject to the requirements of CALGreen. For residential additions or alterations that increase conditioned space, see separate checklist. Repairs to existing structures are not subject to CALGreen at this time.

PROJECT ADDRESS: 3111 Santa Rosa Ave, Santa Rosa CA 95407

PROJECT NAME: Avenue 3111 Apartments

PROJECT DESCRIPTION: New construction

BUILDING PERMIT NUMBER: _____

INSTRUCTIONS:

The Owner (or the Owner's agent) shall employ a *qualified CALGreen Inspector, listed by the City of Santa Rosa Building Division, to complete this checklist via the following steps:

1. The CALGreen Inspector, in collaboration with the owner and the design professional, shall complete Column 2 of this checklist. Either "required" or "not required" is to be selected for each feature/measure. If "required" is selected, a description and reference to the plan sheet where the item is specified should be provided. If "not required" is selected, a description of why the feature/measure does not apply shall be provided. **Sections not separated by horizontal lines are all related to the relative checkboxes in that non-separated box.** See CALGreen Chapter 4 and Appendix A4 for complete descriptions of features and measures listed below. A specific number of Tier 1 electives is required for each general Tier 1 Elective Section. See CALGreen Section A4.601 for Tier 1 scoping.
2. When Column 2 is complete, the Owner, Design Professional, and CALGreen Inspector are to be identified on, sign, and date the CALGreen Building Acknowledgements Section 1 (Design Verification) at the end of this checklist. The completed checklist is then to be submitted to the City of Santa Rosa Building Division as part of the building permit application.
3. Building Division plan review staff will provide a fourth review of the plans and Column 2 (first three by Owner, Design Professional, and CALGreen Inspector as stated above). When approvable, the approved checklist will be included as part of the approved job set that is to be kept on the construction site throughout construction.
4. The CALGreen Inspector is to inspect all applicable features/measures listed in Column 2, and mark the verification boxes In Column 3 as each feature/measure is completed.
5. Prior to final inspection by the Building Division, the CALGreen Inspector shall verify that all applicable features/measures have been installed, and sign and date the CALGreen Building Acknowledgments Section 2 (Implementation Verification) found at the end of this checklist.

***NOTE:** The CALGreen Inspector shall not be the design professional or contractor for the project, and shall not have a financial interest in the project for which services are being provided (except for the cost of providing said services.) If you are a qualified CALGreen Inspector, but have not been added to the approved City list, please contact the Building Division via email at building@srcity.org

COLUMN 1: FEATURE OR MEASURE	**COLUMN 2:** PROJECT DESIGN REQUIREMENTS		**COLUMN 3:** FIELD VERIFICATION
PAGE 2 of 22 EFFECTIVE: 01 JANUARY 2023	MANDATORY MEASURES & TIER 1 PREREQUISITES	TIER 1 ELECTIVES	
CALGreen **DIVISIONS 4.1 & A4.1:** PLANNING AND DESIGN	ALL ITEMS ARE REQUIRED UNLESS OTHERWISE JUSTIFIED	SELECT AT LEAST **TWO** ELECTIVE MEASURES FROM A4.1	SELECT ALL MEASURES VERIFIED IN THE COMPLETED PROJECT
Site Selection			
A4.103.1 Select a site which complies with at least one of the following characteristics (support documentation required at application submittal): 1. An infill site. 2. A greyfield site. 3. An EPA-recognized and remediated brownfield site.		☒	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): Existing site verified via Google Earth			
A4.103.2 Facilitate community connectivity by one of the following methods: 1. Locate the project within a 1/4-mile true walking distance of at least four basic services. 2. Locate the project within 1/2-mile true walking distance of at least seven basic services. 3. Other methods increasing access to additional resources.		☒	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): 1. park 2. Vet Hospital 3. Autoshop 4. E-waste Facility			
Site Preservation			
A4.104.1 Individuals with oversight authority on the project who have been trained in areas related to environmentally friendly development can teach green concepts to other members of the development staff and ensure that training is provided to all parties associated with the project. Prior to beginning the construction activities, all parties involved with the development process shall receive a written guideline and instruction specifying the green goals of the project.		☐	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A):			
Deconstruction and Reuse of Existing Materials			
A4.105.1 and A4.105.2 Existing buildings on the site are deconstructed, and the salvaged materials (which must comply with current building standards) are reused. Materials which can be easily reused include, but are not limited to, the following (verify at least one): 1. Light fixtures 2. Plumbing fixtures 3. Doors and trim 4. Masonry 5. Electrical devices 6. Appliances 7. Foundations or portions of foundations		☐	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A):			

COLUMN 1: FEATURE OR MEASURE	**COLUMN 2:** PROJECT DESIGN REQUIREMENTS		**COLUMN 3:** FIELD VERIFICATION
PAGE 3 of 22 EFFECTIVE: 01 JANUARY 2023	MANDATORY MEASURES & TIER 1 PREREQUISITES	TIER 1 ELECTIVES	
Site Development			
4.106.2 Storm water drainage and retention during construction. Newly constructed projects which disturb less than one acre of land shall prevent the pollution of storm water runoff from the construction activities by complying with lawfully enacted storm water management and/or erosion control ordinances. See Santa Rosa City Code Chapter 17-12.	☒ RQD ☐ N/A		☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): Projects that disturb < 1 acre of soil must manage stormwater			
A4.106.2 The soils at the building site are analyzed and protected as specified in this section. **A4.106.2.1 Soil analysis.** Soil analysis is performed by a licensed design professional and the findings utilized in the structural design of the building. Support documentation is required at application submittal. **A4.106.2.2 Soil protection.** The effect of development on the building sites is evaluated and the soil is protected by one or more of the following: 1. Natural drainage evaluation and erosion controls implemented to minimize erosion. 2. Site access is accomplished by minimizing the amount of cut and fill to install access roads/driveways. 3. Underground construction activities are coordinated to utilize the same trench, minimize disturbed soil, and soil is replaced using accepted compaction methods.		☒	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): Elective A4.106.2.2 selected for this section.			
A4.106.2.3 Displaced topsoil is stockpiled for reuse in designated area and covered or protected from erosion. (Tier 1 Prerequisite)	☒ RQD ☐ N/A		☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): GC to designate Area			
4.106.3 Construction plans shall indicate how site grading or a drainage system will manage all surface water flows to keep water from entering buildings.	☒ RQD ☐ N/A		☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A): See Grading & Utility Plan			
A4.106.3 Landscape design. Post construction landscape designs accomplish one or more of the following: 1. Areas disrupted during construction are restored to be consistent with native vegetation 2. Utilize at least 75 percent native Californian or drought tolerant plant and tree species appropriate for the climate zone region.		☐	☐
Sheet number and description of proposed measure(s) or explanation of why it is not applicable (N/A):			

COLUMN 1: FEATURE OR MEASURE	**COLUMN 2:** PROJECT DESIGN REQUIREMENTS		**COLUMN 3:** FIELD VERIFICATION
PAGE 4 of 22 EFFECTIVE: 01 JANUARY 2023	MANDATORY MEASURES & TIER 1 PREREQUISITES	TIER 1 ELECTIVES	
4.106.4 New construction shall comply with Section **4.106.4.1** (One and two-family dwellings and town-houses with attached private garages) or **4.106.4.2** (multi-family dwellings, hotels, motels, and new residential parking facilities) to facilitate future installation and use of EV chargers. Electric vehicle supply equipment (EVSE) shall be installed in accordance with the California Electrical Code, Article 625. **Exceptions to Section 4.106.4:** 1. On a case-by-case basis, where the local enforcing agency has determined EV charging and infrastructure are not feasible based upon one or more of the following conditions: 1.1 Where there is no local utility power supply or the local utility is unable to supply adequate power. 1.2 Where there is evidence suitable to the local enforcing agency substantiating that additional local utility infrastructure design requirements, directly related to the implementation of Section **4.106.4**, may adversely impact the construction cost of the project. 2. Accessory Dwelling Units (ADU) and Junior Accessory Dwelling Units (JADU) without additional parking facilities. **4.106.4.1 New one- and two-family dwellings and town-houses with attached private garages.** For each dwelling unit, install a listed raceway to accommodate a dedicated 208/240-volt branch circuit. The raceway shall not be less than trade size 1 (nominal 1-inch inside diameter). The raceway shall originate at the main service or subpanel and shall terminate into a listed cabinet, box, or other enclosure in close proximity to the proposed location of an EV charger. Raceways are required to be continuous at enclosed, inaccessible, or concealed areas and spaces. The service panel and/or subpanel shall provide capacity to install a 40-ampere 208/240-volt minimum dedicated branch circuit and space(s) reserved to permit installation of a branch circuit overcurrent protective device. **Exception to 4.106.4.1:** A raceway is not required if a minimum 40-ampere 208/240-volt dedicated EV branch circuit is installed in close proximity to the proposed location of an EV charger at the time of original construction in accordance with the California Electrical Code. **4.106.4.1.1 Identification.** The service panel or subpanel circuit directory shall identify the overcurrent protective device space(s) reserved for future EV charging as "EV CAPABLE". The raceway termination location shall be permanently and visibly marked as "EV CAPABLE". **4.106.4.2 New multifamily dwellings, hotels, motels, and new residential parking facilities.** When parking is provided, parking spaces for new multifamily dwellings, hotels, and motels shall meet the requirements of Sections **4.106.4.2.1** and **4.106.4.2.2**. Calculations for spaces shall be rounded up to the nearest whole number. A parking space served by electric vehicle supply equipment or designed as a future EV charging space shall count as at least one standard automobile parking space only for the purpose of complying with any applicable minimum parking space requirements established by a local jurisdiction. See Vehicle Code Section 22511.2 for further details. **4.106.4.2.1 Multifamily development projects with less than 20 dwelling units; and hotels and motels with less than 20 sleeping units or guest rooms.** The number of dwelling units, sleeping units, or guest rooms shall be based on all buildings on a project site subject to this section.	☒ RQD ☐ N/A		☐

COLUMN 1: FEATURE OR MEASURE	**COLUMN 2:** PROJECT DESIGN REQUIREMENTS		**COLUMN 3:** FIELD VERIFICATION
5 PAGE 5 of 22 EFFECTIVE: 01 JANUARY 2023	MANDATORY MEASURES & TIER 1 PREREQUISITES	TIER 1 ELECTIVES	
4.106.4.2.1(1) EV Capable. 10% of the total number of parking spaces on a building site, provided for all types of parking facilities, shall be electric vehicle charging spaces (EV spaces) capable of supporting future Level 2 EVSE. Electrical load calculations shall demonstrate that the electrical panel service capacity and electrical system, including any on-site distribution transformer(s), have sufficient capacity to simultaneously charge all EVs at all required EV spaces at a minimum of 40 amperes. The service panel or subpanel circuit directory shall identify the overcurrent protective device space(s) reserved for future EV charging purposes as "EV CAPABLE" in accordance with the California Electrical Code. **Exceptions to 4.106.4.2.1(1):** 1. When EV chargers (Level 2 EVSE) are installed in a number equal to or greater than the required number of EV capable spaces. 2. When EV chargers (Level 2 EVSE) are installed in a number less than the required number of EV capable spaces, the number of EV capable spaces required may be reduced by a number equal to the number of EV chargers installed. **Notes:** a. Construction documents are intended to demonstrate the project's capability and capacity for facilitating future EV charging. b. There is no requirement for EV spaces to be constructed or available until receptacles for EV charging or EV chargers are installed for use. **4.106.4.2.1(2) EV Ready.** 25% of the total number of parking spaces shall be equipped with low power Level 2 EV charging receptacles. For multifamily parking facilities, no more than one receptacle is required per dwelling unit when more than one parking space is provided for use by a single dwelling unit. **Exception to 4.106.4.2.1(2):** Areas of parking facilities served by parking lifts. **4.106.4.2.2 Multifamily development projects with 20 or more dwelling units, hotels, and motels with 20 or more sleeping units or guest rooms.** The number of dwelling units, sleeping units, or guest rooms shall be based on all buildings on a project site subject to this section. **4.106.4.2.2(1) EV Capable.** 10% of the total number of parking spaces on a building site, provided for all types of parking facilities, shall be electric vehicle charging spaces (EV spaces) capable of supporting future Level 2 EVSE. Electrical load calculations shall demonstrate that the electrical panel service capacity and electrical system, including any on-site distribution transformer(s), have sufficient capacity to simultaneously charge all EVs at all required EV spaces at a minimum of 40 amperes. The service panel or subpanel circuit directory shall identify the overcurrent protective device space(s) reserved for future EV charging purposes as "EV CAPABLE" in accordance with the California Electrical Code. **Exception to 4.106.4.2.2(1):** When EV chargers (Level 2 EVSE) are installed in a number greater than 5% of parking spaces required by Section **4.106.4.2.2(3)**, the number of EV capable spaces required may be reduced by a number equal to the number of EV chargers installed over the 5% required.			

COLUMN 1: FEATURE OR MEASURE	**COLUMN 2:** PROJECT DESIGN REQUIREMENTS		**COLUMN 3:** FIELD VERIFICATION
6 PAGE 6 of 22 EFFECTIVE: 01 JANUARY 2023	MANDATORY MEASURES & TIER 1 PREREQUISITES	TIER 1 ELECTIVES	
Notes to 4.106.4.2.2(1): a. Construction documents shall show locations of future EV spaces. b. There is no requirement for EV spaces to be constructed or available until receptacles for EV charging or EV chargers are installed for use. **4.106.4.2.2(2) EV Ready.** 25% of the total number of parking spaces shall be equipped with low power Level 2 EV charging receptacles. For multifamily parking facilities, no more than one receptacle is required per dwelling unit when more than one parking space is provided for use by a single dwelling unit. **Exception to 4.106.4.2.2(2):** Areas of parking facilities served by parking lifts. **4.106.4.2.2(3) EV Chargers.** 5% of the total number of parking spaces shall be equipped with Level 2 EVSE. Where common use parking is provided, at least one EV charger shall be located in the common use parking area, and shall be available for use by all residents or guests. When low power Level 2 EV charging receptacles or Level 2 EVSE are installed beyond the minimum required, an automatic load management system (ALMS) may be used to reduce the maximum required electrical capacity to each space served by the ALMS. The electrical system and any on-site distribution transformers shall have sufficient capacity to deliver at least 3.3 kW simultaneously to each EV charging station (EVCS) served bye the ALMS. The branch circuit shall have a minimum capacity of 40 amperes, and installed EVSE shall have a capacity of not less than 30 amperes. ALMS shall not be used to reduce the minimum required electrical capacity to the required EV capable spaces. **4.106.4.2.2.1 Electric vehicle charging stations (EVCS).** Electric vehicle charging stations require by Section **4.106.4.2.2(3)** shall comply with Section **4.106.4.2.2.1**. **Exception to 4.106.4.2.2.1:** Electric vehicle charging stations serving public accomodations, public housing, motels, and hotels shall not be required to comply with this section. See California Building Code, Chapter 11B, for applicable requirements. **4.106.4.2.2.1.1 Location.** EVCS shall comply with at least one of the following options: 1. The charging space shall be located adjacent to an accessible parking space meeting the requirements of the California Building Code, Chapter 11A, to allow use of the EV charger from the accessible parking space. 2. The charging space shall be located on an accessible route, as defined in the California Building Code, Chapter 2 to the building. **Exception:** Electric vehicle charging stations designed and constructed in compliance with the California Building Code, Chapter 11B, are not required to comply with Section **4.106.4.2.2.1.1**. **4.106.4.2.2.1.2 Electric vehicle charging stations (EVCS) dimensions.** 1. The minimum length of each EV space shall be 18 feet. 2. The minimum width of each EV space shall be 9 feet. 3. One in every 25 charging spaces, but not less than one, shall also have an 8-foot wide minimum aisle. A 5-foot wide minimum aisle shall be permitted provided the minimum width of the EV space is 12 feet. 4. Surface slope for this EV space and the aisle shall not exceed 1 unit vertical in 48 units horizontal (2.083% slope) in any direction.			

TIERNEY / FIGUEIREDO
TFA ARCHITECTS AIA
817 Russell Ave., Suite H Santa Rosa, CA 95403 707.576.1557 info@tfarch.com

REV	DATE / MEMO	BY

LICENSED ARCHITECT
RANDY FIGUEIREDO
REN 11-30-25
STATE OF CALIFORNIA

These drawings & designs are the property of the Architect and no part thereof shall be copied or used in connection with any other work or project without the written consent of Tierney/Figueiredo Architects.

CALGREEN CHECKLIST - RESIDENTIAL

AVENUE 3111 APARTMENTS
3111 Santa Rosa Avenue
Santa Rosa, CA 95407

TFA Project #:	1725A
Date:	6/25/2023
Scale:	AS NOTED
Drawn by:	AB
Checked by:	RF
CAD File:	See left hand margin

Sheet #:
CG.6
Total Sheets in Set:

Date: Jun 25, 2023 - 6:56pm Filename: S:\1725A_3111 Santa Rosa Ave Apartments\CD\Latest\1725A_CG.X Cal Green Checklist.dwg Updated by: katie