

IHI SENSOR REPORT

Bao cao cam bien nha may

Thoi gian: 2026-06-20 08:00 - 17:00

Nha may: IHI Factory Ha Noi

Loai cam bien: Vibration + Temperature + Pressure

Du lieu do:

1. May nen khi (Air Compressor 1)

- Vibration RMS: 4.2 mm/s (binh thuong: <4.5)
- Nhiet do vong bi: 68 do C (canh bao: >75)
- Ap suat dau: 6.2 bar (dinh muc: 5.5-6.5)
- Danh gia: BINH THUONG

2. Quat hut (Exhaust Fan 3)

- Vibration RMS: 7.8 mm/s (canh bao: >6.5)
- Nhiet do motor: 92 do C (canh bao: >85)
- Ap suat hut: -120 Pa (binh thuong: -100 den -150)
- Danh gia: CANH BAO - can kiem tra canh quat

3. May bom (Pump 2)

- Vibration RMS: 3.1 mm/s (binh thuong)
- Nhiet do: 55 do C
- Luu luong: 120 m³/h (dinh muc: 100-130)
- Danh gia: BINH THUONG

Bang tom tat:

| Thiet bi | Trang thai | Xu ly |

|---|---|---|

| Air Compressor 1 | OK | Khong |

| Exhaust Fan 3 | WARNING | Kiem tra canh quat trong 24h |

| Pump 2 | OK | Khong |

De xuat: Lap lich bao tri Exhaust Fan 3 trong tuan nay. Theo doi nhiet do motor moi 4 gio.