



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no.	: NL09-400-1002-061-04	Revision no.:	6
Description of the product	: Door locking device with hook for horizontal power operated sliding doors. Both central and side opening		
Trademark	: Merih		
Type no.	: KLT 003		
Name and address of the manufacturer	: Merih Asansör Sanayi ve Ticaret A.Ş. Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Temelli Sincan, Ankara, Türkiye		
Name and address of the certificate holder	: Merih Asansör Sanayi ve Ticaret A.Ş. Başkent OSB, Recep Tayyip Erdoğan Bulvarı, No:8, Temelli Sincan, Ankara, Türkiye		
Certificate issued on the following requirements	: Lifts Directive 2014/33/EU		
Certificate based on the following standard	: EN81-1/2:1998+A3:2009, EN81-20:2020, EN81-50:2020		
Test laboratory	: None		
Date and number of the laboratory report	: None		
Date of EU-type examination	: March 2009, September 2009, April-July 2010, December 2011, April – October 2016, December 2021		
Additional document with this certificate	: Report belonging to the EU- type examination certificate no.: NL09-400-1002-061-04 rev.6		
Additional remarks	: This revision replaces certificate NL09-400-1002-061-04 rev. 5 of 18-11-2016 Max. rated voltage 230 VAC Max. rated current 0,5A/1,0A Max. door height 2600 mm Door width 700 - 1300 mm Furthermore see chapter 5 of the report belonging to this EU type examination certificate.		
Conclusion	: The safety component meets the requirements of the Lifts Directive 2014/33/EU taking into account any additional remarks mentioned above.		

Amsterdam

Date : 10-12-2021
Valid until : 10-12-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by