



## FA TESTING/INSPECTION PUNCH LIST

If batteries are defective, replace for current customers. For new customers, request approval. Any defects such as SD, WF, MP need approval.

Customer/Property Name: \_\_\_\_\_ Date: \_\_\_\_\_

	Yes	No
1. Is panel free of troubles? If no, <i>DO NOT TEST</i> .		
2. Are there panel instructions within 3 ft. of panel?		
3. Is there a sequence of operation?		
4. Check manufactured date of battery. <span style="float: right;">Date: _____</span>		
5. Is there a lock on breaker?		
Is breaker location labeled on panel?		
6. Is there a FACP sign?		
7. Have you tested ITV and recorded duration of time for activations?		
If less than 20 seconds WT/WF, needs adjusting. If over 90 seconds check WT/WF If over 60 seconds in LA City for electric flow switch (vane-type)		
8. Have all other devices been tested?		
<div style="display: flex; justify-content: space-between;"><div><div>_____ Smoke</div><div>_____ Pull</div><div>_____ WF</div><div>_____ Tamper</div><div>_____ Bells</div></div><div><div>_____ Duct detector</div><div>_____ Beam detector</div><div>_____ Horn</div><div>_____ Horn strobes</div><div>_____ Speakers</div></div></div>		
9. Any test defects?		
10. Code violation – missing coverage		

Name: \_\_\_\_\_

Signature: \_\_\_\_\_