

TRENCH EDGE
SHALL BE A MINIMUM
OF 5' FROM ALL PROPERTY
LINES.

USE PIPE LENGTH = 300 L.F.

LOSS = 3.5' @ 30 GPM

HEAD = 3.5' + 11.7' + 2' MISC.
= 17.2'

USE HYDROMATIC
OSP33 SEE AMP
CURVE, PUMP CONTROLS
AND ALARM SYSTEM
SHALL BE ENJO 474
OR EQUAL SET
DOSE = 450 GAL

LINES SHALL BE
ED ACCORDING TO
E WATER, CO
205 OR PIERCE

HEALTH DEPT. STANDARDS,

ES TO BE PLACED 18" ABOVE
LINE AND DOUBLE SLEEVED.

ALL SEWER LINES
AND PRESSURE LINES
SHALL BE CAUTIONED
WHEN UNDER DRIVEWAYS.



SITE PLAN
SCALE 1"=30'

STUB INLET = VARIOUS

W/ INLET = VARIOUS } SHALL COMPLY WITH HEALTH DEPT. STANDARDS

INLET = 98.20

E.I. = 94.10

ELEV. = 105.50

LEV. = 105.80

ALL WORK SHALL BE IN ACCORDANCE
WITH HEALTH DEPARTMENT STANDARDS.

16306 118TH AV. C.T.E.

16307 118TH AV. C.T.E.

System M