

1 Architectural requirements

1.1 Office rooms shall provide at least 12 m² of usable floor area.

1.2 Doors must provide a clear width of 0.85 m.

Fluchtwege muss jederzeit frei bleiben und darf nicht verstellt werden.

Element	Requirement
Corridor	Corridors shall remain free of storage.

