



Overview				Site
Inspect N	63929	Page:	1/1	GREENFORD IND TETRIS A40 ROCKWARE AVENUE GREENFORD UB6 0AA
Job No	14875			
Customer	AECOM			
Contact	Muhammed Basathia	Date	22/05/2024	
Tel				

Pass

ISI Equipment No	Make / Model	Serial No	Client ID
20052024005	Door Powered Vertical	Stokvis 0007819	609340

Asset Photograph

Capture photograph of Asset, including asset number	See Photo 1
-----------------------------------------------------	-------------

Hazard Priority and Findings

Intolerable - Defects requiring immediate action	None
Substantial - Defects requiring attention within a time period	None
Moderate - Other defects requiring attention	None
Tolerable - Observations	None



General Comments

None

Engineer

Neil Wheeler