



Overview				Site	
Inspect N	63915	Page:	1/1	GREENFORD IND	
Job No	14875			TETRIS A40 ROCKWARE AVENUE	
Customer	AECOM			GREENFORD	
Contact	Muhammed Basathia	Date	22/05/2024	UB6 0AA	
Tel					

Pass

ISI Equipment No	Make / Model	Serial No	Client ID
20052024017	Door Powered Vertical	AGS DOORS (48332)	609323

Asset Photograph

Capture photograph of Asset, including asset number	See Photo 1
---	-------------

Hazard Priority and Findings

Intolerable - Defects requiring immediate action	None
Substantial - Defects requiring attention within a time period	None
Moderate - Other defects requiring attention	None
Tolerable - Observations	None



General Comments

None

Engineer

John Harding