

Master Preventive Maintenance Schedule

Consolidated service intervals across critical rotating equipment

Field	Value
Document No.	MSCH-MASTER-0001
Revision	Rev 3.1
Equipment OEM	(synthetic OEM)
Applicable standard	ISO 10816 / IEC / CEA norms
Classification	O&M reference - SYNTHETIC (Ballast demo)
Owner	Plant O&M / Reliability

Disclaimer: This is a synthetic document generated for the Ballast demo. Values are grounded in public standards and typical industry practice but do not represent any specific OEM's proprietary manual.

Service Intervals (running hours unless noted)

Equipment	Key PM task	Interval	Critical spare
Boiler Feed Pump	DE thrust bearing	8,000 h	Thrust bearing (long lead)
Boiler Feed Pump	Mechanical seal	16,000 h	Seal cartridge
Boiler Feed Pump	Full overhaul	48,000 h	Rotor kit
Coal Mill	Roll/liner	12,000-18,000 h	Grinding roll
Coal Mill	Gearbox oil	8,000 h	-
ID/FD/PA Fan	Bearing	20,000 h	Fan bearing
CW Pump	Impeller inspection	Annual	Impeller
Turbine-Generator	Major overhaul	~ 4 years	Journal bearing
Generator	RTD / winding check	Annual	RTD set

Note: interval-based PM is superseded by condition-based action when CBM trends breach ISO 10816 alarm zones (see SOP-CBM-0007). This is the core of the predictive strategy.