ASCE 41-23 Tier 1 Checklists

FIRM:	
PROJECT NAME:	
SEISMICITY LEVEL:	
PROJECT NUMBER:	
COMPLETED BY:	
DATE COMPLETED:	
REVIEWED BY:	
REVIEW DATE:	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

Project Name _____

Project Number _____

17.1.1CP Very Low Seismicity Checklist

Table 17-1. Very Low Seismicity Checklist.

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Structural Components							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	LOAD PATH: The structure contains a complete, well-defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation.	5.4.1.1	A.2.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	WALL ANCHORAGE: Exterior concrete or masonry walls that are dependent on the diaphragm for lateral support are anchored for out-of-plane forces at each diaphragm level with steel anchors, reinforcing dowels, or straps that are developed into the diaphragm. Connections have adequate strength to resist the connection force calculated in the Quick Check procedure of Section 4.4.3.7.	5.7.1.1	A.5.1.1	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown