ASCE 41-23 Tier 1 Checklists

FIRM:	
PROJECT NAME:	
SEISMICITY LEVEL:	
PROJECT NUMBER:	
COMPLETED BY:	
DATE COMPLETED:	
REVIEWED BY:	
REVIEW DATE:	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

Project Name _____

Project Number _____

17.1.2CP Basic Configuration Checklist

Table 17-2. Collapse Prevention Basic Configuration Checklist.

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Low Seismicity							
Building System—General							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	LOAD PATH: The structure contains a complete, well-defined load path, including structural elements and connections, that serves to transfer the inertial forces associated with the mass of all elements of the building to the foundation.	5.4.1.1	A.2.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	ADJACENT BUILDINGS: The clear distance between the building being evaluated and any adjacent building is greater than 0.25% of the height of the shorter building in low seismicity, 0.5% in moderate seismicity, and 1.5% in high seismicity.	5.4.1.2	A.2.1.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	MEZZANINES: Interior mezzanine levels are braced independently from the main structure or are anchored to the seismic-force-resisting elements of the main structure.	5.4.1.3	A.2.1.3	
Building System—Building Configuration							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	WEAK STORY: The sum of the shear strengths of the seismic-force-resisting system in any story in each direction is not less than 80% of the strength in the adjacent story above.	5.4.2.1	A.2.2.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	SOFT STORY: The stiffness of the seismic-force-resisting system in any story is not less than 70% of the seismic-force-resisting system stiffness in an adjacent story above or less than 80% of the average seismic-force-resisting system stiffness of the three stories above.	5.4.2.2	A.2.2.3	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	VERTICAL IRREGULARITIES: All vertical elements in the seismic-force-resisting system are continuous to the foundation.	5.4.2.3	A.2.2.4	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	GEOMETRY: There are no changes in the net horizontal dimension of the seismic-force-resisting system of more than 30% in a story relative to adjacent stories, excluding 1-story penthouses and mezzanines.	5.4.2.4	A.2.2.5	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	MASS: There is no change in effective mass of more than 50% from one story to the next. Light roofs, penthouses, and mezzanines need not be considered.	5.4.2.5	A.2.2.6	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

C	NC	N/A	U			
☐	☐	☐	☐	TORSION: The estimated distance between the story center of mass and the story center of rigidity is less than 20% of the building width in either plan dimension. This statement does not apply to buildings with flexible diaphragms.	5.4.2.6	A.2.2.7

Status	Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Moderate Seismicity (Complete the Following Items in Addition to the Items for Low Seismicity)				
Geologic Site Hazards				
C NC N/A U ☐ ☐ ☐ ☐	LIQUEFACTION: Liquefaction-susceptible, saturated, loose granular soils that could jeopardize the building's seismic performance do not exist in the foundation soils at depths within 50 ft (15.2 m) under the building.	5.4.3.1	A.6.1.1	
C NC N/A U ☐ ☐ ☐ ☐	SLOPE FAILURE: The building site is located away from potential earthquake-induced slope failures or rockfalls so that it is unaffected by such failures or is capable of accommodating any predicted movements without failure.	5.4.3.1	A.6.1.2	
C NC N/A U ☐ ☐ ☐ ☐	SURFACE FAULT RUPTURE: Surface fault rupture and surface displacement at the building site are not anticipated.	5.4.3.1	A.6.1.3	

Status	Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
High Seismicity (Complete the Following Items in Addition to the Items for Moderate Seismicity)				
Foundation Configuration				
C NC N/A U ☐ ☐ ☐ ☐	TIES BETWEEN FOUNDATION ELEMENTS: For buildings supported on soils classified as Site Class D, DE, E, or F, the individual pile caps, piles, and piers are restrained by concrete beams or slabs adequate to resist seismic forces. For buildings supported on soils classified as Site Class E or F, individual spread footings are restrained by concrete beams or slabs adequate to resist seismic forces.	5.4.3.4	A.6.2.2	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers