ASCE 41-23 Tier 1 Checklists

FIRM:	
PROJECT NAME:	
SEISMICITY LEVEL:	
PROJECT NUMBER:	
COMPLETED BY:	
DATE COMPLETED:	
REVIEWED BY:	
REVIEW DATE:	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

Project Name _____
Project Number _____

17.13CP Structural Checklist for Building Types C3: Concrete Frames with Infill Masonry Shear Walls and C3a: Concrete Frames with Infill Masonry Shear Walls and Flexible Diaphragms

Table 17-26. Collapse Prevention Structural Checklist for Building Types C3 and C3a.

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Low and Moderate Seismicity							
Seismic-Force-Resisting System							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2.	5.5.1.1	A.3.2.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	SHEAR STRESS CHECK: The shear stress in the reinforced masonry shear walls, calculated using the Quick Check procedure of Section 4.4.3.3 is less than 70 lb/in.^{2} (0.48 MPa).	5.5.3.1.1	A.3.2.4.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	SHEAR STRESS CHECK: The shear stress in the unreinforced masonry shear walls, calculated using the Quick Check procedure of Section 4.4.3.3 is less than 30 lb/in.^{2} (0.21 MPa) for clay units and 70 lb/in.^{2} (0.48 MPa) for concrete units. Bays with openings greater than 25% of the wall area shall not be included in A_w of Equation (4-8).	5.5.3.1.1	A.3.2.5.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	INFILL WALL CONNECTIONS: Masonry is in full contact with frame.	5.5.3.5.1 5.5.3.5.3	A.3.2.6.1	
Connections							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	TRANSFER TO SHEAR WALLS: Diaphragms are connected for transfer of loads to the shear walls.	5.7.2	A.5.2.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	CONCRETE COLUMNS: All concrete columns are doweled into the foundation with a minimum of four bars.	5.7.3.1	A.5.3.2	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

Project Name _____
Project Number _____

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
High Seismicity (Complete the Following Items in Addition to the Items for Low and Moderate Seismicity)							
Seismic-Force-Resisting System							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	DEFLECTION COMPATIBILITY: Secondary components have the shear capacity to develop the flexural strength of the components.	5.5.2.5.2	A.3.1.6.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	FLAT SLABS: Flat slabs or plates not part of the seismic-force-resisting system have continuous bottom steel through the column joints.	5.5.2.5.3	A.3.1.6.3	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	PROPORTIONS: The height-to-thickness ratio of the unreinforced infill walls at each story is less than 9.	5.5.3.1.2	A.3.2.6.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	CAVITY WALLS: The infill walls are not of cavity construction.	5.5.3.5.2	A.3.2.6.3	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	INFILL WALLS: The infill walls are continuous to the soffits of the frame beams and to the columns to either side.	5.5.3.5.3	A.3.2.6.4	
Diaphragms (Stiff or Flexible)							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	DIAPHRAGM CONTINUITY: Floor and roof diaphragms do not have expansion joints or vertical offsets, such as split levels, sawtooth, or clerestory configurations.	5.6.1.1	A.4.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	OPENINGS AT SHEAR WALLS: Diaphragm openings immediately adjacent to the shear walls are less than 25% of the wall length.	5.6.1.3	A.4.1.4	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	OPENINGS AT EXTERIOR MASONRY SHEAR WALLS: Diaphragm openings immediately adjacent to exterior masonry shear walls are not greater than 8 ft (2.4 m) long.	5.6.1.3	A.4.1.6	
Flexible Diaphragms							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	CROSSTIES: There are continuous crossties between diaphragm chords.	5.6.1.2	A.4.1.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	STRAIGHT SHEATHING: All straight-sheathed diaphragms have horizontal spans less than 24 ft (7.3 m) and aspect ratios less than 2-to-1 in the direction being considered.	5.6.2	A.4.2.1	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

C	NC	N/A	U			
☐	☐	☐	☐	DIAGONALLY SHEATHED AND UNBLOCKED DIAPHRAGMS: All diagonally sheathed or unblocked wood structural panel diaphragms have horizontal spans less than 40 ft (12.2 m) and aspect ratios less than or equal to 4-to-1.	5.6.2	A.4.2.2
C	**NC**	**N/A**	**U**	BLOCKED DIAPHRAGMS: All blocked wood structural panel diaphragms have horizontal spans less than 120 ft (36.5 m) and have aspect ratios less than or equal to 4-to-1.	5.6.2	A.4.2.3
☐	☐	☐	☐			
C	**NC**	**N/A**	**U**	CANTILEVERED WOOD DIAPHRAGMS: All cantilevered wood diaphragms that provide lateral support for concrete or masonry walls consist of wood structural panels and have a maximum cantilever length of 20 ft (6.1 m) if unblocked or 35 ft (10.7 m) if blocked, and a maximum ratio of cantilever length to diaphragm width of 1:2 if unblocked and 1:1 if blocked. In addition, the cantilevered diaphragm has a back-span length equal to or greater than the cantilevered portion.	5.6.2	A.4.2.4
☐	☐	☐	☐			
C	**NC**	**N/A**	**U**	NON-CONCRETE-FILLED DIAPHRAGMS: Bare steel deck diaphragms or steel deck diaphragms with fill other than reinforced structural concrete consist of horizontal spans of less than 120 ft (36.5 m) and have aspect ratios less than 4-to-1.	5.6.3	A.4.3.1
☐	☐	☐	☐			
C	**NC**	**N/A**	**U**	OTHER DIAPHRAGMS: Diaphragms do not consist of a system other than wood, steel deck, concrete, or horizontal bracing.	5.6.5	A.4.7.1
☐	☐	☐	☐			
Connections						
C	**NC**	**N/A**	**U**	UPLIFT AT PILE CAPS: Pile caps have top reinforcement, and piles are anchored to the pile caps.	5.7.3.5	A.5.3.8
☐	☐	☐	☐			
C	**NC**	**N/A**	**U**	STIFFNESS OF WALL ANCHORS: Anchors of concrete or masonry walls to wood structural elements are installed taut and are stiff enough to limit the relative movement between the wall and the diaphragm to no greater than 1/8 in. (3.1 mm) before engagement of the anchors.	5.7.1.2	A.5.1.4
☐	☐	☐	☐			

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown