ASCE 41-23 Tier 1 Checklists

FIRM:	
PROJECT NAME:	
SEISMICITY LEVEL:	
PROJECT NUMBER:	
COMPLETED BY:	
DATE COMPLETED:	
REVIEWED BY:	
REVIEW DATE:	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

Project Name _____
Project Number _____

17.10IO Structural Checklist for Building Type CFS2: Cold-formed Steel Lightframe Bearing Wall Construction, Strap-Braced Lateral Wall System

Table 17-21. Immediate Occupancy Structural Checklist for Building Type CFS2.

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Very Low Seismicity							
Seismic-Force-Resisting System							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	REDUNDANCY: The number of lines of strap-braced walls in each principal direction is greater than or equal to 2.	5.5.1.1	A.3.2.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	STRAP-BRACED WALLS—BRACE AXIAL STRESS CHECK: The axial stress in the diagonal straps, calculated using the Quick Check procedure of Section 4.4.3.4 is less than $0.50F_y$.	5.5.4.1	A.3.3.1.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	STRAP-BRACED WALLS—CHORD STUD AXIAL CHECK: The axial force caused by overturning plus the gravity load on the end stud is less than the nominal strength of the end stud calculated in accordance with AISI S100.	5.5.4.9.5	A.3.3.2.9	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	NARROW STRAP-BRACED WALLS: Narrow strap-braced walls with an aspect ratio greater than 2-to-1 are not used to resist seismic forces.	5.5.4.9.1	A.3.3.2.5	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	WALLS CONNECTED THROUGH FLOORS: Strap-braced walls have an interconnection between stories to transfer overturning and shear forces through the floor.	5.5.4.9.2	A.3.3.2.6	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	HILLSIDE SITE: For structures that are taller on at least one side by more than one-half story because of a sloping site, all strap-braced walls on the downhill slope have an aspect ratio less than 1-to-2.	5.5.4.9.3	A.3.3.2.7	
Connections							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	POSTS: There is a positive connection of posts to the foundation.	5.7.3.3	A.5.3.3	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	SILLS (BASE TRACK): All sills or base tracks are bolted to the foundation.	5.7.3.3	A.5.3.4	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	GIRDER–COLUMN CONNECTION: There is a positive connection using plates, connection hardware, or straps between the girder and the column support.	5.7.4.1	A.5.4.1	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

Project Name _____
Project Number _____

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Low, Moderate, and High Seismicity (Complete the Following Items in Addition to the Items for Very Low Seismicity)							
Seismic-Force-Resisting System							
C	**NC**	**N/A**	**U**	HOLD-DOWN ANCHORS: All strap-braced walls have hold-down anchors attached to the end studs, constructed in accordance with acceptable construction practices.	5.5.3.6.6	A.3.3.2.8	
Diaphragms							
C	**NC**	**N/A**	**U**	DIAPHRAGM CONTINUITY: Floor and roof diaphragms do not have expansion joints or vertical offsets, such as split levels, sawtooth, or clerestory configurations.	5.6.1.1	A.4.1.1	
C	**NC**	**N/A**	**U**	ROOF CHORD CONTINUITY: All chord elements are continuous, regardless of changes in roof elevation.	5.6.1.1	A.4.1.3	
C	**NC**	**N/A**	**U**	PLAN IRREGULARITIES: There is tensile capacity to develop the strength of the diaphragm at reentrant corners or other locations of plan irregularities.	5.6.1.4	A.4.1.7	
C	**NC**	**N/A**	**U**	DIAPHRAGM REINFORCEMENT AT OPENINGS: There is reinforcing around all diaphragm openings larger than 50% of the building width in either major plan dimension.	5.6.1.5	A.4.1.8	
C	**NC**	**N/A**	**U**	SPANS: All diaphragms with spans greater than 12 ft (3.6 m) consist of wood structural panels.	5.6.2	A.4.2.2	
C	**NC**	**N/A**	**U**	UNBLOCKED DIAPHRAGMS: All unblocked wood structural panel diaphragms have horizontal spans less than 30 ft (9.1 m) and aspect ratios less than or equal to 3-to-1.	5.6.2	A.4.2.2	
C	**NC**	**N/A**	**U**	OTHER DIAPHRAGMS: Diaphragms do not consist of a system other than wood, steel deck, concrete, or horizontal bracing.	5.6.5	A.4.7.1	
Connections							
C	**NC**	**N/A**	**U**	SILL (BASE TRACK) BOLTS: Sill or base track bolts are spaced at 4 ft (1.2 m) or less, with acceptable edge and end distance provided for steel and concrete.	5.7.3.3	A.5.3.7	
C	**NC**	**N/A**	**U**	STRAP-BRACE CONNECTIONS: Strap connections develop the yield capacity of the straps.	5.5.4.4	A.3.3.1.5	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

C	NC	N/A	U			
☐	☐	☐	☐	STRAP-BRACE DETAILING: Strap braces are tight to the stud and attached to the intermediate studs in accordance with the requirements of AISI S400.	5.5.4.9.6	A.3.3.2.10

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown