ASCE 41-23 Tier 1 Checklists

FIRM:	
PROJECT NAME:	
SEISMICITY LEVEL:	
PROJECT NUMBER:	
COMPLETED BY:	
DATE COMPLETED:	
REVIEWED BY:	
REVIEW DATE:	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers

Project Name _____
Project Number _____

17.9IO Structural Checklist for Building Type CFS1: Cold-formed Steel Lightframe Bearing Wall Construction, Shear Wall Lateral System

Table 17-19. Immediate Occupancy Structural Checklist for Building Type CFS1.

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
Very Low Seismicity							
Seismic-Force-Resisting System							
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	REDUNDANCY: The number of lines of shear walls in each principal direction is greater than or equal to 2.	5.5.1.1	A.3.2.1.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	SHEAR STRESS CHECK: The shear stress in the shear walls, calculated using the Quick Check procedure of Section 4.4.3.3 is less than the following values: Wood structural panel sheathing 1,000 lb/ft (14.6 kN/m), Steel sheet sheathing 700 lb/ft (10.2 kN/m), and All other conditions 100 lb/ft (1.5 kN/m).	5.5.3.1.1	A.3.2.8.1	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	STUCCO (EXTERIOR PLASTER) SHEAR WALLS: Multistory buildings do not rely on exterior stucco walls as the primary seismic-force-resisting system.	5.5.3.7.1	A.3.2.8.2	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	GYPSUM WALLBOARD OR PLASTER SHEAR WALLS: Interior plaster or gypsum wallboard is not used for shear walls on buildings more than one story high with the exception of the uppermost level of a multistory building.	5.5.3.7.1	A.3.2.8.3	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	NARROW SHEAR WALLS: Narrow shear walls with an aspect ratio greater than 2-to-1 are not used to resist seismic forces.	5.5.3.7.1	A.3.2.8.4	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	WALLS CONNECTED THROUGH FLOORS: Shear walls have an interconnection between stories to transfer overturning and shear forces through the floor.	5.5.3.7.2	A.3.2.8.5	
C ☐	**NC** ☐	**N/A** ☐	**U** ☐	HILLSIDE SITE: For structures that are taller on at least one side by more than one-half story because of a sloping site, all shear walls on the downhill slope have an aspect ratio less than 1-to-2.	5.5.3.7.3	A.3.2.8.6	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

Status				Evaluation Statement	Tier 2 Reference	Commentary Reference	Comments
C	NC	N/A	U	OPENINGS: Walls with openings greater than 80% of the length are braced with wood structural panel or steel sheet shear walls with aspect ratios of not more than 1.5-to-1 or are supported by adjacent construction through positive ties capable of transferring the seismic forces.	5.5.3.7.5	A.3.2.8.8	
Connections							
C	NC	N/A	U	POSTS: There is a positive connection of posts to the foundation.	5.7.3.3	A.5.3.3	
C	NC	N/A	U	SILLS (BASE TRACK): All sills or base tracks are bolted to the foundation.	5.7.3.3	A.5.3.4	
C	NC	N/A	U	GIRDER–COLUMN CONNECTION: There is a positive connection using plates, connection hardware, or straps between the girder and the column support.	5.7.4.1	A.5.4.1	
Low, Moderate, and High Seismicity (Complete the Following Items in Addition to the Items for Very Low Seismicity)							
Seismic-Force-Resisting System							
C	NC	N/A	U	HOLD-DOWN ANCHORS: All shear walls have hold-down anchors attached to the end studs, constructed in accordance with acceptable construction practices.	5.5.3.7.6	A.3.2.8.9	
C	NC	N/A	U	NARROW SHEAR WALLS: Narrow shear walls with an aspect ratio greater than 1.5-to-1 are not used to resist seismic forces.	5.5.3.7.1	A.3.2.8.4	
Diaphragms							
C	NC	N/A	U	DIAPHRAGM CONTINUITY: Floor and roof diaphragms do not have expansion joints or vertical offsets, such as split levels, sawtooth, or clerestory configurations.	5.6.1.1	A.4.1.1	
C	NC	N/A	U	ROOF CHORD CONTINUITY: All chord elements are continuous, regardless of changes in roof elevation.	5.6.1.1	A.4.1.3	
C	NC	N/A	U	PLAN IRREGULARITIES: There is tensile capacity to develop the strength of the diaphragm at reentrant corners or other locations of plan irregularities.	5.6.1.4	A.4.1.7	
C	NC	N/A	U	DIAPHRAGM REINFORCEMENT AT OPENINGS: There is reinforcing around all diaphragm openings larger than 50% of the building width in either major plan dimension.	5.6.1.5	A.4.1.8	

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

C	**NC**	**N/A**	**U**	SPANS: All diaphragms with spans greater than 12 ft (3.6 m) consist of wood structural panels.	5.6.2	A.4.2.2
C	**NC**	**N/A**	**U**	UNBLOCKED DIAPHRAGMS: All unblocked wood structural panel diaphragms have horizontal spans less than 30 ft (9.1 m) and aspect ratios less than or equal to 3-to-1.	5.6.2	A.4.2.2
C	**NC**	**N/A**	**U**	OTHER DIAPHRAGMS: Diaphragm do not consist of a system other than wood, steel deck, concrete, or horizontal bracing.	5.6.5	A.4.7.1
Connections						
C	**NC**	**N/A**	**U**	SILL (BASE TRACK) BOLTS: Sill or base track bolts are spaced at 4 ft (1.2 m) or less, with acceptable edge and end distance provided for steel and concrete.	5.7.3.3	A.5.3.7

Legend: C = Compliant, NC = Noncompliant, N/A = Not Applicable, U = Unknown

© 2023 American Society of Civil Engineers