









LEGEND:

SYMBOL	DESCRIPTION
	400 A TPN ISOLATING SWITCH
	TANENT METER
	W/P SOCKET IN FLOOR BOX
	SMOKE DETECTOR
	CEILING RECESSED VOICE EVACUATION SPEAKER
	HEAT DETECTOR
	INTERFACE TO GAS DETECTION SYSTEM
	ICP DATA CABINET 12U WALL MOUNT

S.NO	DESCRIPTION	LOAD IN K.W
1	LIGHT, POWER & EQUIPMENT	131.5 K.W
2	AHU-G-0088A AHU-G-0088K MUA-G-0088A KEF-G-0088A	2.2 K.W 1.1 K.W 3 K.W 2.2 K.W
TOTAL LOAD		140.00 K.W

GENERAL NOTES:

01. 25mmØ CONDUIT TO BE LAID FROM EACH F&B UNIT ELECTRICAL PANEL LOCATION TO KEF LOCATION ON ROOF FOR ELECTRICAL SUPPLY TO KEF.
02. 25mmØ CONDUIT WITH DRAW WIRE TO BE LAID FROM THE TENANT DB LOCATION TO BACK BOX PROVIDED IN OUT SIDE SEATING AREA FOR TENANT USE. BACKBOX PROVIDED IS FOR FUTURE SOCKET BY TENANT.

NOTES:

01. ISOLATOR WILL BE LOCATED AT HIGH LEVEL ABOVE FALSE CEILING
02. IDF SYSTEMS AS PER DESIGN DRAWINGS

KEY PLAN



NOTES

1. DRAWINGS DIMENSIONS ARE TO BE READ, NOT TO BE SOLID.
2. ARCHITECTURAL DRAWING MUST BE SEEN IN CONJUNCTION WITH ALL OTHER SERVICE DRAWINGS AND CONTRACT DOCUMENTS AND IN CASE OF ANY DISCREPANCIES, FIRST BETWEEN THESE DRAWINGS AND CONTRACT DOCUMENTS, THEN BETWEEN THESE DRAWINGS REPORTED TO THE ENGINEER BEFORE THE COMMENCEMENT OF ANY WORK ON SITE.
3. ALL THE LEVELS AND DIMENSIONS MUST BE CHECKED AND VERIFIED BY THE MAIN CONTRACTOR BEFORE THE COMMENCEMENT OF THE WORK ON THE SITE OR THE PREPARATION OF THE SHAP DRAWINGS.
4. THE INSPECTOR'S EXTERNAL PAVING SUPPORT (CONCRETE) MUST STRICTLY COMPLY WITH THE OWNER'S REQUIREMENTS AND DIRECTIONS.
5. NO CHANGES AND/OR PERTURBATIONS OF ANY DESCRIPTION WILL BE PERMITTED TO THE OWNER-PROVIDED EXTERNAL CLASS SHIP FRONTS.
6. SUPPLY, STORAGE AND PROTECTION OF EXPANSION JOINT COVERS AND RELATED ACCESSORIES INSIDE ALL WEATHER SPACES MUST BE THE RESPONSIBILITY OF THE MAIN CONTRACTOR. THE INSPECTION AND INSTALLATION OF THE WEATHER BARRIER, THE BARRIER & INSULATION DRIVE ESSENTIAL WILL BE BY THE OWNER.
7. THIS DRAWING IS INDICATIVE ONLY, NOT TO BE USED FOR CONSTRUCTION,) AND IS ACCURATE AS AT THE DATE SHOWN ON THE DRAWING.
8. THIS DRAWING IS SUBJECT TO CHANGE AS PLANNING, DEVELOPMENT AND CONSTRUCTION CONTINUES THROUGHOUT, OPENING OF THE RESPONSIBILITY.
9. IT IS THE RESPONSIBILITY OF THE INSPECTOR OF THIS DRAWING TO UPDATE THEMSELVES WITH ANY SUBSEQUENT REVIEWS, UPDATES, ADDITIONS, DELETIONS AND/OR SUBSTITUTIONS.
10. IT IS THE RESPONSIBILITY OF THE INSPECTOR TO UNDERWAKE AN ON-SITE MEASURE TO VERIFY ALL DIMENSIONS SHOWN ON THIS DRAWING.
11. UNDETAILED REAL ESTATE CO. DOES NOT ACCEPT ANY LIABILITY OF THIS DRAWING OR THE INSPECTOR'S USE AND/OR INTERPRETATION OF THE DRAWING.
12. THE ANCHOR BOLT SIZE USED FOR ANY LOADING SUPPORTING STRUCTURE SHALL NOT EXCEED MORE THAN 16mm DEPTH TO AVOID ANY DAMAGE THAT MAY CAUSED IN THE MEMBRANE DUE TO CONDUIT.

FOR REVIEW

OWNER

تجدید
TAMDEEN
GROUP

PROJECT TITLE

Al Khiran Outlet Mall

CONSULTANTS

cracknell SSH

DESIGN ARCHITECT

CALLISONRTKL
A DESIGN CONSULTANCY OF ARCADIS

ENGINEER OF RECORD



MANAGED BY
TAMDEEN
MAIL MANAGEMENT
TAMDEEN MAIL MANAGEMENT CO. K.S.C.
P.O. BOX: 20060 SAFAT 13151, KUWAIT
TEL: +965 25362330
FAX: +965 25362360
WWW.TAMDEENMAILS.COM

DRAWING TITLE:

GROUND FLOOR RESTAURANT - ELEC PLAN

UNIT NO.	G-103	
USAGE:	RESTAURANT	
TRADE	SCALE	DATE
ELEC	1:50 @ A1	DEC 2020
DRAWN BY	CHECKED BY	APPROVED BY
--	M.RAMADAN	--
DRAWING No.	OF	REV.
E-01	05 OF 09	01