


FIRE LEGEND	
FHC-1 * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	INTERNAL FIRE HOSE CABINET (RECESSED) WITH A.) 1 NO. HOSE REEL B.) 02 1/2" LANDING VALVE WITH CANVAS C.) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. D.) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-2 * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	EXTERNAL FREE STANDING FIRE HOSE CABINET A.) 1 NO. HOSE REEL B.) 02 1/2" LANDING VALVE WITH CANVAS C.) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. D.) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-A * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	FIRE HOSE CABINET (RECESSED) WITH A.) 1 NO. HOSE REEL B.) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. C.) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-B * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	EXTERNAL FREE STANDING FIRE HOSE CABINET WITH A.) 1 NO. HOSE REEL B.) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. C.) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
ACV	AUTOMATIC CONTROL VALVE (ACV)
FCV	FLOW CONTROL STATION WITH P.R.V.
BVS	BUTTERFLY VALVE SUPERVISED (BVS)
US	UPRIGHT TYPE SPRINKLER
QRS	QUICK RESPONSE TYPE SPRINKLER
PS	PENDANT SPRINKLER
UPS	UPRIGHT AND PENDANT SPRINKLER
SWQRS	SIDE WALL QUICK RESPONSE TYPE SPRINKLER
6kg	6kg. MULTI PURPOSE DRY POWDER EXTING.
USP	UPRIGHT SPRINKLER ONLY & PENDANT SPRINKLER TO BE PROVIDED BY TENANT



- NOTES
1. DRAWINGS DIMENSIONS ARE TO BE READ NOT TO BE SCALED.
 2. ARCHITECTURAL DRAWING MUST BE READ IN CONJUNCTION WITH ALL OTHER SERVICE DRAWINGS AND CONTRACT DOCUMENTS AND IN CASE OF ANY DISCREPANCIES ARISE BETWEEN THESE DRAWINGS AND ANY OF THE DOCUMENTS THEY SHOULD BE IMMEDIATELY REPORTED TO THE ENGINEER BEFORE THE COMMENCEMENT OF ANY WORK ON SITE.
 3. ALL THE LEVELS AND DIMENSIONS MUST BE CHECKED AND VERIFIED BY THE MAIN CONTRACTOR BEFORE THE COMMENCEMENT OF ANY ITEM OF WORK ON THE SITE OR THE PREPARATION OF THE SHOP DRAWINGS.
 4. THE INVESTOR'S EXTERNAL FACING SHOPFRONT SIGNAGE (IF ANY) MUST STRICTLY COMPLY WITH THE OWNER'S REQUIREMENTS AND DIRECTIONS.
 5. NO CHANGES AND/OR PENETRATIONS OF ANY DESCRIPTION WILL BE PERMITTED TO THE OWNER - PROVIDED EXTERNAL GLASS SHOP FRONTS.
 6. SUPPLY, STORAGE AND PROTECTION OF EXPANSION JOINT COVERS AND RELATED ACCESSORIES INSIDE ALL INVESTOR SPACES IS BY THE OWNER. INSTALLATION OF THE SAME WILL BE BY THE INVESTOR. SUPPLY AND INSTALLATION OF THE VAPOR BARRIER, FIRE BARRIER & INSULATION DRAPE ASSEMBLY WILL BE BY THE OWNER.
 7. THIS DRAWING IS INDICATIVE ONLY (NOT TO BE USED FOR CONSTRUCTION) AND IS ACCURATE AS AT THE DATE SHOWN ON THE DRAWING.
 8. THIS DRAWING IS SUBJECT TO CHANGE AS PLANNING, DEVELOPMENT AND CONSTRUCTION CONTINUES THROUGH UNTIL OPENING OF THE CENTRE.
 9. IT IS THE RESPONSIBILITY OF THE RECIPIENT OF THIS DRAWING TO UPDATE THEMSELVES WITH ANY SUBSEQUENT REVIEWS, UPDATES, ADDITIONS, DELETIONS AND /OR SUBSTITUTIONS.
 10. IT IS THE RESPONSIBILITY OF THE INVESTOR TO UNDERTAKE AN ON-SITE MEASURE TO VERIFY ALL DIMENSIONS SHOWN ON THIS DRAWING
 11. TAMDEEN REAL ESTATE CO. DOES NOT ACCEPT ANY LIABILITY OF ANY FORM FOR THE RECIPIENT'S USE AND/OR INTERPRETATION OF THIS DRAWING
 12. THE ANCHOR BOLT SIZE USED FOR ANY FLOORING SUPPORTING SYSTEM SHOULD NOT EXCEED MORE THAN 8mm DEPTH TO AVOID ANY DAMAGE THAT MAY CAUSED IN THE IMBEDDED PVC CONDUIT.

FOR REVIEW

OWNER

تمدين
TAMDEEN
GROUP

PROJECT TITLE

Al Khiran Outlet Mall

CONSULTANTS

cracknell SSH

DESIGN ARCHITECT

CALLISONRTKL
A DESIGN CONSULTANCY OF ARCADIS

ENGINEER OF RECORD

مطعم ومقهى
OHA ENGINEERING CONSULTANT
P.O. Box 6249 HAWALLI, CODE NO. 32027 - KUWAIT
PHONE: 22402058 - 22405519 FAX: 22455511
E-mail oha@daroha.com

MANAGED BY

تمدين
TAMDEEN MALL MANAGEMENT CO. K.S.C.C
P.O. BOX: 29060 SAFAT 13151, KUWAIT
TEL: +965 25362330
FAX: +965 25362360
WWW.TAMDEENMALLS.COM

DRAWING TITLE: GROUND FLOOR
RETAIL
FIRE PROTECTION SYSTEM

UNIT NO.	G-25	
USAGE.	RETAIL	
TRADE	SCALE	DATE
MECH	1:50 @ A1	MAY 2020
DRAWN BY	CHECKED BY	APPROVED BY
--	--	--
DRAWING No.	OF	REV.
FP-01	07 OF 07	00