


LEGEND:-

CWS	COLD WATER SUPPLY
PRV	PRESSURE REDUCING VALVE
PAV	PRESSURE AVOIDING VALVE
FA	FROM ABOVE
FB	FROM BELOW
TA	TO ABOVE
TB	TO BELOW
HL	HIGH LEVEL
LL	LOW LEVEL
PHL	FROM HIGH LEVEL
PVL	FROM LOW LEVEL
TAL	TO HIGH LEVEL
TBL	TO LOW LEVEL
LL	INVERT LEVEL OF PIPE
GV	GATE VALVE
WM	WATER METER
F.F.L	FINISH FLOOR LEVEL
S.S.L	STRUCTURE SLAB LEVEL



- NOTES
1. DRAWINGS DIMENSIONS ARE TO BE READ NOT TO BE SCALED.

2. ARCHITECTURAL DRAWING MUST BE READ IN CONJUNCTION WITH ALL OTHER SERVICE DRAWINGS AND CONTRACT DOCUMENTS AND IN CASE OF ANY DISCREPANCIES ARISE BETWEEN THESE DRAWINGS THE CONTRACT DOCUMENTS SHALL PREVAIL.

3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE COMMENCEMENT OF ANY WORK ON SITE.

4. ALL THE LEVELS AND DIMENSIONS MUST BE CHECKED AND VERIFIED BY THE MAIN CONTRACTOR BEFORE THE COMMENCEMENT OF ANY ITEM OF WORK ON THE SITE OR THE PREPARATION OF THE SHOP DRAWINGS.

5. THE INVESTOR'S EXTERNAL FACING SHOPFRONT SIGNAGE (IF ANY) MUST STRICTLY COMPLY WITH THE OWNER'S REQUIREMENTS AND DIRECTIONS.

6. NO CHANGES AND/OR PENETRATIONS OF ANY DESCRIPTION WILL BE PERMITTED TO THE OWNER- PROVIDED EXTERNAL GLASS SHOP FRONTS.

7. SUPPLY, STORAGE AND PROTECTION OF EXPANSION JOINT COVERS AND RELATED ACCESSORIES INSIDE ALL INVESTOR SPACES IS BY THE OWNER. INSTALLATION OF THE SAME WILL BE BY THE INVESTOR. SUPPLY AND INSTALLATION OF THE VAPOR BARRIER, FIRE BARRIER & INSULATION DRAPE ASSEMBLY WILL BE BY THE OWNER.

8. THIS DRAWING IS INDICATIVE ONLY ( NOT TO BE USED FOR CONSTRUCTION ) AND IS ACCURATE AS AT THE DATE SHOWN ON THE DRAWING.

9. THIS DRAWING IS SUBJECT TO CHANGE AS PLANNING, DEVELOPMENT AND CONSTRUCTION CONTINUES THROUGH UNTIL OPENING OF THE CENTRE.

10. IT IS THE RESPONSIBILITY OF THE RECIPIENT OF THIS DRAWING TO UPDATE THEMSELVES WITH ANY SUBSEQUENT REVIEWS, UPDATES, ADDITIONS, DELETIONS AND /OR SUBSTITUTIONS.

11. IT IS THE RESPONSIBILITY OF THE INVESTOR TO UNDERTAKE AN ON-SITE MEASURE TO VERIFY ALL DIMENSIONS SHOWN ON THIS DRAWING.

12. TAMDEEN REAL ESTATE CO. DOES NOT ACCEPT ANY LIABILITY OF ANY FORM FOR THE RECIPIENT'S USE AND/OR INTERPRETATION OF THIS DRAWING.

13. THE ANCHOR BOLT SIZE USED FOR ANY FLOORING SUPPORTING SYSTEM SHOULD NOT EXCEED MORE THAN 8mm DEPTH TO AVOID ANY DAMAGE THAT MAY CAUSED IN THE IMBEDDED PVC CONDUIT.

FOR REVIEW

OWNER

TAMDEEN GROUP

PROJECT TITLE

Al Khiran Outlet Mall


CONSULTANTS

cracknell SSH

DESIGN ARCHITECT


CALLISONRTKL  
A DESIGN CONSULTANCY OF ARCADIS

ENGINEER OF RECORD



OHA ENGINEERING CONSULTANT  
P.O. BOX 194444 JALALIYAH CODE 103207 - KUWAIT  
PHONE 2242009 - 2242018 FAX 2242011  
Email: oha@oha.com.kw

MANAGED BY



TAMDEEN MALL MANAGEMENT CO. K.S.C.C  
P.O. BOX: 25060 SAFAT 13151, KUWAIT  
TEL: +965 25362330  
FAX: +965 25362331  
WWW.TAMDEENMALLS.COM

DRAWING TITLE:

GROUND ANCHOR WATER SUPPLY SYSTEM PLAN

DRAWING No.

WS-01

OF

7

REV.

00

UNIT NO.

G-01

USAGE.

ANCHOR

TRADE

SCALE

DATE

MECH.

1:100 @ A0

JAN 2020

DRAWN BY

CHECKED BY

APPROVED BY

---

---

---