


FIRE LEGEND	
FHC-1 * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	INTERNAL FIRE HOSE CABINET (RECESSED) WITH A) 1 NO. HOSE REEL B) 1/2" LANDING VALVE WITH CANVAS C) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. D) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-2 * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	EXTERNAL FREE STANDING FIRE HOSE CABINET A) 1 NO. HOSE REEL B) 1/2" LANDING VALVE WITH CANVAS C) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. D) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-A * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	FIRE HOSE CABINET (RECESSED) WITH A) 1 NO. HOSE REEL B) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. C) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
FHC-B * REFER TO DETAIL DRG. FOR FIRE HOSE CABINET SIZE	EXTERNAL FREE STANDING FIRE HOSE CABINET WITH A) 1 NO. HOSE REEL B) 6 kg. MULTI PURPOSE DRY POWDER FIRE EXTING. C) 2 GALLONS WATER/GAS FIRE EXTINGUISHER
	AUTOMATIC CONTROL VALVE (ACV)
	FLOW CONTROL STATION WITH P.R.V.
	BUTTERFLY VALVE SUPERVISED (BVS)
	UPRIGHT TYPE SPRINKLER
	QUICK RESPONSE TYPE SPRINKLER
	PENDANT SPRINKLER
	UPRIGHT AND PENDANT SPRINKLER
	SIDE WALL QUICK RESPONSE TYPE SPRINKLER
	6kg. MULTI PURPOSE DRY POWDER EXTING.
	UPRIGHT SPRINKLER ONLY & PENDANT SPRINKLER TO BE PROVIDED BY TENANT



- NOTES
1. DRAWINGS DIMENSIONS ARE TO BE READ NOT TO BE SCALED.
  2. ARCHITECTURAL DRAWING MUST BE READ IN CONJUNCTION WITH ALL OTHER SERVICE DRAWINGS AND CONTRACT DOCUMENTS AND IN CASE OF ANY DISCREPANCIES ARISE BETWEEN THESE DRAWINGS AND ANY OF THE DOCUMENTS THEY SHOULD BE IMMEDIATELY REPORTED TO THE ENGINEER BEFORE THE COMMENCEMENT OF ANY WORK ON SITE.
  3. ALL THE LEVELS AND DIMENSIONS MUST BE CHECKED AND VERIFIED BY THE MAIN CONTRACTOR BEFORE THE COMMENCEMENT OF ANY ITEM OF WORK ON THE SITE OR THE PREPARATION OF THE SHOP DRAWINGS.
  4. THE INVESTOR'S EXTERNAL FACING SHOPFRONT SIGNAGE (IF ANY) MUST STRICTLY COMPLY WITH THE OWNER'S REQUIREMENTS AND DIRECTIONS.
  5. NO CHANGES AND/OR PENETRATIONS OF ANY DESCRIPTION WILL BE PERMITTED TO THE OWNER- PROVIDED EXTERNAL GLASS SHOP FRONTS.
  6. SUPPLY, STORAGE AND PROTECTION OF EXPANSION JOINT COVERS AND RELATED ACCESSORIES INSIDE ALL INVESTOR SPACES IS BY THE OWNER. INSTALLATION OF THE SAME WILL BE BY THE INVESTOR. SUPPLY AND INSTALLATION OF THE VAPOR BARRIER, FIRE BARRIER & INSULATION DRAPE ASSEMBLY WILL BE BY THE OWNER.
  7. THIS DRAWING IS INDICATIVE ONLY ( NOT TO BE USED FOR CONSTRUCTION ) AND IS ACCURATE AS AT THE DATE SHOWN ON THE DRAWING.
  8. THIS DRAWING IS SUBJECT TO CHANGE AS PLANNING, DEVELOPMENT AND CONSTRUCTION CONTINUES THROUGH UNTIL OPENING OF THE CENTRE.
  9. IT IS THE RESPONSIBILITY OF THE RECIPIENT OF THIS DRAWING TO UPDATE THEMSELVES WITH ANY SUBSEQUENT REVIEWS, UPDATES, ADDITIONS, DELETIONS AND /OR SUBSTITUTIONS.
  10. IT IS THE RESPONSIBILITY OF THE INVESTOR TO UNDERTAKE AN ON-SITE MEASURE TO VERIFY ALL DIMENSIONS SHOWN ON THIS DRAWING
  11. TAMDEEN REAL ESTATE CO. DOES NOT ACCEPT ANY LIABILITY OF ANY FORM FOR THE RECIPIENT'S USE AND/OR INTERPRETATION OF THIS DRAWING
  12. THE ANCHOR BOLT SIZE USED FOR ANY FLOORING SUPPORTING SYSTEM SHOULD NOT EXCEED MORE THAN 8mm DEPTH TO AVOID ANY DAMAGE THAT MAY CAUSED IN THE IMBEDDED PVC CONDUIT.

#### FOR REVIEW

OWNER

تمدين  
**TAMDEEN**  
GROUP

PROJECT TITLE

Al Khiran Outlet Mall

CONSULTANTS

cracknell SSH

DESIGN ARCHITECT

**CALLISON|TKL**  
A DESIGN CONSULTANCY OF ARCADIS

ENGINEER OF RECORD

مطعم ومقهى  
**OHA ENGINEERING CONSULTANT**  
P.O. Box 6249 HAWALLI, CODE NO. 32027 - KUWAIT  
PHONE: 22402058 - 22405119 FAX: 22435511  
E-mail oha@daroha.com

MANAGED BY

تمدين  
**TAMDEEN**  
MALL MANAGEMENT  
TAMDEEN MALL MANAGEMENT CO. K.S.C.C.  
P.O. BOX: 29060 SAFAT 13151, KUWAIT  
TEL: +965 25362330  
FAX: +965 25362360  
WWW.TAMDEENMALLS.COM

DRAWING TITLE: **GROUND FLOOR  
RESTAURANT  
FIRE PROTECTION SYSTEM**

UNIT NO.	G-118	
USAGE.	RESTAURANT	
TRADE	SCALE	DATE
MECH	1:50 @ A1	MAY 2020
DRAWN BY	CHECKED BY	APPROVED BY
--	--	--
DRAWING No.	OF	REV.
FP-01	08 OF 09	01